

NOV 20 1977

Docket No. 50-340

Toledo Edison Company
ATTN: Mr. Lowell E. Roe
Vice President, Facilities
Development
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

POOR
ORIGINAL

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NO. 7 TO FACILITY OPERATING LICENSE
NO. NPF-3 FOR DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

The Nuclear Regulatory Commission has issued the enclosed Amendment
No. 7 to Facility Operating License No. NPF-3 which is effective as of
the date of issuance.

Amendment No. 7 revises license condition 2.C.(3)(k) by removing the
stipulation within 2.C.(3)(k) for providing acceptable noise test
procedures within four (4) months from date of issuance of License
NPF-3. Also, license condition 2.C.(3)(l) is revised by removing
the stipulation within 2.C.(3)(l) for providing large break spectrum
analyses within six (6) months from date of issuance of License NPF-3.

Also, based upon the stipulation of license conditions 2.C.(3)(m) and
2.C.(3)(q) we find that you have met the stipulations specified in
these conditions and we have been informed by the Office of Inspection
and Enforcement that they find you have installed modifications as
required for license conditions 2.C.(3)(m) and 2.C.(3)(q).

Therefore, we find that license conditions 2.C.(3)(m) and 2.C.(3)(q)
are no longer necessary and these conditions are hereby deleted from
Facility Operating License NPF-3 effective as of the date of issuance
of Amendment No. 7.

Amendment No. 7 also revises the Technical Specifications, Appendix A,
to allow surveillance testing frequency for the Channel Calibration
of the Rosemont reactor coolant system pressure transmitters to be
changed from once every 120 days to once every eighteen months.

Least
60

OFFICE ▶						
SURNAME ▶						
DATE ▶						

8001150956 P

NOV 29 1977

In addition, Amendment No. 7 revises the Technical Specifications, Appendix A by changing the allowable trip setpoint to 7.0 + 1.5 seconds for Sequence Logic Channel (a) of Table 3.3-4, page 3/4 3-13.

We have determined that Amendment No. 7 does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact, and pursuant to 10 CFR Section 51.5(d)(4), that an environmental impact statement, negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Copies of the Federal Register Notice of Issuance of Amendment No. 7 and the Safety Evaluation Supporting Amendment No. 7 to License No. NPF-3 are also enclosed.

Sincerely,

Original Signed by
John F. Stolz

John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management

enclosures:

- 1. Amendment No. 7 to License No. NPF-3
- 2. Federal Register Notice
- 3. Safety Evaluation Supporting Amendment No. 7 to License No. NPF-3

cc w/enclosures: See page 3

POOR ORIGINAL

OFFICE	LWR 1	LWR 1	JELOM	LWR		
SURNAME	EHylton/red	LEng JE	Stolz	JStolz		
DATE	11/ /77	11/17/77	11/23/77	11/29/77		

NOV 29 1977

Toledo Edison Company

- 3 -

cc: Mr. Donald H. Hauser, Esq.
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Gerald Charnoff, Esq.
Snaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

Mr. Harry R. Johnson
Ottawa County Courthouse
Port Clinton, Ohio 43452

Ohio Department of Health
ATTN: Director of Health
450 East Town Street
Columbus, Ohio 43216

Atomic Energy Control Board
P. O. Box 1046
Ottawa Ontario, Canada

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. Bruce Blanchard
Environmental Projects Review
Department of the Interior
Room 5321
18th and C Streets, N. W.
Washington, D. C. 20240

POOR ORIGINAL

OFFICE ➤						
SURNAME ➤						
DATE ➤						