

THE TOLEDO EDISON COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 7
License No. NPF-3

POOR
ORIGINAL

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - B. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - C. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - D. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraphs 2.C.(2) and 2.C.(3)(k) and 2.C.(3)(l) of Facility Operating License No. NPF-3 are hereby amended to read as specified below. Also the license is amended by deleting license conditions 2.C.(3)(m) and 2.C.(3)(q) to Facility Operating License No. NPF-3.

2.C.(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 7, are hereby incorporated in the license. Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

OFFICE →						
SURNAME →						
DATE →						

8001150959

2.C.(3)(k) Prior to startup following the first (1st) regularly scheduled refueling outage or no later than 26 months from the issuance of this license, whichever comes first, Toledo Edison Company shall complete tests and obtain test results as required by the Commission to verify that faults on non-Class I E circuits would not propagate to the Class I E circuits in the Reactor Protection System and the Engineered Safety Features Actuation System.

2.C.(3)(l) within thirty (30) days following two (2) weeks of sustained reactor power operation at a power level of 90 percent or greater of rated thermal power, the Toledo Edison Company shall provide operating reactor coolant system flow data for the facility which can be used to document reactor coolant system total pressure drops.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

John F. Stoiz, Chief
 Light Water Reactors Branch No. 1
 Division of Project Management

Attachment:
 Changes to the Technical
 Specifications

Date of issuance: November 29, 1977

POOR ORIGINAL

OFFICE	LWR 1	LWR 1	OLEE	LWR 1		
SURNAME	EHylton/red	LEngel	CHASS	JStoiz		
DATE	11/ /77	11/17/77	11/23/77	11/29/77		

ATTACHMENT TO LICENSE AMENDMENT NO. 7

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

3/4 3-7

3/4 3-13

POOR
ORIGINAL

OFFICE ▶						
SURNAME ▶						
DATE ▶						