JUN 24 1977

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Lowell E. Roe
Vice President, Facilities
Development
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

POOR ORIGINAL

Gentlemen:

SUBJECT: ISSUANCE OF AMENDMENT NO. 3 TO FACILITY OPERATING LICENSE NO. NPF-3 FOR DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 3 to the Facility Operating License No. NPF-3 which is effective as of the date of issuance. Amendment No. 3 revises license condition 2.C.(3)(j) to allow the performance of specific surveillance and preoperational test requirements related to the equipment and associated instrumentation as provided in the technical specification, and to require that an operator be stationed in the control room when only one decay heat removal train is available for operation to assure that the reactor heat removal pump(s) can be immediately secured should loss of flow occur due to the inadvertent closure of decay heat isolation valves DH 11 and DH 12.

Amendment 3 also revises the Technical Specification, Appendix A, to correct typographical errors presently existing in Table 3.3-12 and Table 3.6.2 of the technical specifications. Table 3.6.2 is also revised to allow surveillance testing of atmospheric vent valves ICS 11A and ICS 11B in operational mode 4. Technical Specification surveillance requirement 4.6.5.1.d.4 is revised to verify that the annulus space can be depressurized to a negative pressure of 0.25 inches water guage within 4 seconds from time that the redundant emergency ventilation systems fans attain a flow rate of 8000 cubic feet per minute. Technical specification 3.4.1 is revised to allow for surveillance and preoperational testing required in facility operational modes 3, 4, or 5. Also, Technical Specification 4.5.2 is revised to verify automatic isolation and interlock action of the decay heat removal system from the reactor control system with a simulated pressure signal.

8001230633 Cont 1

OFFICE ▶						
SURNAME ▶						
DATE ▶						

This license is amended by making the appropriate changes as listed above to the technical specifications on pages 3/4 3-23, 3/4 4-2, 3/4 5-4, 3/4 6-17, 3/4 6-20, 3/4 6-21, 3/4 6-22, and 3/4 6-30. This license is further amended by changing license condition 2.C.(3)(j) of facility operating license No. NPF-3.

We have determined that Amendment No. 3 does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves actions which are insignificant from the standpoint of environmental impact and, pursuant to 10 CFR Section 51.5(d)(4), that an environmental statement, negative declaration or environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

A copy of the Federal Register Notice of Issuance of Amendment No. 3 and the related Safety Evaluation supporting Amendment No. 3 to License No. NPF-3 are also enclosed.

Sincerely,

Original signed by J. Angelo

John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management

Enclosures:
1. Amendment No. 3 to License No. NPF-3
2. Federal Register Notice
3. Safety Evaluation Supporting Amendment No. 3 to License No. NPF-3

cc w/enclosures:
See page 3

POOR ORIGINAL

Rewritten per G. Fess, OELD, See Previous Yellow for Concurrence.

OFFICE ▶	LWR 1	LWR 1	OELD	LWR 1		
SURNAME ▶	EGWilton	LENgle	GFess	JStolz		
DATE ▶	6/24/77	6/24/77	6/24/77	6/24/77		

This license is amended by making the appropriate changes as listed above to the technical specifications on pages 3/4 3-28, 3/4 4-2, 3/4 5-4, 3/4 6-17, 3/4 6-20, 3/4 6-21, 3/4 6-22, and 3/4 6-30. This license is further amended by chaning license condition 2.3.(3)(j) of facility operating license No. NPF-3.

We have determined that Amendment No. 3 does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR Section 51.5(d)(4), that an environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

A copy of the Federal Register Notice of Issuance of Amendment No. 3 and the related Safety Evaluation supporting Amendment No. 3 to License No. NPF-3 are also enclosed.

Sincerely,

John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management

Enclosures:
1. Amendment No. 3 to License No. NPF-3
2. Federal Register Notice
3. Safety Evaluation Supporting Amendment No. 3 to License No. NPF-3

cc w/enclosures:
See page 3

POOR ORIGINAL

OFFICE ▶	LWR #1	LWR #1	OELD	LWR #1		
SURNAME ▶	EGHylton:klj	LEngle		JFStolz		
DATE ▶	6/22/77	6/23/77	6/24/77	6/ /77		

cc: Gerald Charnoff, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

Mr. Donald H. Hauser, Esq.
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Mr. Harry R. Johnson
Ottawa County Courthouse
Port Clinton, Ohio 43452

Ohio Department of Health
ATTN: Director of Health
450 East Town Street
Columbus, Ohio 43216

Atomic Energy Control Board
P. O. Box 1046
Ottawa, Ontario, Canada

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. Bruce Blanchard
Environmental Projects Review
Department of the Interior
Room 5321
18th and C Street, N. W.
Washington, D. C. 20240

POOR ORIGINAL

OFFICE ▶						
SURNAME ▶						
DATE ▶						