)oc/30/48

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS) DISTRIBUTION FOR INCOMING MATERIAL 50-346

REC: STOLZ J F NRC

ORG: ROE L E TOLEDO EDISON

DOCDATE: 06/29/78 DATE RCVD: 06/29/78

COPIES RECEIVED

DOCTYPE: LETTER NOTARIZED: NO SUBJECT

FURNISHING INFO TO QUESTIONS 1 & 4 OF NRC REQUEST FOR ADDL INFO CONCERNING LTR 1 ENCL O CONTAMINATION OF EXISTING SPENT FUEL RACKS, IN SUPPORT OF APPLICANT'S SPENT

PLANT NAME: DAVIS BESSE - UNIT 1

REVIEWER INITIAL: X.IM DISTRIBUTOR INITIAL:

NOTES

1. SEND ALL AMENDMENTS TO J. ROE

PSAR/FSAR AMDTS AND RELATED CORESPONDENCE (DISTRIBUTION CODE BCO1)

FOR ACTION:

ASST DIR VASSALLO**LTR ONLY(1) BR CHIEF LWR#1 RC**LTR ONLY(1)

INTERNAL .

LTR ONLY(1) ALTE ONLY(2) OPERATOR LIC BR**LTR ONLY(1) CAB**LTR ONLY(1) MIPC++LTR ONLY(1) MECH ENG BR**LTR ONLY(1) MATERIAL ENG BR**LTR ONLY(2) REACTOR SYSTEMS BR**LTR ONLY(1) ANALYSIS BR**LTR ONLY(1) CORE PERFORMANCE BR**LTR ONLY (1 AD FOR PLANT SYSTEMS**LTR ONLY (AUXILIARY SYS BR**LTR ONLY(1) I & C SYSTEMS BR**LTR ONLY(1) POWER SYS BR**LTR ONLY(1) AD FOR SITE TECH**LTR ONLY(4) ACCIDENT ANALYSIS**LTR ONLY(1). RAD ASSESSMENT BR**LTR ONLY(1) CEOSCIENCES BR**LTR CHLY(1)

DJ MGR ENGLE**LTR ONLY(1) LIC ASST LWR#1 LA**LTR ONLY(1)

NEC PDR##LTR ONLY(1) OELD**LTR ONLY(1) EMERGENCY PLAN BR**LTR ONLY(1) DIRECTOR NER**LTR ONLY(1) AD FOR ENG**LTR ONLY(1) STRUCTURAL ENG ER**LTR ONLY(1) AD FOR REAC SFTY**LTR ONLY(1) CONTAINMENT SYSTEMS**LTR ONLY(1 AD FOR SITE ANLYS**LTR ONLY(1) EFFLUENT TREAT SYS**LTR ONLY (1 KIRKWOOD**LTR ONLY(1)

EXTERNAL:

PT. CLINTON, OH**LTR ONLY(1) TIC**LTR ONLY(1) NSIC**LTR ONLY(1) ACRS CAT B**LTR ONLY(16)

HANAVER STELLO EISENHUT ENGINEERING BR REACTOR SAFETY BR PLANT SYSTEMS BR EFR

DISTRIBUTION: LTR T ENCL O SIZE: 1P

LPDR'S

CONTROL NER: 781810091

8001231664

REGULATORY DOCKET FILE COPY



LOWELL E. ROE

Vice President Facilities Development 14191 259-5242

June 22, 1978

5. 4.

Docket No. 50-346

License No. NPF-3

Serial No. 451

Director of Nuclear Reactor Regulation Attention: Mr. John F. Stolz, Chief Light Water Reactors Branch #1 Division of Project Management United States Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Stolz:

In our submittal Serial No. 425 dated April 4, 1978, we responded to your Request for Additional Information (RAI) pertaining to the proposed Davis-Besse Nuclear Power Station Unit 1 spent fuel storage capacity modification. Questions 1 and 4 of the R/I dealt with contamination of the existing spent fuel racks to which Toledo Edison had responded that the existing fuel racks had not been contaminated. Subsequent to our responses, Davis-Besse Unit 1 became involved with the burnable poison rod assembly (BPRA)/orifice rod assembly (ORA) problem addressed in our letters, Serial No. 435 dated May 18, 1978 and Serial No. 439 dated May 26, 1978. Activities associated with this problem were envisioned to cause a then undefined contamination of the existing spent fuel racks. We were thus informed that your staff would stop further review on the spent fuel storage application until the responses to RAI Questions 1 and 4 were revised.

In an effort to have the review of the spent fuel storage application proceed without undue delay, we wish to provide the following information.

The BPRA/ORA events included the activity of passing the removed BPRA's and ORA's through the spent fuel pool and into the adjacent cask pit where they will be stored under an adequate shield of water until their ultimate disposal. This transfer operation has been completed. During the transfer, the brief period of mixing of contaminated, borated refueling water present in the transfer pit, with the demineralized water contained (for shielding purposes only) in the spent fuel pool, and any deposits "washed" off the assemblies in the transfer process, have caused only a very small amount of contamination of the spent fuel pool water. Activity levels in the spent fuel pool water are currently on the order of 1.5 X 10", uCi/cc with the primary constituent being Cobalt-58. The existing racks were not subjected to any irradiation by spent fuel assemblies.

THE TOLEDO EDISON COMPANY EDISON PLAZA 300 MADISON AVENUE TOLEDO, OHIO 43652

wind and hereined and



Draining of the spent fuel pool will be done at a convenient time following the May-June outage when proper processing of the slightly borated water can be performed. With proper wash down during the draining of the spent fuel pool, contamination of the existing racks and pool walls will be minimal. Subsequent to draining of the spent fuel pool, the existing racks and area will be properly surveyed for contamination and further decontaminated as necessary, consistent with health physics requirements, to allow as much as practicable uncontrolled handling and disposal of the existing racks. There is the possibility that small areas of the racks will not be able to be reasonably decontaminated below controlled levels. In such cases it may become desirable to remove sections of the racks for disposal as low level waste. This is not envisioned to be a significant amount of material.

We trust that the above information will suffice to allow continuance of your review and timely approval of our application for the spent fuel storage capacity modification.

Yours very truly,

18/2

bj d/5-6

15 . 1 . 14.