

C 03/24/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCLUDING MATERIAL

50-346

REC. STOKL J P
NRC

ORG. ROE L F
TOLEDO EDISON

DOC DATE 03/20/78
DATE RCVD 03/23/78

COPY LETTER NOTARIZED YES
SUBJECT

COPIES RECEIVED
LTR 3 ENCL 40

LICENSE NO WFF-3 684L FOR AHEAD TECH SPECS PROPOSED CHANGE CONCERNING
REVISION TO THE PRESSURIZER HEATUP INTERLOCKS AND ASSOCIATED
INSTRUMENTATION. NOTARIZED 03/20/78

Postmark 3/21/78

PLANT NAME: DAVIS BESSIE - UNIT 1

REVIEWER INITIAL KUM
DISTRIBUTOR INITIAL ML

DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

1. SENT ALL AMENDMENTS TO J. ROE

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE
(DISTRIBUTION CODE 0001)

FOR ACTION: MR CHRISTIAN UNIT ENCL

INTERNAL:

ED FILE+HW ENCL
EPP+HW ENCL
HANAUER+HW ENCL
EISENBLT+HW ENCL
GABER+HW ENCL
GATNER+HW ENCL
J. HODGSON+HW ENCL

NRC PDR+HW ENCL
GELD+HW ENCL ONLY
CHECK+HW ENCL
SHAO+HW ENCL
BUTLER+HW ENCL
J. COLLINS+HW ENCL

EXTERNAL:

EPDR'S
AT. CLINTON CH+HW ENCL
TID+HW ENCL
REID+HW ENCL
NCRS CAT HW ENCL

POOR ORIGINAL

DISTRIBUTION LTR NO ENCL 01
SIZE 09+107

CONTROL NBR

~~XXXXXXXXXX~~

ED
ML

THE END

8001 280 679

P

C 03/24/78
REGULATORY DOCKET FILE COPY



Docket No. 50-346

Serial No. 421

March 20, 1978

The Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an Application for Amendment to Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

The application identifies the changes to the Davis-Besse Nuclear Power Station Unit No. 1 Technical Specifications (Appendix A to Operating License No. NPF-3) reflecting the pressurizer heater interlocks and associated instrumentation. The description of the pressurizer heater interlocks was submitted to the NRC in a letter from me to the attention of Mr. John F. Stolz dated April 7, 1977. In subsequent conversations between our engineering staff and your review staff, we agreed to provide the capability to add and remove control power to the motor operators on valves DH-11 and DH-12 from the Control Room. Also, an alarm has been provided to alert the Reactor Operator when there is control power to the motor operates on DH-11, and DH-11 is open. An identical alarm has been provided for DH-12.

We believe that with the addition of the pressurizer heater interlocks and associated instrumentation, we have completed the provisions necessary for a long-term means of protection against reactor coolant system over pressurization thereby meeting the requirements of License condition 2.C. (3) (d).

A001
S
3/10
~~RECEIVED~~
~~POSTMARKED~~
GTS

We also believe that these design modifications will allow removal of power from DH-11 and DH-12 during refueling operations and simultaneous operation of both decay heat removal pumps, and that therefore License condition 2.C. (3) (j) can be deleted.

Yours very truly,

A handwritten signature in cursive script, appearing to read "Louis E. Roe". The signature is written in dark ink and is positioned below the typed name.

ks e/5-6