



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
795 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

FILE COPY

MAR 17 1977

Docket No. 50-346

Toledo Edison Company
ATTN: Mr. Lowell E. Roe
Vice President
Facilities Development
Edison Plaza
300 Madison Avenue
Toledo, OH 43652

Gentlemen:

This refers to the inspection conducted by Messrs. R. Martin, T. Tambling, F. Maura, and R. Knop of this office on February 8-11, 18-20, 23-24, and March 2-3, 1977, of activities at Davis-Besse Unit 1, Construction site authorized by NRC Construction Permit No. CPPR-80 and to the discussion of our findings with you and members of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No items of noncompliance with NRC requirements were identified during the course of this inspection.

Certain other activities, set forth under Other Significant Items in the Summary of Findings section of the enclosed inspection report, appear to be deviations from commitments which you have made in previous correspondence with the Commission. Please advise us in writing within twenty days of the corrective action you have taken or plan to take, showing the estimated date of completion with regard to these deviations.

Moreover, as identified in the enclosed inspection report, you are also requested to provide this office with the schedule you will follow in implementing a Management Control system to assure the appropriate, periodic recalibration of instruments used to

8002060 809

MAR 17 1977

determine compliance with Technical Specification requirements (including those covered by Section XI of the ASME Code). This refers to those instruments whose calibration requirements were not specifically delineated in the Technical Specifications. Furthermore, it is our understanding that your program for the storage and protection of operations phase quality records will be as stated in item 2.e, of the March 2, 1977 management interview portion of the report.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this notice, the enclosed inspection report, and your response to this notice will be placed in the NRC's Public Document Room, except as follows. If this report contains information that you or your contractors believe to be proprietary, you must apply in writing to this office, within twenty days of your receipt of this notice, to withhold such information from public disclosure. The application must include a full statement of the reasons for which the information is considered proprietary, and should be prepared so that proprietary information identified in the application is contained in an enclosure to the application.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Gaston Fiorelli, Chief
Reactor Operations and
Nuclear Support Branch

Enclosure: IE Inspection
Rpt No. 050-346/77-06

cc w/encl:
Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC
U. Young Park, Power
Siting Commission

| | | | | | |
|-----------|-----------------|----------------|-------------------|---------------|-------------------|
| OFFICE → | RIII <i>W</i> | RIII <i>W</i> | RIII <i>W</i> | RIII <i>W</i> | RIII |
| SURNAME → | Martin <i>W</i> | Maura <i>W</i> | Tambling <i>W</i> | Knop <i>W</i> | Fiorelli <i>W</i> |
| DATE → | 3/14/77 | | | | |