DISTRIBUTION Docket File -AD/SS-L-Rdg L-Rda L-RAB

AUG 0 U 1974

Voss A. Moore, Assistant Director for Light Water Reactors Group 2, L

FINAL RADIATION TECH SPEC POSITION BY RAB - DAVIS BESSE 1

Plant name: Davis Besse 1

Licensing stage: OL Docket number: 50-346

Responsible branch: LWR 2-3 Project Manager: Irving Peltier Requested completion date: 9/6/74

Description of response: Transmittal of RAB comments on Davis Besse

Radiological Tech Specs.

Review status: Complete

Enclosed are comments which are made after review of Davis Besse Tech Specs. This review was performed by S. Block, RAB.

> Original Signed by M. R. Denton

Harold R. Denton, Assistant Director for Site Safety Directorate of Licensing

Enclosure: As stated

cc: w/o encl.

A. Giambusso

W. McDonald

SS/BC's

J. Panzarella

cc: w/encl.

3. Hanauer

P. Schroeder

J. Kastner

A. Schwencer

I. Peltier

A. Kenneke

S. Block

S. Varga

R. Klecker

B. Eisenhut

POOR

		,		MALI
OFFICE >	L:RA	1784	L:46	
	SBlockies	Accept -	HDelton	
	8/29/74	8/29/74	12974	

RADIOLOGICAL ASSESSMENT BRANCH REVIEW OF RADIOLOGICAL (APPENDIX A) TECHNICAL SPECIFICATIONS FOR DAVIS BESSE

(1) Reporting requirements of interest to RAB include items a(2)(e) and a(3)(g) of Regulatory Guide 1.16, "Report of Operating Information". A generic statement such as that given below would be satisfactory:

"Operating information shall be reported in the form and at frequencies specified in USAEC Regulatory Guide No. 1.15 entitled, 'Reporting of Operating Information' dated October 1973."

- (2) A section entitled, "Miscellaneous Radioactive Materials Source" (see Attachment A) should be inserted in Davis Besse Tech Specs. (This section can have sub-healings such as "Radioactive Source Leakage Test" or "Sealed Source Contamination").
- (3) Section 6.7 "Radiation and Respirator Protection Program" is incomplete since the explanation of notes referred to in Table 6.7-1 is missing. A copy of the explanation of these notes is shown in attachment B.

POOR ORIGINAL