

**Florida
Power**
CORPORATION

February 1, 1974

Donald F. Knuth, Director
The Directorate of Regulatory Operations
U. S. Atomic Energy Commission
Washington, D. C. 20545

Subject: Crystal River Plant Unit #3
Docket 50-302

Dear Mr. Knuth:

In order to provide you with the necessary data to evaluate Florida Power Corporation's actions regarding the reported non-conformance discussed in our letter to you of December 27, 1973 we are enclosing copies of the following data:

1. GAI letter #FPC-9738, dated January 23, 1974.
2. GAI letter #FPC-9093, dated October 8, 1973.
3. FPC letter, dated November 5, 1973.
4. Crystal River Unit #3 Construction Procedure #JAJ-W52, Revision 2.
5. Signed Quality Control Checklist (Form #JAJ-132).
6. Field Changes 1 - 8 to Crystal River #3 Construction Procedure JAJ-W52.


These documents are the documentation referenced in our December 27th letter. The GAI letter #FPC-9738, dated January 23, 1974, is a formal transmittal of documentation that was originally at the site in the form of a telecopier communication to Florida Power Corporation. This is the reason for this letter being dated subsequent to the issuance of our final report on December 27th.

Handwritten signature
8003030 855
3 1412

Donald F. Knuth
February 1, 1974
Page -2-

We hope that this additional information will provide you with the necessary data to close this item of non-conformance. Please advise us if you require any further information.

Very truly yours,



J. T. Rodgers
Assistant Vice President

ldh

Enc.

cc: Norman C. Moseley
Director, Region II

This copy to:

GILBERT ASSOCIATES, INC.

January 23, 1974

FPC - #9738

Mr. W. A. Szelistowski
Director, Generation Engineering
Florida Power Corporation
P. O. Box 14042
St. Petersburg, Florida 33733


Re: Nuclear Services and Decay Heat
Sea Water System Analysis

Dear Mr. Szelistowski:

In reference to the above subject as it relates to the 48" underground sea water discharge lines, we have analyzed the in-situ condition to determine whether or not rectification would be required. Based on the information received from the field, GAI concludes that the pipeline can remain installed in the as-built condition. It is, however, assumed that FPC Construction can in fact document the details on the deviation between the original design and the as-built condition.

We feel that this brings to a close this subject unless we hear further from you.

Very truly yours,


E. R. Hottenstein
Project Manager

ERH:ejv

NUCLEAR SERVICES AND DECAY HEATSEA WATER SYSTEM

Reference Drawings:

P-304-611

C-300-747

C-300-748

48" - SEA WATER DISCHARGE LINE SEISMIC DISTURBANCE ANALYSIS

The purpose of this investigation is to find out whether the 3" allowable movement is enough to warrant no separation at pipe joints due to seismic disturbance. This analysis covers only the soil movement caused by the wave action of ground shaking. The other ground motions caused by surface faulting, land sliding and ground fissuring are avoided during the site selection. The consolidation of backfill soil is avoided by properly specifying the backfill material.

The basic tools used in the analysis are the formulae derived by Newmark (Ref. 1).

$$\text{Axial strain} \quad \epsilon_m = V_m / C \quad \text{--- (1)}$$

$$\text{Curvatural} \quad 1/R = A_m / C^2 \quad \text{--- (2)}$$

where V_m , A_m , and C are the particle velocity, acceleration and the wave velocity respectively.

The following site informations are furnished by Mr. W. J. Santamour of Civil Engineering Department after the reviewing of the Unit No. 2 Site Seismic Survey done by the Weston Geophysical Research Corporation.

Below Elevation 84: Dilatational wave velocity $C_D = 6900$ ft/sec
 Shear wave velocity $C_S = 2700$ ft/sec
 Poisson's ratio $\nu = 0.38$

Above Elevation 84: Dilatation wave velocity $C_D = 1600$ ft/sec

The pipes are installed between elevation 94 and 96.

In order to perform the analysis, the following assumptions are made:

1. The soil particle velocity in the direction of wave propagation is caused by the dilatational wave and the longitudinal component of Rayleigh wave in a complex manner. The percentage of contribution from each component is difficult to estimate. For teleseismic waves, interpretations of different wave forms can be achieved because the great distance and long travel time makes different frequency wave component dispersed and cause natural separation of various wave types. However, the strong motion record, close to the source of energy release, is less obvious to interpret. Trifunac (Ref. 2) showed qualitatively that surface (Love and Rayleigh) may contribute significantly to strong, near field, ground motion.

For an elastic half space, the Rayleigh wave velocity approaches shear wave velocity. For layered soil and rock the Rayleigh wave is dispersive; hence, its velocity is the function of periods and modes. For engineering purposes the wave velocity in Equation (1) will be taken as the average of the dilatational wave and the shear wave velocity. This is more conservative than just taking the dilatational wave velocity.

2. The soil particle acceleration perpendicular to the direction of wave propagation is caused by the shear wave and the Love wave in a complex manner. Since the Love wave velocity is sandwiched between the shear wave velocities of the upper and lower layer (Ref. 3), it is conservative to use upper layer shear wave velocity in Equation (2).
3. The site SSE value is 0.1G. For conservative reasons, this G value is assumed at the base rock. Assuming that the ground motion is effected by the local geology only and that SH wave propagates upwards vertically, the soil will amplify base rock G value (Ref. 4, 5). However, other works (Ref. 7, 8, 9) indicated that the effects of source mechanism and travel path may overshadow the local geological effects. Nevertheless, the soil amplification will be assumed for conservative reason. From Tables 1 and 2 of Reference 6, the maximum amplification factor among various site condition is less than 3. Applying the ultraconservative factor of 3, the SSE value for soil will be 0.3G.
4. Wave velocity obtained by in SITU wave propagation test is for soil at very low strain level. The velocity will be reduced at higher strain. As shown in Equations (1) and (2), it is more conservative to use lower velocity. For conservative reason, the velocity will be reduced by a factor of 2.
5. Above elevation 84, the dilatational wave velocity is $C_D = 1600$ ft/sec. Assuming the Poisson's ratio $\nu = 0.35$, the shear wave velocity is approximately $C_S = 1600/2(1 + 0.35) = 600$ ft/sec. The average of C_D and C_S is $C = 1100$ ft/sec, and $C = 550$ ft/sec at higher strain.
6. Based on the statistic data (Ref. 10), 1G acceleration corresponds to 48 in./sec velocity on alluvium.
7. The field test showed that the underground pipe will move with the surrounding soil with no appreciable relative displacement. Under this situation the pipes will not separate at the joints. The only way that the pipes may separate is under the unlikely assumption that one piece of the pipe moves with the ground and the adjacent one slips totally from the surrounding soil.

Based on the foregoing assumptions, the axial strain is

$$\epsilon_m = 0.3 \times 48 / (550 \times 12) = 0.00218$$

and curvature is

$$1/R = 0.3 \times 32.2 / (550)^2 = 0.0000318/\text{ft}$$

By Taylor's series expansion

$$f(x) = f(b) + f'(b)(x - b) + f''(b)(x - b)^2/2 + \dots$$

where $x - b$ is the pipe section length 18 ft, $f'(b)$ is the axial strain,

$f''(b)$ is the curvature. The relative displacement is $f(x) - f(b) = f'(b)(x - b) + f''(b)(x - b)^2/2 + \dots$. Since the total velocity and acceleration were used to calculate ϵ_m and $1/R$, it is justified to combine them by root sum square approach. However, the absolute sum will be used for conservative reason. Hence, the displacement is


$$D = 0.00218 \times 18 \times 12 + 0.0000318 \times 12 \times (18)^2/2 \\ = 0.47 \text{ in.} + 0.062 \text{ in.} = 0.53 \text{ in.} \ll 3 \text{ in. allowable}$$

The conclusion of this investigation is that the pipes will not separate at joints during earthquake disturbance.

REFERENCES

1. Newmark, N. M., "Problems in Wave Propagation in Soil and Rock". Proceeding of International Symposium on Wave Propagation and Dynamic Properties of Earth Material, The University of New Mexico, August 1967.
2. Trifunac, M. D., "Response Envelope Spectrum and Interpretation of Strong Earthquake Ground Motion," BSSA*, Vol. 61, No. 2, P. 343-356, April 1971.
3. Fung, Y. C., "Foundations of Solid Mechanics," Prentice-Hall, 1969.
4. Roesset, J. M., "Fundamentals of Soil Amplification," in "Seismic Design for Nuclear Power Plants," Ed. R. J. Hansen, MIT Press, 1970.
5. Schnabel, P., H. B. Seed, and J. Lysmer, "Modification of Seismograph Records for Effects of Local Soil Conditions," BSSA, Vol. 62, No. 6, P. 1649-1664, December 1972.
6. Lysmer, J., H. B. Seed, and Schnabel, "Influence of Base-Rock Characteristics on Ground Response," BSSA, Vol. 61, No. 5, P. 1231-1231, October 1971.
7. Udawadia, F. E. and M. D. Trifunac, "Comparison of Earthquake and Microtremor Ground Motions in El Centro, California," BSSA, Vol. 63, No. 4, P. 1227-1253, August 1973.
8. Hudson, D. E., "Local Distribution of Strong Earthquake Ground Motions," BSSA, Vol. 62, No. 6, P. 1765-1786, December 1972.
9. Hall, W. J., N. M. Newmark, and D. B. Mohraz, "Comments on Earthquake Transmission from Basement Rock to Surface," Paper No. 83, 5th WCEE*, Rome 1973.
10. "A Study of Vertical and Horizontal Earthquake Spectra," by N. M. Newmark Consulting Engineering Service for USAEC, Wah-1225, April 1973.
11. Nasu, N., S. Kazama, T. Morioka, and T. Tamura, "Vibration Test of the Underground Pipe with a Comparatively Cross-Section," Paper No. 64, 5th WCEE, Rome 1973.

* BSSA: Bulletin of the Seismological Society of America.
WCEE: World Conference on Earthquake Engineering.



October 8, 1973

FPC#9093

Mr. W. A. Szelistowski
Director Generation Engineering
Florida Power Corporation
P.O. Box 14042
St. Petersburg, Florida 33733

Re: Crystal River Unit Three 48" Nuclear
Service and Decay Heat Service Seawater
System, Underground Concrete Discharge
Piping

Ref: FPC-GAI-150, Telex from FPC dated
October 5, 1973

Dear Mr. Szelistowski:

In reference to the above communications, GAI realizes the seriousness of your problem and will review the situation with a view to making every effort possible to determine a solution that will have the least total input on the Project.

We propose the following: An engineering analysis be made to determine, if in fact, the pipe line as constructed can meet design criteria. Our basic concern is the ability of the pipe to withstand a seismic disturbance. The analysis will not commence before October 16, 1973. By November 1, 1973 an initial reply is expected provided that in-put information is available.

Concurrently with the above effort, we further propose to investigate alternative "fixes" should the analysis indicate such a course of action is required.

This letter has been telecopied to the site.

Very truly yours,

F. J. Tomazic
Project Control Analyst

FJT:dc

FLORIDA POWER CORPORATION
P. O. BOX 276
CRYSTAL RIVER, FLORIDA 32629

File
4-17-3

November 5, 1973

Gilbert Associates, Inc.
P. O. Box 1498
Reading, Pa. 19603

Attention: Mr. E. R. Hottenstein

Subject: Crystal River Unit #3
48" NSSW Concrete Pipe

*Crystal River Unit #3
48" NSSW Concrete Pipe*

In response to your 11-1-73 letter (FPC-9267) we transmit one copy of the procedure (JAJ-W52) used for installation of the 48" pipe. We specifically refer you to section 6.4.D of the procedure. We also transmit one copy of the completed, signed off Quality Control Check Lists (JAJ-132) for QC inspection of the pipe installation.

Should additional information be needed, please contact us.

J. E. Colby
J. E. Colby, Engineer

R. S. Burns, Manager Mechanical
& Structural Engineering

JFC/RSB/kah

cc: C. E. Jackson

J. A. JONES CONSTRUCTION CO.

COVER SHEET

DOCUMENT NUMBER: JAJ-W52	ORIGINAL DATED: 7/14/72	ATTACHMENTS: None
TITLE: WORK PROCEDURE-INSTALLATION OF NUCLEAR SERVICE AND DECAY HEAT SEA WATER UNDERGROUND PIPING (Florida Power Corporation-Crystal River #3)		
SCOPE OF REVISION: Revision 1, dated 12/1/72		
1. General Revision. Revision 2, dated 12/21/72		
1. Page 6: Paragraph 5.20 added. Section 6 changed. Paragraphs 7.0, 8.0, 8.1 and 8.2 deleted.		
2. Exhibits 4,5,6 and 7 added.		

POOR ORIGINAL

APPROVAL DATES, SIGNATURES AND INITIALS

	ORIGINAL ISSUE	DATE	REV.NO.	INITIAL & DATE	REV.NO.	INITIAL & DATE
AUTHOR	<i>R. L. Tomlin</i>	7/14/72	1	<i>R. L. Tomlin 7/14/72</i>	2	<i>Rao 12/19/72</i>
JONES QC	<i>J. A. Jones</i>	7/14/72	1	<i>J. A. Jones 11/22/72</i>	2	<i>J. A. Jones 12/19/72</i>
JONES PROJECT	<i>J. A. Jones</i>	7/14/72	1	<i>J. A. Jones 11/22/72</i>	2	<i>J. A. Jones 12/19/72</i>
FPC	<i>W. J. Jackson</i>	7/14/72	1	<i>W. J. Jackson 12-1-72</i>	2	<i>W. J. Jackson 12-22-72</i>

J. A. JONES CONSTRUCTION CO.

POST OFFICE BOX 566
CHARLOTTE, NORTH CAROLINA 28201

WORK PROCEDURE JAJ-W52

INSTALLATION OF NUCLEAR SERVICE AND DECAY HEAT SEA WATER UNDERGROUND PIPING

- 1.0 PURPOSE
 - 1.1 To provide instructions for the installation of Nuclear Service and Decay Heat Sea Water Underground Piping.
- 2.0 SCOPE
 - 2.1 This procedure includes the Nuclear Sea Water intake and discharge piping.
- 3.0 RESPONSIBILITY
 - 3.1 The J. A. Jones Construction Co. Mechanical General Superintendent has the primary responsibility for implementation of this procedure.
- 4.0 REFERENCES
 - 4.1 FPC-W8 Procedure for Warehouse Functions.
 - 4.2 GAI Dwg, P-304-611, Nuclear Service and Decay Heat Sea Water Piping Plan and Sections
 - 4.3 GAI Dwg, FD-302-611, System Flow Diagram
 - 4.4 GAI Dwg, G-736-002, Plot-Main Plant Area
 - 4.5 GAI Dwg, G-744-010, Intake and Discharge Canal-Excavation
 - 4.6 GAI Dwg. SC-426-501, Instake Structure
 - 4.7 GAI Dwg. SC-422-001, Nuclear Service Sea Water Pump Chamber
 - 4.8 GAI Dwg. SC-422-015, Aux. Bldg.
 - 4.9 GAI Dwg. P-304-613, Nuclear Service and Decay Heat Sea Water-Plan-Aux. Bldg.
 - 4.10 RO-2766 Nuclear Services Seawater Piping

DOCUMENT CONTROL

7/14/72
ORIGINAL DATED
1
REVISION
12/1/72
EFFECTIVE

POOR ORIGINAL

JAJ-W52
DOCUMENT NO.
PAGE 1 OF 10

- 4.11 Nuclear Service and Decay Heat Suspended Seawater Piping, Gilbert Associates, Inc. RO-3013
- 4.12 FPC-W48, Work Procedure-Pipe Erection.
- 4.13 ES-111A American Cast Iron Pipe Company drawing.
- 4.14 Interpace Pipe Laying Schedule, Revision F, dated, 6/21/71
- 4.15 Interpace Instructions for Installation of Concrete Pressure Pipe with Rubber and Steel Joints.
- 4.16 GAI Dwg. SC-401-041, Rev. 1, Filter Blanket Decay Heat Pit.
- 4.17 P. C. Shah letter FPC-6924, dated 10/13/72.
- 4.18 Specification for Excavation and Placement of Structural Fill, Gilbert Associates, Inc., SP-5629.
- 4.19 TP-7-3-265-5, TP-7-3-266-4, Nuclear Services and Decay Heat Seawater Systems, Buried Ductile Intake Piping Hydrostatic Test.
- 4.20 TG-00046, Hydrostatic and Pneumatic Components.
- 5.0 INSTRUCTIONS-LAYING 48" CAST IRON INTAKE PIPE (DRY CONDITION)
- 5.1 Dewatering shall be effected using a filtered dewatering system. Water will be collected from the trench through lines of 6", 8" or 10" perforated, galvanized pipe. Pipe size selection will depend on volume of water to be removed. One pipe will be run along each bottom corner of the trench as shown in Exhibit 1. If necessary, a third dewatering pipe will be laid down the middle of the trench as shown in Exhibit 1. Cross connections between the parallel dewatering lines will be laid as necessary to achieve efficient dewatering.
- 5.2 Excavation, placing of pipe, and fill shall be in accordance with Exhibits 1 and 2.
- 5.3 The trench bottom shall be excavated as close to grade as possible (at least 8" below the bottom of the pipe).
- 5.4 In the area of the pipe joints, over-excavation will be allowed to permit assembly and testing. Over-excavate for the dewatering pipe as shown in Exhibit 1.

POOR ORIGINAL

DOCUMENT CONTROL

7/14/72
ORIGINAL DATED
1 12/1/72
REVISION EFFECTIVE

J. A. JONES CONSTRUCTION CO.

JAJ-W52
DOCUMENT NO.
PAGE 2 OF 10

5.5

Hold for Quality Control Check.

- A. Prior to any backfilling, verify that all mud, sludge, sediment and poor fill material has been removed and that a general state of cleanliness exists.
- B. Check Zone "A" material for conformance to Reference 4.16 prior to use in backfilling. On-site testing laboratory perform at least one gradation test for each 150 tons of fill.

5.6

General over-excavation shall be leveled with Zone "A" fill compacted to 98% maximum density. Maximum density shall be determined from Zone "A" test strip as described in PTL Report of September 1972.

5.7

A uniform layer of Zone "A" material shall be compacted per section 5.6 up to the elevation of the bottom of the pipe. The level of this Zone "A" material shall be carefully graded, by hand wherever necessary, to meet the design grade line.

5.8

Approximately 5 inches of Zone "A" material shall be compacted to 98% maximum density (see section 5.6) and subsequently cut to leave two trapezoidal trenches four feet wide in which the pipe will rest (see Exhibit 1).

5.9

Hold for Quality Control check. One compaction test shall be made for each 200 yards of fill.

5.10

Handling Pipe

- A. Slings shall be rigged on the external surface of the pipe.
- B. No temporary welds shall be made to the pipe to facilitate handling.
- C. Each section of pipe shall rest on the shaped trench bottom for about one-half, or more, of its full length (except at the joints where over-excavation has been provided for assembly and testing) and shall be firmly held in position so that the invert forms a continuous grade with the invert of the section of pipe previously placed.
- D. The angular deflection between centerlines of any two adjoining pipe sections shall not exceed one degree (equivalent to about 3" lateral deflection over 16' length).
- E. All hub interiors and spigot ends shall be cleaned of loose dirt and sand.

DOCUMENT CONTROL

7/14/72

ORIGINAL DATED

1

REVISION

12/1/72

EFFECTIVE

J. A. JONES CONSTRUCTION CO.

JAJ-MS2
DOCUMENT NO.

PAGE 3 OF 10

5.11 Hold for Quality Control check of cleanliness per 5.10 E. Record on Form No. JAJ-131 (Exhibit 3).

5.12 Joining pipe sections

A. Cast Iron Mechanical (Locked Fastite) Joints

1. Clean the joint mating surfaces.
2. Insert the gasket into the gasket recess located in the socket end.
3. Melt the American Locked Fastite joint lubricant by heating and apply a thin coat of this heated lubricant to the plain end of the pipe with a brush. Caution is necessary to avoid overheating the lubricant. The melting point of the lubricant is 150 degrees F to 160 degrees F. The flash point is 525 degrees F. Do not use solvents or other substances, which might be injurious to the rubber gasket, for cleaning the joint or for thinning the lubricant.
4. With the joint reasonably straight, pull the plain end into the socket.
5. The mechanical joint shall be pulled up and torqued to 65 ft. pounds or to a $\frac{1}{4}$ " gap in the joint at the closest point, whichever occurs first. Place two $\frac{1}{2}$ " spacers, separated about 180 degrees in the joint to assure $\frac{1}{4}$ " gap is maintained. The torque wrench shall be calibrated at least once every six months.

B. The four flanged cast iron pipe joints on the 90 degree ell sections shall be bolted in accordance with FPC-W48 and Ref. 4.2.

5.13 Hold for Quality Control check. Record on Form No. JAJ-131.

- A. Verify thermal gap is $\frac{1}{2}$ " minimum.
- B. Verify alignment as performed by field engineers.
- C. Verify 65 foot pound maximum torque has been applied; check 10% of the mechanical joint bolts.
- D. Verify absence of loose material from the pipe.

QUALITY CONTROL

7/14/72
ORIGINAL DATED

1 12/1/72
REVISION EFFECTIVE

J. A. JONES CONSTRUCTION CO.

JAJ-WS
DOCUMENT NO.

PAGE 4 OF 10

- E. Make inspection of the pipe liner for visually apparent cracks or loose lining. Cracks or loose lining shall be repaired per Manufacturer's instruction.
- 5.14 The joints shall be leak tested in accordance with Reference 4.19 and Reference 4.20 and section 3.06 of Reference 4.10.
- 5.15 Quality Control verify that leak test results are within requirements established by Reference 4.19. Record results of leak test on Form No. JAJ-131. (Exhibit 3, attached).
- 5.16 After successful leak test, each joint shall be wrapped in accordance with detail 5 of Reference 4.2. If practicable, leave water in pipe to add inertia during the backfilling operation called out in paragraph 5.18.
- 5.17 Hold for Quality Control check.
- A. Verify that joints have been wrapped in accordance with detail 5 of Reference 4.2.
- B. Verify that backfill materials called out in paragraph 5.18 meet requirements established in References 4.16 and 4.18.
- 5.18 Complete Backfill (see Exhibits 1 and 2)
- A. A coarse, washed sand shall be sluiced in the trench beneath the pipe. In addition, sand shall be sluiced into the over-excavation for the joints. It is necessary that excess water used in sluicing be drained off. During subsequent backfilling operations sand will be used exclusively around joints to a point 2 feet above the top of the pipe.
- B. Zone "A" fill shall be brought up to the pipe's spring-line. Thin (less than 12" loose) lift construction shall be used and after compaction the elevation of the top of each lift shall be uniform across the trench width in order to preclude movement of the pipes. The Zone "A" fill material shall be compacted to 90% maximum density (see section 4.6).
- C. Backfilling shall be continued using thin lift construction: Zone III fill material placed in horizontal layers of approximately twelve inches thickness. The fill shall be spread and graded to prevent excessive particle segregation. Compaction shall be 90% Modified. This method shall continue from springline to the elevation of the top of the pipe.

7/14/72
ORIGINAL DATED

1 12/1/72
REVISION EFFECTIVE

J. A. JONES CONSTRUCTION CO.

JAJ-W52
DOCUMENT NO.

PAGE 5 OF 10

- D. The next lift above the elevation of the top of the pipe shall be at least two feet thick and shall be placed all at one time using Zone III material compacted to 90% Modified.
- E. Subsequent lifts shall utilize the thin (less than 12" loose fill) lift construction method using Zone III fill compacted to 90% Modified up to a height of 5 feet above the top of the pipe. This 5-foot "cushion" will be adequate to protect the pipe during standard compaction methods to be used for the remainder of the trench.
- F. From 5 feet above the top of the pipe up to the surface, backfill with Zone III and compact to 95% Modified.

5.19 Quality Control checks shall be made and documented during the backfill operations. Reports shall be included in Quality Control files.

- A. Verify gradation and plasticity index for Zone III material.
- B. Verify gradation for Zone "A" material.
- C. Verify that method of spreading and maximum amount of lift for Zone III materials meet requirements.
- D. Make at least one compaction test per lift.

5.20 The On-site Independent Testing Laboratory shall make the inspections and tests called for by section 5 and submit results on the appropriate form for retention in the Quality Record files:

- A. Form No. JAJ-131 (see Exhibit 3) for individual pipe sections,
- B. Form No. FPC Q-009 for discrepancies, and
- C. Special Pittsburgh Testing Laboratory forms (see Exhibits 5, 6 and 7) for reports of compaction, plasticity and gradation.

6.0 INSTRUCTIONS - LAYING 48" CONCRETE (DISCHARGE) PIPE SECTIONS

6.1 The requirements of sections 5.1 through 5.9 shall be met for concrete pipe. Before each section of pipe is laid, Quality Control shall check the bedding requirements and report completion of that inspection on Form No. JAJ-132 (see Exhibit 4) under "Bedding".

DOCUMENT CONTROL

J. A. JONES CONSTRUCTION CO.

7/14/72
ORIGINAL DATED
2 12/19/72
REVISION EFFECTIVE

JAJ-152
DOCUMENT NO.
PAGE 6 OF 10

6.2 Handling Pipe sections

- A. Reference 4.15 provides guidance for laying and joining concrete pipe.
- B. Slings shall be rigged externally; no temporary welds.
- C. The pipe sections are serialized. Each section shall be laid in its assigned location as designated in Reference 4.2.
- D. Both ends to be joined shall be cleaned with rags or other suitable means and clear water before being joined.
- E. Before being joined, both ends shall be lubricated with vegetable soap (about 7 ounces per joint).
- F. The pipe section being laid shall be held in suspension after alignment until the joint has been thrust fully home.
- G. The gasket shall be thoroughly lubricated by immersion in a viscous solution of vegetable soap, and stretched around the spigot to obtain an even tension in the circumferential groove. The gasket shall be placed so as to lie true in the groove without twists.

6.3 Hold for Quality Control check. Report completion of inspection of joint cleanliness, joint lubrication and gasket lubrication and placement under "Joint Preparation" on Form No. JAJ-132.

6.4 Joint Closure

- A. As the joint is being closed, the closure shall be checked by two spacers (3/4" steel bar inserts held about 180° apart).
- B. A feeler gage shall be used to detect any irregularities in the gasket by checking through the recess provided by the spacers.
- C. If the gasket is out of place, the pipe section shall be backed out, the joint re-lubricated, an undamaged and lubricated gasket installed, and the sections re-closed to the spacers.
- D. Given gasket alignment, the spacers shall be removed and the joint thrust fully home.

DOCUMENT CONTROL

7/14/72
ORIGINAL DATED

J. A. JONES CONSTRUCTION CO.

JAJ-W52
DOCUMENT NO.

2 12/19/72
REVISION EFFECTIVE

PAGE 7 OF 10

- 6.5 Hold for Quality Control check. Quality Control report verification of gasket placement, joint closure and alignment (as performed by field engineers) under "Joint Fitup Alignment" on Form No. JAJ-132.
- 6.6 The pipe joints shall be mortared from the outside at a convenient time. Follow instructions from the mortar manufacturer when applying mortar.
- A. Outside joints shall be wrapped before mortaring with a special cloth strip which has metal reinforcing on each side. This strip shall be drawn tight around the pipe to provide a form to hold the mortar in the joint. Leave an opening across the top of the joint.
- B. Mortar of a consistency which will flow into the joint shall be used. A wire curved to about a 24" radius shall be used to force the mortar into the lower portions of the joint recess.
- C. Mortar of a thicker consistency shall be used to completely fill the joint recess across the top of the pipe.
- 6.7 Verify absence of loose material from the pipe. Make inspection of the pipe liner for visually apparent cracks or loose surface. Cracks or loose surface shall be repaired per Manufacturer's instructions. Report completion of foregoing inspections under "Pipe Condition" on Form No. JAJ-132. The pipe joints shall be mortared from the inside at a convenient time. These joints may be mortared using trowels. All excess mortar shall be removed. Follow instructions from the mortar manufacturer when applying mortar.
- 6.8 Quality Control check exterior mortaring for each joint and record completion of inspection in the "Exterior Joint Mortar" column of Form No. JAJ-132.
- 6.9 Quality Control check interior mortaring for each joint and record completion of inspection in the "Interior Joint Mortar" column of Form No. JAJ-132.
- 6.10 The requirements of sections 5.18 and 5.19 shall be met for concrete pipe subject to the following modifications:
- A. The use of sand to protect joints is optional.
- B. If Zone "A" material is no longer available, Zone III material may be substituted in backfilling to the pipe's springline.

DOCUMENT CONTROL

J. A. JONES CONSTRUCTION CO.

11/14/72
ORIGINAL DATED
2
REVISION
12/19/72
EFFECTIVE

JAJ-132
DOCUMENT NO.

PAGE 7A OF 10

C. From two feet above the top of the pipe up to the surface, backfill with Zone III material and compact to 95% modified.

6.11 The On-site Independent Testing Laboratory shall make the inspections and tests called for by section 6 and submit results on the appropriate form for retention in the Quality Record files.

A. Form No. JAJ-132 (see Exhibit 4) for individual pipe sections,

B. Form No. FPC Q-009 for discrepancies, and

C. Special Pittsburgh Testing Laboratory forms (see Exhibits 5, 6 and 7) for reports of compaction, plasticity and gradation.

DOCUMENT CONTROL

7/14/72

ORIGINAL DATED

2

REVISION

12/19/72

EFFECTIVE

J. A. JONES CONSTRUCTION CO.

JAJ-W52

DOCUMENT NO.

PAGE 7B OF 10

INTAKE

ZONE III (95% Mod)

ZONE III (90% Mod)
USE THIN LIFT CONSTRUCTION


ZONE III (90% Mod)
PLACE THIS ZONE IN
ONE LIFT

ZONE III (90% Mod)
USE THIN LIFT
CONSTRUCTION

ZONE 'A' (90% Mod)

ZONE 'A' (95% Mod)


ZONE 'A' (95% Mod)



DOCUMENT

6", 8", OR 10" PERFORATED GALVANIZED
DEWATERING PIPES

INTAKE



TYPICAL JOINT
PLAN

DOCUMENT CONTROL

POOR ORIGINAL

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

Para-graphs	5.1 - 5.4	5.10 E. 5.13D., E	5.12 A. 1., 2., 3.	5.12 A.5.	5.12 B.	5.14	5.16	5.18 A.	5.18 B.	5.18 C. E., F., G
Pipe Piece No.	Bedding	Readi- ness to join	Joint Fitup Alignmt.	Mech. Joint Bolting	Flanged Joint Bolting	Leak Test	Wrapping	Sluffed Sand	Zone A to Spring line	Zone B

Distribution: White FPC Quality Engr.
 Canary PTA Chief Inspector
 Pink JAJ Quality Control
 Golden rod FPC Const. Supt.

Note: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature.

Form No. JAJ-131 Exhibit 3

QUALITY CONTROL

J. A. JONES CONSTRUCTION CO.
FLORIDA POWER CORPORATION
 CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPHS	6.1	6.3	6.5	6.7	6.8	6.9	5.18 B. 6.10 B.	5.18 C., 6.10 C.
PIPE PIECE NO.	BEDDING	JOINT Prepara- ration	JOINT FITUP ALIGNMENT	Pipe Condition	EXTERIOR Joint Mortar	INTERIOR Joint Mortar	Zone A/III to Spring- line	ZONE III

QUALITY CONTROL

Distribution:

- White FPC Quality Engr.
- Conary PTL Chief Inspector
- Pink JAJ Quality Control
- Goldenrod FPC Const. Supt.

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the squares and record the inspection date just below signature. Report discrepancies on Form No. FPC Q-009.

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3
 QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

PARAGRAPHS PIPE PIECE NO.	48" CONCRETE PIPE										5. 16 C., 6. 10 C.	
	6.1 BEDDING	6.3 JOINT PREPARATION	6.5 JOINT FITUP ALIGNMENT	6.7 PIPE CONDITION	6.8 EXTERIOR JOINT MORTAR	6.9 INTERIOR JOINT MORTAR	5. 18 B. 6. 10 B.	ZONE A/III TO SPRINGLINE	ZONE III			
107	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
52	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
51	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
50	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
106	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
105	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
104	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
49	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
48	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
47	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A
103	7/2/72 12-22-72	N/A	N/A	7/2/72 12-22-72	N/A	N/A	N/A	N/A	N/A		N/A	N/A

each side piece

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

INSTALLATION OF UNDERGROUND PIPING

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PIECE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A/III TO SPRINGLINE		ZONE III	
							5. 18 C. 6. 10 B.	5. 18 C. 6. 10 C.		
101	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
102	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
103	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
104	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
105	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
106	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
107	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
108	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
109	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	
110	1-2-73	1-2-73	1-2-73	1-4-73	1-8-73	1-28-73	2-12-73	2-20-73	2-20-73	

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature. Report discrepancies on Form No. FPC C-309.

FPC Quality Engr.
 PTL Chief Inspector
 JAJ Quality Control

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

PARAGRAPHS	PIPE PIECE NO.	48" CONCRETE PIPE										5. 18 C. 6. 10 C.
		5. 18 B. 6. 10 B.	6. 9	6. 6	6. 7	6. 5	6. 7	6. 6	6. 9	6. 9	6. 10 B.	
		INTERIOR JOINT MORTAR	EXTERIOR JOINT MORTAR	PIPE CONDITION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A III TO SPRINGLINE	ZONE III		
95		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
96		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
97		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
98		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
99		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
30		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
31		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
32		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
33		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
34		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
35		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
36		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
37		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	
90		2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	2-2-73 1-18-73	

NOTE: In each column, opposite each pipe piece, that sign in the upper of the two

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION
 48" CONCRETE PIPE

PARAGRAPHS PIPE PIECE NO.	5.1 BEDDING	6.3 JOINT PREPARATION	6.5 JOINT FITUP ALIGNMENT	6.7 PIPE CONDITION	6.8 EXTERIOR JOINT MORTAR	6.9 INTERIOR JOINT MORTAR	5.18 B. 6.10 B. ZONE A/III TO SPRINGLINE	5.14 C. 5.10 C. ZONE III
38	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
39	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
35	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
34	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
33	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
86	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
32	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
85	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
31	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73
41	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73	1-4-73 1-4-73 1-4-73

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPHS	6.1	6.3	6.5	6.7	6.8	6.9	5.18 B. 6.10 B.	5.18 C. 6.10 C.
PIPE PIECE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ' ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A III TO SPRINGLINE	ZONE III
29	7-19-73	7-19-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
30	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
31	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
32	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
37	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
36	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
35	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
78	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
79	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
80	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
81	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73
82	7-20-73	7-20-73	7-20-73	7-23-73	7-23-73	7-23-73	7-23-73	7-23-73

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature. Report discrepancies on Form No. FPC C-002.

FPC Quality Engr.
 PTL Chief Inspector
 PTL Quality Control

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPH	6.1	6.3	6.5	6.7	6.8	6.9	5.16 B. 6.10 B.	5.16 C. 6.10 C.
PIPE PIECE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A / III TO SPRINGS LINE	ZONE II
22	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
21	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
20	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
19	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
18	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
17	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
16	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
15	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
14	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
13	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
12	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
11	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73
10	1-23-73	1-23-73	1-23-73	1-23-73	1-29-73	1-29-73	1-29-73	2-12-73

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature. Report discrepancies on

Quality Control
 Date

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPHS	6.1	6.3	6.5	6.7	6.8	6.9	5.18 B. 6.10 B.	5.18 C. 6.10 C.	ZONE III
PIPE # SEE L.D.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A/III TO SPRINGLINE		
72	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
71	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
18	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
17	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
70	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
16	1-24-73	1-24-73	1-25-73	1-30-73	N/A	N/A	2-27-73		
15	1-24-73	1-24-73	1-25-73	1-30-73	N/A	N/A	2-27-73		
69	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
68	1-24-73	1-24-73	1-25-73	1-30-73	1-24-73		2-27-73		
19	1-24-73	1-24-73	1-25-73	1-30-73	N/A	N/A	2-27-73		

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature Report discrepancies on Form No. FPC C-009.

Signature: [Blank]
 Date: [Blank]
 PQC Quality Eng.
 PQC Chief Inspector
 PQC Quality Control
 PQC Office, Fla.

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPHS	5.1	6.3	6.5	6.7	6.8	6.9	5.19 B. 6.10 B.	5.12 C. 5.10 C.
PIPE PIECE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A/III TO SPRINGLINE	ZONE III
14	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
16	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
18	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
15	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
12	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
14	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
11	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
13	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
10	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
12	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
1	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			
53	9-25-73	9-25-73	9-25-73		7. D. Dillberry 10-29-73			

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two squares and record the inspection date just below the signature. Report discrepancies on Form No. E.P. 0-670

Signature: J.A.J. Quality Engr.
 P.T.L. Chief Inspector
 J.A.J. Quality Control
 F.F.C. Const. Dept.

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.

FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PARAGRAPHS	6.1	6.3	6.5	6.7	6.8	6.9	5.13 B. 6.10 B.	5.15 C. 6.10 C.
PIPE FACE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A 'III TO SPRINGLINE	ZONE III
2	9-26-73	9-26-73	9-26-73					
54	9-26-73	9-26-73	9-26-73					
3	9-26-73	9-26-73	9-26-73					
55	9-26-73	9-26-73	9-26-73					
4	9-26-73	9-26-73	9-26-73					
56	9-26-73	9-26-73	9-26-73					
5	9-26-73	9-26-73	9-26-73					
57	9-26-73	9-26-73	9-26-73					
6	9-26-73	9-26-73	9-26-73					
58	9-26-73	9-26-73	9-26-73					
7	9-26-73	9-26-73	9-26-73					
59	9-26-73	9-26-73	9-26-73					

POOR ORIGINAL

J. A. JONES CONSTRUCTION CO.
 FLORIDA POWER CORPORATION

CRYSTAL RIVER NO. 3

QUALITY CONTROL CHECK LIST FOR NUCLEAR SERVICE AND DECAY HEAT UNDERGROUND PIPING INSTALLATION

48" CONCRETE PIPE

PIECES	6.1	6.3	6.5	6.7	6.8	6.9	5.18 B. 6.10 B.	5.15 C. 6.10 C.
PIECE NO.	BEDDING	JOINT PREPARATION	JOINT FITUP ALIGNMENT	PIPE CONDITION	EXTERIOR JOINT MORTAR	INTERIOR JOINT MORTAR	ZONE A/III TO SPRINGLINE	ZONE III
8	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
60	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
5	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
6	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
7	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
8	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
57	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
58	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
59	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
60	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
61	OK. 4-22-73	OK. 4-22-73	OK. 4-22-73	OK.	OK.	OK.		
N/A								

NOTE: In each column, opposite each pipe piece no., the inspector shall sign in the upper of the two square and record the inspection date just below the signature. Report discrepancies on Form No. FPC Q-009.

J.A.J. Quality Control
 J.A.J. Chief Inspector
 J.A.J. Quality Control
 J.A.J. Chief Inspector

R.B.J. JAN 11 '73

Construction Procedure No. JAJ-W52 Date 7/14/72

Field Change No. 1 D.A. OLIVER 1/10/73
Originator Date

Reason for Change:

Extreme difficulty is being encountered in compacting Zone III fill in the confined space between the Auxiliary Building and the alongside 48" cast iron pipe running south from the anchor block at the north end.

Description of Method:

Backfill requirements of paragraphs 5.18 C,D,E and F are changed for the space confined by the Auxiliary Building foundation, Auxiliary Building foundation overhang and the 48" cast iron nuclear services intake piping alongside the Auxiliary Building.

In this confined space, sand shall be sluiced in from the pipe's spring line up to the bottom of the building overhang.

Sand shall be used outside the confined space where it is practicable to compact Zone III fill.

Approved: C. Pecher 10 JAN 73
FPC Construction Supervisor

Concurrence: R.D. Davis for D.W.P. 10 Jan 73
FPC Quality Engineer

Notification: J.L. Smith 1/10/73
Q.C. Dept. Representative

Review: S. Ray 1/10/73
GAI/QA Dept.

Comments:

POOR ORIGINAL DOCUMENT CONTROL

Construction Procedure No. JAJ-W52

Date 7/14/72

Field Change No. 2

D.A. OLIVER

Originator

Date

Reason for Change:

Hydrostatic tests of the Nuclear Service and Decay Heat Sea Water Underground Piping will be performed by the Florida Power Corp. Test Group and results recorded on FPC forms.

Description of Method:

The leak test requirement (section 5.14) and associated quality control reports (section 5.20 and the "Leak Test" column of Form No. JAJ-131, Exhibit 3) are deleted from JAJ-W52.

Approved:

FPC Construction Supervisor

J. H. H. Jr. 1-11-73

Concurrence:

FPC Quality Engineer

R. J. Davis for D.P. 16 Jan '73

Notification:

Q.C. Dept. Representative

J. H. H. Jr. 1/16/73

Review:

GAI/QA Dept.

A. Ray Bushman 1/16/73

Comments:

POOR ORIGINAL DOCUMENT CONTROL

Construction Procedure No. JAJ-W52 Date 7/14/72

Field Change No. 3 Originator T. McAllister Date February 2, 1973

Reason for Change:

To define "visually apparent cracks" as stated in paragraph 6.7.
Reference: Letter from Lock Joint Pipe, Interspace Corporation,
dated January 25, 1973.

Description of Method:

Minor or "hairline" cracks need not be reported, as this condition is
considered normal by the manufacturer.

Approved: C. Parker 2 FEB 73
FPC Construction Supervisor

Concurrence: D. W. Redrick 2 FEB 1973
FPC Quality Engineer

Notification: J. C. ... 2/2/73
Q.C. Dept. Representative

Review: A. Ray ... 2/2/73
GAI/QA Dept.

Comments:

POOR ORIGINAL

DOCUMENT CONTROL

Construction Procedure No. JAJ-WF2 Date 7/14/72

Field Change No. 4 Originator J.R. Arundson Date 2/2/73

Reason for Change:

The Neolube lubrication requirement of section 7.1.2 of FPC-W48 does not apply for installation of the nuclear service and decay heat sea water underground piping.

Description of Method:

Add to Section 5.12 B: Neolube lubrication shall not be required.

Approved:	<u>C. Packer</u>	<u>2/2/73</u>
FPC Construction Supervisor		
Concurrence:	<u>D. W. Pedrick, Jr.</u>	<u>2/2/73</u>
FPC Quality Engineer		
Notification:	<u>J. H. ...</u>	<u>2/2/73</u>
Q.C. Dept. Representative		
Review:	<u>S. Ray ...</u>	<u>2/2/73</u>
GAI/QA Dept.		
Comments:		

POOR ORIGINAL

DOCUMENT CONTROL

Construction Procedure No. JAJ-WF 2 D 7/11/72

Field Change No. 5 D. Short 2/14/73
Originator Date

Reason for Change:

Testing will not be required for the first joint (intake end) of the 48" Cast Iron Intake Pipe (Nuclear Service and Decay Heat Sea Water Piping) since this joint will be completely encased in concrete.

Description of Method:

Add to section 5.14: No leak test is required for the first joint at the intake end for both lines of pipe. These two joints will be completely encased in concrete.

Approved: C. Parker 2/14/73
 FPC Construction Supervisor

Concurrence: J.W. Pedrick 2/14/73
 FPC Quality Engineer

Notification: [Signature] 2/14/73
 Q.C. Dept. Representative

Review: [Signature] 2/14/73
 GAI/QA Dept.

Comments:

POOR ORIGINAL

CONSTRUCTION PROCEDURE

Construction Procedure No. JAJ - W52 Date 7/14/73
Title Work Procedure - Installation of Nuclear Service and Decay Heat
S&W Water Underground Piping
Field Change No. _____ Originator J. R. Anderson Date 9/27/73

Reason For Change: to add welding requirements of steel wedge ring.
See attach Interpace Dwg. D-4-390 Rev. A.

DOCUMENT CONTROL

Description of Method: welding in accordance with Mfg. Dwg. D-4-390
weld to be a 1/4" fillet weld around the
circumference, except for the bottom 12 inches.
The welding sequence to be the skip weld method
as shown on D-4-390. Use qualified welders and
a qualified welding procedure for this weld.
Weld shall be visually inspected to assure the
weld is a least 1/4 inch fillet and that the
welds are free from cracks.
The weld inspection will be reported on a Q-009
inspection report, and identified to the follow-
ing example (Piece #61 to #60).

POOR ORIGINAL

Route in order shown below:


- (1) Approval: FPC Construction Supv.
- (2) Notification: QC Dept. Supv.
- (3) Review: GAI/QA Representative
- (4) Concurrence: FPC Quality Engineer
- (5) Distribution: Document Control

Signature _____ Date 9-27-73

CONCRETE JOINT SEALING COMPOUND; RAM-NEK OR EQUAL (BY OTHERS)
 EMBEDDED CYLINDER PIPE WITH RUBBER AND STEEL WEDGE RING JOINT

D-4-360

23



DOCUMENT CONTROL

APPROVED
 W. E. ADEK
 GILBERT ASSOCIATES, INC.
 MAR 8 1973

NOM. DIA.	CORE	JOINT DEPTH	JOINT DIA.	A	B	SELL O.D.
4 1/2"	3.085"	4 1/8"	5 1/4"	10 ±	2 1/2"	5 3/4"

WELD METHOD
 REPEAT PROCEDURE UNTIL LENGTH OF SEIGING RING IS WELDED TO BELL RING, EXCEPT BOTTOM 12"

WEDGE RING TO BE SUPPLIED IN ONE SECTION.

POOR ORIGINAL

POOR ORIGINAL

FIELD CHANGE TO CONSTRUCTION PROCEDURE

Construction Procedure No. JAJ-W52 Date July 14, 1972

Title Work Procedure - Installation of Nuclear Service and Decay Heat Sea

Field Change No. 7 J. R. Amundson 10/5/73
Originator Date

Reason For Change:

Void Field Change #6 to Procedure JAJ-W52, and write Field Change #7 to have the welding of the wedge ring to bell ring meet the vendors approved welding requirements.

Description of Method:

Weld the wedge ring to the bell ring, to the requirements of Interp drawing D-4-390, using E-6010 Electrodes.

Visually inspect the welds to assure the 1/4" Fillet or Flush weld is free of crack.

The welding inspector will report the results of all acceptable weld on a Q-009 inspection form. Example (Piece #61 to 60).

AWS recommended Amperage for:

- 1/8" rod 75 to 125 AMPs
- 5/32 rod 110 to 170 AMPs

DOCUMENT CONTROL

Route in order shown below:

- (1) Approval: FPC Construction Supv. [Signature] 10
- (2) Notification: QC Dept. Supv. [Signature] 11
- (3) Review: GAI/QA Representative [Signature] 12
- (4) Concurrence: FPC Quality Engineer [Signature] 13
- (5) Distribution: Document Control _____

POOR ORIGINAL

Lock Joint Pipe

INTERFACE

260 CHERRY HILL ROAD / PARSIPPANY, NEW JERSEY 07054 / 201-335-1111 / TELEEX: 136421 / CABLE: INTERPACE

September 28, 1973

Florida Power Corporation
P. O. Box 14042
St. Petersburg, Florida 33733

Attention: Mr. J. Landers


Subject: Job No. CO-69-15
Red Level, Florida

Gentlemen:

We have been requested by our Mr. Burdell to comment on the welding method used at the seismic joint end of the pipe.

The seismic steel wedge ring may be welded with a flush weld rather than a fillet weld as shown on the drawings provided that the weld develops the full strength equivalent to a one-quarter inch fillet.

Very truly yours,



Harry W. Brenner
Project Engineer

EWB:cms

DOCUMENT CONTROL

48" SEISMIC JOINT IN PRESTRESSED CONCRETE
EMBEDDED CYLINDER PIPE WITH RUBBER AND
STEEL EXPANSION JOINT

DRAWING NUMBER
D-4-300
SCALE: 1/4" = 1'-0"

JOINT SEALING COMPOUND; (BY OTHERS)

MORTAR COVERING

HIGH TENSILE CIRCUMFERENTIAL
PRESTRESSED WIRE

WIRE MESH REINFORCEMENT
STEEL BELL RING

CONTROL

COVERING

CORE

RED LEVEL

NOMINAL DIA.

STEEL CYLINDER

RAM-NEK OR EQUAL (BY OTHERS)

FLORIDA POWER CORP.


CRYSTAL SPRING PLANT UNIT 3

APPROVED


GILBERT ASSOCIATES, INC.

W. E. ALBEEK

MAR 6 1973



WELD SEQUENCE



SKIP WELD METHOD

WELD 2" SKIP 6". REPEAT PROCEDURE UNTIL
FULL LENGTH OF SEISMIC RING IS WELDED
TO BELL RING, EXCEPT BOTTOM 12"

STEEL SPIGOT RING

WIRE MESH REINFORCEMENT

JOINT DIA.

JOINT DEPTH

RUBBER GASKET

STEEL WEDGE RING

NOM. DIA.	CORE	JOINT DEPTH	JOINT DIA.	A	B	BELL O.D.
48"	3" OR 5"	4 1/8"	5 1/4"	10" ±	2 1/4"	56 1/2"

WEDGE RING TO BE SUPPLIED IN ONE SECTION.

POOR ORIGINAL

80000000

Construction Procedure No. JAJ-W52 Date July 14, 1972

Title Work Procedure - Installation of Nuclear Service & Decay Heat Sea Water Underground Pipe

Field Change No. 8 J. R. Amundson 10/18/73
Originator Date

Reason For Change: Delete Para 6.6 and last four sentences of para. 6.7

Add: Pipe joint shall be sealed at a convenient time following the Manufacturers Drawing.

Ref. Drawings : D-3-682
SS-CO-69-15-7 & D-3-691
D-4-390 (See Field Change #7)

DOCUMENT CONTROL

Route in order shown below:

	Signature	Date
(1) Approval: FPC Construction Supv.	<i>[Signature]</i>	10-18-73
(2) Notification: QC Dept. Supv.	<i>[Signature]</i>	10/18/73
(3) Review: GAI/QA Representative	<i>[Signature]</i>	10/18/73
(4) Concurrence: FPC Quality Engineer	<i>[Signature]</i>	10-18-73
(5) Distribution: Document Control		

14

CONTROL DOCUMENT

PIPE DIA.	V. WEDGE JOINT LAP LENGTH	JOINT DEPTH	WIRE MESH LENGTH	WIRE SIZE
42"	1' 0"	4 1/2"	5' 0"	14
48"	1' 0"	5 1/2"	5' 0"	14

* PIPE MESHING ONLY THE BELLY END THIS
MAY STRAPPING AND LENGTH

1. ALL CY MUST BE CHECKED WITH FEELER GAGE
DURING OPERATION 45.2 IN THE SAME WAY AS
FOR REGULAR JOINT.

2. ADD 3.00' TO LAP LENGTH OF SPIGOT END AND
DEDUCT 3.00' FROM LAP LENGTH OF BELLY END
OF STANDARD FITTINGS.


FOR YOUR OWN PROTECTION
CALL US AT 1-800-368-1313

INTERNATIONAL PIPE & CERAMIC CORPORATION
LOCK JOINT PIPE PRODUCTS

RUBBER & STEEL FLEXIBLE T-JOINT
CLAMP TAPE 42" R 30"
PRESTRESSED CONCRETE EMBEDDED CYL PIPE

SCALE 1" = 6'-0"

DATE: 11/11/83



INSTALLATION TO BE PERFORMED IN THE FIELD

REMOVE CLAMP RING IF ATTACHED TO BELL

DO NOT PUSH SPIGOT HOME UNTIL WEDGE IS IN CONTACT WITH BELL

PULL CLAMP RING INTO POSITION

MEASURE GAP BETWEEN CLAMP RING SECTIONS. TOTAL OF TWO GAPS MUST BE 1/2"

PLACE RAM-NEK DIAPHRAGM WITH PAPER ATTACHED ON PIPE AND TIGHTEN STRAPPING. GRIND JOINT WITH MORTAR.

REMOVE PAPER FROM SEPARATE 18" LONG RAM-NEK PATCH AND PLACE OVER GRINDING TO COVER MORTAR WITH RAM-NEK.

WHEN ADJACENT ENDS ARE TO OVERLAP 2 3/8" FOR ALL PIPE SIZES.

VIEW OF CLAMP RING, AT CORNER

SECTION XX

POOR ORIGINAL



REV.	DESCRIPTION

DATE: 11/11/83

PIPE DIAMETER	PIPE FACE LAID LENGTH	JOINT DEPTH	PIPE LENGTH
42"	16 00	3 1/2"	16 31 1/2"
48"	16 09	3 1/2"	16 42 1/2"

PIPE HAVING ONLY THE DEEL END WELDED TO BE STANDARD LAID LENGTH.

PIPE SIZE	FACE LAID LENGTH	JOINT DEPTH	PIPE LENGTH
42"	16 00	3 1/2"	16 31 1/2"
48"	16 09	3 1/2"	16 42 1/2"



APPROVED
 GILBERT ASSOCIATES, INC.
 W. E. MEEK
 MAR 8 1973

- NOTES:
1. GASKET MUST BE CHECKED WITH FEELER GAGE THE SAME WAY AS FOR REGULAR JOINT
 2. USE SKIP WELD METHOD
 3. USE 3/4" DIA PLAN ROD
 4. USE E-COD ELECTRODES
 5. WHEN JOINT OPENINGS ARE USED WITH FIELD WELDED JOINTS, ONE SIDE OF THE JOINT SHOULD BE CLOSED AND THE OTHER SIDE KEPT AT THE "A" AMOUNT SHOWN ABOVE
 6. INTERFACE WILL NOT BE RESPONSIBLE FOR WELDED JOINTS IF THE SKIP WELD METHOD IS NOT USED. HEAT CONCENTRATIONS FROM WELDING ARE SUFFICIENT TO MELT THE RUBBER GASKET IF EXTREME CARE IS NOT USED.
 7. ADD 0.05" TO LAID LENGTH OF SPIGOT END OF STANDARD 42" FITTINGS AND 0.06" TO LAID LENGTH OF SPIGOT END OF STANDARD 48" FITTINGS.

FLORIDA POWER CORP.
 CRYSTAL RIVER PLANT UNIT 3

RUBBER & STEEL TIED JOINT			
FIELD WELDED TYPE			
12" AND 48" PRESTRESSED CONCRETE CYLINDER PIPE			
SCALE	DR. C.	APP. DATE	REV. NO.
	1-26-63	APP. J.C.P.	3-13-69
	3-13-69	APP.	3-5-69

REV.	DESCRIPTION	DATE	BY	APP.
A	CHANGE AMOUNT OF WELD DIFFERENTIATION	11-24-65		


RED LEVEL, F.A.

POOR ORIGINAL

POOR ORIGINAL

FLORIDA POWER CORP.
CRYSTAL RIVER PLANT UNIT 3

W. E. ALBER
MAR 8 1973



- NOTES:
1. BELL & BACK UP RINGS TO BE SHIPPED ON STEEL CYLINDER. SLIDE BACK CLEAR OF ENDS BEFORE FLACING CLOSURE.
 2. SEE INSTRUCTION SHEETS FOR INSTALLATION PROCEDURE.
 3. PULL BELL RINGS HOME BY CHAIN HOIST AND CABLES.
 4. FIELD WELD JOINT - SEE DWG D-3-G-1 (RED LEVEL)

GILBERT
CORP., INC. W. O. No.

FEB 26 1973

NO. 23-66	CH. 474	REV. 27-66	APP. 23	6-27-66	APP	SCALE NTS
-----------	---------	------------	---------	---------	-----	-----------

FIELD WELD JOINT - CLOSURE SURVEY W/ SEISMIC JOINT

DRAWING NUMBER	SS-CO-69-15-7
----------------	---------------

(2) CAGES OF WELDED FABRIC EACH: WIRE SIZE = 0 X 5, 1/2 X 1/2 CONCRETE COLLAR TO BE POURD AROUND CLOSURE.

NOM. DIA. 16" THRU 54" MAINTAIN APPROXIMATELY 53" DIAMETER INSIDE CAGE TO MAINTAIN APPROXIMATELY 54" DIAMETER/2 OUTSIDE CAGE TO MAINTAIN APPROXIMATELY 54" DIAMETER/2

NOMINAL DIA. 48" 58" CYLINDER THICKNESS

USE EG010 ELECTRODES