

JUL 29 1976

John F. Stolz, Chief, LWR Branch No. I, Division of Project Management

FLORIDA POWER CORPORATION CRYSTAL RIVER UNIT 3
(D/N 30-302) STATUS OF COMPLETION

Enclosed for your information is a copy of Region II's initial status report on the subject facility.

This report highlights an area which we wish to bring to your attention at this time. Please note that the report makes reference to FPC's stated plans to request issuance of an operating license prior to completion of the containment building dome repair and proof testing.

As noted, the Region is opposed to this course of action by FPC and IE Headquarters supports their position on this matter. We would view the incompleteness of the dome repair and required testing as being outside the acceptable state of plant readiness required by 50.57(a)1 and accordingly IE could not make a satisfactory finding as to plant completeness under the proposed circumstances. We would be pleased to discuss this matter with you if desired.

We will keep you informed of the licensee's progress as additional reports are received.

POOR ORIGINAL

Witnessed by
Gen W. Roy

Gen W. Roy, Chief,
Field Coordination and
Enforcement Branch
Division of Field Operations
Office of Inspection and
Enforcement

Enclosure:
(See next page)

OFFICE →	FCEB:IE	RIP:IE	FCEB:IE			
SURNAME →	GGGower	BHGrier	GW Roy			
DATE →	7/29/76	7/29/76	7/29/76			

8003170540 S

John F. Stolz

- 2 -

JUL 29 1976

Enclosure:

Memo-Mosley to Thompson
w/enclosures dtd 7/22/76

cc w/encl:

S. C. DeYoung, DPM
L. Engle, DPM

cc w/o encl:

B. H. Grier, IE
H. C. Mosley, IE:II
G. C. Gower, IE

POOR ORIGINAL

OFFICE →	FCBB:IE	RIP:IE	FCBB:IE		
SURNAM →	GCGower	BHGrier	GWRoy		
DATE →	7/ /76	7/ /76	7/ /76		