



8. Designation of Apparent Cause of Occurrence:

Design	_____	Procedure	_____
Manufacture	_____	Unusual Service Condition Including Environmental	_____
Installation/ Construction	_____	Component Failure	_____
Operator	_____		

Other (Specify) The apparent cause was due to the unstable water temperature in Lake Dardanelle during the first weather of the winter season.

9. Analysis of Occurrence:

The only noticeable Environmental Impact was the removal of the mentioned fish from the lake. These fish were disposed of through land fill operation, none were dumped into the discharge embayment.

10. Corrective Action:

Corrective action was taken in accordance with procedure 1607. This included continuous monitoring for another 24 hour period. The findings of this were that only 2251 lbs. of fish were impacted.

POOR ORIGINAL

11. Failure Data:

The circumstances of this report are similar to those reported in Non-Routine, Non-Radiological Environmental Reports No. 50-313/74-1 and 50-313/74-2.

12. Reviews and Approvals:

Reviewed and Approved by: Plant Safety Committee Yes (x) No

Plant Superintendent Yes (x) No

Reference: JWA-695 Date: 11/26/74

Reviewed by: Donald A. Ruster Date: 11/29/74  
Licensing Supervisor

Approved by: James M. Howell Date: 12-2-74  
Safety Review Committee

Approved by: William J. Conway Date: 12/2/74  
Manager of Nuclear Services

Approved by: James M. Howell Date: 12-2-74  
Director of Power Production

Approved by: J. D. Hillier Date: 12-2-74  
Senior Vice President

POOR ORIGINAL