

8005010 828



REGULATORY COPY

HELPING BUILD ARKANSAS

## ARKANSAS POWER &amp; LIGHT COMPANY

9TH &amp; LOUISIANA STREETS • LITTLE ROCK, ARKANSAS 71203 • (501) 272-4211

November 20, 1974

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

TELE COPY

Mr. A. J. Giambusso  
Deputy Director for Reactor Projects  
Director, Office of Regulation  
Office of Regulation  
United States Atomic Energy Commission  
Washington, D. C. 20545

Subject: Arkansas Power & Light Company  
Arkansas Nuclear One-Unit 1  
Docket No. 50-313  
License No. DPR-51  
Environmental Technical Specifications



Dear Mr. Giambusso:

Environmental Technical Specification (ETS) 2.1.1 limits the maximum differential temperature ( $\Delta T$ ) across the Arkansas Nuclear One-Unit 1 condenser to 15°F during normal operation with all four circulating water pumps in operation. The  $\Delta T$  is to be measured at the condenser inlet and outlet every hour utilizing the computer output or every two hours utilizing the condenser temperature recorder when the computer is inoperable.

The  $\Delta T$  measured at 75% Full Power (FP) was 18-20°F using the computer and the condenser temperature recorder. However, when the outlet temperature was measured at the end of the discharge flume (before mixing with lake water) it was found to be only 6-7°F higher than the inlet. From this, it was determined that the outlet temperature detector, which is located in the discharge pipe just outside the condenser water box, was not measuring the true average condenser outlet temperature. The assumed cause of this is thermal stratification of the water in the water box.

To alleviate this problem we plan to move the condenser outlet temperature detector to a location in the discharge flume where the circulating water will be thoroughly mixed but will be prior to mixing with the lake water. This will provide an accurate indication of the condenser  $\Delta T$  to the computer and the condenser temperature recorder.

11889

TAX PAYING, INVESTOR OWNED



MEMBER MIDDLE SOUTH UTILITIES SYSTEM

November 20, 1974


In the interim period prior to implementation of this design change, we propose to perform the following monitoring of the condenser  $\Delta T$ :

1. With the plant operating at steady state power levels, the condenser  $\Delta T$  will be monitored once each shift using measurements at the condenser inlet and near the end of the discharge flume.
2. At each power plateau reached in the Power Escalation Sequence the condenser  $\Delta T$  will be measured within two (2) hours after the power level has stabilized.
3. If the condenser inlet temperature exceeds 85°F with all four circulating water pumps running or 70°F with less than four circulating water pumps running, the condenser outlet temperature will be monitored every two (2) hours to assure that ETS 2.1.2 on maximum outlet temperature is met.

As soon as the design change can be made and implemented, we will propose a revised Environmental Technical Specification to reflect the new detector location. The proposed monitoring of once per shift rather than every two hours will help to reduce the currently high workload on plant personnel due to the testing program in progress.

Your prompt attention to this matter and concurrence with our proposed action is requested.

Very truly yours,

  
J. D. Phillips  
Senior Vice President

JDP:lt

cc: Mr. Norman C. Moseley, Director  
Directorate of Regulatory Operations  
United States Atomic Energy Commission  
Region II  
230 Peachtree Street, N.W., Suite 818  
Atlanta, Georgia 30303