

BALTIMORE GAS AND ELECTRIC COMPANY

P. O. BOX 1475

BALTIMORE, MARYLAND 21203

June 27, 1980

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Calvert Cliffs Nuclear Power Plant
Units Nos. 1 & 2, Dockets Nos. 50-317 & 50-318
Request for Amendment

- References:
- a) NRC letter dated 4/10/80 from D. G. Eisenhut to All Power Reactor Licensees, Definition of OPERABLE.
 - b) NRC Meeting Summary dated 6/18/80 from C.Y. Li to Distribution List, Offsite Power Sources.
 - c) NRC letter dated 1/14/77 from D. L. Ziemann to A. E. Lundvall, Jr., Amendments 19 and 5.

Dear Mr. Denton:

Baltimore Gas and Electric Company hereby requests an Amendment to its Operating Licenses Nos. DPR-53 and DPR-69 for Calvert Cliffs Units 1 and 2, respectively, with the submittal of the enclosed proposed changes to the Technical Specifications.

Change No. 1 (Attachment No. 1) is being requested in accordance with Reference (a) and clarifies the definition of the term OPERABLE. Inasmuch as this change is being submitted in conformance with the NRC's Model Technical Specifications, which were enclosed with Reference (a), no further discussion or justification of this change is necessary.

Change No. 2 (Attachment No. 2) is intended to allow the substitution of an installed 69 kV offsite power source in place of one of the normal (500 kV) offsite power sources in the event of a station transformer failure. This change was presented to your Staff in a recent meeting, which is summarized in Reference (b), and the attached marked-up technical specification conforms exactly to the guidance provided to us by the Staff subsequent to that meeting. It should be noted that this change to the technical specifications is being requested to make the existing technical specification more explicit as regards the use of the 69 kV line. The use of this line as an additional offsite power source had previously been evaluated and approved by NRC as documented in Amendments 19 and 5 to our Unit No. 1 and 2 licenses, respectively, and the attendant NRC Safety Evaluation, Reference (c).

8007020436

The enclosed changes have been reviewed by our Plant Operations and Safety Review Committee and Off-Site Safety and Review Committee, and they have concluded that the changes will not result in an undue risk to the public health and safety.

We have determined, pursuant to 10 CFR Part 170, that Change No. 1 constitutes a Class II and a Class I amendment with associated fees of \$1,200 and \$400 and that change No. 2 constitutes a Class III and a Class I amendment with associated fees of \$4,000 and \$400. Accordingly, enclosed is BG&E Check No. A023820 in the amount of \$6,000.00.

BALTIMORE GAS AND ELECTRIC COMPANY

By:

A. E. Lundvall, Jr.

A. E. Lundvall, Jr.
Vice President, Supply

STATE OF MARYLAND:

: TO WIT:

CITY OF BALTIMORE:

Arthur E. Lundvall, Jr. being duly sworn stated that he is Vice President of the Baltimore Gas and Electric Company, a corporation of the State of Maryland; that he executed the foregoing Amendment for the purposes therein set forth; that the statements made in said Amendment are true and correct to the best of his knowledge, information and belief; and that he was authorized to execute the Amendment on behalf of said corporation.

WITNESS My Hand and Notarial Seal:

Luth W. Greese

My Commission expires:

July 1, 1982

- cc: J. A. Biddison, Esquire
- G. F. Trowbridge, Esquire
- Messrs. E. L. Conner, Jr. - NRC
- R. E. Architzel - NRC