

(412) -56-6000 July 3, 1980

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1

Docket No. 50-334

Revision to Proposed Technical Specification For NPSH Modifications

## Gentlemen:

Enclosed are three (3) signed originals and thirty-seven (37) copies of a revision to the proposed technical specifications for NPSH modifications to the Low Head Safety Injection and Recirculation Spray Pumps.

The purpose of this revision is to provide the flow and pressure acceptance criteria for the Quench Spray Pumps surveillance.

## Safety Evaluation

This change provides the assurance that the Quench Spray Subsystem will perform its intended safety function by periodically testing the system. The test criteria are established so that an adequate flow and sufficient discharge pressure are developed to ensure pump operability.

Very truly yours,

C. N. Dunn

Vice President, Operations

cc: Mr. D. A. Beckman, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, Pennsylvania 15077

U.S. Nuclear Regulatory Commission c/o Document Management Branch Washington, D.C. 20555 Attest:

Thomas Welfer, Jr. Secretary

COMMONWEALTH OF PENNSYLVANIA)

) SS:

COUNTY OF ALLEGHENY

(CORPORATE SEAL)

> DONALD W. SHANNON, NOTARY PUBLIC PITTSBURGH, ALLEGHENY COUNTY MY COMMISSION EXPIRES JUNE 7, 1983 Member, Pennsylvania Association of Notaries