OPERATING DATA REPORT

DOCKET NO. 050-298 DATE July 1, 1980 COMPLETED BY P. L. Ballinger TELEPHONE 402-825-3811

OPERATING STATUS

1. Unit Name:
Cooper Nuclear Station
Notes

2. Reporting Period:
June 1980
Notes

3. Licensed Thermal Power (MWt):
2381
1000

4. Nameplate Rating (Gross MWe):
836
1000

5. Design Electrical Rating (Net MWe):
778
1000

6. M
Image: Image:

8. If Cha. yes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: Turbing modifications to remove cracked turbine discs and to replace turbine blades and discs with pressure controlling baffle plates resulted in reduced generating capacity

9. Power Level To Which Restricted, If Any (Net MWe): _____None___

10. Reasons For Restrictions, If Any: _None

	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period	720.0	4,367.0	52,608.0
12. Number Of Hours Reactor Was Critical	659.3	2,105.3	43,342.6
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	616.7	2,054.4	42.530.0
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,211,064.0	4.289 584.0	80,471,310.0
17. Gross Electrical Energy Generated (MWH)	329.828.0	1.34. 3.0	25.886.871.0
18. Net Electrical Energy Generated (MWH)	315,966.0	1,297 194.0	24,955,371.0
19. Unit Service Factor	85.1	47.0	80.8
20. Unit Availability Factor	85.7	47.0	80.8
21. Unit Capacity Factor (Using MDC Net)	69.1	46.8	74.7
22. Unit Capacity Factor (Using DER Net)	56.4	38.2	61.0
23. Unit Forced Outage Rate	0.9	1.4	4.4

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

None

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _

INITIAL CRITICALITY

26. Units In Test Status (Prior to Commercial Operation):

Forecast

INITIAL ELECTRICITY COMMERCIAL OPERATION





Achieved

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	050-298			
UNIT	Cooper Nuclear Station			
DATE	July 1, 1980			
COMPLETED BY	P. L. Ballinger			
TELEPHONE	402-825-3811			

.

AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
0	17	575
0	18	555
0	19	546
3	20	547
37	21	541
201	22	374
324	23	500
355	24	529
443	25	621
547	26	626
585	27	621
559	28	615
566	29	598
566	30	601
553	31	
556		

INSTRUCTIONS

MONTH June

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. _050-298 UNIT NAME <u>Cooper Nuclear</u> Station DATE July 1, 1980 COMPLETED BY P. I. Ballinger TELEPHONE 402-825-3811

.

REPORT MONTH __June_

	and the second			-			1		
No.	Date	Type ¹	Duration (Hours)	Reason?	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
80-5	800301	s	55.8	с	2	NA	NA	NA	1980 Refueling and Maintenance Outage
80-6	800604	F	5.9	A	3	NA	NA	NA	Reactor scram from low reactor water level following reactor feedwater pump overspeed trip. Malfunctioning reactor feed pump controller problem was corrected and reactor returned to operation.
80-7	800622	s	NA	н	NA	NA	NA	NA	Power was reduced to allow adjustment of the control rod pattern.
1 F: F S: 5 (9/77)	orced 'uled	2 Reas A-Ec B-M C-Ri D-R E-O F-A G-O H-O	son: quipment F aintenance efueling egulatory F perator Tra dministration perational 1 ther (Expla	failure (I or Test testriction ining & re Error (E in)	Explain) m License Exa xplain)	mination	3 Metho 1-Man 2-Man 3-Auto 4-Otho	d: ual ual Scram. omatic Scram. rr (Explain)	4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG- 0161) 5 Exhibit 1 - Same Source

(9/77)

COOPER NUCLEAR STATION OPERATIONS NARRATIVE JUNE 1980

* *, * *

Startup for Cycle 6 began on June 3, 1980 and first reactor criticality occurred at 0748 hours. Maintenance work on the turbine resulted in removal of 12 rows of low pressure turbine blades. Pressure controlling baffle plates were installed in the turbine to allow continued operation until replacement turbine rotors can be obtained from manufacturer. A reduced electrical generating capacity of approximately 140 MWe has resulted from removal of the 12 rows of turbine blades.

Reactor scram occurred at 2349 hours, June 4, 1980 resulting from reactor low water level scram signal. Reactor feed pump tripped during the main turbine overspeed trip testing. A malfunctioning RFP controller allowed the feed pump turbine speed to increase to trip level. Feedwater flow was lost to the reactor resulting in a low water level scram. Control problem with feed pump corrected and returned reactor to criticality at 0542 hours, June 5, 1980.

Plant operated the remainder of June with no unscheduled power reduction and with only one scheduled power reduction on June 22 to allow for adjustment of the control rod pattern.