## LICENSEE EVENT REPORT

)	CONTROL BLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION
0 1 7 8	N E C P R 1 2 0 0 - 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5 57 CAT 58
0 1 7 8	REPORT L 6 0 5 0 0 0 2 9 8 7 0 5 1 6 8 0 8 0 6 1 3 8 0 9
0 2	During performance of surveillance procedure 6.3.10.7, Primary Containment Isolation
0 3	Valve Timing, RHR-MO-57, the RHR discharge to radwaste inboard isolation, failed to
0 4	close in the time required by Tech. Specs. The redundant isolation valve met the
0 5	time limit placed on it. This event presented no adverse consequences from the
0 6	standpoint of public health and safety.
0 7	
7 8	9 SYSTEM CAUSE CAUSE COMP. VALVE
0 9	CODE SUBCODE COMPONENT CODE SUBCODE SU
	17 REPORT   8 0
	ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER    D   18   Z   19   Z   20   Z   21   0   0   0   N   23   24   26   27   28   29   30   31   32   COMPONENT MANUFACTURER    D   18   Z   19   Z   20   Z   21   0   0   0   0   N   23   24   24   25   26   27   28   29   30   31   32   COMPONENT MANUFACTURER    D   18   Z   19   Z   20   Z   21   37   40   41   23   42   43   47   47   47   47   47   47   47
10	Principle action was to adjust stem travel so that valve met limits. Review of valve
11	history showed limits adjusted February 7, 1980 which accounted for increased stroke
12	time. Stroke time was not checked after maintenance which resulted in the valve ex-
1 2	ceeding time limits during next scheduled test. Personnel were reinstructed to
7 8	verify stroke time after maintenance of T.S. related valves.
15	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 Operator Observation
RI	2 10 12 17 44 45 46 10 12 17 44 45 46 10 10 12 17 17 19 10 10 10 10 10 10 10 10 10 10 10 10 10
7 8	9 10 11 44 45 80 PERSONNEL EXPOSURES
1 7	NUMBER TYPE DESCRIPTION (39) NA 11 12 13 80
	PERSONNEL INJURIES NUMBER DESCRIPTION 41
7 B	9 11 12 LUSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
7 8	Z 42 NA 80
20	PUBLICITY SEAUED DESCRIPTION 45  NA  NA  NA  NA  NA  NA  NA  NA  NA  N
н	9 10 68 69 80-3 NAME OF PREPARER Paul F. Doan PHONE: 402-825-3811