

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 323-5341



Alabama Power

the southern electric system

F. L. CLAYTON, JR.
Senior Vice President

June 30, 1980

Docket No. 50-364

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. A. Schwencer

JOSEPH M. FARLEY NUCLEAR PLANT - UNIT 2
SEISMIC QUALIFICATION REVIEW

Gentlemen:

Enclosed is the detailed qualification summary information for each of the non-NSSS mechanical and electrical equipment items selected by the Seismic Qualification Review Team for further evaluation.

Should you have any questions, please advise.

Yours very truly,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

CLB/rt

Enclosure

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge
Mr. L. Kintner (w/enclosure)
Mr. W. Bradford

BoS, 11

8007090 *237*

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Qualification Summary of Equipment

- I. Plant Name: J. M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name REACTOR CONTAINMENT AIR COOLER UNITS

1. Scope: NSSS BOP
2. Model Number: NA Quantity: 4
3. Vendor: American Air Filter
4. If the component is a cabinet or panel, name and model No. of the devices included:

5. Physical Description a. Appearance Air Cooler Unit
b. Dimensions 11'-5" x 11'-5"
c. Weight 27.820#
6. Location: Building: Containment
Elevation: 155'
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: NA F/B: _____ V: _____
9. a. Functional Description: Cool Containment during normal operation and following a LOCA
b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: SS-1102-14

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: _____

Test and/or Analysis by American Air Filter IEP 495
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): FNP Seismic spectra- See SS-1102-14

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-axis _____

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name REACTOR CAVITY HYDROGEN DILUTION FANS

1. Scope: NSSS BOP
2. Model Number: NA Quantity: 2
3. Vendor: Joy Manf.
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Fan
- b. Dimensions 25'L x 13.5"R
- c. Weight Fan 385 lbs. Motor 130 lbs./Steel Inlet Bell & Screen 15 lbs.
6. Location: Building: Containment
- Elevation: 129'
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: NA F/B: _____ V: _____
9. a. Functional Description: Dilution of Hydrogen in Reactor Cavity
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: SS-1102-106

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Joy-Manf. Company
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): FNP Seismic Analysis- See SS-1102-106

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis _____

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

- Static Analysis Equivalent Static Analysis
 Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
 Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
 (specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. <u>Identification Location</u>	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable

B. <u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
.0035in.	Shaft	None

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name EMERGENCY AIR COMPRESSOR

1. Scope: NSSS BOP
2. Model Number: 10T3NLE10 Quantity: 2
3. Vendor: Ingersoll-Rand Company
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description
- a. Appearance Type 30 Air Compressor
- b. Dimensions 70'L x 66'H 26"W
- c. Weight 1,500#
6. Location. Building: Auxiliary
- Elevation: 100'
7. Field Mounting Conditions Bolt (No. 8, Size 5/8")
 Weld (Length)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: NA F/B: V:
9. a. Functional Description: Redundancy to Main Air Compressor
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both Possible use after steam line break
10. Pertinent Reference Design Specifications: SS-1102-136

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Wyle Laboratories 42746-1
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs) See SS-1102-136
FNP Seismic Response Spectrum-

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis _____

3. No. of Qualification Tests: OBE 4 SSE 1 Other _____
(specify)

4. Frequency Range: 1 Hz - 40 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = NA F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. 8, Size 5/8") Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then

Complete:

1. Description of Test including Results: _____

2. Method of Analysis:
 Static Analysis Equivalent Static Analysis
 Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
 Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRS
 Other: _____
 (specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A.	<u>Identification</u>	<u>Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

DAMPING 1/2%

J/N 42746
Page _____
Date 6-8-74

K⁰² LOGARITHMIC 46 7403
3 X 3 CYCLES
KEUFFEL & ESSER CO.




FIGURE 1
Frequency (Hz)

CUSTOMER Ingersoll-Rand AXIS Vertical and Lateral
SPECIMEN _____ LOCATION NO. VCA
S/N _____ TEST RUN NO. 9

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

DAMPING 1/2%

J/N 42746
Page _____
Date 6-8-74

LOGARITHMIC
3 & 3 CYCLES
467403
REUPPEL & KESER CO.
MILWAUKEE, WIS. U.S.A.




FIGURE 2
Frequency (Hz)

CUSTOMER Ingersoll-Rand AXIS Vertical and Lateral
SPECIMEN _____ LOCATION NO. HCA
S/N _____ TEST RUN NO. 9

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

DAMPING 1/2%

J/N 42746

Page _____

Date 6-8-74

K&E LOGARITHMIC
3 1/2 X 5 1/2 IN.
MEUFFEL & ESSER CO.




FIGURE 3
Frequency (Hz)

CUSTOMER Ingersoll-Rand

AXIS Longitudinal/Vertical

SPECIMEN _____

LOCATION NO. VCA

S/N _____

TEST RUN NO. 14

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

J/N 42746

Page _____

Date 6-8-74

DAMPING _____

K-E LOGARITHMIC 46 7403
1.0 3.0 10.0
REDFIELD & BERRY CO.




FIGURE 4
Frequency (Hz)

CUSTOMER Ingersoll-Rand

AXIS Longitudinal/Vertical

SPECIMEN _____

LOCATION NO. HCA

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name COMPONENT COOLING WATER HEAT EXCHANGER

1. Scope: NSSS BOP
2. Model Number: NA Quantity: 3
3. Vendor: Struthers Wells Corporation
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance Tubular Heat Exchanger
 b. Dimensions 52" I.D. x 29'-0" Long
 c. Weight 53,000 lbs dry 84,250 Flooded
6. Location: Building: Auxiliary
Elevation: 100'
7. Field Mounting Conditions Bolt (No. 4, Size 1")
 Weld (Length)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 25.9 Hz F/B: V:
9. a. Functional Description: To transfer heat from the component cooling water to service water
 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: SS-1302-11

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Struthers Wells Corporation
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat
2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name SUMP PUMP

1. Scope: NSSS BOP
2. Model Number: GVBS-3K Quantity: 9
3. Vendor: Crane Chempump
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance Sump Pump
 b. Dimensions 12'-1/8" x 10'-3/4" (Varies)
 c. Weight 102.8# (Varies)
6. Location: Building: Auxiliary & Containment
Elevation: Varies with location
7. Field Mounting Conditions Bolt (No. _____, Size _____) Varies
 Weld (Length _____)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: NA F/B: V:
9. a. Functional Description: To pump water out of a sump.
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both Leak Detection
10. Pertinent Reference Design Specifications: SS-1302-12

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: NA

Test and/or Analysis by Chempump A-18219
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): FNP Response Spectra- See SS-1302-12

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J. M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel PWR _____

II. Component Name BORIC ACID TANKS

1. Scope: NSSS BOP
2. Model Number: NA Quantity: 2
3. Vendor: Mitternight Boiler Works, Inc.
4. If the component is a cabinet or panel, name and model No. of the devices included: _____

5. Physical Description a. Appearance Vessel Cylindrical
- b. Dimensions 25'H x 12'-9"Ø
- c. Weight 13,670#

6. Location: Building: Auxiliary
- Elevation: 100'

7. Field Mounting Conditions Bolt (No. 8, Size 1.5"Ø)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: 50 Hz F/B: _____ V: _____

9. a. Functional Description: Containment of Boric Acid

- b. Is the equipment required for Hot Standby Cold Shutdown
 Both

10. Pertinent Reference Design Specifications: SS-1102-30

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X _____

Combination of Test and Analysis: _____

Test and/or Analysis by URS/John A. Blume Ass. Engineer
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): FNP Seismic Spectra- See SS-1102-30

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution
 Mass Point

4. Computer Codes: _____
Frequency Range and No. of modes considered: NA
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: NA Basis for the damping used: _____

7. Support Considerations in the model: Support lugs

8. Critical Structural Elements: See also SS-1102-30

A. Identification	Location	Governing Load		Total Stress	Stress Allowable
		or Response Combination	Seismic Stress		
	Full conditions			1.8ksi	17.7ksi

8. Max. Deflection Location Effect Upon Functional Operability

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name LIMIT SWITCH

1. Scope: NSSS BOP
2. Model Number: EA-170 Quantity: _____
3. Vendor: NAMCO
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Limit Switch Box
- b. Dimensions 3"x2"x1"
- c. Weight Less than 11 lbs.
6. Location: Building: Auxiliary
- Elevation: Varies according to location
7. Field Mounting Conditions Bolt (No. 2, Size #10) Varies according to location
- Weld (Length _____)
- _____
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: NA F/B: _____ V: _____
9. a. Functional Description: Position indication
- b. Is the equipment required for Hot Standby Cold Shutdown
- Both NA
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Acme-Cleveland Development Company
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 1 - 35 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)

No
6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting: 0.6g + 9.52g over range of 1-35 Hz

1. Bolt (No. 2, Size #10) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: The trip position of each switch remained within the required limit.

10. Other tests performed (such as fragility test, including results): Fragility, Sine Sweep, Sine Dwell - All switches performed with no malfunctions for all tests

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. Identification	Location	Governing Load			
		or Response	Seismic	Total	
		Combination	Stress	Stress	Stress Allowable

B. Max. Deflection Location Effect Upon Functional Operability

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR y
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name SERVICE WATER PUMP

1. Scope: NSSS BOP
2. Model Number: 27CC Quantity: 5
3. Vendor: Johnston Pump Company
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Service water pump
b. Dimensions 30"Ø / Head-175'
c. Weight 1127#
6. Location: Building: Service water structure
Elevation: 191'-6"
7. Field Mounting Conditions Bolt (No. 4, Size 1 3/8")
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 16.33 Hz F/B: _____ V: 145 Hz
9. a. Functional Description: To pump service water into
cooling system
b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: SS-1105-7

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Nickerson/Brown Consulting Engineers
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of Seismic and Operating

2. Required Response Spectra (attach the graphs): See SS-1105-7

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat
2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then

Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: BMDAT, CANBM, SCANBM, MOMTS, BEAM, MDLDF, SMOMTS
Frequency Range and No. of modes considered: 5 modes

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: 3%OBE, 5%DBE Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. Identification	Location	Governing Load			
		or Response Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Deflection	Location	Effect Upon Functional
		Operability

Qualification Summary of Equipment

I. Plant Name: J.M. Farley Unit 2 Type:
 1. Utility: Alabama Power Company PWR X
 2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name EXCESS FLOW CHECK VALVE

1. Scope: NSSS BOP
2. Model Number: FVL 48F Quantity: _____
3. Vendor: Marotta Scientific Controls
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description
 - a. Appearance 3" Nom Dia. Solenoid Opgr. TEE BODN Check VLI
 - b. Dimensions 10"(L) x 4.25"(W) x 7.75"(H)
 - c. Weight NA
6. Location: Building: CTMT Bldg.
Elevation: 108'-6" P-23
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length 13")

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: NA F/B: _____ V: _____
9. a. Functional Description: Limit excess flow from containment.

 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
 None
10. Pertinent Reference Design Specifications: _____
SS-1102-127

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by American Environments Company, Inc.
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random
 sine beat
2. Single Axis Multi-Axis continuous sine sweep & dwell

3. No. of Qualification Tests: OBE _____ SSE _____ Other 2 (valve open, valve closed) (specify)

4. Frequency Range: 3 to 33 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 3g F/B = 3g V = 3g

7. Laboratory Mounting: Clamped between Flanges

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No modifications, No physical damage - Post seismic operation revealed no malfunctions

10. Other tests performed (such as fragility test, including results): _____

Hydro test - No physical damage or seat leakage

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name RELIEF VALVE

1. Scope: NSSS BOP
2. Model Number: NA Quantity: _____
3. Vendor: Lonergan
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description
- a. Appearance 3/4" x 1" 150# Angle Relief Valve
- b. Dimensions 9" x 6"
- c. Weight 9 lbs.
6. Location: Building: Auxiliary
- Elevation: _____
7. Field Mounting Conditions Bolt (No. 4, Size 5/8")
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: 202 Hz F/B: _____ V: _____
9. a. Functional Description: Overpressurization relief
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
 None
10. Pertinent Reference Design Specifications: _____

7597-20-M6i

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X _____

Combination of Test and Analysis: _____

Test and/or Analysis by Loneragan
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)

No
6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:
[X] Static Analysis [] Equivalent Static Analysis
[] Dynamic Analysis: [] Time-History
[] Response Spectrum
3. Model Type: [] 3D [X] 2D [] 1D
[] Finite Element [X] Beam [] Closed Form Solution

4. [] Computer Codes: _____
Frequency Range and No. of modes considered: _____
[X] Hand Calculations

5. Method of Combining Dynamic Responses: [] Absolute Sum [] SRSS
[] Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: Flange

8. Critical Structural Elements:

A.	<u>Identification</u>	<u>Location</u>	Governing Load	Seismic	Total	Stress
			or Response			
	Cast Body					16,200

Cast Body

16,200

B. Max. Deflection Location Effect Upon Functional Operability

Not Calculated

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
 1. Utility: Alabama Power Company PWR X
 2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name CONTAINMENT PURGE ISOLATION VALVE

1. Scope: [] NSSS [X] BOP
 2. Model Number: 48" NRIA w/BETTIS T520-SR2 Quantity: 4
 3. Vendor: Henry Pratt Company
 4. If the component is a cabinet or panel, name and model No. of the devices included: _____
 5. Physical Description a. Appearance Butterfly Valve 48" I.D.
 69 11/16" (H) X 59 1/2" (W) (Valve Only)
 b. Dimensions 98 5/8" (H) X 115 3/4" (W) X 20" (D) (Valve & Actuator)
 c. Weight 6550# valve and operator
 6. Location: Building: Auxiliary Building - V281, V284
 Containment Building - V282, V283
 Elevation: 130'-6"
 7. Field Mounting Conditions [X] Bolt (No. 44, Size 1")
 [X] Weld (Length 138")
 [] _____
 8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
 S/S: NA F/B: _____ V: _____
 9. a. Functional Description: Containment Air supply & exhaust closing
 time 5 seconds - fail closed
 b. Is the equipment required for [] Hot Standby [] Cold Shutdown
 [] Both Neither
 10. Pertinent Reference Design Specifications: _____
 SS-1102-50

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: _____

Test and/or Analysis by Henry Pratt Company - Report # D-0006-1
(name of Company or Laboratory & Report No.)

V. Vibration Input:

- 1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
- 4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

- 1. Single Frequency Multi-Frequency: random sine beat
- 2. Single Axis Multi-Axis _____

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____

Frequency Range and No. of modes considered: _____

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: Body assumed fixed

8. Critical Structural Elements:

		Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A.	<u>Identification Location</u>				

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
----	------------------------	-----------------	---

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name 60" MOTOR OPERATED BUTTERFLY VALVE

1. Scope: NSSS BOP
2. Model Number: Triton-XL Quantity: 6
3. Vendor: Henry Pratt Company
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance _____
- b. Dimensions 73" Dia., 20" length
- c. Weight Operator - 1100# Valve - 8800#
6. Location: Building: River water structure and valve box at S.W. structure
Elevation: 105'-6" and 183'-0"
7. Field Mounting Conditions Bolt (No. 52, Size 1-3/4")
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: _____ F/B: _____ V: _____
9. a. Functional Description: On/off service - separates river water pump trains; river water bypass to pond
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: _____

Test and/or Analysis by Henry Pratt Company
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of 1 & 2

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat
2. Single Axis Multi-Axis _____

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name PRESSURE SWITCH

1. Scope: NSSS BOP
2. Model Number: 604GCX Quantity: 4
3. Vendor: Custom Component Switches
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance Rectangular Aluminum Box with Press Por and Conduit Conn.
 b. Dimensions 6-1/4" x 4-3/4" x 2-3/4"
 c. Weight 1 1/2 lbs.
6. Location: Building: River Water Structure
Elevation: 105'-0"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
No resonance found
S/S: at frequencies 5 - 150 Hz F/B: # as S/S V: # as S/S
9. a. Functional Description: Actuates alarm on 20psi decreasing river water header pressure
 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Custom Component Switches
(name of Company or Laboratory & Report No.)
QTR604GCJRO -5155-01)

V. Vibration Input:

- 1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
- 4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP Response Spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

- 1. Single Frequency Multi-Frequency: random sine beat
- 2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 5 - 150 - 5 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 3g F/B = 3g V = 3g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Pressure switch met or exceeded all requirements per SQS IEEE standard 344-1971; no electrical contact-chatter or premature actuation due to vibration

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

I. Plant Name: J.M. Farley Unit 2 Type:
 1. Utility: Alabama Power Company PWR X
 2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name 4.15KV SWITCHGEAR

1. Scope: NSSS BOP

2. Model Number: NA Quantity: 1 Set

3. Vendor: Allis-Chalmers

4. If the component is a cabinet or panel, name and model No. of the devices included: Refer to master parts list for busses 2F, 2G, 2H, 2J, 2K and 2L

5. Physical Description a. Appearance Vertical Panel
 b. Dimensions Approx 26"W x 71"H x 74"D (each panel)
 c. Weight Approx 2100 pounds - each panel

6. Location: Building: 2F,2G-Aux bldg. elevation 139'-0" & 121'-0"
2H,2J-Diesel bldg. elevation 155'-0"
Elevation: 2K,2L-Serv.water bldg.elevation 188'-6"

7. Field Mounting Conditions Bolt (No. _____, Size _____)
NA Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 7.5 Hz F/B: 9Hz, 13Hz V: None

9. a. Functional Description: Class 1E 4.16 KV Switchgear

b. Is the equipment required for Hot Standby Cold Shutdown
 Both

10. Pertinent Reference Design Specifications: _____
SS-1102-38

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____
Allis Chalmers Seismic Test Facility

Test and/or Analysis by Test Report 40012-PR-3004 and 8971-ST-937
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): OBE & SSE for 3 locations

3. Required Acceleration in Each Direction: See FNP Response Spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat sine dwell
2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other 20 each axis
(specify)

4. Frequency Range: 1 - 30 Hz (Sine dwell)

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 0.5g F/B = 0.5g V = 0.5g

7. Laboratory Mounting:

1. Bolt (No. 8, Size 5/8") Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Acceptable - no structural damage - some acceptable relay chatter

10. Other tests performed (such as fragility test, including results): _____
resonance search at 0.2g input and 0.5 octave per minute

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name MEDIUM VOLTAGE ELECTRICAL PENETRATION

1. Scope: NSSS BOP
2. Model Number: 127D1643 Quantity: 6
3. Vendor: General Electric Company
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description: a. Appearance Cylindrical Weldment
 b. Dimensions Approx 60" (not including J Boxes)
 c. Weight _____
6. Location: Building: Containment
Elevation: 139'-0"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weid (Length 100% Circumferential)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: no resonant frequen- F/B: # S/S Y: # S/S
cies below 33Hz
9. a. Functional Description: Pressure tight containment penetration
for electrical circuits
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____
SS-1102-64

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

San Jose Test Facility

Test and/or Analysis by General Electric Company
(name of Company or Laboratory & Report No.)

V. Vibration Input:

- 1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
- 4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): OBE & SSE RRS for containment @ elevation 155'-0"

3. Required Acceleration in Each Direction:

S/S = .12g ZPA F/B = .11g ZPA V = .108g ZPA

VI. If Qualification by Test, then Complete:

- 1. Single Frequency Multi-Frequency: random sine beat sine dwell
- 2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other 96 sine dwell
20 sine beat
(specify)

4. Frequency Range: 1 - 33 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = .25g F/B = 1.0g V = 0.5g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____
100% Circumferential

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Acceptable - no structural damage - no pressure decay, no electrical malfunctions

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:
 Static Analysis Equivalent Static Analysis
 Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
 (specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

		Governing Load			
		or Response	Seismic	Total	Stress
A.	<u>Identification</u>	<u>Location</u>	<u>Combination</u>	<u>Stress</u>	<u>Stress Allowable</u>

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
----	------------------------	-----------------	---

Qualification Summary of Equipment

I. Plant Name: J.M. Farley Unit 2 Type:

1. Utility: Alabama Power Company PWR x

2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name POWER CENTER TRANSFORMER

1. Scope: [] NSSS [x] BOP

2. Model Number: PAV0123 & PAV0126 Quantity: _____

3. Vendor: Westinghouse Electric Corporation

4. If the component is a cabinet or panel, name and model No. of the devices included: NA

5. Physical Description a. Appearance Metal enclosed structure

PAV 0126 35" x 20 1/2" x 62-3/4"

b. Dimensions PAV 0123 44 1/2" x 25 1/2" x 78"

c. Weight PAV0123 3100 lbs. PAV0126 1510 lbs.

6. Location: Building: Auxiliary Building, River Intake

Elevation: Aux. Bldg. 121', 139' & 155' River Intake- 102'

7. Field Mounting Conditions [] Bolt (No. _____, Size _____)

NA [] Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S: 10Hz F/B: 10Hz V: None

9. a. Functional Description: Part of Power Distribution System

b. Is the equipment required for [] Hot Standby [] Cold Shutdown

[x] Both

10. Pertinent Reference Design Specifications: _____

ss-1102-44

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: _____

Combination of Test and Analysis: X

Test and/or Analysis by Westinghouse-Report #SBR-73-3
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): Response Spectra for OBE & SSE Aux. bldg. and river intake

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 0.5Hz to 25Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = $\frac{0.5g(1-5Hz)}{1.0g(5-10Hz)}$ F/B = same V = same
0.5g(10-25Hz)

7. Laboratory Mounting: NA

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Acceptable - no structural damage

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then

Complete:

1. Description of Test including Results: Prototype test of larger transformer (1500 KVA), single frequency, single axis resonance-search and sine beat

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____

Frequency Range and No. of modes considered: _____

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
 (specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. <u>Identification</u>	<u>Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>
Tie Plate	Top of core & coil		1500KVA= 643psi 1000KVA= 257psi 300KVA= 355psi		- Vibration tested

B. <u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
N/A		

Qualification Summary of Equipment

I. Plant Name: J.M. Farley Unit 2 Type:
 1. Utility: Alabama Power Company PWR X
 2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name AKD-5 LOW VOLTAGE SWITCHGEAR

1. Scope: NSSS BOP
 2. Model Number: AKD-5 Quantity: _____
 3. Vendor: General Electric Company

4. If the component is a cabinet or panel, name and model No. of the devices included: _____
as stated on bill of material

5. Physical Description a. Appearance Switchgear cubicle
 b. Dimensions Stack #1 26"x72"x30"
 c. Weight Approximately 8000#-each panel

6. Location: Building: Aux. Bldg, Service Intake Structure
Elevation: Aux Bldg. 121', 139' & 155' Service Intake 188'

7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: _____ F/B: 9 Hz V: _____

9. a. Functional Description: DC switchgear

b. Is the equipment required for Hot Standby Cold Shutdown
 Both

10. Pertinent Reference Design Specifications: _____
SS-1102-52

III. Is Equipment Available for Inspection in the Plant: [] Yes [] No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Report No. 72LSP-1

Test and/or Analysis by General Electric APPOLO Systems Dept.
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

OBE & SSE RRS - Aux. Bldg.

2. Required Response Spectra (attach the graphs): and River Intake Structure

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ r/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency [] Multi-Frequency: [] random

[] sine beat
 sine sweep

2. Single Axis [] Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other Resonance search, sine sweep
(specify)

4. Frequency Range: 5 - 500 Hz

5. TRS enveloping RRS using Multi-Frequency Test [] Yes (Attach TRS & RRS graphs)

[] No

6. Input g-level Test at S/S = 0.5g F/B = 0.5g v = 0.5g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) [] Weld (Length _____) [] _____

8. Functional operability verified: Yes [] No [] Not Applicable

9. Test Results including modifications made: Acceptable - no structural damage -
Equipment remained functional

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History

Response Spectrum

3. Model Type: 3D 2D 1D

Finite Element Beam Closed Form Solution

4. Computer Codes: _____

Frequency Range and No. of modes considered: _____

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS

Other: _____

(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A.	Identification	Location	Governing Load or Response			
			Combination	Seismic Stress	Total Stress	Stress Allowable

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
----	------------------------	-----------------	---

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Southern Co. Services BWR

II. Component Name BATTERIES

1. Scope: NSSS BOP
2. Model Number: 3DCJ-3 Quantity: 4
3. Vendor: C & D Batteries (Division of ELTRA Corporation)
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description
- a. Appearance
- b. Dimensions 5-9/32"W x 7-3/8"D x 10-5/16"H
- c. Weight 27# each
6. Location: Building: Service Water
- Elevation: 188'-9"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 in-Rack Weld (Length _____)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 27 Hz F/B: None below 33 Hz V: None below 33 Hz
9. a. Functional Description: Provide 125V.D.C. Power
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by TTI Testing Laboratories, Inc.
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 0.16g (ZPA) F/B = 0.16g (ZPA) V = 0.15g (ZPA)

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat sine dwell

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other 3 sine dwell tests
(specify)

4. Frequency Range: 27HZ, 33 Hz

5. TRS enveloping RRS vs g Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 1.6g F/B = 1.5g V = 1.3g

7. Laboratory Mounting:

1. Bolt (No. 20, Size 1/2") Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: no malfunction

10. Other tests performed (such as fragility test, including results): _____

Resonant Frequency Search

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: SCSI BWR _____

II. Component Name BATTERY CHARGERS

1. Scope: NSSS BOP
2. Model Number: 1ARR130AC3 Quantity: 2
3. Vendor: C & D Batteries (Division of ELTRA Corporation)
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance _____
 b. Dimensions 17"W x 14½"D x 12"H
 c. Weight 60#
6. Location: Building: Service Water
Elevation: 188'-9"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: None below 33 Hz F/B: None below 33 Hz V: None below 33 Hz
9. a. Functional Description: Maintain charge on 125 V.D.C. batteries.

 b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by TII Testing Laboratories, Inc.
(name of Company or Laboratory & Report No.)

V. Vibration Input:

- 1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
- 4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 0.16g(ZPA) F/B = 0.16g(ZPA) V = 0.15g(ZPA)

VI. If Qualification by Test, then Complete:

- 1. Single Frequency Multi-Frequency: random sine beat sine dwell
- 2. Single Axis Multi-Axis
- 3. No. of Qualification Tests: OBE _____ SSE _____ Other 3 sine dwell tests (specify)
- 4. Frequency Range: 27HZ, 33 Hz
- 5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No
- 6. Input g-level Test at S/S = 1.6g F/B = 1.5g V = 1.3g
- 7. Laboratory Mounting:
 - 1. Bolt (No. 8, Size 1/4") Weld (Length _____) _____
 - 8. Functional operability verified: Yes No Not Applicable
 - 9. Test Results including modifications made: no malfunction

10. Other tests performed (such as fragility test, including results): _____

Resonant Frequency Search

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____

Frequency Range and No. of modes considered: _____

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____

(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. <u>Identification</u>	<u>Location</u>	<u>Governing Load or Response Combination</u>	<u>Seismic Stress</u>	<u>Total Stress</u>	<u>Stress Allowable</u>
--------------------------	-----------------	---	---------------------------	-------------------------	-----------------------------

B. Max. Deflection Location Effect Upon Functional
Operability

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR x
2. NSSS: Westinghouse 3. A/E: SCSI BWR _____

II. Component Name BATTERY RACK

1. Scope: NSSS BOP
2. Model Number: NA Quantity: 2
3. Vendor: C & D Batteries (Division of ELTRA Corporation)
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance _____
- b. Dimensions 3'-0"W x 13 5/8"D x 30 13/16"H
- c. Weight 85#
6. Location: Building: Service Water
- Elevation: 188'-9"
7. Field Mounting Conditions Bolt (No. 6, Size 3/8")
- Weld (Length _____)
- _____
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: very large F/B: 28.6 Hz V: 56.6 Hz
9. a. Functional Description: support 20 batteries
- b. Is the equipment required for Hot Standby Cold Shutdown
- Both
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: _____

Test and/or Analysis by Alabama Power Company
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 0.16g ZPA F/B = 0.15g ZPA V = 0.15g ZPA

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis _____

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: SCSI BWR

II. Component Name DIESEL GENERATOR RELAY PANEL

1. Scope: NSSS BOP
2. Model Number: Custom Built Quantity: 5
3. Vendor: Wolfe & Mann Manufacturing Company
4. If the component is a cabinet or panel, name and model No. of the devices included: relays CFVB, HFA, HEA, RRX147, 1AV, GFD12, 1HCV, 1AC, 1CW, CEH51A, switch M4
5. Physical Description a. Appearance
- b. Dimensions 24"W x 25½"D x 90"H
- c. Weight NA
6. Location: Building: Diesel
- Elevation: 155'-0"
7. Field Mounting Conditions Bolt (No. 4, Size ½")
 Weld (Length)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: No. res found in 1-33 Hz F/B: Same as S/S V: Same as S/S
9. a. Functional Description: Diesel Protection
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Wyle Labs Report No. 42613-1
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 0.2g ZPA F/B = 0.2g ZPA V = 0.13g ZPA

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other 7 sine beat tests
(specify)

4. Frequency Range: 1.5Hz - 27 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 0.2g F/B = 0.2g V = 0.13g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: CFVB relay chattered at 1.5, 2, 4, 5 Hz otherwise structural integrity and performance was demonstrated

10. Other tests performed (such as fragility test, including results): _____

Resonance Frequency Search

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A.	<u>Identification</u>	<u>Location</u>	<u>Governing Load</u> <u>or Response</u>	<u>Seismic</u>	<u>Total</u>	<u>Stress</u>

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional</u> <u>Operability</u>

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: SCSI BWR

II. Component Name Relays for Diesel Generators

1. Scope: NSSS BOP
2. Model Number: 7012 PCL & 7022 PE Quantity: 25
3. Vendor: Agastat
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance
- b. Dimensions 3½"W x 3"D x 4½"H
- c. Weight 2#
6. Location: Building: Diesel
- Elevation: 155'
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S: NA F/B: _____ V: _____
9. a. Functional Description: Diesel Control
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Wyle Labs. - Report 43375-1
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random
 sine beat

2. Single Axis Multi-Axis
5 Tests at 2/3 fragility Level

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 0.5 Hz-33Hz 1 Full Fragility Test

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)

6. Input g-level Test at S/S = NA No F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No contact chatter greater than 100 msec

10. Other tests performed (such as fragility test, including results): _____
Fragility Test


FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

DAMPING 1% 2% 5%

46 7403

LOGANTHROPIC 3 X 3 CYCLES
MATHIAS & LINDEN CO. INC. 1964



Frequency (Hz)

AXIS 2ND SS/V

LOCATION NO. CONTROL

FULL SCALE SHOCK SPECTRUM (g Peak)


1.0 10 100 1000

DAMPING 1% 2% 5%

40 1403

165
100
50
25
12.5
6.3
3.15
1.6
0.8
0.4
0.2
0.1

Acceleration - (g peak)



0.1

Frequency (Hz)

AXIS 2ND FB/V

LOCATION NO. CONTROL

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 10 100 1000

DAMPING 1% 2% 5%




FIGURE 2

REQUIRED RESPONSE SPECTRUM
IS CURVE OF FIGURE 2 OF APPENDIX III MULTIPLIED BY 1.414

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name ESF Equipment Rm. Cooler Thermostats

1. Scope: NSSS BOP
2. Model Number: TP-8101 Quantity: _____
3. Vendor: Barber Colman
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Thermostat
- b. Dimensions 2"x4"
- c. Weight 1-2 lbs.
6. Location: Building: Auxiliary
- Elevation: Vary according to elevation (100'-121')
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: NA F/B: _____ V: _____
9. a. Functional Description: Monitor temp and regulate
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: SS-1102-11

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A. Identification	Location	Governing Load			
		or Response Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Deflection	Location	Effect Upon Functional Operability

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: SCSI BWR

II. Component Name D.C. Distribution Cabinet

1. Scope: NSSS BOP
2. Model Number: 18-2-D-93210-4 Quantity: 2
3. Vendor: ITE Imporial Corp.
4. If the component is a cabinet or panel, name and model No. of the devices included: Molded case circuit breakers EH-2-B015
5. Physical Description a. Appearance
b. Dimensions 32"width 65" height 5-3/4 depth
c. Weight NA
6. Location: Building: Service Water
Elevation: 188'9"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: _____ F/B: 12HZ No resonance
V: below 33 HZ
9. a. Functional Description: 125 v. D.C. Distribution
b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: x

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by ITE Imperial Corp. - Report R-ST5-6
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random

2. Single Axis Multi-Axis sine beat

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 1-26 HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = 0.55g F/B = 0.65g V = 0.47g

7. Laboratory Mounting:

1. Bolt (No. 4, Size 3/8") Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No malfunction

10. Other tests performed (such as fragility test, including results): _____

Resonance Frequency Search

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name Pressure Transmitter

1. Scope: NSSS BOP
2. Model Number: 59PM Quantity: 15
3. Vendor: VERITRAK/W
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description
- a. Appearance Aluminum Housing & Terminal Box
- b. Dimensions 9"x9"x9"
- c. Weight 17 lbs.
6. Location: Building: Auxiliary Building
- Elevation: 104' - 140'
7. Field Mounting Conditions Bolt (No. 2, Size 3/8")
 Weld (Length)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
No resonances
S/S: Below 35HZ F/B: # S/S V: # S/S
9. a. Functional Description: Consists of measuring cell that converts force into an AC impedance bridge unbalance
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: SS-1102-86
(Seismic, Class I)

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Westinghouse Astro Nuclear Lab - Report #SD4050
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 1.0 to 35.0 Hz

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = .5 to 4.0g F/B = .5 to 4.0g V = .33 to 2.8

7. Laboratory Mounting:

1. Bolt (No. 2, Size 3/8") Weld (Length _____) _____

3. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Performed satisfactorily (mechanically electrically)

10. Other tests performed (such as fragility test, including results): None
Resonance Frequency Search

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name Level Transmitter

1. Scope: NSSS BOP
2. Model Number: XM-36490 Quantity: 2
3. Vendor: Delaval, Gems Sensor Div.
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance Ball Float (captive)
 b. Dimensions 24"x12"
 c. Weight 50 lbs.
6. Location: Building: Containment
Elevation: 110'
7. Field Mounting Conditions Bolt (No. 8, Size 7/8")
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 15HZ F/B: 12HZ V: below 33HZ
 No resonance
9. a. Functional Description: Ball Float actuates fixed reed switches that provide a linear resistance vs position
 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: SS-1102-86
(3000CF, 62.1 PSIG, 2x10³ RADS, Seismic Class I

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Testing Lab Inc. Report
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNF response spectra

3. Required Acceleration in Each Direction: See FNF response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OSE _____ SSE _____ Other Resonance Freq. Search
Seismic Dwell Test
(specify)

4. Frequency Range: 4 to 33 HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)

6. Input g-level Test at S/S = 3.0g No Yes F/B = 3.0g V = 2.0g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) Combination

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Performed Satisfactorily

10. Other tests performed (such as fragility test, including results): None

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
 1. Utility: Alabama Power Company PWR X
 2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name Air Operated Globe Valve

1. Scope: NSSS BOP
 2. Model Number: 6" - Globe Cage Trim Quantity: 1
 3. Vendor: Hammell - Dahl
 4. If the component is a cabinet or panel, name and model No. of the devices included:

 5. Physical Description a. Appearance Large Dome Chamber
 b. Dimensions 36"
 c. Weight 218 lbs.
 6. Location: Building: Containment
Elevation: 111'
 7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

 8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 27HZ F/B: _____ V: _____
 9. a. Functional Description: Air operated Globe Valve

 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
 10. Pertinent Reference Design Specifications: SS-1102-036
(150 PSIG, 200°F OBE 3G's Horizontal and Vertical)

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X

Combination of Test and Analysis: _____

Test and/or Analysis by Hammell - Dahl Report #538
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of Gravity, Hydrodynamic

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X _____

Combination of Test and Analysis: _____

Test and/or Analysis by Hammell - Dahl Report #538
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of Gravity, Hydrodynamic

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name Air Operated Globe Valve

1. Scope: NSSS BOP
2. Model Number: 6" EP 667 Size 80 Quantity: 3
3. Vendor: Fisher Controls
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Large Control Valve
b. Dimensions 73"x25"
c. Weight 1290 lbs.
6. Location: Building: Auxiliary Building
Elevation: 141'
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 15HZ F/B: 15HZ V: 15HZ
9. a. Functional Description: Air Operated Globe Valve for main stream pressure relief
b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: SS-1102-49
(Seismic Class I)

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: _____

Analysis: X _____

Combination of Test and Analysis: _____

Test and/or Analysis by Fisher Controls Seismic Certification
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction:

S/S = 3g F/B = 3g V = 3g

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: _____

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name Solenoid Valves

1. Scope: NSSS BOP
2. Model Number: HT8320A108V Quantity: 2
3. Vendor: Automatic Switch Co.
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Brass 3 Port Body, Topmounted Col
 b. Dimensions 2"Lx4"Hx2"W
 c. Weight 1½ lbs.
6. Location: Building: River Water Structure
Elevation: 104'-0"
7. Field Mounting Conditions Boit (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: _____ F/B: _____ V: _____
9. a. Functional Description: On low air pressure from compressor, valve switches over to nitrogen bottle.
 b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Automatic Switch Co. Report #1357 - 7/20/72
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random
 sine beat
 NA

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: Minimum 20 HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = _____ F/B = _____ V = _____

7. Laboratory Mounting: 4.3g to 6.0g

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Valves did not malfunction
after u-load was applied

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name River Water Level Transmitter

1. Scope: NSSS BOP
2. Model Number: 1152DP6A22PB Quantity: 2
3. Vendor: Rosemont Engineering Co.
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Flanges & Capsule on bottom, electronic on top
- b. Dimensions 4½"Wx9"Hx4½"D
- c. Weight 12 lbs.
6. Location: Building: Roof - River Water Structure
- Elevation: 130'-9'
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 24HZ F/B: 26HZ V: 68HZ
9. a. Functional Description: Senses River level on back pressure in bubble tube, send signal to control room
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Rosemount Inc. RMT - 117145
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat Sine dwell

2. Single Axis multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other 8 sine dwell tests
(specify)

4. Frequency Range: 22HZ - 78HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 3g F/B = 3g V = 3g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Resonance found with panel mounting basket, no significant change in transmitter out put

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR

II. Component Name Pressure Switch (Used for Level Alarms)

1. Scope: [] NSSS [X] BOP
2. Model Number: 604GZ1 Quantity: 2
3. Vendor: Custom Componet Switches, Inc.
4. If the component is a cabinet or panel, name and model No. of the devices included:
5. Physical Description a. Appearance Rectangular Aluminum Box with Pressport and Conduit Conn.
 b. Dimensions 4½"Wx6½"Hx2-3/4"D
 c. Weight 24 ounces
6. Location: Building: Mounted on Roof Service Water Structure
Elevation: 206'6"
7. Field Mounting Conditions [X] Bolt (No. _____, Size _____)
[] Weld (Length _____)
[] _____
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
No resonant frequencies
S/S: found 5-150HZ F/B: #S/S V: #S/S
9. a. Functional Description: Switch gives alarm on low pond level
- b. Is the equipment required for [] Hot Standby [] Cold Shutdown
[X] Both
10. Pertinent Reference Design Specifications:

II. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by: Custom Components Sw. Inc, QTR604GCJR05155-01
(name of Company or Laboratory & Report No.)

V. Vibration Input:

- 1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
- 4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

- 1. Single Frequency Multi-Frequency: random sine beat continuous sine
- 2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 5-150-5HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No

6. Input g-level Test at S/S = 0.64g to 3g F/B = 0.64g to 3g V = 0.64g to 3g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No electrical contact chatter, premature activation, or resonant frequencies observed

10. Other tests performed (such as fragility test, including results): _____

Qualification Summary of Equipment

I. Plant Name: J.M. Farley -Unit 2 Type:

1. Utility: Alabama Power Company PWR X

2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name Float Type Level Switch

1. Scope: NSSS BOP
2. Model Number: Series SL-200 Ass. No. 83842-A2 Quantity: 10
3. Vendor: Robertshaw Controls Co. - Levelac Level Switches
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description
 - a. Appearance Cast Float Housing & Explosion Proof Switch Assembly
 - b. Dimensions 7"Wx19"Hx7"D
 - c. Weight 35 lbs.
6. Location: Building: Diesel Building - Engine Rooms & Oil Storage Rooms
Elevation: 155'-0"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)
 Bolted to Field FAB. Seismic Bracket
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
no resonance
S/S: 5 - 33HZ F/B: #S/S V: #S/S
9. a. Functional Description: Switch gives alarm on rising level in
room located
- b. Is the equipment required for Hot Standby Cold Shutdown
 Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Ogden Technology Lab, Inc. Job #70682
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random
 sine beat
 continuous sine

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 5-33 HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No 0.5g,

6. Input g-level Test at S/S = 1.5 + 5.0g F/B = 1.5 + 5.0g V = 1.5 + 5.0g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: Switch chattered on No. 1 sw.,
no chatter on No. 2 sw (Switch chatter = electrical discontinuity)
except at 33HZ from 2.0g to 5.0g.

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:
 Static Analysis Equivalent Static Analysis
 Dynamic Analysis: Time-History
 Response Spectrum
3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution
4. Computer Codes: _____
 Frequency Range and No. of modes considered: _____
 Hand Calculations
5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
 (specify)
6. Damping: _____ Basis for the damping used: _____
7. Support Considerations in the model: _____
8. Critical Structural Elements:
 Governing Load
 or Response Seismic Total Stress
 A. Identification Location Combination Stress Stress Allowable

B. <u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
---------------------------	-----------------	---

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley - Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name Pressure Switch

1. Scope: NSSS BOP
2. Model Number: 604GZM1 Quantity: 2
3. Vendor: Custom Component Switches Inc.
4. If the component is a cabinet or panel, name and model No. of the devices included: _____
5. Physical Description a. Appearance Rectangular Aluminum box with Pressport & conduit conn.
- b. Dimensions 4 1/2" W x 6 1/2" H x 2-3/4" D
- c. Weight 24 ounces
6. Location: Building: Inside Service Water Intake Structure
- Elevation: 191'-0"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
- Weld (Length _____)
- _____
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
No resonant frequencies
S/S: found 5 + 150 HZ F/B: #S/S V: #S/S
9. a. Functional Description: On low air pressure, switch gives alarm and switch over signal to solenoid valve to apply N₂ back-up supply.
- b. Is the equipment required for Hot Standby Cold Shutdown
- Both _____
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Custom Component Sw. Inc., QTR604GCJR05155-01
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only
4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random sine beat continuous sine

2. Single Axis Multi-Axis

3. No. of Qualification Tests: OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: 5-150-5 HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs) No 0.64g to 0.64g to 0.64g to

6. Input g-level Test at S/S = 3g F/B = 3g V = 3g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Weld (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No electrical contact chatter, premature actuation, or resonant frequencies observed.

10. Other tests performed (such as fragility test, including results): _____

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:
 Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____
Frequency Range and No. of modes considered: _____
 Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

		Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A.	<u>Identification</u>	<u>Location</u>			

B.	<u>Max. Deflection</u>	<u>Location</u>	<u>Effect Upon Functional Operability</u>
----	------------------------	-----------------	---

Qualification Summary of Equipment

I. Plant Name: J.M. Farley - Unit 2

Type:

1. Utility: Alabama Power Company

PWR X

2. NSSS: Westinghouse 3. A/E: Bechtel

BWR

II. Component Name Power Supply

1. Scope: NSSS BOP

2. Model Number: N11048

Quantity: 2

3. Vendor: North Electric Co.

4. If the component is a cabinet or panel, name and model No. of the devices included: N/A

5. Physical Description a. Appearance Ventilated sheet metal housing

b. Dimensions 3 1/2" x 5" x 6 1/2"

c. Weight 7 lbs.

6. Location: Building: Control Room (Aux. Bldg.)

Elevation: 157'-6"

7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)

8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

No resonance
S/S between 5-20HZ F/B: #S/S V: #S/S

9. a. Functional Description: Power Supply for level and temperature
Instrument loops

b. Is the equipment required for Hot Standby Cold Shutdown
 Both

10. Pertinent Reference Design Specifications:

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X.

1. Analysis:

2. Combination of Test and Analysis:

Test and/or Analysis by North Electric Co. 662-1780-19611
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) 5. Combination of

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = F/B = V =

VI. If Qualification by Test, then Complete:

1. <input checked="" type="checkbox"/> Single Frequency	[] Multi-Frequency:	[] random
		[] sine beat
		<input checked="" type="checkbox"/> continuous sweep

2. Single Axis [] Multi-Axis

3. No. of Qualification Tests: OBE SSE Other
(specify)

4. Frequency Range: 15 to 55 HZ

5. TRS enveloping RRS using Multi-Frequency Test [] Yes (Attach TRS & RRS graphs)
[] No

6. Input g-level Test at S/S = 0.172g to 2.32g F/B = # S/S V = # S/S

7. Laboratory Mounting:

1. Bolt (No. , Size) [] Weld (Length) []

8. Functional operability verified: Yes [] No [] Not Applicable

9. Test Results including modifications made: Power Supplies performed
satisfactorily before, during and after all tests.

10. Other tests performed (such as fragility test, including results): Shock,
temp. shock, and humidity.

VII. If Qualification by Analysis or by the Combination of Test and Analysis, then Complete:

1. Description of Test including Results: _____

2. Method of Analysis:

Static Analysis Equivalent Static Analysis

Dynamic Analysis: Time-History
 Response Spectrum

3. Model Type: 3D 2D 1D
 Finite Element Beam Closed Form Solution

4. Computer Codes: _____

Frequency Range and No. of modes considered: _____

Hand Calculations

5. Method of Combining Dynamic Responses: Absolute Sum SRSS
 Other: _____
(specify)

6. Damping: _____ Basis for the damping used: _____

7. Support Considerations in the model: _____

8. Critical Structural Elements:

A.	Identification	Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable

8. Max. Deflection Location Effect Upon Functional Operability

Qualification Summary of Equipment

- I. Plant Name: J.M. Farley Unit 2 Type:
1. Utility: Alabama Power Company PWR X
2. NSSS: Westinghouse 3. A/E: Bechtel BWR _____

II. Component Name DIFFERENTIAL PRESSURE SWITCHES

1. Scope: NSSS BOP
2. Model Number: 288A Quantity: 2
3. Vendor: Barton Instrument Corporation
4. If the component is a cabinet or panel, name and model No. of the devices included: N/A
5. Physical Description a. Appearance Dial & Switches Front, Cell on Back
 b. Dimensions 7½"W x 7½"H x 5½"D
 c. Weight 8 lbs.
6. Location: Building: River Water Structure
Elevation: 106'-6"
7. Field Mounting Conditions Bolt (No. _____, Size _____)
 Weld (Length _____)
 Bolt on Seismic Mount (Field Fab)
8. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
S/S: 38 Hz F/B: no resonance for range of frequency 1-60Hz V: # F/B
9. a. Functional Description: Switch Alarms on Decreasing ΔP across tube water piping
 b. Is the equipment required for Hot Standby Cold Shutdown
 Both
10. Pertinent Reference Design Specifications: _____

III. Is Equipment Available for Inspection in the Plant: Yes No

IV. Equipment Qualification Method: Test: X

Analysis: _____

Combination of Test and Analysis: _____

Test and/or Analysis by Wyle Lab 53178
(name of Company or Laboratory & Report No.)

V. Vibration Input:

1. Loads considered: 1. Seismic only 2. Hydrodynamic only 3. Explosive only

4. Other (Specify) _____ 5. Combination of _____

2. Required Response Spectra (attach the graphs): See FNP response spectra

3. Required Acceleration in Each Direction: See FNP response spectra

S/S = _____ F/B = _____ V = _____

VI. If Qualification by Test, then Complete:

1. Single Frequency Multi-Frequency: random

2. Single Axis Multi-Axis sine beat

3. No. of Qualification Tests: OBE _____ SSE _____ Other 11 sine dwell tests
(specify)

4. Frequency Range: 10HZ to 58HZ

5. TRS enveloping RRS using Multi-Frequency Test Yes (Attach TRS & RRS graphs)
 No

6. Input g-level Test at S/S = 3g F/B = 3g V = 2g

7. Laboratory Mounting:

1. Bolt (No. _____, Size _____) Wei. (Length _____) _____

8. Functional operability verified: Yes No Not Applicable

9. Test Results including modifications made: No resonances detected in Sw.#1,

Sw.#2 detected resonance in X-axis at 20HZ, 30HZ, and 58HZ. SW#2 relay had chatter at sine dwell at 38HZ with 3g input.

10. Other tests performed (such as fragility test, including results): _____

