



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

*Sera*

June 12, 1980

Docket No 50-261

Mr. J. A. Jones  
Senior Vice President  
Carolina Power and Light Company  
336 Fayetteville Street  
Raleigh, North Carolina 27602

Dear Mr. Jones:

The Commission has issued the enclosed Amendment No. 47 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. The amendment consists of changes to the Technical Specifications and is in response to your request dated March 6, 1979.

The amendment consists of a change to the Technical Specifications which clarifies a note on Table 3.5-3. The note allows blockage of channels ("High Differential Pressure Between any Steamline and the Steamline Header" and "Pressurizer Low Pressure and Low Level") when the Reactor Coolant System pressure is less than 2000 psig.

Copies of the Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

A handwritten signature in dark ink, appearing to read "Steven A. Varga".

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Enclosures:

1. Amendment No. 47 to DPR-23
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures  
See next page

80 07100 150

Mr. J. A. Jones  
Carolina Power and Light Company - 2 -

June 12, 1980

cc: G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

U. S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Hartsville Memorial Library  
Home and Fifth Avenues  
Hartsville, South Carolina 29550

Mr. McCuen Morrell, Chairman  
Darlington County Board of Supervisors  
County Courthouse  
Darlington, South Carolina 29535

State Clearinghouse  
Division of Policy Development  
116 West Jones Street  
Raleigh, North Carolina 27603

Attorney General  
Department of Justice  
Justice Building  
Raleigh, North Carolina 27602

Michael C. Farrar, Chairman  
Atomic Safety and Licensing  
Appeal Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Richard S. Salzman  
Atomic Safety and Licensing  
Appeal Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. W. Reed Johnson  
Atomic Safety and Licensing  
Appeal Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Director, Technical Assessment Division  
Office of Radiation Programs (AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460