

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 7 8 N C B E P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 9 14 15 25 26 30 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

0 1 7 8 L 6 0 5 0 - 0 3 2 5 7 0 6 0 7 8 0 8 0 7 1 1 8 0 9 60 61 68 69 74 75 80

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a normal tour of the Reactor Building during a refueling outage, the

0 3 | auxiliary operator found both the inner and outer doors of the 50' elevation

0 4 | air lock open. The outer door was immediately closed, and Security personnel

0 5 | were stationed at the air lock to prevent the opening of the outer door. CRD

0 6 | rebuilding was in progress at the time.

0 7 |

0 8 | Technical Specifications 3.6.5.1, 6.9.1.9b

SYSTEM CODE S A 11		CAUSE CODE E 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE E 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 0 21 22		SEQUENTIAL REPORT NO. 0 5 3 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN A 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41	
NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER A 25 43		COMPONENT MANUFACTURER X 9 9 9 26 44 47							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The inner door interlock solenoid which prevents both doors from opening simul-
1 1 taneous had a burned coil. The coil was replaced and access to the air lock was
1 2 returned. No reason could be determined for the coil burnout. This is considered
1 3 an isolated event and no further action is required.
1 4

8 9 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 H (28) 0 0 0 (29) N/A A (31) Operator Surveillance

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 6 Z (33) - (34) N/A N/A LOCATION OF RELEASE (36)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7		0	0	0	37	2	38	N/A	39

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
00040	N/A

7		8		9		11		12			
				LOSS OF OR DAMAGE TO FACIL TY		TYPE		DESCRIPTION		(43)	
1	9			Z	(42)						N/A

PUBLICITY		8007150665		NRC USE ONLY	
ISSUED		DESCRIPTION			
N		N/A			

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521