

The second second

CONNECTION TURNET AND ROWER COMPANY -ART / ARD CLICTRIC LOOKT COMPANY NEW COMPANY AND CLICTRIC LOOKTANY NEW COMPANY HERE COM P.O. BOX 270 HARTFORD, CONNECTICUT 06101 (203) 666-6911

July 9, 1980 MP-1-1564

Director Office of Management Information and Program Control U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Reference: Provisional License DPR-21 Docket No. 50-245

Dear Sir:

In accordance with Millstone Unit 1 Technical Specification 6.9.1.6, the following monthly operating data report for Millstone Unit 1 is enclosed. One additional copy of the report is enclosed.

Also enclosed is a corrected copy of the May operating data report page with the corrections noted in parenthesis. The original May operating data report page was in error due to a watt-hour meter that was not returned to its original reading after its calibration.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

Musick

E. J. Mroczka Station Superintendent Millstone Nuclear Power Station

EJM/GRH/kaf

Enclosures: (1)

cc: Director, Office of Inspection and Enforcement, Region I Director, Office of Inspection and Enforcement, Washington, D. C. (10) U. S. Nuclear Regulatory Commission, c/o Document Management Branch, Washington, D.C. 20555