

TSC

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

June 13, 1980

Docket Nos. 50-213
50-245
50-336
A01060

Mr. Boyce H. Grier, Director
Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

- References:
- (1) B. H. Grier letter to W. G. Council dated March 13, 1980, transmitting I&E Bulletin No. 80-06.
 - (2) D. L. Ziemann letter to W. G. Council dated November 29, 1978, (Docket Nos. 50-213; 50-245; and 50-336).
 - (3) W. G. Council letter to D. L. Ziemann dated January 2, 1979, (Docket No. 50-245).
 - (4) W. G. Council letter to R. Reid dated January 3, 1979, (Docket No. 50-336).
 - (5) W. G. Council letter to D. L. Ziemann dated April 27, 1979, (Docket No. 50-245).
 - (6) W. G. Council letter to R. Reid dated April 27, 1979, (Docket No. 50-336).
 - (7) D. G. Eisenhut letter to All Light Water Reactors dated September 27, 1979.
 - (8) R. Reid letter to W. G. Council dated October 30, 1979, (Docket Nos. 50-245 and 50-336).
 - (9) W. G. Council letter to D. L. Ziemann and R. Reid dated November 13, 1979 (Docket Nos. 50-213; 50-245; and 50-336).
 - (10) R. Reid letter to W. G. Council dated December 11, 1979, (Docket No. 50-336).
 - (11) W. G. Council letter to R. Reid dated January 16, 1980, (Docket No. 50-336).
 - (12) W. G. Council letter to B. H. Grier dated April 24, 1979 (Docket No. 50-336).
 - (13) W. G. Council letter to B. H. Grier dated April 24, 1979, (Docket No. 50-213).
 - (14) W. G. Council letter to B. H. Grier dated April 24, 1979 (Docket No. 50-245 response to I&E Bulletin No. 79-08).
 - (15) W. G. Council letter to D. G. Eisenhut dated October 18, 1979 (Docket Nos. 50-213; 50-245; and 50-336).
 - (16) W. G. Council letter to H. R. Denton dated November 21, 1979 (Docket Nos. 50-213; 50-245; and 50-336).
 - (17) W. G. Council letter to H. R. Denton dated December 31, 1979 (Docket Nos. 50-213; 50-245; and 50-336).

8007170 320

- (18) W. G. Council letter to H. R. Denton dated January 31, 1980 (Docket Nos. 50-213; 50-245; and 50-336).
- (19) W. G. Council letter to H. R. Denton dated December 13, 1979 (Docket No. 50-213).
- (20) W. G. Council letter to H. R. Denton dated January 17, 1980, (Docket No. 50-213).
- (21) W. G. Council letter to H. R. Denton dated February 7, 1980, (Docket No. 50-213).
- (22) H. R. Denton letter to W. G. Council dated January 2, 1980, (Docket No. 50-213).
- (23) W. G. Council letter to D. M. Crutchfield dated May 23, 1980.

Gentlemen:

Haddam Neck Plant
Millstone Nuclear Power Station, Unit Nos. 1 and 2
I&E Bulletin No. 80-06 - Engineered Safety Features Reset Control

In Reference (1), Connecticut Yankee Atomic Power Company (CYAPCO) and Northeast Nuclear Energy Company (NNECO) were requested to investigate the applicability of Staff concerns regarding the reset logic associated with all engineered safety feature components.

Reference (1) alludes to previous NRC communications relating to the subject Bulletin including NRR generic letters, TMI-related I&E Bulletins, and NUREG-0578. To facilitate Staff review of this issue, relevant docketed correspondence has been researched yielding the following information. References (2) through (11) relate to the subject of containment venting and purging for all three operating units and the issue of ESF components for Millstone Unit No. 2 only. References (12) through (14) relate to responses to the I&E Bulletin Nos. 79-06 and 79-08 series. References (15) through (18) relate to responses to the short-term lessons-learned requirements. Finally, References (19) through (21) relate to the Show Cause Order transmitted by Reference (22).

Reference (1) identifies three specific action items which are addressed as follows.

Item (1)

Review the drawings for all systems serving safety-related functions at the schematic level to determine whether or not upon the reset of an ESF actuation signal, all associated safety-related equipment remains in its emergency mode.

Response

The drawings for all systems serving safety-related functions have been reviewed at the schematic level to determine whether or not upon reset of an ESF actuation signal all safety-related equipment remains in its emergency mode. This review has been completed as documented in Attachments 1, 2, and 3, for the Haddam Neck Plant, Millstone Unit No. 1, and Millstone Unit No. 2, respectively. For each component, the following information is provided.

- (1) Equipment number
- (2) Equipment description
- (3) Schematic drawing number
- (4) Initiating engineered safety feature actuation signal
- (5) Fulfillment of acceptance criteria

A component was determined to be acceptable provided that reset of an ESF actuation signal did not result in a change of state for that component.

For the Haddam Neck Plant, the attachment indicates that no components with unacceptable reset logic were identified. In accordance with our commitment of Reference (23), the containment isolation valves associated with the reactor coolant pump auxiliaries are being removed from the high containment pressure and safety injection system actuation circuits. As such, the seven valves associated with these systems are not addressed in the attachment.

For Millstone Unit No. 1, a total of four components were found to be in non-compliance with the acceptance criteria. These are Items 13 - 16 of Attachment 2. The disposition of these components is provided in the response to Item 3 of Reference (1).

For Millstone Unit No. 2, as indicated on the attached sheets, Items 6, 9, 10, 13, 14, 15, 19, 20, 29, 36, 37, 38, 39, 48, 51, 52, 53, 54, 58, 61, 62, 78, 79, 80, 81, 82, 95, 104, 118, 132, 136, 180, and 187 were found not to comply with the acceptance criteria. The disposition of these components is provided in the response to Item 3 of Reference (1).

Item (2)

Verify the actual installed instrumentation and controls at the facility are consistent with the schematic reviewed in Item (1) above by conducting a test to demonstrate that all equipment remains in its emergency mode upon removal of the actuating signal and/or manual resetting of the various isolating or actuation signals. Provide a schedule for the performance of the testing in your response to this Bulletin.

Response

For all three units, it is intended that the testing requested above will be completed prior to startup from the 1980 refueling outages. It is noted that the testing completed to date has not identified any discrepancies between the schematics and the actual performance of the equipment. Subsequent to completion of the tests, documentation will be available at the respective sites for Staff inspection as required.

Item (3)

If any safety-related equipment does not remain in its emergency mode upon reset of an ESF signal at your facility, describe proposed system modification, design change, or other corrective action planned to resolve the problem.

Response

For the Haddam Neck Plant, no corrective actions beyond those identified in Reference (23) are necessary.

For Millstone Unit No. 1, circuitry modifications for Items 13 to 16 will be completed by January 1, 1981. Until the modifications are completed, operating procedures will be revised to inform plant operators of the equipment changes that occur upon reset of the accident signal. This measure will ensure that appropriate operator action will be taken following reset. The above procedure changes will be implemented by July 1, 1980.

For Millstone Unit No. 2, circuitry modifications for the 33 unacceptable items identified above will be completed by January 1, 1981. Emergency operating procedures have been revised to inform operators of the equipment changes that occur upon reset of accident signals. These revisions include a listing of all components affected and the change that occurs. This measure will ensure that appropriate operator action will be taken following reset.


The exception to the above corrective measures regards Items 95 and 118 involving the control circuits for the containment sump isolation valves. NNECO review of the significance of the unacceptable items has determined that the control circuits containment sump isolation valves warranted modification during the current outage. Therefore, even though Attachment 3 indicates that Items 95 and 118 did not comply, the circuitry modifications and subsequent testing have been completed.

In summary, by January 1, 1981, all three operating units will have completed modifications such that the acceptance criterion of Reference (1) will be fulfilled for all ESF components. For those few components which do not currently comply, adequate administrative measures will be in effect to ensure continued safe operation of the facilities for the interim period.

We trust you find the above information satisfactory to resolve the Reference (1) concerns.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY



W. G. Council
Senior Vice President

Attachments

ATTACHMENT 1

HADDAM NECK PLANT

I&E BULLETIN NO. 80-06

ENGINEERED SAFETY FEATURES RESET CONTROL

JUNE, 1980

PLANT NAME: CONNECTICUT YANKEE

SHEET 1

DOCKET NO.: 50-213

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (16103 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
1	F-17-1	CTMT RECIRC FAN DMPR	32001 SH 11A	CI/A&B	YES
2	F-17-2	CTMT RECIRC FAN DMPR	32001 SH 11A	CI/A&B	YES
3	F-17-3	CTMT RECIRC FAN DMPR	32001 SH 11A	CI/A&B	YES
4	F-17-4	CTMT RECIRC FAN DMPR	32001 SH 11A	CI/A&B	YES
5	TV-1811A	REACTOR CTMT OPEN PRESS ISO VLV	32001 SH 11B	CI/A	YES
6	TV-1812	REACTOR CTMT OPEN PRESS ISO VLV	32001 SH 11B	CI/A&B	YES
7	HICV-1840	REACTOR CTMT SUMP DISCH ISO VLV	32001 SH 11B	CI/A	YES
8	TV-1841	REACTOR CTMT DRAIN LINE ISO VLV	32001 SH 11F 3B	CI/A&B	YES
9	SOV-12-1	RAD MON ISO VLV	32001 SH 11B	CI/C	YES
10	MOV-331	RCR SEAL BYPASS	32112 SH 26	CI/C	YES
11	TV-1842A	VLV STEM LEAKOFF HEADER	32001 SH 11F	CI/A	YES
12	TV-1842B	VLV STEM LEAKOFF HEADER	32001 SH 11F	CI/B	YES
13	TV-1843	VAPOR SEAL HEAD DRAIN TK VLV	32001 SH 11F	CI/A	YES
14	TV-1847	DRAIN HEADER ISO VLV	32001 SH 11F	CI/A	YES
15	TV-1312-1	S.G. #1 BLOWDOWN ISO VLV	32001 SH 11B	CI/A&B	YES

PLANT NAME: CONNECTICUT YANKEE

SHEET 2

DOCKET NO.: 50-213

ITEM	EQUIP. NO.	EQUIPMENT DESCRIPTION	SCHEMATIC DWG. NO. (16103 SERIES)	ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL	IE BULLETIN 80-06 CRITERIA MET
16	TV-1312-2	S.G. #2 BLOWDOWN ISO VLV	32001 SH 11B	CI/A&B	YES
17	TV-1312-3	S.G. #3 BLOWDOWN ISO VLV	32001 SH 11B	CI/A&B	YES
18	TV-1312-4	S.G. #4 BLOWDOWN ISO VLV	32001 SH 11B	CI/A&B	YES
19	TV-1831	NEUTRON SHIELD TK COOL/ WATER VLV	32001 SH 11B	CI/A&B	YES
20	TV-1212	MAIN STEAM LINE DRAIN TO BLOWN TK VLV	32001 SH 11B	CI/A&B	YES
21	TV-1213	MAIN STEAM LINE DRAIN TO CONDENSER VLV	32001 SH 11B	CI/A&B	YES
22	TV-1846	CMF SUMP PUMP DISCH VLV	32001 SH 11F	CI/B	YES
23	TV-1844	PZR PRESS RELIEF TK DRAIN VLV	32001 SH 11F	CI/B	YES
24	TV-1845	PZR PRESS RELIEF TK VENT VLV	32001 SH 11F	CI/B	YES
25	TV-1848	AIR ACTIVITY MONITOR INLET VLV	32001 SH 11F	CI/B	YES
26	TV-1811B	CTMT LEAK MONITOR VLV	32001 SH 11F	CI/B	YES
27	AOV-202	LETDOWN ORIFICE ISO VLV	32001 SH 11B & 11F	CI/A&B	YES
28	AOV-203	LETDOWN ORIFICE ISO VLV	32001 SH 11B & 11F	CI/A&B	YES
29	AOV-204	LETDOWN ORIFICE ISO VLV	32001 SH 11B & 11F	CI/A&B	YES

PLANT NAME: CONNECTICUT YANKEE

SHEET 3

DOCKET NO.: 50-213

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (16103 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
30	AOV-554	RELIEF TK DRAIN VLV	32001 SH 11B & 11F	CI/A	YES
31	AOV-558	RELIEF TK VENT VLV	32001 SH 11B & 11F	CI/A	YES
32	TV-950	DRAIN HEADER SAMPLE TRIP VLV	32112 SH 32A, B	CI/A&B	YES
33	TV-955	PRESS STEAM SAMPLE TRIP VLV	32112 SH 32A, B	CI/A&B	YES
34	TV-960	PRESS LIQUID SAMPLE TRIP VLV	32112 SH 32A, B	CI/A&B	YES
35	TV-965	LOOP #1 HOT LEG SAMPLE TRIP VLV	32112 SH 32A, B	CI/A&B	YES
36	FCV-611	DRAIN COOLER SHELL OUTLET VLV	32001 SH 11B & 11F	CI/A&B	YES
37	MOV-861-C	SI STOP VALVES	32112 SH 29	SI-/B	YES
38	MOV-861D	SI STOP VALVES	32112/29	SI-4B	YES
39	MOV-871A	DELUGE STOP VALVES	32112/29	SI-4B	YES
40	MOV-871B	DELUGE STOP VALVES	32112/29	SI-4B	YES
41	SOV-796	RES HT EX, FLOW CONTROL	32113/1	SI-4B	YES
42	FCV-110	CHARGING FLOW CONT	32113/6	SI-4B	YES
43	MOV-373	REFUELING WATER INLET VLV	32112/29	SI-4B	YES
44	MOV-861A	SI STOP VALVES	32112/29	SI-4B	YES

PLANT NAME: CONNECTICUT YANKEE

SHEET 4

DOCKET NO.: 50-213

ITEM	EQUIP. NO.	EQUIPMENT DESCRIPTION	SCHEMATIC DWG. NO. (16103 SERIES)	ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL	IE BULLETIN 80-06 CRITERIA MET
45	MOV-861B	SI LOOP VALVES	32112/29	SI-4B	YES
46	MOV-200	LETDOWN ISOLATION VALVE	32112/28	SI-4B	YES
47	MOV-257	VOLUME CONTROL TANK OUTLET VALVE	32112/29	SI-4B	YES
48	MOV-292B	LOOP CHARGING VALVES	32112/29A	SI-4B	YES
49	MOV-292C	LOOP CHARGING VALVES	32112/29A	SI-4B	YES
50	FCV-602	BHR LOOP BYPASS FLOW CONT	32113/4	SI-4B	YES
51	MOV-22	CONT SUMP RHR SUCT	10899-ESK-6T	SI-4B	YES
52	P92A	LPSI PUMP (A)	10899-ESK-5P	SI-4B	YES
53	P92B	LPSI PUMP (B)	10899-ESK-5P	SI-4B	YES
54	P15A	HPSI PUMP (A)	32112/9	SI-4B	YES
55	P15B	HPSI PUMP (B)	32112/9	SI-4B	YES
56	P-18-1A	CHARGING PUMP (1A)	32112/8	SI-4B	YES
57	P-18-1B	CHARGING PUMP (1B)	32112/8	SI-4B	YES
58	F-17-2	RECIR FAN (2)	32001/6DA	SI-4B	YES
59	F-17-1	RECIR FAN (1)	32001/6D	SI-4B	YES
60	F-17-3	RECIR FAN (3)	32001/6DC	SI-4B	YES
61	F-17-4	RECIR FAN (4)	32001/6D	SI-4B	YES

PLANT NAME: CONNECTICUT YANKEE

SHEET 5

DOCKET NO.: 50-213

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (16103 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
62	P-37-1C	SERV WTR PUMP (1C)	32001/6E	SI-4B	YES
63	P-37-1D	SERV WTR PUMP (1D)	32001/6E	SI-4B	YES
64	P-37-1B	SERV WTR PUMP (1B)	32001/6E	SI-4B	YES
65	P-37-1A	SERV WTR PUMP (1A)	32001/6E	SI-4B	YES
66	MOV-861C	SI STOP VALVE	32112 SH 29	SI-/A	YES
67	MOV-861D	SI STOP VALVE	32112/29	SI-4A	YES
68	MOV-871A	DELUGE STOP VALVE	32112/29	SI-4A	YES
69	MOV-871B	DELUGE STOP VALVE	32112/29	SI-4A	YES
70	MOV-200	LETDOWN ISOLATION VALVE	32112/28	SI-4A	YES
71	MOV-373	REFUELING WATER INLET VALVE	32112/29	SI-4A	YES
72	MOV-861A	SI STOP VALVES	32112/29	SI-4A	YES
73	MOV-861B	SI STOP VALVES	32112/29	SI-4A	YES
74	MOV-257	VOLUME CONTROL TANK OUTLET VALVE	32112/29	SI-4A	YES
75	MOV-292B	LOOP CHARGING VALVES	32112/29A	SI-4A	YES
76	FCV-602	RHR LOOP BYPASS FLOW CONT	32113/4	SI-4A	YES
77	MOV-22	CONT SUMP RHR SUCT	10899-ESK-6T	SI-4A	YES

PLANT NAME: CONNECTICUT YANKEE

SHEET 6

DOCKET NO.: 50-213

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (16103 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
78	SOV-796	RES HT EX FLOW CONT	32113/1	SI-4A	YES
79	FCV-110A	CHARGING FLOW CONT	32113/6A	SI-4A	YES
80	P92A	LPSI PUMP (A)	10899-ESK-5P	SI-4A	YES
81	P92B	LPSI PUMP (B)	10899-ESK-5P	SI-4A	YES
82	P15A	HPSI PUMP (A)	32112/9	SI-4A	YES
83	P15B	HPSI PUMP (B)	32112/9	SI-4A	YES
84	P-18-1A	CHARGING PUMP (1A)	32112/8	SI-4A	YES
85	P-18-1B	CHARGING PUMP (1B)	32112/8	SI-4A	YES
86	F-17-2	RECIR FAN (2)	32001/6DA	SI-4A	YES
87	F-17-1	RECIR FAN (1)	32001/6D	SI-4A	YES
88	F-17-3	RECIR FAN (3)	32001/6DC	SI-4A	YES
89	F-17-4	RECIR FAN (4)	32001/6D	SI-4A	YES
90	P-37-1C	SERV WTR PUMP (1C)	32001/6E	SI-4A	YES
91	P-37-1D	SERV WTR PUMP (1D)	32001/6E	SI-4A	YES
92	P-37-1B	SERV WTR PUMP (1B)	32001/6E	SI-4A	YES
93	P-37-1A	SERV WTR PUMP (1A)	32001/6E	SI-4A	YES

ATTACHMENT 2

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 1

I&E BULLETIN NO. 80-06

ENGINEERED SAFETY FEATURES RESET CONTROL

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 1

DOCKET NO.: 50-245MAIN STEAM SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
1	203-1A (MS-1A)	INBD MAIN STEAM ISO VLV	478	CI	YES
2	203-1B (MS-1B)	INBD MAIN STEAM ISO VLV	478	CI	YES
3	203-1C (MS-1C)	INBD MAIN STEAM ISO VLV	478	CI	YES
4	203-1D (MS-1D)	INBD MAIN STEAM ISO VLV	478	CI	YES
5	203-2A (MS-2A)	OTBD MAIN STEAM ISO VLV	479	CI	YES
6	203-2B (MS-2B)	OTBD MAIN STEAM ISO VLV	479	CI	YES
7	203-2C (MS-2C)	OTBD MAIN STEAM ISO VLV	479	CI	YES
8	203-2D (MS-2D)	OTBD MAIN STEAM ISO VLV	479	CI	YES
9	220-1 (MS-5)	MAIN STEAM DRAIN ISO VLV	481	CI	YES
10	220-2 (MS-6)	MAIN STEAM DRAIN ISO VLV	482	CI	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 2

DOCKET NO.: 50-245FWCI SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
11	642A	'A' FEED REG VALVE	659	RX LEVEL	YES
12	642B	'B' FEED REG VALVE	659	RX LEVEL	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 3

DOCKET NO.: 50-245ISOLATION CONDENSER SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
13	1-IC-1 (1301-1)	RX VESSEL TO ISO COND	880	ICS	NO
14	1-IC-2 (1301-2)	RX VESSEL TO ISO COND	881	ICS	NO
15	1-IC-3 (1301-3)	ISO COND TO RX VESSEL	882	ICS	NO
16	1-IC-4 (1301-4)	ISO COND TO RX VESSEL	883	ICS	NO
17	1-IC-17 (1301-17)	VENT TO MAIN STM LINE	888	RPS	YES
18	1-IC-20 (1301-20)	VENT TO MAIN STM LINE	888	RPS	YES
19	1C (M7-28)	EMERGENCY CONDENSATE TRANS- FER PUMP	335	RPS	YES
20	15G-10U	GAS TURBINE & GEN REMOTE CONTROL	1070	ICS	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 4

DOCKET NO.: 50-245EMERGENCY SERVICE WATER SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
21	1501-65A	ESW PUMP 'A'	763	RPS	YES
22	1501-65C	ESW PUMP 'C'	764	RPS	YES
23	1501-65B	ESW PUMP 'B'	788	RPS	YES
24	1501-65D	ESW PUMP 'D'	789	RPS	YES

PLANT NAME: MILLSTONE UNIT NO. 1DOCKET NO.: 50-245CORE SPRAY SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
25	1401A (M8-74A)	CORE SPRAY PUMP	741	SYS I	YES
26	1402-24A (V10-13A)	OUTBOARD ISO VALVE	745	SYS I	YES
27	1402-25A (V10-14A)	INBOARD ISO VALVE	746	SYS I	YES
28	1402-9A (V10-16A)	TESTABLE CHECK VALVE	744	SYS I	YES
29	1402-3A (V10-10A)	PUMP SUCTION VALVE	742	SYS I	YES
30	1402-4A (V10-17A)	TEST BYPASS VALVE	743	SYS I	YES
31	1401B (M8-74B)	CORE SPRAY PUMP	752	SYS II	YES
32	1402-24B (V10-13B)	OUTBOARD ISO VALVE	756	SYS II	YES
33	1402-25B (V10-14B)	INBOARD ISO VALVE	757	SYS II	YES
34	1402-9B (V10-16B)	TESTABLE CHECK VALVE	755	SYS II	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 6

DOCKET NO.: 50-245CORE SPRAY SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
35	1402-3B (V10-10B)	PUMP SUCTION VALVE	753	SYS II	YES
36	1402-4B (V10-17B)	TEST BYPASS VALVE	754	SYS II	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 7

DOCKET NO.: 50-245SHUTDOWN COOLING SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
37	1002A	'A' SHUTDOWN PUMP	855	CI	YES
38	1-SD-2A (1001-2A)	'A' PUMP SUCTION VLV	858	CI	YES
39	1-SD-4A (1001-4A)	'A' PUMP DISCHARGE VLV	859	CI	YES
40	1-SD-1 (1001-1)	INLET ISOLATION VALVE	863	CI	YES
41	1-SD-5 (1001-5)	OUTLET ISOLATION VALVE	864	CI	YES
42	1002B	'B' SHUTDOWN PUMP	865	CI	YES
43	1-SD-2B (1001-2B)	'B' PUMP SUCTION VALVE	868	CI	YES
44	1-SD-4B (1001-4B)	'B' PUMP DISCHARGE VLV	869	CI	YES
45	1-HS-4 (205-2-5)	RX HEAD COOL ISO VALVE	480	CI	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 8

DOCKET NO.: 50-245AUTO DEPRESSURIZATION SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
46	RV-203-3A	BLOWDOWN VALVE	488	ADS	YES
47	RV-203-3C	BLOWDOWN VALVE	488	ADS	YES
48	RV-203-3F	BLOWDOWN VALVE	488	ADS	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 9

DOCKET NO.: 50-245LPCI/CTMNT COOLING SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
49	1502A	LPCI PUMP 'A'	761	CH 1	YES
50	1502C	LPCI PUMP 'C'	762	CH 1	YES
51	1-LP-7A (V10-27A)	HEAT EXCHANGER BYPASS	768	LPCI	YES
52	1-LP-26A (V10-34A)	MIN FLOW BYPASS TO TORUS	769	LPCI	YES
53	1-LP-15A (V10-3A)	OTBD TO CONTAINMENT SPRAY	771	CH 1	YES
54	1-LP-16A (V10-21A)	INBD TO CONTAINMENT SPRAY	772	CH 1	YES
55	1-LP-9A (V10-29A)	OTBD LPCI TO RECIRC	773	CH 1	YES
56	1-LP-10A (V10-30A)	INBD LPCI TO RECIRC	774	CH 1	YES
57	1-LP-13A (V10-20A)	OTBD TO TORUS SPRAY	776	CH 1	YES
58	1-LP-43A (V10-4A)	OTBD TEST LINE TO TORUS	777	CH 1	YES
59	1-LP-44A (V10-28A)	INBD TEST LINE TO TORUS	778	CH 1	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 10

DOCKET NO.: 50-245LPCI/CTMNT COOLING SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
60	1-LP-14A (V10-5A)	INBD TO TORUS SPRAY	779	CH 1	YES
61	1502B	LPCI PUMP 'B'	786	CH 2	YES
62	1502D	LPCI PUMP 'D'	787	CH 2	YES
63	1-LP-7B (V10-27B)	HEAT EXCHANGER BYPASS	793	CH 2	YES
64	1-LP-26B (V10-34B)	MIN FLOW BYPASS TO TORUS	794	CH 2	YES
65	1-LP-15B (V10-3B)	OTBD TO CONTAINMENT SPRAY	796	CH 2	YES
66	1-LP-16B (V10-21B)	INBD TO CONTAINMENT SPRAY	797	CH 2	YES
67	1-LP-9B (V10-29B)	OTBD LPCI TO RECIRC	798	CH 2	YES
68	1-LP-10B (V10-30B)	INBD LPCI TO RECIRC	799	CH 2	YES
69	1-LP-13B (V10-20B)	OTBD TO TORUS SPRAY	800	CH 2	YES
70	1-LP-43B (V10-4B)	OTBD TEST LINE TO TORUS	801	CH 2	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 11

DOCKET NO.: 50-245LPCI/CTMNT COOLING SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
71	1-LP-44B (V10-28B)	INBD TEST LINE TO TORUS	802	CH 2	YES
72	1-LP-14B (V10-5B)	INBD TO TORUS SPRAY	803	CH 2	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 12

DOCKET NO.: 50-245ATMOSPHERIC CONTROL SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
73	1601-1 (AC-7)	DRYWELL VENT VLV	817	CI	YES
74	1601-2 (AC-8)	DRYWELL & TORUS VENT TO RX BLDG	816	CI	YES
75	1601-7 (AC-6)	TORUS PURGE VALVE	817	CI	YES
76	1601-11 (AC-12)	TORUS VENT RELIEF VALVE	817	CI	YES
77	1601-18 (AC-5)	DRYWELL INERTING & PURVE VLV	817	CI	YES
78	1601-19 (AC-4)	DRYWELL & TORUS VENT FROM RX BLDG	816	CI	YES
79	1601-24 (AC-9)	DRYWELL VENT RELIEF VLV	817	CI	YES
80	1601-28 (AC-10)	VENT TO EMERG GAS TREATMENT	816	CI	YES
81	1601-29 (AC-11)	TORUS VENT VALVE	817	CI	YES
82	FCV-6-38A	DRYWELL FLOOR DRAIN ISO VLV	969	CI	YES
83	FCV-6-38B	DRYWELL FLOOR DRAIN ISO VLV	969	CI	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 13

DOCKET NO.: 50-245ATMOSPHERIC CONTROL SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
84	FCV-6-33A	DRYWELL EQUIP DRAIN ISO VLV	969	CI	YES
85	FCV-6-33B	DRYWELL EQUIP DRAIN ISO VLV	969	CI	YES

PLANT NAME: MILLSTONE UNIT NO. 1DOCKET NO.: 50-245RECIRC SAMPLE ISO SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
86	220-44 (SM-1)	INBD RECIRC LOOP SAMPLE VLV	483	CHA	YES
87	220-45 (SM-2)	OTBD RECIRC LOOP SAMPLE VLV	483	CHB	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 15

DOCKET NO.: 50-245RX CLEANUP SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
88	1201-2 (1-CU-2)	RX OUTLET ISO VLV	684	CHA	YES
89	1201-5 (1-CU-3)	INLET SYS ISO VLV	685	CHB	YES
90	1201-7 (1-CU-5)	AUX PMP SUCTION AND BACKUP ISO VLV	686	CHB	YES
91	1201-80 (1-CU-28)	RETURN ISO VLV	687	CHA	YES
92	1201-2A (1-CU-2A)	RX OUTLET BYPASS ISO VLV	684	CHB	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 16

DOCKET NO.: 50-245STANDBY GAS TREATMENT SYSTEM

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
93	HVE-5A	GAS TREATMENT FAN	1120	RPS	YES
94	HVE-5B	GAS TREATMENT FAN	1121	PPS	YES

PLANT NAME: MILLSTONE UNIT NO. 1

SHEET 17

DOCKET NO.: 50-245NUCLEAR BOILER

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>CWD'S SCHEMATIC DWG. NO.</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
95	202-4A (V10-37A)	RX RECIRC PUMP 'A' SUC VLV	442	RPS	YES
96	202-4B (V10-37B)	RX RECIRC PUMP 'B' SUC VLV	459	RPS	YES
97	202-5A (V10-38A)	RX RECIRC PUMP 'A' DISCH VLV	443	RPS	YES
98	202-5B (V10-38B)	RX RECIRC PUMP 'B' DISCH VLV	460	RPS	YES
99	202-7A (V10-39A)	RX RECIRC PUMP 'A' BYPASS VLV	444	RPS	YES
100	202-7B (V10-39B)	RX RECIRC PUMP 'B' BYPASS VLV	461	RPS	YES

ATTACHMENT 3

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2

I&E BULLETIN NO. 80-06

ENGINEERED SAFETY FEATURES RESET CONTROL

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 1

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
1	P-41A	HPSI PUMP	32008 SH 1 & 69	SIAS/1	YES
2	2-SI-617	HPSI FLOW CONTROL VLV	32008 SH 17	SIAS/1	YES
3	2-SI-627	HPSI FLOW CONTROL VLV	32008 SH 18	SIAS/1	YES
4	2-SI-637	HPSI FLOW CONTROL VLV	32008 SH 19	SIAS/1	YES
5	2-SI-647	HPSI FLOW CONTROL VLV	32008 SH 20	SIAS/1	YES
6	P-42A	LPSI PUMP	32008 SH 4 & 64	SIAS/1	NO
7	2-SI-615	LPSI INJ FLOW CONTROL VLV	32008 SH 21	SIAS/1	YES
8	2-SI-625	LPSI INJ FLOW CONTRGL VLV	32008 SH 22	SIAS/1	YES
9	2-SI-618	SI CHECK VLV LEAK-OFF	32008 SH 56	SIAS/1	NO
10	2-SI-628	SI CHECK VLV LEAK-OFF	32008 SH 57	SIAS/1	NO
11	2-CH-508	B.A. TK DISCH BYPASS VLV	32009 SH 8	SIAS/1	YES
12	2-CH-509	B.A. TK DISCH BYPASS VLV	32009 SH 9	SIAS/1	YES
13	2-CH-501	VOL CONT TK DISCH VLV	32009 SH 6	SIAS/1	NO
14	2-CH-512	VOL CONT TK MAKEUP VLV	32009 SH 21	SIAS/1	NO
15	P-18A	CHARGING PUMP	32009 SH 40 & 48	SIAS/1	NO
16	2-CH-515	CONDENSATOR COOLANT LETDOWN VLV	32009 SH 33	SIAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 2

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
17	P-5A	SERVICE WATER PUMP	32013 SH 5	SIAS/1	YES
18	HV-6439	TBCCW HX 'A' INLET VLV	32013 SH 20	SIAS/1	YES
19	TV-6307	RBCCW HX 'B' OUTLET VLV	32013 SH 41	SIAS/1	NO
20	TV-6308	RBCCW HX 'A' OUTLET VLV	32013 SH 40	SIAS/1	NO
21	DG-H7A	DIESEL GENERATOR H7A	32041 SH 3	SIAS/1	YES
22	P-11A	RBCCW PUMP	32015 SH 1	SIAS/1	YES
23	HV-6080	CTMT AIR RECIRC CLT 'A' OUTLET VLV	32015 SH 31	SIAS/1	YES
24	HV-6088	CTMT AIR RECIRC CLT 'C' OUTLET VLV	32015 SH 35	SIAS/1	YES
25	HV-6315	SFP HX 'A' DISCH VLV	32015 SH 12	SIAS/1	YES
26	HV-6731	RBCCW SAFGRD RM HX OUTLET VALVE	32015 SH 8	SIAS/1	YES
27	P-122A	VITAL SW/G RM CHILLED WTR PUMP	32023 SH 44	SIAS/1	YES
28	F-54A	VITAL SW/G RM COOLING FAN	32021 SH 19	SIAS/1	YES
29	2-CH-196	VCT BYPASS VLV	32009 SH 54	SIAS/1	NO
30	2-SI-614	SI TK OUTLET VLV	32008 SH 12	SIAS/1	YES
31	2-SI-624	SI TK OUTLET VLV	32008 SH 38	SIAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 3

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
32	F-14A	CTMT AIR REC FAN	32022 SH 1 & 55	SIAS/1	YES
33	F-14C	CTMT AIR REC FAN	32022 SH 2 & 56	SIAS/1	YES
34	F-15A	ENGR SFGRD RM AIR REC FAN	32022 SH 17	SIAS/1	YES
35	F-112A	BATTERY ROOM ROOF EXH FAN	32021 SH 1	SIAS/1	YES
36	HV-8846	CHILLED WATER VLV TO X-84A	32023 SH 47	SIAS/1	NO
37	HV-8847	CHILLED WATER VLV TO X-85 & X-79	32023 SH 47	SIAS/1	NO
38	HV-8848	SERVICE WATER VLV TO CHILLER X-168A	32023 SH 47	SIAS/1	NO
39	HV-8850	CHILLED WATER MAKEUP ISO VLV	32023 SH 47	SIAS/1	NO
40	F-13A	CEAM COOLING FAN	32022 SH 5	SIAS/1	YES
41	F-13C	CEAM COOLING FAN	32022 SH 7	SIAS/1	YES
42	F-13B	CEAM COOLING FAN	32033 SH 6	SIAS/2	YES
43	P-41C	HPSI PUMP	32008 SH 2 & 69	SIAS/2	YES
44	2-SI-616	HPSI FLOW CONTROL VLV	32008 SH 13	SIAS/2	YES
45	2-SI-626	HPSI FLOW CONTROL VLV	32008 SH 14	SIAS/2	YES
46	2-SI-636	HPSI FLOW CONTROL VLV	32008 SH 15	SIAS/2	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 4

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
47	2-SI-646	HPSI FLOW CONTROL VLV	32008 SH 16	SIAS/2	YES
48	P-42B	LPSI PUMP	32006 SH 5 & 64	SIAS/2	NO
49	2-SI-635	LPSI FLOW CONTROL VLV	32008 SH 23	SIAS/2	YES
50	2-SI-645	LPSI FLOW CONTROL VLV	32008 SH 24	SIAS/2	YES
51	2-SI-638	S.I. CHECK VLV LEAK-OFF	32008 SH 58	SIAS/2	NO
52	2-SI-648	S.I. CHECK VLV LEAK-OFF	32008 SH 59	SIAS/2	NO
53	P-19A	BORIC ACID PUMP	32009 SH 4	SIAS/2	NO
54	P-19B	BORIC ACID PUMP	32009 SH 5	SIAS/2	NO
55	2-CH-514	BORIC ACID TO CHARGING LINE VLV	32009 SH 10	SIAS/2	YES
56	2-CH-510	BORIC ACID RECIRC VLV	32009 SH 24	SIAS/2	YES
57	2-CH-511	BORIC ACID RECIRC VLV	32009 SH 25	SIAS/2	YES
58	P-18C	CHARGING PUMP	32009 SH 43 & 48	SIAS/2	NO
59	P-5C	SERVICE WATER PUMP	32013 SH 7	SIAS/2	YES
60	HV-6438	TBCCW HX 'B' INLET VLV	32013 SH 20	SIAS/2	YES
61	TV-6306	RBCCW HX 'C' OUTLET VLV	32013 SH 42	SIAS/2	NO
62	TV-6307	RBCCW HX 'B' OUTLET VLV	32013 SH 43	SIAS/2	NO
63	DG-H7B	DIESEL GENERATOR H7B	32041 SH 15	SIAS/2	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 5

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
64	P-11C	RBCCW PUMP	32015 SH 3	SIAS/2	YES
65	HV-6084	RBCCW AIR REC CLT 'B' OUTLET VLV	32015 SH 33	SIAS/2	YES
66	HV-6092	RBCCW AIR REC CLT 'D' OUTLET VLV	32015 SH 37	SIAS/2	YES
67	HV-6316	SFP HX 'B' DISCH VLV	32015 SH 13	SIAS/2	YES
68	HV-6735	RBCCW SAFGRD, RM HX OUTLET VLV	32015 SH 9	SIAS/2	YES
6 ^o	HV-6739	SAMPLE & DEGAS CLR OUTLET VLV	32015 SH 38	SIAS/2	YES
70	P-122B	VITAL SW/G RM CHILLED WTR PUMP	32023 SH 45	SIAS/2	YES
71	F-54B	VITAL SW/G RM COOLING FAN	32021 SH 20	SIAS/2	YES
72	2-SI-634	SI TK OUTLET VLV TK #3	32008 SH 39	SIAS/2	YES
73	2-SI-644	SI TK OUTLET VLV TK #4	32008 SH 40	SIAS/2	YES
74	F-14B	CTMT AIR RECIRC FAN	32022 SH 3 & 57	SIAS/2	YES
75	F-14D	CTMT AIR RECIRC FAN	32022 SH 4 & 58	SIAS/2	YES
76	F-15B	ENG SAFGRD RM AIR RECIRC FAN	32022 SH 18	SIAS/2	YES
77	F-112B	BATTERY ROOM ROOF EXH FAN	32021 SH 2	SIAS/2	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 6

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
78	HV-8853	CHILLED WATER TO X-84B	32023 SH 48	SIAS/2	NO
79	HV-8854	CHILLED WATER TO X-84 & X-79	32023 SH 48	SIAS/2	NO
80	HV-8855	CHILLED WATER MAKE-UP ISO VLV	32023 SH 48	SIAS/2	NO
81	HV-8856	SERVICE WATER VLV TO CHILLER X-169B	32023 SH 48	SIAS/2	NO
82	P-18B	CHARGING PUMP	32009 SH 41	SIAS/5	NO
83	P-5B	SERVICE WATER PUMP	32013 SH 6	SIAS/5	YES
84	P-11B	RBCCW PUMP	32015 SH 2	SIAS/5	YFS
85	P-43A	CTMT SPRAY PUMP	32008 SH 6 & 69	CSAS/1	YES
86	HV-3021	CTMT SPRAY CONTROL VLV	32008 SH 29	CSAS/1	YES
87	P-43B	CTMT SPRAY PUMP	32008 SH 7 & 69	CSAS/2	YES
88	HV-3022	CTMT SPRAY CONTROL VLV	32008 SH 30	CSAS/2	YES
89	2-CH-505	RCP CONTROL BLEED-OFF ISO VLV	32009 SH 30	CIAS/1	YES
90	2-CH-198	RCP BLEED-OFF	32009 SH 30	CIAS/1	YES
91	HV-7311	PMW CTMT ISO VLV	32007 SH 31	CIAS/1	YES
92	HV-4246	S.G. #1 BLOWDOWN VLV	32020 SH 14	CIAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 7

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
93	HV-4250	S.G. #1 BLOWDOWN VLV	32020 SH 11	CIAS/1	YES
94	HV-7690	RC SAMPLING ISO VLV	32027 SH 3	CIAS/1	YES
95	HV-9150	CTMT DRAIN SUMP ISO VLV	32030 SH 3	CIAS/1	NO
96	HV-9126	WASTE GAS SURGE TK INLET VLV	32026 SH 2	CIAS/1	YES
97	HV-9016	PDT PUMP DISCH ISO VLV	32025 SH 11	CIAS/1	YES
98	HV-8126	CTMT PURGE OUTLET DAMPER	32022 SH 47	CIAS/1	YES
99	HV-8127	ENCL BLDG PURGE EXH DAMPER	32022 SH 48	CIAS/1	YES
100	HV-8121	CTMT RAD MONITOR ISO VLV	32022 SH 26	CIAS/1	YES
101	HV-8124	CTMT RAD MONITOR ISO VLV	32022 SH 43	CIAS/1	YES
102	HV-8050	PURGE FAN INLET ISO DAMPER	32022 SH 29	CIAS/1	YES
103	HV-8080	CTMT PURGE INLET DAMPER	32022 SH 45	CIAS/1	YES
104	HV-8081	ENCL BLDG SUPPLY DAMPER	32022 SH 46	CIAS/1	NO
105	F-39A	CTMT RAD MONITOR FAN	32022 SH 14	CIAS/1	YES
106	HV-8150	CTMT H2 SAMPLE ISO VLV	32022 SH 30	CIAS/1	YES
107	HV-8377	H2 PURGE ISO VLV	32022 SH 59	CIAS/1	YES
108	HV-8378	H2 PURGE ISO VLV	32022 SH 60	CIAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 8

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
109	HV-7312	N2 SUPPLY ISO VLV	32008 SH 49	CIAS/2	YES
110	HV-2525	REGEN HX DISCH TO LD HX	32009 SH 39	CIAS/2	YES
111	2-CH-516	R.C. LETDOWN VLV	32009 SH 34	CIAS/2	YES
112	2-CH-506	RCP BLEED-OFF ISO VLV	32009 SH 31	CIAS/2	YES
113	HV-1060	PZR STEAM SAMPLE VLV	32007 SH 28	CIAS/2	YES
114	HV-1062	PZR SURGE LINE SAMPLE VLV	32007 SH 29	CIAS/2	YES
115	HV-1064	RC HOT LEG SAMPLE VLV	32007 SH 30	CIAS/2	YES
116	HV-4248	S.G. #2 BLOWDOWN VLV	32020 SH 15	CIAS/2	YES
117	HV-4251	S.G. #2 BLOWDOWN SAMPLE VLV	32020 SH 12	CIAS/2	YES
118	HV-9151	CTMT SUMP PUMP ISO VLV	32030 SH 4	CIAS/2	NO
119	HV-9125	WASTE GAS INLET ISO VLV	32026 SH 1	CIAS/2	YES
120	HV-9230	PDT SAMPLE SHUTOFF VLV	32025 SH 17	CIAS/2	YES
121	HV-9015	PDT DISCH ISO VLV	32025 SH 10	CIAS/2	YES
122	F-23	CTMT PURGE SUPPLY FAN	32022 SH 10	CIAS/2	YES
123	HV-8125	CTMT PURGE EXH VLV	32022 SH 44	CIAS/2	YES
124	HV-8128	CTMT & ENCL BLDG EXH VLV	32022 SH 36	CIAS/2	YES
125	HV-8122	CTMT RAD MONITOR ISO VLV	32022 SH 27	CIAS/2	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 9

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
126	HV-8082	CTMT PURGE SUPPLY VLV	32022 SH 28	CIAS/2	YES
127	F-39B	CTMT RAD MONITOR FAN	32022 SH 15	CIAS/2	YES
128	HV-8151	CTMT H2 SAMPLE ISO VLV	32022 SH 31	CIAS/2	YES
129	HV-8379	H2 PURGE VENT TO EBFS PLE	32022 SH 61	CIAS/2	YES
130	HV-8380	H2 PURGE CTMT VENT	32022 SH 62	CIAS/2	YES
131	HV-8656	CTMT AIR SAMPLE VLV	32022 SH 73	CIAS/2	YES
132	P-42A	LPSI PUMP	32008 SH 4 & 64	SRAS/1	NO
133	HV-6050	RBCCW SHTDN HV OUTLET VLV	32015 SH 10	SRAS/1	YES
134	HV-3008	CTMT SUMP RECIRC VLV	32008 SH 25	SRAS/1	YES
135	2-SI-659	SI PUMP RECIRC HDR SHUT-OFF VLV	32008 SH 54	SRAS/1	YES
136	P-42B	LPSI PUMP	32008 SH 5 & 64	SRAS/2	NO
137	HV-6055	RBCCW SHTDN HX OUTLET VLV	32015 SH 11	SRAS/2	YES
138	HV-3009	CTMT SUMP RECIRC. VLV	32008 SH 24	SRAS/2	YES
139	2-SI-660	SI PUMP RECIRC HDR SHUT-OFF VLV	32008 SH 55	SRAS/2	YES
140	HV-8143	FUEL HNDLG AREA VENT TO PLENM	32022 SH 52	EBFAS/1	YES
141	F-25A	ENCL BLDG FILTRATION FAN	32022 SH 21	EBFAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 10

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
142	HV-8695	SJAE VENT ISO VLV	32022 SH 66	EBFAS/1	YES
143	HV-8074	ENCL BLDG SUC ISO DAMPER	32022 SH 35	EBFAS/1	YES
144	HV-8153	ENCL BLDG PLEN ISO DAMPER	32022 SH 37	EBFAS/1	YES
145	HV-8247	RADWASTE AREA EXH DAMPER	32021 SH 12	EBFAS/1	YES
146	HV-8249	RADWASTE AREA EXH DAMPER	32021 SH 14	EBFAS/1	YES
147	F-32A	CONTROL RM FILTER FAN	32023 SH 5	EBFAS/1	YES
148	HV-8650	CTMT CLEANUP DAMPER	32022 SH 67	EBFAS/1	YES
149	HV-8062	FUEL HNDLG AREA VENT TO PLEN	32022 SH 39	EBFAS/2	YES
150	F-25B	ENCL BLDG FILTRATION FAN	32022 SH 22	EBFAS/2	YES
151	HV-8654	SJAE VENT ISO VLV	32022 SH 65	EBFAS/2	YES
152	HV-8070	ENCL BLDG VENT ISO DMPR	32022 SH 50	EBFAS/2	YES
153	HV-8063	ENCL BLDG PLEN ISO DMPR	32022 SH 53	EBFAS/2	YES
154	HV-8133	RADWASTE AREA EXH DMPR	32021 SH 13	EBFAS/2	YES
155	HV-8248	RADWASTE AREA EXH DMPR	32021 SH 15	EBFAS/2	YES
156	F-32B	CONTROL RM FILTER FAN	32023 SH 6	EBFAS/2	YES
157	HV-8651	CTMT CLEANUP DMPR	32022 SH 68	EBFAS/2	YES
158	HV-8143	FUEL HNDLG AREA VENT TO PLNM	32022 SH 52	AEAS/1	YES

PLANT NAME: MILLSTONE UNIT NO. 2

SHEET 11

DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
159	F-25A	ENCL BLDG FILTRATION FAN	32022 SH 21	AEAS/1	YES
160	HV-8695	SJAE VENT ISO VLV	32022 SH 66	AEAS/1	YES
161	HV-8074	ENCL BLDG VENT SUC ISO DMPR	32022 SH 35	AEAS/1	YES
162	HV-8153	ENCL BLDG PLENUM ISO DMPR	32022 SH 37	AEAS/1	YES
163	F-32A	CONTROL RM FILTER FAN	32023 SH 38	AEAS/1	YES
164	HV-8650	CTMT CLEANUP DMPR	32022 SH 67	AEAS/1	YES
165	F-20	FUEL HNDLG AREA FAN	32021 SH 6	AEAS/1	YES
166	HV-8275	FUEL HNDLG AREA EXH DMPR	32021 SH 9	AEAS/1	YES
167	HV-8141	FUEL HNDLG AREA DMPR	32021 SH 8	AEAS/2	YES
168	HV-8062	FUEL HNDLG AREA ISO DMPR	32022 SH 39	AEAS/2	YES
169	F-25B	ENCL BLDG FILTRATION FAN	32022 SH 22	AEAS/2	YES
170	HV-8654	SJAE VENT ISO VLV	32022 SH 65	AEAS/2	YES
171	HV-8070	ENCL BLDG VENT SUCT ISO DMPR	32022 SH 50	AEAS/2	YES
172	HV-8063	ENCL BLDG PLENUM ISO DMPR	32022 SH 53	AEAS/2	YES
173	F-32B	CONTROL RM FILTER FAN	32023 SH 39	AEAS/2	YES
174	HV-8651	CTMT CLEANUP DAMPER	32022 SH 68	AEAS/2	YES

PLANT NAME: MILLSTONE UNIT NO. 2DOCKET NO.: 50-336

<u>ITEM</u>	<u>EQUIP. NO.</u>	<u>EQUIPMENT DESCRIPTION</u>	<u>SCHEMATIC DWG. NO. (25203 SERIES)</u>	<u>ENGINEERED SAFETY ACTUATION SIGNAL/CHANNEL</u>	<u>IE BULLETIN 80-06 CRITERIA MET</u>
175	HV-8326	FUEL HNDLG AREA ISO DMPR	32021 SH 10	AEAS/2	YES
176	HV-4217	S.G. #1 ISO VLV	32020 SH 18	MSI/1	YES
177	HV-4221	S.G. #1 ISO VLV	32020 SH 20	MSI/1	YES
178	HV-4218	S.G. #1 ISO VLV BYPASS	32020 SH 1	MSI/1	YES
179	H-5A	S.G. FEED PUMP TURBINE	32012 SH 7	MSI/1	YES
180	HV-5419	S.G. #1 FEEDWATER ISO VLV	32012 SH 25	MSI/1	NO
181	FV-5268	S.G. #1 FEEDWATER REG VLV	32012 SH 31	MSI/1	YES
182	HV-4193	MAIN STEAM LEG LOW PT DRAIN	32020 SH 45	MSI/1	YES
183	HV-4217	S.G. #1 ISO VLV	32020 SH 18	MSI/2	YES
184	HV-4221	S.G. #1 ISO VLV	32020 SH 20	MSI/2	YES
185	HV-4222	S.G. #2 ISO VLV BYPASS	32020 SH 2	MSI/2	YES
186	H-5B	S.G. FEED PUMP TURBINE	32012 SH 9	MSI/2	YES
187	HV-5420	S.G. #2 FEEDWATER ISO VLV	32012 SH 26	MSI/2	NO
188	FV-5269	S.G. #2 FEEDWATER REG VLV	32012 SH 32	MSI/2	YES
189	HV-4209	MAIN STEAM LEG LOW PT DRAIN	32020 SH 46	MSI/2	YES