

TIC



Docket No. 50-346  
License No. NPF-3  
Serial No. 1-146  
June 30, 1980

RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Mr. James G. Keppler  
Regional Director, Region III  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

IE Bulletin No. 79-14, dated July 2, 1979, requested that we develop and implement an inspection program to verify that the Davis-Besse Nuclear Power Station Unit 1 seismic analysis input of safety related piping systems conforms to the actual field conditions.

Our inspection of normally accessible safety related piping was completed September 21, 1979. The results of our detailed engineering reviews of the inspection packages and follow-on analytical work required by Item 4B of the Bulletin were submitted on October 19, 1979 and June 16, 1980, and show that none of the discrepancies found during the inspection of accessible piping affect system operability.

Our inspection of normally inaccessible safety related piping was completed May 22, 1980. Discrepancies found during the inspection were reviewed in accordance with the guidance provided in Supplement Nos. 1 and 2 to IE Bulletin No. 79-14. Attached are our detailed engineering reviews for all of the field inspection packages. These reviews indicates that there are two deviations which affect system operability. These will be corrected prior to startup from our current refueling outage. Other discrepancies found during the inspection of inaccessible piping systems do not affect system operability. Our schedule for follow-on analytical work required under Item 4B of the Bulletin to support our findings is also attached.


*Attachment sent to ADM files*

8007170 532

9

This completes our walkdown of accessible and inaccessible safety related piping system and the detailed engineering evaluation of the discrepancies found during these walkdowns. Upon correction of the two deviations mentioned above and discussed in more detail in the attached report, we feel confident that the Davis-Besse seismic analysis acceptably conforms to the as-built safety related systems.

Yours very truly,

A handwritten signature in black ink, appearing to be 'M. A. ...', written in a cursive style.

RPC:CLM

Attachments

db d/2-3

cc:

U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
Division of Reactor Operations Inspection  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulations  
Division of Operating Reactors  
Washington, D.C. 20555