



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

LICENSE NO. DPR-77

AMENDMENT NO. 2

1. The Nuclear Regulatory Commission (the Commission) having found that:
 - A. The application for amendment to the Sequoyah Nuclear Plant, Unit 1 (the facility) license, DPR-77, filed by the Tennessee Valley Authority (licensee), dated March 28, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the license, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public, and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by a page change to the Appendix A Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

8007180


596

(2) - Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 2, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications.

A. This amended license is effective as of May 24, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Attachment:
Appendix A Technical
Specification changes

Date of Issuance:
July 1, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 2

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Page

8-1

8.1 SPECIFICATION 3/4.11.1

Prior to initial criticality, the requirements for sampling and analysis for items A.6, A.7, and A.9 in Table 4.11-1 may be waived provided the release is through the turbine building sump (item B.2 of the Table 4.11-1).

8.2 SPECIFICATION 4.8.1.1.2c

The surveillance requirements for verifying diesel generator voltage and frequency during diesel generator starts is waived for the original surveillance interval only.

8.3 SPECIFICATION 4.7.8.1, ITEM D 3

The 1/4 inch negative pressure requirement within the spent fuel storage area and ESF pump rooms is waived during the low power test program. However, the auxiliary building gas treatment system shall be capable of maintaining these areas at a slight negative pressure during this period.

8.4 SPECIFICATION 3.3.3.10, TABLE 3.3-13, ITEM 33

Flow rates for ventilation systems for the shield building exhaust, auxiliary building and service building may be estimated using the design flow rate for the appropriate fans. This interim waiver extends the 30-day limit for 18 months from the issuance of this license. This waiver is considered to be an interim measure until flow rate monitors for the ventilation system for these structures can be repaired or replaced.

8.5 SPECIFICATIONS 3.5.2, 3.5.3, 3.6.2.1, 3.6.3.1, and 3.7.1.2

Prior to initial criticality, the provisions of Specification 3.0.4 are not applicable when system inoperability has been determined solely on unresolved piping support or restraint deficiencies.