YANKEE ATOMIC ELECTRIC COMPANY



Rowe, Massachusetts 01367

July 2, 1980

U. S. Nuclear Regulatory Commission Office of Inspection and Enforcement Region I 631 Park Avenue King of Prussia, Pennsylvania 19406

Attention: Mr. B. H. Grier

Dear Mr. Grier:

On June 27, 1980 I reported LER 80-12 for linear indications found during IE Bulletin 79-17 stagnant borated line inspections.

Subsequent internal liquid penetrant examinations of the internal surfaces confirm no thru the wall defects. Reporting requirements subject to IE Bulletin 79-17 are therefore cancelled.

Very truly yours,

Herbert A. Autio
Plant Superintendent

Merbert a. antis

HAA

meg