



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

JUL 3 1980

Docket No. 50-546  
Docket No. 50-547

Public Service of Indiana  
ATTN: Mr. S. W. Shields  
Senior Vice President  
Nuclear Division  
1000 East Main Street  
Plainfield, IN 46168

Gentlemen:

Thank you for your interim report dated June 2, 1980, pursuant to 10 CFR 50.55(e) regarding problem in operation of centrifugal charging pumps at their minimum allowable flow rate. We will review your final report on this matter upon receipt.

Your cooperation with us is appreciated.

Sincerely,

A handwritten signature in cursive script, appearing to read "G. Fiorelli".

G. Fiorelli, Chief  
Reactor Construction and  
Engineering Support Branch

cc: C. Kammerer, CA  
H. Thornburg, IE  
Mr. G. N. Brown, Project  
Director  
Central Files  
Reproduction Unit NRC 20b  
PDR  
Local PDR  
NSIC  
TIC  
LeBoeuf, Lamb, Leiby & MacRae  
Mr. Dave Martin, Office of  
Attorney General  
Mr. John R. Galloway, Staff  
Director, Environment, Energy  
and Natural Resources Subcommittee

8007210 021