



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

THE TOLEDO EDISON COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 25  
License No. NPF-3

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees) dated October 23, 1978, as supplemented January 26, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8007210333


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-3 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 25, are hereby incorporated in the license. Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: July 2, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 25

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

3/4 5-4

3/4 7-24

## EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS -  $T_{avg} > 280^{\circ}\text{F}$

### LIMITING CONDITION FOR OPERATION

3.5.2 Two independent ECCS subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE high pressure injection (HPI) pump,
- b. One OPERABLE low pressure injection (LPI) pump,
- c. One OPERABLE decay heat cooler, and
- d. An OPERABLE flow path capable of taking suction from the borated water storage tank (BWST) on a safety injection signal and automatically transferring suction to the containment sump on a borated water storage tank low level signal during the recirculation phase of operation.

APPLICABILITY: MODES 1, 2 and 3.

#### ACTION:

- a. With one ECCS subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 72 hours or be in HOT SHUTDOWN within the next 12 hours.
- b. In the event the ECCS is actuated and injects water into the Reactor Coolant System, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 90 days describing the circumstances of the actuation and the total accumulated actuation cycles to date.

### SURVEILLANCE REQUIREMENTS

4.5.2 Each ECCS subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed or otherwise secured in position, is in its correct position.

## EMERGENCY CORE COOLING SYSTEMS

### SURVEILLANCE REQUIREMENTS

- b. At least once per 18 months, or prior to operation after ECCS piping has been drained by verifying that the ECCS piping is full of water by venting the ECCS pump casings and discharge piping high points.
- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment emergency sump and cause restriction of the pump suction during LOCA conditions. This visual inspection shall be performed:
  1. For all accessible areas of the containment prior to establishing CONTAINMENT INTEGRITY, and
  2. Of the areas affected within containment at the completion of each containment entry when CONTAINMENT INTEGRITY is established.
- d. At least once per 18 months by:
  1. Verifying automatic isolation and interlock action of the DHR system from the Reactor Coolant System when a simulated Reactor Coolant System pressure of  $\geq 413$  psig is applied.
  2. A visual inspection of the containment emergency sump which verifies that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
  3. Verifying a total leak rate  $\leq 20$  gallons per hour for the LPI system at:
    - a) Normal operating pressure or hydrostatic test pressure of  $\geq 150$  psig for those parts of the system downstream of the pump suction isolation valve, and
    - b)  $\geq 45$  psig for the piping from the containment emergency sump isolation valve to the pump suction isolation valve.
  4. Verifying that a minimum of 72 cubic feet of solid granular trisodium phosphate dodecahydrate (TSP) is contained within the TSP storage baskets.

TABLE 3.7-3 (Continued)

SAFETY RELATED HYDRAULIC SNUBBERS\*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR INACCESSIBLE (A or I)</u>	<u>HIGH RADIATION ZONE** (Yes or No)</u>	<u>ESPECIALLY DIFFICULT TO REMOVE (Yes or No)</u>
34-HCB-4-H34	Containment, 643'	I	Yes	No
34-HCB-4-H34	Containment, 643'	I	Yes	No
<u>DECAY HEAT REMOVAL SYSTEM</u>				
33C-CCA-4-H2	Containment, 567'	A	Yes	No
33C-CCA-4-H3	Containment, 567'	A	Yes	No
33C-CCA-4-H7	Containment, 560'	A	Yes	No
33C-CCA-4-H10	Containment, 560'	A	Yes	No
33C-CCA-4-H11	Containment, 567'	A	Yes	No
33C-GCB-7-H3	Auxiliary Building, 568'	A	No	No
33C-GCB-7-H4	Auxiliary Building, 566'	A	No	No
33C-GCB-7-H6	Auxiliary Building, 566'	A	No	No
33C-GCB-7-H7	Auxiliary Building, 557'	A	No	No
33C-HCB-24-H5A	Auxiliary Building, 569'	A	No	No
<u>EMERGENCY CORE COOLING SYSTEM</u>				
33A-GCB-4-H5	Auxiliary Building, 556'3"	A	No	No
33A-GCB-8-H3	Auxiliary Building, 553'	A	No	No
33A-GCB-8-H4	Auxiliary Building, 553'	A	No	No
33A-GCB-8-H10	Auxiliary Building, 556'3"	A	No	No
33A-HCB-2-H21	Auxiliary Building, 552'9"	A	No	No
33B-HCB-1-H3	Auxiliary Building, 557'	A	No	No
33B-HCB-1-H4	Auxiliary Building, 556'9"	A	No	No

TABLE 3.7-3 (Continued)  
SAFETY RELATED HYDRAULIC SNUBBERS\*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR INACCESSIBLE (A or I)</u>	<u>HIGH RADIATION ZONE** (Yes or No)</u>	<u>ESPECIALLY DIFFICULT TO REMOVE (Yes or No)</u>
<u>EMERGENCY DIESEL GENERATOR SYSTEM</u>				
47-HBD-358-H3	Auxiliary Building, 607'	I	No	No
47-HBD-358-H6	Auxiliary Building, 607'	I	No	No
47-HBD-359-H2	Auxiliary Building, 607'	I	No	No
47-HBD-359-H10	Auxiliary Building, 607'	I	No	No
<u>HIGH PRESSURE INJECTION SYSTEM</u>				
33C-CCB-2-H47	Containment, 568'	A	Yes	No
<u>LOW PRESSURE INJECTION/CORE FLOOD SYSTEM</u>				
33B-CCA-6-H1	Containment, 561'	A	Yes	No
33B-CCA-6-H5	Containment, 561'	A	Yes	No
33B-CCA-6-H5	Containment, 561'	A	Yes	No
33B-CCA-6-H6	Containment, 565'	A	Yes	No
33B-CCB-5-H1	Containment, 566'	A	Yes	No
33B-CCB-5-H3	Containment, 566'	A	Yes	No
33B-CCB-5-H4	Containment, 566'	A	Yes	No
33B-CCB-5-H6	Containment, 566'	A	Yes	No
33B-CCB-6-H2	Containment, 566'	A	Yes	No
33B-CCB-6-H4	Containment, 566'	A	Yes	No
33B-CCB-6-H5	Containment, 566'	A	Yes	No
33B-CCB-6-H8	Containment, 580'	I	Yes	No