

## UNITED STATES NUCLEAR REGULATORY COMMISSION REGION I 631 PARK AVENUE KING OF PRUSSIA, PENNSYLVANIA 19406

Docket No. 50-213 File No. IAL 80-20

JUL 9 3 1980

Connecticut Yankee Atomic Power Company
ATTN: Mr. W. G. Counsil
Vice President - Nuclear
Engineering and Operations
P. O. Box 270
Hartford, Connecticut 06101

## Gentlemen:

This refers to the telephone conversation between you and Mr. G. H. Smith of this office on July 3, 1980, regarding certain matters affecting the emergency preparedness capabilities at the Haddam Neck Plant identified during the Health Physics Appraisal conducted during the period June 23 - July 3, 1980. These concerns were discussed between you and Mr. J. White of the Health Physics Appraisal Team on July 3, 1980.

With regard to the matters brought to your attention by Mr. White and discussed in the referenced conversation, it is our understanding that the following actions will be undertaken and completed as outlined below:

- A. By the end of the current outage and prior to the resumption of operation of the Haddam Neck Plant:
  - 1. Undertake and complete a review of all emergency plan procedures related to off-site dose assessment and projection (i.e. Emergency Plan 1.5-16, 17) making appropriate revisions to:
    - Clarify required actions, eliminate existing ambiguities, errata, and omissions.
    - b. Clarify the duties and responsibilities of personnel when different groups and/or locations are addressed in the present plan.
    - c. Develop efficient procedures for contability and reliability testing of all emergency survey instruments.
  - Develop procedures for an emergency repair/corrective action team.
  - 3. Develop criteria for classifying the various types of emergencies listed in your emergency plan. Such criteria are to be based on readings obtained from installed instrumentation as well as the results of environmental surveillance projections.

## 1111 0 3 1980

Within five days following the resumption of operation of the Haddam Neck В. Plant conduct initial training and retraining of all individuals assigned to the emergency response organization and ensure that those individuals are able to perform their assigned duties in accordance with the entire emergency plan implementing procedure as revised according to item A above.

If our understandings as described above are not in agreement with your actual plans and actions being implemented, notify this office by telephone within 24 hours.

Sincerely,

Boyce H. Grier Director

James M. allan

R. Graves, Plant Superintendent

D. G. Diedrick, Manager of Quality Assurance

J. R. Himmelwright, Licensing Safeguards Engineer