

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | I | L | Z | I | S | 2 | 7 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5 | CAT 58

0 | 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 0 | 4 | 7 | 0 | 2 | 0 | 2 | 8 | 0 | 8 | 0 | 3 | 0 | 3 | 8 | 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During normal operation, maintenance personnel found S/G Level Xmtr 2LT-
0 3 | 538 had shifted high by 2.25%. This error was non-conservative for low-
0 4 | low S/G level and low S/G level coincident with SF > FF Rx trip as
0 5 | presented in T.S. Table 3.1.1. No safety implications were involved as
0 6 | the redundant channels were operable. The health and safety of the pub-
0 7 | lic was not affected.

0 9 | SYSTEM CODE | I | A | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | E | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | T | 15 | VALVE SUBCODE | Z | 16

17 | LER/RO REPORT NUMBER | 8 | 0 | EVENT YEAR | 8 | 0 | SEQUENTIAL REPORT NO. | 0 | 0 | 9 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 | ACTION TAKEN | E | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | N | 23 | NRPD-4 FORM SUB | Y | 24 | PRIME COMP. SUPPLIER | N | 25 | COMPONENT MANUFACTURER | F | 1 | 2 | 0 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The cause of the out of tolerance channel was determined to be trans-
1 1 | mitter drift (Fischer-Porter model #13D2495 xmtr). The xmtr was re-
1 2 | calibrated and the channel returned to service. The drift was attributed
1 3 | to natural aging of the components. Therefore, no further action is
1 4 | required.

1 5 | FACILITY STATUS | E | 28 | % POWER | 0 | 9 | 8 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | Operator Observation | 31 | DISCOVERY DESCRIPTION | 32

1 6 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | Z | 38 | DESCRIPTION | NA | 39

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | NA | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45 | NRC USE ONLY

8007220 391