NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I L Z I S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 9 5 (7) | 0 6 1 6 8 0 (8) | 0 7 1 6 8 0 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Following performance of the diesel generator loading test (PT-11) on 0
03 DG, the fuel oil storage tank level was found to be 300 gallons less than
04 the 40,000 gallon limit specified in T.S. 3.15.3.A The health and
05 safety of the public were not affected because redundant sources of A.C.
06 power were verified operable. This is the first occurrence of this type.
07
08 80
7 8 9

09 | SYSTEM CODE E E (11) | CAUSE CODE A (12) | CAUSE SUBCODE B (13) | COMPONENT CODE E N G I N E (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 3 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER C 6 3 4 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The engineering assistant in charge of ordering fuel did not anticipate
11 the fuel consumption associated with DG testing every three days. Fuel
12 was transferred from 2A DG storage tank immediately. (Unit 2 in CSD at
13 the time). Fuel consumption will be estimated and fuel pre-ordered as
14 needed to maintain level. No further action required. 80
7 8 9

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator Observation
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA
7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

8007220453

NAME OF PREPARER Alan T. Krawczak PHONE: 312-746-2084