



Portland General Electric Company

Doris J. Broehl, Assistant Vice President

July 17, 1980

Trojan Nuclear Plant
Docket 50-344
License NPF-1

Director of Nuclear Reactor Regulation
ATTN: Mr. R. A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Attached to this letter is a list of Requests for Design Changes (RDCs) associated with the modification program described in the Report on Design Modifications for the Trojan Control Building (PGE-1020). These items are modifications involving piping supports necessary to qualify piping systems for response spectra developed in accordance with PGE-1020, Appendix B. The items on this list will not individually or collectively with other modifications reduce the shear capacity of any major shear wall greater than 1 percent. Nor do the items involve weight additions which may result in an increase of greater than 1 percent of the calculated lateral forces in any major shear wall.

Until the license is amended to allow modification of the Control Building, we will continue to keep you, the Licensing Board and other parties informed of work associated with those modifications. We will continue to keep you informed of any activities at Trojan which involve changes greater than 1 percent as described above.

Sincerely,

A001
S
1/1

c: Mr. R. H. Engelken, Director
U. S. Nuclear Regulatory Commission
Region V

Control Building Service List

8007220 570 P
Portland, Oregon 97204

ATTACHMENT

Following is the list of Request for Design Change (RDC) work items for which field work may be performed within the next few weeks.

The relationship of the work with the Control, Auxiliary and Fuel Building structures is briefly summarized below:

<u>RDC No.</u>	<u>Modification</u>	<u>Relationship</u>
79-028	Job No. 141: A restraint on a 14-inch dia line in the Component Cooling Water System is being modified. HBD-31-2 (SR110)	The restraint is attached to a 44-inch thick shear wall at elevation 55 ft in the Auxiliary Building. Total net weight addition is about 120 lbs.
	Job No. 204: A restraint on a 10-inch dia line in the Spent Fuel Pool Cooling System is being modified. HCC-48-1 (SR78)	The restraint is welded to floor steel at elevation 66 ft in the Auxiliary Building Area 12.

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)
) Docket 50-344
PORTLAND GENERAL ELECTRIC COMPANY,)
et al) (Control Building Proceeding)
)
(Trojan Nuclear Plant))

CERTIFICATE OF SERVICE

I hereby certify that on July 17, 1980, Licensee's letter, dated July 17, 1980 with a list of Requests for Design Changes, has been served upon the persons listed below by depositing copies thereof in the United States mail with proper postage affixed for first class mail.

Marshall E. Miller, Esq., Chairman
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Atomic Safety and Licensing Appeal
Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Kenneth A. McCollom, Dean
Division of Engineering,
Architecture and Technology
Oklahoma State University
Stillwater, Oklahoma 74074

Docketing and Service Section (3)
Office of the Secretary
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Hugh C. Paxton
1229 - 41st Street
Los Alamos, New Mexico 87544

Joseph R. Gray, Esq.
Counsel for NRC Staff
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Lowenstein, Newman, Reis, Axelrad & Toll
1025 Connecticut Ave., N. W.
Suite 1214
Washington, D. C. 20036

CERTIFICATE OF SERVICE

Frank W. Ostrander, Jr., Esq.
Assistant Attorney General
State of Oregon
Department of Justice
500 Pacific Building
520 S. W. Yamhill
Portland, Oregon 97204

William Kinsey, Esq.
Bonneville Power Administration
P. O. Box 3621
Portland, Oregon 97208

Ms. Nina Bell
728 S. E. 26th Avenue
Portland, Oregon 97214


Mr. John A. Kullberg
15523 S. E. River Forest Drive
Portland, Oregon 97222

Mr. David B. McCoy
348 Hussey Lane
Grants Pass, Oregon 97526

Ms. C. Gail Parson
P. O. Box 2992
Kodiak, Alaska 99615

Mr. Eugene Rosolie
Coalition for Safe Power
215 S. E. 9th Avenue
Portland, Oregon 97214

Columbia County Courthouse
Law Library
Circuit Court Room
St. Helens, Oregon 97051


Ronald W. Johnson
Assistant General Counsel
Portland General Electric Company

Dated: July 17, 1980

4sal0A3