



(LTR)

Report No. LO-87-80-134Date: May 28, 1980RELEASED BY LOFT CDCS *sh*

**THIS DOCUMENT CONTAINS
POOR QUALITY PAGES**

RE&C Internal Report RE-A-80-047

USNRC - P394

INTERNAL TECHNICAL REPORT

Title: STRESS ANALYSIS OF THE
MODIFIED PULSED NEUTRON ACTIVATION
SYSTEM DOWNSTREAM SHIELD
SUPPORT STRUCTURE

Organization: Applied Mechanics Branch

Author: W. R. Mosby/ *W. R. Mosby*

NRC Research and Technical
Assistance Report

Checked By: D. P. Finicle/ *D. P. Finicle*

Approved By: R. C. Guenzler/ *R. C. Guenzler*

cc: J. R. Barker (3)
D. P. Finicle
V. W. Gorman *out*
R. C. Guenzler
M. M. Laughlin (3)
W. R. Mosby

Courtesy release to the public on request.
This document was prepared primarily for
internal use. Citation or quotation of this
document or its contents is inappropriate.

8007230194



LOFT TECHNICAL REPORT

Title STRESS ANALYSIS OF THE MODIFIED PULSED NEUTRON ACTIVATION SYSTEM DOWNSTREAM SHIELD SUPPORT STRUCTURE		LTR No. LO-87-80-134 RE-A-80-047
Author W. R. Mosby		Released By LOFT CDCS
Performing Organization Applied Mechanics Branch		Date May 28, 1980 <i>Sh</i>
LOFT Review and Approval <i>R. C. Gungler 4/24/80</i> <i>H. J. Hanson 4-30-80</i>		Project System Engineer <i>R. T. Ford 4/30/80</i>

PSB Mgr.

LMD Mgr.

ABSTRACT

The modified LOFT Pulsed Neutron Activation (PNA) System downstream shielding support structure was stress analyzed for deadweight and worst-case LOCE loads. No deficiencies were found in the structure. This stress analysis was performed for the PNA Shielding Configuration that has been used on Test L3-2 and that is to be used on Test L3-7.

DISPOSITION OF RECOMMENDATIONS

Reference No. 6, LTR LO-87-79-127, will be issued at a later date. No other disposition is required. *RC 4/24/80*

per telecon 5-29-80

NRC Research and Technical Assistance Report

CONTENTS

	Page
ABSTRACT	i
1. INTRODUCTION	1
2. METHOD OF ANALYSIS	2
3. RESULTS	3
4. REFERENCES	4
APPENDIX A - PNA DOWNSTREAM SHIELDING SUPPORT STRESS ANALYSIS	A-i
APPENDIX B - SAP IV SOURCE LISTING	B-i

1. INTRODUCTION

The purpose of this investigation was to determine the adequacy of the modified Pulsed Neutron Activation system structure to support the PNA sources, detectors, and lead shielding during the most severe design loading. The loading consisted of deadweight plus acceleration due to an 8-inch, hot-leg, 0.001 second opening time LOCE. Stresses in the modified downstream detector shielding support structure and the most highly stressed portions of the existing PNA structure were calculated and compared to AISC¹ and ASME² Code allowables. This stress analysis was performed for the PNA shielding configuration that has been used on Test L3-2 and that is to be used on Test L3-7.

2. METHOD OF ANALYSIS

Affected portions of the existing PNA structure along with the modified downstream shielding support structure³ were modelled using the SAP IV finite element computer program.⁴

Deadweight and three response spectrum runs (one for each of x, y, and z directions) were made. The response spectra were obtained from a computer analysis of the MTA.⁵ Ten percent damping was used in generating the response spectra to account for the damping effects of the lead brick shielding.

Beam element and plate element stresses from the SAP IV runs were calculated and combined, using the absolute sum of all force components, and compared to AISC and ASME Code allowables, respectively.

Some portions of the existing PNA structure were analyzed by multiplying the results of the previous PNA stress analysis⁶ by the ratio of the present shielding mass to the original shielding mass, while other parts were analyzed using the static-equivalent load method.⁷

The SAP IV computer output is not included in this report, but is available for inspection at the Applied Mechanics branch.

A listing of the SAP IV version used is included in Appendix B.

3. RESULTS

All components of the PNA shielding support structure analyzed in this investigation were found to be adequate.

Components not analyzed in this report include the actual methods of attachment of the lead shielding to the PNA source support structure, as mentioned in the previous PNA stress analysis.

4. REFERENCES

1. Manual of Steel Construction, American Institute of Steel Construction, 7th edition, 1970.
2. "Nuclear Power Plant Components," ASME Boiler and Pressure Vessel Code, American Society of Mechanical Engineers, Section III, Division 1, 1977.
3. EG&G Idaho, Inc., "LOFT Pulse Neutron Activation System," Drawing No. 210358, August 24, 1979.
4. R. C. Guenzler, IBM 360/75 and CDC7600 Versions of SAP IV, a Structural Analysis Program for Static and Dynamic Analysis of Linear Systems, TR-775, January 1976.
5. R. G. Rahl, "Stress Analysis of the LOFT Mobile Test Assembly," LTR 1110-20, February 20, 1974.
6. W. R. Mosby, "Stress Analysis of the Pulsed Neutron Activation System Support Structure," LTR LO-87-79-127, to be published.
7. RDT Standard F9-2T, Division of Reactor Research and Development, United States Atomic Energy Commission, January 1974.

LO 87 80 134

APPENDIX A

PNA DOWNSTREAM SHIELDING SUPPORT STRESS ANALYSIS

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Date _____ Page A-1 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Work Request _____

Contents

I. Materials	2
A. Beams, channels, plate	2
B. Welds	3
C. Bolts	4
II. Arrangement of Structure	4
III. Loading Considered	4
IV. Existing structure affected by downstream shielding modifications	10
A. structural Members 1-10 (fig. 1)	10
B. Existing W6x25 beam, member 11 (fig. 1)	15
C. W6x15.5 beams, 12-14 (fig. 1)	17
V. New downstream shielding structure	19
A. W4x13 beams, members 15-24 (fig. 1, 2)	19
B. C6x13 channels, members 26 & 27 (fig. 1)	20
C. Plates used in downstream shielding box, member 25, fig. 1	21
VI. Connections	23
A. Connections in existing structure	23
B. Connections in new downstream shielding structure	24

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-2 of _____ Pages
 Date _____
 Prepared By W.R. Mosby Checked _____ Work Request _____

I. Materials

A. Beams, channels, plate

material - A-36 steel

$$S_y = 36,000 \text{ psi} = \text{yield stress}$$

$$S_u = 58,000 \text{ psi} = \text{ultimate stress}$$

$$\rho = .286 \text{ lb/in}^3$$

AISC code (Ref. 1) allowable stresses were used for all structural members except plates. For plates, the stress intensities for membrane stress alone and for membrane plus bending were compared to ASME (Ref. 2) allowable stress intensities of $\frac{2}{3} S_y$ and S_y , respectively.

For structural members other than plate, the following allowable stresses were used:

$$F_t = \text{allowable axial stress in tension} = .6 S_y$$

$$F_b = \text{allowable normal stress in bending} = .6 S_y$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-4 of _____ Pages
 Prepared By W.R. Mosby Date _____
 Checked _____ Work Request _____

II. Arrangement of structure

Figures 1 and 2 show the physical arrangement of the structure considered in this analysis.

Figures 3, 4, and 5 show the SAP^{IV} model of the structure used in this analysis.

III. Loading considered

The same loading used in the original PNA LOCE analysis (Ref. 6) was used in this analysis.

A plot of the spectra was shown in ref. 6 and will not be repeated here.

Static equivalent loads the same as in ref. 6 were used here:

$$A_x = \text{acceleration in } x\text{-direction} = 1.5 (\text{spectrum peak}) = 4.46g$$

$$A_y = 2.81g$$

$$A_z = +1.46g, -3.46g$$

CALCULATION WORK SHEET

Page A-5 of _____ Pages

Subject Downstream Shielding Support An Date _____

Prepared By W. R. Mosby Checked _____ Work Request _____




Figure 1: Overall view of shielding support structure looking toward MTA

CALCULATION WORK SHEET

Page A-6 of _____ Pages
Subject PNA Downstream Shielding Support An. Date _____
Prepared By W. R. Masby Checked _____ Work Request _____





Figure 2: Overall View of Shielding Support Structure, looking away from MTA

CALCULATION WORK SHEET

Page A-7 of _____ Pages

Subject PNA Downstream Shielding Support An. Date _____

Prepared By W.R. Mosby Checked _____ Work Request _____



- node
- beam element number
- ⊥ section schematic and orientation
- ▨ built-in beam end

Figure 3: SAP IV Model of Shielding Support structure

CALCULATION WORK SHEET

Page A-9 of _____ Pages

Subject PNA Downstream Shielding Support An. Date _____

Prepared By W.K. Mosby Checked _____ Work Request _____




Figure 5: Detail of SAPIV Model of Shielding Support Structure showing Plate Elements Representing Rear of Shielding Box

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-10 of _____ Pages
 Date _____
 Prepared By W.R. Masby Checked _____ Work Request _____

IV. Existing structure affected by downstream shielding modifications

A. Structural members 1-10 (fig. 1)

These members were analyzed previously (Ref. 6).

The results of this analysis are in the form of

$$R = \frac{\text{combined stress}}{\text{allowable stress}} \quad ?$$

From Ref. 1, part 5, section 1.6, equations 1.6-1a, 1.6-1b, and 1.6-2 as applicable. These members will be more severely stressed in the present case due to An (next page)

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-11 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

increased shielding weight. Therefore new values of R can be conservatively calculated by multiplying R by

$$\frac{\text{weight of new downstream} + \text{source shielding}}{\text{weight of source shielding}}$$

This is conservative because it neglects the weight of the old downstream shielding which would appear in the denominator.

$$\begin{aligned} &\text{Weight of new downstream shielding} \\ &= .42 \frac{\text{lb}}{\text{in}^3} \times 28 \text{ in} \times 24 \text{ in} \times 34.75 \text{ in} = 9807 \text{ lb} \end{aligned}$$

$$\text{weight of source shielding (ref. 6)} = 7903$$

$$R' = R \left(\frac{9807 + 7903}{7903} \right) = \underline{\underline{2.24 R}}$$

Table I shows the results of this procedure.

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-12 of Pages
 Prepared By W.R. Mosby Date
 Checked Work Request

Table I: Stress/Allowable for Existing Structure

Structural Member	Element # ₂ (Ref. #)	R (Ref. #)	Eqn. # (Ref. #)	R'	Passes?	Element # ₂ (present)
1	1	.140	1.6-2	.314	yes	1
2	3	.130	1.6-2	.291	yes	3
3	5	.340	1.6-1a	.762	yes	11
	164	.310	1.6-1a	.695	yes	
4	17	.110	1.6-1b	.247	yes	32
5	18	.120	1.6-1b	.269	yes	33
6	19	.120	1.6-1b, -2	.269	yes	34
7	158	.690	1.6-2	1.546	no	47
	159	.360	1.6-2	.807	yes	
	160	.250	1.6-2	.560	yes	
	161	.260	1.6-2	.583	yes	
	162	.460	1.6-2	1.031	no	
	163	.630	1.6-2	1.412	no	
8	140	.180	1.6-2	.403	yes	48
	141	.130	1.6-2	.291	yes	
	142	.160	1.6-1b, -2	.359	yes	
	143	.330	1.6-1b, -2	.74	yes	
	144	.530	1.6-2	1.188	no	
9	315	.170	1.6-2	.381	yes	13
	316	.150	1.6-2	.336	yes	
	317	.210	1.6-2	.471	yes	
10	136	.460	1.6-2	1.031	no	19 20
	137	.410	1.6-1b	.919	yes	
	138	.570	1.6-1b	.515	yes	
	139	.340	1.6-1b, -2	.762	yes	

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-13 of _____ Pages
 Date _____
 Prepared By W.R. Mosby Checked _____ Work Request _____

The members shown to fail in Table I will be analyzed somewhat less conservatively by adding the maximum force components caused by x-direction accelerations applied to the downstream shielding in the beams in question (shear force V_2 and moment M_2 , along with axial force R_1 and torsion T_1) to the maximum force components calculated for these beams in Ref. 6. X-direction accelerations are the only ones which cause the downstream shielding to load these beams.

$$\text{Forces} \left\{ \begin{array}{l} R_1 = 4185 + 1094 = 5,279 \text{ lb}; T_1 = 392 + 22 = 414 \text{ in-lb} \\ V_2 = 1,068 + 568 = 1,636 \text{ lb}; M_2 = 45,890 \text{ in-lb} \\ V_3 = 6,931 \text{ lb} \quad M_3 = 7,710 + 11,544 = 19,254 \text{ in-lb} \end{array} \right.$$

Stresses (W4x13 section)

$$S_a = \frac{5279}{3.82} = 1,382 \text{ psi}$$

$$S_{b_2} = \frac{45,890}{5.45} = 8,420 \text{ psi}$$

$$\begin{aligned} S_v &\leq \frac{2961}{2.8} + \frac{6931}{1.17} + \frac{414(1.20)}{.154} \\ &= 7,734 \text{ psi} \end{aligned}$$

$$S_{b_3} = \frac{19,254}{1.85} = 10,408 \text{ psi}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-14 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

Allowable stresses (Ref. 1)

$$C_c = \sqrt{\frac{27^2 (297106)}{36,000}} = 126.1$$

$$\frac{KtL}{r} \leq \frac{2(44.6)}{.991} = 90 < C_c \quad ; \quad \frac{KtL/r}{C_c} = .71$$

$$F_a = \frac{[1 - \frac{1}{2}(.71)^2] (36,000)}{\frac{5}{3} + \frac{7}{8}(.71) - \frac{1}{8}(.71)^2} = 14,260 \text{ psi}$$

$$\frac{f_a}{F_a} = \frac{1382}{14,260} = .10 \quad \text{so use eqn. 1.6-2 :}$$

$$F_b = .6(36,000) = 21,600$$

$$.10 + \frac{8,420 + 10,908}{21,600} = .97 < 1$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-15 of Pages
 Prepared By W.R. Mosby Date
 Checked Work Request

B. Existing W6x25 beam, member 11 (fig. 1)

Almost all the loading on this beam is due to deadweight and LOCE z-accelerations. (fig 6).




Figure 6: Existing W6x25 beam: arrangement

The total force acts on both the W6x25 beam and on 8-W4x13 beams of average length 42 inches.

The stiffness of the 8 W4x13's together is

$$K_1 = \frac{2EI}{l^3} = \frac{2(29 \times 10^6)(11.3)}{42^3}$$

$$K_1 = 7.077 \times 10^9 \text{ lb/in}$$


The stiffness of the W6x25 beam will be calculated by assuming that half the load is applied by each vertical W6x15.5 and using the average

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-16 of Pages
 Prepared By W.R. Mosby Checked Work Request

of the deflections calculated at both points (Fig. 7)

From Ref. 1,



$\Delta x_a =$ deflection at a

$$= \frac{F a}{12 E I l} \left[(l^2 - a^2)(b + 2c) - (b + c)^2 - c^2 \right]$$

$$\Delta x_b = \frac{F c}{12 E I l} \left[(l^2 - c^2)(b + 2a) - (a + b)^2 - a^2 \right]$$

Figure 7: W6x25 beam (#11, sig. 1)

With $l = 116$
 $a = 51$
 $b = 26$

$c = 39$
 $E = 29 \times 10^6$
 $I = 53.3$

$$\Delta x = \frac{1}{2} (\Delta x_a + \Delta x_b) = 1.793 \times 10^{-5} F'$$

$$K = K_2 = \frac{F'}{\Delta x} = \underline{5.578 \times 10^4 \text{ lb/in}}$$

The total force applied to the W6x25 beam is

$$F' = \frac{5.578 \times 10^4}{7.077 \times 10^4 + 5.578 \times 10^4} (9807)(3.46) = \underline{\underline{14,956 \text{ lb}}}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-17 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Work Request _____
 Date _____

Bonding moment at a & b:

$$M_a = \frac{1}{2} F' \left\{ \frac{(b+c)(a)}{l} + \frac{(c)(a)}{l} \right\} = 22.86 F'$$

$$M_b = \frac{1}{2} F' \left\{ \frac{cb + 2ca}{l} \right\} = 21.52 F'$$

$$\text{Max moment} = M_a = 341,894 \text{ in-lb}$$

$$S = 16.7 \text{ for } W6 \times 25, \text{ so}$$

$$f_b = \frac{341,894}{16.7} = 20,473 \text{ psi} < 0.6 \text{ yield} = 21,600 \text{ psi}$$

C. W6x15.5 beams, members 12-14, Fig. 1

Loads (maximum)

$$R_1 = 8108 \text{ lb}$$

$$T_1 = 95 \text{ in-lb}$$

$$V_2 = 2606 \text{ lb}$$

$$M_2 = 17,910 \text{ in-lb}$$

$$V_3 = 461 \text{ lb}$$

$$M_3 = 58,504 \text{ in-lb}$$

$$f_a = \frac{8,108}{4.57} = 1,774 \text{ psi}$$

$$f_{b_2} = \frac{17,910}{10} = 1,791 \text{ psi}$$

$$f_v = \frac{2,606}{3.23} + \frac{461}{1.41} + \frac{95(1.235)}{.111}$$

$$f_{b_3} = \frac{58,504}{3.23} = 18,113 \text{ psi}$$

$$= 1335 \text{ psi}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-18 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Work Request _____

shear

$$\frac{F_v}{F_r} = \frac{1335}{14,400} = .09 < 1$$

combined

$$\frac{KL}{r} \leq \frac{(1)(92)}{1.46} = 63 < C_c$$

$$C_c = 126.1, \quad \frac{KL/r}{C_c} = .5$$

$$F_a = \frac{[1 - \frac{1}{2}(.5)^2] 36,000}{\frac{5}{8} + \frac{3}{8}(.5) - \frac{1}{8}(.5)^2} = 17,133 \text{ psi}$$

$$F_c' \leq \frac{12(\pi^2)(29,000,000)}{23(63)^2} = 37,624$$

$$C_m = .85, \quad F_b = .6(36,000) = 21,600; \quad \text{eqns. 1.6-1a + 1.6-1b}$$

are then:

$$1.6-1a \quad \frac{1774}{17133} + \frac{.85(1741)}{(1 - \frac{1774}{37624})21,600} + \frac{.85(17133)}{(1 - \frac{1774}{37624})21,600} = \underline{\underline{.92 < 1}}$$

$$1.6-1b \quad \frac{1774}{21,600} + \frac{1741 + 17133}{21,600} = \underline{\underline{1.00}}, \text{ so o.k.}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support Anc Page A-19 of _____ Pages
 Date _____
 Prepared By W.R. Masby Checked _____ Work Request _____

V. New downstream shield structure
 A. W4 x 13 beams, members 15 - 24

Loads (MAXimum) -

$$R_1 = 3271 \text{ lbs}$$

$$T_1 = 935 \text{ lbs}$$

$$V_2 = 1243 \text{ lbs}$$

$$M_2 = 45190 \text{ in-lbs}$$

$$V_3 = 3235 \text{ lbs}$$

$$M_3 = 19,776 \text{ in-lbs}$$

Stresses -

$$f_a = \frac{3271}{3.82} = 856 \text{ psi}$$

$$f_{b_2} = \frac{45,190}{5.45} = 8292 \text{ psi}$$

$$f_w \leq \frac{1243}{2.8} + \frac{3235}{1.17} + \frac{935(.28)}{.154}$$

$$f_{b_3} = \frac{19,776}{1.85} = 10,690 \text{ psi}$$

$$= 4909 \text{ psi}$$

Allowable stresses (ref. 1)

$$C_c = 126.1, \quad \frac{KL}{r} \approx \frac{1(80)}{.991} = 80.73, \quad \frac{KL/r}{C_c} = .64$$

$$F_a = \frac{[1 - \frac{1}{2}(.64)^2](36,000)}{\frac{5}{3} + \frac{3}{8}(.64) - \frac{1}{8}(.64)^3} = 15,277 \text{ psi}$$

$$\frac{f_a}{F_a} = \frac{856}{15,277} = .06, \quad \text{so eqn. 1.6-2 applies}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-20 of _____ Pages
 Date _____
 Prepared By W.R. Mosby Checked _____ Work Request _____

$$.06 + \frac{8292 + 10,690}{21,600} = \underline{\underline{.94 < 1}}$$

$$\frac{f_v}{F_v} = \frac{4909}{14,400} = \underline{\underline{.34 < 1}}$$

B. C 6 x 13 channels, members 26+27, fig. 1

Loads (max)

$R_1 = 6828$

$T_1 = 882$

$V_2 = 1229$

$M_2 = 57,618$

$V_3 = 4083$

$M_3 = 11,310$

section properties

$A_1 = 7.66 \text{ in}^2$

$J_1 = .482, k_1 = .343$

$r = .525$

$A_2 = 2.959 \text{ in}^2$

$S_2 = 11.6$

$A_3 = 5.299 \text{ in}^2$

$S_3 = 1.28$

Stresses

$f_a = \frac{6828}{7.66} = 891 \text{ psi}$

$f_{b_2} = \frac{57,618}{11.6} = 4967 \text{ psi}$

$f_v = \frac{1229}{2.959} + \frac{4083}{5.299} + \frac{882(.343)}{.482} = 1822 \text{ psi}; f_{b_3} = \frac{11,310}{1.28} = 8836 \text{ psi}$

CALCULATION WORK SHEET

Subject PIVA Downstream Shielding Support An. Page A-21 of _____ Pages
 Prepared By W. R. Mosby Checked _____ Date _____
 Work Request _____

$$\frac{kl}{r} = \frac{2(32)}{.525} = 122 ; C_c = 126.1 ; \frac{kl}{r/C_c} = .9675$$

$$F_a = \frac{[1 - (.9675)^4] 36,000}{\frac{5}{3} + \frac{3}{8} (.9675) - \frac{1}{8} (.9675)^3} = 9,994 \text{ psi}$$

$$\frac{F_a}{F_a} = .089 < .15, \text{ so 1.6-2 applies -}$$

$$.089 + \frac{4967 + 8836}{21,600} = \underline{\underline{.73 < 1}}$$

$$\frac{F_m}{F_r} = \frac{1822}{14,900} = \underline{\underline{.13 < 1}}$$

C. Plates used in downstream shielding box (#25, fig. 1)

plate thickness = .25 in

Maximum loads -

membrane stresses

$$\sigma_x = 742 \text{ psi}$$

$$\sigma_y = 1079 \text{ psi}$$

$$\tau_{xy} = 2296 \text{ psi}$$

$$\left. \begin{array}{l} \sigma_x = 742 \text{ psi} \\ \sigma_y = 1079 \text{ psi} \\ \tau_{xy} = 2296 \text{ psi} \end{array} \right\} 2\tau_{\text{max membrane}} = 4940 \text{ psi}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-22 of Pages
 Date
 Prepared By W.R. Mosby Checked Work Request

bending stresses + membrane stresses

$$\left. \begin{aligned}
 \sigma_x &= 6496 + 742 = 7238 \\
 \sigma_y &= 8270 + 1079 = 9349 \\
 \tau_{xy} &= 12237 + 2296 = 14533
 \end{aligned} \right\} 2\tau_{\max \text{ memb + bend}} = 29,371 \text{ psi}$$

Allowable stresses - the ASME code (Ref. 7)
 will be used as a guide here, since the
 AISC code (Ref. 1) does not address plate
 structures -

$$\text{allowable membrane stress intensity} = \frac{2}{3}(36,000) = \underline{24,000 \text{ psi}}$$

$$\text{allowable memb. + bending stress intens.} = \underline{36,000}$$

$$\text{so } \frac{2\tau_{\max \text{ memb}}}{24,000} = \underline{\underline{.21 < 1}}$$

$$\frac{2\tau_{\max \text{ memb + bend}}}{36,000} = \underline{\underline{.82 < 1}}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-23 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

VI. Connections
A. Connections in existing structure

The method of **IV. A.** (p.10) will be used

1. Connection of angled W4x13 beam to MTA built-up beam (fig. 1, connection # 1)

See ref. 6, p. 69: this is the most highly stressed major connection in the source structure, so re-analyze:

$$R_1 = 2988 \quad T_1 = 123 \quad (\text{See Fig. 3, node 54})$$

$$V_2 = 1953(2.24) = 4375; M_2 = 8031$$

$$V_3 = 1162 \quad M_3 = 16,960(2.24) = 37,990$$

at ①

$$\left. \begin{aligned} \tau_{12} &= \frac{2988}{2.683} + \frac{2(37,990)}{2.683(4.06)} = 8,089 \text{ psi} \\ \tau_2 &= \frac{4375}{2.683} = 1631 \text{ psi} \\ \tau_{32} &= 3699 \text{ psi} \end{aligned} \right\} \sigma_{\max} = \underline{\underline{8946 \text{ psi} < 14,400}}$$

at ②

$$\left. \begin{aligned} \tau_{13} &= 8089 \\ \tau_{23} &= 1631 \\ \tau_3 &= 3699 \end{aligned} \right\} \sigma_{\max} = \underline{\underline{10,111 \text{ psi} < 14,400 \text{ psi}}}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-24 of _____ Pages
 Date _____
 Prepared By W.R. Masby Checked _____ Work Request _____

2. Connections between W6x15.5 uprights and existing W6x15 beams (Fig. 1, # 2-6) see ref. 6 p. 47-51:

$$\sigma_{MAX} = 2.2 + (5383) = \underline{\underline{12,053}} < 19,400 \text{ psi}$$

B. Connections in new shielding support structure

1. Connections between C6x13 channel and W6x15.5 upright beams (# 7-10, Sig. 1)





Figure 8: Connection between C6x13's and W6x15.5's

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-25 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

Loads

$$R_1 = 6828 \text{ lb}$$

$$T_1 = 882 \text{ in-lb}$$

$$V_2 = 1229 \text{ lb}$$

$$M_2 = 57,618 \text{ in-lb}$$

$$V_3 = 4083 \text{ lb}$$

$$M_3 = 11,310 \text{ in-lb}$$

Forces parallel to weld

due to R_1 $F'_{R_1} = \frac{6828}{4(6)} = \underline{285 \text{ lb/in}}$

due to M_2 :

$$\frac{1}{4}(57,618) = F'_{M_2}(3)(6) \Rightarrow F'_{M_2} = \underline{900 \text{ lb/in}}$$

Forces perpendicular to weld

due to V_2

$$F'_{V_2} = \frac{1229}{4(6)} = \underline{51 \text{ lb/in}}$$

due to V_3

$$F'_{V_3} = \frac{4083}{4(6)} = \underline{170 \text{ lb/in}}$$

due to T_1 : $F'_{T_1} = \frac{882}{6(2)(6)} = \underline{12 \text{ lb/in}}$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-26 of Pages
 Prepared By W.R. Masby Checked Work Request

due to M_3

$$2 \left\{ 2 \left(\frac{1}{2} F'_{m_3} \right) (3) \right\} = \frac{1}{4} (11,310)$$

$$F'_{m_3} = 471.25 \text{ lb/in}$$

$$\begin{aligned} \text{total force/in} &= \sqrt{(285 + 800)^2 + (51 + 12 + 471.25)^2 + 170^2} \\ &= 1221 \text{ lb/in} \end{aligned}$$

$$\sigma_{\text{weld}} = \frac{1221}{(.707)(.25)} = \underline{\underline{6910 \text{ psi} < 14,400 \text{ psi}}}$$

2. Connections between C6X13 channels and W4X13 beam (fig. 1, # 11)





Figure 9: Connections between C6X13 channels and W4X13 beam

CALCULATION WORK SHEET

Subject PVA Downstream Shielding Support An. Page A-27 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

Weld section properties -

$$\text{Area} = 2 (.343 (2.16 - .437) + .437 (.06)) = 4.73 \text{ in}^2$$

$$\bar{x} = \frac{.437 (1.624) + \frac{2.16}{2} (.141)}{1.624 + .741} = .488 \text{ in}$$

$$\bar{I}_{xx} = \underline{.692 \text{ in}^4}$$

$$\bar{y} = \frac{\frac{4.06}{2} (1.774) + \frac{.343}{2} (.591)}{.591 + 1.774} = 1.566 \text{ in}$$

$$\bar{I}_{yy} = \underline{3.979 \text{ in}^4}$$

Loads

$$R_1 = 1952 \text{ lb}$$

$$T_1 = 298 \text{ in-lb}$$

$$V_2 = 308 \text{ lb}$$

$$M_2 = 7447 \text{ in-lb}$$

$$V_3 = 1322 \text{ lb}$$

$$M_3 = 7771 \text{ in-lb}$$

forces

parallel to weld

$$\text{due to } V_2 : \frac{308}{4.32} = 71.3 \text{ lb/in.}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-28 of _____ Pages
 Prepared By W.R. Mosby Checked _____ Date _____
 Work Request _____

$$\text{due to } V_3 : \frac{1322}{8.12} = 163 \text{ lb/in}$$

$$\text{due to } T_1 : \frac{298}{6(4.06)} = 12.2 \text{ lb/in}$$

normal to weld

due to M_2

$$\frac{7497(4.06 - 1.566)}{2(3.974)} (.437) = 1028 \text{ lb/in}$$

due to M_3

$$\frac{7771(2.16 - .988)}{2(1.692)} (.343) = 3220 \text{ lb/in}$$

due to R_1

$$\frac{1952}{2(4.06 + 2.16)} = 157 \text{ lb/in}$$

$$\begin{aligned} \text{MAX force/in} &= \sqrt{(3220 + 157)^2 + (163 + 12.2)^2} \\ &= 3382 \text{ lb/in} \end{aligned}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An Page A-29 of Pages
 Prepared By W.R. Mosby Checked Work Request

so weld stress $\leq \frac{3382}{.343} = 9859 \text{ psi} < 19,900$

3. Connection between W4X13 beam and MTA built-up beams (fig. 1, #12; fig. 10)





Figure 10: W4X13 beam structure

strength of connection -



Effective weld leg - thicknesses of section are greater than 1/4 inch, so RS&T, sec. 1.17.6 applies -

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-30 of Pages
 Prepared By W.R. Masby Checked Date
 Work Request

and maximum weld size is $\frac{1}{16}$ inch less than material thickness


flanges : $.345 - \frac{1}{16} = .2825 \Rightarrow .25$ inch leg, a

web : $.28 - \frac{1}{16} = .2175$ inch leg, a

$a < \frac{3}{16}$ in each case, so the weld throat is equal to the weld leg, .25 and .22 inches, respectively. The weld allowable stress is

14,400 psi vs. 21,600 psi for the base metal.

To allow for this, reduce the effective weld throats by $\frac{14,400}{21,600} = .67$ to .17 in and .15 in, respectively. The weld pattern is then:




CALCULATION WORK SHEET

Page A-31 of _____ Pages
 Subject PNA Downstream Shielding Support An. Date _____
 Prepared By W.R. Mosby Checked _____ Work Request _____

The effective weld section is as strong as the beam itself, so no further analysis is required.

By inspection, the gusset welds (fig. 1, # 13; fig. 10) are stronger than the end welds just considered.

4. Connections between 8 W4X13 beams and MTA built-up beam and C6X13 channels (fig. 1, # 14/15)



The weld at the built-up beam end is the weaker, so analyze it with the worst loads.

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-32 of _____ Pages
 Date _____
 Prepared By W. R. Mosby Checked _____ Work Request _____

LOADS

$$R_1 = 1297 \text{ lb}$$

$$T_1 = 25 \text{ in-lb} \cong 0$$

$$V_2 = 306 \text{ lb}$$

$$M_2 = 51465 \text{ in-lb}$$

$$V_3 = 777 \text{ lb}$$

$$M_3 = 13,312 \text{ in-lb}$$

Forces parallel to weld

due to V_2

$$F'_{V_2} = \frac{306}{8} = 38.25 \text{ lb/in}$$

due to M_3

$$F'_{M_3} = \frac{13,312}{9.6(4)} = 347 \text{ lb/in}$$

Forces perpendicular to weld

in direction

due to R_1

$$F'_{R_1} = \frac{1297}{8} = 162 \text{ lb/in}$$

CALCULATION WORK SHEET

Subject PNA Downstream Shielding Support An. Page A-33 of Pages
 Prepared By W.R. May Checked Date
 Work Request

in -3 direction

due to M_2

$$F'_{m_2} = \frac{51465}{9.6(4)} = 1340 \text{ lb/in}$$

$$\begin{aligned} \text{Total weld force/in} &= \sqrt{(347 + 38.25)^2 + 162^2 + 1390^2} \\ &= 1404 \text{ lb/in} \end{aligned}$$

$$\text{weld stress} = \frac{1404}{(707)(1.25)} = \underline{\underline{7992 \text{ psi} < 19,400 \text{ psi}}}$$

S. Connections between plates in welded box structure

The plates are nearly simply-supported, so the welds are only subject to the membrane stresses in the plates

Loads MAX normal stress in plate = 3191 psi
 MAX shear stress in plate = 2296 psi

CALCULATION WORK SHEET

Page A-34 of _____ Pages
 Subject PNA Downstream Shielding Support An. Date _____
 Prepared By W.R. Mosby Checked _____ Work Request _____

weld forces/inch

parallel - $2296 (.25) = 574 \text{ lb/in}$

normal - $3141 (.25) = 785 \text{ lb/in}$

total = 973 lb/in


weld stress = $\frac{973}{.707(.25)} = \underline{\underline{5505 \text{ psi} < 14,900 \text{ psi}}}$

6. Bolted connection in shield box structure (fig 1, #17)

18 bolts, $\frac{1}{2}$ inch 13 VNC

stress = $\frac{9807 \text{ lb} (4.46)}{18 (.1414)} = \underline{\underline{17,127 \text{ psi} < 20,000 \text{ psi}}}$

the bolts attach the cover plate to the box through a welded angle 20 inches long (See sketch),



weld stress = $\frac{9807 (4.46)}{80 (.125) (.707)} = \underline{\underline{6187 \text{ psi} < 14,900 \text{ psi}}}$

APPENDIX B
SAP IV SOURCE LISTING

CALCULATION WORK SHEET

Subject SAP IV Source Listing Page B-1 of _____ Pages
Date _____
Prepared By _____ Checked _____ Work Request _____



SAP IV Source Listing