

**ornl**

**OAK  
RIDGE  
NATIONAL  
LABORATORY**

**UNION  
CARBIDE**

**OPERATED BY  
UNION CARBIDE CORPORATION  
FOR THE UNITED STATES  
DEPARTMENT OF ENERGY**

**8007240317**

*Terry*  
NUREG/CR-1417  
ORNL/NUREG/NSIC-175  
(Revision to ORNL/NUREG/NSIC-147)

Index to  
**NUCLEAR SAFETY**  
A Technical Progress Review  
by  
Chronology, Permuted Title, and Author  
Vol. 11 (1) through Vol. 20 (6)

Wm. B. Cottrell

Margaret Passiakos

Prepared for the U.S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research  
Under Interagency Agreements DOE 40-551-75 and 40-552-75

NUCLEAR SAFETY INFORMATION CENTER

**NSIC**

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

AVAILABILITY OF NSIC DOCUMENTS

Recent NSIC reports that may be ordered from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161 are listed below.

SIC/NSIC	Title	Price*
112	Compilation of Nuclear Standards, 9th Edition, 1977, Part 11. Unit 4 Status Activities, J. P. Szakely, Oct. 1977	\$12.50
113	A Selected Bibliography on Emergency Core Cooling Systems (ECCS) for Light-Water-Cooled Power Reactors (LWRs), Wm. B. Cottrell, Jan. 1974	\$12.50
114	Annotated Bibliography of Safety-Related Occurrences in Nuclear Power Plants as Reported in 1973, R. L. Scott and R. B. Gallaber, Nov. 1973	\$13.00
117	Protection of Nuclear Power Plants Against External Disasters, Wm. B. Cottrell, April 1973	\$15.00
119	A Selected Bibliography on Pressure Vessels for Light-Water-Cooled Power Reactors (LWRs) Fred A. Heddleson, Jan. 1975	\$15.00
120	Annotated Bibliography of Hydrogen Considerations in Light-Water-Power Reactors, G. W. Keilholtz, Feb. 1974	\$16.00
121	Reactor Operating Experiences, 1972-1974, U.S. Nuclear Regulatory Commission, Dec. 1975	\$ 8.00
122	Annotated Bibliography of Safety-Related Occurrences in Nuclear Power Plants as Reported in 1974, R. L. Scott and R. B. Gallaber, May 1975	\$15.00
123	Nuclear Power: Accident Probability, Risks, and Benefits: A Bibliography, NSIC Staff, Feb. 1974	\$ 8.00
118 <sup>1</sup>	Siting of Nuclear Facilities., Selections from Nuclear Safety, J. R. Buchanan, July 1976	\$ 9.75
125	LMFBR Safety, 1. Review of Current Issues and Bibliography of Literature (1960-1969), J. R. Buchanan and G. W. Keilholtz, Sept. 1976	\$12.75
126	Annotated Bibliography of Safety-Related Occurrences in Boiling-Water Nuclear Power Plants as Reported in 1975, R. L. Scott and R. B. Gallaber, July 1975	\$11.00
127	Annotated Bibliography of Safety-Related Occurrences in Pressurized-Water Nuclear Power Plants as Reported in 1975, R. L. Scott and R. B. Gallaber, July 1975	\$10.75
128	HTGR Safety, 1. Review of Current Issues and Bibliography of Literature (1960-1977), J. R. Buchanan and G. W. Keilholtz, July 1978	\$ 8.50
129	LMFBR Safety, 2. Review of Current Issues and Bibliography of Literature (1970-1972), J. R. Buchanan and G. W. Keilholtz, Dec. 1976	\$13.00
130	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, November 1973-June 1976, J. R. Buchanan, Oct. 1976	\$ 3.50
131	LMFBR Safety, 3. Review of Current Issues and Bibliography of Literature (1972-1974), J. R. Buchanan and G. W. Keilholtz, April 1977	\$12.75
132	LMFBR Safety, 4. Review of Current Issues and Bibliography of Literature (1974-1975), J. R. Buchanan and G. W. Keilholtz, April 1977	\$13.00
133	Index to Nuclear Safety, A Technical Progress Review by Chronology, Permuted Title, and Author, Vol. 11, No. 1 Through Vol. 12, No. 6, Wm. B. Cottrell and Ann Klein, April 1977	\$ 3.50
134	Reports Distributed Under the NRC Light-Water Reactor Safety Technical Exchange, Wm. B. Cottrell and D. S. Sharp, April 1977	\$ 4.00
135	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, J. R. Buchanan, March 1977	\$ 3.50
136	Design Data and Safety Features of Commercial Nuclear Power Plants, Vol. VI (Sixth Volume of ORNL/NWIC-55), F. A. Heddleson, June 1977	\$ 5.50
137	Annotated Bibliography of Safety-Related Occurrences in Boiling-Water Nuclear Power Plants as Reported in 1976, R. L. Scott and R. B. Gallaber, Sept. 1977	\$11.75
138	Annotated Bibliography of Safety-Related Occurrences in Pressurized-Water Nuclear Power Plants as Reported in 1976, R. L. Scott and R. B. Gallaber, Aug. 1977	\$12.00
139	LMFBR Safety, 5. Review of Current Issues and Bibliography of Literature: Vol. 5, 1975-1976, J. R. Buchanan and G. W. Keilholtz, July 1977	\$13.75
140	Structural Integrity of Materials in Nuclear Service: A Bibliography, F. A. Heddleson, July 1977	\$ 9.25
141	Summary Data for U.S. Commercial Nuclear Power Plants, F. A. Heddleson	

NUREG/CR-1417  
ORNL/NUREG/NSIC-175  
(Revision to ORNL/NUREC/NSIC-147)  
Dist. Category AE

Contract No. W-7405-eng-26

Nuclear Safety Information Center

INDEX TO  
*NUCLEAR SAFETY*  
A TECHNICAL PROGRESS REVIEW  
BY  
CHRONOLOGY, PERMUTED TITLE, AND AUTHOR  
VOL. 11(1) THROUGH VOL. 20(6)

Wm. B. Cottrell  
Engineering Technology Division  
Margaret Passiakos  
Information Division

Manuscript Completed - April 30, 1980  
Date Published - June 1980

Prepared for the  
U.S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research  
Under Interagency Agreements DOE 40-551-75 and 40-552-75

NRC FIN No. B0126

Prepared by the  
OAK RIDGE NATIONAL LABORATORY  
Oak Ridge, Tennessee 37830  
operated by  
UNION CARBIDE CORPORATION  
for the  
DEPARTMENT OF ENERGY

Printed in the United States of America. Available from  
National Technical Information Service  
U.S. Department of Commerce  
5285 Port Royal Road, Springfield, Virginia 22161

Available from  
GPO Sales Program  
Division of Technical Information and Document Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

## CONTENTS

	<u>Page</u>
FOREWORD .....	v
ABSTRACT .....	vii
INTRODUCTION .....	ix
SECTION 1. CHRONOLOGICAL MAIN INDEX .....	1
SECTION 2. PERMUTED-TITLE (KWIC) INDEX .....	103
SECTION 3. AUTHOR INDEX .....	137

## FOREWORD

The Nuclear Safety Information Center (NSIC), which was established in March 1963 at Oak Ridge National Laboratory, is principally supported by the U.S. Nuclear Regulatory Commission's Office of Nuclear Regulatory Research. Support is also provided by the Division of Reactor Research and Technology of the Department of Energy. NSIC is a focal point for the collection, storage, evaluation, and dissemination of safety information to aid those concerned with the analysis, design, and operation of nuclear facilities. Although the most widely known product of NSIC is the technical progress review *Nuclear Safety*, the Center prepares reports and bibliographies as listed on the inside covers of this document. The Center has also developed a system of key words to index the information which it catalogs. The title, author, installation, abstract, and key words for each document reviewed are recorded at the central computing facility in Oak Ridge. The references are cataloged according to the following categories:

1. General Safety Criteria
2. Siting of Nuclear Facilities
3. Transportation and Handling of Radioactive Materials
4. Aerospace Safety (inactive ~1970)
5. Heat Transfer and Thermal Hydraulics
6. Reactor Transients, Kinetics, and Stability
7. Fission Product Release, Transport, and Removal
8. Sources of Energy Release under Accident Conditions
9. Nuclear Instrumentation, Control, and Safety Systems
10. Electrical Power Systems
11. Containment of Nuclear Facilities
12. Plant Safety Features - Reactor
13. Plant Safety Features - Nonreactor
14. Radionuclide Release, Disposal, Treatment, and Management  
(inactive September 1973)
15. Environmental Surveys, Monitoring, and Radiation Dose Measurements  
(inactive September 1973)
16. Meteorological Considerations

17. Operational Safety and Experience
18. Design, Construction and Licensing
19. Internal Exposure Effects on Humans Due to Radioactivity  
in the Environment (inactive September 1973)
20. Effects of Thermal Modifications on Ecological Systems  
(inactive September 1973)
21. Radiation Effects on Ecological Systems (inactive September 1973)
22. Safeguards of Nuclear Materials

Computer programs have been developed that enable NSIC to (1) operate a program of selective dissemination of information (SDI) to individuals according to their particular profile of interest, (2) make retrospective searches of the stored references, and (3) produce topical indexed bibliographies. In addition, the Center Staff is available for consultation, and the document literature at NSIC offices is available for examination. NSIC reports (i.e., those with the ORNL/NSIC and ORNL/NUREG/NSIC numbers) may be purchased from the National Technical Information Service (see inside front cover). All of the above services are free to NRC and DOE personnel as well as their direct contractors. They are available to all others at a nominal cost as determined by the DOE Cost Recovery Policy. Persons interested in any of the services offered by NSIC should address inquiries to:

J. R. Buchanan, Assistant Director  
Nuclear Safety Information Center  
P.O. Box Y  
Oak Ridge National Laboratory  
Oak Ridge, Tennessee 37830

Telephone 615-574-0391  
FTS number is 624-0391

## ABSTRACT

This index to *Nuclear Safety* covers articles published in *Nuclear Safety*, Vol. 11, No. 1 (January-February 1970), through Vol. 20, No. 6 (November-December 1979). It is divided into three sections: a chronological list of articles (including abstracts) followed by a permuted-title (KWIC) index and an author index. *Nuclear Safety*, a bimonthly technical progress review prepared by the Nuclear Safety Information Center (NSIC), covers all safety aspects of nuclear power reactors and associated facilities. Over 600 technical articles published in *Nuclear Safety* in the last ten years are listed in this index.



## INTRODUCTION

*Nuclear Safety*, a bimonthly technical progress review, is prepared by the Oak Ridge National Laboratory and is jointly sponsored by the Nuclear Regulatory Commission and the Department of Energy. The technical articles (i.e., excluding special reviews and features) are refereed and cover all topics relevant to the safe design, construction, and operation of nuclear facilities. In addition to that primary emphasis on power reactors, safety considerations in reactor fuel fabrication, spent-fuel processing, nuclear waste disposal, handling of radioactive materials, and the environmental effects of these operations are also treated.

Cumulative indexes of *Nuclear Safety* have been prepared annually since 1967. However, starting in 1974, the issues covered extended back only through Volume 11. This issue of the *Index to Nuclear Safety* covers articles included in *Nuclear Safety*, Vol. 11, No. 1, through Vol. 20, No. 6. Persons interested in an index to earlier *Nuclear Safety* volumes should purchase ORNL/NSIC-107 (see inside front cover).

This index is presented in three sections as follows:

- Section 1 (orange) - Chronological List of Articles by Volume
- Section 2 (white) - Permuted-Title (KWIC) Index
- Section 3 (green) - Author Index

A KWIC (KeyWord in Context) index is one in which article titles are permuted around the various significant words contained therein. For example, the title, "Design Basis for Nuclear Power Plant Protection Systems," is indexed under the words Design, Nuclear, Power, Plant, and Protection. As may be seen by reference to Section 2 (white) of this report, the index words are arranged alphabetically in a column in the center of the page, with the titles permuted around them. In some cases, additional significant words in parentheses have been added to the title by the editors to allow more precise indexing. The location of the indexed articles in *Nuclear Safety* is indicated by the seven-digit numbers in the column to the right of the page, as described below. The KWIC code was developed by IBM and has proved to be a useful tool for the preparation of indexes for many different purposes.

Early issues of the index were used primarily for the benefit of the *Nuclear Safety* editors. However, it has been so helpful that it is now prepared and distributed as an NSIC report. The index is published annually following the close of each *Nuclear Safety* volume year.

The seven-digit index number given in all three sections is divided into four parts (00-0-0-000) which stand, respectively, for volume-number-section-page. It provides ready entry from the permuted-title (KWIC) index (white) and author index (green) to the main index (orange), which gives title, author, and abstract when available. Corporate affiliation is given in the orange section for all authors. Abstracts are also included for those articles that contained one. Volume 11 corresponds to 1970; Volume 12, 1971; Volume 13, 1972; Volume 14, 1973; Volume 15, 1974; Volume 16, 1975; Volume 17, 1976; Volume 18, 1977; Volume 19, 1978; and Volume 20, 1979.

Wm. B. Cottrell, Editor  
W. H. Jordan, Advisory Editor  
A. L. Ragan, Editorial Reviewer  
Section Editors.

1. General Safety Considerations  
J. R. Buchanan
2. Accident Analysis  
P. M. Haas
3. Control and Instrumentation  
E. W. Hagen
4. Plant Safety Features  
H. W. Godbee and E. L. Compere
5. Environmental Effects  
R. O. Chester and C. T. Garten
6. Operating Experiences  
W. R. Casto
7. Current Events  
Wm. B. Cottrell

## Section 1

## CHRONOLOGICAL MAIN INDEX

*Nuclear Safety* articles are indexed in this section by volume in the chronological order of their appearance in the Journal. Titles (white section) and authors (green section) are keyed to this main index by means of a seven-digit number in the left-hand column; the number is divided into four parts (00-0-0-000), which stand for volume-number-section-page, respectively. Following the index number are the appropriate article title and author. For example, Vol. 11, No. 1, Sect. 3, p. 20 (11-1-3-020) contained the article, "The Design Basis for Nuclear Power Plant Protection Systems," by R. S. Stone (see index). The dates pertinent to each volume are listed in the Introduction. Abstracts are included in this section for all articles that had one.

## BIBLIOGRAPHY

- 11-1-1-001 THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM  
BAKER, L., JR. + HODE, D. + MILLER, C. E., JR.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS  
THE GENERAL AIM OF THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM IS THE IMPROVEMENT OF THE TECHNOLOGICAL BASE NEEDED TO UNDERSTAND ACCIDENT SITUATIONS, TO DEVELOP SAFETY SYSTEMS, AND TO DEVELOP STANDARDS AND CODES FOR SAFE DESIGN, SITING, CONSTRUCTION, AND OPERATION OF AEC TEST FACILITIES AND COMMERCIAL LIQUID METAL FAST BREEDERS. IN ITS SCOPE THE PROGRAM INCLUDES STUDIES OF THE PHENOMENA ASSOCIATED WITH ABNORMAL OPERATION, POTENTIAL ACCIDENTS, AND SAFETY SYSTEMS DESIGNED TO PREVENT ACCIDENTS OR TO LIMIT THEIR CONSEQUENCES. EMPHASIS IS PLACED ON PREVENTION, EARLY DETECTION, AND CONTROL OF POTENTIAL ACCIDENTS.
- 11-1-2-012 ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEATING  
UCHIDA, H. + YAMURA, T.  
UNIVERSITY OF TOKYO, TOKYO, JAPAN  
A BASIC INVESTIGATION WAS MADE OF THE POWERFUL PULSELIKE PRESSURE INCREASES THAT OCCUR IN A NARROW WATER CHANNEL WHEN THE WATER IS BEING HEATED RAPIDLY. IN THE EXPERIMENTS A VERTICAL WATER COLUMN WAS HEATED AT THE BOTTOM, AND THE TOP OF THE WATER WAS A FREE SURFACE. TEMPERATURE CHANGE RATES ON THE HEATED SURFACE WERE VARIED FROM 1000 TO 25,000C/SEC. THE INVESTIGATION INDICATED THAT THE PRESSURE CHANGES IN A CHANNEL UNDERGOING RAPID HEATING EXHIBIT TWO KINDS OF PATTERNS, NAMELY, AN INITIAL INCREASE TO A PEAK PRESSURE THAT IS INFLUENCED BY THE HEATING RATE AND THEN A SERIES OF PRESSURE PULSES THAT CAN BE EXPLAINED ANALYTICALLY AS A DYNAMICS PROBLEM SIMILAR TO THAT ASSOCIATED WITH A WATER HAMMER. IN THIS SECOND STAGE THE MAXIMUM PRESSURE IS GREATER THAN THE PEAK PRESSURE IN THE FIRST STAGE. THESE PRESSURE CHANGES ARE SIMILAR TO PRESSURE CHANGES OBSERVED IN BOBAY AND SPEER EXPERIMENTS.
- 11-1-3-020 THE DESIGN BASIS FOR NUCLEAR POWER PLANT PROTECTION SYSTEMS  
STONE, R. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE DESIGN BASIS FOR A NUCLEAR PLANT PROTECTION SYSTEM GIVES FUNCTIONAL REQUIREMENTS AND ESTABLISHES THE CIRCUMSTANCES UNDER WHICH THE SYSTEM MUST BE CAPABLE OF OPERATING. IT TAKES INTO ACCOUNT BOTH THE SYSTEM'S CHARACTERISTICS AND THOSE OF THE ENTIRE COMPLEX OF PROTECTIVE FEATURES. THESE LATTER CHARACTERISTICS CONSIST IN THOSE ASPECTS OF PLANT DESIGN THAT FORESTALL, AVOID, OR MITIGATE HAZARDOUS OCCURRENCES IN THE POWER-GENERATING CHAIN. THE BASIC REQUIREMENTS ARE TO ENSURE PUBLIC SAFETY AND, IF POSSIBLE, TO PREVENT DAMAGE TO THE PLANT. A PROPER DESIGN BASIS TIES TOGETHER ALL THE INFORMATION NECESSARY FOR THE DEVELOPMENT OF A COMPETENT PLANT PROTECTION SYSTEM. WITHOUT SUCH A DESIGN BASIS, THE SYSTEM WILL BE HAZARDOUS AND INCOMPLETE.
- 11-1-4-025 A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS  
TAN, C. P.  
FRANKLIN INSTITUTE RESEARCH LABORATORIES, PHILADELPHIA, PENNSYLVANIA  
PRESTRESSED CONCRETE REACTOR VESSELS (PCRVS) ARE ADAPTABLE TO LARGE NUCLEAR CORES AND THE HIGH PRESSURES NEEDED FOR THE SAFE AND ECONOMICAL PRODUCTION OF NUCLEAR POWER WITH GAS-COOLED REACTORS. THERE ARE AT PRESENT 18 PCRVS, MOST OF WHICH ARE IN GREAT BRITAIN AND FRANCE. IN THE UNITED STATES A PCRV FOR THE FORT ST. VRAIN HIGH TEMPERATURE GAS-COOLED REACTOR IS UNDER CONSTRUCTION. THE BASIC PROBLEMS FACING THE DESIGNER AND CONSTRUCTOR OF PCRVS WERE (1) LACK OF APPLICABLE CODES, (2) LITTLE KNOWLEDGE OF LONG TERM BEHAVIOR OF CONCRETE UNDER MULTIAXIAL STRESSES AT HIGH TEMPERATURE, (3) LITTLE INFORMATION ON STRESS CONCENTRATIONS IN CONCRETE DUE TO PENETRATIONS OF VARIOUS SIZES AND TO THE ANCHORAGES, (4) POROSITY OF CONCRETE, AND (5) LIMITED CAPACITY OF COMMERCIALLY AVAILABLE PRESTRESSING SYSTEMS. MOST OF THESE PROBLEMS HAVE BEEN RESOLVED THROUGH ENGINEERING INGENUITY COMPLEMENTED WITH EXTENSIVE RESEARCH AND DEVELOPMENT. SATISFACTORY DESIGNS OF PCRVS HAVE BEEN ACCOMPLISHED BY DEVELOPING SOPHISTICATED ANALYTICAL METHODS AND TESTING STRUCTURAL MODELS. PCRVS APPEAR TO BE FAVORED FOR ADVANCED REACTORS BECAUSE OF ADAPTABILITY WITH RESPECT TO SIZE AND PRESSURE.
- 11-1-5-014 VARIABILITY OF WIND DIRECTION WITHIN THE UNITED STATES  
SINGER, I. A. + NAGLE, C. E.  
BROOKHAVEN NATIONAL LABORATORY, UPTON, L. I., NEW YORK  
INCREASED INTEREST IN ATMOSPHERIC DIFFUSION, AS WELL AS (PARTICULARLY, FOR NUCLEAR SAFETY REASONS) ATTACHED TO THE SITING OF NUCLEAR POWER REACTORS HAS COMPELLED THE NEED FOR A QUANTITATIVE MEASURE OF THE VARIABILITY OF WIND DIRECTION WITH TIME. IT HAS BEEN PROPOSED THAT THE CONSISTENCY OF THE WIND, DEFINED AS THE MEAN VECTOR AND DIRECTION OF THE MEAN SCALAR WIND ( $V/V$ ), BE USED FOR SIMPLY CLASSIFICATION PURPOSES. A TRIGONOMETRIC TRANSFORMATION IS USED TO LINEARIZE THE VARIATION OF CONSISTENCY WITH THE MEAN ANGULAR RANGE OF

DIRECTION. THIS FUNCTION, CALLED THE STEADINESS,  $S$ , IS THEN CORRELATED FOR VARIOUS TIME PERIODS, AND BY USE OF EXTREME-VALUE THEORY THE RECURRENCE INTERVALS OF VARIOUS MEAN WIND DIRECTION RANGES CAN BE PREDICTED. THIS HAS BEEN DONE FOR 34 STATIONS IN THE UNITED STATES. RECURRENCE INTERVAL MAPS OF THE STEADINESS OF WIND DIRECTION WITHIN THE UNITED STATES FOR VARIOUS TIME PERIODS ARE PRESENTED THAT SHOW THE INTERRELATION OF GEOGRAPHICAL LOCATION AND SYNOPTIC METEOROLOGY WITH WIND DIRECTION PERSISTENCE. THE MOST PERSISTENT WIND DIRECTIONS APPEAR AT COASTAL STATIONS, AND THE LEAST PERSISTENT OCCUR IN MOUNTAINOUS REGIONS.

- 11-1-5-039 U. S. A. STANDARD N13.2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION MONITORING ( A GUIDE FOR MANAGEMENT )  
HART, J. C. + NOELLEF, D. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE - HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASSACHUSETTS  
RADIATION PROTECTION IN ANY NUCLEAR-BASED OPERATION IS A RESPONSIBILITY OF MANAGEMENT. THE USA STANDARD N13.2 IS DESIGNED TO PROVIDE A GENERAL REVIEW OF THE TYPE AND EXTENT OF MONITORING NEEDED FOR THE SAFE USE AND APPLICATION OF RADIATION SOURCES. THIS STANDARD MAY BE USED DURING THE PLANNING STAGES OF AN OPERATION AS A GUIDE TO AN EFFECTIVE MONITORING PROGRAM.
- 11-1-5-043 TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN FOOD CHAINS  
BEICHLER, D. E. + DUNAWAY, R. L. + NELSON, D. J.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
PROLIFERATION OF NUCLEAR TECHNOLOGY AND CONCERN FOR RADIOACTIVITY IN THE BIOSPHERE DEMAND MORE SOPHISTICATED EVALUATIONS OF FUTURE NUCLEAR INSTALLATIONS AND PROCEDURES. ADEQUATE ANALYSES OF RADIONUCLIDE DISPERSION IN THE ENVIRONMENT WILL REQUIRE MORE SUBSTANTIAL BIOENVIRONMENTAL INFORMATION THAN IS PRESENTLY AVAILABLE. FREQUENTLY INFORMATION KNOWN FOR ONE ECOLOGICAL SYSTEM (E.G., ARCTIC TUNDRA) WILL NOT BE APPLICABLE TO OTHER ECOSYSTEMS (E.G., TEMPERATE OR TROPICAL FORESTS). ONLY WITH SUFFICIENT ECOLOGICAL DATA CAN PREDICTIVE MODELS BE DEVELOPED THAT WILL ENABLE ASSESSMENT OF THE ENVIRONMENTAL CONSEQUENCES OF RADIOACTIVE CONTAMINATION. A SIMPLE SOURCE PATHWAY RECEPTOR MODEL, ANALOGOUS TO THE ECOLOGICAL FOOD CHAIN, REQUIRES PATHWAY IDENTIFICATION, DATA ON ASSIMILATION BY EACH LINK (ORGANISM) IN THE PATHWAY, AND DETERMINATION OF THE BIOLOGICAL TURNOVER OF EACH RADIONUCLIDE. FOR ACUTE RELEASES OF RADIOACTIVITY TO THE ENVIRONMENT, EVALUATION OF THESE VARIABLES IS NEEDED TO PREDICT TIME DEPENDENT CONCENTRATIONS OF RADIOACTIVITY IN ORGANISMS. FOR CHRONIC RELEASES, CONCENTRATION FACTORS ALONE WILL OFTEN SUFFICE. THE BIOLOGICAL CONCENTRATION AND TURNOVER OF RADIONUCLIDES BY ANIMALS ARE SUMMARIZED IN THIS PAPER. DATA ARE PRESENTED FOR USE IN ENVIRONMENTAL MODELS AND CORRELATION WITH SPECIES CHARACTERISTICS (E.G., BODY SIZE) THAT ALLOW ESTIMATION OF ABSOLUTE VALUES FOR MANY DIFFERENT ANIMAL GROUPS BASED ON EXISTING EXPERIMENTAL DATA.
- 11-2-1-107 INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS  
TURNER, S. E. + MCCULLOUGH, C. R. + LYERLY, R. L.  
SOUTHERN NUCLEAR ENGINEERING, INC., DUNEDIN, FLORIDA  
THE CONSEQUENCES OF INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS HAVE BEEN STUDIED FROM THE STANDPOINT OF THE POTENTIAL HAZARD TO THE HEALTH AND SAFETY OF THE PUBLIC. THIS EVALUATION OF THE POTENTIAL THREAT OF SABOTAGE CONSIDERED (1) HISTORICAL PRECEDENTS, (2) THE OPINIONS OF EXPERIENCED AND KNOWLEDGEABLE INDIVIDUALS, (3) MOTIVATION AND LIKELY EXTENT OF KNOWLEDGE OF VARIOUS TYPES OF SABOTEURS, AND (4) AN ASSESSMENT OF THE PROBABILITY AND POSSIBLE CONSEQUENCES OF A NUMBER OF POSTULATED SABOTAGE ACTS, AS WELL AS THE LEVEL OF DAMAGE NECESSARY TO CREATE A PUBLIC HAZARD. ON THE BASIS OF THE STUDY, IT IS CONCLUDED THAT, ALTHOUGH SABOTAGE WITH SERIOUS CONSEQUENCES TO THE PUBLIC IS POSSIBLE IN THEORY, THE PROBABILITY IS SUFFICIENTLY LOW THAT NO GRAVE RISK TO THE HEALTH AND SAFETY OF THE PUBLIC EXISTS.
- 11-2-3-115 AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS AT ORNL  
OAKES, L. C.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
REACTOR SAFETY FUNCTIONS REQUIRING FAST RESPONSE ARE AUTOMATED, BUT OBJECTIONS ARISE WHEN SOME TRADITIONALLY MANUAL OPERATIONS ARE PROPOSED FOR AUTOMATION. IN A REACTOR CONTROL SYSTEM, PERHAPS MORE THAN IN ANY OTHER, THE OPERATOR IS DEPENDENT ON SENSORY INSTRUMENTATION FOR DETERMINING THE OPERATING STATE. COMPARISONS OF RELIABILITY, OPERABILITY, ECONOMICS, AND SAFETY FOR AUTOMATIC VS. MANUAL CONTROL ARE ABOUT THE SAME IF SIMILAR PERFORMANCE IS EXPECTED. THESE ARE EXEMPLIFIED BY DISCUSSIONS OF AUTOMATIC STARTUPS AND SHUTTING. OPERATOR JUSTIFICATION IS EVEN NOW SOMEWHAT PHILOSOPHICAL, AND RESULTS OF CURRENT RESEARCH AND DEVELOPMENT IN COMPUTER CONTROL AND DIAGNOSTIC TECHNIQUES WILL FURTHER TEND TO REDUCE HIS ROLE. A GREATER AMOUNT OF AUTOMATION THAN NOW USED WOULD LEAD TO IMPROVED SAFETY AND OPERABILITY.

- 11-2-4-119 CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL  
 REEDY, S. F. + SIMS, J. E.  
 CHICAGO BRIDGE AND IRON COMPANY, OAK BROOK, ILLINOIS - CHICAGO  
 BRIDGE AND IRON COMPANY, MEMPHIS, TENNESSEE  
 THE MONTICELLO NUCLEAR GENERATING PLANT IN MINNESOTA, OWNED BY  
 NORTHERN STATES POWER COMPANY, IS UNIQUE IN THAT IT WAS THE  
 FIRST FIELD FABRICATED NUCLEAR REACTOR PRESSURE VESSEL BUILT IN  
 THE UNITED STATES. THE MATERIALS FOR THIS VESSEL WERE  
 FABRICATED IN THE NORMAL MANNER AND SHIPPED TO THE SITE FOR  
 FINAL ASSEMBLY INTO A COMPLETED VESSEL. SPECIAL TRAINING FOR  
 FIELD MACHINING, WELDING, AND QUALITY CONTROL WAS REQUIRED. THE  
 COMPLETION OF THE PRESSURE VESSEL AHEAD OF SCHEDULE SHOWED THAT  
 THE FIELD FABRICATION OF NUCLEAR PRESSURE VESSELS IS BOTH  
 FEASIBLE AND ECONOMICAL.
- 11-2-5-130 STATUS OF INVESTIGATIONS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES  
 MCCLAIN, W. C. + BHADSHAW, R. L.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
 A COMMITTEE OF THE NATIONAL ACADEMY OF SCIENCES FIRST SUGGESTED  
 THE USE OF SALT FORMATIONS FOR THE DISPOSAL OF RADIOACTIVE  
 WASTES IN 1955. AND FEASIBILITY STUDIES BEGAN AT OAK RIDGE  
 NATIONAL LABORATORY AND ELSEWHERE AS EARLY AS 1957. BY THE  
 EARLY 1960'S, EMPHASIS HAD SHIFTED FROM DIRECT DISPOSAL OF  
 LIQUID WASTES TO SOLIDIFICATION AND DISPOSAL OF THE RESULTING  
 SOLIDS. A CONCEPT FOR DISPOSAL OF SUCH SOLIDS IN A SALT MINE  
 WAS DEVELOPED, AND PREPARATIONS FOR A DEMONSTRATION EXPERIMENT  
 BEGAN IN 1963. THE RADIOACTIVE PHASE OF THIS DEMONSTRATION  
 BEGAN IN NOVEMBER 1965 AND SUCCESSFULLY DEMONSTRATED THE  
 FEASIBILITY AND SAFETY OF HANDLING HIGHLY RADIOACTIVE  
 MATERIALS IN AN UNDERGROUND ENVIRONMENT. THIS EXPERIMENT ALSO  
 DEMONSTRATED THE STABILITY OF SALT UNDER THE EFFECTS OF HEAT  
 AND RADIATION. DATA OBTAINED ON THE CREEP AND PLASTIC FLOW  
 CHARACTERISTICS OF SALT HAVE MADE IT POSSIBLE TO ARRIVE AT A  
 SUITABLE MINE DESIGN FOR A DISPOSAL FACILITY. A STUDY OF THE  
 ECONOMICS OF DISPOSAL IN SALT MINES INDICATES THAT THIS METHOD  
 WILL BE COMPATIBLE WITH COMPETITIVE NUCLEAR POWER. AN ANALYSIS  
 OF THE PROJECTED POWER REACTOR WASTES AND THE SAFETY  
 CONSIDERATIONS INVOLVED POINTS TO THE NEED FOR A GOVERNMENT  
 OWNED WASTE REPOSITORY TO BE IN OPERATION BEFORE 1980.
- 11-2-6-142 SAN ONOFRE EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALIES  
 ORTEGA, O. J. + JOHNSON, C. G. + BASKIN, K. P.  
 SOUTHERN CALIFORNIA EDISON COMPANY, LOS ANGELES, CALIFORNIA  
 IN JANUARY 1968 THE UPPER LIMIT FOR OPERATION AT THE SAN  
 ONOFRE NUCLEAR GENERATING STATION WAS SET AT 90 PERCENT POWER,  
 405 MW(E), BECAUSE DISCREPANCIES HAD BEEN NOTED IN REACTOR  
 THERMAL POWER AS RECKONED BY DIFFERENT METHODS. CALCULATIONS  
 BASED ON THE TEMPERATURE DIFFERENTIALS ACROSS THE STEAM  
 GENERATOR IN THE PRIMARY LOOPS GAVE ONE VALUE, AND  
 CALORIMETRICS IN THE SECONDARY SYSTEM GAVE ANOTHER. IT APPEARED  
 THAT COOLANT FLOW WAS LESS THAN THE DESIGN VALUE. EXTENSIVE  
 TESTING DURING MARCH, SEPTEMBER, AND OCTOBER 1968 REVEALED THAT  
 TEMPERATURE SENSORS GAVE MISLEADING INDICATIONS BECAUSE OF  
 THEIR LOCATIONS. ACCORDINGLY, ADDITIONAL DIRECT IMMERSION  
 RESISTANCE TEMPERATURE DETECTORS (RTD'S) WERE INSTALLED  
 DOWNSTREAM OF EACH COOLANT PUMP TO GIVE ACCURATE COLD-LEG  
 MIXED-MEAN TEMPERATURES. ACCURATE CORE OUTLET TEMPERATURES WERE  
 AT LAST BEING PROVIDED BY CORE THERMOCOUPLES. THE DATA FROM THE  
 NEW RTD'S PROVED THAT COOLANT FLOW ACTUALLY WAS EQUAL TO OR  
 GREATER THAN DESIGN FLOW. ON THE STRENGTH OF THIS KNOWLEDGE,  
 OPERATION AT 100 PERCENT POWER RATING, 450 MW(E), WAS BEGUN IN  
 DECEMBER 1968 AFTER AN 18-MONTH INVESTIGATION OF THE ANOMALY.  
 THE PROBLEM DEMONSTRATED THE GREAT NEED FOR INSTRUMENTATION TO  
 ACCURATELY READ TWO PERFORMANCE PARAMETERS IN LARGE PWR'S (1)  
 MIXED-MEAN HOT- AND COLD-LEG TEMPERATURES AND (2) FLOW OF  
 PRIMARY COOLANT.
- 11-3-1-185 THE UTILITY'S ROLE IN NUCLEAR SAFETY RESEARCH AND DEVELOPMENT  
 MOORE, J. B.  
 SOUTHERN CALIFORNIA EDISON COMPANY, LOS ANGELES, CALIFORNIA  
 PLANNING FOR NEW ELECTRICITY GENERATING UNITS IN LARGE  
 UTILITIES IS CHARACTERIZED BY CONTRACTING FOR A SERIES OF  
 SIMILAR UNITS TO BE OPERATIONAL OVER A SPAN OF YEARS BEFORE  
 CHANGING TO A DIFFERENT DESIGN. DELAY, CAUSED BY DESIGN  
 CHANGES MADE NECESSARY BECAUSE OF EQUIPMENT PROBLEMS AND BY  
 CHANGING REQUIREMENTS IN REACTOR LICENSING, UPSET THIS ORDERLY  
 GROWTH AND HAVE A CASCADING EFFECT SO THAT A SERIOUS RISK OF  
 ELECTRICAL BLACKOUTS ENSUES DURING THE TRANSITION FROM FOSSIL  
 FUELED TO NUCLEAR FUELED ELECTRICITY GENERATION. THE UTILITY'S  
 ROLE IS TO ASSURE FEEDBACK OF OPERATING EXPERIENCE AND PROPER  
 EVALUATION OF THE FEED-FORWARD TO STANDARDS AND CRITERIA THAT  
 OCCURS PRIOR TO ACTUAL OPERATING EXPERIENCE.
- 11-3-2-195 STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS  
 DICKERMAN, C. E.  
 ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS  
 STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS  
 ARE INCLUDED IN THE COMPREHENSIVE USAEC SAFETY PROGRAM.  
 INFORMATION IS NOW BECOMING AVAILABLE ON VAPORIZATION, PRESSURE  
 GENERATION, AND VOIDING OF SODIUM COOLANT UNDER TRANSIENT  
 HEATING. SEMIEMPIRICAL MODELS OF OXIDE FUEL FAILURE ARE BEING  
 DEVELOPED FROM TRANSIENT EXPERIMENT DATA. THE COMPLEX RELATIONS

BETWEEN FUEL FAILURE, MELTDOWN, AND SECONDARY MOVEMENTS OF FUEL AND COOLANT ARE BEING STUDIED IN SODIUM FILLED CAPSULES, AUTOCLAVES, AND LOOPS. DATA NOW AVAILABLE INDICATE THAT, IN SOME CASES AT LEAST, THE REAL BEHAVIOR MAY BE SIGNIFICANTLY LESS HAZARDOUS THAN PREDICTIONS BASED ON LIMITING CASE MODELS REQUIRED IN THE ABSENCE OF ACTUAL DATA.

- 11-3-3-206 PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED POWER REACTOR PLANTS  
OBPIFN, H. G. + WALKER, C. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
CURRENT PRACTICES IN PROTECTION SYSTEM DESIGNS VARY WIDELY, INDICATING DIFFERENCES IN DESIGN CRITERIA, AS WELL AS THE LACK OF COMMONLY RECOGNIZED 'BEST WAYS' IN DESIGN APPROACHES FOR CARRYING OUT SIMILAR FUNCTIONS. THE DESIGN OF THE INSTRUMENTATION SYSTEMS FOR THE ENGINEERED SAFETY FEATURES PRESENTS A CONSIDERABLY MORE COMPLEX PROBLEM THAN THE DESIGN OF THE REACTOR SHUTDOWN SYSTEM. EXAMINATIONS OF THE DESIGNS OF FOUR TYPICAL PROTECTION INSTRUMENTATION SYSTEMS FOR BOILING AND PRESSURIZED WATER POWER REACTORS INDICATED THAT (1) DESIGNS SHOULD BE EFFECTIVELY DOCUMENTED, (2) LOGICAL AND APPROPRIATE REQUIREMENTS FOR PERFORMANCE AND RELIABILITY SHOULD BE ESTABLISHED, AND (3) DETAILED CRITERIA ARE NEEDED FOR INSTRUMENTATION SYSTEM DESIGN.
- 11-3-4-215 THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM  
WEEMS, S. J. + LYMAN, W. G. + HAGA, P. B.  
NPR ASSOCIATES, INC., WASHINGTON, D.C. - WESTINGHOUSE PWR SYSTEMS DIVISION, PITTSBURGH, PENNSYLVANIA  
THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM, WHICH WAS DESIGNED AND DEVELOPED AT WESTINGHOUSE ELECTRIC CORPORATION, EMPLOYS ROTATED ICE AS A STATIC HEAT SINK FOR RAPID ABSORPTION OF ENERGY THAT MIGHT BE RELEASED THROUGH RUPTURE OF REACTOR COOLANT PIPING. THE CONCEPT IS ADAPTABLE TO ALL CURRENT TYPES OF COMMERCIAL NUCLEAR POWER PLANTS. THE BASIC DESIGN PHILOSOPHY, SYSTEM PARAMETERS, AND FULL SCALE SECTION PROTOTYPING CONDUCTED TO ESTABLISH THE SOUNDNESS AND PRACTICALITY OF THE CONCEPT ARE DESCRIBED, AS WELL AS THE FIRST PLANT APPLICATIONS - THE DONALD C. COOK NUCLEAR PLANT FOR THE AMERICAN ELECTRIC POWER SYSTEM AND THE SQUOYAH NUCLEAR PLANT FOR THE TENNESSEE VALLEY AUTHORITY.
- 11-3-4-223 RESEARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTORS  
ROW, T. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
MANY OF THE PRESSURIZED WATER REACTORS OPERATING OR UNDER CONSTRUCTION INCLUDE CONTAINMENT BUILDING PRESSURE REDUCTION SPRAY SYSTEMS DESIGNED TO INCORPORATE A FISSION PRODUCT SEQUESTERING ADDITIVE. A PROGRAM TO EVALUATE ALL ASPECTS OF THE USE OF A SPRAY SYSTEM AS AN ENGINEERED SAFETY FEATURE HAS BEEN COORDINATED BY OAK RIDGE NATIONAL LABORATORY FOR THE AEC SINCE MARCH 1967. THE MAJOR RESEARCH EFFORT HAS BEEN CENTERED AT OAK RIDGE NATIONAL LABORATORY, WITH ADDITIONAL WORK BEING DONE AT BATTELLE-NORTHWEST AND THROUGH PRIVATELY SPONSORED RESEARCH BY THE NUCLEAR INDUSTRY. CURRENT EVALUATIONS INDICATE THAT SPRAY SYSTEMS WILL RAPIDLY REMOVE MOLECULAR IODINE AND THAT METHYL IODIDE AND PARTICULATE REMOVAL ARE SIGNIFICANTLY SLOWER PROCESSES. RADIOLYTIC HYDROGEN GENERATION BY POSTACCIDENT COOLING OF THE REACTOR CORE INTRODUCES A SIGNIFICANT DESIGN CONSIDERATION.
- 11-3-6-235 RADON CONCENTRATION IN REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IODINE-131 RELEASE  
CLACK, E. W. + ECKHOFF, W. D.  
KANSAS STATE UNIVERSITY, MANHATTAN, KANSAS  
THE CONTAINMENT BUILDING AIR AT THE KANSAS STATE UNIVERSITY TRIGA MARK II REACTOR BECAME CONTAMINATED WITH RADON, WHICH PRESUMABLY CAME FROM THE THAWING GROUND JUST OUTSIDE THE VENTILATION INTAKE. GAMMA-RAY SPECTROM ANALYSIS IDENTIFIED THE CONTAMINATION AS RADON AND ITS PROGENY INSTEAD OF IODINE-131, WITH WHICH IT CAN BE CONFUSED. A SIMILAR INCIDENT OCCURRED IN 1962 AT THE UNION CARBIDE REACTOR IN STERLING FOREST, NEW YORK.
- 11-3-6-237 A COMPARISON OF TWO NITROGEN-16 RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH REACTOR FUEL  
CASHWELL, E. J.  
UNIVERSITY OF WISCONSIN, MADISON, WISCONSIN  
PERSONNEL AT THE UNIVERSITY OF WISCONSIN NUCLEAR REACTOR HAVE MADE DETAILED RADIATION MEASUREMENTS FOR COMPARING THE EFFICIENCY OF A PLEXIGLAS PLATE TYPE NITROGEN-16 DIFFUSER WITH AN 80 GAL/MIN JET-TYPE DIFFUSER. ALTHOUGH MUCH LESS EFFECTIVE THAN THE JET-TYPE DIFFUSER, THE PLATE TYPE DIFFUSER OFFERS GREATER SIMPLICITY AND RELIABILITY AND WITH NO REACTIVITY DISTURBANCES.
- 11-4-1-283 SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE UNITED KINGDOM  
FARMER, P. R.  
OXFORD HEALTH AND SAFETY BRANCH, RISLEY, WARRINGTON, ENGLAND  
THE BUILDING OF ANY REACTOR INTRODUCES SOME RISK TO THE PUBLIC, BUT IT APPEARS THAT THE FAST REACTOR MAY PRESENT LESS RISK THAN CURRENT REACTORS BECAUSE IT CAN BE DESIGNED SO AS NOT TO REQUIRE A POWER SOURCE WHEN SHUT DOWN. SINCE IT IS UNLIKELY THAT IT CAN EVER BE POSITIVELY ESTABLISHED THAT EVERY ENERGY RELEASE CAN ALWAYS BE CONTAINED, RELIANCE MUST BE PLACED IN THE

GREATER LIKELIHOOD OF IDENTIFYING THE FAULT AND SHUTTING DOWN THE REACTOR. THE OBJECTIVE OF CURRENT SAFETY RESEARCH IS TO PROVIDE TWO INDEPENDENT MECHANICAL SHUTDOWN SYSTEMS ACTIVATED BY INDEPENDENT SIGNALS. MEANS ARE BEING DEVELOPED FOR DETECTION OF FUEL SUBASSEMBLY FAILURES THROUGH DELAYED NEUTRONS, FISSION PRODUCTS, ACOUSTICS, AND POSSIBLY THE SHOCK OF SUBASSEMBLY COLLAPSE.

- 11-4-2-249 RECENT DEVELOPMENTS IN FAST REACTOR KINETICS  
 BUTLER, D. K. + KENELPY, D. A.  
 ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS  
 ANALYSIS OF THE SAFETY OF A FAST BREEDER REACTOR REQUIRES CALCULATION OF THE TIME DEPENDENT NEUTRON FLUX AND FISSION POWER DENSITIES. METHODS FOR THESE CALCULATIONS WHICH ARE REVIEWED ARE THOSE BASED ON NEUTRON DIFFUSION THEORY - POINT KINETIC, ADIABATIC, QUASI-STATIC, AND EXACT SOLUTIONS. THE METHODS ARE USED IN DIGITAL COMPUTER PROGRAMS IN COMBINATION WITH THOSE CALCULATIONS OF MECHANICAL CHANGES, FLUID FLOW, AND HEAT TRANSFER WHICH ARE REQUIRED FOR THE ANALYSIS OF STABILITY AND ACCIDENTS. LIMITATIONS OF COMPUTER CAPABILITY REQUIRE THE USE OF APPROXIMATE METHODS WHERE APPLICABLE. COMPARISON OF RESULTS OBTAINED WITH EACH METHOD SHOWS THAT THE QUASI-STATIC OR EXACT SOLUTION IS REQUIRED TO OBTAIN ACCURATE VALUES FOR POWER GENERATION DURING SEVERE TRANSIENTS. INCORPORATING THESE MORE ACCURATE METHODS INTO COMPUTER PROGRAMS WHICH INCLUDE EQUALLY ACCURATE CALCULATIONS OF THE THERMAL AND MECHANICAL EFFECTS WILL BE IMPORTANT IN DEVELOPING COMPUTER CODES FOR ACCIDENT ANALYSIS.
- 11-4-2-246 TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT STRUCTURES  
 DOAN, P. L.  
 UNITED ENGINEERS AND CONSTRUCTORS, INC., PHILADELPHIA, PENNSYLVANIA  
 DESCRIPTIONS OF THE CHARACTERISTICS OF TORNADOS ARE PRESENTED THAT ARE BASED ON DOCUMENTED INFORMATION. THE NUCLEAR PLANT LIFETIME TORNADO RISK IS ASSESSED, AND MECHANISTIC CALCULATIONAL TECHNIQUES ARE PRESENTED TO DETERMINE THE EFFECTS ON PLANT STRUCTURES OF DYNAMIC WIND FORCES, STATIC PRESSURE DIFFERENTIALS, AND TORNADO GENERATED MISSILES. PARTICULAR ATTENTION IS GIVEN TO THE EFFECTS OF THE DESIGN TORNADO ON THE SPENT FUEL STORAGE POOL. POTENTIAL LOSS OF WATER BY ENTRAINMENT, SUCTION, EVAPORATION, AND RADIAL PRESSURE DIFFERENTIALS IS ASSESSED. ON THE BASIS OF HIGHLY CONSERVATIVE ASSUMPTIONS, IT IS SHOWN THAT THE SPENT FUEL STORAGE POOLS OF EXISTING LIGHT WATER REACTORS ARE QUITE ADEQUATELY DESIGNED TO ENSURE SAFE CONTAINMENT OF FISSION PRODUCTS IN THE EVENT THE DESIGN TORNADO OCCURS.
- 11-4-3-309 THE THIRD RELIABILITY MEETING AT RISO  
 LEONARDINI, L.  
 EUROPEAN NUCLEAR ENERGY AGENCY, PARIS, FRANCE  
 AN INTERNATIONAL MEETING ON RELIABILITY PROBLEMS RELATED TO THE SAFETY OF THE MECHANICAL COMPONENTS AND SYSTEMS IN NUCLEAR REACTORS WAS HELD IN DENMARK DURING SEPTEMBER 1969. TWENTY-EIGHT PAPERS WERE PRESENTED BY REPRESENTATIVES FROM NINE COUNTRIES. RELIABILITY ENGINEERING TECHNIQUES WERE DESCRIBED, AND THE NEED FOR FAILURE DATA COLLECTION SYSTEMS AND BANKS WAS DISCUSSED. MUCH REMAINS TO BE DONE WITH RESPECT TO APPLICATION OF THE DATA.
- 11-4-4-315 INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS  
 FOW, T. H. + DAVIS, B. J.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
 AN INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION PRODUCTS SPONSORED BY THE FRENCH SOCIETY FOR RADIOPROTECTION WAS HELD AT SACLAY, FRANCE, NOV. 4-6, 1969. THE MEETING WAS ATTENDED BY 218 DELEGATES REPRESENTING 16 COUNTRIES AND 3 INTERNATIONAL AGENCIES. PRESENTED WERE 30 PAPERS AND 4 SUMMARY REPORTS. THE SCOPE OF THE CONGRESS WAS SUFFICIENTLY BROAD THAT ESSENTIALLY ALL PHASES OF FISSION PRODUCT RELEASE AND TRANSPORT WERE INCLUDED. APPROXIMATELY TWO-THIRDS OF THE PAPERS PRESENTED AT THE CONGRESS WERE DEVOTED TO FISSION PRODUCT RELEASE BEHAVIOR AND REMOVAL UNDER WATER-COOLED AND GAS-COOLED REACTOR CONDITIONS. THE REMAINING PAPERS WERE ADDRESSED TO LMFBR (LIQUID METAL COOLED FAST BREEDER REACTOR) CONDITIONS.
- 11-4-6-323 THE ORR EMERGENCY COOLING FAILURE  
 FLEER, E. P.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
 THREE IDENTICAL UNITS THAT SUPPLY EMERGENCY POWER FOR AFTERHEAT PROTECTION OF THE OAK RIDGE RESEARCH REACTOR FAILED SIMULTANEOUSLY, AND THE REACTOR WAS OPERATED WITHOUT EMERGENCY POWER FOR THE AFTERHEAT REMOVAL SYSTEM FOR 5 HR BEFORE THE CONDITION WAS DISCOVERED. THE INCIDENT WAS CAUSED BY SEVEN COMMON MODE FAILURES OR ERRORS IN THREE IDENTICAL CHANNELS - A TOTAL OF 21 FAILURES. HAD ANY ONE OF THESE NOT HAPPENED, THE REACTOR WOULD NOT HAVE BEEN STARTED UP WITHOUT THE AVAILABILITY OF EMERGENCY COOLING FROM THE THREE INOPERATIVE UNITS. THE REACTOR WAS NOT ENDANGERED BECAUSE A DISSIMILAR UNIT OF LOW RELIABILITY WAS ACTIVATED. IT IS NOTWORTHY THAT THIS PROBLEM OCCURRED IN A PLANT WITH AN OUTSTANDING SAFETY AND AVAILABILITY RECORD.



11-5-1-365

APC GOES PUBLIC - A CASE HISTORY  
BROWN, H. C., JR.

U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
IN THE SPRING OF 1969, THE U. S. ATOMIC ENERGY COMMISSION DECIDED TO TAKE THE CASE FOR NUCLEAR POWER DIRECTLY TO THE PUBLIC BY WAY OF THE TOWN HALL AND THE VILLAGE SQUARE, THE UNIVERSITY SYMPOSIUM, AND THE SPEAKER CIRCUIT. A FACTUAL APPROACH HAS BEEN USEFUL IN COUNTERING MISINFORMATION AND IN ALLAYING UNFOUNDED FEARS, BUT THE INITIAL OUTINGS ALSO DEMONSTRATED THAT THE FACTS DO NOT ALWAYS SPEAK FOR THEMSELVES BECAUSE THEY ARE HIGHLY COMPLEX AND OCCASIONALLY CHALLENGED BY SMALL SEGMENTS OF THE SCIENTIFIC FRATERNITY. IT HAS BEEN NECESSARY TO TRANSLATE TECHNICAL JARGON INTO EVERYDAY LANGUAGE AND TO LEARN TO COMPETE WITH THE SHOWMANSHIP OF CRITICS. THE NEED FOR NUCLEAR ELECTRIC POWER IS INCREASINGLY RECOGNIZED, BUT NO SUBSTANTIAL ABATMENT IN PUBLIC CONCERN FOR THE ENVIRONMENT IS IN SIGHT. LARGER SEGMENTS OF THE PUBLIC RECOGNIZE THAT THE SOLUTION TO THE ENVIRONMENTAL PROBLEM IS NEITHER TO TURN THE CLOCK BACK NOR THE LIGHT SWITCH OFF, AND THEY ARE PREPARED TO PAY A LITTLE MORE FOR A CLEAN ENVIRONMENT.

11-5-1-369

THE WATER REACTOR SAFETY PROGRAM PLAN

BRADBURN, H. P. + COOPER, C. H. + GILMORE, C. E.  
IDAHO NUCLEAR CORPORATION, IDAHO FALLS, IDAHO

A USAEC REPORT DESIGNATED WASH-1146 HAS BEEN ISSUED TO SET FORTH A COMPREHENSIVE PLAN FOR USE BY THE DIVISION OF REACTOR DEVELOPMENT AND TECHNOLOGY IN ITS ADMINISTRATION OF WATER-REACTOR SAFETY PROGRAM AND FOR INFORMING THE NUCLEAR INDUSTRY CONCERNING THE SCOPE AND OBJECTIVES OF THE SPECIFIC PROJECTS THAT COMPRISE THE PROGRAM. THE REPORT COMPILES AND CORRELATES THE PROBLEMS AND INFORMATION NEEDS OF REACTOR SAFETY AND ASSIGNS PRIORITIES TO THE VARIOUS FACETS OF THE OVERALL PROBLEM. THE VIEWS EXPRESSED, ALTHOUGH NOT HELD UNIVERSALLY THROUGHOUT THE INDUSTRY, DO GENERALLY REPRESENT A CONSENSUS DETERMINED FROM COMMENTS SOLICITED FROM ALL MAJOR USERS OF SAFETY-RELATED INFORMATION, AND THE DOCUMENT THEREFORE FORMS AN AGREED-UPON BASIS UPON WHICH FUTURE CONSIDERATION AND DISCUSSION OF THE WATER-REACTOR SAFETY PROGRAM CAN BE FOUNDED. IT IS EXPECTED THAT THE PLAN WILL BE USED TO ASSURE THAT THE RESOURCES AVAILABLE TO THE SAFETY PROGRAM ARE APPLIED WHERE MOST NEEDED.

11-5-2-375

CRITERIA AND REQUIREMENTS FOR ROT PLANT PROTECTION SYSTEMS  
WALKER, C. S.

TENNESSEE VALLEY AUTHORITY, KNOXVILLE, TENNESSEE  
A SET OF GENERAL DESIGN CRITERIA AND REQUIREMENTS FOR REACTOR PROTECTION SYSTEMS HAS BEEN ISSUED AS A TENTATIVE STANDARD FOR APPLICATION TO REACTORS AND CRITICAL ASSEMBLIES UNDER THE JURISDICTION OF THE USAEC DIVISION OF REACTOR DEVELOPMENT AND TECHNOLOGY. THIS STANDARD, C 16-1T, INCLUDES WITHIN ITS SCOPE ALL THE ACTIVE DEVICES, SUCH AS INSTRUMENTS, ACTUATORS, AND ELECTRIC POWER SUPPLIES, NECESSARY TO PREVENT UNACCEPTABLE RELEASE OF RADIOACTIVE MATERIALS OR UNACCEPTABLE PLANT DAMAGE. THIS STANDARD APPLIES TO THE OVERALL BEHAVIOR OF THE PROTECTION SYSTEM, RATHER THAN TO THE DESIGN OF INDIVIDUAL EQUIPMENT ITEMS. THE MAJOR SECTIONS ARE DESIGN BASIS, CRITERIA AND REQUIREMENTS, AND QUALITY ASSURANCE. EMPHASIS IS GIVEN THE DESIGN BASIS SECTION, WHICH PRESCRIBES THE INTERDISCIPLINARY INFORMATION AND ANALYSES FOR SPECIFYING THE NECESSARY PROTECTIVE FUNCTIONS, TOGETHER WITH THE SYSTEM-RELIABILITY REQUIREMENTS. CRITERIA ARE THEN GIVEN FOR PROVIDING DEFENSES AGAINST VARIOUS KINDS OF FAILURES AND FOR ACCOMODATING THE SYSTEMS AND PROCEDURES REQUIRED TO OPERATE THE PLANT NORMALLY.

11-5-3-379

LMPFB SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM  
CASTLEMAN, A. W., JR.

BROOKHAVEN NATIONAL LABORATORY, UPTON, L. I., NEW YORK  
THE POTENTIAL HAZARD PRESENTED BY THE POSSIBILITY OF FISSION-PRODUCT AND PLUTONIUM TRANSPORT FROM LIQUID METAL COOLED REACTORS INTO THE ENVIRONMENT IS A MAJOR FACTOR IN REACTOR SITING, DESIGN, AND OPERATION. FORTUNATELY CONSIDERABLE INFORMATION ON THE BEHAVIOR OF FISSION PRODUCTS IN SODIUM SYSTEMS IS AVAILABLE WITH WHICH TO ASSESS THEIR FATE UNDER CONDITIONS LIKELY TO EXIST BOTH DURING REACTOR OPERATION AND IN THE EVENT OF AN ACCIDENT. IENON AND KRYPTON ARE THE ONLY FISSION PRODUCTS THAT EXERT LARGE PARTIAL PRESSURES AND ARE THE ONLY ONES LIKELY TO BE SIGNIFICANTLY RELEASED IN THE ABSENCE OF EXTENSIVE SODIUM VAPORIZATION. UNDER INERT CONDITIONS FISSION-PRODUCT IODINE REACTS WITH SODIUM AND, EXCEPT POSSIBLY AT HIGH CONCENTRATIONS WITHIN THE SODIUM THERMAL BOND OF A FUEL ELEMENT, WILL PROBABLY BE RETAINED IN THE LIQUID SODIUM. THE ALKALINE METALS WILL DISTRIBUTE BETWEEN THE COOLANT AND THE SURFACES EXPOSED TO SODIUM, ALTHOUGH LARGE FRACTIONS WILL VAPORIZE IN THE EVENT OF SIGNIFICANT SODIUM VAPORIZATION. ANALYSIS OF THE BEHAVIOR OF BARIUM AND STRONTIUM REQUIRES FURTHER STUDY, HOWEVER, IT IS KNOWN THAT THEIR VOLATILITY IS LOW, AND THEY WILL PROBABLY INTERACT WITH THE OXYGEN DISSOLVED IN REACTOR-GRADE SODIUM AND DEPOSIT ON THE PRIMARY-SYSTEM PIPING. CALCULATIONAL METHODS ARE AVAILABLE FOR PREDICTING THE MAXIMUM EXTENT OF VAPORIZATION OF CS, RB, SR, I (AS WAI), BA, TP, AND SB AS A FUNCTION OF SODIUM VAPORIZATION.

- 11-5-4-391 RADIOACTIVE WASTE DISPOSAL BY HYDRAULIC FRACTURING  
DE LAGUNA, W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE PETROLEUM INDUSTRY HAS DEVELOPED, LARGELY SINCE WORLD WAR II, THE TECHNIQUE OF HYDRAULIC FRACTURING TO INCREASE OIL RECOVERY THAT IS TODAY ALMOST UNIVERSALLY USED IN RESERVOIR ROCKS OF LOW PERMEABILITY. SINGLE INJECTIONS OF 100,000 GAL OF OIL CONTAINING 250,000 LB OF SAND ARE NOT UNUSUAL. MUCH THE SAME EQUIPMENT AND PROCEDURE MAY BE USED FOR WASTE DISPOSAL, ALTHOUGH THERE ARE CERTAIN SIGNIFICANT DIFFERENCES. THE DISPOSAL WELL AT OAK RIDGE WAS DRILLED AND CASING TO A DEPTH OF 1000 FT IN SHALE BY USING STANDARD OIL-FIELD METHODS. THE CASING IS SLOTTED NEAR THE BOTTOM, AND FOR WASTE DISPOSAL A SELF-HARDENING MIXTURE OF WASTE, PORTLAND CEMENT, AND CLAY IS PUMPED DOWN UNDER HIGH PRESSURE TO FORM A WIDESPREAD, THIN, HORIZONTAL FRACTURE IN THE SHALE IN WHICH THE WASTE SETS UP SOLID. AFTER FOUR INJECTIONS INTO THE SAME SLOT, TOTALING ROUGHLY 500,000 GAL, THE BOTTOM OF THE WELL IS PLOTTED AND A NEW SLOT CUT SOME 10 FT HIGHER UP THE WELL. PROBLEMS THAT HAD TO BE SOLVED AT OAK RIDGE TO MAKE POSSIBLE THE OPERATIONAL DISPOSAL OF MEDIUM-LEVEL RADIOACTIVE WASTE WERE (1) DETERMINING THE GEOMETRY OF THE FRACTURES FORMED IN THE SHALE, (2) ESTABLISHING THE FORMULA FOR A SATISFACTORY WASTE-CEMENT-CLAY MIX, (3) DESIGNING AND CONSTRUCTING THE SURFACE PLANT, AND (4) FORMULATING METHODS OF MONITORING THE OPERATION.
- 11-6-1-435 BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACCELERATOR CENTER  
JENKINS, T. M.  
STANFORD LINEAR ACCELERATOR CENTER, PALO ALTO, CALIFORNIA  
THE HEALTH PHYSICS DEPARTMENT AT THE STANFORD LINEAR ACCELERATOR CENTER (SLAC) ACTIVELY PARTICIPATES WITH THE RESEARCH AREA DEPARTMENT IN PROBLEMS RELATED TO SAFE BEAM TRANSPORT AND SHIELDING. THE RESULT OF SUCH PLANNING AND DESIGN IS SET FORTH IN AN OPERATIONAL DOCUMENT KNOWN AS THE BEAM AUTHORIZATION SHEET, WHICH, ALONG WITH THE RADIATION RULE BOOK, PROVIDES THE GUIDELINES THROUGH WHICH THE ACCELERATOR, BEAM SWITCHYARD, AND RESEARCH AREA ARE OPERATED SAFELY. PLANNING AND OPERATIONAL PHASES OF RADIATION PROTECTION AT SLAC INCLUDE (1) PRIMARY ELECTRON- AND POSITRON-BEAM CONTAINMENT, (2) CONTROL OF DANGEROUS SECONDARY-BEAM AREAS AND ANY THAT ARE POTENTIALLY DANGEROUS, (3) RADIATION AND SHIELDING CALCULATIONS, (4) BEAM CHECK-OUT PROCEDURES AND MEASUREMENTS, AND (5) ROUTINE MONITORING. SEVERAL CLASSIC EXAMPLES ILLUSTRATE THE INGENUITY REQUIRED TO SATISFY THE SAFETY CRITERIA ESTABLISHED AT SLAC, AND THE INFORMATION PRESENTED SHOULD BE OF PARTICULAR INTEREST TO THOSE WHO ARE PLANNING NEW ACCELERATORS.
- 11-6-1-445 A SYSTEMS APPROACH TO NUCLEAR PLANT SAFETY  
SNEDEKER, J. T.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA  
THE COMPLEXITY AND ADVANCED TECHNOLOGY OF TODAY'S NUCLEAR PLANTS WARRANT A NEW LOOK AT NUCLEAR PLANT SAFETY. THE EVALUATION TECHNIQUE ADVANCED IS BASED ON DEFINING THE EVENTS FOR WHICH A NUCLEAR PLANT MUST BE DESIGNED AND THEN SPECIFYING THE UNACCEPTABLE CONSEQUENCES OF THOSE EVENTS. IT IS THEN POSSIBLE TO SYSTEMATICALLY ANALYZE THE PLANT TO IDENTIFY THE ACTIONS, SYSTEMS, AND COMPONENTS ESSENTIAL TO ACCOMMODATING THE SPECIFIED EVENTS SO THAT UNACCEPTABLE RESULTS ARE NOT OBTAINED. THE ACTIONS, SYSTEMS, AND COMPONENTS IDENTIFIED AS ESSENTIAL MUST THEN BE DESIGNED AND OPERATED IN SUCH A WAY THAT SPECIFIED STANDARDS OF REDUNDANCY AND QUALITY ARE MAINTAINED. IN THIS WAY PLANT DESIGN AND OPERATION REFLECT A COMPREHENSIVE AND CONSISTENT BALANCE WITH RESPECT TO NUCLEAR SAFETY.
- 11-6-2-450 EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS  
MILLER, D.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS  
THE EQUATION OF STATE IS IMPORTANT IN FAST REACTOR SAFETY STUDIES BECAUSE IT COUPLES THE RATE OF ENERGY DEPOSITION WITH THE DEFORMATIONS AND DAMAGE THAT CAN BE PRODUCED IN AN ACCIDENT. THIS FIRST PART OF A TWO-PART REVIEW DISCUSSES THE APPLICATION OF THE EQUATION OF STATE TO REACTOR PROBLEMS AND INDICATES IMPORTANT PROPERTIES AND PROCESSES, ALONG WITH LIMITATIONS ON THEIR APPLICABILITY. THE EQUATION OF STATE IS A COMPLEX ENTITY, WITH BOTH THERMAL AND MECHANICAL DEPENDENCIES. BECAUSE OF THE WIDE RANGE OF CONDITIONS THAT MIGHT BE IMPORTANT IN ACCIDENT ANALYSES, CONSIDERATION MUST BE GIVEN TO A WIDE VARIATION OF PROPERTIES. MATERIALS OF PRINCIPAL INTEREST ARE THE FUEL AND FERTILE MATERIALS (METALLIC OR CERAMIC), CLADDING AND STRUCTURAL MATERIALS (GENERALLY IRON ALLOYS), AND THE SODIUM COOLANT, EACH HAS SPECIAL CHARACTERISTICS. ALTHOUGH EXPERIMENTAL DATA ARE AVAILABLE FOR MANY OF THESE MATERIALS, THEORY AND EMPIRICISM MUST BE USED TO EXTEND AND APPLY THE DATA. PART 2 OF THIS REVIEW, SCHEDULED FOR AN EARLY ISSUE OF NUCLEAR SAFETY, WILL EMPHASIZE SOME METHODS OF MEASUREMENT AT EXTREME CONDITIONS, INCLUDING THE POSSIBLE USE OF REACTORS, AND THE STATUS OF KNOWLEDGE ABOUT SPECIFIC REACTOR MATERIALS.

- 11-6-2-463 FIFTH GERMAN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER PLANTS  
NEPHEW, E. A.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE FIFTH GERMAN SYMPOSIUM ON PROGRESS IN THE DEVELOPMENT OF NEW METHODS FOR SAFETY ANALYSIS OF NUCLEAR POWER PLANTS WAS SPONSORED BY THE INSTITUTE FOR REACTOR SAFETY AND WAS HELD IN HAMBURG, GERMANY, OCT. 27-28, 1969. TEN PAPERS WERE PRESENTED IN THREE DIFFERENT SESSIONS, AND AMPLE TIME WAS PROVIDED FOR DETAILED DISCUSSION OF THE TOPICS. COVERED AND EXTENSIVELY DISCUSSED WERE THE RELIABILITY ANALYSES OF COMPONENTS AND SYSTEMS, AS WELL AS THE ACQUISITION AND USE OF FAILURE DATA, IN THE DESIGN OF REACTOR PLANTS. IT WAS GENERALLY CONCLUDED THAT EXISTING FAILURE DATA ARE INADEQUATE FOR ABSOLUTE RISK ASSESSMENTS BUT CAN BE VERY USEFUL FOR IMPROVING PLANT AVAILABILITY AND COMPARING THE CONSEQUENCES OF ACCIDENTS. ACCORDINGLY, COLLECTION OF FAILURE DATA SHOULD BE ENCOURAGED, BUT THE USE OF THESE DATA IN RELIABILITY ANALYSES CANNOT NOW REPLACE THE MAXIMUM CREDIBLE ACCIDENT CONCEPT AS A BASIS FOR SAFETY ASSESSMENT.
- 11-6-3-468 INSTRUMENTATION FOR MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS  
ROBINSON, T. B. + DUGGINS, B. C.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
VARIOUS ENGINEERED SAFETY FEATURES AVAILABLE IN NUCLEAR FUELED COMMERCIAL POWER STATIONS WOULD BE CALLED UPON TO COPE WITH THE CONSEQUENCES OF A LOSS-OF-COOLANT ACCIDENT. THESE SAFETY FEATURES ARE PROVIDED WITH INSTRUMENTS TO INITIATE OPERATION AND TO MONITOR CONTINUED OPERATION. WHEN THE SAFETY FEATURES WERE CALLED UPON, THE PLANT OPERATOR WOULD NEED INFORMATION REGARDING BOTH THE OPERATION OF THESE EMERGENCY SYSTEMS AND EQUIPMENT AND THE CONTINUING SUCCESS OF THEIR MISSION. A BRIEF STUDY WAS CONDUCTED TO DETERMINE THE TYPES AND EXTENT OF INSTRUMENTATION AVAILABLE IN THE DESIGNS OF REPRESENTATIVE NUCLEAR POWER PLANTS OF THE LATEST GENERATION FOR MONITORING THE COURSE OF A LOSS-OF-COOLANT ACCIDENT. THE FOUR PLANTS SURVEYED APPEARED TO HAVE ADEQUATE AND SUFFICIENT INSTRUMENTATION FOR MONITORING THE OPERATION OF THE EQUIPMENT IN THE ENGINEERED SAFETY SYSTEM FOR THE CASE OF A SUCCESSFULLY CONTAINED LOSS-OF-COOLANT ACCIDENT, HOWEVER, INSTRUMENTS FOR DIRECTLY DETECTING UNEXPECTED DAMAGE TO THE REACTOR CORE APPEAR TO BE LACKING.
- 11-6-4-475 SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFECTS  
CLOUTIER, R. J.  
OAK RIDGE ASSOCIATED UNIVERSITIES, OAK RIDGE, TENNESSEE  
THE DIVISION OF BIOLOGY AND MEDICINE OF THE U.S. ATOMIC ENERGY COMMISSION AND THE ENVIRONMENTAL CONTROL ADMINISTRATION OF THE U.S. PUBLIC HEALTH SERVICE WERE THE SPONSORS OF THE SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFECTS, HELD IN OAK RIDGE, TENN., DEC. 8-11, 1969. THIS SYMPOSIUM WAS ONE OF A SERIES ON MEDICAL USES OF RADIONUCLIDES CONDUCTED BY THE MEDICAL DIVISION OF THE OAK RIDGE ASSOCIATED UNIVERSITIES. THE TOPICS OF THE 32 INVITED PAPERS MAY BE GROUPED INTO THREE GENERAL CATEGORIES - (1) MATHEMATICS FOR CALCULATING RADIATION DOSE TO A PATIENT FROM INTERNALLY ADMINISTERED RADIONUCLIDES, (2) DISTRIBUTION AND RETENTION OF RADIONUCLIDES IN PATIENTS AND (3) BIOLOGIC EFFECTS OF RADIONUCLIDES.
- 11-6-4-482 LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE MORTALITY RISKS FROM REACTOR ACCIDENTS  
OTWAY, H. J. + ERDMANN, R. C.  
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO - UCLA, LOS ANGELES, CALIFORNIA  
THE LITERATURE REGARDING THE LATE SOMATIC EFFECTS OF IONIZING RADIATION WAS REVIEWED AND ESTIMATES WERE MADE OF THE MORTALITY RISK FOR LEUKEMIA AND THYROID CARCINOMA BASED ON A LINEAR THEORY OF CARCINOGENESIS. THE ESTIMATES WERE ONE DEATH PER MILLION PERSONS PER RAD OF IODINE-131 THYROID IRRADIATION AND 30 DEATHS PER MILLION PERSONS PER RAD FROM LEUKEMIA DUE TO WHOLE-BODY IRRADIATION. THESE NUMBERS ARE APPLIED TO THE DOSE-DISTANCE RELATIONS FOR HYPOTHETICAL DESIGN ACCIDENTS CALCULATED FOR PRESSURIZED-WATER AND FAST BREEDER REACTORS. IT IS CONCLUDED THAT FOR THESE POSTULATED ACCIDENTS AND REACTOR TYPES THE LONG-TERM RISK OF DEATH FROM LEUKEMIA MAY BE COMPARABLE TO OR GREATER THAN THAT FROM THYROID CARCINOMA.
- 11-6-5-493 REPORT ON SEMINAR OF TRIGA OWNERS  
KRAKER, P.  
U.S. DEPARTMENT OF THE INTERIOR, DENVER, COLORADO  
A SEMINAR OF TRIGA RESEARCH-REACTOR OWNERS WAS HELD IN DENVER, COLO., IN FEBRUARY 1970. SOME OF THE REMARKS, OPINIONS, AND INFORMATION FROM THE SESSIONS ARE ASSEMBLED AND PUBLISHED IN THIS ARTICLE UNDER THE FOLLOWING HEADINGS - REACTOR FUNDING, TECHNICAL SPECIFICATIONS AND REACTOR LICENSING, TRIGA FUEL ELEMENTS, TRIGA REACTOR DESIGN IMPROVEMENTS, TRIGA EXPERIENCES, HEALTH-PHYSICS CONSIDERATIONS, AND TRIGAS AND USAREC COMPLIANCE.
- 12-1-1-001 RADIATION STANDARDS AND PUBLIC HEALTH  
EISENBUD, M.  
NEW YORK UNIVERSITY MEDICAL CENTER, NEW YORK, NEW YORK  
THE RADIATION SAFETY RECORD OF THE AEC HAS BEEN GOOD, BUT CHANGES IN THE PRESENT REGULATORY SYSTEM ARE NEEDED TO

RECONCILE DIFFERENCES BETWEEN PUBLIC ATTITUDES AND THE AEC. AEC REGULATIONS ARE BASED ON THE RECOMMENDATIONS OF THE ICRP AND THE NCRP, AND THE STANDARDS CONTAIN EXTENSIVE BUILT-IN CONSERVATISM. HOWEVER, THE EMPHASIS ON THE MAXIMUM PERMISSIBLE CONCENTRATIONS OF RADIONUCLIDES IN AIR AND DRINKING WATER SHOULD BE CHANGED TO SPECIFY THE MAXIMUM PERMISSIBLE DAILY INTAKE FROM ALL SOURCES TO TAKE INTO CONSIDERATION MULTIPLE SOURCES AND ECOLOGICAL FACTORS. FURTHER, THE DUAL RESPONSIBILITY OF THE AEC FOR THE DEVELOPMENT OF NUCLEAR POWER AND THE PROTECTION OF THE PUBLIC HAS CONTRIBUTED TO LACK OF PUBLIC CONFIDENCE IN THE AEC. ACCORDINGLY IT IS RECOMMENDED THAT RESPONSIBILITIES FOR SETTING RADIATION LIMITS BE SHIFTED TO ANOTHER AGENCY OF THE FEDERAL GOVERNMENT. THE SAME AGENCY, IN COOPERATION WITH THE STATES, SHOULD ASSUME RESPONSIBILITY FOR ENVIRONMENTAL MONITORING IN THE VICINITY OF AEC-LICENSED FACILITIES.

- 12-1-2-009 OFFSHORE SITING OF NUCLEAR ENERGY STATIONS  
ANDERSON, T. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
QUESTIONS INVOLVING ENVIRONMENTAL QUALITY, PRIORITY OF LAND USES, AND PUBLIC SAFETY HAVE CREATED AND WILL CONTINUE TO CREATE DIFFICULTIES IN FINDING ACCEPTABLE SITES FOR NUCLEAR POWER PLANTS. INTEREST IS INCREASING IN OFFSHORE STATIONS AS ONE SOLUTION TO THE SITING PROBLEM. INVESTIGATIONS OF OFFSHORE STATIONS HAVE INCLUDED BOTH ARTIFICIAL ISLANDS AND FLOATING PLATFORMS AND HAVE TOUCHED ON ENVIRONMENTAL EFFECTS, ECONOMICS, AND SAFETY. INDICATIONS ARE THAT MANY OF THE PROBLEMS ASSOCIATED WITH SITING NUCLEAR POWER PLANTS COULD BE ALLEVIATED BY OFFSHORE STATIONS. THE FLOATING-STATION CONCEPT, IN PARTICULAR, SEEMS TO HAVE SIGNIFICANT POTENTIAL FOR THE FUTURE. BEFORE THIS POTENTIAL CAN BE REALIZED, HOWEVER, CONSIDERABLE DEVELOPMENT OF THE CONCEPT WILL BE NEEDED.
- 12-1-3-015 PLUME RISE - A RECENT CRITICAL REVIEW  
BRIGGS, G. A.  
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, OAK RIDGE TENNESSEE  
COMPARISONS OF A LARGE NUMBER OF PLUME-RISE OBSERVATIONS AND FORMULAS INDICATED THAT A RELATIVELY SIMPLE MODEL PROVIDED THE BEST PREDICTIONS OF PLUME RISE IN A VARIETY OF METEOROLOGICAL CONDITIONS. THE MODEL PREDICTS THAT NEAR THE STACK THE RISE OF A HOT, BUOYANT PLUME IS PROPORTIONAL TO THE RECIPROCAL OF THE WIND SPEED, TO THE ONE-THIRD POWER OF THE HEAT EMISSION, AND TO THE TWO-THIRDS POWER OF THE DISTANCE DOWNWIND. THIS '2/3 LAW' OF RISE FITS THE BULK OF PUBLISHED OBSERVATIONS. DEPENDENCE ON DISTANCE DOWNWIND GRADUALLY DIMINISHES IN NEUTRAL ATMOSPHERIC CONDITIONS BEYOND THE DISTANCE RELATED TO THE HEAT EMISSION AND THE STACK HEIGHT. IN STABLE CONDITIONS, RATHER ABRUPT LEVELING OF PLUMES OCCURS AT A DISTANCE DEPENDENT ON THE WIND SPEED AND THE ATMOSPHERIC VERTICAL TEMPERATURE GRADIENT. THE MODEL WAS ALSO APPLIED TO THE PREDICTION OF WHETHER A HOT PLUME WILL PENETRATE AN ELEVATED INVERSION AND WAS FOUND TO AGREE WITH OBSERVATIONS.
- 12-1-3-025 ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM  
AUBERBACH, S. I.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
ONE OF THE CURRENT CONCERNS OVER THE INCREASING INSTALLATION OF NUCLEAR POWER STATIONS IS THE POTENTIAL IMPACT OF RADIOACTIVE WASTE RELEASES ON LOCAL ECOSYSTEMS. IN PARTICULAR, THE QUESTION HAS BEEN RAISED WHETHER WASTE RELEASES AT MAXIMUM PERMISSIBLE CONCENTRATION (MPC) LEVELS WOULD CAUSE ECOLOGICAL PROBLEMS DUE TO THE RADIOACTIVITY. HYPOTHETICAL ANNUAL SUBMERSION DOSE RATES FROM WATER ASSUMED TO BE MAINTAINED AT THE OCCUPATIONAL MPC X 1/30 WERE CALCULATED FOR ORGANISMS LIVING CONTINUOUSLY IN THESE WATERS. THESE HYPOTHETICAL DOSES ARE USED AS A BASIS FOR COMPARISONS IN A VARIETY OF ECOLOGICAL STUDIES OF LOW DOSES OF IONIZING RADIATION AND ARE ANALYZED AND EVALUATED IN TERMS OF DETECTABILITY OF BIOLOGICAL EFFECTS AT MPC LEVELS. PRESENT KNOWLEDGE BASED ON THESE AND SIMILAR STUDIES OF THE ECOLOGICAL EFFECTS OF LOW-LEVEL CHRONIC DOSES, SUCH AS COULD RESULT FROM ROUTINE REACTOR RELEASES UNDER CURRENT STANDARDS, GUIDELINES, AND OPERATIONAL EXPERIENCE, INDICATES THAT ANY POSSIBLE BIOLOGICAL EFFECTS WOULD BE UNDETECTABLE. ALTHOUGH THE DATA IN SUPPORT OF THIS CONTENTION ARE LIMITED, THEY CONSISTENTLY POINT TO THIS CONCLUSION.
- 12-1-4-035 FUEL MELTDOWN AT ST. LAURENT I  
CORBETT, B. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE ST. LAURENT I PLANT, ELECTRICITE DE FRANCE'S NEW 500-MW (E) GAS-COOLED NUCLEAR GENERATING FACILITY, SUFFERED A FUEL MELTDOWN ON OCT. 17, 1969. DURING A ROUTINE REFUELING OPERATION, GRAPHITE ADSORBERS, INCLUDING A GRAPHITE FLOW RESTRICTOR, WERE MISTAKENLY LOADED AT THE TOP OF A FUEL ELEMENT CHANNEL. THE COOLANT-FLOW REDUCTION DAMAGED 6 OF THE 10 FUEL ELEMENTS IN THIS CHANNEL, AND THERE WAS

SOME EVIDENCE THAT UP TO 10 KG OF URANIUM (EQUIVALENT TO A COMPLETE FUEL ELEMENT) COMPLETELY MELTED. SUBSEQUENT CLEANUP AND PLANT MODIFICATIONS WERE EXPECTED TO REQUIRE ABOUT 1 YEAR OF REACTOR DOWNTIME.

- 12-2-1-75 THE IAEA-AEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER  
GIFFORD, P. A., JR.  
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENNESSEE  
A SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER STATIONS WAS HELD IN NEW YORK CITY, AUG. 10-14, 1970. THE PRINCIPAL TOPICS CONSIDERED WERE NUCLEAR POWER AS AN ENERGY SOURCE, STANDARDS FOR THE CONTROL OF EFFLUENTS, EFFLUENT CONTROL AND MONITORING, CONSIDERATIONS AFFECTING STEAM POWER-STATION SITE SELECTION, AND BENEFIT VS. RISK ASSESSMENT.
- 12-2-1-83 AN APPRECIATION OF FAST REACTOR SAFETY-1970  
BASSMUSSEN, M. C.  
MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASSACHUSETTS  
THIS UKAEA REPORT CONCISELY SUMMARIZES CURRENT THINKING IN THE UNITED KINGDOM WITH REGARD TO FAST REACTOR SAFETY - SPECIFICALLY, SODIUM-COOLED FAST REACTOR SAFETY. THE PRINCIPAL PURPOSE OF THE REPORT IS STATED, AS FOLLOWS, BY P. W. PAPPER IN THE FOREWORD - IT IS IMPORTANT FOR ALL COUNTRIES THAT FAST REACTORS SHOULD BE SAFE AND THAT SAFETY SHOULD BE A MATTER OF COMMERCIAL BARGAINING. THE IMMEDIATE NEED NOW IS TO DEVELOP A COMMON INSIGHT INTO THE TECHNICAL UNCERTAINTIES OF FAST REACTORS, FROM WHICH MAY EVOLVE A SAFETY PHILOSOPHY WHICH CAN BE MEANINGFULLY PURSUED BY ALL COUNTRIES. THERE IS STILL NEED FOR MORE WORK AND IN THE BELIEF THAT PROBLEMS OF ALL MAJOR SYSTEMS REQUIRE INTERNATIONAL RECOGNITION AND JOINT EFFORT IN THEIR SOLUTION, THIS COMPENDIUM IS OFFERED IN THE HOPE THAT THE COMMENT AND CRITICISM IT MIGHT EVOKE COULD LEAD TO A SECOND IMPROVED VERSION WITH CONTRIBUTIONS FROM OTHER NATIONS.
- 12-2-2-85 RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA  
HUNT, D. C.  
DOW CHEMICAL COMPANY, GOLDEN, COLORADO  
A STUDY WAS MADE OF THE POSSIBLE HAZARD OUTSIDE AN ENCLOSURE DUE TO INCIDENTAL RELEASE FROM THE ENCLOSURE FOLLOWING THE UNCONTROLLED RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE BY REVIEWING THE EXISTING OBSERVATIONAL DATA ON SUCH RESTRICTED PLUTONIUM RELEASES. OBSERVATIONS BASED ON BOTH ACCIDENT EXPERIENCE AND EXPERIMENTS DESIGNED TO STUDY THE RESTRICTED RELEASE WERE CONSIDERED. THE CONCLUSION BASED ON THE OBSERVATIONAL DATA IS THAT RESTRICTED RELEASE IS UNLIKELY TO LEAD TO DANGEROUS FREE RELEASE OF A PLUTONIUM AEROSOL. A REMARKABLE EXAMPLE OF THIS WAS THE FIRE AT THE ROCKY PLATS PLANT ON MAY 11, 1969. ONLY A MINUTE AMOUNT OF THE PLUTONIUM INVOLVED IN THE FIRE ESCAPED FROM THE BUILDING IN WHICH THE FIRE OCCURRED, AND NO PLUTONIUM WAS DETECTED BEYOND THE PLANT BOUNDARIES.
- 12-2-3-90 FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED REACTORS  
BAUMANN, C. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
AN APPLICATIONS STUDY IS MADE OF RADIATION MEASURING INSTRUMENTS AND SYSTEMS THAT MIGHT BE SUITABLE FOR DEVELOPMENT AS MONITORS OF THE FISSION PRODUCT ACTIVITY OF THE PRIMARY GAS-COOLANT STREAM IN HIGH TEMPERATURE GAS-COOLED REACTORS. PARTICULAR ATTENTION IS GIVEN TO THE PLATEOUT IN LOOP COMPONENTS, PRIMARILY THE HEAT EXCHANGERS. THE DETECTORS REVIEWED ARE IONIZATION CHAMBERS, BETA AND GAMMA SPECTROMETERS, CHARGED-WIRE PRECIPITATORS, CHERENKOV DETECTORS, FILTERS, DIFFUSION TUBES, THERMAL-GRADIENT TUBES, DEPOSITION TUBES, AND IMPACTORS. THE PRINCIPLE OF OPERATION OF EACH IN A SYSTEM IS DESCRIBED, AND THE ADVANTAGES AND DISADVANTAGES IN APPLICATION TO THE PROBLEM ARE EVALUATED. ON THE BASIS OF LINEAR PENETRATION REQUIREMENTS, GAS STREAM SAMPLING TECHNIQUES, CONCURRENCY OF READOUT, AND THE CHARACTERISTIC MERITS OF THE INDIVIDUAL SYSTEMS, IT APPEARS THAT THE DEPOSITION TUBE AND GAMMA SPECTROMETER SYSTEMS CAN BE FURTHER DEVELOPED AS COMPETENT PLATEOUT MONITORS FOR HIGH TEMPERATURE GAS LOOPS IN NUCLEAR REACTOR SERVICE.
- 12-2-4-100 THE ELEVENTH AEC AIR CLEANING CONFERENCE  
MOELLER, D. W.  
HARVARD UNIVERSITY, BOSTON, MASSACHUSETTS  
THE ELEVENTH AEC AIR-CLEANING CONFERENCE WAS HELD AUG. 31-SEPT. 3, 1970, IN RICHLAND, WASH. THE SUBJECTS DISCUSSED WERE (1) SODIUM AEROSOLS FROM LIQUID METAL-COOLED FAST BREEDER REACTORS (2) WATER-REACTOR FISSION PRODUCT RELEASE ESTIMATIONS (3) REMOVAL AND BEHAVIOR OF FISSION PRODUCT GASES (4) IODINE CHARACTERIZATION AND REMOVAL (5) OTHER FILTRATION STUDIES (6) INSTRUMENT DEVELOPMENT AND EVALUATION (7) EFFECTS OF AIRBORNE RADIOACTIVE MATERIALS (8) FIRE SAFETY AND (9) STANDARDS DEVELOPMENT. THE PROCEEDINGS OF THE CONFERENCE WERE PUBLISHED IN JANUARY 1971.

- 12-2-5-110 PREDICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS  
COLLINS, G. F.  
THE RESEARCH CORPORATION OF NEW ENGLAND, HARTFORD, CONNECTICUT  
A METHOD OF PREDICTING THE TRANSPORT DISTANCE REQUIRED TO COMPLETE THE TRANSITION FROM OVERWATER TO OVERLAND DIFFUSION AS A FUNCTION OF PLUME HEIGHT, WIND SPEED, AND VERTICAL TEMPERATURE PROFILE WAS SUGGESTED BY ISAAC VAN DER HOVEN IN NUCLEAR SAFETY FOR SPRING-OCT. 1967. THIS ARTICLE DESCRIBES FIELD STUDIES CONDUCTED ON THE SHORES OF CAPE COD BAY DURING THE SUMMER OF 1969 TO TEST THE ACCURACY OF VAN DER HOVEN'S TECHNIQUE AND ITS APPLICABILITY TO IRREGULAR TERRAIN. THE RESULTS OF THE STUDY SHOW THAT THE METHOD OFFERS A PRACTICAL TOOL FOR COMPILING A SEA-BREEZE FUMIGATION CLIMATOLOGY.
- 12-2-5-114 METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE PRODUCED BY MAN  
HANNA, S. I. + SWISHER, S. D.  
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENNESSEE  
INTERACTIONS AMONG THE HEAT AND MOISTURE PRODUCED BY MAN AND ALL SCALES OF ATMOSPHERIC PHENOMENA ARE BEING STUDIED IN LIGHT OF CURRENT OBSERVATIONS AND FUTURE PROJECTIONS OF ENERGY CONSUMPTION. ATMOSPHERIC PROCESSES ARE NOW BEING SIGNIFICANTLY INFLUENCED ON LENGTH SCALES UP TO ABOUT 20 KM, A FIGURE THAT IS LIKELY TO INCREASE AS ENERGY PRODUCTION INCREASES. PRESENT RESEARCH EFFORTS ON THESE ATMOSPHERIC INTERACTIONS ARE INSUFFICIENT AND PROGRAMS TO SUPPLEMENT THESE ARE NEEDED.
- 12-2-6-123 FUEL MELTING INCIDENT AT THE FERMI REACTOR ON OCT. 5, 1966  
SCOTT, R. L., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
ON OCT. 5, 1966, THE ENRICO FERMI 1 NUCLEAR REACTOR SUSTAINED THE PARTIAL MELTDOWN OF TWO FUEL SUBASSEMBLIES AS THE RESULT OF COOLANT FLOW BLOCKAGE. IT WAS DETERMINED THAT A COMPONENT WITHIN THE REACTOR VESSEL HAD VIBRATED LOOSE AND CAUSED FLOW BLOCKAGE WHEN HYDRODYNAMIC FORCES CARRIED IT UP TO THE INLET NOZZLE OF THE FUEL SUBASSEMBLIES. RECOVERY OPERATIONS WERE SUCCESSFUL AND WERE CLIMAXED BY FULL POWER OPERATION AT 200 MW(T) (65 MW(E)) ON OCT. 16, 1970. MANY REPORTS AND ARTICLES HAVE BEEN WRITTEN ABOUT THE INCIDENT DURING THE PAST 4 YEARS, BUT MOST OF THESE WERE FRAGMENTARY BECAUSE THE INVESTIGATIONS AND ANALYSES HAD NOT BEEN COMPLETED. THIS REVIEW WAS PREPARED TO PRESENT A CONCISE DESCRIPTION OF THE INCIDENT AND SUMMARY OF THE RESULTS OF THE INVESTIGATIONS. THE SEQUENCE OF EVENTS LEADING UP TO THE INCIDENT AND DURING THE INCIDENT IS REVIEWED, THE CONSIDERATIONS THAT LED TO UNDERSTANDING WHAT HAD TRANSPIRED ARE PRESENTED, AND THE LESSONS DERIVED FROM THE INCIDENT ARE DISCUSSED.
- 12-2-6-134 REPORT ON THE 1970 ANS CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS  
SCOTT, R. L., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
FIFTY-THREE PAPERS WERE PRESENTED AT THE AMERICAN NUCLEAR SOCIETY'S 1970 CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS. THE PAPERS COVERED THE MAIN SUBJECT AREAS OF QUALITY ASSURANCE, SAFETY AND INSTRUMENTATION SYSTEMS, COMMERCIAL REACTORS, AND ADVANCED REACTORS. SOME OF THE MORE INTERESTING AND INFORMATIVE ASPECTS OF THE PAPERS INCLUDED STARTUP EXPERIENCES AT A COMMERCIAL NUCLEAR POWER PLANT, REVIEWS OF THE NUCLEAR STANDARDS PROGRAMS IN THE UNITED STATES, RESULTS OF LOSS-OF-COOLANT ACCIDENT STUDIES, AND RESULTS OF A SIMULATED ACCIDENT IN AN ACTUAL CONTAINMENT STRUCTURE.
- 12-3-1-185 RADIATION IN PERSPECTIVE - 50 COMPARISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS  
HULL, A. P.  
BROOKHAVEN NATIONAL LABORATORY, UPTON, L.I., NEW YORK  
FOSSIL AND NUCLEAR FUELED STEAM PLANTS SEEM THE PRACTICAL MEANS FOR MEETING IMMEDIATE POWER NEEDS. THE USE OF NUCLEAR FUELED PLANTS IS BEING RESTRICTED IN SEVERAL INSTANCES BECAUSE REACTOR RELATED HAZARDS HAVE BEEN EXAGGERATED. NINETY POWER REACTORS, IN THE UNITED STATES AND ABROAD, HAVE GENERATED 2.5 X 10<sup>11</sup> KWH OVER 650 REACTOR YEARS WITHOUT SERIOUS INCIDENTS. COMPARISON OF ROUTINE DISCHARGES OF HAZARDOUS AGENTS FROM DIFFERENT TYPES OF STEAM POWER PLANTS SHOWS THAT NUCLEAR FUELED PLANTS PRODUCE THE LOWEST CONCENTRATIONS OF SUCH AGENTS RELATIVE TO PROTECTION STANDARDS. RADIOACTIVE RELEASES ASSOCIATED WITH THE BROOKHAVEN GRAPHITE RESEARCH REACTOR ARE COMPARABLE TO THE UPPER AMOUNTS ANTICIPATED FROM 1000-MW(E) REACTORS, AND THE MEASURED BROOKHAVEN EXTERNAL RADIATION LEVELS, DEPOSITION, AND AQUATIC CONCENTRATIONS SUGGEST THAT THE RADIATION LEVEL IN THE VICINITY OF LARGE POWER REACTORS SHOULD BE INSIGNIFICANT. THE CALCULATED RISK (ABOUT 10(XP-7)/YEAR) OF FATAL INJURY FROM THE ANTICIPATED MAXIMUM EXPOSURES OF A FEW MILLIREMS PER YEAR ABOVE NATURAL BACKGROUND IS SMALL COMPARED WITH THAT OF OTHER ACCEPTED HAZARDS OF EVERYDAY LIVING.
- 12-3-1-196 BEST SUMMARY - WATER-COOLED REACTOR SAFETY  
COTTRELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE COMMITTEE ON REACTOR SAFETY TECHNOLOGY OF THE ORGANIZATION FOR ECONOMIC COOPERATION AND DEVELOPMENT HAS PUBLISHED AN

ASSESSMENT OF WATER-COOLED REACTOR SAFETY. THIS ASSESSMENT SUMMARIZES OVER 3 YEARS OF EFFORT BY A WORKING GROUP OF SOME OF THE MOST QUALIFIED EUROPEAN NUCLEAR SAFETY EXPERTS. FOR THE PURPOSES OF THIS REPORT, THE SCOPE OF WORK IS DIVIDED INTO EIGHT AREAS, AND IN EACH AREA, TO THE EXTENT PRACTICAL, THE PROBLEM IS DEFINED, ANALYTICAL METHODS ARE SURVEYED, AVAILABLE EXPERIMENTAL AND THEORETICAL PROGRAMS ARE EVALUATED, AND THE EFFECTS ON ACCIDENT ANALYSIS ARE NOTED. THE EIGHT AREAS SO COVERED INCLUDE (1) THERMOHYDRAULIC EFFECTS OF BLOWDOWN (2) EMERGENCY CORE COOLING (3) BEHAVIOR OF MOLTEN CORE MATERIALS (4) MISSILE EFFECTS ON CONTAINMENT, PIPES, AND COMPONENTS (5) CONTAINMENT SYSTEM RESPONSE (6) FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL (7) RELIABILITY ANALYSIS IN REACTOR DESIGN AND SAFETY ASSESSMENT AND (8) POWER TRANSIENTS CAUSED BY REACTIVITY ADDITION.

- 12-3-2-203 RESTRICTED RELEASE OF PLUTONIUM II. THEORY  
RUBT, D. C.  
THE DOW CHEMICAL COMPANY, GOLDEN, COLORADO  
A STUDY WAS MADE OF THE POSSIBLE HAZARD OUTSIDE AN ENCLOSURE DUE TO UNCONTROLLED RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE. IN PART I OF THIS STUDY, WHICH WAS PUBLISHED IN NUCLEAR SAFETY, VOL. 12, NO. 2, A REVIEW WAS MADE OF EXISTING OBSERVATIONAL DATA ON SUCH RESTRICTED PLUTONIUM RELEASES. IN THIS SECOND AND LAST PART OF THE STUDY, A MODEL OF RESTRICTED RELEASE IS DEVELOPED. THE MODEL PREDICTS 'FREE-RELEASE' SOURCE STRENGTHS AS A FUNCTION OF THE VARIABLES ASSUMED TO DESCRIBE THE RELEASE. AN ILLUSTRATION OF THE USE OF THE THEORETICAL METHODS IS GIVEN BY APPLYING THEM TO THE ROCKY PLATS CRITICAL MASS FACILITY TEST CELL. THESE PARTICULAR CALCULATIONS SHOW THAT THE ACTUAL RELEASE WOULD BE SIGNIFICANTLY LESS THAN THE ALLOWABLE PLUTONIUM-239 MPC VALUE FOR INSOLUBLE MATERIAL IN CONTROLLED AREAS IF NOMINAL VALUES ARE ASSUMED FOR ALL RELEASE PARAMETERS. A PARAMETRIC STUDY INDICATED THAT THE CALCULATED RESULTS ARE MOST SENSITIVE TO THE RATE OF RELEASE OF PLUTONIUM WITHIN THE ENCLOSURE AND TO THE ASSUMED THERMAL EQUILIBRIUM CONDITIONS WITHIN THE ENCLOSURE.
- 12-3-3-217 REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS  
JOSLIN, W. M. + MOORE, J. S. + RUSS, J. C.  
AMERICAN NATIONAL STANDARDS INSTITUTE, OAK PARK, ILLINOIS -  
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA -  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA  
THE EFFORTS BEING MADE BY THE AMERICAN NATIONAL STANDARDS INSTITUTE, INC., THE AMERICAN NUCLEAR SOCIETY, AND THE INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS IN PROMOTING ENGINEERING STANDARDS DEVELOPMENT PROGRAMS FOR NUCLEAR POWER SYSTEMS ARE DISCUSSED BY THREE LEADERS IN THE FIELD. SOME EXAMPLES ARE GIVEN OF THE DIFFICULTIES AND THE SATISFACTIONS, AND SOME SUGGESTIONS ARE MADE FOR SOLVING THE PROBLEMS. THE REVIEWERS PRESENT A GENERAL CONCLUSION THAT THE TIME ELAPSE FROM INCEPTION TO ADOPTION NEEDS TO BE SHORTENED AND THAT MORE PARTICIPATION AND CLOSE COORDINATION ARE NEEDED AMONG GROUPS HAVING OVERLAPPING INTERESTS.
- 12-3-3-226 THE USE OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL SAFE DESIGN  
EPLEN, E. P. + DITTO, S. J.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
SOME OF THE PRINCIPLES GOVERNING CURRENT DESIGNS OF ELECTRICAL OR ELECTRONIC VOTING LOGIC SYSTEMS CAN BE APPLIED TO THE DESIGN OF CONTROL AND PROTECTION SYSTEMS WHERE THE VOTING LOGIC IS AT THE LEVEL OF THE LARGE ELECTROMECHANICAL DEVICES THAT ACT DIRECTLY TO CONTROL A PROCESS. THIS APPLICATION IS OF PARTICULAR BENEFIT IN SYSTEMS FOR WHICH THERE MAY BE A SIGNIFICANT PENALTY FOR FAILURE IN THE SO-CALLED SAFE MODE AS WELL AS IN THE UNSAFE MODE. SUCH SYSTEMS HAVE FREQUENTLY MADE USE OF 'FAILURE-TO-DANGER' TECHNIQUES, WHICH IN SOME AREAS MIGHT LEAD TO A COMPROMISE OF SAFETY OBJECTIVES. THE USE OF ACTUATORS AS LOGIC ELEMENTS ALLOWS THE DESIGN OF SIMPLER SYSTEMS, WITH MORE COMPLETE TESTABILITY, AND CAN PROVIDE AN ULTIMATE GAIN IN SAFETY.
- 12-3-4-234 NUCLEAR SAFETY IN AMERICAN RADIOCHEMICAL PROCESSING PLANTS  
USCIB, W. E. + BROWDER, F. W. + HANN, S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
WITH THE PROJECTED RAPID GROWTH OF NUCLEAR ELECTRIC POWER GENERATION AND THE ACCOMPANYING GROWTH IN REPROCESSING OF SPENT NUCLEAR FUEL, THE WHOLE AREA OF NUCLEAR AND RADIOCHEMICAL SAFETY BECOMES INCREASINGLY IMPORTANT. THERE IS AN INDICATED WORLDWIDE NEED FOR INFORMATION ON ACCEPTED PRACTICES, RECOMMENDED METHODS, AND REGULATIONS FOR SAFE OPERATION IN RADIOCHEMICAL PROCESSING PLANTS. EXPERIENCE AND DEVELOPMENTS IN THE UNITED STATES ARE DESCRIBED TO ILLUSTRATE SAFETY CONSIDERATIONS IN ALL STAGES FROM SITE SELECTION AND LICENSING THROUGH DESIGN, CONSTRUCTION, AND OPERATION AND MAINTENANCE OF PROCESSING PLANTS.
- 12-4-1-283 NUCLEAR POWER IN PERSPECTIVE - THE FLIGHT OF THE BEMIGIANT  
HESS, D. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
PREMISED ON THE ASSUMPTION THAT THE PUBLIC PRESS IS BOTH A MIRROR OF OPINION AND A REFLECTOR OF PUBLIC INTEREST AND

CRITIQUE, NEARLY 800 ITEMS IN THE DAILY AND PERIODICAL PRESS PERTAINING TO THE NUCLEAR INDUSTRY AND COVERING A PERIOD OF ABOUT 1 YEAR WERE EXAMINED FOR THEIR PHILOSOPHICAL AND PSYCHOLOGICAL IMPACT ON THE READER. ACCORDINGLY THIS SURVEY IS A RETROSPECTIVE ASSESSMENT IN ORDER OF PRIORITY OF THE PRINCIPAL CONTROVERSIAL ISSUES CONFRONTING THE NUCLEAR COMMUNITY. THE HOPE IS THAT, FROM THIS WORK, NUCLEAR ADVOCATES AND ALLIED INTERESTS MAY FIND A FIRMER SENSE OF DIRECTION AND SIGNIFICANT AREAS WHERE SPECIAL ATTENTION CAN BE MOST PROFITABLY DEVOTED TO AFFORD THE PUBLIC THE REASSURANCES IT NEEDS TO FEEL AT EASE IN THE PRESENCE OF THE ENERGY GIANT.

12-4-1-291 NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF NUCLEAR SAFETY  
MARRONE, J.

NUCLEAR ENGINEERING LIABILITY INSURANCE AGENCY, NEW YORK, NEW YORK  
NUCLEAR LIABILITY INSURANCE HAS BEEN MADE AVAILABLE TO THE NUCLEAR INDUSTRY BY AMERICAN INSURERS THROUGH POOLING ARRANGEMENTS THAT DISTRIBUTE THE RISK AMONG MANY PARTICIPATING INSURERS. THE LIABILITY INSURANCE AFFORDED BY THE POOLS HAS THUS FAR BEEN THE ONLY MEANS EMPLOYED TO SATISFY THE FINANCIAL PROTECTION REQUIREMENTS IMPOSED BY THE AEC ON SOME OF ITS LICENSEES. THE EXTRAORDINARY SAFETY RECORD OF THE NUCLEAR INDUSTRY IS QUITE VISIBLE IN THE POOLS' LIABILITY CLAIMS EXPERIENCE. THE MOST SIGNIFICANT FACT ISSUING FROM 14 YEARS OF OPERATION IS THAT THE NUCLEAR LIABILITY POOLS HAVE NEVER RECEIVED A CLAIM FOR BODILY INJURY OR PROPERTY DAMAGE CAUSED DURING THE OPERATION OF A LICENSED NUCLEAR REACTOR - THIS INCLUDES ALL TYPES OF LICENSED REACTORS. CRITICS OF NUCLEAR SAFETY HAVE PLAYED A ROLE IN ACHIEVING THIS RECORD. THE LIABILITY LOSS EXPERIENCE OF THE NUCLEAR INDUSTRY SUGGESTS THAT A POSITIVE IMAGE OF SAFETY IN THE NUCLEAR INDUSTRY COULD BE PROJECTED BY PRESENTING IT AS AN EXAMPLE, WARRANTING EMULATION, OF EFFECTIVE CONTROL OF A RELATIVELY NEW AND SERIOUS HAZARD. THAT OVER 1 MILLION PERSONS HAVE BEEN KILLED IN CONVENTIONAL ACCIDENTS IN THE UNITED STATES IN THE 10-YEAR PERIOD 1960 TO 1969 STRONGLY SUGGESTS THAT MUCH COULD BE LEARNED FROM THE NUCLEAR SAFETY PROGRAM BY THOSE WHO ARE CONCERNED ABOUT SAFETY IN THE NONNUCLEAR AREA.

12-4-2-297 FISSION GAS EFFECTS IN REACTOR FUELS I. BASIC STUDIES  
CARROLL, R. M.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE LITERATURE DEALING WITH THE BASIC PROCESSES OF FISSION-GAS BEHAVIOR IN REACTOR FUEL MATERIALS WHICH WAS PUBLISHED BETWEEN 1968 AND THE FALL OF 1970 IS REVIEWED. PARTICULAR ATTENTION IS CALLED TO THE 85 PUBLICATIONS CITED, AND NO ATTEMPT IS MADE TO PROVIDE A COMPREHENSIVE SUMMARY OF THEM. A CONSISTENT PATTERN IS SHOWN FOR ALL THE FUELS STUDIED. FISSION GAS WITHIN THE FUEL MATRIX DIFFUSES RAPIDLY EVEN AT COMPARATIVELY LOW TEMPERATURES, HOWEVER, THE GAS IS ATTACHED TO TRAPPING SITES WITH A FORCE THAT DEPENDS ON THE NATURE OF THE SITE AND THE NUMBER OF GAS ATOMS COLLECTED AT THE SITE. VARIOUS DRIVING FORCES CAN DISLODGE THE GAS ATOMS FROM THE SITE, AND NEW SITES CAN BE CREATED BY IRRADIATION. THUS GAS BEHAVIOR DURING FISSIONING DEPENDS ON VARIOUS TRAPPING AND DRIVING FORCES.

12-4-2-305 RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUCTION  
RIVARD, J. B.

SANDIA LABORATORIES, ALBUQUERQUE, NEW MEXICO  
A QUANTITATIVE APPROACH TO SYSTEM SAFETY HAS BEEN DEVELOPED. THE RISKS FROM COMPONENT ACTIVITIES ARE EXPRESSED AS EXPLICIT FUNCTIONS OF THE RESOURCES AVAILABLE FOR THEIR REDUCTION, AND THE MINIMUM SYSTEM RISK IS THEN FOUND BY DYNAMIC PROGRAMMING. NUMERICAL EXAMPLES OF THE METHOD ARE GIVEN.

12-4-3-310 JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970  
HAGEN, E. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE SECOND JOINT SYMPOSIUM BY THE IEEE POWER AND NUCLEAR SCIENCE GROUPS ON THE GENERAL TOPIC OF NUCLEAR POWER, CONTROL, AND INSTRUMENTATION WAS HELD IN NEW YORK CITY, NOV. 3-6, 1970. THE TALKS AND PAPERS PRESENTED TOTALLED 121 AT 15 SESSIONS, OF WHICH TWO WERE TUTORIAL. ENVIRONMENTAL CONSIDERATIONS WERE THE SUBJECT OF THE GENERAL MEETING, AND THE LUNCHEON SPEAKER DEPENDENT TECHNOLOGY. THE TECHNICAL SESSIONS COVERED SOME OPERATING EXPERIENCES, RELIABILITY ANALYSES, AND STANDARDS FOR NUCLEAR POWER STATIONS. THERE WERE ALSO PAPERS ON NUCLEAR INSTRUMENTATION FOR RESEARCH AND DEVELOPMENT IN NUCLEAR PHYSICS, BIOMEDICINE, SPACE EXPLORATION, AND DATA COLLECTING.

12-4-4-326 ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE ENVIRONMENT  
ELWOOD, J. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
A RAPIDLY EXPANDING NUCLEAR POWER ECONOMY HAS RESULTED IN INCREASED PUBLIC CONCERN OVER RELEASES OF RADIONUCLIDES TO THE ENVIRONMENT. REVIEW OF AVAILABLE LITERATURE ON TRITIUM, ONE OF THE RADIONUCLIDES RELEASED TO THE ENVIRONMENT AT NUCLEAR POWER REACTORS AND FUEL REPROCESSING PLANTS, INDICATES THAT TRITIUM CAN BE TAKEN IN BY PLANTS AND ANIMALS AND ORGANICALLY BOUND, REGARDLESS OF THE MEANS OF EXPOSURE. HOWEVER, THERE APPEARS TO BE NO CONCENTRATION FACTOR RELATIVE TO HYDROGEN AT ANY LEVEL OF



FOOD CHAINS ANALYZED TO DATE. ISOTOPE EFFECTS APPARENTLY DO NOT SIGNIFICANTLY ALTER TRITIUM BEHAVIOR COMPARED WITH THAT OF STABLE HYDROGEN (HYDROGEN-1) IN NATURAL ECOSYSTEMS. TURNOVER TIMES OF TRITIUM IN COUPLED ECOSYSTEM COMPARTMENTS ARE DEPENDENT ON CLIMATIC, HYDROLOGICAL, AND METEOROLOGICAL FACTORS AND THUS ARE SITE SPECIFIC FOR EACH ECOSYSTEM. HALF-TIMES ARE MUCH LONGER IN A DESERT ECOSYSTEM COMPARED WITH THOSE IN A TROPICAL RAIN FOREST. THE TOTAL ECOSYSTEM WILL HAVE A HALF-TIME OF RETENTION AT LEAST AS LONG AS THE COMPARTMENT WITH THE LONGEST HALF-TIME. TRITIUM BODY BURDEN IS DEPENDENT ON THE PATHWAYS OF EXPOSURE. TISSUE-BOUND FRACTIONS ARISE PRIMARILY FROM ORGANICALLY BOUND TRITIUM IN FOOD. BIOLOGICAL HALF-LIVES OF TISSUE-BOUND FRACTIONS ARE LONGER THAN THE HALF-LIFE OF THE BODY-WATER COMPONENT AND MAY BE AS LONG AS ONE-THIRD OF THE ORGANISM'S LIFE-SPAN. TRITIUM IN ALL COMPARTMENTS IN A CHRONICALLY CONTAMINATED ECOSYSTEM WOULD BE EXPECTED TO BE UNIFORMLY LABELED WITH HYDROGEN-3, WITH THE TRITIUM RATIO BEING DEPENDENT ON RELEASE LEVELS.

- 12-4-5-338 IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION ACCIDENTS  
ROHWER, F. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
A SYMPOSIUM ENTITLED 'HANDLING OF RADIATION ACCIDENTS' WAS HELD IN VIENNA ON MAY 19-23, 1969. IT WAS ORGANIZED BY THE INTERNATIONAL ATOMIC ENERGY AGENCY (IAEA) AND THE WORLD HEALTH ORGANIZATION (WHO) TO ENABLE RADIATION MONITORING AND DOSIMETRY SPECIALISTS, MEDICAL DOCTORS EXPERIENCED IN DIAGNOSING AND TREATING RADIATION INJURY, NUCLEAR SAFETY AND WASTE MANAGEMENT SPECIALISTS, PUBLIC RELATIONS OFFICERS, AND MANY OTHERS TO DISCUSS RADIATION ACCIDENTS ON A VERY BROAD BASIS. THE LIST OF SESSION TOPICS INDICATES THE SCOPE OF THE SYMPOSIUM - ORGANIZATION AND PLANNING, EARLY ACCIDENT CONTROL MEASURES, MONITORING AND DOSIMETRY, DECONTAMINATION AND PROTECTIVE MEASURES, MEDICAL MANAGEMENT OF EXPOSED OR CONTAMINATED PERSONS, FUTURE EMPLOYMENT OF OVEREXPOSED PERSONS, AND REVIEW OF SELECTED ACCIDENTS. THE AGENDA INCLUDED 55 PAPERS AND A PANEL DISCUSSION ON SYMPOSIUM PROGRAM HIGHLIGHTS AND RECOMMENDATIONS FOR FURTHER WORK RELATIVE TO RADIATION ACCIDENTS. TWO HUNDRED AND TWELVE PARTICIPANTS FROM 34 COUNTRIES AND 9 INTERNATIONAL ORGANIZATIONS PARTICIPATED IN THE SYMPOSIUM. THE PROCEEDINGS OF THE SYMPOSIUM HAVE BEEN PUBLISHED BY THE IAEA AS REPORT STI/PUB/229.
- 12-5-1-421 LMFBR SAFETY  
ROSE, D.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS  
THIS REVIEW OF LIQUID METAL COOLED FAST BREEDER REACTOR SAFETY EMPHASIZES THE RESEARCH EFFORT AND RECENT RESULTS OF THE MAJOR RESEARCH AND DEVELOPMENT PROGRAMS OF THE U.S. ATOMIC ENERGY COMMISSION AND OF U.S. INDUSTRY. THE SAFETY PROGRAM FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR STRESSES ACCIDENT PREVENTION AND THE EARLY DETECTION AND CONTROL OF POTENTIAL ACCIDENTS. THE MAIN AREAS OF INTEREST INCLUDE THE INVESTIGATION OF FUEL BEHAVIOR AND OF FUEL FAILURE PROPAGATION, THE UNDERSTANDING OF THE PHENOMENA INVOLVED IN REACTIVITY ACCIDENTS AND THE DEVELOPMENT OF TECHNIQUES TO ASSESS THEIR EFFECTS, THE MECHANICAL RESPONSES OF REACTOR SYSTEMS TO ACCIDENTS, AND THE CONTAINMENT OF THE CONSEQUENCES OF POSTULATED ACCIDENTS.
- 12-5-1-433 LIGHT WATER REACTOR SAFETY  
BRIGHT, G. O.  
AEROJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO  
LIGHT WATER REACTOR SAFETY PROBLEMS ARE PRIMARILY ASSOCIATED WITH THE LARGE POWER REACTORS NOW BEING CONSTRUCTED. CONSIDERATION OF THESE COMPLEX SYSTEMS HAS RESULTED IN THE DEVELOPMENT OF A WATER REACTOR SAFETY PROGRAM PLAN, WHICH REPRESENTS AN INDUSTRY WIDE CONSENSUS ON ISSUES, NEEDS, AND PRIORITIES. THE PRINCIPAL ISSUES ARE IDENTIFIED AS DEVELOPMENT AND CONFIRMATION OF ANALYTICAL TECHNIQUES FOR DESIGN AND SAFETY EVALUATION. SPECIFIC AREAS OF GREATEST IMPORTANCE ARE EMERGENCY CORE COOLING CAPABILITY, FUEL FAILURE PHENOMENA UNDER ABNORMAL CONDITIONS, AND DEVELOPMENT OF NEEDED STANDARDS AND QUALITY ASSURANCE PROCEDURES. CURRENT AND PLANNED FUTURE PROGRAMS SHOULD PROVIDE ADEQUATE CAPABILITY FOR SOLUTION OF PROBLEMS THAT CAN BE IDENTIFIED AT PRESENT, BUT SAFETY IS A MOVING TARGET AND, AS REACTOR DESIGN ADVANCES, A CONTINUING PROGRAM IS FORESEEN.
- 12-5-1-438 HIGH SAFETY  
KAPLAN, S. I.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
FOR A HIGH TEMPERATURE GAS COOLED REACTOR (HTGR), THE POSTULATED ACCIDENT MECHANISMS THAT CARRY POPULATION SAFETY SIGNIFICANCE ARE THOSE WHICH EITHER INCREASE THE RELEASABLE FISSION PRODUCT INVENTORY OF THE PRIMARY SYSTEM OR THOSE WHICH RELEASE THE PRIMARY SYSTEM CONTENTS TO THE ENVIRONMENT. NOMINALLY THESE MECHANISMS COMPRISE LOSS OF COOLANT, GRAPHITE OXIDATION, LOSS OF FORCED CIRCULATION OF COOLANT, REACTIVITY EXCURSIONS, AND CORE BLOCKAGE. HOWEVER, THE SPECIFIC MULTIPLE LINES FOR SAFEGUARDING AGAINST ALL THESE ACCIDENT MECHANISMS WHICH ARE POSTULATED FOR A LARGE HTGR REACTOR THE PROBABILITY OF THEIR OCCURRENCE EXTREMELY LOW. SAFETY DIRECTED RESEARCH HAS

PROVIDED A GOOD GENERAL UNDERSTANDING OF THE MAJOR FISSION PRODUCT ESCAPE AND TRANSPORT MECHANISMS, CORE PHYSICS, AND GRAPHITE OXIDATION PHENOMENA, ALTHOUGH MUCH DETAILED EXPERIMENTAL INFORMATION IS STILL NEEDED BEFORE RIGOROUS PREDICTIONS OF COOLANT CHEMISTRY AND FISSION PRODUCT BEHAVIOR FOR NEW DESIGNS BECOME FEASIBLE. FUTURE RESEARCH PATHS WILL BE INFLUENCED BY THE SHIFTS IN RELATIVE IMPORTANCE OF CERTAIN ACCIDENT MECHANISMS AS REACTOR SIZE INCREASES, BY INCREASED PUBLIC PRESSURE TO MINIMIZE ALL RADIOACTIVE RELEASES, AND BY NEW DEVELOPMENTS IN FUEL AND COMPONENT DESIGN.

12-5-2-448

PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY OVERVIEW  
SLATER, H. G.

NIAGARA MOHAWK POWER CORPORATION, SYRACUSE, NEW YORK  
THE RECENT HISTORY OF PUBLIC AND PRESS ATTITUDES TOWARD NUCLEAR POWER AND ITS EFFECT ON THE ENVIRONMENT CAN BE TRACED IN THE RESULTS OF POLLS, PANEL MEETINGS, DEBATES, ETC. ALTHOUGH OPPOSITION IS NOT THE RULE, THE QUICK RESPONSE BY THE NUCLEAR INDUSTRY TO THE ENVIRONMENTALISTS' POSITIONS HAS HELPED TO IMPROVE PUBLIC RELATIONS. SINCE NUCLEAR TECHNOLOGY IS INVOLVED IN THESE COMPLEX PROBLEMS, ITS LEADERS MUST DO ALL THEY CAN TO INFORM THE PUBLIC AND TO RESPOND WITH CANDOR TO IMPORTANT QUESTIONS SO THAT MUTUAL TRUST AND UNDERSTANDING MAY PREVAIL. SUCH OPENNESS MAY AT FIRST SEEM SELF-DEFEATING, BUT IN THE LONG RUN IT WILL SUCCEED.

12-5-2-456

THE OUTCRY OVER EXPOSURE GUIDELINES  
AUXIER, J. A.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THERE HAS BEEN A GROWING PUBLIC CONCERN ABOUT RADIATION POLLUTION OF THE ENVIRONMENT OVER THE PAST FEW YEARS. ALSO, THE PUBLIC NEWS MEDIA HAVE GIVEN INCREASED COVERAGE TO INDIVIDUALS CRITICAL OF THE RADIATION EXPOSURE GUIDES AND STANDARDS RECOMMENDED BY THE FEDERAL RADIATION COUNCIL AND OTHER NATIONAL AND INTERNATIONAL COMMITTEES AND COUNCILS. THE RECOMMENDATIONS OF THE FEDERAL RADIATION COUNCIL ARE THOSE WITH WHICH THE ATOMIC ENERGY COMMISSION AND OTHER FEDERAL AGENCIES MUST COMPLY. THIS ARTICLE IS INTENDED TO GIVE AN OBJECTIVE VIEW OF SOME OF THE MANY PROBLEMS, HYPOTHESES, AND ASSUMPTIONS THAT UNDERLIE THE POSITIONS OF THOSE CRITICAL OF THE RADIATION EXPOSURE STANDARDS AND GUIDELINES, AS WELL AS THOSE WHO MAINTAIN STADNCHLY THAT THE RECOMMENDED DOSE LEVELS ARE ADEQUATELY LOW. IT IS CONCLUDED HERE, AS HAS BEEN DONE BY THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS, THAT THERE IS NO NEED TO ADJUST THE GUIDELINES AT PRESENT. CURRENT CONTAMINATION LEVELS ARE SO LOW, RELATIVE TO THE GUIDELINES, THAT EXPOSURE LEVELS WILL NOT REACH 10 PERCENT OF THE RECOMMENDED GUIDELINE LIMITS DURING THE NEXT FEW DECADES. CONSEQUENTLY, EVEN IF FUTURE RESEARCH INDICATED A NEED FOR THE FULL 10-FOLD REDUCTION RECOMMENDED BY THE CRITICS, THE AVERAGE POPULATION DOSE WOULD STILL BE BELOW REDUCED GUIDELINES.

12-5-3-461

COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS  
WINTON, M. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
MANY COMPUTER PROGRAMS HAVE BEEN DEVELOPED FOR USE IN VARIOUS ASPECTS OF NUCLEAR ACCIDENT ANALYSIS. THE NUCLEAR SAFETY INFORMATION CENTER HAS SEPARATED OVER 200 OF THESE CODES INTO 15 GROUPS AND TABULATED THEM. THE RESULTING TABLE GIVES NAME OF CODE, MACHINE ON WHICH IT IS OPERABLE, ITS LANGUAGE, CORPORATE AUTHOR, A STATEMENT OF WHAT THE CODE DOES, A REFERENCE CITATION, AND DATE OF THE REFERENCE. AN OUTLINE OF THE ANALYSIS OF A LOSS OF COOLANT ACCIDENT IS GIVEN, AND CODES THAT MIGHT BE USED IN THE ANALYSIS ARE BRIEFLY DISCUSSED. SEVERAL COMPARISONS OF SIMILAR CODES ARE CITED, AND SOME OF THE RESULTS ARE DISCUSSED. IN ADDITION, THERE IS NOTATION OF THOSE CODES ON WHICH INFORMATION MAY BE OBTAINED FROM THE ARGONNE CODE CENTER, THE EUROPEAN NUCLEAR ENERGY AGENCY (ENEA) LIBRARY AT ISPRA, AND THE RADIATION SHIELDING INFORMATION CENTER.

12-5-3-487

FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR ACCIDENTS  
BITTENHOUSE, P. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE STATUS OF RESEARCH AND TESTING FOR IDENTIFYING THE MODES OF FUEL ROD FAILURE THAT MAY RESULT FROM A LOSS OF COOLANT ACCIDENT IN A LIGHT WATER COOLED REACTOR AND THE INFLUENCE OF SUCH FAILURES ON THE EFFICIENCY AND EFFECTIVENESS OF EMERGENCY COOLING ARE REVIEWED. SUBJECTS COVERED INCLUDE DEFORMATION AND RUPTURE OF ZIRCALOY CLADDING OF FUEL RODS, COOLANT CHANNEL BLOCKAGE RESULTING FROM THIS MODE OF FUEL ROD FAILURE, AND EMBRITTLEMENT OF CLADDING BY REACTION WITH STEAM. THE EFFECTS OF ALL THESE FACTORS ON THE INTEGRITY OF THE REACTOR CORE AND ON THE ABILITY TO COOL THE CORE ARE DISCUSSED.

12-5-4-496

RELIABILITY ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY  
RUBEL, P.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
RELIABILITY ENGINEERING SEEKS DELIBERATELY TO INCREASE THE LIKELIHOOD THAT DEVICES OR SYSTEMS WILL FUNCTION AS INTENDED. TO THIS END, ANALYTICAL TECHNIQUES ARE ROUTINELY APPLIED IN FIELDS SUCH AS AEROSPACE IN WAYS THAT GIVE NATIONAL DIRECTION TO THE VARIOUS QUALITY ASSURANCE ACTIVITIES. A RECENT SURVEY

OF SIMILAR APPLICATIONS TO ENHANCE REACTOR SAFETY REVEALED THAT, ALTHOUGH QUALITATIVE ANALYSIS METHODS HAVE BEEN ADOPTED WIDELY, PROBABILISTIC MODELING AND RISK FORECASTING HAVE BEEN SOMEWHAT RESTRICTED BY LACK OF ADEQUATE SUPPORTING INFORMATION. PROBABILISTIC ANALYSIS USE IS EXPANDING, HOWEVER, AS CURRENT EFFORTS GRADUALLY OVERCOME THE INFORMATION PROBLEM. MEANWHILE, QUALITY ASSURANCE HAS BENEFITED FROM THE INSIGHT PROVIDED BY THE PRELIMINARY RISK EVALUATION STUDIES.

- 12-5-4-499 REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE  
HAGEN, E. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE AVERAGE AVAILABILITY OF FIRST-GENERATION NUCLEAR POWER REACTORS TO PRODUCE UNINTERRUPTIBLY A SUPPLY OF THERMAL ENERGY WAS DETERMINED TO BE 83.4 PERCENT FOR SEVEN COMMERCIALY OPERATED ELECTRICITY-GENERATING STATIONS BY REVIEWING THE STATION OPERATING REPORTS FOR A 3-YEAR PERIOD. THE SAFEST NUCLEAR POWER REACTOR IS ONE THAT IS IN NORMAL STEADY-STATE OPERATION, AND THEREFORE IT WAS PERTINENT TO DETERMINE THE CAUSES OF ABNORMAL OPERATION OR UNSCHEDULED SHUTDOWN. OPERATIONAL DEVIATIONS AND UNPLANNED STATION SHUTDOWNS WERE ANALYZED AND CATEGORIZED INTO THOSE RELATED TO HEAT TRANSFER SYSTEMS, INSTRUMENTATION AND CONTROLS, AND THE ELECTRIC TURBINE GENERATOR POWER SYSTEM. THE CENTRAL PROBLEM AREAS WERE FOUND TO BE LEAKS IN THE HEAT TRANSFER SYSTEM, DIFFICULTIES WITH THE CONTROL ROD DRIVES IN THE PRIMARY SYSTEM, AND BOTH LEAKS AND TURBINE CONTROLS IN THE SECONDARY PLANT. FROM THE DATA AVAILABLE A FIGURE OF MERIT WAS PRODUCED TO EVALUATE THE UNSCHEDULED SHUTDOWNS AND ALSO TO GIVE A COMPARATIVE EVALUATION OF STATION SERVICE RELIABILITY FOR USE OF UTILITY OPERATORS.
- 12-5-5-516 REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION PRODUCT REMOVAL  
HOW, T. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
CONTAINMENT BUILDING SPRAY SYSTEMS AS FISSION PRODUCT REMOVAL DEVICES ARE BECOMING WIDESPREAD IN PRESSURIZED WATER REACTOR DESIGN, AND THE AEC HAS BEEN SPONSORING A RESEARCH PROGRAM TO INVESTIGATE THE APPLICABILITY OF THESE SYSTEMS AS ENGINEERED SAFETY FEATURES. THE OAK RIDGE NATIONAL LABORATORY HAS COORDINATED THE PROGRAM FOR THE AEC AND MAINTAINED LIAISON BETWEEN COMMISSION SPONSORED LABORATORIES AND NUCLEAR INDUSTRY. THREE SPRAY SOLUTIONS ARE PRESENTLY IN USE OR BEING SERIOUSLY CONSIDERED BY PLANT DESIGNERS. MOLECULAR IODINE REMOVAL BY THESE SPRAYS IS VERY EFFECTIVE, AND DECONTAMINATION FACTORS RANGING FROM 20 AND 1000 MAY BE OBTAINED, DEPENDING ON THE SOLUTION SELECTED. THE EXPLOSION HAZARD FROM GENERATION OF RADIOLYTIC HYDROGEN, FIRST IDENTIFIED IN THIS PROGRAM IN 1967, CONTINUES TO REQUIRE SERIOUS CONSIDERATION IN PLANT DESIGN.
- 12-5-5-523 FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM  
WITT, F. J. + WHITMAN, G. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM IS ONE OF THE MAJOR NUCLEAR PRESSURE VESSEL SAFETY RESEARCH EFFORTS SPONSORED BY THE U.S. ATOMIC ENERGY COMMISSION. THE SCOPE OF THIS INVESTIGATION COVERS METALLURGY, CHEMISTRY, MATERIAL PROPERTIES, INSPECTION, ANALYTICAL AND EXPERIMENTAL STRESS AND STRAIN ANALYSES, ENVIRONMENTAL EFFECTS, FRACTURE MECHANICS, AND THE GENERAL AREA OF FRACTURE BEHAVIOR. IN THIS ARTICLE, HOWEVER, THE DISCUSSION IS LIMITED MAINLY TO CONSIDERATIONS OF HOW THICKNESS AFFECTS THE FRACTURE BEHAVIOR OF STEELS AS MANIFESTED IN DYNAMIC TEAR TEST SPECIMENS, WIL-DOCTILITY TRANSITION DROPWEIGHT SPECIMENS, COMPACT TENSION SPECIMENS, AND FLAWED TENSILE SPECIMENS. TEST RESULTS HAVE DEMONSTRATED A SIGNIFICANT INCREASE IN TOUGHNESS LEVELS AS A FUNCTION OF TEMPERATURE. SIMILAR BEHAVIOR IS INDICATED TO OCCUR AFTER THE STEEL IS SUBJECTED TO HIGH FAST NEUTRON FLUENCES, ALTHOUGH THERE IS A SIGNIFICANT INCREASE IN THE TEMPERATURE AT WHICH THE MAJOR PORTION OF THE CHANGE OCCURS. IN ADDITION, A PROPOSED METHOD OF RELATING FLAW SIZE AND NOMINAL STRESS (LOAD) AS A FUNCTION OF TEMPERATURE FOR FRANGIBLE, TRANSITIONAL, AND TOUGH BEHAVIORS HAS BEEN SHOWN TO HAVE A POTENTIAL FOR CALCULATING QUANTITATIVE SAFETY MARGINS IN REACTOR PRESSURE VESSELS.
- 12-5-6-530 SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITING  
PELLETIER, C. A.  
HEALTH SERVICES LABORATORY, IDAHO FALLS, IDAHO  
THE FIFTH ANNUAL MIDYEAR SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY WAS HELD IN IDAHO FALLS, IDAHO, ON NOV. 3-6, 1970. FORTY-TWO PAPERS ON 'HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITING' WERE GIVEN IN SESSIONS DEALING WITH GENERAL SITE-SELECTION CRITERIA FOR NUCLEAR POWER REACTORS, SITING EVALUATIONS FOR LARGE ACCELERATORS, FUEL, COOLANT, AND FISSION PRODUCT INTERACTIONS, EVALUATION OF ENVIRONMENTAL CONTAMINATION AROUND NUCLEAR FACILITIES, BEHAVIOR OF AIRBORNE RADIOACTIVITY, RADIONUCLIDES IN BIOLOGICAL SYSTEMS, COMPARISON OF HAZARDS FROM INTERNAL CONTAMINATION, RADIATION STANDARDS, AND PUBLIC RELATIONS. RAPPORTEUR SESSIONS WERE HELD ON THE ENVIRONMENTAL IMPACT OF OPERATING POWER PLANTS AND FUEL REPROCESSING PLANTS AND ON DIRECT RADIATION FROM CLOUDS.

- 12-5-7-538 DRESDEN 2 INCIDENT OF JUNE-5, 1970  
CAGLE, C. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
ON JUNE 5, 1970, WHILE DRESDEN UNIT 2 (A SECOND GENERATION BOILING WATER REACTOR) WAS UNDERGOING POWER TESTING AND WAS OPERATING AT APPROXIMATELY 75 PERCENT POWER (1875 MW(T), 623 MW(E)), A SPUROUS SIGNAL IN THE REACTOR PRESSURE CONTROL SYSTEM ALTERED THE STEAM FLOW TO THE TURBINE AND CAUSED A TURBINE TRIP FOLLOWED BY A REACTOR SCRAM. SUBSEQUENT ERRATIC WATER LEVEL AND PRESSURE CONTROL IN THE REACTOR VESSEL, COMPOUNDED BY A STUCK INDICATOR PEN ON A WATER LEVEL MONITOR - RECORDER AND INABILITY OF THE ISOLATION CONDENSER TO FUNCTION AS NEEDED, LED TO DISCHARGE OF STEAM AND WATER THROUGH SAFETY VALVES INTO THE REACTOR DRY WELL. ELECTRIC CABLES WERE DAMAGED, AND ELECTRIC MOTORS DEVELOPED LOW RESISTANCE PROBLEMS. NO SIGNIFICANT AMOUNT OF RADIOACTIVE CONTAMINATION WAS DISCHARGED TO THE ENVIRONMENT. THERE WAS NO PRESSURE DAMAGE OF THE REACTOR VESSEL OR THE DRY WELL CONTAINMENT WALLS. RECOVERY INCLUDED REPLACING SOME ELECTRIC CABLES WITH IMPROVED CABLES HAVING HIGHER TEMPERATURE RATINGS, REROUTING OTHER ELECTRIC CABLES, DRYING ELECTRIC MOTORS, REORIENTING THE DISCHARGE DIRECTION OF SAFETY VALVES, REVISING THE REACTOR PRESSURE CONTROL SYSTEM, IMPROVING THE CAPABILITY OF THE ISOLATION CONDENSER, AND REVISING OPERATING AND EMERGENCY PROCEDURES. THE REACTOR REMAINED SHUT DOWN UNTIL AUG. 8, 1970. TWO TO 3 WEEKS OF THIS DOWNTIME WAS ASCRIBED TO REFUELING.
- 12-6-1-549 QUALITY ASSURANCE STANDARDS AND PRACTICES  
LANGSTON, M. E.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
THE U. S. ATOMIC ENERGY COMMISSION HAS BEEN TAKING MANY POSITIVE STRENGTHENING ACTIONS TO ESTABLISH AND ENFORCE A SYSTEMATIC, DISCIPLINED APPROACH TO THE ASSURANCE OF QUALITY IN ADVANCED REACTORS AND TEST FACILITIES TO PROVIDE FOR SAFE, RELIABLE, AND ECONOMIC OPERATION IN A TIMELY AND PREDICTABLE MANNER. THIS ARTICLE DESCRIBES SOME OF THESE STRENGTHENING ACTIONS DIRECTED TOWARD THE DEVELOPMENT AND APPLICATION OF QUALITY ASSURANCE STANDARDS AND PRACTICES FOR ADVANCED REACTOR DEVELOPMENT AND TECHNOLOGY PROGRAMS. THIS ARTICLE ALSO DESCRIBES THE ASSISTANCE RENDERED TO THE ANSI SUBCOMMITTEE N45-3 IN THE PREPARATION OF INDUSTRY STANDARDS.
- 12-6-1-553 CASKS FOR IRRADIATED FUEL - A LOOK AT THE CASK DESIGNERS GUIDE  
LANGHAAR, J. W.  
E. I. DU PONT DE NEMOURS AND COMPANY, WILMINGTON, DELAWARE  
SHIPPING CONTAINERS FOR RADIOACTIVE MATERIALS IN QUANTITIES AND CONCENTRATIONS ABOVE SOME BATHER LOW LIMITS ARE REQUIRED BY FEDERAL REGULATION TO MEET CERTAIN PERFORMANCE CRITERIA UNDER SPECIFIED ENVIRONMENTAL CONDITIONS, INCLUDING A HYPOTHETICAL ACCIDENT. THE THICKLY SHIELDED CONTAINERS FOR IRRADIATED FUEL AND OTHER STRONG GAMMA EMITTERS REQUIRE RIGOROUS DESIGN AND ANALYSIS TO ASSURE RETENTION OF SHIELDING AND ADEQUATE HEAT REMOVAL. MUCH EFFORT HAS BEEN DEVOTED DURING THE PAST 10 YEARS TO DESIGNING CASKS TO MEET THESE REQUIREMENTS AND TO DEVELOPING PROCEDURES TO DEMONSTRATE COMPLIANCE WITH THE REGULATIONS. THE EMPHASIS HAS BEEN PRIMARILY ON LEAD SHIELDED CASKS, WHICH HAVE BEEN COMMONLY USED IN THE UNITED STATES BECAUSE OF A FAVORABLE BALANCE BETWEEN INVESTMENT AND OPERATING COST. UNDER SOME CONDITIONS, THE GREATER PAYLOAD OR SMALLER SIZE OF A URANIUM SHIELDED CASK JUSTIFIES THE GREATER INVESTMENT. AMONG THE DESIGN CONSIDERATIONS ARE HEAT REMOVAL, CRITICALITY, SHIELDING, STRUCTURAL INTEGRITY UNDER IMPACT AND FIRE CONDITIONS, THERMAL BEHAVIOR IN A FIRE, RESISTANCE TO FRACTURE AT VERY LOW TEMPERATURES, AND ASSURANCE OF PROPER FABRICATION. THESE DESIGN CONSIDERATIONS ARE DISCUSSED IN DETAIL IN THE CASK DESIGNERS GUIDE, USABC REPORT ORNL-NSIC-68, WHICH ALSO DESCRIBES THE METHODS OF ANALYSIS, FABRICATION TECHNIQUES, AND TESTING PROCEDURES FOUND ACCEPTABLE.
- 12-6-2-562 FISSION GAS EFFECTS IN REACTOR FUELS II. ENGINEERING APPLICATIONS  
CARROLL, R. M.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE LITERATURE DEALING WITH THE ENGINEERING EFFECTS OF FISSION GAS BEHAVIOR IN REACTOR FUEL MATERIAL IS QUITE EXTENSIVE. THIS REVIEW COVERS THE PAPERS PUBLISHED FROM 1968 TO 1970. THE 73 PUBLICATIONS CITED AND BRIEFLY SUMMARIZED DEAL PRIMARILY WITH FUEL SWELLING MODELS, HIGH TEMPERATURE EFFECTS, NEW EXPERIMENTAL TECHNIQUES, AND ENGINEERING FOR FISSION GAS RELEASE.
- 12-6-2-569 A SURVEY OF HEAT CONDUCTION COMPUTER PROGRAMS  
SHOKER, W. A.  
BETTS ATOMIC POWER LABORATORY, WEST HIFFLIN, PENNSYLVANIA  
MANY PROBLEMS IN REACTOR ANALYSIS REQUIRE KNOWLEDGE OF THE TEMPERATURE VARIATIONS DURING NORMAL REACTOR TRANSIENTS AND IN ACCIDENT SITUATIONS. IN SOLID BODIES THE HEAT CONDUCTION EQUATION DESCRIBES THERMAL BEHAVIOR. MOST OFTEN A CLOSED-FORM SOLUTION CANNOT BE OBTAINED BECAUSE OF COMPLEX GEOMETRIES AND BOUNDARY CONDITIONS, BUT THESE PROBLEMS MAY BE CONVENIENTLY APPROXIMATED BY NUMERICAL SOLUTIONS OBTAINED ON HIGH-SPEED COMPUTERS. ELEVEN HEAT CONDUCTION PROGRAMS REPORTED IN THE LITERATURE ARE REVIEWED. ALL THESE PROGRAMS APPROXIMATE THE

HEAT CONDUCTION EQUATION IN AT LEAST TWO DIMENSIONS UNDER TRANSIENT AND STEADY-STATE CONDITIONS FOR GENERAL TYPES OF BOUNDARY CONDITIONS. THE COMPARISON OF PROGRAMS INCLUDES CONSIDERATION OF THE METHOD USED TO DESCRIBE GEOMETRY, THE NUMERICAL DIFFERENCING METHOD, THE MAXIMUM ALLOWABLE NUMBER OF NODES, AND THE MANNER OF SPECIFICATION OF BOUNDARY CONDITIONS, MATERIAL PROPERTIES, AND HEAT-GENERATION RATE.

12-6-3-593

SUBCRITICALITY MEASUREMENT IN AN LMFBR  
ACFERMANN, M. J., JR.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
RELIABLE KNOWLEDGE OF THE SUBCRITICALITY STATE OF A NUCLEAR REACTOR AT ALL TIMES DURING SHUTDOWN, COUPLED WITH PROPER ADMINISTRATIVE CONTROL, SHOULD PRECLUDE THE POSSIBILITY OF THAT REACTOR ACCIDENTALLY BECOMING CRITICAL OR SUPERCRITICAL. THIS REVIEW OF THE STATE OF THE ART OF SUBCRITICALITY MEASUREMENT IN THE LMFBR GIVES PARTICULAR ATTENTION TO PODS MEASUREMENT TECHNIQUES - NEUTRON SOURCE MULTIPLICATION, NEUTRON NOISE ANALYSIS, INVERSE KINETICS, AND PULSED NEUTRONS. IT IS CONCLUDED THAT THE NEUTRON SOURCE MULTIPLICATION TECHNIQUE IS THE ONLY METHOD APPLICABLE FOR MEASURING THE SUBCRITICALITY IN AN LMFBR OVER THE FULL RANGE OF SHUTDOWN. PRESENT SUBCRITICALITY MEASUREMENT DEVELOPMENT PROGRAMS ARE REVIEWED, AND FUTURE APPLICATIONS ARE DISCUSSED.

12-6-4-591

KRYPTON - XENON REMOVAL SYSTEMS  
KEILHOLTE, G. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE NEED FOR MORE ELECTRIC POWER AND THE CORRESPONDING INCREASE IN THE NUMBER OF NUCLEAR POWER REACTORS AND FUEL RECOVERY PLANTS MAKE IT DESIRABLE TO HAVE NEAR ZERO RELEASE OF FISSION PRODUCT GASES TO THE ATMOSPHERE. SYSTEMS FOR RETAINING AND STORING RADIOACTIVE XENON AND KRYPTON HAVE BEEN DEVELOPED, AND FOUR OF THE MOST PROMISING METHODS CAPABLE OF FULL SCALE APPLICATION ARE DESCRIBED. CURRENT SYSTEMS INVOLVE ONE OR MORE OF THE FOLLOWING PROCESSES (1) ADSORPTION ON CHARCOAL AT AMBIENT OR LOWER TEMPERATURES, (2) CRYOGENIC DISTILLATION WITHOUT CHARCOAL, (3) SEPARATION BY PERMELECTIVE MEMBRANES, AND (4) SELECTIVE ABSORPTION OF KRYPTON AND XENON IN FLUOROCARBON SOLVENTS.

12-6-5-600

EFFECTS ON ORGANISMS OF ENTRAINMENT IN COOLING WATER - STEPS TOWARD PREDICTABILITY  
COUDANT, C. C.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
MODELS ARE BEING DEVELOPED AT OAK RIDGE NATIONAL LABORATORY AND ELSEWHERE FOR PREDICTING ECOLOGICAL EFFECTS OF THERMAL SHOCKS RECEIVED BY ORGANISMS PASSING THROUGH THERMAL POWER PLANT COOLING SYSTEMS. FOR THESE MODELS WERE DEVELOPED INITIALLY FOR STUDYING DIRECTLY LETHAL EFFECTS, BUT THEY ARE APPLICABLE TO SUCH SUBLETHAL EFFECTS AS EQUILIBRIUM LOSS AND INCREASED SUSCEPTIBILITY TO PREDATION. THESE PREDICTIVE MODELS AND THE BASIC BIOLOGICAL DATA REQUIRED FOR USE OF THEM PROVIDE FOR SELECTION OF LIMITS OF TEMPERATURE ELEVATIONS AND DURATIONS OF EXPOSURE TO WARMED WATER AT POWER PLANTS WHICH WILL PREVENT DETRIMENTAL EFFECTS.

12-6-6-608

FAILURE OF W REACTOR PRIMARY SCRAM SYSTEM  
GALLAGHER, G. R.

U. S. ATOMIC ENERGY COMMISSION, RICHLAND, WASHINGTON  
THE W REACTOR AT HANFORD SCRAMMED FROM AN OPERATING LEVEL OF APPROXIMATELY 450 MW AT 0525 HR, SEPT. 30, 1970. THE REACTOR WAS IN A POWER HOLDING MODE WITH THE PRIMARY LOOP AT EQUILIBRIUM FLOW AND TEMPERATURE. THE SCRAM SIGNAL WAS INITIATED BY SIMULTANEOUS LOW FLOW TRIPS ON SEVERAL PROCESS TUBES. DUE TO A UNIQUE MALFUNCTION, THE ROD SAFETY SYSTEM DID NOT RESPOND TO THE SCRAM SIGNAL. OTHER SCRAM TRIP INSTRUMENTATION RESPONDED AS DESIGNED, AND THE REACTOR WAS SHUT DOWN AND MAINTAINED IN A SAFE CONDITION BY THE BALL SAFETY SYSTEM. NO OVERHEATING OF REACTOR COMPONENTS OCCURRED, AND NO RADIATION WAS RELEASED. THE SHUTDOWN TRANSIENT WAS NORMAL IN ALL RESPECTS. THE LOW FLOW WAS CAUSED BY A PRIMARY PUMP TRIPPING FROM STEAM TURBINE DRIVE SPEED DOWN TO PUMP MOTOR ELECTRIC DRIVE SPEED. THE TURBINE TRIP WAS PRECIPITATED BY ONE OF THE TURBINE CONDENSER CONDENSATE PUMPS LOSING SUCTION BECAUSE OF A PLUGGED SCREEN. THE SAFETY RODS FAILED TO SCRAM DUE TO A COMBINATION OF CIRCUMSTANCES INVOLVING THE NO. 59 ROD ASSIGNMENT SWITCH BEING IN THE OFF POSITION AND THERE BEING FOUR FAILED (SHORTED) DIODES IN THE NO. 59 ROD SCRAM CIRCUIT. THIS COMBINATION OF EVENTS AND THE PARALLEL WIRING CHARACTERISTICS OF THE ROD SAFETY CIRCUIT ALLOWED POWER FROM AN AUXILIARY ELECTRICAL CIRCUIT TO FEED ALL THE ROD SCRAM SOLENOIDS AND THUS KEEP THEM ENERGIZED AFTER THE MAIN SCRAM RELAYS HAD TRIPPED.

12-6-6-615

SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL  
HCCORD, R. V.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
TWENTY-TWO PAPERS AND A PANEL DISCUSSION WERE PRESENTED AT THE SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL. THE PAPERS COVERED ALL ASPECTS OF NUCLEAR REACTOR OPERATOR TRAINING FROM PHILOSOPHY AND OBJECTIVES TO DETAILED TRAINING METHODS.

TWO PAPERS WERE PRESENTED ON THE TRAINING AND LICENSING OF RADIOCHEMICAL PROCESSING PLANT PERSONNEL. SEVERAL PAPERS DISCUSSED PUBLIC RELATIONS AND THE EDUCATION OF THE PUBLIC FOR THE ACCEPTANCE OF NUCLEAR POWER.

- 13-1-1-001 THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE REACTOR LICENSING PROCESS  
BUSH, S. H.  
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) IN THE REACTOR LICENSING PROCESS IS REVIEWED IN THE CONTEXT OF ITS ORIGINAL CHARTER ESTABLISHED BY CONGRESS. SPECIFICALLY, MEMBERSHIP AND OPERATIONAL PROCEDURES ARE REVIEWED WITH RESPECT TO SPECIFIC PROJECTS. AN IMPORTANT ACTIVITY OF THE ACRS IS REVIEW OF GENERIC SAFETY ITEMS AND CODES, STANDARDS, AND CRITERIAL RECOMMENDATIONS AND COMMENTS ARE MADE CONCERNING AREAS WHERE CONTINUING IMPROVEMENTS ARE POSSIBLE IN THE REGULATORY WORK LOAD, EVALUATION OF DESIGN CONCEPTS, AND OPERATION OF THE ACRS.
- 13-1-1-013 SOME EFFECTS OF PUBLIC INTERVENTION ON THE REACTOR LICENSING PROCESS  
BRIGHT, G. O.  
AERODUFT NUCLEAR COMPANY, IDAHO FALLS, IDAHO  
THE ENVIRONMENTAL PROTECTION MOVEMENT, WHICH HAS GROWN SO STRONG OVER THE LAST 2 TO 3 YEARS, HAS GREATLY AFFECTED THE CIVILIAN POWER REACTOR LICENSING PROCESS. INTERVENTION IN PUBLIC LICENSING HEARINGS AND COURT ACTION HAVE BOTH BEEN WIDELY EMPLOYED, WITH A NET RESULT, IN MANY CASES, OF SIGNIFICANTLY INCREASING THE TIME REQUIRED TO OBTAIN BOTH CONSTRUCTION AND OPERATING LICENSES. IT IS CONCLUDED THAT A STRONG EFFORT MUST BE MADE BY INDUSTRY IF PROTRACTED DELAYS ARE TO BE AVOIDED.
- 13-1-2-022 THE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON RISK PROBABILITY  
RELEIS, M. + ERMANN, R. C.  
UNIVERSITY OF CALIFORNIA AT LOS ANGELES, LOS ANGELES, CALIFORNIA  
EXAMINATION OF THE ORIGINALLY PROPOSED FARMER LIMIT LINE CRITERION FOR NUCLEAR PLANTS LED TO A TOTAL INDIVIDUAL MORTALITY RISK THAT IS FAIRLY HIGH WITH RESPECT TO OTHER RECORDED RISKS. FOR EXAMPLE, IN THE CASE OF AN EQUAL WIND DIRECTION PROBABILITY OF 1/12 (ANY 30 DEGREE VECTOR OVER A 360 DEGREE CIRCLE), THE TOTAL RISK FROM AN ACCIDENTAL RELEASE AT THE PLANT WAS ONLY  $3.9 \times 10^{-6}$  BUT WAS STILL 34 TIMES THAT CAUSED BY LIGHTNING. A NEW LOCATION FOR THE LIMIT LINE WAS THEREFORE DEDUCED THAT WOULD SATISFY BOTH FARMER'S PROBABILISTIC SAFETY ANALYSIS PHILOSOPHY AND AT THE SAME TIME LIMIT THE ADDED RISK TO THE INDIVIDUALS LIVING AT THE EXCLUSION RADII TO A VERY LOW VALUE. FINALLY, THE PROBABILISTIC SAFETY ANALYSES OF THREE EXISTING NUCLEAR PLANTS ARE COMPARED WITH THE ORIGINAL AND MODIFIED LIMIT LINES. HENCE ONE CAN OBSERVE A CORRESPONDENCE BETWEEN CALCULATED PLANT RELEASE DATA AND THE LIMIT LINE CONCEPT. WE THUS CONCLUDE THAT AN INTEGRATED SAFETY ANALYSIS BASED ON THE LIMIT LINE CONCEPT COULD PROVIDE THE NUCLEAR INDUSTRY WITH AN ADEQUATE REACTOR SITING TECHNIQUE.
- 13-1-3-029 THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCIETY OF AMERICA  
HAGEN, E. W. + PRODE, G. E. + BASSETT, T. G.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE - NIAGARA MOHAWK POWER CORPORATION, SYRACUSE, NEW YORK  
THE ELECTRIC POWER GENERATION SEGMENT OF THE NUCLEAR FIELD IS INCREASING IN SIZE AND IN IMPORTANCE AND, THEREFORE, IN ITS RESPONSIBILITIES AND NEED TO BE HEARD. SOME OF THIS INDUSTRY'S CONCERNS ABOUT STANDARDS, RELIABILITY, COMMUNICATIONS, AND INSTRUMENTATION AND CONTROL NEEDS WERE EXPRESSED AT THE INSTRUMENT SOCIETY OF AMERICA'S 14TH POWER INSTRUMENTATION SYMPOSIUM. MORE STANDARDS ARE STILL NEEDED, AND TO RESOLVE SOME OF THE MAJOR SAFETY PROBLEMS NOW BEFORE THE INDUSTRY, SEVERAL IMPORTANT INSTRUMENTATION AND CONTROL OBJECTIVES MUST BE MET. ALSO COMMUNICATION BETWEEN THE ENGINEERING DESIGN AND THE OPERATING GROUPS COULD BE IMPROVED.
- 13-1-4-037 CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER REACTORS  
FIRST, M. W.  
HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASSACHUSETTS  
ALTHOUGH LIQUID METAL COOLED FAST BREEDER REACTORS ARE DESIGNED TO AVOID SODIUM RELEASES, SOUND PUBLIC HEALTH PRACTICE DEMANDS THAT THE NATURE AND POTENTIAL CONSEQUENCES OF EVERY CONCEIVABLE TYPE OF RELEASE BE EVALUATED. IN THIS ARTICLE A TYPICAL REACTOR HANDLING LARGE VOLUMES OF HOT SODIUM IS ANALYZED CAREFULLY TO DETERMINE WHERE ACCIDENTAL LEAKS AND SPILLS MAY OCCUR. STANDBY CONTROL METHODS ARE RECOMMENDED TO PREVENT SPREAD OF AIRBORNE SODIUM AND ITS REACTION PRODUCTS, TO REDUCE REACTOR SHUTDOWN TIME, AND TO MINIMIZE CLEANUP COSTS. CRITICAL FACTORS AFFECTING THE DESIGN OF ENGINEERED CONTROLS FOR THE CONTAINMENT OF ACCIDENTAL SODIUM RELEASES WERE TEMPERATURE OF THE METAL, OXYGEN CONCENTRATION AND SIZE OF THE SPACE INTO WHICH THE SPILL OF LEAK OCCURS, RATE OF SODIUM ESCAPE, AND THE AMOUNT OF SODIUM LIKELY TO BE RELEASED BEFORE REMEDIAL MEASURES CAN BE TAKEN TO STOP IT.

- 13-1-5-047 FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACILITIES  
SCOTT, R. L. \* HARLEY, P. R.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THIRTY-THREE INCIDENTS ARE TABULATED CONCERNING PROBLEMS ENCOUNTERED WITH BOLTS, SCREWS, NUTS, AND THREADED FITTINGS, ALL OF WHICH SHOULD BE OF INTEREST TO BOTH DESIGNERS AND OPERATORS. THESE INCIDENTS HAVE REQUIRED APPROXIMATELY 70 MONTHS OF ADDITIONAL REACTOR DOWNTIME. AT ONE FACILITY AN ESTIMATED EXPENDITURE OF \$10,000 WAS CAUSED BY THE FAILURE OF A 1-IN. THREADED STRAINER PLUG. THE THREE MAJOR TYPES OF FAILURES - CORROSION, FATIGUE, AND GALLING - ARE DISCUSSED.
- 13-1-5-054 ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE STRENGTH  
CLACK, R. W. \* ECKHOFF, W. D.  
KANSAS STATE UNIVERSITY, MANHATTAN, KANSAS  
ASSUMING EXTENDED STEADY-STATE REACTOR OPERATION, USEFUL APPROXIMATIONS OF FISSION PRODUCT SOURCE STRENGTH (IN CURIES) CAN BE MADE BY MULTIPLYING THE THERMAL-ENERGY RELEASE (IN MWD) BY 100 AND DIVIDING BY THE TIME INTERVAL FROM SHUTDOWN (IN YEARS).
- 13-2-1-099 THE ASME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR REACTORS  
MCGUFFEY, J. R.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
TO ENHANCE THE SAFETY AND RELIABILITY OF VESSELS, PUMPS, VALVES, AND PIPING USED IN NUCLEAR POWER SYSTEMS, THE ASME BOILER AND PRESSURE VESSEL CODE HAS SET FORTH SPECIFIC QUALITY-ASSURANCE (QA) RESPONSIBILITIES FOR THE OWNER, THE MANUFACTURERS, THE INSTALLERS, THE ASME, AND AUTHORIZED INSPECTION AGENCIES. IN PARTICULAR, THE MANUFACTURERS AND THE INSTALLERS OF SUCH COMPONENTS MUST OPERATE UNDER A CONTROLLED MANUFACTURING SYSTEM AND UNDER DETAILED QA PROGRAMS. THIS APPROACH TO CONTROLLING THE DESIGN, FABRICATION, AND INSTALLATION OF NUCLEAR COMPONENTS DURING THE PAST 3 YEARS HAS MATERIALLY IMPROVED THE INTEGRITY OF NUCLEAR PRESSURE BOUNDARY AND PRESSURE-CONTAINING SYSTEMS.
- 13-2-1-103 THE IMPACT OF THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS  
SEAGREN, R. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
AN EFFORT IS UNDER WAY TO REVISE AND UPDATE THE IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS. UNDER THE NEW REGULATIONS THE PRESENT SYSTEM OF CLASSIFYING RADIOACTIVE MATERIAL INTO GROUPS ACCORDING TO THE RADIOTOXICITY OF THE RADIONUCLIDE CONCERNED WILL BE DISCONTINUED. INSTEAD, ASSESSMENTS OF THE LIKELY INTAKE OF RADIOACTIVE MATERIAL AFTER SERIOUS DAMAGE TO PACKAGING ARE COMBINED WITH CALCULATED RADIATION DOSES FOR UNIT INTAKE OF SOME 280 RADIONUCLIDES TO DERIVE A THEORETICAL SAFE LIMIT FOR THE RADIOACTIVE CONTENT OF TRANSPORT PACKAGES. ACTIVITY RELEASE RATES FOR PACKAGING UNDER NORMAL CONDITIONS OF TRANSPORT AS WELL AS UNDER ACCIDENT CONDITIONS ARE TO BE BASED ON THESE SAFE LIMITS.
- 13-2-2-107 STRUCTURAL EFFECTS OF CONFINED DYNAMIC LOADS  
BABIP, L. M.  
FORD RESEARCH AND ENGINEERING CENTER, DEARBORN, MICHIGAN  
THIS REVIEW OF MODERN METHODS OF DESIGN AND ANALYSIS IN THE FIELD OF STRUCTURAL EFFECTS OF DYNAMIC LOADS STEMS FROM CURRENT NEEDS TO ENSURE THE CONTAINMENT OF CHEMICAL REACTIONS THAT MAY ACCIDENTALLY OCCUR IN LIQUID METAL HEATED STEAM GENERATORS ASSOCIATED WITH CERTAIN NUCLEAR POWER PLANTS. IT IS RECOMMENDED THAT THE DESIGN OF CYLINDRICAL VESSELS SUBJECTED TO TRANSIENT INTERNAL PRESSURES BE BASED ON THE AMPLITUDE - IMPULSE PLANE REPRESENTATION OF THE DYNAMIC BURSTING CRITERION. METHODS AVAILABLE FOR APPLICATION TO THE PROBLEM UNDER CONSIDERATION ARE DYNAMIC LIMIT ANALYSIS AND FINITE DIFFERENCE ANALYSIS, WITH BRIEF MENTION OF RECENT DEVELOPMENTS IN FINITE ELEMENT METHODS.
- 13-2-2-114 SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR REACTOR PLANTS  
SMITH, C. B. \* MATTHIENEN, B. H.  
UNIVERSITY OF CALIFORNIA, LOS ANGELES, CALIFORNIA  
RESEARCH BEING CONDUCTED TO DETERMINE THE EFFECTS OF EARTHQUAKES ON NUCLEAR POWER PLANTS INCLUDES DYNAMIC TESTS OF FULL-SCALE NUCLEAR POWER PLANTS AND THE DEVELOPMENT OF MATHEMATICAL MODELS OF THE SYSTEM BASED ON EXPERIMENTAL RESULTS. THESE TESTS HAVE BEEN CONDUCTED AT THE UCLA RESEARCH REACTOR, THE EXPERIMENTAL GAS-COOLED REACTOR (EGCR), THE CAROLINAS-VIRGINIA TUBE REACTOR (CVTR), THE FERRIS FAST BREEDER REACTOR, AND THE SAN ONOFRE NUCLEAR GENERATING STATION. EXPERIMENTAL INVESTIGATIONS INCLUDE THE RESPONSE DUE TO AMBIENT EXCITATION (WIND AND NATURAL GROUND VIBRATIONS), FORCED VIBRATIONS USING STRUCTURAL VIBRATORS, FORCED VIBRATIONS USING IMPULSES, FREE VIBRATIONS FROM A LARGE INITIAL DISPLACEMENT ('SNAPBACK' TESTS), AND FORCED VIBRATIONS CAUSED BY EXPLOSIVE BLASTS. THE MAJOR EMPHASIS OF THE WORK IS ON DEVELOPING METHODS FOR EXCITING FULL-SCALE STRUCTURES AT LEVELS COMPARABLE WITH STRONG MOTION EARTHQUAKES AND USING THESE TESTS TO DEVELOP MATHEMATICAL MODELS FOR REACTOR SYSTEMS. CURRENT EFFORT IS CONCENTRATED ON ANALYZING THE RESULTS OF BLAST TESTS. ANALYSIS TO DATE HAS PROVED THE FEASIBILITY OF THE BLAST TECHNIQUES AND IS GIVING INSIGHT INTO THE NONLINEARITIES ASSOCIATED WITH HIGH

LEVEL RESPONSE. EXCELLENT AGREEMENT WAS OBTAINED IN COMPARISONS OF FORCED VIBRATION TEST DATA AND BLAST DATA. NEVERTHELESS, NONLINEAR BEHAVIOR OF NUCLEAR PLANT COMPONENTS IS STILL NOT WELL UNDERSTOOD, AND ADDITIONAL WORK IS REQUIRED TO DEFINE THE MECHANISMS THAT GIVE RISE TO NONLINEARITIES.

- 13-2-4-122 PIPE RUPTURE STUDY - 1971  
VANDENBERG, S. R.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA  
THE PIPE RUPTURE STUDY IS CONCERNED WITH EXTENDING THE UNDERSTANDING OF FAILURE CAUSING MECHANISMS AND IMPROVING THE CAPABILITY FOR EVALUATING REACTOR PIPING SYSTEMS TO MINIMIZE THE PROBABILITY OF FAILURES. FOLLOWING A DETAILED REVIEW TO DETERMINE THE EFFORT MOST NEEDED TO IMPROVE NUCLEAR SYSTEM PIPING (PHASE I), ANALYTICAL AND EXPERIMENTAL EFFORTS (PHASE II) WERE STARTED IN 1965. THIS STATUS REPORT SUMMARIZES THE ACCOMPLISHMENTS OF A BROAD PROGRAM IN (1) AT-REACTOR TESTS OF THE EFFECT OF PRIMARY COOLANT ENVIRONMENT ON THE FATIGUE BEHAVIOR OF PIPING STEELS, (2) FATIGUE STUDIES THROUGH BOTH BENCH-SCALE AND LARGE COMPONENT TESTS, (3) FRACTURE MECHANICS, (4) SOLUTION OF PROBLEMS IN STRESS ANALYSIS, AND (5) FAILURE PROBABILITY STUDY OF ACTUAL REACTOR PIPING SYSTEMS. BROADLY, THE RESULTS OBTAINED SHOW THAT PRIMARY PIPING SYSTEMS ARE VERY SAFE, THAT SUCH PIPING IS CONSERVATIVELY DESIGNED (TO B31.7 NUCLEAR PIPING CODE), AND THAT THE MATERIALS, PARTICULARLY IN LOW CYCLE FATIGUE, ARE SUCH THAT CONSIDERABLE LEFWAY EXISTS ON THE SIDE OF SAFETY, I. E., THE NUMBER OF STRESS CYCLES TO INITIATE AND GROW CRACKS THROUGH PIPE WALLS ARE AT LEAST AN ORDER OF MAGNITUDE GREATER THAN THE NUMBER OF CYCLES IN PLANT SERVICE LIFETIMES OF 40 YEARS.
- 13-2-5-130 ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT  
KNOX, J. B. + PETERSON, K. R.  
LAWRENCE RADIATION LABORATORY, LIVERMORE, CALIFORNIA  
THE RADIOACTIVE DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A TYPICAL NUCLEAR FUEL REPROCESSING PLANT IS ESTIMATED FOR VARIOUS DISTANCES AND TIMES, INCLUDING THE GLOBAL EQUILIBRIUM POPULATION DOSE RESULTING FROM A CONSTANT RATE OF EMISSION. THE TOTAL POPULATION DOSE AT ANY LOCATION DEPENDS ON BOTH THE PROXIMITY TO THE PLANT AND THE POPULATION OF THE AREA AFFECTED. THE LARGEST POPULATION DOSE OCCURS IN ASIA, PRINCIPALLY BECAUSE OF ITS DENSE POPULATION, BUT THIS IS A SMALL FRACTION OF THAT RECEIVED FROM NATURAL RADIOACTIVITY. THE NEXT LARGEST DOSE IS WITHIN 1000 KM OF THE SOURCE, AND THE SMALLEST DOSES ARE IN POLAR AND EQUATORIAL LATITUDES.
- 13-3-0-181 NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA CONFERENCE  
NUCLEAR SAFETY EDITORIAL STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE NUCLEAR SAFETY ASPECTS OF THE FOURTH INTERNATIONAL CONFERENCE ON THE PEACEFUL USES OF ATOMIC ENERGY, HELD AT GENEVA IN SEPTEMBER 1971, DEALT WITH ENVIRONMENTAL ASPECTS AND PUBLIC ACCEPTANCE, INSURANCE AND REGULATION, POWER PLANT SAFETY, WASTE MANAGEMENT, HEALTH PHYSICS AND RADIATION PROTECTION, AND NUCLEAR PLANT PERFORMANCE. THE AUTHORS OF THE MORE THAN 100 PAPERS GIVEN AT THESE SESSIONS, REPRESENTING MOST OF THE WORLD'S NATIONS WITH NUCLEAR POWER CAPABILITY, WERE GENERALLY SANGUINE IN THEIR PRESENTATIONS AND SEEMED TO FEEL THAT CONTINUING EXPERIENCE AND ADVANCING TECHNOLOGY WOULD EVENTUALLY SOLVE MOST IF NOT ALL THE PROBLEMS CURRENTLY ASSOCIATED WITH NUCLEAR POWER. RESEARCH AND DEVELOPMENT MUST CONTINUE, HOWEVER, IN ORDER TO MAKE POSSIBLE THE PROMISE OF ABUNDANT POWER TO THE NEXT CENTURY'S TEENING MILLIONS WHO WOULD OTHERWISE FACE ENERGY STARVATION.
- 13-3-1-209 BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE COURTS  
NICHOLS, B. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
ALTHOUGH ENVIRONMENTAL LEGISLATION RESULTING FROM PUBLIC CONCERN DATES BACK TO THE RIVERS AND HARBORS ACT OF 1899, ONLY RECENTLY HAS THE MOMENTUM OF CONCERN RESULTED IN FEDERAL LEGISLATION THAT FORMALLY WEIGHS THE COSTS OF ENVIRONMENTAL IMPACT AGAINST THE ECONOMIC AND TECHNICAL BENEFITS TO BE GAINED. THE NATIONAL ENVIRONMENTAL POLICY ACT OF 1969 (NEPA) NOT ONLY STRENGTHENS PREVIOUS LEGISLATION BUT, IN ADDITION, REQUIRES A BALANCING OF THE ENVIRONMENTAL IMPACT AND THE TECHNICAL AND ECONOMIC BENEFITS TO THE PUBLIC AS A WHOLE. THE INTERPRETATION OF NEPA BY THE U.S. COURT OF APPEALS FOR THE DISTRICT OF COLUMBIA CIRCUIT IN THE CALVERT CLIFFS CASE HAS HAD CONSIDERABLE IMPACT ON BOTH THE U.S. ATOMIC ENERGY COMMISSION (AEC) AND THE ELECTRIC-POWER INDUSTRY. ALTHOUGH THE BURDEN ON THE COMMISSION AND INDUSTRY MAY SEEM CUMBERSOME, IT IS CONCEIVABLE THAT THE THOROUGH REVIEW OF ALL ASPECTS OF PLANNED PROJECTS REQUIRED BY NEPA MAY RESULT IN A TWOFOLD BENEFIT - THE REDUCTION OF BOTH ENVIRONMENTAL IMPACT AND ECONOMIC OUTLAY AT FUTURE NUCLEAR POWER PLANTS. THIS ARTICLE DISCUSSES THE IMPLICATIONS FOR THE NUCLEAR POWER INDUSTRY OF ENVIRONMENTAL LEGISLATION AND THE DECISION OF THE COURT IN THE CALVERT CLIFFS CASE.



- 13-3-1-216 NATIONAL CONFERENCE ON WASTE HEAT UTILIZATION  
MORGAN, J. G.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE CONFERENCE ON WASTE HEAT UTILIZATION WAS HELD IN GATLINBURG, TENN., OCT. 27-29, 1971. AMONG THE TOPICS CONSIDERED WERE TECHNICAL STATUS FOR HEAT UTILIZATION, DEMONSTRATION PROJECTS, MARKETING AND ECONOMICS, PROJECTED APPLICATIONS, SITE SELECTION, AND WATER LAW AND WATER REGULATIONS. ALTHOUGH AT PRESENT THE FRACTION OF WASTE HEAT EFFECTIVELY USED MAY BE SMALL, THE CONFERENCE PROJECTED A SENSE OF URGENCY FOR PROMPT PLANNING AND ACTION. HOWEVER, IT WAS ALSO POINTED OUT THAT REGULATION CONSTRAINTS AND UNCERTAINTIES ACT AS DETERRENENTS TO FINANCIAL INVESTMENT FROM PRIVATE SECTORS.
- 13-3-3-220 DETECTION OF FAILED FUEL ELEMENTS  
GROOS, E.  
COMMISSION OF THE EUROPEAN COMMUNITIES, KERNFORSCHUNGSANLAGE, JULICH, GERMANY  
SAFETY, VERSATILITY, AND ECONOMY OF A HIGH TEMPERATURE PEBBLE-BED REACTOR COULD BE IMPROVED IF FUEL ELEMENTS WITH UNDESIRABLE HIGH FISSION PRODUCT RELEASE WERE REMOVED FROM THE CORE LOADING. HOWEVER, MEASUREMENTS FOR DETECTING THESE LEAKY ELEMENTS CAN ONLY BE PERFORMED DURING THE INTERCYCLING PERIODS WHEN A FUEL ELEMENT IS OUT OF THE CORE. THE COMMON DIFFICULTY ENCOUNTERED IN THE THREE DETECTION METHODS INVESTIGATED WAS THE SHORT TIME AVAILABILITY FOR MEASUREMENTS, 7 TO 24 SEC, DEPENDING ON THE RATE OF CIRCULATION OF THE FUEL ELEMENTS. A FISSION GAS ANNEALING METHOD HAS PROVED APPLICABLE, AND A TECHNIQUE USING A LASER BEAM FOR REMOVING SMALL AMOUNTS OF GRAPHITE FOR BETA COUNTING IS STILL BEING EXAMINED.
- 13-3-5-225 THE 1971 TRITIUM SYMPOSIUM AT LAS VEGAS  
BARTON, C. J. + BOTLER, H. M. + CUMMING, R. E.  
ROHBER, P. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
A 'TRITIUM SYMPOSIUM' SPONSORED BY THE WESTERN ENVIRONMENTAL RESEARCH LABORATORY OF THE ENVIRONMENTAL PROTECTION AGENCY AND THE UNIVERSITY OF NEVADA AT LAS VEGAS WAS HELD IN LAS VEGAS AUG. 30 TO SEPT. 2, 1971. APPROXIMATELY 100 PAPERS WERE PRESENTED COVERING A BROAD RANGE OF TOPICS, INCLUDING TRITIUM PRODUCTION, ITS MOVEMENT IN THE ENVIRONMENT, ENVIRONMENTAL RELEASE AND MONITORING, DETECTION AND MEASUREMENT, BIOLOGICAL EFFECTS, BIOKINETICS, APPLICATIONS IN BIOLOGY AND MEDICINE, AND HEALTH PHYSICS. SOME SPEAKERS REVIEWED PUBLISHED INFORMATION, BUT MANY NEW DATA WERE DISCUSSED BY OTHERS. THE SYMPOSIUM SERVED A USEFUL PURPOSE IN GATHERING TOGETHER SCIENTISTS CONCERNED WITH DIVERSE ASPECTS OF THIS IMPORTANT HYDROGEN ISOTOPE. MOST OF THE PAPERS FROM THE SYMPOSIUM, ALONG WITH SOME THAT WERE NOT PRESENTED, WILL BE PUBLISHED IN THE PROCEEDINGS DURING THE SUMMER OF 1972. THIS ARTICLE TOUCHES ON ALL ASPECTS OF THE MEETING, BUT PAPERS OF PARTICULAR INTEREST IN THE FIELD OF NUCLEAR SAFETY ARE EMPHASIZED.
- 13-4-1-275 NATURAL RADIATION IN THE URBAN ENVIRONMENT  
TEATES, D. B. + GOLDIN, A. S. + MOELLER, D. W.  
HARVARD UNIVERSITY, BOSTON, MASS.  
NATURAL RADIATION IS THE LARGEST SOURCE OF POPULATION DOSE AND IS IMPORTANT AS A BASE LINE WITH WHICH RADIATION PROTECTION STANDARDS MAY BE COMPARED. IN THIS ARTICLE PREVIOUS WORK ON NATURAL BACKGROUND RADIATION LEVELS IS SUMMARIZED, AND SOME NEW DATA FROM BOSTON, MASS., ARE REPORTED. GAMMA DOSE RATES, CORRECTED FOR COSMIC RADIATION, WERE MEASURED WITH LARGE IONIZATION CHAMBERS - DOSE RATES INSIDE WOODEN SINGLE FAMILY DWELLINGS WERE 25 TO 50 PERCENT LOWER THAN THOSE OUTSIDE, IN MASONRY MULTIPLE FAMILY DWELLINGS, THEY WERE ABOUT 10 PERCENT LOWER. CONCENTRATIONS OF RADON DAUGHTERS IN THE AIR WERE MEASURED BY PREDECAY AND POSTDECAY ALPHA SPECTROMETRY - CONCENTRATIONS IN DWELLINGS WERE COMPARABLE WITH OUTDOOR CONCENTRATIONS, BUT CONCENTRATIONS IN BASEMENTS WERE HIGHER BY A FACTOR OF ABOUT 5. CONCENTRATIONS IN OFFICE BUILDINGS WERE QUITE LOW, THE RADON DAUGHTERS BEING REMOVED BY THE VENTILATION SYSTEM. EFFECTS OF BUILDING TYPE, CONSTRUCTION MATERIALS, AND VENTILATION ON HUMAN DOSE ARE DISCUSSED, AS ARE POSSIBLE WAYS OF REDUCING POPULATION DOSE.
- 13-4-2-287 SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS  
SMETS, H. B.  
EUROPEAN NUCLEAR ENERGY AGENCY, PARIS, FRANCE  
THE FIRST EUROPEAN CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS WAS HELD AT ISPRA, ITALY, ON OCT. 27-30, 1970. FORTY-FIVE REPRESENTATIVES OF 14 COUNTRIES AND INTERNATIONAL ORGANIZATIONS MET TO CONSTITUTE A WORLDWIDE FORUM ON MATHEMATICAL MODELS AND PRACTICAL CONSEQUENCES OF SPACE-TIME CALCULATIONS. THEY REPORTED THAT SEVERAL COMPUTER PROGRAMS HAD BEEN DEVELOPED FOR THE SOLUTION OF SPACE-TIME PROBLEMS. AS THE MODELS BECAME MORE COMPLEX, HOWEVER, A BALANCE MUST BE STRUCK BETWEEN THE DESCRIPTION OF NEUTRON BEHAVIOR AND THAT OF FEEDBACK EFFECTS SO THAT COMPUTATIONAL IMPROVEMENTS TRULY RESULT IN IMPROVED UNDERSTANDING OF REACTOR BEHAVIOR.

- 13-4-3-295 A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS  
FRY, D. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A METHOD IS PRESENTED FOR ON-LINE MONITORING OF THE REACTIVITY FEEDBACK TIME CONSTANTS FOR DETERMINING THE OPERATING STABILITY OF LARGE FAST BREEDER REACTORS. IN THIS METHOD, MONITORING CAN BE PERFORMED WITHOUT INTERFERING WITH NORMAL REACTOR OPERATION, WITH NEGLIGIBLE REACTOR POWER DISTURBANCE, AND WITHOUT THE NEED FOR SPECIAL IN-CORE REACTIVITY OSCILLATORS. THE METHOD ALSO IS CONDUCIVE TO THE DETECTION OF PARTIAL FLOW BLOCKAGES IN COOLANT CHANNELS IN REACTOR CORE SUBASSEMBLIES.
- 13-4-6-304 ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY  
WADE, L. JR.  
UT-ARC AGRICULTURAL RESEARCH LABORATORY, OAK RIDGE, TENN.  
A RESEARCH TECHNICIAN ENTERED A COBALT-60 IRRADIATION FACILITY AT THE UNIVERSITY OF TENNESSEE-ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY IN OAK RIDGE, TENN., AND RECEIVED A TOTAL BODY EXPOSURE OF 260 R. CONTRIBUTING FACTORS IN THE INCIDENT WERE MALFUNCTIONING INTERLOCK SYSTEMS, FAILURE TO OBSERVE WARNING DEVICES, AND FAILURE TO FOLLOW ESTABLISHED PROCEDURES. SEVERAL PHYSICAL AND ADMINISTRATIVE CONTROLS HAVE BEEN ADDED TO PREVENT SUCH AN INCIDENT.
- 13-5-1-153 PRELIMINARY OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER  
STEINER, D. + PRAAS, A. P.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER ARE CONSIDERED WITH REFERENCE TO A CONCEPTUAL FUSION REACTOR BASED ON THE DEUTERIUM - TRITIUM FUEL CYCLE. THIS ANALYSIS LEADS TO THE FOLLOWING OBSERVATIONS (1) THE ENGINEERED FEATURES NECESSARY TO LIMIT BIOLOGICAL IMPACT IN THE EVENT OF AN ACCIDENT MAY HAVE TO SATISFY LESS STRINGENT REQUIREMENTS IN FUSION REACTOR DESIGN THAN IN FISSION-REACTOR DESIGN. (2) DURING NORMAL OPERATION, TRITIUM WILL PRESENT THE PRIMARY SOURCE OF RADIOACTIVITY IN EFFLUENTS ASSOCIATED WITH FUSION POWER. THE MONITORING OF TRITIUM IN EFFLUENTS WILL BE REQUIRED ONLY AT THE REACTOR SITE SINCE THE FUEL REPROCESSING SYSTEM OF A FUSION REACTOR IS AN INTEGRAL PART OF THE REACTOR. ECONOMIC CONTAINMENT OF TRITIUM MUST BE A MAJOR OBJECTIVE OF FUSION REACTOR TECHNOLOGY. (3) LONG LIVED RADIOISOTOPES WILL BE PRODUCED IN THE STRUCTURAL COMPONENTS OF FUSION REACTORS. IF DEUTERIUM IS EMPLOYED AS THE STRUCTURAL MATERIAL, DISPOSAL SCHEMES SIMILAR TO THOSE CURRENTLY PROPOSED FOR FISSION REACTOR WASTES MAY BE REQUIRED. IF VANADIUM IS EMPLOYED, RECYCLE OF THE STRUCTURAL MATERIAL APPEARS POSSIBLE. (4) ALTHOUGH AFTERHEAT REMOVAL WILL BE QUANTITATIVELY LESS OF A PROBLEM WITH FUSION POWER THAN WITH FISSION POWER, IT MUST BE CONSIDERED IN THE ENGINEERING DESIGN OF FUSION REACTORS.
- 13-5-3-166 INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERENCE AND EXHIBIT  
LISSER, C. S. + RADS, B. G. + DUGGINS, S. C.  
BAGEN, E. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE  
THE 26TH INSTRUMENT SOCIETY OF AMERICA CONFERENCE AND EXHIBIT PRESENTED A REVIEW OF THE STATE OF THE TECHNOLOGY OF THE INDUSTRY AND A SUGGESTION OF THINGS TO COME. A BROAD RANGE OF TOPICS CONCERNING INSTRUMENTATION THEORY AND APPLICATION WAS CONSIDERED IN THE 92 TECHNICAL SESSIONS COMPRISING THE CONFERENCE PROGRAM, AN INNOVATION THIS YEAR WAS A SERIES OF DISTINGUISHED LECTURES ON SPECIAL AREAS OF INSTRUMENTATION. CONCERN ABOUT INTERNATIONAL STANDARDS HIGHLIGHTED THE ECONOMIC ASPECT, AND MORE RESEARCH AND DEVELOPMENT WERE ACKNOWLEDGED TO BE NEEDED IN THE ENVIRONMENTAL FIELD. SOME NEW WORK WAS REPORTED ON THE STUDY OF VIBRATION AND ITS EFFECTS IN AND ON NUCLEAR PLANTS. SELECTED PAPERS OF PARTICULAR SAFETY SIGNIFICANCE ARE REVIEWED.
- 13-5-4-173 GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR STRUCTURES  
SINWEIL, I. S.  
BCHTFL CORPORATION, GAITHERSBURG, MARYLAND  
THE CONTAINMENT INTERIOR STRUCTURES OF PRESSURIZED WATER REACTORS HAVE SEVERAL SAFETY FUNCTIONS FOR WHICH THEIR STRUCTURAL INTEGRITY IS OF UTMOST IMPORTANCE. BY PROVIDING SUPPORT DURING PLANT OPERATION AND POSTULATED EARTHQUAKES, THEY HELP PREVENT THE OCCURRENCE OF A LOSS OF COOLANT ACCIDENT. FURTHERMORE, IF AN ACCIDENT DOES OCCUR, THEY HELP MITIGATE ITS CONSEQUENCES BY PROTECTING THE CONTAINMENT AND ALL THE PROVIDED ENGINEERED SAFETY FEATURES FROM JET FORCES, WHIPPING PIPES, DIFFERENTIAL PRESSURES, AND MISSILES. THE PROBLEMS AND COMPLEXITY OF COMBINING SYSTEM AND STRUCTURAL REQUIREMENTS IN ARRIVING AT A CONSERVATIVE AND YET ECONOMICAL DESIGN WARRANT A GENERAL DISCUSSION OF THE CRITERIA INVOLVED AND OF THE SPECIAL DYNAMIC STRUCTURAL PROBLEMS ENCOUNTERED.
- 13-5-5-180 SYMPOSIUM ON RADIOECOLOGY APPLIED TO THE PROTECTION OF MAN AND HIS ENVIRONMENT  
SMETS, J. G. P. M. + BERLIN, A. + ANAVIS, R. J.  
COMMISSION OF EUROPEAN COMMUNITIES, LUXEMBOURG  
THIS SYMPOSIUM, ORGANIZED BY THE COMMISSION OF THE EUROPEAN COMMUNITIES, WAS DEVOTED TO THE ASSESSMENT OF THE ACHIEVEMENTS OF RADIOECOLOGY IN THE PROTECTION OF MAN AGAINST RADIOACTIVE

POLLUTANTS (AREAS STILL IN NEED OF RESEARCH WERE DEFINED) AND TO THE DETERMINATION OF THE EXTENT TO WHICH THE KNOWLEDGE GAINED IN RADIOECOLOGY CAN BE APPLIED TO THE FIGHT AGAINST NONRADIOACTIVE POLLUTANTS. ONE OF THE CONCLUSIONS WAS THAT THE CONCEPT OF 'RADIOECOLOGICAL FORECASTING' SHOULD BE INTRODUCED, ALLOWING FOR LONG TERM PLANNING IN THE SETTING UP OF NEW NUCLEAR INSTALLATIONS. MANY OF THE CONCEPTS DEVELOPED IN RADIOECOLOGY FIND THEIR PLACE IN THE FIGHT AGAINST NONRADIOACTIVE POLLUTANTS, THE NOTION OF 'ENGAGED DAMAGE' CAN BE USED FOR THE DEVELOPMENT OF 'CRITERIA' AND 'GUIDE LEVELS' IN THE ESTABLISHMENT OF REGULATIONS.

- 13-5-5-391 ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES  
GIFFORD, P. A., JR.  
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENNESSEE  
IN CITIES, ATMOSPHERIC DISPERSION AND TRANSPORT OF POLLUTANTS ARE AFFECTED BY SEVERAL FACTORS THAT ARE NOT PRESENT IN THE NONURBAN ENVIRONMENT, PRINCIPALLY THE ENHANCED SURFACE ROUGHNESS AND HEAT CAPACITY. THE EFFECTS OF THESE ON THE MICROMETEOROLOGY OF THE URBAN ATMOSPHERIC BOUNDARY LAYER ARE BRIEFLY SUMMARIZED, AND DIFFUSION MODELS FOR URBAN SOURCES ARE REVIEWED. THE BOUNDARY LAYER OVER A CITY IS USUALLY NEARLY ADIABATIC. DISPERSION IS ENHANCED BY THE INCREASED URBAN ROUGHNESS, ALTHOUGH TRANSPORT BY THE MEAN WIND IS SLIGHTLY DECREASED BY THE AERODYNAMIC DRAG. SUCH REMOVAL PROCESSES AS FALLOUT AND PRECIPITATION SCAVENGING, AS WELL AS CHEMICAL REACTIONS, ARE BRIEFLY DISCUSSED.
- 13-6-1-451 ISPRAS CONTRIBUTION TO REACTOR SAFETY  
RANDEL, J.  
JOINT CENTRE FOR NUCLEAR RESEARCH, ISPPA (VARESE), ITALY  
EURATOMS JOINT RESEARCH CENTRE AT ISPPA HAS HAD FOR SEVERAL YEARS AN EXTENSIVE PROGRAM IN REACTOR SAFETY RESEARCH AND DEVELOPMENT. IN THE PAST REACTOR SAFETY FIELD, IT INCLUDED WORK ON THE INTERACTION BETWEEN URANIUM DIOXIDE AND SODIUM AND ON THE DYNAMIC LOADING OF LIQUID METAL COOLED FAST BREEDER REACTOR CONTAINMENT. RESEARCH IN SUPPORT OF WATER REACTOR SAFETY COVERS DEPRESSURIZATION AND EMERGENCY CORE COOLING SYSTEM STUDIES. A MORE GENERALIZED RESEARCH EFFORT IS UNDER WAY IN THE AREAS OF REACTOR DYNAMICS, RELIABILITY THEORY, EARLY FAILURE DETECTION, AND FRACTURE MECHANICS AND PIPE RUPTURE.
- 13-6-2-459 RADIOLYTIC HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS  
ZITTEL, H. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE RADIOLYTIC GENERATION OF HYDROGEN FROM THE PRESSURE SUPPRESSION COOLANT LIQUID FOLLOWING A LOSS OF COOLANT ACCIDENT IN LIGHT WATER COOLED POWER REACTORS IS AN IMPORTANT CONSIDERATION SINCE IT COULD CONCEIVABLY RESULT IN A HAZARDOUS CONDITION. STUDIES CARRIED OUT IN THIS LABORATORY ON THE PROBABLE RADIOLYTIC HYDROGEN GENERATION IN BOTH THE PWR AND BWR ACCIDENT CASES HAVE BEEN INSTRUMENTAL IN ESTABLISHING A BASE FROM WHICH TO CONSIDER THIS POINT. A REVIEW OF THE EXPERIMENTAL WORK AND THE CONCLUSIONS ARISING FROM THE WORK ARE GIVEN.
- 13-6-2-467 SOME PRELIMINARY CONSIDERATIONS RELATING TO AN EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL  
BROOK, A. J.  
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY, WARRINGTON, LANCAS  
THE CALCULATION OF ENERGY RELEASE RESULTING FROM SEVERE ECCURSIONS IN FAST REACTORS DEMANDS A KNOWLEDGE OF THE EQUATION OF STATE OF REACTOR FUEL. THIS ARTICLE DISCUSSES THE MODIFYING EFFECTS THAT FISSION PRODUCTS MAY PRODUCE ON PRESSURE TEMPERATURE RELATIONS AND OUTLINES SOME OF THE MAJOR UNCERTAINTIES IN THE PHYSICAL AND CHEMICAL BEHAVIOR OF THE FISSION PRODUCTS. ATTENTION IS DRAWN TO THE IMPORTANCE OF REACTOR CONDITIONS AT THE INITIATION OF THE SUPERPROMPT ECCURSION, AND AN INDICATION IS GIVEN OF THE EFFECTS OF FISSION PRODUCT PRESSURES ON NUCLEAR ECCURSION YIELDS AND CONTAINMENT REQUIREMENTS.
- 13-6-4-478 EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BED  
UNDERHILL, D. W.  
HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASS.  
THEORETICAL AND EXPERIMENTAL STUDIES SHOW THAT, IN THE EVENT OF AN ACCIDENTAL RUPTURE OF A PRESSURIZED NOBLE GAS ADSORPTION BED, (1) THE FRACTIONAL RELEASE OF ADSORBED FISSION GASES CAN BE SMALLER THAN THE RATIO OF THE INITIAL-TO-FINAL BED PRESSURES, (2) FOR A GIVEN SET OF CONDITIONS, THE FRACTION OF KRYPTON RELEASED WILL BE GREATER THAN THAT OF XENON, AND (3) WHERE THE LEAK IS RELATIVELY SLOW AND THE CARRIER GAS IS ARGON, AS IN THE PROPOSED FAST FLUX TEST FACILITY DESIGN, THE FRACTION OF FISSION GASES ESCAPING CAN BE SIGNIFICANTLY SMALLER THAN THAT OF THE CARRIER GAS.
- 13-6-5-482 THE EMERGING ROLE OF THE CAMPUS RADIATION SAFETY OFFICER  
ZIEMER, P. L.  
PURDUE UNIVERSITY, LAFAYETTE, INDIANA  
UNIVERSITY RADIATION SAFETY OFFICERS (RSOS) FROM THROUGHOUT THE UNITED STATES AND CANADA MET AT PURDUE UNIVERSITY IN SEPTEMBER 1971 TO EXAMINE THEIR ROLE ON THE CAMPUS AND HOW THIS ROLE IS CHANGING. THE CONFERENCE FOCUSED PRIMARILY ON ADMINISTRATIVE

ASPECTS OF CAMPUS RADIATION SAFETY PROGRAMS BUT ALSO INCLUDED DISCUSSIONS OF PRACTICAL HEALTH PHYSICS PROBLEMS COMMON TO THE CAMPUSES. A WIDE DIVERSITY WAS SEEN IN THE ORGANIZATIONAL STRUCTURES AND RESPONSIBILITIES OF THE MANY UNIVERSITIES REPRESENTED. THE CAMPUS ALSO PARTICIPATES IN HEALTH PHYSICS ADMINISTRATION, TEACHING, AND RESEARCH. FINDING THE PROPER BALANCE OF THESE FUNCTIONS IN AN ORGANIZATIONALLY SOUND FRAMEWORK WILL PERMIT HIM TO FILL HIS ROLE IN MEETING THE GROWING HEALTH PHYSICS NEEDS OF HIS CAMPUS IN THE FUTURE.

- 14-1-1-001 EARTHQUAKE RESISTANT DESIGN OF ENGINEERING STRUCTURES  
BELL, C. G.  
UNIVERSITY OF NORTH CAROLINA, CHARLOTTE, NORTH CAROLINA  
A 2-WEEK MEETING ON EARTHQUAKE-RESISTANT DESIGN OF ENGINEERING STRUCTURES, HELD AT THE UNIVERSITY OF CALIFORNIA, BERKELEY, JUNE 19-30, 1972, IS SUMMARIZED. THE PRINCIPAL TOPICS COVERED INCLUDE SEISMOLOGY AND STRONG-MOTION RECORDS, RESPONSE OF SOILS AND DAMS, FINITE ELEMENT APPLICATIONS IN STRUCTURES AND FOUNDATIONS, A NEW LARGE SHAKER, AND PROBABILISTIC DESIGN. CONSIDERABLE INFORMATION WAS PRESENTED THAT WILL BE USEFUL AS BACKGROUND IN SITING AND EARTHQUAKE-RESPONSE CONSIDERATIONS FOR NUCLEAR REACTORS.
- 14-1-1-006 THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS  
DAVIS, J. P.  
CONSOLIDATED EDISON COMPANY, NEW YORK, N. Y.  
THIS IS THE FIRST OF A SERIES OF TWO ARTICLES, AND IT PRESENTS A SURVEY OF THE REGULATION OF ENVIRONMENTAL FEATURES OF NUCLEAR POWER PLANTS. RECEIVING PARTICULAR ATTENTION IS THE JURISDICTION OF THE ATOMIC ENERGY COMMISSION UNDER THE ATOMIC ENERGY ACT OF 1954, AND ITS EXPANSION UNDER THE NATIONAL ENVIRONMENTAL POLICY ACT OF 1969. SEVERAL OTHER FEDERAL AGENCIES, INCLUDING THE FEDERAL POWER COMMISSION, THE CORPS OF ENGINEERS, AND THE ENVIRONMENTAL PROTECTION AGENCY, ALSO PLAY IMPORTANT ROLES IN THIS AREA. IN ADDITION, THERE HAVE BEEN INTERESTING RECENT DEVELOPMENTS IN THE STATE REGULATORY PICTURE IN THE FIELD OF POWER PLANT SITING.
- 14-1-2-014 PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT ACCIDENTS  
LINDACKERS, K-H + STOEBEL, W.  
TECHNICAL SURVEILLANCE ORGANIZATION, BREINLAND, FEDERAL REPUBLIC OF GERMANY  
IN THE PAST, IT HAS BEEN THE PRACTICE IN THE FEDERAL REPUBLIC OF GERMANY TO BASE SITE SELECTION AND ENGINEERING SAFEGUARDS FOR NUCLEAR POWER PLANTS ON THE SO-CALLED MAXIMUM CREDIBLE ACCIDENT CONCEPT (MCA CONCEPT). IN THE OPINION OF THE AUTHORS, IT WILL NOW BE NECESSARY TO USE A MORE QUANTITATIVE APPROACH, AS DEVELOPED BY THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY, BECAUSE NUCLEAR POWER PLANTS MUST BE CONSTRUCTED IN MORE DENSELY POPULATED AREAS. WITH RESPECT TO LIGHT WATER REACTORS, LOSS OF COOLANT ACCIDENTS COULD LEAD TO A RELATIVELY HIGH RELEASE OF FISSION PRODUCTS. IN THIS ARTICLE THE PROBABILITY ANALYSIS IS APPLIED TO LOSS OF COOLANT ACCIDENTS IN THE NUCLEAR POWER PLANTS OF WURGASSEN (BWR) AND STADE (DWR), WHICH ARE NOW UNDER CONSTRUCTION. THE INFLUENCE OF UNCERTAINTIES IN THE MAIN FACTORS OF THIS ANALYSIS (E.G., PROBABILITY OF FAILURES IN PIPING AND CONTAINMENT) IS DISCUSSED.
- 14-1-3-021 HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS  
HAUDENBUSH, M. H.  
GULF GENERAL ATOMIC, INC., SAN DIEGO, CALIFORNIA  
CONTROL BOARD LAYOUT DESIGN TRENDS IN THE NUCLEAR POWER INDUSTRY ARE EXAMINED AND EVALUATED FROM A HUMAN ENGINEERING ASPECT. EXTENSIVE REVIEW OF EXISTING LITERATURE AND STUDY OF PRESENT CONTROL BOARD LAYOUT PHILOSOPHY SUBSTANTIATE THE SUGGESTION THAT A GREAT NEED EXISTS WITHIN THE NUCLEAR POWER INDUSTRY FOR CONTROL BOARD LAYOUT STANDARDS BASED ON FORMAL HUMAN ENGINEERING STUDIES. RESULTS OF A DETAILED HUMAN ENGINEERING EVALUATION OF A MINIATURIZED CONTROL BOARD ARE PRESENTED TO DEMONSTRATE BOTH THE ADVANTAGES AND DISADVANTAGES OF SIZE REDUCTION. FINALLY, A SUBJECTIVE DISCUSSION OF OPERATOR-AUTOMATION INTERFACES SUGGESTS THE DIRECTION FUTURE CONTROL BOARD DESIGN SHOULD TAKE TO ASSURE OPTIMUM OPERATOR CONTROL AND SAFETY.
- 14-1-6-027 SAFETY EXPERIENCE GAINED FROM RAPSODIE OPERATION  
ARGOUS, J. P. + CHANTOT, H. + PETIT, J.  
STACHURA, S. J.  
COMMISSARIAT A L'ENERGIE ATOMIQUE, SAINT PAUL, LEZ, FRANCE + ATOMICS INTERNATIONAL, CANOGA PARK, CALIF.  
THIS ARTICLE BRIEFLY DESCRIBES AND ANALYZES THREE OPERATIONAL INCIDENTS AT THE FRENCH EXPERIMENTAL FAST REACTOR RAPSODIE. THESE EVENTS SERVED TO IDENTIFY VARIOUS DESIGN INADEQUACIES TO BE AVOIDED IN FUTURE PLANTS AND ALSO DEMONSTRATED SEVERAL POSITIVE SAFETY ASPECTS OF THE DESIGN. THE INCIDENTS INVOLVED (1) SODIUM OVERFLOW THROUGH PENETRATIONS IN A SMALL ROTATING PLUG AS A RESULT OF INADVERTENT REACTOR COVER-GAS OVERPRESSURE, (2) A FUEL-HANDLING INCIDENT THAT RESULTED IN DEFORMATION OF HANDLING MECHANISMS AND CORE ASSEMBLIES, AND (3) OVERFLOW OF A FUSIBLE METAL SEAL IN A SMALL ROTATING PLUG DUE TO A PRESSURIZATION ANOMALY. THE INCIDENTS GENERALLY INVOLVED COMBINATIONS OF DESIGN, EQUIPMENT, PROCEDURAL, OR OPERATIONAL ERRORS.

- 14-2-1-079 SAFETY ASSESSMENT PHILOSOPHY OF THE FAST FLUX TEST FACILITY  
FFTF PROJECT PERSONNEL  
HANFORD ENGINEERING DEVELOPMENT LABORATORY, RICHLAND, WASH.  
THIS REPORT EXPLAINS HOW SAFETY HAS BEEN EMPHASIZED THROUGHOUT THE FAST FLUX TEST FACILITY (FFTF) PROJECT AS AN INTEGRAL PART OF THE TOTAL PROJECT EFFORT FROM THE INCEPTION OF DESIGN THROUGHOUT ALL ASPECTS OF THE ENGINEERING, CONSTRUCTION, TESTING, OPERATION, AND MAINTENANCE OF THE PLANT. THIS OVERALL CONCEPT IS EXPRESSED IN TERMS OF THREE LEVELS OF SAFETY. THE FIRST LEVEL ADDRESSES THE PREVENTION OF ACCIDENTS THROUGH THE INTRINSIC FEATURES OF THE DESIGN OF THE PLANT AND THE QUALITY, REDUNDANCY, TESTABILITY, INSPECTABILITY, AND FAIL SAFE FEATURES OF THE COMPONENTS OF THE REACTOR AND PLANT. THE SECOND LEVEL CONCERNS PROVIDING PROTECTION AGAINST SUCH INCIDENTS AS REACTIVITY INSERTIONS OR FAILURES OF PARTS OF THE CONTROL SYSTEM WHICH MIGHT OCCUR IN SPITE OF THE CARE TAKEN IN DESIGN, CONSTRUCTION, AND OPERATION TO PREVENT THEM. THE THIRD LEVEL OF SAFETY SUPPLEMENTS THE FIRST TWO THROUGH FEATURES THAT ADD MARGIN IN THE PLANT DESIGN AS ADDITIONAL ASSURANCE THAT PROTECTION TO THE PUBLIC IS PROVIDED EVEN IN THE EVENT OF THE OCCURRENCE OF EXTREMELY UNLIKELY AND UNFORSEEN CIRCUMSTANCES. ALSO INCLUDED IN THE DISCUSSION ARE THE PRINCIPAL FFTF DESIGN PARAMETERS AND THE REACTOR'S INHERENT SAFETY FEATURES, THE PROGRAMS OF TESTING AND DEVELOPMENT TO SUPPORT THE DESIGN, AND THE CARE USED IN CONSTRUCTION AND TESTING.
- 14-2-2-091 COUPLED NEUTRONICS HYDRODYNAMICS METHODS  
TOBIAS, M.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE PRINCIPAL FEATURES OF COMPUTER CODES AND METHODS FOR REACTOR DISASSEMBLY ANALYSIS ARE BRIEFLY SURVEILED. FROM THE BASICALLY HAND CALCULATED METHOD OF BETHE AND TAIT, THESE METHODS HAVE PROGRESSED TO FAIRLY ELABORATE PROGRAMS DESIGNED TO ESTIMATE THE CONSEQUENCES OF A HYPOTHETICAL FAST REACTOR CORE DISASSEMBLY. SUCCESSIVE DEVELOPMENTS HAVE INCLUDED SUCH FEATURES AS DOPPLER FEEDBACK, DELAYED NEUTRONS, IMPROVED EQUATIONS OF STATE, AND MORE ELABORATE GEOMETRIES.
- 14-2-3-095 OBSTACLES TO COMPLETE AUTOMATION OF REACTOR CONTROL  
EPLER, E. P. + OAKES, L. C.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
ANOMALOUS REACTIVITY CHANGES RESULTING FROM CONDITIONS OTHER THAN ANTICIPATED CONTROL ROD MOTION OCCURRED IN EARLY EXPERIMENTAL REACTORS AND LED TO LOCAL MELTING. DOUBT HAS BEEN EXPRESSED, HOWEVER, THAT SUCH CHANGES COULD OCCUR IN COMMERCIAL POWER REACTORS. DEFENSES AGAINST THE REACTIVITY ANOMALY HAVE SINCE BEEN DEVELOPPED FOR TEST AND PRODUCTION REACTORS WHICH HAVE PERMITTED AN INCREASED DEGREE OF AUTOMATION TO BE SAFELY APPLIED. THE PRINCIPLES SO DEVELOPPED, WHICH RELY ON DIGITAL TECHNIQUES, ARE EQUALLY APPLICABLE TO POWER REACTORS. ACCEPTED CRITERIA FOR THE APPLICATION OF DIGITAL TECHNIQUES TO CONTROL AND PROTECTION SYSTEMS HAVE NOT YET BEEN DEVELOPPED, HOWEVER, AN EXTENSION OF EXISTING PRACTICES AND PRECEDENTS SHOULD BE ADEQUATE UNTIL SUCH CRITERIA ARE AVAILABLE.
- 14-2-3-105 LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS  
TRIE, J. A.  
CONSULTANT, BARRINGTON, ILL.  
A MEANS IS DESCRIBED FOR SEPARATING A REACTOR PLANT'S VARIABLE RADIATION FROM A LARGER AND ALSO VARYING BACKGROUND UTILIZING THE DIFFERING CHARACTER OF FLUCTUATIONS PRESENT. IT IS SHOWN THAT AN ACCURACY OF PLUS OR MINUS 0.9 MRE PER YEAR IN THE FENCE LINE DOSE RATE FROM A BOILING WATER REACTOR (BWR) PLUME IS OBTAINABLE FROM RANDOM FLUCTUATION ANALYSIS, IN WHICH THE STANDARD DEVIATION IS THE BASIC MEASUREMENT TOOL. OTHER SPECIFIC APPLICATIONS OF AUTOCORRELATION, CROSS CORRELATION, AND SPECTRAL ANALYSIS TO THE GENERAL PROBLEM OF SIGNAL EXTRACTION IN LOW LEVEL ENVIRONMENTAL MONITORING ARE DISCUSSED.
- 14-2-4-111 THE TWELFTH AEC AIR CLEANING CONFERENCE  
MOELLER, D. W. + FIRST, M. W.  
HARVARD SCHOOL OF PUBLIC HEALTH, BOSTON, MASS.  
THE TWELFTH AEC AIR-CLEANING CONFERENCE WAS HELD AUGUST 28-31, 1972, IN OAK RIDGE, TENN. REGISTRATION TOTALED A RECORD 360 PEOPLE, INCLUDING PERSONNEL FROM ESSENTIALLY ALL FACETS OF GOVERNMENT, INDUSTRY, AND EDUCATIONAL INSTITUTIONS, PLUS REPRESENTATIVES FROM SEVEN FOREIGN COUNTRIES. MAJOR TOPICS WERE CURRENT RESEARCH ON AIR AND GAS CLEANING SYSTEMS OF INTEREST TO THE NUCLEAR COMMUNITY AND MORE RECENT CONSIDERATIONS IN THE DESIGN OF SYSTEMS TO RESIST THE EFFECTS OF FIRE, EARTHQUAKES, AND OTHER MECHANICAL STRESSORS. ALSO DISCUSSED WERE AIR CLEANING PROBLEMS ASSOCIATED WITH URANIUM MINING, HIGH TEMPERATURE GAS COOLED REACTORS, AND CHEMICAL PROCESSING PLANTS. CLEAR-CUT BENEFITS RESULTING FROM THE CONFERENCE WERE BETTER DEFINITION OF THE MAJOR PROBLEMS CONFRONTING THE PROFESSION AND PROVISION OF AN OPPORTUNITY FOR GROUPS WORKING ON SIMILAR PROBLEMS TO SHARE THEIR MOST RECENT DATA. PROCEEDINGS OF THE CONFERENCE WERE PUBLISHED IN JANUARY 1973.

- 14-3-1-165 THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS  
DAVIS, J. P.  
CONSOLIDATED EDISON COMPANY, NEW YORK, N.Y.  
PART ONE OF THIS TWO-PART ARTICLE (SEE NUCLEAR SAFETY FOR JANUARY-FEBRUARY 1974) DISCUSSED U. S. NEEDS FOR ELECTRIC POWER AND THE ROLE OF NUCLEAR ENERGY IN MEETING THESE NEEDS. THE MAJOR PORTION OF THE ARTICLE REVIEWED THE REGULATORY PROCESS THAT IS CURRENTLY REQUIRED FOR NUCLEAR POWER PLANTS. PART TWO DISCUSSES THE RADIOLOGICAL AND NONRADIOLOGICAL EFFECTS OF NUCLEAR POWER GENERATION ON THE ENVIRONMENT AND THE MEANS FOR THEIR REGULATION ALONG WITH SOME RELATED CASES AND CONTROVERSIES. PROPOSALS FOR IMPROVEMENTS THROUGH CHANGES IN PROCEDURES AND NEW LEGISLATION ARE ALSO EXAMINED.
- 14-3-1-181 ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY  
WEIDER, H. J. A.  
FEDERAL INSTITUTE OF MATERIALS TESTING, FEDERAL REPUBLIC OF GERMANY  
THE INCREASING DEMAND FOR NUCLEAR STANDARDS TO FACILITATE THE SITING, DESIGN, AND LICENSING OF NUCLEAR POWER PLANTS IS EVIDENT IN GERMANY AS IN MOST OTHER COUNTRIES WITH A VIABLE NUCLEAR CAPABILITY. AS A RESULT, THE GERMAN STANDARDS INSTITUTE'S NUCLEAR TECHNOLOGY COMMITTEE HAS RECENTLY INTENSIFIED ITS EFFORT. IN ADDITION, SEVERAL GERMAN TECHNICAL SOCIETIES ARE INVOLVED IN THE STANDARDIZATION EFFORT, AND GERMANY COOPERATES IN THE INTERNATIONAL STANDARDS ORGANIZATION ACTIVITIES.
- 14-3-2-187 PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE  
BUSH, S. H.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
THE PROBABILITY OF SIGNIFICANT DAMAGE TO CRITICAL COMPONENTS OF A NUCLEAR REACTOR SYSTEM DUE TO TURBINE FAILURE HAS BEEN ASSESSED BY DETERMINING THE COMBINED PROBABILITIES OF TURBINE FAILURE AND EJECTION OF AN ENERGETIC MISSILE (P1), ON THE BASIS OF 70,000 TURBINE YEARS OF OPERATION, A MISSILE FROM THE TURBINE STRIKING A CRITICAL COMPONENT (P2), AND SIGNIFICANT DAMAGE OCCURRING TO THE COMPONENT (P3). THE OVERALL PROBABILITY (P4) IS AN INDICATION OF HOW MUCH THE NUCLEAR PLANT DESIGNER NEEDS TO BE CONCERNED WITH THE TURBINE MISSILE PROBLEM. TURBINE FAILURES WERE REVIEWED TO ESTABLISH RELEVANCE WITH REGARD TO CURRENT PRACTICE IN DESIGN, FABRICATION, AND OPERATION OF NUCLEAR STEAM TURBINES. IF P1 IS 10(-4) PER YEAR, P2 IS 10(-3) FOR STRIKES ON A 1200 SQUARE FT. AREA, AND P3 APPROACHES 1, THEN P4 IS APPROXIMATELY 10(-7) IF P2 INCREASES, EVALUATION OF P3 BECOMES NECESSARY.
- 14-3-2-201 FACTORS LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST REACTOR CORES  
TEAGUE, H. J. + MATHER, D. J.  
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, COLCHESTER, NR. WARRINGTON, LANC.  
PRELIMINARY CALCULATIONS ARE REPORTED WHICH ILLUSTRATE HOW PRESSURES FROM FISSION PRODUCTS IN IRRADIATED FUEL WOULD DRASTICALLY REDUCE THE EXPLOSIVE ENERGY RELEASE IN A FAST REACTOR SUBJECT TO A FAST REACTIVITY BUMP. ADDITIONAL EMPHASIS IS PUT ON THE REDUCTION OF DAMAGING EFFECTS DUE TO RAPID GENERATION OF SODIUM VAPOR FOR THREE REASONS - LOWER FUEL TEMPERATURES AT CORE DISASSEMBLY, LESS VIOLENT INTERNAL DISASSEMBLY PROCESSES, AND GAS BLANKETING OF FUEL PARTICLES.
- 14-3-3-206 STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS  
HAGEN, E. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
AVAILABILITY OF RELIABLE STANDBY OR EMERGENCY POWER SYSTEMS HAS ALWAYS BEEN A PRIME CONSIDERATION IN STATION DESIGN, BEGINNING WITH THE EARLY NUCLEAR REACTOR POWER PLANTS. THE DOCUMENTED OPERATING EXPERIENCES WERE REVIEWED FOR THE STATION OFF-SITE AND ON-SITE STANDBY, EMERGENCY A-C POWER SOURCES, AND THE BATTERY SYSTEMS. PART 1 DISCUSSES THESE SYSTEMS FOR THE GENERATING REACTORS COMMISSIONED ABOUT 1959-1967. THE ABILITY OF THESE SYSTEMS TO PERFORM SATISFACTORILY WHEN NEEDED HAS BEEN VERY GOOD FOR THE EARLY PLANTS, BUT THE ABILITY TO PERFORM SATISFACTORILY AT ANY GIVEN TIME WAS SOMETHING LESS. HOWEVER, WITH THE ADVANCEMENT OF REGULATORY DESIGN GUIDES AND INDUSTRY STANDARDS, THE RELIABILITY IS EXPECTED TO CONTINUE TO BE GOOD AND THE AVAILABILITY TO BE IMPROVED. IN THE LATER PLANTS, TO BE DISCUSSED IN PART 2, WITH STANDARDIZED AND MODULARIZED DESIGNS, THESE EFFORTS AND EFFECTS WILL BECOME APPARENT THROUGH BETTER USE, TESTING, AND DOCUMENTATION.
- 14-3-5-220 SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FOR RADIATION WORKERS  
FASON, C. F. + BROOKS, H. G.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
IT HAS BEEN STATED THAT THE AVERAGE YEARLY OCCUPATIONAL RADIATION EXPOSURE OF A RADIATION WORKER IS COMPARABLE TO THAT OF NATURAL BACKGROUND (THAT IS, 120 TO 150 MREMS), THUS THERE IS NO NEED TO ASSESS THE WORKER'S MEDICAL RADIATION EXPOSURE TO ENSURE HIS ON THE JOB HEALTH AND SAFETY. ON THE OTHER HAND, THERE ARE THOSE WHO BELIEVE THAT, IF A WORKER HAS UNDERGONE A LARGE THERAPEUTIC EXPOSURE, IT MAY BE DESIRABLE TO RESTRICT FUTURE OCCUPATIONAL EXPOSURE WHERE THE RISK OF A LARGE

ACCIDENTAL EXPOSURE MAY BE UNUSUALLY HIGH. IT HAS ALSO BEEN STATED THAT, ALTHOUGH THE RADIATION DOSE RESULTING FROM MEDICAL EXPOSURE SHOULD NOT, IN GENERAL, BE INCLUDED IN DOSE LIMITATIONS, IT WOULD NEED TO BE TAKEN INTO ACCOUNT IN ANY ASSESSMENT OF THE TOTAL RISK TO THE INDIVIDUAL FROM RADIATION EXPOSURE. IN VIEW OF THE APPARENT DIFFERENCES OF OPINION ON THE VALUE OF NOTING MEDICAL RADIATION EXPOSURES, IS THERE A NEED FOR A RECORD-KEEPING SYSTEM THAT WILL PROVIDE MANAGEMENT, LABOR, AND THE MEDICAL PROFESSION WITH THE INFORMATION NECESSARY TO WEIGH THE TOTAL RISK OF A WORKER EXPOSED TO A SOURCE OF IONIZING RADIATION. THIS ARTICLE REVIEWS VARIOUS ASPECTS RELATING TO THIS QUESTION.

- 14-4-1-267 PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS  
STARR, C. + GREENFIELD, N. A.  
UNIVERSITY OF CALIFORNIA AT LOS ANGELES, LOS ANGELES, CALIF.  
THE RESULTS OF A STUDY COMPARING NUCLEAR POWER PLANTS WITH OIL FIRED PLANTS ARE REVIEWED AND ASSESSED IN TERMS OF PUBLIC HEALTH RISKS. THE STUDY WAS UNDERTAKEN AS A BASIC CONTRIBUTION TO THE STATE OF CALIFORNIA'S LONG RANGE PLANNING ON HOW BEST TO MEET THE POWER NEEDS OF ITS GROWING POPULATION. BASED ON AN 8-MONTH EVALUATION OF OIL FIRED AND NUCLEAR PLANTS IN URBAN SETTINGS, THE AUTHORS CONCLUDE THAT THE PUBLIC HEALTH RISK FROM EITHER TYPE OF PLANT IS ROUGHLY COMPARABLE TO THE HAZARDS TO WHICH THE PUBLIC IS EXPOSED BY UNCONTROLLABLE NATURAL EVENTS - LIGHTNING, INSECT OR SNAKE BITES, ETC. SUCH DEATHS OCCUR AT AN ANNUAL RATE OF APPROXIMATELY ONE PER BILLION OF POPULATION. A COMPARISON OF THE RISK FACTORS IN ROUTINE OPERATION OF DIFFERENT TYPES OF POWER PLANTS SHOWED THAT PUBLIC HEALTH RISKS FROM NUCLEAR PLANTS AVERAGED LESS THAN ONE-TENTH OF THE RISKS FROM OIL FIRED PLANTS.
- 14-4-1-274 THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RADIOACTIVE MATERIALS  
PRIOR, W. A.  
USIAC OAK RIDGE OPERATIONS, OAK RIDGE, TENN.  
THE THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RADIOACTIVE MATERIALS WAS HELD IN RICHLAND, WASH., AUG. 16-20, 1971. ALL PHASES OF TRANSPORTATION WERE COVERED IN THE 93 PAPERS PRESENTED, AND THERE WERE OVER 450 REGISTRANTS REPRESENTING 17 NATIONS. HIGHLIGHTS OF THE MANY TOPICS DISCUSSED IN BOTH THE FORMAL AND INFORMAL SESSIONS ARE REVIEWED IN THIS ARTICLE.
- 14-4-2-291 PRESSURIZED WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE  
DOAN, P. L. + LANNING, D. D. + RASMUSSEN, N. C.  
UNITED ENGINEERS AND CONSTRUCTORS, PHILADELPHIA, PA. + MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.  
THE UNLIKELY LOSS OF COOLANT BY SOME TYPES OF POSTULATED PRESSURE VESSEL RUPTURES IN A LARGE, FOUR-LOOP 2750-MW(T) PRESSURIZED WATER REACTOR HAS BEEN STUDIED TO ASSESS THE RELATIVE IMPORTANCE AND CONSEQUENCES OF PRINCIPAL BLOWDOWN PROCESSES. THE COMPUTER CODES WHAM AND RELAPS HAVE BEEN EMPLOYED AS THE PRINCIPAL TOOLS OF ANALYSIS. A LARGE NUMBER OF COMPUTER RUNS HAVE BEEN MADE WITH VARYING PARAMETERS SUCH AS BREAK TIME, BREAK LOCATION, BREAK SIZE, FUEL CLADDING GAP CONDUCTANCE, EMERGENCY CORE COOLING INJECTION RATES, VOID COEFFICIENTS, AND PHASE SEPARATION MODELS. CLEAR PATTERNS ARE OBSERVED ON THE ASYMPTOTIC BEHAVIOR OF MANY BLOWDOWN PARAMETERS.
- 14-4-2-304 PHENOMENOLOGICAL RESEARCH IN LMFBR ACCIDENT ANALYSIS  
KELSER, C. M.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
CURRENT NEEDS FOR, AND PROGRAMS OF, PHENOMENOLOGICAL RESEARCH APPLIED TO PROBLEMS IN ACCIDENT ANALYSIS OF LIQUID METAL COOLED FAST BREEDER REACTORS ARE REPORTED. THIS SURVEY IS RESTRICTED TO PHENOMENA INVOLVED IN ANALYSIS OF HYPOTHETICAL ACCIDENTS - SODIUM VOIDING - COOLANT DYNAMICS, FUEL DYNAMICS, FUEL FAILURE PROPAGATION, FUEL COOLANT INTERACTION, POSTACCIDENT HEAT REMOVAL, VESSEL AND PLUG RESPONSE, SODIUM FIRES AND AEROSOLS, AND FISSION PRODUCT TRANSPORT. REPORTED FOR EACH CASE ARE THE CURRENT NEED, THE STATUS, THE CURRENT PROGRAM, AND THE ULTIMATE OBJECTIVE OF THE APPLICABLE RESEARCH. THE SURVEY INDICATES THAT IN THE RELATIVELY NEAR TERM AN IMPROVED BASIS FOR DESCRIBING AND PREDICTING THE COURSE OF AN ACCIDENT WILL PROBABLY BE DEVELOPED. IT IS MUCH LESS CERTAIN TO WHAT EXTENT IT WILL BE POSSIBLE TO FACTOR THIS UNDERSTANDING INTO PLANT DESIGN IN SUCH A WAY AS TO DECREASE THE NEED FOR STRONG CONTAINMENTS. AN ADVANCED TESTING PROGRAM REQUIRING MUCH LARGER SCALE TESTS MAY BE NEEDED.
- 14-4-3-315 AN ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER REACTORS  
DUNA, D. W. + SAIR, P. F.  
NORTH CAROLINA STATE UNIVERSITY, RALEIGH, N. C.  
CONTROL ROD SYSTEM FAILURES AND MALFUNCTIONS ARE REVIEWED FOR ALL OF THE NUCLEAR POWER REACTORS FROM INCEPTION TO COMMERCIAL OPERATION THROUGH 1971. FAILURE RATES ARE CALCULATED AND TYPES OF FAULTS ANALYZED FOR COMMON CAUSES. SYSTEM PERFORMANCES ARE COMPARED FOR THE MAJOR VENDORS OF PRESSURIZED AND BOILING WATER REACTORS AS WELL AS OTHERS. RESULTS INDICATE THAT OVERALL FAILURE RATES FOR THE REACTORS CONSIDERED ARE NOT WIDELY VARIANT.

- 14-4-5-325 CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN LMFBR  
TADMOR, J.  
SOBEQ NUCLEAR RESEARCH CENTRE, YAVNE, ISRAEL  
A THEORETICAL EVALUATION HAS BEEN MADE OF THE CONSEQUENCES OF AN ENVIRONMENTAL RELEASE OF SODIUM IN THE FORM OF AN AIRBORNE CLOUD RESULTING FROM A SODIUM FIRE IN A LIQUID METAL COOLED FAST REACTOR. THE EVALUATION TAKES INTO CONSIDERATION ONLY THE HAZARDS OF THE RADIOISOTOPES OF THE SODIUM. PROBLEMS ASSOCIATED WITH ACCOMPANYING FISSION PRODUCTS WERE NOT INCLUDED. ON THE BASIS OF CONSERVATIVE ASSUMPTIONS, THE DATA SHOW THAT THE MOST SIGNIFICANT EXPOSURE WOULD BE TO A CHILD THROUGH THE FORAGE - COW - MILK FOOD CHAIN PATHWAY. THE WHOLE BODY DOSE FOR AN INSTANTANEOUS DIRECT ENVIRONMENTAL RELEASE OF 1 G OF SODIUM (CONTAINING 0.31 CURIES OF SODIUM-24 AND 1.6 X 10<sup>(-4)</sup> CURIES OF SODIUM-22) WOULD BE ABOUT 0.2 REM, THE CORRESPONDING DOSE RESULTING FROM A RELEASE OF 1000G OF SODIUM WITHIN THE REACTOR CONTAINMENT VESSEL, FOLLOWED BY A SUBSEQUENT CONTAINMENT VESSEL LEAKAGE RATE OF 0.1 PERCENT PER DAY, WOULD BE ABOUT 13 REMS. RESTRICTIONS ON THE USE OF MILK AND MILK PRODUCTS WOULD CONSIDERABLY REDUCE THESE VALUES. OTHER POSSIBLE COUNTERMEASURES THAT MIGHT BE TAKEN TO COPE WITH THE ENVIRONMENTAL HAZARDS ARE ALSO DISCUSSED.
- 14-4-5-340 SYMPOSIUM ON HEALTH PHYSICS IN THE HEALING ARTS  
HART, J. C. + POSTON, J. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE SEVENTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY, HELD IN SAN JUAN, PUERTO RICO, DECEMBER 11-14, 1972, DEALT WITH HEALTH PHYSICS IN THE HEALING ARTS. THE SYMPOSIUM, WHICH INCLUDED OVER 100 TECHNICAL PAPERS, WAS ORGANIZED INTO NINE SESSIONS (INCLUDING TWO PANEL DISCUSSIONS). TOPICS INCLUDED - WHAT DO WE KNOW ABOUT (RADIATION) EFFECTS, RADIATION EXPOSURES IN THE HEALING ARTS, OPERATIONAL HEALTH PHYSICS AND QUALITY CONTROL, TRAINING, THE STATUS AND FUTURE TRENDS OF HEALTH PHYSICS TRAINING, TECHNOLOGICAL ASPECTS, GENERAL, EXPOSURE REDUCTION METHODOLOGY, REGULATION VS STANDARDIZATION, AND QHE PASA. HIGHLIGHTS OF THE TECHNICAL SESSIONS, INCLUDING REFRESHER COFFEE AND PANEL DISCUSSIONS, ARE REVIEWED, AND THE COMPLETE SYMPOSIUM AGENDA IS INCLUDED.
- 14-4-5-356 DENSIFICATION OF REACTOR FUELS  
COLBERT, W. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE MOVEMENT OF FUEL AS A CONSEQUENCE OF DENSIFICATION WAS DETERMINED TO BE THE CAUSE FOR COLLAPSE OF THE FUEL CLADDING IN A NUMBER OF PRESSURIZED WATER REACTORS. CLADDING COLLAPSE PRESENTED AN UNEVALUATED CONFIGURATION FOR HEAT REMOVAL IN BOTH NORMAL AND ACCIDENT SITUATIONS. ON NOV. 14, 1972, THE REGULATORY STAFF OF THE U.S. ATOMIC ENERGY COMMISSION ISSUED ITS TECHNICAL REPORT ON DENSIFICATION OF LIGHT WATER REACTOR FUELS. THEN ON FEB. 2, 1973, THE STAFF ISSUED THE REPORT ENTITLED ADDITIONAL TESTIMONY ON POINT BEACH 2 NUCLEAR PLANT IN REGARD TO FUEL DENSIFICATION AND ITS EFFECTS. BECAUSE OF THE INTEREST IN THIS SUBJECT, SUMMARIES OF BOTH OF THESE AEC REPORTS ARE PRESENTED HERE, ALONG WITH THE BIBLIOGRAPHY INCLUDED WITH THE NOVEMBER 14 REPORT.
- 14-4-6-362 ACTIVITY CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD  
JOSEPH, J. W., JR. + LITTLE, J. W., JR.  
E. I. DU PONT DE NEMOURS AND COMPANY, AIKEN, S. C.  
ANTIMONY IN AN IRRADIATED SOURCE ROD MELTED WHILE THE ROD WAS SUSPENDED IN AIR IN THE K REACTOR ROOM AT THE SAVANNAH RIVER PLANT. THE FAILURE RELEASED ABOUT 85,000 CURIES OF ACTIVITY, WHICH WAS DISTRIBUTED IN THE REACTOR ROOM AND THE CONFINEMENT FILTERS IN THE VENTILATION EXHAUST SYSTEM. THE CONFINEMENT FILTERS PREVENTED A SIGNIFICANT ACTIVITY RELEASE, ONLY 3 MILLICURIES ESCAPED TO THE ENVIRONS, AND NO DECONTAMINATION WAS REQUIRED OUTSIDE THE REACTOR BUILDING. DECONTAMINATION OF THE REACTOR ROOM AND REPLACEMENT OF THE CONTAMINATED FILTER COMPARTMENTS REQUIRED ABOUT 3 1/2 MONTHS BEFORE THE REACTOR WAS RETURNED TO NORMAL OPERATION.
- 14-5-1-409 HEALTH EFFECTS OF ELECTRICITY GENERATION FROM COAL, OIL, AND NUCLEAR FUEL  
LAVE, L. B. + FREERBURG, L. C.  
CARNEGIE-MELLON UNIVERSITY, PITTSBURGH, PA.  
OCCUPATIONAL AND PUBLIC HEALTH EFFECTS OF GENERATING ELECTRICITY FROM COAL, URANIUM, AND OIL ARE COMPARED, WITH PARTICULAR ATTENTION GIVEN TO ACCIDENT AND CHRONIC-DISEASE RATES FOR FUEL EXTRACTION AND AIRBORNE EMISSIONS FROM POWER AND REPROCESSING PLANTS. IT IS CONCLUDED THAT URANIUM OFFERS LESS OF A HEALTH HAZARD AS A FUEL THAN COAL. THE ANALYSIS IS BASED ON CURRENT OPERATING PRACTICE, HOWEVER, ADVANCES IN TECHNOLOGY CAN BE EXPECTED TO REDUCE BOTH THE OCCUPATIONAL AND PUBLIC HEALTH RISKS FROM THESE FUELS.
- 14-5-1-428 INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY  
PALMFR, J. F.  
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO  
AN IAEA SYMPOSIUM ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY WAS HELD FEB. 5-9, 1973, AT THE NUCLEAR RESEARCH CENTER, JULICH, FEDERAL REPUBLIC OF GERMANY. THE MEETING WAS ATTENDED BY APPROXIMATELY 250 PARTICIPANTS FROM 30 COUNTRIES, AND 80



PAPERS WERE PRESENTED. THE PAPERS ARE REVIEWED AND THE PANEL DISCUSSION IS SUMMARIZED TO GIVE SOME INSIGHT INTO INTERNATIONAL VIEWS ON THE PROBLEMS RELATED TO REACTOR SAFETY.

- 14-5-1-439 ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY  
COTTBELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A TOPICAL MEETING ON WATER REACTOR SAFETY SPONSORED BY THE AMERICAN NUCLEAR SOCIETY, THE ATOMIC INDUSTRIAL FORUM, THE OAK RIDGE NATIONAL LABORATORY, AND THE UNIVERSITY OF UTAH WAS HELD AT SALT LAKE CITY, MAR. 26 TO 28, 1973. THE MEETING WAS ATTENDED BY MORE THAN 360 TECHNICAL SPECIALISTS, WHO HEARD A TOTAL OF 44 PAPERS IN THE FOLLOWING TECHNICAL SESSIONS - ACCIDENT ANALYSIS AND PROBABILITY, FLUID FLOW DURING LOCA, MECHANICAL BEHAVIOR OF MATERIALS, HEAT TRANSFER DURING LOCA, STANDARDS AND SURVEILLANCE, COMPUTER CODES AND APPLICATIONS, PROTECTION FROM NATURAL AND MAN-MADE PHENOMENA, AND COMPARATIVE ANALYSES OF LOCA. OVER HALF OF THE PAPERS AND SESSIONS WERE CONCERNED WITH THE LOSS-OF-COOLANT ACCIDENT. A PANEL DISCUSSION ON REACTOR SAFETY RESEARCH - WHAT, WHY, HOW, PRESENTED A PLETHORA OF VIEWS ON THE SUBJECT.
- 14-5-2-446 OZONE FORMATION BY THE RADIOLYSIS OF LIQUID NITROGEN - CALCULATION AND MEASUREMENT  
GAULT, J. D. \* LOGAN, K. W. \* DANNER, H. \*  
FEDERAL UNIVERSITY OF SANTA CATARINA, FLORENCE, POLIS, BRAZIL \*  
UNIVERSITY OF MISSOURI, COLUMBIA, MO.  
A SIMPLE EXPERIMENTAL METHOD IS PRESENTED WHICH ALLOWS AN ESTIMATE OF THE AMOUNT OF OZONE PRESENT WHEN OXYGEN CONTAMINATED LIQUID NITROGEN IS EXPOSED TO A RADIATION FIELD. ALSO, IF THE RADIATION LEVEL AND OXYGEN CONCENTRATION ARE KNOWN, THE AMOUNT OF OZONE FORMED CAN BE CALCULATED. IN OUR CASE, THERE IS GOOD AGREEMENT. THE RESULTS INDICATE THAT THE CONCENTRATION OF THE OXYGEN IMPURITY IS MUCH LESS SIGNIFICANT THAN PREVIOUSLY SUPPOSED. INSTEAD, THE AMOUNT OF LIQUID NITROGEN REMAINING WHEN THE CRYOSTAT IS REFILLED IS THE PRIMARY FACTOR IN DETERMINING THE MAXIMUM AMOUNT OF OZONE THAT WILL BE PRESENT AT ANY TIME.
- 14-5-2-452 U. S. STUDIES ON LMFBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS  
DICKERMAN, C. E.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
THIS ARTICLE PRESENTS A BRIEF REVIEW OF THE U. S. EFFORT, BETWEEN FALL 1969 AND SPRING 1972, RELATING TO EVALUATION OF THE BEHAVIOR OF THE FUEL AND COOLANT IN LIQUID METAL COOLED FAST BREEDER REACTORS UNDER ACCIDENT CONDITIONS. THE EXPERIMENTAL WORK IS CENTERED LARGELY AROUND THE TRANSIENT REACTOR TEST FACILITY. INVESTIGATIONS OF STEADY-STATE POWER OPERATION SUGGEST THAT SAFETY AND RELIABILITY CAN BE ATTAINED EVEN WITH PARTIAL BLOCKAGES OF COOLANT FLOW. RESULTS OF TRANSIENT TESTS ARE LESS SEVERE THAN PREDICTIONS BASED ON PESSIMISTIC ASSUMPTIONS, AND ADDITIONAL EFFORT IS REQUIRED TO PERMIT ACCURATE MODELING OF DETAILED BEHAVIOR.
- 14-5-3-461 SNEAK-CIRCUIT ANALYSIS  
BANKIN, J. P.  
THE BOEING COMPANY, HOUSTON, TEXAS  
BEGINNING IN LATE 1967, THE BOEING COMPANY IN HOUSTON, TEX., DEVELOPED A COMPUTER AIDED ELECTRICAL SYSTEMS ANALYSIS TECHNIQUE TO HELP ASSURE FAULT-FREE OPERATION OF NASA'S APOLLO AND SKYLAB HARDWARE. THE TECHNIQUE, CALLED SNEAK-CIRCUIT ANALYSIS, IS BASED ON THE DISCOVERY THAT THERE ARE TOPOLOGICAL CRITERIA THAT ENABLE PRECOGNITION OF A CIRCUIT TO EXHIBIT UNPLANNED MODES OF OPERATION. THE RESULTS OF SNEAK-CIRCUIT ANALYSIS OVER THE LAST 5 YEARS HAVE SHOWN THAT IT IS NO LONGER NECESSARY TO ACCEPT THE SUPPOSITION THAT A FEW OPERATIONAL SURPRISES ARE INEVITABLE IN COMPLEX ELECTRICAL SYSTEMS. ELECTRICAL SYSTEMS CAN BE MADE FOOLPROOF FROM THE OPERATIONAL POINT OF VIEW, SPECIFICALLY, SNEAK-CIRCUIT ANALYSIS WILL DISCLOSE ALL LATENT CURRENT PATHS, INADVERTENT INHIBITS OR ACTIVATIONS, AMBIGUOUS SYSTEM INDICATIONS, AND MISLEADING CONSOLE LABELS. RELAY RACES, SNEAK GROUNDS, AND POWER SUPPLY CROSS-TIES ARE INCLUDED. THIS ARTICLE PRESENTS AN OVERVIEW OF THESE PROBLEMS AND OTHER PRODUCTS OF THE ANALYSIS AS FOUND IN AEROSPACE, COMMERCIAL, AND NUCLEAR SYSTEMS.
- 14-5-4-470 DESIGN AND EVALUATION OF FFTF CONTAINMENT  
SIMPSON, D. E.  
WESTINGHOUSE HAWFORD COMPANY, RICHLAND, WASH.  
THE FAST FLUX TEST FACILITY HAS BEEN THE SUBJECT OF AN EXTENSIVE REGULATORY REVIEW SIMILAR TO THAT FOR POWER REACTOR CONSTRUCTION PERMITS. THE REVIEW EXTENDED FROM SEPTEMBER 1970 TO EARLY 1973, BUT INTERIM AGREEMENTS ALLOWED CONSTRUCTION TO PROCEED WITHOUT DELAY. A MAJOR PART OF THE REVIEW WAS DIRECTED TO THE CONTAINMENT DESIGN AND THE DEFINITION OF APPROPRIATE BASES FOR EVALUATING THE CONTAINMENT FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR SYSTEM. STUDIES OF HYPOTHETICAL ACCIDENTS WERE CARRIED OUT FOR OVERPOWER AND LOSS OF COOLING CIRCUMSTANCES, ARBITRARILY NEGLECTING REACTOR SCRAM. INITIAL STUDIES INDICATED AN ACCIDENT ENERGY OF 150 MW-SEC OF THEORETICALLY AVAILABLE WORK TO BE REASONABLY CONSERVATIVE. MORE RECENT STUDIES, INCORPORATING PRELIMINARY RESULTS OF RESEARCH AND DEVELOPMENT BASED ON THE EARLIER STUDIES,

INDICATE THAT A MUCH LOWER ENERGY IS MORE REALISTIC. ANALYSES AND SCALE MODEL TESTS SHOW THAT THE DESIGN CAN CONTAIN THE ENERGY AT 150 MW-SEC AND MAINTAIN MECHANICAL INTEGRITY, NOT ONLY OF THE CONTAINMENT STRUCTURE BUT ALSO OF THE REACTOR VESSEL AND THE HEAT TRANSPORT SYSTEM.

- 14-5-5-482 MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL REPROCESSING OPERATIONS  
LENNEMANN, W. L.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
SINCE 1944 THE U. S. ATOMIC ENERGY COMMISSION (AND ITS PREDECESSOR, THE MANHATTAN DISTRICT) HAS BEEN OVERSEEING THE MANAGEMENT OF RADIOACTIVE WASTES FROM ITS FUEL REPROCESSING PLANTS WHICH ARE CONTRACTOR OPERATED. EXPERIENCE DURING THE YEARS HAS INDICATED THAT MANAGEMENT OF THESE RADIOACTIVE WASTES REQUIRES UNFLEETING EVALUATION AND APPRAISAL BY HIGHLY TRAINED MANAGEMENT AND MANAGEMENT GROUPS. EXPERIENCE WITH LEAKING WASTE TANKS AT HANFORD, SAVANNAH RIVER, AND THE NATIONAL REACTOR TESTING STATION TO 1972 IS SUMMARIZED. IMPORTANT RELATED ACTIVITIES ARE PERIODIC REVIEWS, FREQUENT ANALYSES, AND CONTINUOUS PLANNING. GUIDANCE IS PROVIDED FOR DESIGNERS OF FUEL REPROCESSING WASTE MANAGEMENT SYSTEMS INCLUDING SUCH FEATURES AS ACID WASTE STORAGE, DOUBLE CONTAINMENT, PROTECTION AGAINST CREDIBLE FORCES OF NATURE, FACILITIES FOR EMPTYING WASTE STORAGE TANKS, SPACE AND ACCESS FOR INSPECTION, ADEQUATE RADIATION MONITORING DEVICES CONNECTED TO A CENTRAL RECORDING STATION, AND SEGREGATION AND DIVERSION CAPABILITY FOR DISCHARGED EFFLUENT AQUEOUS STREAMS.
- 14-5-6-507 MATERIALS PERFORMANCE AT NUCLEAR POWER PLANTS  
SCOTT, E. L., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
SAFETY RELATED OCCURRENCES - FAILURES, INCIDENTS, AND DEFICIENCIES - REPORTED BY LIGHT WATER REACTOR NUCLEAR POWER PLANTS ARE REVIEWED FOR THE PERIOD 1967-1972. THE OCCURRENCES ARE LIMITED, HOWEVER, TO THOSE IN WHICH A MATERIAL FAILURE WAS INVOLVED. TABLES ARE GIVEN FOR EACH YEAR, INDICATING THE FACILITY AND COMPONENTS INVOLVED, THE CAUSE OF FAILURE, AND THE AREA IN WHICH THE DEFICIENCY ORIGINATED (I.E., MATERIAL SELECTION, DESIGN, FABRICATION, INSTALLATION, OPERATION, OR MAINTENANCE). EACH INCIDENT IS DISCUSSED, AND AREAS IN WHICH MATERIALS PERFORMANCE CAN BE IMPROVED ARE INDICATED.
- 14-6-1-563 NUCLEAR EMERGENCY PLANNING IN THE STATE OF NEW JERSEY  
AMATO, C. G.  
STATE OF NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION,  
TRENTON, N. J.  
TO MEET THE NECESSITY FOR A PUBLIC EMERGENCY PLAN FOR LARGE SCALE RADIATION INCIDENTS, THE STATE GOVERNMENT OF NEW JERSEY HAS DEVELOPED PIPAG, PROCEDURES FOR IMPLEMENTING PROTECTIVE ACTION GUIDES. PIPAG IS A CONTINGENCY PLAN BASED ON COOPERATIVE, PRUDENT PREPLANNING, AIMED TOWARD MAINTAINING PUBLIC CONFIDENCE AND CONTROLLING DOSE AND DOSE COMMITMENTS. THE PLAN IS BASED ON THE LAW, GEOGRAPHY, RESOURCES, AND POLICIES OF NEW JERSEY. IT MAXIMIZES THE USE OF EXISTING RESOURCES AND RELIES ON THE CONCEPT OF CIVIL DEFENSE ORGANIZATIONS AS LOCAL GOVERNMENTS IN AN EMERGENCY. BOTH THE TECHNOLOGY AND SOCIOLOGY ASPECTS OF A REACTOR ACCIDENT ARE CONSIDERED SINCE PIPAG, IF EVER IMPLEMENTED, WILL DEAL WITH COMMUNITIES OF PEOPLE. THE SOCIAL CONCEPTS OF DISASTER AND REACTOR ACCIDENTS ARE INTRODUCED, AND THE FACTORS AFFECTING DISASTERS, AS WELL AS PROTECTIVE ACTION LEVELS, ARE DISCUSSED.
- 14-6-1-574 STATE RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION  
NUCLEAR SAFETY EDITORIAL STAFF AT OAK RIDGE NATIONAL LABORATORY,  
OAK RIDGE, TENN.  
FOLLOWING THE RELATED PUBLIC AND STATE AWARENESS OF TWO INCIDENTS THAT OCCURRED AT THE DRESDEN NUCLEAR POWER STATION IN 1970 AND 1971, THE STATE OF ILLINOIS UNDERTOOK A SEPARATE INVESTIGATION TO ASSURE THAT THE PUBLIC HEALTH AND SAFETY OF THE PEOPLE OF ILLINOIS ARE ADEQUATELY SAFEGUARDED. THIS INVESTIGATION WAS CONDUCTED IN PART BY DR. RALPH LAPP, A PRIVATE NUCLEAR CONSULTANT. HIS REPORT, SUBMITTED TO THE ILLINOIS COMMERCE COMMISSION ON DEC. 7, 1972, EXAMINES THE INCIDENTS AND SUBSEQUENT REVIEWS IN DETAIL AND MAKES CONCLUSIONS AND RECOMMENDATIONS RELEVANT TO A STATES RESPONSIBILITY TO ITS PUBLIC. TO THE EXTENT THAT THIS INFORMATION WOULD BE PERTINENT TO THE INTERACTION WHICH MAY BE EXPECTED BETWEEN ANY UTILITY AND ITS STATE GOVERNMENT, THE RELEVANT CONCLUSIONS ARE PRESENTED; TAKEN FROM THE LAPP REPORT.
- 14-6-1-576 SITING PRACTICE AND ITS RELATION TO POPULATION  
PIPER, H. P. + BRIDDLESON, F. A.  
PROJECT MANAGEMENT CORPORATION, CHICAGO, ILL. AND OAK RIDGE  
NATIONAL LABORATORY, OAK RIDGE, TENN.  
A STUDY WAS MADE TO DETERMINE THE RELATION BETWEEN POWER REACTOR SITES AND THE SURROUNDING POPULATION IN THE UNITED STATES AND IN SOME FOREIGN COUNTRIES. RESULTS SHOW THAT THE POPULATION VS. DISTANCE ENVELOPE REPRESENTED BY A COMBINATION OF THE INDIAN POINT AND ZION SITES HAS SERVED AS AN UPPER BOUNDARY TO CURRENT SITING PRACTICE. IT IS ALSO SHOWN THAT THE APPLICATION OF ENHANCED SAFETY FEATURES HAS HAD NO DISCERNIBLE EFFECT ON THE SELECTION OF SITES.

- 14-6-2-586 POWER PLANT SAFETY AND EARTHQUAKES  
SMITH, C. B.  
APPLIED NUCLEONICS COMPANY, LOS ANGELES, CALIF.  
THIS ARTICLE STRESSES THE IMPORTANCE OF CONSIDERING SEISMIC EFFECTS IN THE DESIGN OF POWER PLANTS FOR ELECTRICITY GENERATION, WITH EMPHASIS ON NUCLEAR POWER PLANTS. THE POTENTIAL EFFECTS ON PLANT PERFORMANCE ARE DESCRIBED, METHODS FOR SEISMIC ANALYSIS ARE REVIEWED, AND THE NEED FOR SEISMIC INSTRUMENTATION AND TESTING ARE DISCUSSED.
- 14-6-2-597 PROBABILITY AND CONSEQUENCES OF TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE  
SHAPPERT, L. B. \* BROBST, W. R. \* LANGHAAR, J. W.  
SISLER, J. A.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN. \* U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C. \* E. I. DU PONT DE NEMOURS AND COMPANY, WILMINGTON, DEL. \* U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
FOR 1980 THE PROJECTED ELECTRICAL GENERATING CAPACITY OF NUCLEAR POWER PLANTS IN THE UNITED STATES IS ABOUT 130 MW(M), THIS, IN TURN, WILL GENERATE THOUSANDS OF SHIPMENTS OF RADIOACTIVE MATERIALS ANNUALLY. THE PROBABILITY OF ACCIDENTS INVOLVING THESE SHIPMENTS WITHIN THE PUBLIC DOMAIN HAS BEEN ESTIMATED AND BROKEN DOWN INTO FIVE SEVERITY CATEGORIES. IT IS ESTIMATED THAT IN 1980 THE SHIPMENTS CONSIDERED WOULD BE INVOLVED IN LESS THAN 20 ACCIDENTS, MOST OF WHICH WOULD RESULT IN ONLY MODERATE DAMAGE TO THE SHIPPING SYSTEM AND NO SIGNIFICANT NUCLEAR RELATED HAZARDS. AN ESTIMATE WAS MADE OF THE EFFECT OF AN EXTREMELY SEVERE ACCIDENT INVOLVING LOSS OF CONTAMINATED COOLANT FROM A SPENT FUEL SHIPPING CASK AND THE POSSIBLE EXPOSURE TO THE PUBLIC. AS A RESULT OF THE ESTIMATES, IT IS CONCLUDED THAT THE LIKELIHOOD OF ANY SERIOUS RADIOLOGICAL INJURY IS VERY SMALL AND THE TRANSPORTATION OF NUCLEAR MATERIALS IN THE FUEL CYCLE HAS A HIGH DEGREE OF SAFETY.
- 14-6-3-605 COMPARATIVE RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS  
HOWARD, R. S. \* SCHULTZ, M. A.  
PENNSYLVANIA STATE UNIVERSITY, UNIVERSITY PARK, PENN.  
FIVE REACTOR PROTECTION SYSTEMS HAVE BEEN ANALYZED USING A MONTE CARLO SIMULATION TECHNIQUE TO SOLVE FOR SYSTEM RELIABILITY AS A FUNCTION OF TEST AND REPAIR INTERVAL. THE SYSTEMS WERE EVALUATED FOR BOTH SAFETY RELIABILITY AND PROTECTION AGAINST FALSE SHUTS. THE ANALYSIS TECHNIQUE IS DESCRIBED IN DETAIL, WITH EMPHASIS ON THE ASSUMPTIONS MADE AND THE VALIDITY OF THE RESULTS. A METHOD OF SCALING THE INPUT FOR THE MONTE CARLO PROGRAM BY VARYING THE REPAIR INTERVAL IS DEVELOPED. THE SYSTEMS ANALYZED INCLUDE FOUR COMMERCIAL REACTOR PROTECTION SYSTEMS, EACH DESIGNED BY A DIFFERENT MANUFACTURER, AND A PROPOSED SYSTEM, SUGGESTED AT PENNSYLVANIA STATE UNIVERSITY. THE RELIABILITIES OF THE SYSTEMS ARE COMPARED BY EXAMINING SYSTEM FAILURE PROBABILITIES. CONSIDERABLE DIFFERENCES IN PERFORMANCE WERE FOUND IN THE VARIOUS SYSTEMS, SUGGESTING THAT STILL BETTER CONFIGURATIONS MAY YET BE OBTAINED.
- 14-6-4-618 SAFETY DESIGN BASES OF THE HTGR  
WESSMAN, G. L. \* MOPPETE, T. R.  
GULF GENERAL ATOMIC COMPANY, SAN DIEGO, CALIF.  
THE HIGH TEMPERATURE GAS-COOLED REACTOR (HTGR) HAS INHERENT AND DESIGN SAFETY FEATURES THAT ARE SIGNIFICANT AND UNIQUE, REQUIRING A NUMBER OF SAFETY CRITERIA AND APPROACHES THAT DIFFER MARKEDLY FROM OTHER REACTOR TYPES. FIRST, THIS ARTICLE BRIEFLY REVIEWS THE DESIGN OF HTGR PLANTS THAT HAVE BEEN BUILT AND ARE BEING OFFERED IN THE UNITED STATES. IT THEN REVIEWS THE SAFETY CONSIDERATIONS IN THE DESIGN OF THE PLANTS NOW BEING OFFERED. THE UNIQUE FEATURES, THEIR DEVELOPMENT, AND THEIR EFFECTS ON SAFETY CRITERIA ARE DESCRIBED, WITH PARTICULAR EMPHASIS ON THE DESIGN BASES OF THE PRESTRESSED CONCRETE REACTOR VESSEL.
- 14-6-4-634 SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES  
ESTREICH, P. J.  
EASCO SERVICES INCORPORATED, NEW YORK, N. Y.  
A MATHEMATICAL BASIS IS DEVELOPED TO PROVIDE THE PRACTICING ENGINEER WITH A METHOD FOR SIZING AIR CLEANING SYSTEMS FOR NUCLEAR FACILITIES. IN PARTICULAR, GENERAL FORMULAS ARE PROVIDED TO RELATE CLEANING AND CONTAMINATION DYNAMICS OF AN ENCLOSURE SUCH THAT SAFE CONDITIONS ARE OBTAINED WHEN WORKING CREWS ENTER. INCLUDED IN THESE CONSIDERATIONS IS THE SIZING OF AN AIR CLEANING SYSTEM TO PROVIDE RAPID DECONTAMINATION OF AIRBORNE RADIOACTIVITY. MULTIPLE NUCLIDE CONTAMINATION SOURCES, LEAK RATE, DIRECT RADIATION, CONTAMINANT MIXING EFFICIENCY, FILTER EFFICIENCIES, AIR CLEANING SYSTEM OPERATIONAL MODES, AND CRITERIA FOR MAXIMUM PERMISSIBLE CONCENTRATIONS ARE INTEGRATED INTO THE PROCEDURE.
- 14-6-5-643 PROBLEMS AND TECHNIQUES FOR REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM MINE ATMOSPHERES  
GOODWIN, A.  
U.S. DEPARTMENT OF THE INTERIOR, WASHINGTON, D.C.  
VENTILATION WITH FRESH AIR HAS BEEN, AND WILL CONTINUE TO BE, THE PRIMARY SOLUTION FOR CONTROLLING RADON AND RADON DAUGHTER ACTIVITY IN MINES. HOWEVER, PROCEDURES TO MAKE THE VENTILATION

PROCESS MORE EFFECTIVE AND TO REDUCE CONTAMINATION HAVE BEEN PROPOSED, SUCH AS SEALING OFF OF OLD WORKINGS, THE USE OF COATINGS TO REDUCE RADON INFLOW, AND MINE PRESSURIZATION. AIR CLEANING TECHNIQUES HAVE PROVED SUCCESSFUL IN CERTAIN APPLICATIONS. FOR EXAMPLE, RADON DAUGHTERS CAN BE REMOVED BY MECHANICAL FILTERING AND BY ELECTROSTATIC PRECIPITATION METHODS, BOTH OF WHICH REMOVE CONDENSATION NUCLEI TO WHICH RADON DAUGHTERS BECOME ATTACHED. THE RADON GAS THAT PASSES THROUGH CONTINUES TO DECAY, BUT, IN THE ABSENCE OF CONDENSATION NUCLEI, THE DAUGHTERS HAVE LARGE DIFFUSION LENGTHS AND ARE TRAPPED ON THE WALLS OF AIR COURSES, THUS INHIBITING THEIR GROWTH. RADON GAS HAS BEEN SUCCESSFULLY REMOVED FROM AIR, ALTHOUGH THERE ARE NO KNOWN REPORTS OF THIS HAVING BEEN DONE IN OPERATING MINES. IT HAS BEEN CAPTURED ON ACTIVATED CHARCOAL AND SILICA GEL AND CHEMICALLY REMOVED BY REACTING WITH A HALOGEN FLUORIDE AND A METAL FLUORIDE.

- 14-6-5-651 THE ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY COMMISSION  
JABLON, S.  
NATIONAL ACADEMY OF SCIENCES, WASHINGTON, D.C.  
THE ATOMIC BOMB CASUALTY COMMISSION (ABCC) WAS AUTHORIZED IN NOVEMBER 1947, WHEN IT BECAME APPARENT TO THE EARLIER INVESTIGATION TEAM THAT LONG TERM STUDIES OF THE SURVIVORS WERE REQUIRED. THE ABCC WAS ESTABLISHED UNDER THE NATIONAL RESEARCH COUNCIL OF THE NATIONAL ACADEMY OF SCIENCES AND HAS SINCE, IN COOPERATION WITH THE JAPANESE INSTITUTE OF HEALTH, MAINTAINED A MEDICAL SURVEILLANCE OF MORE THAN 100,000 INDIVIDUALS. THE EXAMINATIONS REVEALED NO SIGNIFICANT CHANGE IN GENETIC EFFECTS, ALTHOUGH EFFECTS ON GROWTH, MENTAL RETARDATION, AND LENTICULAR OPACITIES WERE OBSERVED. THE MAJOR EFFORT OF THE STUDY HAS BEEN CONCERNED WITH MORTALITY STUDIES, WHEREIN THE RADIATION EFFECTS ARE MANIFESTED CHIEFLY THROUGH CHANGES IN THE OCCURRENCE OF CANCER. THE INCIDENCE OF LEUKEMIA AS A FUNCTION OF DOSE, AGE, AND TIME HAS BEEN OBTAINED. FOR SURVIVORS WHO HAD THE LARGEST DOSE, OVER 200 RADS, CANCER DEATHS HAVE BEEN ABOUT 60 PERCENT HIGHER THAN EXPECTATION. NO NOTICEABLE DIFFERENCE IN DEATH RATES WAS OBSERVED FOR ANY CAUSE EXCEPT CANCER. THE STUDIES ARE CONTINUING, AS THEY SHOULD, AT LEAST THROUGHOUT THE LIFETIME OF THE EXPOSED SURVIVORS.
- 14-6-6-660 SWITCH FAILURES AT NUCLEAR FACILITIES  
COLBERT, W. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
SWITCH FAILURES IN NUCLEAR POWER PLANTS ARE REVIEWED FOR THE PERIOD 1964 TO MARCH 1973. THE TYPES OF FAILURES, SYSTEMS AFFECTED, AND THE NUMBER OF FAILURES ARE TABULATED, AND TECHNIQUES FOR MINIMIZING FAILURES ARE DISCUSSED.
- 15-1-1-001 REGULATION OF NUCLEAR POWER REACTORS AND RELATED FACILITIES  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE U.S. ATOMIC ENERGY COMMISSION (AEC) HAS THE RESPONSIBILITY TO PROTECT THE HEALTH AND SAFETY OF THE PUBLIC BY ASSURING THAT AN OWNER/OPERATOR DESIGNS, BUILDS, AND OPERATES, AND MAINTAINS THE INTEGRITY OF, A NUCLEAR FACILITY OVER ITS LIFETIME IN ACCORDANCE WITH THE CRITERIA, CODES, STANDARDS, AND REGULATORY JUDGMENTS DIRECTED TOWARD THAT END. THIS ARTICLE DISCUSSES THE PHILOSOPHY AND MEANS FOR PROTECTING THE PUBLIC HEALTH. THE RELEVANT AEC RULES AND REGULATIONS, AS WELL AS THE DETAILS OF THE LICENSING PROCESS AND THE AEC INSPECTION PROGRAM, ARE SUMMARIZED.
- 15-1-3-015 IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION  
HAGEN, E. W. + KERLIN, T. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
IN RECOGNITION OF THE SIGNIFICANT ADVANCES BEING MADE IN THE FIELD OF NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION, THE INTERNATIONAL ATOMIC ENERGY AGENCY ORGANIZED A SERIES OF BIENNIAL SYMPOSIUMS ON THE SUBJECT. THESE MEETINGS PROVIDED SPECIALISTS FROM THE MEMBER STATES WITH AN OPPORTUNITY FOR A COMPREHENSIVE EXCHANGE OF INFORMATION ON THE CURRENT INTERNATIONAL STATUS OF THIS IMPORTANT FIELD. IN THIS ARTICLE THE DISCOURSE FROM THE FIRST MEETING (VIENNA, 1969) IS SUMMARIZED, THE PROCEEDINGS FROM THE SECOND MEETING (VIENNA, 1971) ARE REVIEWED, AND SOME OF THE PRESENTATIONS MADE AT THE THIRD MEETING (PRAGUE, 1973) ARE DISCUSSED.
- 15-1-4-030 THE ECCS RULE-MAKING HEARING  
COTTELL, W. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE GENESIS, EXPOSITION, AND SOME OF THE RAMIFICATIONS OF THE ECCS RULE-MAKING HEARING, DOCUMENT RM-50-1, ARE REVIEWED. WHEN THE AEC PROMULGATED THE INTERIM ACCEPTANCE CRITERIA (IAC) IN JUNE OF 1971, A SERIES OF EVENTS WAS INITIATED WHICH IS STILL BEING FELT BY THE NUCLEAR COMMUNITY. THIS ARTICLE EXAMINES BRIEFLY WHAT THE EMERGENCY CORE COOLING SYSTEM (ECCS) IS AND HOW IT PERFORMS IN BOTH PWRs AND BWRs, AS WELL AS THE RESULTS OF THE VARIOUS STUDIES AND RESEARCH AND DEVELOPMENT (R+D) PROGRAMS THAT WERE FITTANT AT THAT TIME. THE RESULTING CONTROVERSIES FOLLOWING PUBLICATION OF THE IAC PRECIPITATED THE HEARING, WHICH BEGAN JAN. 27, 1972, AND ENDED JULY 25, 1973. THE COURSE OF THE HEARING AND THE AEC CONCLUDING STATEMENT - IN

EFFECT, PROPOSED REVISED CRITERIA - ARE SUMMARIZED. ALTHOUGH THE PROPOSED CRITERIA HAVE NOT YET BEEN ADOPTED, THE RAMIFICATIONS OF THE HEARING INCLUDE A REVIEW AND REDIRECTION OF R&D PROGRAMS, CONTEMPLATED OPERATING OF SOME EXISTING PLANTS, AND NEW REACTOR DESIGNS BY THE VENDORS. THE AUTHOR CONCLUDES THAT THE HEARING WAS A NECESSARY AND CONSTRUCTIVE, IF TRAUMATIC, EXPERIENCE.

- 15-1-5-056 POPULATION DOSES FROM THE NUCLEAR INDUSTRY TO 2000 A.D.  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
DURING THE NEXT FEW DECADES, IT IS ANTICIPATED THAT THE NUCLEAR POWER INDUSTRY IN THE UNITED STATES WILL UNDERGO A REMARKABLE GROWTH. TO PROJECT THE EFFECT OF THIS GROWTH ON THE RADIATION DOSES OF THE GENERAL PUBLIC, THE U.S. ATOMIC ENERGY COMMISSION MADE A REVIEW OF CURRENT REACTOR OPERATING EXPERIENCES. FROM THIS REVIEW A DETAILED ANALYSIS OF THE RADIATION DOSE TO A MAJOR SECTION OF THE COUNTRY DUE TO EFFLUENTS FROM NUCLEAR FACILITIES FOR CONDITIONS PROJECTED FOR THE YEAR 2000 WAS UNDERTAKEN. THE STUDY INDICATES THAT THE AVERAGE DOSE TO THE U.S. POPULATION FROM NUCLEAR POWER WILL INCREASE FROM AN ESTIMATED 0.003 MR/HR PER PERSON IN 1970 TO AS MUCH AS 0.2 MR/HR IN THE YEAR 2000. THIS CONTRIBUTION REMAINS A SMALL FRACTION OF THE RADIATION DOSE FROM EITHER NATURAL OR MAN-MADE SOURCES OF IONIZING RADIATION.
- 15-1-6-067 SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972  
SCOTT, R. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
SUMMARIZED AND EVALUATED ARE 644 REPORTS OF INCIDENTS, FAILURES, AND DESIGN OR CONSTRUCTION DEFICIENCIES AT LIGHT WATER REACTOR CENTRAL POWER STATIONS DURING 1972. THE MATERIAL IS PRESENTED IN TABLES THAT INCLUDE THE FREQUENCY OF ITEMS REPORTED WITH REGARD TO COMPONENTS, SYSTEMS, CAUSES, SPECIFIC DEFICIENCIES, AND TIME OF OCCURRENCE. SELECTED FOR DISCUSSION ARE INCIDENTS THAT OCCURRED DURING CONSTRUCTION AND OCCURRENCES AT BOILING WATER AND PRESSURIZED WATER REACTORS.
- 15-1-6-076 EVALUATION OF INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER REACTORS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE REPORT EVOLVING FROM A REVIEW OF EIGHT INCIDENTS OF PRIMARY COOLANT RELEASES FROM EIGHT OPERATING BOILING WATER REACTORS BY A SEVEN MEMBER GROUP FROM THE AEC DIRECTORATE OF LICENSING AND DIRECTORATE OF REGULATORY OPERATIONS IS DESCRIBED. INCLUDED ARE SOURCES FOR OBTAINING THE REPORT AND THE COMPLETE SECTION ON CONCLUSIONS AND RECOMMENDATIONS.
- 15-2-1-127 AEC'S NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND SCHEDULES  
KOUTS, H. J. C.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
THE RESEARCH OBJECTIVES AND PROGRAM PLANS OF THE AEC'S RECENTLY ESTABLISHED DIVISION OF REACTOR SAFETY RESEARCH ARE DISCUSSED. THE PRIMARY OBJECTIVE OF THE DIVISION IS TO PROVIDE INFORMATION NEEDED BY THE AEC'S AND THE REGULATORY STAFF SO AS TO AVOID UNNECESSARILY STRICT LIMITATIONS ON THE OPERATION OF NUCLEAR POWER PLANTS. THE MEANS FOR SATISFYING PUBLIC CONCERN RELATED TO THE SAFETY OF NUCLEAR PLANTS AND THE CONSERVATISM IMPOSED BY LACK OF KNOWLEDGE, AS BEING DEVELOPED BY THE SAFETY PROGRAM, ARE DISCUSSED. THE SAFETY PROJECTS CURRENTLY SPONSORED ARE ALL RELATED TO WATER REACTOR SAFETY, ALTHOUGH SAFETY STUDIES RELATING TO THE HTGR AND THE LMBR ARE PLANNED. IN ADDITION TO THE LOFT AND THE PRP - TWO LARGE PROGRAMS WHICH HAVE BEEN UNDER WAY FOR SOME TIME - A NUMBER OF SMALLER, MORE BASIC PROJECTS ARE ALSO UNDER WAY IN THE AREAS OF BLOWDOWN HEAT TRANSFER, TWO-PHASE PUMP CHARACTERISTICS, STEAM WATER MIXING, AND PRIMARY SYSTEM INTEGRITY. SEVERAL ADDITIONAL WATER REACTOR SAFETY PROJECTS, SOME BEING INITIATED AND OTHERS BEING PLANNED, ARE IDENTIFIED AND DISCUSSED.
- 15-2-1-132 AEC TESTIMONY AT THE 1973 JCAR HEARINGS ON REACTOR SAFETY  
COTTRELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
IN PHASE IIA OF THE JOINT COMMITTEE ON ATOMIC ENERGYS HEARINGS ON REACTOR SAFETY, HELD SEPT. 25-27 AND OCT. 1, 1973, THE 5 AEC COMMISSIONERS AND 12 OF THEIR STAFF PRESENTED TESTIMONY. THIS TESTIMONY, WHICH IS REVIEWED HERE AS REPORTED IN THE HEARING RECORD, WAS CONCERNED WITH ALL ASPECTS OF COMMISSION ACTIVITIES RELATED TO THE NUCLEAR POWER-REACTOR PROGRAM, INCLUDING (1) REACTOR SAFETY RESEARCH AND DEVELOPMENT, (2) WASTE-MANAGEMENT INVESTIGATIONS, (3) THE PROTECTION OF MATERIALS AND FACILITIES, AND (4) THE AEC'S REGULATORY ACTIVITIES AS WELL AS THOSE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS AND THE ATOMIC SAFETY AND LICENSING BOARD PANEL. THE PRESENTATIONS AS A WHOLE REFLECT TREMENDOUS ACTIVITY ON THE PART OF THE AEC TO PROVIDE FOR THE SAFE UTILIZATION OF THIS ENERGY RESOURCE. THE PRESENTATION DISCUSSED IN DETAIL MANY ACTUAL AND POTENTIAL PROBLEMS, INCLUDING NEEDED SAFETY RESEARCH, THE ACCIDENT RISK STUDY, WASTE MANAGEMENT EXPERIENCE, SABOTAGE, DIVERSION, REACTOR LICENSING, INSPECTION, OPERATING EXPERIENCE, AND STANDARDS DEVELOPMENT.

- 15-2-2-146 IAEA-INGFR MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHMENT  
WILLIARD, R. K.  
HANFORD ENGINEERING DEVELOPMENT LABORATORY, RICHLAND, WASH.  
SPECIALISTS FROM SIX NATIONS PARTICIPATED IN A WORKING-GROUP MEETING ON THE TECHNIQUES AND TECHNOLOGY OF SODIUM COMBUSTION AND ITS EXTINGUISHMENT. THE MEETING WAS HELD IN RICHLAND, WASH., ON MAY 22-25, 1972. THE PRINCIPAL TOPICS CONSIDERED WERE DETECTION OF SODIUM LEAKS AND FIRES, EXTINGUISHMENT OF SODIUM FIRES, AND CONTROL OF COMBUSTION PRODUCTS. ALTHOUGH MUCH INFORMATION ON THESE TOPICS IS NOW AVAILABLE, THE LMFBR INDUSTRY WILL REQUIRE ADDITIONAL DEVELOPMENT IN ALL AREAS.
- 15-2-3-151 ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS  
AEC REGULATORY STAFF  
AEC  
THE ANTICIPATED TRANSIENTS WITHOUT SCRAM (ATWS) REPORT FOR WATER COOLED NUCLEAR POWER PLANTS PROVIDES A GENERAL EXPLANATION OF THE POSSIBILITY OF OCCURRENCE OF AN ATWS EVENT AND OF THE NATURE OF THE RESULTANT CONSEQUENCES. THE RELIABILITY REQUIRED OF THE PROTECTION OR SHUTDOWN SYSTEM TO REDUCE THE ATWS TO AN ACCEPTABLE RISK IS DETERMINED, AND DESIGN ASPECTS AND FAILURE ANALYSES OF THE PROTECTION SYSTEM ARE DISCUSSED. THE REGULATORY STAFFS CONCLUSIONS ARE GIVEN, AND, WITH THE OBJECTIVE OF IMPROVING REACTOR PLANT SAFETY AND PROTECTION SYSTEM RELIABILITY, AN IMPLEMENTATION PROGRAM INCLUDING BACKFITTING IS PRESENTED.
- 15-2-3-154 SAFETY ASSESSMENT OF REACTOR SYSTEMS  
GREEN, A. E.  
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY, WARRINGTON, LANCASHIRE, ENGLAND  
THE PRACTICE IN THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY IS TO CARRY OUT INDEPENDENT RELIABILITY AND SAFETY ASSESSMENTS OF THOSE REACTOR SYSTEMS ON WHICH SAFETY IS DEPENDENT. THE INDEPENDENT ASSESSMENT IS COMPLEMENTARY TO THE DESIGN PROCESS, AND, WHEN THE RESULTS ARE IN AGREEMENT, GREATER CONFIDENCE IS PLACED IN PROCEEDING WITH THE DEVELOPMENT OF THE SYSTEM OR PROJECT. PRESENTED ARE VIEWPOINTS IN THE UNITED KINGDOM ON HOW SAFETY OF SYSTEMS SHOULD BE PREDICTED, EMPLOYING COMPONENT FAILURE PROBABILITIES INTERPRETED IN THE LIGHT OF 'REAL-WORLD' CONSIDERATIONS. THE TYPE OF SAFETY ASSESSMENT DESCRIBED HAS BEEN SUCCESSFUL IN A NUMBER OF APPLICATIONS, AND THESE BENEFITS ARE REVIEWED.
- 15-2-4-163 EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINMENT SYSTEM  
WADE, G. E.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.  
THE CONTAINMENT SYSTEM FOR BOILING-WATER REACTORS HAS EVOLVED FROM THE DRY SPHERICAL TYPE USED ON DRESDEN 1 THROUGH FOUR GENERATIONS OF PRESSURE SUPPRESSION TYPES. THE MARK I, II, AND III PRESSURE SUPPRESSION CONTAINMENT SIZES AND ARRANGEMENTS ARE PRESENTED, AND THE REASONS FOR THE DESIGN EVOLUTION ARE DISCUSSED. THE FIVE BASIC MODELS IN THE PRESSURE SUPPRESSION ANALYTICAL MODEL AND A TYPICAL RESPONSE TO A LOSS OF COOLANT ACCIDENT ARE DESCRIBED. THE TEST PROGRAM BEING CONDUCTED TO VERIFY THE NEW PRESSURE SUPPRESSION HORIZONTAL VENT DESIGN IS BRIEFLY DESCRIBED. OVERALL DESIGN CHARACTERISTICS OF THE EMERGENCY CORE COOLING SYSTEM NETWORK, WHICH IS ESSENTIAL IN MAINTAINING THE INTEGRITY OF THE CONTAINMENT, ARE OUTLINED. THE NEW MARK III CONTAINMENT DESIGN ELIMINATES THE NEED FOR INVENTING. THE DESIGN OBJECTIVES ARE OUTLINED FOR THE SYSTEM THAT HANDLES THE HYDROGEN GENERATED BY THE INITIAL METAL WATER REACTION OF THE ZIRCONIUM.
- 15-2-4-173 NEW ACCEPTANCE CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
IN A 140-PAGE REPORT ISSUED DEC. 26, 1973, THE ATOMIC ENERGY COMMISSION ESTABLISHED REVISED ECCS DESIGN CRITERIA, GAVE THE SCHEDULE FOR THEIR IMPLEMENTATION, AND PRESENTED A DETAILED TECHNICAL JUSTIFICATION FOR THE REVISIONS. BECAUSE OF THE INTEREST IN THIS MATTER, WE ARE PRESENTING HERE THE NEW CRITERIA AND THE INTRODUCTION TO THE AFOREMENTIONED REPORT WHICH SUMMARIZES THE COMMISSIONS POSITION. THESE SECTIONS ARE PRESENTED BELOW AS THEY APPEAR IN THE COMMISSION DOCUMENT EXCEPT THAT REFERENCED MATERIAL HAS BEEN EXPANDED AND PLACED AT THE END OF THE ARTICLE AND FOOTNOTES HAVE BEEN INCORPORATED INTO THE TEXT. THE LENGTH OF THE REPORT PRECLUDED PUBLICATION HERE OF THE DETAILED TECHNICAL RATIONALE, BUT THAT MAY BE FOUND IN THE DECEMBER 1973 ISSUE OF REGULATORY ADJUDICATION ISSUANCES (RAI-73-12), PAGES 1095-1138. THE ECCS RULE-MAKING HEARING, DOCKET RM-50-1, WHICH LED TO THIS COMMISSION REPORT, WAS SUMMARIZED IN NUCLEAR SAFETY, VOL. 15, NO. 1, PAGES 30-55.
- 15-2-5-185 RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGICAL HEALTH  
DEVORE, S. T.  
U.S. DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE, WASHINGTON, D.C.  
THE BUREAU OF RADIOLOGICAL HEALTH OF THE DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE HAS NUMEROUS RESPONSIBILITIES REGARDING THE LIMITATION OF MANS EXPOSURE TO IONIZING AND NONIONIZING RADIATIONS. THIS ARTICLE SUMMARIZES MANY OF THE BUREAUS

ACTIVITIES IN 1972 IN DISCHARGING THESE RESPONSIBILITIES. INCLUDED HEREIN ARE BRIEF REPORTS ON THE BUREAU'S WORK IN THE FOLLOWING AREAS, (1) STUDIES OF DIAGNOSTIC X-RAY EXPOSURES, (2) DEVELOPMENT OF X-RAY-MACHINE SAFETY STANDARD, (3) X-RAY-USER TRAINING AND EDUCATION, (4) DEVELOPMENT OF LASER AND INDUSTRIAL X-RAY STANDARDS, (5) DEVELOPMENT OF MICROWAVE-OVEN STANDARD, (6) ENFORCEMENT ACTIVITIES, (7) IMPROVED PROTECTION IN THE HANDLING OF RADIOACTIVE MATERIALS, AND (8) RESEARCH ON BIOLOGICAL EFFECTS.

- 15-2-5-190 FOG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLING TOWERS  
HANNA, S. R.  
AIR RESOURCES ATMOSPHERIC TURBULENCE AND DIFFUSION LABORATORY, OAK RIDGE, TENN.  
METHODS OF DETERMINING FOG AND DRIFT DEPOSITION DUE TO EMISSIONS FROM EVAPORATIVE COOLING TOWERS ARE REVIEWED AND FORMULAS SUGGESTED THAT CAN BE USED AS A BASIS FOR CALCULATIONS. THE GAUSSIAN PLUME FORMULA IS RECOMMENDED FOR CALCULATING FOG CONCENTRATIONS FROM WHICH VISIBILITY CAN BE ESTIMATED. FOR DRIFT DROPLETS WITH DIAMETERS GREATER THAN 200 MICROMETERS, DEPOSITION IS CALCULATED BY BALLISTICS METHODS, KNOWING THE ENVIRONMENTAL WIND SPEED AND RELATIVE HUMIDITY AND THE VERTICAL VELOCITY OF THE PLUME AND THE DROPLET. EVAPORATION OF THE DROPLETS IS ACCOUNTED FOR. DRIFT DROPLETS WITH DIAMETERS LESS THAN 200 MICROMETERS ARE ASSUMED TO BE DISPERSED ACCORDING TO THE GAUSSIAN PLUME FORMULA, WITH THE PLUME TILTED DOWNWARD TO ACCOUNT FOR THE SETTLING SPEED OF THE DROPLET.
- 15-2-6-198 SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER REACTOR FACILITIES  
THOMPSON, D.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
THE EDITORS OF NUCLEAR SAFETY HAD PREVIOUSLY BEEN EXTRACTING INFORMATION ON RECENT OCCURRENCES FROM THE MORE COMPREHENSIVE FILES OF THE NUCLEAR SAFETY INFORMATION CENTER. WE ARE PLEASED TO INITIATE IN THIS ISSUE A SUMMARY USING PRINTOUT FROM THE RECENTLY ESTABLISHED FILE ON ABNORMAL OCCURRENCE REPORTS WHICH HAS BEEN DEVELOPED BY THE OFFICE OF OPERATIONS EVALUATION, AEC DIRECTORATE OF REGULATORY OPERATIONS.
- 15-3-1-241 WATER REACTOR SAFETY RESEARCH INFORMATION MEETING  
COTTELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE IS A REVIEW OF THE WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE AEC DIVISION OF REACTOR SAFETY RESEARCH, HELD AT AEC HEADQUARTERS, WASHINGTON, D. C., DEC. 4-6, 1973. OVER 150 PEOPLE ATTENDED THE MEETING, BUT NO PROCEEDINGS ARE PLANNED. THE MEETING INCLUDED 37 PRESENTATIONS GROUPED INTO THE FOLLOWING SESSIONS (I) SEPARATE-EFFECTS PROGRAM, (II) LOSS-OF-FLUID TEST (LOFT) PROGRAM, (III) POWER BEST FACILITY (PBF) PROGRAM, (IV) LOSS-OF-COOLANT (LOCA) ANALYSIS PROGRAMS, (V) REACTOR SAFETY STUDIES, (VI) REGULATORY TECHNICAL ASSISTANCE PROGRAMS, (VII) HEAVY SECTION STEEL TECHNOLOGY PROGRAM, (VIII) REACTOR PRIMARY COOLANT SYSTEM PIPE RUPTURE STUDIES, AND (IX) VENDOR REACTOR SAFETY PROGRAMS. IT IS APPARENT FROM THESE PRESENTATIONS THAT THE AEC IS SPONSORING EXTENSIVE PROGRAMS IN THE AREAS OF BOTH LOCA AND PRIMARY SYSTEM INTEGRITY, BUT MUCH WORK REMAINS TO BE DONE. BRIEF SUMMARIES OF ALL PRESENTATIONS ARE INCLUDED.
- 15-3-1-262 THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE FWPCA AND RELATED LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS  
DAVIS, J. P.  
CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.  
THIS TWO PART ARTICLE PRESENTS A GENERAL OVERVIEW OF THE NEW FEDERAL WATER POLLUTION CONTROL ACT (ENACTED IN OCTOBER 1972) AND DISCUSSES ITS IMPACT ON THE REGULATION OF NUCLEAR POWER FACILITIES. PART I, INCLUDED HERE, DESCRIBES THE PERMIT PROGRAM FOR THE NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM, WHICH REPLACES THE REFUSE ACT PERMIT PROGRAM AND REQUIRES A PERMIT FOR THE DISCHARGE OF ANY SUBSTANCE TO THE WATERWAYS OF THE UNITED STATES.
- 15-3-2-276 PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PLANTS  
WALL, I. B.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.  
THE RISK TO THE PUBLIC FROM AN AIRCRAFT STRIKING A NUCLEAR POWER PLANT HAS BEEN EVALUATED IN A QUANTIFIED MANNER. AIRCRAFT ACCIDENT DATA HAVE BEEN ANALYZED TO ESTIMATE THE PROBABILITY OF AN AIRCRAFT STRIKING A TYPICAL NUCLEAR POWER PLANT AT SITES ADJACENT TO AND REMOTE FROM AN AIRPORT. IN THE EVENT THAT AN AIRCRAFT STRIKES A BUILDING, THE REGION OF IMPACT IS GENERALLY RESTRICTED TO A LOCAL COMPONENT. TWO MODES OF SIGNIFICANT DAMAGE ARE DELINEATED (1) PERFORATION AND (2) LOCAL COLLAPSE. METHODS HAVE BEEN DEVELOPED TO ESTIMATE THE CONDITIONAL PROBABILITIES OF SUCH STRUCTURAL DAMAGE GIVEN AN AIRCRAFT STRIKE AND PROBABILITY VALUES CALCULATED FOR A REPRESENTATIVE STRUCTURE. ACTUAL RISK TO THE PUBLIC (PROBABILITY VS. RADIOACTIVE-RELEASE MAGNITUDE) MAY BE ESTIMATED FROM A CLASSIFICATION OF CRITICAL SAFETY COMPONENTS BY THEIR STRUCTURAL PROTECTION AND THE LIKELY RELEASE MAGNITUDE IN THE EVENT OF THEIR DAMAGE. ALL FORESEEABLE RELEASES EITHER CAUSE INSIGNIFICANT OFF-SITE DOSE OR, FOR MOST SITES, ARE ASSOCIATED

WITH VERY LOW PROBABILITIES. A BRIEF EVALUATION SHOWS THAT FIRE UPON IMPACT IS NOT A SIGNIFICANT INCREMENT OF RISK. COMPARISON OF THESE RISKS TO SOCIALLY ACCEPTABLE RISK LEVELS SHOWS THAT REACTOR SITES BEYOND 5 MILES FROM AN AIRPORT OR AWAY FROM A BUSY AIR CORRIDOR SHOULD BE ACCEPTABLE. OTHER POTENTIAL SITES WOULD REQUIRE INDIVIDUAL EXAMINATION, AND, IN SOME CASES, HARDENING OF THE STRUCTURE MAY BE NECESSARY.

- 15-3-2-285 ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING CASE, E. G.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
IN AN ARTICLE DERIVED FROM TESTIMONY AT A RECENT PUBLIC HEARING ON AN OPERATING LICENSE FOR PRAIRIE ISLAND 1 AND 2, AEC TESTIMONY AS TO THE PROBABILITY OF A SPECIFIC CLASS 9 ACCIDENT-A SUDDEN LOSS-OF-COOLANT ACCIDENT (LOCA) ACCOMPANIED BY A SERIOUS FAILURE OF EMERGENCY CORE COOLING WAS PRESENTED. IN ARRIVING AT THE CONCLUSION THAT THE PROBABILITY FOR SUCH AN EVENT WOULD BE LESS THAN 10 (EXP-7) PER REACTOR YEAR AND THAT THE ENVIRONMENTAL RISK OF SUCH AN ACCIDENT WAS NEGLIGIBLE, FAILURE PROBABILITIES WERE ASSIGNED TO THREE STEPS IN THE ACCIDENT SEQUENCE. THE LIKELIHOOD OF A SUDDEN MAJOR LOCA WAS IN THE RANGE 10 (EXP-3)-(EXP-5) PER REACTOR YEAR, THE LIKELIHOOD OF SERIOUS EMERGENCY CORE COOLING SYSTEM FAILURE WAS IN THE RANGE 10 (EXP-2)-(EXP-4) PER REACTOR YEAR, AND THE LIKELIHOOD OF CONTAINMENT BREACH WAS IN THE RANGE 10 (EXP-3)-(EXP-4). THIS ARTICLE SUMMARIZES THE COMMISSIONS RATIONALE FOR ITS PROBABILITY ESTIMATES.
- 15-3-3-292 AAS STANDARD N18.8 ON DESIGN BASES FOR PROTECTIVE SYSTEMS FERGUSON, R. L.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
THE STANDARDS COMMITTEE OF THE AMERICAN NUCLEAR SOCIETY HAS DEVELOPED CRITERIA RELATED TO ESTABLISHING THE DESIGN BASES FOR THE INTEGRATED RESPONSE OF THE ACTUATOR SYSTEMS, THE PROTECTION SYSTEMS, AND THEIR SUPPORTING SYSTEMS TO THE POSTULATED ACCIDENTAL EVENTS THAT MIGHT OCCUR DURING THE LIFE OF NUCLEAR POWER STATIONS. THESE CRITERIA REPRESENT THE FIRST ATTEMPT TO DEVELOP CRITERIA FOR THE INTEGRATED RESPONSE OF THE SEVERAL SYSTEMS THAT PROTECT THE STATION AND THE PUBLIC.
- 15-3-4-295 THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED NEUTRON ABSORBER FOTRE, R. E. + ALVEZ, D. L.  
DOW CHEMICAL COMPANY, ROCKY FLATS, COLO.  
RASCHE RINGS HAVE BEEN USED FOR CRITICALITY PREVENTION IN THE STORAGE OF ENRICHED URANIUM-235 SOLUTION FOR OVER 8 YEARS AT THE DOW CHEMICAL COMPANY'S NUCLEAR SAFETY LABORATORY AT ROCKY FLATS, COLO. UNDER NEARLY IDEAL STORAGE CONDITIONS, THE RELATIVELY PURE, LOW ACID SOLUTION HAS CAUSED NO CORROSION. PRODUCTION PLANTS HANDLING INDUSTRIAL GRADE SOLUTIONS EXPERIENCE GREATER CORROSION, REQUIRING OCCASIONAL RING REPLACEMENT. MATERIAL ACCOUNTABILITY PROCEDURES ALLOW MASS BASED INVENTORY MEASUREMENTS TO 0.1 PERCENT. A NOVEL VOLUME CALIBRATION TECHNIQUE ENHANCES THE ACCURACY AND HEALTH PHYSICS SAFETY OF GOOD MATERIAL CONTROL, WHICH IN TURN CONTRIBUTES TO NUCLEAR SAFETY. THE MORE AN INDUSTRIAL LIQUID DIFFERS FROM THE PRESENT SOLUTION, THE LESS APPLICABLE ARE THE CONCLUSIONS REPORTED HERE.
- 15-3-4-302 SEPARATION AND CONTAINMENT OF NOBLE GASES ( A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS ) BARTON, C. J.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE NOBLE GASES SYMPOSIUM HELD IN LAS VEGAS, NV., SEPT. 24-28, 1973, COVERED ALL IMPORTANT ASPECTS OF THIS TOPIC, INCLUDING SEPARATION AND CONTAINMENT CONSIDERED HERE. CHARCOAL BEDS, AT AMBIENT OR LOWER TEMPERATURES, PROVIDE A WIDE RANGE OF DELAY TIMES TO PERMIT DECAY OF THE SHORT LIVED RARE GASES. MORE SOPHISTICATED TECHNIQUES, SUCH AS CRYOGENIC SYSTEMS AND ABSORPTION IN LIQUID FLUOROCARBONS, CAN MINIMIZE THE VOLUME OF LONG LIVED SEPARATED RARE GAS, PRINCIPALLY KRYPTON-85, FOR LONG TERM STORAGE. CONTAINMENT OF KRYPTON-85 IN PRESSURIZED STEEL CYLINDERS STORED IN WELL ENGINEERED FACILITIES IS THE PREFERRED METHOD AT PRESENT.
- 15-3-5-306 IAEA-WMO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE ATMOSPHERE HOSKER, R. P., JR.  
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION OAK RIDGE, TENN.  
THIS ARTICLE IS A REVIEW OF A SYMPOSIUM ON THE BEHAVIOR OF RADIOACTIVE ATMOSPHERIC CONTAMINANTS, THE SYMPOSIUM WAS HELD IN VIENNA, NOV. 12-16, 1973. THEORETICAL AND EXPERIMENTAL REPORTS ON LOCAL, REGIONAL, AND GLOBAL DISPERSION OF EFFLUENTS ARE DISCUSSED, AS ARE THE PRODUCTION AND ENVIRONMENTAL IMPACT OF THE EFFLUENTS.
- 15-3-5-311 RELEASES OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972 NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
PRESENTED IN THIS ARTICLE IS A TABULATION OF RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS FOR CALENDAR YEAR 1972. THE DATA INCLUDED ARE THOSE REPORTED BY THE LICENSEE EXCEPT FOR CERTAIN CALCULATIONS MADE BY THE AEC REGULATORY STAFF. A SIMILAR REPORT WAS MADE FOR 1971. IT IS



ALSO SHOWN IN THIS ARTICLE THAT THE RADIOACTIVITY IN EFFLUENTS FROM LICENSED NUCLEAR POWER PLANTS HAS GENERALLY BEEN LOW IN COMPARISON WITH THE LIMITS SET FORTH IN THE U.S. ATOMIC ENERGY COMMISSIONS 10 CFR, PART 20, STANDARDS FOR PROTECTION AGAINST RADIATION.

- 15-3-6-316 VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE PRESENTS THE RESULTS OF THREE INDEPENDENT SURVEYS OF DATA DESCRIBING MALFUNCTIONS OF VALVES USED IN REACTOR FACILITIES DURING THREE SEPARATE BUT OVERLAPPING TIME INTERVALS AND A FOURTH SURVEY OF EXPERIENCE CONCERNING THE STRUCTURAL INTEGRITY OF VALVES. NONE OF THE VALVE PROBLEMS COVERED BY THE REVIEWS HAVE POSED A THREAT TO THE HEALTH AND SAFETY OF THE OFF-SITE PUBLIC. HOWEVER, IN A FEW CASES, VALVE MALFUNCTIONS HAVE LED TO NONRADIOTOLOGICAL INJURIES TO PLANT PERSONNEL. THE APPARENT RATES OF MALFUNCTION OF VALVES RANGED FROM 2.5 TO 9.1 PER PLANT PER YEAR, ALTHOUGH THE HIGHER NUMBER IS BELIEVED BIASED BY A LARGE AMOUNT OF PREOPERATIONAL TEST DATA. THE FOURTH SURVEY INDICATED THAT 15 PERCENT OF THE VALVES DID NOT MEET WALL THICKNESS SPECIFICATIONS.
- 15-4-1-375 THE AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS  
RASMUSSEN, W. C.  
MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.  
THE U.S. ATOMIC ENERGY COMMISSION INITIATED A REACTOR SAFETY STUDY IN SEPTEMBER 1972 TO ESTIMATE THE PROBABILITY OF OCCURRENCE OF VARIOUS POTENTIAL ACCIDENTS IN LIGHT WATER NUCLEAR POWER PLANTS AND OF THEIR CONSEQUENCES. THE STUDY IS DIVIDED INTO SEVEN MAJOR TASKS, INCLUDING SUCH TOPICS AS THE IDENTIFICATION OF ACCIDENT SEQUENCES, THE ASSIGNMENT OF PROBABILITIES, FISSION PRODUCT TRANSPORT IN EACH ACCIDENT SEQUENCE, FISSION PRODUCT DISTRIBUTION IN THE ENVIRONMENT, HEALTH EFFECTS AND PROPERTY DAMAGE, NONNUCLEAR RISKS, AND INTERPRETATION AND COMMUNICATION OF THE MEANING OF LOW PROBABILITY EVENTS TO Nontechnical READERS. A FINAL REPORT IS EXPECTED IN THE SUMMER OF 1974.
- 15-4-1-383 THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL  
GOODRICH, W. H.  
U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
(EDITORS NOTE - THIS ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM THE TESTIMONY OF THE ATOMIC SAFETY AND LICENSING BOARD (ASLB) PANEL CHAIRMAN, NATHANIEL H. GOODRICH, BEFORE THE JOINT COMMITTEE ON ATOMIC ENERGY OF THE U.S. CONGRESS ON SEPT. 27, 1973. CHAIRMAN GOODRICH OUTLINES THE ASLB WORK LOAD AND EXPLAINS HOW BOARDS ARE APPOINTED. VARIOUS FACTS OF THE HEARING PROCESS ARE DISCUSSED, INCLUDING SPECIFICALLY THE LEGAL BASIS, CONDUCT, ASSETS AND CONTRIBUTIONS, AND OPTIMIZATION. SOME RECENT EXPERIENCES ARE ALSO MENTIONED.) THE FUNCTION OF THE ATOMIC SAFETY AND LICENSING BOARD (ASLB) IS TO CONDUCT HEARINGS, AS NEEDED, PURSUANT TO SEC. 191 OF THE ATOMIC ENERGY ACT. HEARINGS ARE CONDUCTED IN EACH INSTANCE BY THREE MEMBER BOARDS APPOINTED FROM THE MEMBERSHIP OF THE ASLB PANEL, WHICH WAS RECONSTITUTED FOR THIS SOLE PURPOSE IN NOVEMBER 1971. PRIOR TO THAT TIME, PANEL OFFICIALS ALSO WERE RESPONSIBLE FOR APPELLATE REVIEW OF HEARING BOARD DECISIONS. THE APPELL FUNCTION IS NOW CONDUCTED SEPARATELY BY BOARDS APPOINTED FROM AN ATOMIC SAFETY AND LICENSING APPEAL PANEL, WHICH OPERATES INDEPENDENTLY OF THE ASLB PANEL.
- 15-4-2-387 PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES  
ADVISORY COMMITTEE REACTOR SAFEGUARDS, U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.  
(EDITOR'S NOTE - THIS ARTICLE WAS ADAPTED FROM SECTION 5 OF 'REPORT ON THE INTEGRITY OF REACTOR VESSELS FOR LIGHT WATER POWER REACTORS,' WASH-1285, PUBLISHED BY THE AEC ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN JANUARY 1974. THE EDITORS FELT THAT THE STATISTICAL DATA ON PRESSURE VESSEL FAILURES PRESENTED HERE WOULD BE OF PARTICULAR INTEREST TO THE READERS OF NUCLEAR SAFETY. THOSE INTERESTED IN THE BACKGROUND AND SUPPORTING MATERIAL PRESENTED IN THE REMAINDER OF THE REPORT MAY OBTAIN A COMPLETE COPY FROM THE SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE, WASHINGTON, FOR \$1.20.) OPERATING EXPERIENCE WITH NUCLEAR REACTOR PRESSURE VESSELS IS INADEQUATE, BOTH WITH RESPECT TO THE NUMBER OF VESSEL YEARS OF SERVICE AND THE NUMBER OF KNOWN DEFECTS, TO PERMIT A DIRECT STATISTICAL DETERMINATION OF THE PROBABILITY OF FAILURE. THUS AN ALTERNATE APPROACH HAS BEEN TAKEN WHICH INVOLVES THE FOLLOWING STEPS, 1. CONSIDERATION OF OPERATIONAL AND FAILURE DATA FOR NONNUCLEAR TYPES OF PRESSURIZED COMPONENTS, SUCH AS BOILER DRUMS AND UNFIRED PRESSURE VESSELS. 2. CLASSIFICATION OF THESE NONNUCLEAR VESSEL FAILURES INTO THREE CATEGORIES ADOPTED FOR THIS ARTICLE. 3. COMPARISON OF THE DESIGN, CONSTRUCTION, INSPECTION, AND OPERATING PROCEDURES USED FOR BOILER DRUMS AND UNFIRED PRESSURE VESSELS WITH THOSE USED FOR NUCLEAR REACTOR VESSELS, AND ESTIMATION OF THE EFFECTS OF ANY DIFFERENCES ON THE RELATIVE PROBABILITY OF FAILURE OF THE TWO TYPES OF VESSELS. 4. UTILIZATION OF THE INFORMATION FROM THE ABOVE STEPS TO APPRAISE THE PROBABILITY OF DISRUPTIVE REACTOR VESSEL FAILURE.

- 15-4-2-399 PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS  
WALL, I. B.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.  
A METHOD IS DESCRIBED FOR ESTIMATING THE POTENTIAL HAZARD TO A NUCLEAR POWER STATION FROM MAJOR FLOODING OF A NEARBY RIVER. THE METHOD, APPLIED TO THE MONTICELLO REACTOR SITE FOR ILLUSTRATION, USES HISTORICAL DATA TO ESTIMATE BOTH THE PROBABLE MAGNITUDES AND THE PROBABILITIES OF OCCURRENCE OF FLOODS DURING THE 50-YEAR LIFE OF THE PLANT. THIS APPROACH AVOIDS THE LONG EXTRAPOLATIONS FROM LIMITED DATA ASSOCIATED WITH ATTEMPTS TO ESTIMATE THE MAGNITUDE OF THE PROBABLE MAXIMUM FLOOD, WHICH MAY HAVE A RETURN PERIOD OF 10,000 YEARS, AND PERMITS THE CALCULATION OF CONFIDENCE LIMITS ASSOCIATED WITH DEVIATION FROM THE EXPECTED BEHAVIOR. ON THE BASIS OF ESTIMATES OF POTENTIAL EFFECTS, IT IS CONCLUDED THAT A REASONABLE NUCLEAR PLANT DESIGN BASIS WOULD BE THE FLOOD MAGNITUDE WITH AN OCCURRENCE PROBABILITY OF 10(FIP-4) TO 10(FIP-5) DURING THE NEXT 50-YEAR PERIOD.
- 15-4-3-409 PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL REPUBLIC OF GERMANY  
SCHALLOPP, B.  
BUND SCHALLOPP FÜR KERNREAKTOR-INSTRUMENTIERUNG, BERLIN, FEDERAL REPUBLIC OF GERMANY  
THIS ARTICLE REVIEWS SOME OF THE BASIC IDEAS AND PHILOSOPHIES APPLIED TO REACTOR PROTECTION SYSTEMS IN THE FEDERAL REPUBLIC OF GERMANY FROM THE SPECIAL POINT OF VIEW OF THE AUTHOR. REVIEWED ARE THE IMPLEMENTATION AND APPLICATION OF DESIGNS FOR THE SELF-MONITORING OF ELECTRONIC SYSTEMS AND FOR THE USE OF COMPUTERS IN THE PROTECTION SYSTEMS OF EXISTING NUCLEAR POWER STATIONS.
- 15-4-3-417 THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION  
SULOUFF, M. D. + HAGEN, E. W.  
NUCLEAR PENNSYLVANIA POWER AND LIGHT COMPANY, ALLENTOWN, PA.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE 16TH ANNUAL INSTRUMENT SOCIETY OF AMERICA POWER INSTRUMENTATION SYMPOSIUM, GEARED TO THE THEME 'CHALLENGES FOR POWER INSTRUMENTATION,' IS REVIEWED. THE SYMPOSIUM PRESENTED NEW CONCEPTS IN USING EXISTING PROCESS CONTROL INSTRUMENTATION, A DISCUSSION OF AEC REGULATORY GUIDES AFFECTING INSTRUMENTATION FOR ENVIRONMENTAL MONITORING OF POWER PLANTS, AND THE NEED FOR INDUSTRY STANDARDS. NEW APPROACHES WERE PRESENTED RELATIVE TO CONTROL ROOM DESIGN, SEISMIC QUALIFICATION OF INSTRUMENTATION, DIRECT DIGITAL CONTROL DESIGNS, AND NITROUS OXIDE ABATEMENT.
- 15-4-4-423 PENETRATION TESTING FOR THE DETERMINATION OF PROPERTIES OF SOILS  
ROBINSON, G. C., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
SAFE PERFORMANCE OF MANY NUCLEAR POWER PLANTS IS INHERENTLY RELATED TO SOIL BEHAVIOR, PARTICULARLY AS AFFECTED BY THE LOADINGS THAT EARTH QUAKES MAY IMPOSE. SITES WITH COMPETENT ROCK FOUNDATIONS WILL BE INCREASINGLY DIFFICULT TO ACQUIRE BECAUSE OF INTERRELATIONS WITH ENVIRONMENT, LOAD LOCATION, AND ECONOMIC FACTORS. CONSEQUENTLY THE TECHNIQUES USED FOR ASSESSING SOIL PROPERTIES CONSTITUTE AN INTEGRAL PART OF THE INTERDISCIPLINARY REVIEW OF SUCH FACILITIES. ALTHOUGH STANDARD PENETRATION TESTING IS ONE OF THE MOST WIDELY USED TECHNIQUES FOR ASSESSING SOIL PROPERTIES, ITS LIMITATIONS ARE NOT WELL UNDERSTOOD. THIS ARTICLE REVIEWS THESE LIMITATIONS AND SUGGESTS RECOMMENDATIONS WHEREBY MORE QUANTIFIABLE SOIL TESTS MAY BE POSSIBLE.
- 15-4-4-432 TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT STRUCTURES  
MCDONALD, J. B. + MEHTA, K. C. + MINOP, J. E.  
TEXAS TECH UNIVERSITY, LUBBOCK, TEXAS  
THIS ARTICLE REVIEWS THE VARIOUS FACTORS INVOLVED IN TORNADO RESISTANT DESIGN AND EVALUATES THEIR RELEVANCE IN LIGHT OF CURRENT DESIGN CRITERIA. THE FPP SCALE RATIO OF STORMS AND THE RECORD KEEPING EFFORTS OF THE NATIONAL SEVERE STORMS FORECAST CENTER IN KANSAS CITY, MO., HAVE GENERATED DATA THAT PROVIDE A MORE CONCISE UNDERSTANDING OF THE GEOGRAPHICAL DISTRIBUTIONS OF TORNADOES AND THEIR INTENSITY. SUCH DATA HAVE RESULTED IN USEFUL REGION CRITERIA FOR THE DESIGN OF TORNADO RESISTANT NUCLEAR PLANTS. THE AEC DESIGN BASIS TORNADO AND ITS IMPLICATIONS ARE DISCUSSED, WITH SPECIFIC REFERENCE TO OCCURRENCE AND INTENSITY DATA, TORNADO - WIND MODELS, TORNADO STRUCTURE INTERACTION, AND TORNADO GENERATED MISSILES. THE USE OF TORNADO - WIND MODELS REPRESENTS A RATIONAL APPROACH TO DETERMINING THE FORCES ON STRUCTURES AND ALSO PROVIDES DATA FOR EVALUATING THE FLIGHT POTENTIAL OF MISSILES. TORNADO STRUCTURE INTERACTION, THE PHENOMENON WHEREBY THE METEOROLOGICAL EFFECTS ARE TRANSLATED INTO LOADS ON THE STRUCTURE, IS DISCUSSED AT LENGTH. A CLEAR UNDERSTANDING OF THESE LOADS CAN LEAD TO ECONOMY OF CONSTRUCTION WITHOUT COMPROMISING SAFETY. CURRENTLY THERE ARE MANY QUESTIONS RELATING TO DESIGN FOR TORNADO GENERATED MISSILES. HOPEFULLY FUTURE RESEARCH IN THIS AREA WILL LEAD TO AN UNDERSTANDING OF THE PHENOMENON AND ALLOW A RELAXING OF THE MISSILE CRITERIA.

- 15-4-5-440 REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE HEARING  
SNYDER, W. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
(EDITOR'S NOTE - AT THE REQUEST OF THE NUCLEAR SAFETY EDITORS, W. S. SNYDER HAS PREPARED THE FOLLOWING REVIEW OF THE FINAL ENVIRONMENTAL STATEMENT (FES) IN THE 'AS LOW AS PRACTICABLE' HEARING. SNYDER MAKES NO ATTEMPT TO COMMENT ON EXTERNAL EVENTS THAT OCCURRED EITHER BEFORE OR SINCE THE HEARING OR ON INFORMATION INCLUDED IN THE HEARING BUT NOT IN THE FES. HOWEVER, IN THIS REVIEW HE HAS REACHED A COMPROMISE ON THE VARIOUS QUESTIONS AT ISSUE, A COMPROMISE THAT IS COMMENSURATE WITH HIS RESPONSIBILITY IN ACCEPTING THIS TASK.)
- 15-4-5-443 CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE HEARING  
(EDITOR'S NOTE - THE CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE 'AS LOW AS PRACTICABLE' HEARING, DOCKET NO. RA-50-2, WAS ISSUED ON FEB. 20, 1974. IN ADDITION TO THE 145-PAGE STATEMENT, THE REGULATORY STAFF SIMULTANEOUSLY RELEASED A 450-PAGE ATTACHMENT CONTAINING THE TEXT OF FIVE DRAFT REGULATORY GUIDES THAT PROVIDE MODELS AND PARAMETERS FOR CALCULATING AVERAGE EXPECTED RELEASES. THE 'AS LOW AS PRACTICABLE' HEARING, WHICH BEGAN IN JANUARY 1972, IS NOW NEARING COMPLETION, BUT IT WILL BE SEVERAL MONTHS BEFORE THE PROPOSED RULES OR SOME VARIATION OF THEM ARE PUBLISHED IN THE FEDERAL REGISTER WITH AN EFFECTIVE DATE. IN THE MEANTIME, THE REGULATORY STAFF'S CONCLUDING STATEMENT PROVIDES THE BEST INTERIM GUIDANCE AVAILABLE. ALTHOUGH THE LENGTH OF THIS STATEMENT, COMPLETE WITH THE REGULATORY STAFF'S DISCUSSION OF ITS RECOMMENDATIONS AND COST-BENEFIT CONSIDERATIONS PRECLUDES PUBLICATION HERE, WE ARE REPRODUCING THE INTRODUCTION TO THE STATEMENT (INCLUDING THE REGULATORY STAFF'S CONCLUSIONS AND RECOMMENDATIONS) AND THE PROPOSED RULE ITSELF. PERSONS INTERESTED IN MORE DETAILS SHOULD EXAMINE THE FULL REPORT, WHICH IS A PART OF THE HEARING RECORD. IN ADDITION, THE FINAL ENVIRONMENTAL STATEMENT IS REVIEWED IN THE PRECEDING ARTICLE OF THIS ISSUE OF NUCLEAR SAFETY. THE TWO SECTIONS OF THE CONCLUDING STATEMENT ARE PRESENTED HERE VERBATIM, INCLUDING THE STAFF'S USE OF FOOTNOTES AND REFERENCES.)
- 15-4-5-453 POPULATION EXPOSURE TO X-RAYS - U.S. 1973  
(EDITOR'S NOTE - WHILE THE NUCLEAR INDUSTRY IS BEING REQUIRED TO REDUCE EXPOSURE LEVELS TO 'AS LOW AS PRACTICABLE,' THE MEDICAL PROFESSION CONTINUES TO BE THE DOMINANT SOURCE OF NONBACKGROUND RADIATION EXPOSURE TO THE POPULATION. THE ENTIRE SUMMARY SECTION OF THE PUBLIC HEALTH SERVICE REPORT ON 'POPULATION EXPOSURE TO X-RAYS - U.S. 1970,' (DHEW (FDA) PUBLICATION 73-9047, IS QUOTED BELOW. ALTHOUGH THE REPORT DOES NOT PRESENT A CONCLUSION AS TO THE AVERAGE POPULATION EXPOSURE FROM MEDICAL RADIATION, SUCH A NUMBER MAY BE CALCULATED FROM THE DATA GIVEN. THE 137-PAGE REPORT INCLUDES A COMPREHENSIVE ASSESSMENT OF MEDICAL EXPOSURES IN THE UNITED STATES BY REGION, TYPE OF EXAMINATION, AGE OF EQUIPMENT, ETC., WITH THE DETAILED DATA IN APPENDICES. THE REPORT CARRIES A DATE OF NOVEMBER 1973, ALTHOUGH IT WAS DISTRIBUTED IN APRIL 1974, AND MAY BE PURCHASED FROM THE SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE, WASHINGTON, D.C.)
- 15-4-6-455 UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERMET CORES DURING OUTGASSING  
GRAY, L. S.  
SAVANNAH RIVER LABORATORY, AIKEN, SOUTH CAROLINA  
DURING ROUTINE OUTGASSING OF SCRAP URANIUM - ALUMINUM CERMET CORES, UNEXPECTED EXOTHERMIC REACTIONS RELEASED SUFFICIENT ENERGY TO MELT NINE CORES. IN THE SUBSEQUENT INVESTIGATION, COMPOUNDS IN THE SCRAP URANIUM WERE IDENTIFIED, AND THE HISTORY OF THE MATERIAL WAS DEFINED. THE INCIDENT WAS INITIATED BY REACTIONS AT ABOUT 350C BETWEEN POWDERED ALUMINUM METAL AND MIXED URANATE SALTS, WHICH RELEASED SUFFICIENT ENERGY TO INITIATE OTHER ALUMINOTHERMIC REACTIONS. A PLAUSIBLE REACTION SEQUENCE IS POSTULATED TO ACCOUNT FOR THE ENERGY RELEASED IN THE INCIDENT.
- 15-4-6-460 THE LEAK OF TANK 106-T AT HANFORD  
ROBINSON, R. A.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE REVIEWS AN INCIDENT IN WHICH APPROXIMATELY 115,000 GAL OF RADIOACTIVE LIQUID WASTE LEAKED FROM A 533,000-GAL UNDERGROUND STORAGE TANK AT THE HANFORD PLANT OF THE U.S. ATOMIC ENERGY COMMISSION IN 1973. THE ENSUING INVESTIGATION INDICATED THAT THE LEAKED MATERIAL WAS RETAINED IN THE SOIL IN THE VICINITY OF THE WASTE TANKS AND POSED NO THREAT TO THE WORKERS AND THE NEARBY COLUMBIA RIVER. HOWEVER, THE INVESTIGATION DID POINT OUT THE NEED FOR IMPROVED MONITORING PROCEDURES, WHICH ARE PRESENTLY BEING IMPLEMENTED.
- 15-5-1-513 SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUCLEAR MATERIALS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
DIVERSION OF SPECIAL NUCLEAR MATERIAL PRESENTS A THREAT AS AN EXPLOSIVE WEAPON, AS A BIOLOGICAL POISON, OR AS A RADIATION SOURCE. HOWEVER, THERE ARE ONLY A FEW STEPS IN THE NUCLEAR FUEL CYCLE WHICH ARE VULNERABLE TO DIVERSION OR SABOTAGE. THESE

STEPS ARE IDENTIFIED. THE PROTECTIVE MEASURES REQUIRED BY THE COMMISSION BOTH ON SITE AND IN TRANSIT ARE DESCRIBED, AS ARE THE RESEARCH AND DEVELOPMENT THAT ARE UNDER WAY TO IMPROVE THE CAPABILITY OF THE U.S. SAFEGUARDS.

- 15-5-1-519 UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY ASSESSMENT  
CROWLEY, J. H. + DOAN, P. L. + MCCREATH, C. R.  
UNITED ENGINEERS AND CONSTRUCTORS, INC., PHILADELPHIA, PA.  
THE SITING OF NUCLEAR PLANTS UNDERGROUND IS EXAMINED BROADLY ON THE BASIS OF TECHNICAL FEASIBILITY, DESIGN, SAFETY, AND ECONOMICS. DISCUSSION IS GENERAL FOR ALL REACTOR TYPES AND UNDERGROUND SITING ALTERNATIVES, BUT SPECIFIC DETAILS ARE MAINLY REFERRED TO A 1000-MW PRESSURIZED WATER REACTOR LOCATED IN A DEEP ROCK CAVERN. CONCLUSIONS ARE THAT CURRENT TECHNOLOGY IS ENTIRELY ADEQUATE AND THAT THE ENHANCED SAFETY POSTURE OF AN UNDERGROUND SITE MAY FACILITATE CLOSE-IN SITING AND WITH NO GREATER RISK OR POSSIBLY LESS THAN THAT OF A SURFACE SITE. ECONOMIC TRADE-OFFS ARE IDENTIFIED, AND IT HAS NOT BEEN CLEARLY ESTABLISHED THAT UNDERGROUND SITING WOULD RESULT IN AN ECONOMIC PENALTY.
- 15-5-2-535 COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS  
WINTON, M. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
MANY COMPUTER CODES HAVE BEEN DEVELOPED FOR USE IN VARIOUS ASPECTS OF NUCLEAR ACCIDENT ANALYSIS. THE NUCLEAR SAFETY INFORMATION CENTER HAS SEPARATED OVER 180 OF THESE CODES INTO 13 GROUPS AND TABULATED THEM. THE RESULTING TABLE GIVES NAME OF CODE, MACHINE ON WHICH IT IS OPERABLE, ITS LANGUAGE, CORPORATE AUTHOR, A STATEMENT OF WHAT THE CODE DOES, A REFERENCE CITATION, AND DATE OF THE REFERENCE.
- 15-5-3-554 A PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION TO DETECT INCIPIENT FAILURE IN NUCLEAR PRESSURE VESSELS  
BELL, R. L.  
CELESCO, CANOGA PARK, CALIF.  
SIGNIFICANT ADVANCES IN THE TECHNOLOGY AND APPLICATION OF THE ACOUSTIC EMISSION PHENOMENON TO DETECTION, LOCATION, AND CHARACTERIZATION OF INCIPIENT FAILURE MECHANISMS IN PRESSURE VESSELS HAVE BEEN MADE OVER THE LAST SEVERAL YEARS. IN ADDITION TO PROGRAMS CARRIED OUT BY DEVELOPMENT LABORATORIES AND PRIVATE RESEARCH FACILITIES, THE GOVERNMENT AND THE UTILITY INDUSTRY HAVE ALSO SPONSORED PROGRAMS THAT HAVE GREATLY INCREASED THE SCOPE AND APPLICABILITY OF THE TECHNIQUE TO NUCLEAR PRESSURE VESSEL INSPECTION. BOTH PERIODIC HYDROTEST MONITORING WITH ACOUSTIC EMISSION AND CONTINUOUS ACOUSTIC EMISSION SURVEILLANCE ARE FEASIBLE FOR APPLICATION TO BOILING WATER REACTOR AND PRESSURIZED WATER REACTOR PRESSURE VESSELS. BOTH APPROACHES HAVE THEIR LIMITATIONS AND ADVANTAGES BUT, IN GENERAL, APPEAR TO PROVIDE MORE INFORMATION ON THE INTEGRITY OF THE NUCLEAR PRESSURE VESSEL THAN ANY OTHER NONDESTRUCTIVE TESTING TECHNIQUE PRESENTLY USED. ALTHOUGH RESEARCH AND DEVELOPMENT WORK IS CONTINUING WITH REGARD TO BETTER DETERMINING THE SEVERITY OF THE ACOUSTIC EMISSION SOURCES, CONSIDERABLE FIELD APPLICATION IS ALREADY PROVIDING USEFUL BASE-LINE AND OPERATING INFORMATION.
- 15-5-4-572 THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY PLATS PLANT I.  
SCHUSKE, C. L. + MCCARTHY, J. D.  
THE DOW CHEMICAL COMPANY, GOLDEN, COLO.  
THE NUCLEAR SAFETY PROGRAM FOR THE DOW-AFC PRODUCTION AND RESEARCH COMPLEX AT ROCKY PLATS BEGAN IN 1952. SINCE THEN, CONSIDERABLE CHANGES HAVE BEEN MADE IN THE RESPONSIBILITIES OF THE NUCLEAR SAFETY AND OPERATING GROUPS. THESE RESPONSIBILITIES INCLUDE THE TRAINING OF PERSONNEL, THE AUDITING OF OPERATIONS, AND THE PERFORMING OF MAXIMUM CREDIBLE ACCIDENT REVIEWS OF PLANT FACILITIES. SIGNIFICANT CHANGES IN ADMINISTRATIVE POLICIES AND DOCUMENTATION OF THESE POLICIES WERE BROUGHT ABOUT OWING TO THE INFLUENCE OF THE COMPANY MANAGEMENT COMMITTEES AND THE AFC ALBUQUERQUE OPERATIONS OFFICE. THESE CHANGES ARE DISCUSSED HERE. PART II, TO APPEAR IN THE NEXT ISSUE OF NUCLEAR SAFETY, DISCUSSES THE IMPACT OF OUR EXPERIMENTAL AND COMPUTATIONAL PROGRAMS ON PLANT OPERATIONS.
- 15-5-5-585 THE LAW AND LOW LEVEL RADIATION  
EASON, C. F. + ST. DENIS, W. Y.  
U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
ONE OF THE RESPONSIBILITIES OF THE HEALTH PHYSICIST IS TO RECOMMEND AND ENFORCE RADIATION PROTECTION STANDARDS BASED UPON RECOGNIZED OCCUPATIONAL RADIATION EXPOSURE GUIDES. IT FOLLOWS, THEREFORE, THAT THE HEALTH PHYSICIST, BECAUSE OF HIS BACKGROUND AND TECHNICAL KNOWLEDGE, WILL PLAY A KEY ROLE IN EVALUATING A CLAIM ALLEGEDLY ARISING OUT OF EXPOSURE TO IONIZING RADIATION. THIS ARTICLE EXAMINES A NUMBER OF LATENT RADIATION INJURY CASES WITH PARTICULAR EMPHASIS ON THE KINDS OF RADIATION RECORDS OFFERED IN EVIDENCE, THE NATURE OF THE EXPERT TESTIMONY BY BOTH THE HEALTH PHYSICIST AND THE MEDICAL EXPERT, AND THE CONCLUSIONS OF THE COURT OR BOARD IN THE FINAL ADJUDICATION OF THE CLAIM. THE ARTICLE ALSO EXPLORES THE VIEWS OF THOSE WHO HOLD THAT THE PRESENT LEGAL SYSTEM IN THE UNITED STATES IS NOT APPROPRIATE FOR THE HANDLING OF LATENT INJURY CLAIMS.

- 15-5-5-592 **SYMPOSIUM ON COOLING-TOWER ENVIRONMENT - 1974**  
TAYLOR, F. G., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A SYMPOSIUM CONCERNING THE ENVIRONMENTAL ASPECTS OF COOLING TOWERS WAS HELD AT THE UNIVERSITY OF MARYLAND, COLLEGE PARK, MD., MAR. 4-6, 1974. THE MEETING, SPONSORED BY THE U.S. ATOMIC ENERGY COMMISSION AND THE STATE OF MARYLAND POWER PLANT SITING PROGRAM, CONSISTED OF SIX TECHNICAL SESSIONS WITH INVITED SPEAKERS FROM UNIVERSITY, GOVERNMENT, INDUSTRY, AND UTILITY SPECIALISTS PRESENTING A STATE OF THE ART SURVEY. ATTENDANCE WAS LIMITED BY INVITATION TO THOSE ACTIVELY INVOLVED IN COOLING TOWER RESEARCH IN ORDER TO ENHANCE THE FREE EXCHANGE OF IDEAS IN DISCUSSION FOLLOWING THE PRESENTATIONS. ONE HUNDRED AND FIFTY ATTENDEES, INCLUDING REPRESENTATIVES FROM FOUR FOREIGN COUNTRIES, EXCHANGED VIEWS TO MESH THE VARIED TECHNICAL SESSIONS INTO A COMPREHENSIVE SYMPOSIUM.
- 15-5-6-599 **EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY**  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A STUDY WAS MADE OF NUCLEAR AND FOSSIL POWER PLANT OPERATING EXPERIENCE TO COMPARE PLANT AVAILABILITY AND TO DETERMINE THE CAUSE AND SAFETY SIGNIFICANCE OF PLANT OUTAGES FOR NUCLEAR PLANTS. RESULTS SHOWED THAT THE AVAILABILITY OF THE NUCLEAR POWER PLANTS IS LOWER THAN THE GENERAL DESIGN OBJECTIVE DURING THE FIRST TWO 3 YEARS OF COMMERCIAL SERVICE. FOLLOWING THIS PERIOD OF OPERATION, HOWEVER, AVERAGE AVAILABILITY HAS APPROACHED OR EXCEEDED 80 PERCENT. THE AVERAGE AVAILABILITY OF NUCLEAR PLANTS HAS BEEN NEARLY THE SAME AS THAT OF FOSSIL PLANTS OF APPROXIMATELY THE SAME SIZE DURING THE 12-YEAR PERIOD 1960 TO 1971. APPROXIMATELY HALF OF THE FORCED OUTAGES OF NUCLEAR PLANTS RESULTED FROM EVENTS THAT ARE CONSIDERED TO HAVE SAFETY SIGNIFICANCE. IN NO CASE, HOWEVER, WAS THERE INJURY TO THE PUBLIC OR A RELEASE OF RADIOACTIVE MATERIALS IN EXCESS OF PERMISSIBLE LEVELS.
- 15-6-1-651 **NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS**  
YADIGAROGU, G. + ANDERSEN, S. O.  
UNIVERSITY OF CALIFORNIA, BERKELEY, CALIF.  
THIS ARTICLE IS A REVIEW OF THE CONFERENCE ON NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS, HELD IN SAN FRANCISCO, CALIF., NOV. 8-9, 1973. THE STATE OF THE ART OF MAJOR TECHNOLOGIES FOR OFFSHORE AND UNDERGROUND SITING IS REVIEWED BOTH IN TERMS OF DECOUPLING THE LICENSING OF REACTORS FROM SITE RELATED ENVIRONMENTAL FACTORS AND ENGINEERING, FINANCIAL, AND REGULATORY UNCERTAINTIES. PROBLEMS OF COMPREHENSIVE SITE EVALUATION AND TECHNOLOGY ASSESSMENT ASSOCIATED WITH THESE INNOVATIVE CONCEPTS ARE ALSO DISCUSSED. THE CONFERENCE PARTICIPANTS AGREED THAT MAJOR NEW TECHNOLOGIES FOR EXTENDING SITING OPTIONS ARE AVAILABLE. OFFSHORE BREAKWATER PROTECTED POWER PLANTS SEEM TO ENJOY ALMOST UNIVERSAL ACCEPTANCE AMONG ARCHITECT ENGINEER AND UTILITY PLANNERS, BUT OPINIONS WERE STRONGLY DIVIDED ON THE SAFETY AND ECONOMICS OF OTHER NOVEL CONCEPTS.
- 15-6-1-665 **BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS**  
HILL, R. M. + BRYAN, R. H. + NICHOLS, B. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE DESCRIBES THE EVOLUTION OF A METHOD USED TO DEVELOP BENEFIT COST ANALYSES FOR INCLUSION IN ENVIRONMENTAL STATEMENTS PREPARED FOR THE AEC DIRECTORATE OF LICENSING. THE ARTICLE DISCUSSES (1) THE HISTORY OF THE FEDERAL GOVERNMENT'S DEVELOPMENT OF BENEFIT COST ANALYSES FOR WATER RESOURCES PROJECTS, (2) THE EFFECT OF THE CALVEFT CLIFFS CASE ON AEC LICENSING ACTIVITIES, (3) THE DEVELOPMENT OF AEC GUIDES FOR PREPARATION OF ENVIRONMENTAL REPORTS AND BENEFIT COST ANALYSES AND THEIR EFFECT ON OTHER ACTIVITIES, AND (4) SOME POSSIBLE TRENDS IN THE DEVELOPMENT AND USE OF BENEFIT COST ANALYSES DEVELOPED FOR ENVIRONMENTAL REPORTS AND STATEMENTS.
- 15-6-1-673 **AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS**  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE AEC HAS SPONSORED THIS STUDY, ALSO KNOWN AS THE REACTOR SAFETY STUDY, TO MAKE A QUANTITATIVE ASSESSMENT OF THE POTENTIAL RISKS INVOLVED IN NUCLEAR POWER PLANT ACCIDENTS. THE STUDY GROUP, WHICH WAS DIRECTED BY DR. NORMAN C. RASCHUSSEN, HAS COMPLETED 2 YEARS OF WORK AND PREPARED A DRAFT REPORT ENTITLED AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS. THIS PRODIGIOUS REPORT CONSISTS OF OVER 3000 PAGES BUT FOR CONVENIENCE IS DIVIDED INTO 14 SEPARATE VOLUMES. THE SUMMARY REPORT CONSISTS OF 29 PAGES, AND THE MAIN REPORT HAS 248 PAGES. THE REMAINDER OF THE REPORT CONSISTS OF APPENDICES. REPRINTED BELOW IS THE SECTION ENTITLED INTRODUCTION AND RESULTS FROM THE DRAFT SUMMARY REPORT. WHILE THE STUDY HAS PRESENTED THE ESTIMATED RISKS FROM NUCLEAR POWER PLANT ACCIDENTS AND COMPARED THEM WITH OTHER RISKS THAT EXIST IN OUR SOCIETY, IT HAS MADE NO JUDGMENT ON THE ACCEPTABILITY OF NUCLEAR RISKS. ALTHOUGH THE STUDY RELIEVES NUCLEAR ACCIDENT RISKS ARE VERY SMALL, THE JUDGMENT AS TO WHAT LEVEL OF RISK SOCIETY SHOULD ACCEPT IS A BROADER ONE THAN CAN BE MADE HERE.

- 15-6-2-676 LOSS OF FLUID TEST INTEGRAL TEST FACILITY AND PROGRAM  
 COPLEN, H. L. + YBARRODO, L. J.  
 AERONET NUCLEAR COMPANY, IDAHO FALLS, IDAHO  
 THE LOSS OF FLUID TEST INTEGRAL TEST FACILITY WAS DESIGNED TO SIMULATE, AS NEARLY AS POSSIBLE, ALL THE IMPORTANT EFFECTS THAT ARE ANTICIPATED TO OCCUR DURING A LOSS OF COOLANT ACCIDENT IN A LARGE PRESSURIZED WATER REACTOR TYPE NUCLEAR STEAM SUPPLY SYSTEM. INTEGRAL, AS USED HERE, DEFINES AN EXPERIMENT COMBINING THE NUCLEAR, THERMAL, HYDRAULIC, AND STRUCTURAL PROCESSES OCCURRING DURING A LOSS OF COOLANT ACCIDENT AS OPPOSED TO THE SINGLE AND DUAL EFFECT, NON NUCLEAR, SMALL SCALE, THERMOHYDRAULIC EXPERIMENTS CONDUCTED TO DATE. A MINIMUM OF 19 LOSS OF COOLANT EXPERIMENTS IS PLANNED IN THE LOSS OF FLUID TEST WITH VARIOUS SIMULATED LINE BREAK LOCATIONS AND SIZES, INCLUDING SOME INITIAL ISOTHERMAL TESTS USING A CORE SIMULATOR RATHER THAN THE ACTUAL FUEL ASSEMBLIES.
- 15-6-3-691 COMPUTER CONTROL AT BRUCE NUCLEAR GENERATING STATION  
 MORRIS, D. I.  
 ATOMIC ENERGY OF CANADA LIMITED, SHERIDAN PARK, ONTARIO, CAN.  
 THE 3000-MW(E) BRUCE NUCLEAR GENERATING STATION, SCHEDULED TO GO CRITICAL IN SEPTEMBER 1975, UTILIZES DIRECT DIGITAL CONTROL FOR REACTOR REGULATION AND ELECTRIC POWER OUTPUT IN A REACTOR FOLLOWING TURBINE MODE. THE DESIGN AND OPERATING PHILOSOPHIES HAVE BEEN IMPLEMENTED SUCCESSFULLY AT OTHER NUCLEAR STATIONS WHICH ARE PRESENTLY PRODUCING POWER. THE COMPUTERS, PERIPHERALS, AND SOFTWARE OPERATING SYSTEM ARE DESIGNED TO PROVIDE A VARIETY OF HARDWARE AND SOFTWARE SELF-CHECKING FUNCTIONS SO THAT TRANSFER OF CONTROL TO THE STANDBY SYSTEM CAN BE CARRIED OUT AUTOMATICALLY AND CAN BE EITHER PARTIAL OR TOTAL, DEPENDING ON WHICH THE PARTICULAR FAILURE MODE WARRANTS. THE MAIN TASK OF THE DUAL DIGITAL COMPUTERS IS TO PROVIDE UNIT REACTOR POWER REGULATION TO CONTROL THE GENERATION OF ELECTRIC POWER TO AN OPERATOR ENTERED VALUE. A NUMBER OF FUNCTIONALLY INDEPENDENT PROGRAMS PROVIDE DIRECT DIGITAL CONTROL IN THE FORM OF ANALOG OR DIGITAL OUTPUTS TO DEVICES IN THE FIELD, SO THAT THE ENTIRE OPERATION FROM REACTOR WARMUP TO 100 PERCENT ELECTRIC POWER OUTPUT IS DONE WITHOUT OPERATOR INTERVENTION. THE MAJORITY OF THE ALARM ANNUNCIATION REQUIREMENTS FOR THE GENERATING UNIT ARE HANDLED BY THE CONTROL COMPUTERS UTILIZING HIGH-SPEED PRINTERS AND CATHODE-RAY TUBE DISPLAYS. AN EXTENSIVE OPERATOR INTERACTIVE GRAPHICAL DISPLAY SYSTEM, WHICH HAS REDUCED THE CONGESTION OF CONTROL-PANEL INSTRUMENTATION, HAS BEEN INCORPORATED IN THE UNIT'S DIGITAL CONTROL COMPUTER SYSTEM.
- 15-6-3-702 A SURVEY OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REACTOR CONTAINMENTS  
 OYEN-MEYER, H.  
 AB ATOMENERGI, SWEDISH ATOMIC ENERGY ESTABLISHMENT  
 THIS ARTICLE SUMMARIZES DATA RELATED TO THE INSTRUMENTATION, TESTING PRACTICES, AND MONITORING PROCEDURES FOR BOILING AND PRESSURIZED WATER REACTOR CONTAINMENT ATMOSPHERES. QUESTIONNAIRES WERE SENT TO A REPRESENTATIVE SELECTION OF REACTOR INSTALLATIONS IN THE UNITED STATES, WEST GERMANY, AND SWEDEN WHICH HAD EITHER RECENTLY STARTED OPERATION OR WERE STILL UNDER CONSTRUCTION. COMPILATION OF THE ANSWERS IN TABULAR FORM REVEALED SURPRISING DIFFERENCES BETWEEN THE DIFFERENT INSTRUMENT ARRAYS IN REGARD TO THE DESIGN CRITERIA EMPLOYED. THE SURVEY INDICATES THAT FURTHER INFORMATION REGARDING INSTRUMENTATION PHILOSOPHY IS NEEDED.
- 15-6-4-711 ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTRATIONS  
 BELLAMY, R. R.  
 U. S. ATOMIC ENERGY COMMISSION,  
 THE CAPABILITY OF ACTIVATED CHARCOAL TO ADSORB ELEMENTAL IODINE AND METHYL IODIDE AT LOW CONCENTRATIONS HAS BEEN EXPERIMENTALLY EVALUATED TO OBSERVE THE EFFECT OF THE VARIATION OF CERTAIN OPERATING PARAMETERS WITHIN SPECIFIED LIMITS. THE OPERATING PARAMETERS INCLUDE INLET CONCENTRATION, SUPERFICIAL VELOCITY, RELATIVE HUMIDITY, TYPE OF CHARCOAL AND IMPREGNANT, CHARCOAL MESH SIZE, DURATION OF TEST, AND BED DEPTH. THE DATA OBTAINED IN AN INTENSIVE STUDY OF THESE PARAMETERS HAVE BEEN CORRELATED ASSUMING A TWO-STEP ADSORPTION MECHANISM FOR RADIOIODINE ON ACTIVATED CHARCOAL. THE CORRELATION IS PRESENTED TO AID THE NUCLEAR INDUSTRY IN DESIGNING CHARCOAL ADSORBER SYSTEMS FOR RADIOIODINE RETENTION.
- 15-6-4-723 THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY FLATS PLANT II.  
 SCHUSKE, C. L. + MCCARTHY, J. D.  
 DOW CHEMICAL COMPANY, GOLDEN, COLO.  
 THIS IS THE SECOND PART OF A TWO PART ARTICLE ON THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S PRODUCTION AND RESEARCH COMPLEX AT ROCKY FLATS, GOLDEN, COLO. PART I (NUCL. SAFETY, 15(5)) DESCRIBED THE ADMINISTRATIVE AND CONTROL ASPECTS OF THE PROGRAM. PART II DISCUSSES THE EXPERIMENTAL AND COMPUTATIONAL PROGRAMS. THESE PROGRAMS HAVE CONTRIBUTED DATA ON THE CRITICALITY PARAMETERS NEEDED IN THE DESIGN OF NEW EQUIPMENT AND FACILITIES, AS WELL AS THE EVALUATION OF EXISTING FACILITIES. THESE DATA HAVE RESULTED IN UNIQUE EQUIPMENT DESIGNS, SUCH AS METAL MELTING CRUCIBLES AND STORAGE FACILITIES IN WHICH DOUBLING AND TRIPLING OF PROCESS BATCHES NOT

PREVIOUSLY PERMITTED HAVE BEEN SAFELY ACCOMPLISHED. THESE INNOVATIONS HAVE CONSEQUENTLY LED TO MONETARY SAVINGS IN HANDLING OF FISSILE MATERIALS.

- 15-6-5-732 BIOLOGICAL EFFECTS OF NOBLE GASES ( A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASSES SYMPOSIUM AT LAS VEGAS )  
ROHWER, P. S. + BARTON, C. J.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE NOBLE GASES SYMPOSIUM HELD IN LAS VEGAS, NEV., SEPT. 24 TO 28, 1973, COVERED ALL IMPORTANT ASPECTS OF THIS TOPIC, INCLUDING THE BIOLOGICAL EFFECTS CONSIDERED HERE. SEPARATE SESSIONS WERE DEVOTED TO THE BIOLOGICAL EFFECTS OF RADON AND OF THE OTHER NOBLE GASES, BUT SPECIAL ATTENTION WAS FOCUSED ON KRYPTON-85, THE LONGEST-LIVED NOBLE GAS RELEASED FROM NUCLEAR FACILITIES, PRINCIPALLY FUEL REPROCESSING PLANTS. THE COST BENEFIT ASPECT OF LIMITING EXPOSURE OF THE WORLD POPULATION TO LOW CONCENTRATIONS OF THIS RADIONUCLIDE WAS DISCUSSED EXTENSIVELY DURING THE SYMPOSIUM. THE MAJORITY OF THE PARTICIPANTS FELT THAT EFFECTIVE CONTROLS ON LARGE SCALE EMISSIONS OF KRYPTON-85, SUCH AS THOSE FROM FUEL REPROCESSING PLANTS, SHOULD BE INSTITUTED AS SOON AS PRACTICABLE SO AS TO MINIMIZE POSSIBLE GENETIC EFFECTS FROM THIS MAN MADE RADIOACTIVITY.
- 15-6-6-738 U. S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
STATISTICAL INFORMATION CONCERNING NUCLEAR POWER PLANT AVAILABILITY, PLANT CAPACITY, AND REACTOR AVAILABILITY FACTORS FOR 1973 WAS COMPILED FROM SEMIANNUAL REPORTS SUBMITTED TO THE U. S. ATOMIC ENERGY COMMISSION (AEC). STATISTICS SHOWED THAT PLANT AVAILABILITY DURING 1973 WAS SLIGHTLY LOWER THAN THAT REPORTED FOR 1972. A PREVIOUS OBSERVATION CONCERNING ATTAINMENT OF, AND CONTINUED PERFORMANCE AT, 80 PERCENT AVAILABILITY AFTER 3 TO 4 YEARS OPERATION WAS NOT SUBSTANTIATED BY EXPERIENCE DURING 1973 BECAUSE OF EXTENSIVE OUTAGES AT A FEW PLANTS THAT STRONGLY INFLUENCED THE AVERAGES FOR THE SMALL NUMBER OF PLANTS THAT HAVE BEEN IN OPERATION FOR 3 YEARS OR MORE. HOWEVER, PLANT AVAILABILITY AND CAPACITY FACTORS FOR NUCLEAR POWER PLANTS ARE COMPARABLE TO THOSE REPORTED ELSEWHERE FOR FOSSIL FUELED POWER PLANTS OF COMPARABLE SIZES AND AGES.
- 16-1-1-1 AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SITES  
BUCHANAN, J. R.  
HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE REVIEWS A PROPOSED REGULATORY GUIDE, POPULATION DISTRIBUTION AROUND NUCLEAR POWER PLANTS, WHICH THE AEC CONSIDERED ISSUING TO PROVIDE GUIDANCE ON ACCEPTABLE POPULATION CHARACTERISTICS FOR A NUCLEAR REACTOR SITE. THE PROPOSED AEC GUIDE INVOLVED CUMULATIVE POPULATION PROJECTIONS WITHIN 5, 20, AND 40 MILES OF THE SITE. TWO TECHNIQUES FOR EVALUATING POPULATION DISTRIBUTIONS AROUND SITES ARE ALSO DISCUSSED. THE FIRST TECHNIQUE IS THE USE OF AN UNWEIGHTED CUMULATIVE POPULATION VS. DISTANCE. THE SECOND TECHNIQUE IS CALLED A SITE POPULATION FACTOR FOR THE PURPOSE OF COMPARING SITES, AND THIS TECHNIQUE WEIGHTS POPULATION AT LONGER DISTANCES LESS THAN THE POPULATION ADJACENT TO A SITE. THE AEC IS CONTINUING WORK ON THESE POTENTIAL TOOLS. ALL PRESENTLY APPROVED SITES HAVE BEEN FOUND TO BE ACCEPTABLE IN TERMS OF POPULATION DENSITY AS WELL AS BY OTHER CONSIDERATIONS.
- 16-1-1-8 WATER REACTOR SAFETY RESEARCH INFORMATION MEETING  
COTTELL, W. B. + HOBSON, D. O. + WHITMAN, G. D.  
HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE IS A REVIEW OF THE SECOND WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE AEC DIVISION OF REACTOR SAFETY RESEARCH, HELD AT AEC HEADQUARTERS, GERMANTOWN, MD., SEPT. 19-20, 1974. THIS MEETING, ALTHOUGH SIMILAR IN SCOPE TO THE FIRST MEETING, WAS ORGANIZED SOMEWHAT DIFFERENTLY IN THAT THERE WERE ONLY FOUR TECHNICAL SESSIONS, WITH PARALLEL SESSIONS ON BOTH DAYS. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT ACCIDENT (LOCA) TEST PROGRAM, (2) FUEL BEHAVIOR PROGRAM, (3) PRIMARY SYSTEM INTEGRITY PROGRAM, AND (4) CODE DEVELOPMENT PROGRAM. OVER 275 PERSONS, INCLUDING SEVERAL FOREIGN REPRESENTATIVES, ATTENDED THE MEETING, BUT NO PROCEEDINGS ARE PLANNED. IT IS APPARENT FROM THE QUANTITY AND QUALITY OF THE TECHNICAL ACHIEVEMENTS REPORTED AT THE MEETING THAT THE CHANGES IN EXPERIMENTAL PROGRAMS, INCLUDING CONSTRUCTION AND/OR MODIFICATIONS OF FACILITIES WHICH SO DOMINATED THE TALKS AT THE FIRST MEETING, ARE BEGINNING TO PRODUCE RESULTS. BRIEF SUMMARIES OF MANY PRESENTATIONS ARE INCLUDED.
- 16-1-2-29 BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS  
BERGLES, A. E.  
IOWA STATE UNIVERSITY, IOWA CITY, IA.  
RECENT EXPERIMENTAL AND ANALYTICAL DEVELOPMENTS IN POOL BOILING BURNOUT ARE REVIEWED, AND RESULTS ARE SUMMARIZED THAT CLARIFY THE DEPENDENCE OF CRITICAL HEAT FLUX ON HEATER GEOMETRY AND FLUID PROPERTIES. NEW ANALYTICAL INTERPRETATIONS OF BURNOUT ARE DISCUSSED, AND THE EFFECTS OF SURFACE CONDITION, AGING,

ACCELERATION, AND TRANSIENT HEATING (OR COOLING) ARE DESCRIBED. AUGMENTATION OF CRITICAL HEAT FLUX, THE RELATION OF SOUND TO BURNOUT, AND NEW TECHNIQUES FOR STABILIZING ELECTRIC HEATERS AT BURNOUT ARE ALSO CONSIDERED.

- 16-1-4-81 RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS I. PRODUCTION  
EDDMAN, C. A. + REYNOLDS, A. B.  
UNIVERSITY OF VIRGINIA, CHARLOTTESVILLE, VA.  
THIS ARTICLE, PRESENTED IN TWO PARTS, REVIEWS THE BEHAVIOR OF RADIONUCLIDES PRODUCED DURING THE NORMAL OPERATION OF A LIQUID METAL COOLED FAST BREEDER REACTOR (LMFR). THE RESULTS GIVEN ARE PRIMARILY FROM THE LITERATURE, BUT SEVERAL INDEPENDENT CALCULATIONS ARE INCLUDED. NUMERICAL RESULTS ARE NORMALIZED TO A 1000-MW (T) LMFR AND ARE COMPARED WITH A SIMILAR SIZE LIGHT WATER REACTOR. SOURCES OF RADIOACTIVITY STUDIED INCLUDE PLUTONIUM AND OTHER TRANSURANIC ELEMENTS, FISSION PRODUCTS, TRITIUM, CORROSION PRODUCTS, ACTIVATION PRODUCTS, AND TRAMP FUEL. THE REVIEW ALSO INCLUDES DATA ON RADIOACTIVITY TAKEN FROM THE OPERATING EXPERIENCES OF LMFRS. DATA ARE INCLUDED FOR THE FAST REACTORS EBR-II, FERMI, SEFOR, DOUNREAY, RAPSODIE, AND BR-5, WITH LIMITED DATA FOR THE THERMAL REACTORS SRE, SRR, AND HALLAM. THIS ARTICLE (PART 1) DISCUSSES THE PRODUCTION OF RADIOACTIVITY, PART 2, SCHEDULED FOR NUCLEAR SAFETY, 16(3), WILL DISCUSS THE TRANSPORT OF RADIOACTIVITY.
- 16-1-5-60 THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS I. AEC OWNED FACILITIES  
BILPS, M. B. + COFFMAN, F. E.  
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D. C.  
PROGRAMS FOR MONITORING AND REPORTING OF RADIOACTIVITY IN EFFLUENTS ARE MAINTAINED AT ALL U.S. ATOMIC ENERGY COMMISSION (AEC) FACILITIES DISCHARGING CONCENTRATIONS OF RADIOACTIVITY THAT HAVE POTENTIAL HEALTH AND SAFETY OR ENVIRONMENTAL SIGNIFICANCE. TO ENSURE THE EFFECTIVE MANAGEMENT AND CONTROL OF EFFLUENTS IS THE OBJECTIVE OF THESE PROGRAMS. THE NATURE AND QUANTITIES OF RADIOACTIVITY DISCHARGED TO THE ENVIRONMENT VARY WIDELY FROM SITE TO SITE, PRIMARILY OWING TO THE WIDE VARIETY OF OPERATIONS AND FACILITIES. EFFLUENT CONTROL PROGRAMS AT AEC SITES ARE PRIMARILY BASED ON GUIDANCE PROMULGATED BY THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION, THE NATIONAL COUNCIL ON RADIATION PROTECTION, AND THE FEDERAL RADIATION COUNCIL. TO MAINTAIN AN OVERVIEW OF ITS EFFLUENT CONTROL PRACTICES, THE AEC HAS DEVELOPED AND INSTITUTED A COMPUTER BASED ANNUAL EFFLUENT DATA REPORTING SYSTEM TO ENSURE THAT EFFLUENT CONTROL PROGRAMS ARE PROPERLY MAINTAINED. THIS SYSTEM HAS PROVED TO BE A VERY USEFUL INTERNAL MANAGEMENT TOOL FOR EVALUATING THE EFFECTIVENESS OF EFFLUENT CONTROL PROGRAMS AND FOR IDENTIFYING POTENTIAL PROBLEM AREAS. AN EFFLUENT REDUCTION PROGRAM THAT FOCUSES ON THE REDUCTION OF QUANTITIES RATHER THAN CONCENTRATIONS OF RADIOACTIVITY HAS RESULTED IN SUBSTANTIAL REDUCTIONS IN QUANTITIES OF RADIOACTIVITY RELEASED FROM SELECTED FACILITIES.
- 16-1-5-71 THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. AEC LICENSED FACILITIES  
HIGGINBOTHAM, L. B. + COLLINS, J. T.  
NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C. AND ENVIRONMENTAL CONSULTANTS, INC., DALLAS, TEX.  
PROGRAMS FOR CONTROL AND MONITORING OF RADIOACTIVE EFFLUENTS ARE REQUIRED AT ALL FACILITIES REGULATED BY THE U.S. ATOMIC ENERGY COMMISSION (AEC). LIMITATIONS AND REQUIREMENTS FOR CONTROL AND MONITORING OF RADIOACTIVE EFFLUENTS ARE EXPRESSED IN AEC REGULATIONS ISSUED UNDER TITLE 10, CODE OF FEDERAL REGULATIONS. AEC REGULATIONS AND POLICIES FOR CONTROL OF EXPOSURES FROM RADIATION AND RADIOACTIVE MATERIALS ARE BASED PRIMARILY ON GUIDANCE PROMULGATED BY THE INTERNATIONAL COMMISSION ON RADIATION PROTECTION, THE NATIONAL COUNCIL ON RADIATION PROTECTION, AND THE FEDERAL RADIATION COUNCIL. CONDITIONS IN OPERATING LICENSES ISSUED BY THE AEC REQUIRE APPROPRIATE SURVEILLANCE AND MONITORING PROGRAMS AS A BASIS FOR DEMONSTRATING COMPLIANCE WITH AEC REGULATORY LIMITS FOR THE RELEASE OF RADIOACTIVE EFFLUENTS.
- 16-1-6-76 INCIDENT AT THE LUCYNS REACTOR  
MILLER, J. M.  
HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE LUCYNS 0.3-MW (T) EXPERIMENTAL NUCLEAR POWER STATION SUFFERED A LOSS OF CARBON DIOXIDE COOLANT AND DEUTERIUM OXIDE MODERATOR, AS WELL AS DAMAGE TO ONE OF ITS FUEL ELEMENTS, ON JAN. 21, 1969. THIS ARTICLE PRESENTS SOME OF THE PRELIMINARY RESULTS OF THE INVESTIGATION AS TO THE CAUSE OF THE INCIDENT. THE FINAL RESULTS HAVE NOT BEEN PUBLISHED.
- 16-1-6-79 IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS  
PRYOR, W. A.  
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, OAK RIDGE, TENN.  
A SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS WAS HELD OCT. 8-12, 1973, AT THE INTERNATIONAL ATOMIC ENERGY AGENCY IN VIENNA. THERE WERE 189 PARTICIPANTS FROM 35 COUNTRIES AND 4 INTERNATIONAL ORGANIZATIONS, AND 45 PAPERS WERE PRESENTED. IN ADDITION TO THE FOUR SESSIONS DEVOTED TO REVIEWS OF GENERAL OPERATING EXPERIENCE, THE MEETING



INCLUDED SESSIONS ON BEHAVIOR OF MAJOR COMPONENTS, WASTE MANAGEMENT SYSTEMS, FUELING EXPERIENCE, TESTING, AND PERSONNEL TRAINING. THIS ARTICLE REVIEWS THE EXPERIENCES DESCRIBED IN THE FORMAL PAPERS AND IN THE PANEL DISCUSSION.

- 16-2-1-127 QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER PLANTS  
BERNSEN, S. A.  
BECHTEL POWER CORPORATION, SAN FRANCISCO, CALIF.  
THIS ARTICLE IS A BRIEF REVIEW OF QUALITY ASSURANCE (QA) PRACTICES AS THEY RELATE TO THE CONSTRUCTION PHASE OF NUCLEAR POWER PLANTS. THE ARTICLE BRIEFLY OUTLINES THE EVOLUTION OF CONSTRUCTION QA REQUIREMENTS, DESCRIBES CONSTRUCTION PRACTICES AND ORGANIZATIONAL RELATIONS THAT HELP IDENTIFY THE UNIQUE CONSTRUCTION PHASE FEATURES THAT AFFECT QA PRACTICES, IDENTIFIES SOME OF THE PRINCIPAL REQUIREMENTS AND PROGRAMMATIC PROBLEMS INVOLVING CONSTRUCTION, AND DISCUSSES POTENTIAL TRENDS AND SUGGESTED GUIDELINES FOR THE IMPLEMENTATION OF PARTICULAR PRACTICES.
- 16-2-1-141 1974 AMS TOPICAL MEETING ON FAST REACTOR SAFETY  
FONTANA, M. H.  
HOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE IS A BRIEF REVIEW OF THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON FAST REACTOR SAFETY, HELD AT BEVERLY HILLS, CALIF., APR. 2-4, 1974, SPONSORED BY THE TECHNICAL GROUP ON REACTOR SAFETY AND THE LOS ANGELES SECTION OF THE AMERICAN NUCLEAR SOCIETY. PRESENTATIONS AND DISCUSSIONS ON SAFETY PHILOSOPHY, RESEARCH NEEDS, AND SAFETY PHENOMENOLOGY INDICATE STEADY PROGRESS TOWARD UNDERSTANDING THE TECHNICAL BASES OF FAST REACTOR SAFETY, ALTHOUGH DIFFERENCES OF OPINION APPEAR TO EXIST WITH RESPECT TO PHILOSOPHY OF APPLICATION TO REACTOR DESIGNS.
- 16-2-3-150 GBR-4 PROTECTION SYSTEMS - FAILURES AND THEIR CONSEQUENCES  
BOEGSMULLER, P. \* DEKAIS, J. J. \* KRAHE, A.  
PIGWATTELLI, R. \* VIEIDER, G.  
GAS BREEDER REACTOR ASSOCIATION, BRUSSELS, BELGIUM  
IN THE GBR-4 DESIGN OF A GAS COOLED FAST BREEDER REACTOR, EMPHASIS IS PLACED ON USING TO ADVANTAGE THE SINGLE PHASE CHARACTER OF THE COOLANT. SPECIFIC FEATURES OF THE PROTECTIVE SYSTEMS ARE FAIL-SAFE NEUTRON ADSORPTION, PERMANENTLY OPERATING AUXILIARY SUPPLIES, AND ATMOSPHERIC PRESSURE COOLING. A COMPUTER PROGRAM THAT USES A POINT REACTOR MODEL FOR HEAT TRANSFER AND NEUTRON KINETICS IS USED FOR TRANSIENT ANALYSIS, AND A STEAM GENERATOR DYNAMICS CODE IS USED TO DESCRIBE SECONDARY SIDE EFFECTS. ANTICIPATED DISTURBANCES IN OPERATION ARE REACTIVITY INSERTION, LOSS OF SUPPLIES, AND LOSS OF COOLANT PRESSURE. FAILURES IN REACTOR PROTECTION SYSTEMS ARE POSTULATED FOR THESE DISTURBANCES IN DECREASING ORDER OF PROBABILITY, AND THE CONSEQUENCES ARE ANALYZED AND DISCUSSED. THE RESULTS LEAD TO THE CONCLUSION THAT, OWING TO THE INHERENT CHARACTERISTICS OF THE SYSTEM AND TO THE SPECIFIC DESIGN, OCCURRENCES ARE WELL WITHIN THE LIMITS OF A TYPICAL PROBABILITY RELEASE CRITERION.
- 16-2-3-162 STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER PLANTS  
HAGEN, M. W.  
HOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS IS THE SECOND PART OF A TWO-PART ARTICLE THAT REVIEWS THE STANDBY EMERGENCY ELECTRIC POWER SYSTEMS FOR COMMERCIAL NUCLEAR POWER PLANTS. PART 1 APPEARED IN THE 14(3) ISSUE OF NUCLEAR SAFETY AND DISCUSSED THESE SYSTEMS AS THEY APPLIED TO THE EARLY PLANTS. PART 2, THE LATER PLANTS, UPDATES THE DESIGN CRITERIA AND CONSIDERATIONS SET FORTH IN PART 1 AND OFFERS SOME SUGGESTIONS FOR IMPROVING RELIABILITY AND AVAILABILITY FOR THESE SYSTEMS. TODAY, EVEN WITHIN THE CONFINES OF A SINGLE LARGE UTILITY, THE SYSTEM DESIGNS VARY BECAUSE OF THE DIFFERENT ARCHITECT ENGINEERS INVOLVED WITH THE VARIOUS PLANTS, PLANT CHARACTERISTICS VARY FROM SITE TO SITE, AND EVEN CONCEPTS CHANGE WITH TIME WITHIN A GIVEN DESIGN GROUP. SOME OF THE DESIGN PROBLEMS AND OPERATING EXPERIENCES FOR THE FOLLOW-ON PLANTS ARE EMPHATICALLY QUALITY ASSURANCE PROCEDURES NOT MENTIONED, AND SOME CONSIDERATIONS CONCERNING RELIABILITY, WHICH HAS NOT CHANGED SIGNIFICANTLY FOR THE LATER PLANTS, ARE DISCUSSED. SINCE HIGH AVAILABILITY OF THE STANDBY EMERGENCY ELECTRIC POWER SYSTEMS APPEARS TO BE THE MORE ATTAINABLE CHARACTERISTIC TO STRIVE FOR, SOME METHODS FOR ACHIEVING THIS ARE PROFFERED.
- 16-2-4-180 RADIOACTIVE HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE  
HAMSTRA, J.  
REACTOR CENTRUM NEDERLAND, THE HAGUE, NETHERLANDS  
THIS ARTICLE REVIEWS THE RADIOACTIVE HAZARDS RESULTING FROM THE DISPOSAL OF HIGH LEVEL REPROCESSING WASTES INTO A DEEP GEOLOGICAL FORMAT ON. THE TERM RADIOACTIVE HAZARD MEASURE (RHM), USED TO MEASURE THE HAZARD FROM BURIED RADIOACTIVE WASTES, IS BASED ON THE MAXIMUM RADIONUCLIDE CONCENTRATION PERMISSIBLE IN WATER. CALCULATIONS ARE MADE OF THE RHM LEVELS FOR THE HIGH LEVEL REPROCESSING WASTES OF BOTH LIGHT WATER REACTOR AND FAST BREEDER REACTOR FUELS. IN COMPARING THESE RHM LEVELS WITH THAT FOR THE NATURAL ACTIVITY OF AN EQUIVALENT AMOUNT OF URANIUM ORE AND ITS MILL TAILINGS, IT IS CONCLUDED THAT AN ACTUAL ADDITIONAL RADIOACTIVE HAZARD FOR BURIED HIGH LEVEL REPROCESSING WASTE ONLY EXISTS FOR THE FIRST 300 TO 500 YEARS AFTER BURIAL.

- 16-2-4-190 THE THIRTEENTH AEC AIR CLEANING CONFERENCE  
 KOELLER, D. W. + UNDERHILL, D. W. + FIRST, M. W.  
 HARVARD UNIVERSITY, CAMBRIDGE, MASS.  
 THE THIRTEENTH AEC AIR CLEANING CONFERENCE WAS HELD AUG. 12-15, 1975, IN SAN FRANCISCO, CALIF. A TOTAL OF 374 PEOPLE REGISTERED, INCLUDING PERSONNEL FROM ESSENTIALLY ALL FACETS OF INDUSTRY, GOVERNMENTAL AGENCIES, AND EDUCATIONAL INSTITUTIONS, PLUS REPRESENTATIVES FROM NINE FOREIGN COUNTRIES. MAJOR TOPICS WERE 1) PERFORMANCE AND RELIABILITY OF AIR CLEANING SYSTEMS 2) ADSORPTION, CONCENTRATION, AND STORAGE OF RADIOACTIVE NOBLE GASES 3) DESIGN, CONSTRUCTION, AND OPERATION OF REACTOR OFF-GAS TREATMENT SYSTEMS 4) DESIGN, TESTING, AND OPERATION OF VENTILATION SYSTEMS FOR REACTORS 5) PLUTONIUM HANDLING FACILITIES, AND FUEL REPROCESSING OPERATIONS 6) SAMPLING AND MONITORING OF AIRBORNE RELEASES, AND 7) CONTROL OF FIRES AND EXPLOSIONS. SUPPLEMENTARY SESSIONS COVERED SPECIAL PROBLEMS ASSOCIATED WITH MANAGING RADIOIODINE AND TRITIUM. A MAJOR DEFICIENCY BROUGHT OUT AT THE CONFERENCE WAS THE CONTINUED LACK OF ATTENTION BEING GIVEN TO AIR CLEANING SYSTEMS, PARTICULARLY IN THE PLANNING STAGES OF NUCLEAR FACILITIES. THERE IS A SIMILAR LACK OF ATTENTION TO THE NEEDS OF THOSE RESPONSIBLE FOR PREOPERATIONAL AND POSTOPERATIONAL TESTING OF SUCH SYSTEMS AFTER INSTALLATION. ON THE POSITIVE SIDE, THE CONFERENCE REVEALED THAT PROGRESS IS BEING MADE ON DEVELOPING PROCESSES FOR TRITIUM REMOVAL, ON CONCENTRATION AND STORAGE PROCEDURES FOR THE NOBLE GASES, AND ON METHODS FOR HANDLING AIR CLEANING PROBLEMS OF HIGH TEMPERATURE GAS COOLED REACTORS AND LIQUID METAL COOLED FAST BREEDER REACTORS. A MODEST EFFORT IS ALSO BEING DIRECTED TO THE POTENTIAL AIR CLEANING PROBLEMS ASSOCIATED WITH NUCLEAR FUSION.
- 16-2-5-234 ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACILITIES IN NEW YORK STATE  
 TERPILAK, M. S. + JOERGENSEN, B. L.  
 ENVIRONMENTAL PROTECTION AGENCY, NEW YORK CITY, N. Y.  
 THE ANNUAL QUANTITIES AND TYPES OF RADIOACTIVE MATERIALS RELEASED FROM THREE OPERATING NUCLEAR ELECTRIC GENERATING FACILITIES AND A NUCLEAR FUELS REPROCESSING FACILITY ARE PRESENTED AND DISCUSSED. THE PERIOD OF INTEREST SPANS THE YEARS 1969 TO 1972 WITH SOME ADDITIONAL DATA FOR THOSE FACILITIES OPERATING BEFORE 1969. RELEASE QUANTITIES HAVE BEEN WELL CONTROLLED, CONSIDERING THE NATURE AND VINTAGE OF THE OPERATIONS. PRESENTED ARE THE RESULTS OF ENVIRONMENTAL SURVEILLANCE RELYING MOST HEAVILY ON THE ACTIVITIES OF THE NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION. OBSERVATIONS AT INDIAN POINT 1 AND AT NUCLEAR FUEL SERVICES, INC., HAVE LED TO THE DISCOVERY OF SEVERAL FACILITY RELATED RADIOISOTOPES IN ENVIRONMENTAL MEDIA. THESE TWO FACILITIES ARE OF COMPARATIVELY EARLY VINTAGE, HAVE PRODUCED SLIGHTLY LARGER AMOUNTS OF WASTE MATERIALS, AND HAVE BEEN THE SUBJECT OF MORE COMPREHENSIVE STUDIES THAN OTHERS IN THE STATE. DOSE CONSEQUENCES TO HYPOTHETICAL PERSONS AND TO POPULATIONS WITHIN 50 MILES OF THE FACILITIES ARE ADDRESSED. IT SHOULD BE STRESSED THAT ALL INDIVIDUAL DOSES PRESENTED ARE HYPOTHETICAL. DOSE VIA THE DRINKING WATER AND COWS MILK PATHWAYS ARE PARTICULARLY CONSERVATIVE. IN EACH CASE THESE HYPOTHETICAL DOSES ARE AT LEAST AN ORDER OF MAGNITUDE OR MORE GREATER THAN THE KNOWN WORST CASE. NO EXCESSIVE EXPOSURE LEVELS ARE KNOWN TO HAVE EXISTED. ALL OPERATIONS HAVE RESULTED IN POSTULATED EXPOSURE LEVELS WELL WITHIN APPLICABLE REGULATIONS OR GUIDELINES, GENERALLY BEING A SMALL PERCENTAGE OF THESE VALUES. POPULATION DOSES HAVE BEEN SURPRISINGLY CONSISTENT THROUGH THE PERIOD OF INTEREST. THEY ARE INSIGNIFICANT IN COMPARISON TO THE DOSE TO THE POPULATION OF THE STATE FROM NATURAL OR MEDICAL SOURCES.
- 16-2-6-22 POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED INSTRUMENTATION  
 NUCLEAR SAFETY STAFF  
 ORNL NATIONAL LABORATORY, OAK RIDGE, TENN.  
 FROM JAN. 1972, TO JUNE 30, 1973, 222 INSTANCES OF SET-POINT DRIFT IN NUCLEAR POWER PLANT PROTECTIVE INSTRUMENTATION DEVICES WERE REPORTED AS ABNORMAL OCCURRENCES BY NUCLEAR POWER PLANT LICENSEES. THIS ARTICLE PRESENTS THE RESULTS OF A STUDY PERFORMED TO ASSESS THE CAUSES AND SIGNIFICANCE OF THESE INCIDENTS.
- 16-2-6-224 DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS  
 CROOKS, J. L. + VISSING, G. S.  
 U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.  
 AVAILABLE TEST AND OPERATING EXPERIENCE DATA ARE PROVIDED FOR DIESEL GENERATOR UNITS INSTALLED AS STANDBY ELECTRIC POWER SUPPLIES IN OPERATING NUCLEAR POWER PLANTS. THE DATA INCLUDE FAILURES EXPERIENCED DURING PERIODIC SURVEILLANCE TESTS AND DURING ABNORMAL EVENTS IN WHICH THE STANDBY POWER SYSTEM WAS REQUIRED TO OPERATE AUTOMATICALLY. THE DIESEL GENERATOR FAILURES EXPERIENCED DURING SURVEILLANCE TESTING OF THE UNITS ARE TABULATED FOR EACH OPERATING NUCLEAR PLANT AND ARE CLASSIFIED BY MANUFACTURER, BY THE ELECTRICAL CAPACITY OR SIZE OF THE DIESEL-GENERATOR UNIT, AND BY THE COMPONENT OR SUBSYSTEM INITIATING THE FAILURE. THE PROBABILITY OF SUCCESSFUL PERFORMANCE COMPUTED FROM THESE SURVEILLANCE TEST DATA IS LESS THAN 0.95 AT A CONFIDENCE LEVEL OF 50 PERCENT FOR MOST UNITS.

- 16-3-1-273 REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING  
 PERLLE, E. + BAUMAN, H.  
 HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON NUCLEAR POWER PLANT SITING, HELD IN PORTLAND, OREG., AUG. 25-28, 1974, INCLUDED SESSIONS DEVOTED TO THE GOVERNMENT AND SITING, METHODOLOGIES OF SITE SELECTION, SPECIAL AND TECHNICAL ISSUES, UTILITY SITING EXPERIENCE, AND SOCIAL AND PUBLIC ACCEPTANCE ISSUES. HIGHLIGHTS OF THE MEETING INCLUDED SPEECHES BY AEC CHAIRMAN DIXIE LEE RAY, MICHAEL McCLOSKEY OF THE SIERRA CLUB, AND SAUL LEVINE OF THE AEC PROBABILISTIC RISK STUDY TEAM. UTILITIES' PROBLEMS AND PRACTICES IN SITING NUCLEAR POWER PLANTS WERE DISCUSSED BY FOUR AMERICANS, AS WELL AS REPRESENTATIVES OF FRENCH AND SWISS, UTILITIES. THE LACK OF WHOLLY SUITABLE SITES AND CONCERN WITH PUBLIC ACCEPTANCE WERE COMMON THEMES ADDRESSED IN WIDELY DIFFERENT MANNERS. INSTITUTIONAL CHANGES IN SITING PROCEDURES AND APPROACHES WERE SUGGESTED IN BOTH THE FIRST SESSION ON GOVERNMENTAL ROLES AND THE FINAL SESSION ON SOCIAL ISSUES.
- 16-3-1-282 NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITING  
 COPP, D. F.  
 HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN. + FEDERAL ENERGY ADMINISTRATION, WASHINGTON, D. C.  
 MEETING THE NATION'S FUTURE ENERGY REQUIREMENTS PORTENDS A MAJOR ROLE FOR NUCLEAR POWER. THIS COULD RESULT IN HUNDREDS OF RELATIVELY SMALL, DISPERSED NUCLEAR SITES THROUGHOUT THE COUNTRY BY THE YEAR 2000 IF PRESENT SITING TRENDS WERE TO CONTINUE. THE SITING OF SEVERAL NUCLEAR REACTORS AND THEIR ASSOCIATED FACILITIES IN A SMALL NUMBER OF CONCENTRATED NUCLEAR ENERGY CENTERS IS AN ALTERNATIVE HAVING MANY ADVANTAGES. THIS ARTICLE DESCRIBES THE BACKGROUND OF THE IDEA AND DISCUSSES SOME OF THE ADVANTAGES AND PROBLEMS IN CLUSTERING NUCLEAR REACTORS INTO NUCLEAR ENERGY CENTERS. IT CONCLUDES THAT THERE ARE COMPELLING ARGUMENTS FOR THE NATIONAL DEPLOYMENT OF NUCLEAR ENERGY, PARTICULARLY BREEDER REACTORS, INTO SUCH CENTERS BUT NOTES THAT THERE ARE MANY UNRESOLVED ISSUES ON WHICH MUCH WORK MUST BE DONE BEFORE FINAL ANSWERS ARE AVAILABLE AS TO THE SIZE, COMPOSITION, AND EXTENT TO WHICH THE ENERGY CENTER CONCEPT CAN BE APPLIED.
- 16-3-2-291 PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES  
 VAN ERP, J. B. + CHAWLA, T. C. + WILSON, R. E.  
 FAUSKE, H. K.  
 ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
 THIS ARTICLE IS A REVIEW OF RECENT EXPERIMENTAL AND ANALYTICAL WORK PERFORMED WITH THE OBJECTIVE OF EVALUATING THE POTENTIAL FOR PIN-TO-PIN FAILURE PROPAGATION WITHIN FUEL SUBASSEMBLIES OF LIQUID METAL COOLED FAST BREEDER REACTORS (LMFRS) OF CURRENT DESIGN. IT IS CONCLUDED THAT (1) PIN-TO-PIN FUEL-FAILURE PROPAGATION FOR CURRENT LMFR DESIGNS IS UNLIKELY, AND (2) IF FAILURE PROPAGATION OCCURS AT ALL, IT WILL BE SELF-LIMITING OR ITS PROGRESSION WILL BE SLOW, THUS ALLOWING AMPLE TIME FOR DETECTION AND CORRECTIVE ACTION IF APPROPRIATE INSTRUMENT SYSTEMS ARE PROVIDED.
- 16-3-3-308 THE 1974 SPECIALISTS MEETING ON REACTOR NOISE  
 THIE, J. A.  
 CONSULTANT, BARRINGTON, ILL.  
 AN INTERNATIONAL MEETING OF SPECIALISTS ON REACTOR NOISE WAS HELD IN ROME, ITALY, OCT. 21-25, 1974. THEORETICAL AND EXPERIMENTAL PAPERS TREATED BOTH ZERO POWER AND POWER REACTORS FOR ALL MAJOR REACTOR TYPES. SIXTEEN DIFFERENT CATEGORIES OF NOISE-ANALYSIS PRACTICAL APPLICATIONS, MOSTLY IN POWER REACTORS, WERE IDENTIFIED FROM THE 46 PAPERS PRESENTED. ABOUT A THIRD OF THESE CATEGORIES ARE NEW SINCE THE LAST INTERNATIONAL CONFERENCE ON NOISE WAS HELD IN 1968. A DEPTH OF UNDERSTANDING OF ZERO POWER NOISE WAS EXHIBITED, AND IN A FEW OF THE MANY CATEGORIES OF POWER REACTOR NOISE, GOOD EXPERIMENTAL AND THEORETICAL UNDERSTANDINGS WERE PROJECTED.
- 16-3-3-316 QUANTIFICATION OF MAN - MACHINE SYSTEM RELIABILITY IN PROCESS CONTROL  
 FRANK P. LEES  
 LOUGHBOROUGH UNIVERSITY OF TECHNOLOGY, ENGLAND  
 AUTHORITATIVE DISCOURSES ON THE SUBJECT OF HUMAN RELIABILITY IN CONTROL SYSTEMS ARE AVAILABLE IN JOURNALS DEVOTED TO ERGONOMICS, CYBERNETICS, AND HUMAN FACTORS. HOWEVER, THE SUBJECT IS ALSO OF PRIME INTEREST TO OPERATIONS IN THE NUCLEAR INDUSTRY. THEREFORE AN OVERVIEW OF THE SUBJECT OF OPERATOR RELIABILITY IS PRESENTED BY BOTH A DIGEST OF A PREVIOUSLY PUBLISHED PAPER AND AN ADDED SHORT BIBLIOGRAPHY.
- 16-3-4-318 RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPORT  
 ERDMAN, C. A. + KELLY, J. L. + REYNOLDS, A. B.  
 UNIVERSITY OF VIRGINIA, CHARLOTTESVILLE, VA.  
 THIS IS THE SECOND PART OF A TWO PART ARTICLE ON RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF A LIQUID-METAL-COOLED FAST BREEDER REACTOR (LMFR). PART 1, INCLUDED IN NUCLEAR SAFETY 10(1), DISCUSSED THE PRODUCTION OF RADIOACTIVITY. PART 2 REVIEWS THE TRANSPORT OF THE VARIOUS RADIONUCLIDES. ALTHOUGH RELIANCE WAS PLACED ON PUBLISHED RESULTS FOR BOTH PARTS, SOME

NEW CALCULATIONS WERE MADE WHERE NEEDED. RESULTS WERE NORMALIZED TO A 1000-MW(2) LWFR AND COMPARED WITH VALUES FOR A LIGHT WATER REACTOR (LWR). THIS REVIEW INCLUDES THE TRANSPORT OF TRITIUM AND CORROSION PRODUCTS, TRANSPORT OF FISSION PRODUCTS FROM FAILED FUEL, BEHAVIOR OF RADIOACTIVITY IN SODIUM AND COLD TRAPS, AND OPERATION OF GASEOUS RADWASTE SYSTEMS. OPERATING EXPERIENCES ARE REVIEWED FOR THE FAST REACTORS BRP-II, FERMI, SEFOR, DOUNFEAY, RAPSDIE, AND BR-5. LIMITED DATA ARE GIVEN FOR THE THERMAL REACTORS SEE, SEEN, AND HALLAM.

- 16-3-5-337 KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMENA  
 SERRALE, K. + FRENCH, C. + CHADOT, G. + MAJOR, A.  
 WARD, K.  
 LOWELL TECHNOLOGICAL INSTITUTE, LOWELL, MASS.  
 THIS ARTICLE DESCRIBES A GENERAL EQUATION FOR THE KINETICS OF SERIALY RELATED QUANTITIES LINKED BY LINEAR FIRST-ORDER PRODUCTION AND DESTRUCTION PHENOMENA. THE EQUATION IS APPLICABLE TO SYSTEMS OF CONCERN IN NUCLEAR AND RADIOLOGICAL SCIENCES AND HEALTH PHYSICS. SUGGESTED APPLICATIONS INCLUDE (1) THE SERIAL TRANSFORMATION OF RADIONUCLIDES, (2) THE COLLECTION AND ANALYSIS OF SERIALY RELATED AIRBORNE RADIOACTIVE PARTICULATES, (3) THE INVENTORY OF QUANTITIES IN THE CORE OF A NUCLEAR REACTOR, SUCH AS FISSION PRODUCTS, POISONS, FISSILE ELEMENTS, AND TRANSURANICUM ELEMENTS, (4) INTERNAL DOSIMETRY, SUCH AS THE BURDEN OF RADIONUCLIDES IN THE VARIOUS SEGMENTS OF THE GASTROINTESTINAL TRACT AND RESULTING DOSES FOR SINGLE OR CONTINUOUS INTAKES OF PARENT AS WELL AS DAUGHTER RADIONUCLIDES, (5) THE QUANTITY OF AIRBORNE RADIOACTIVE AEROSOLS GENERATED IN A VENTILATED SPACE THROUGH THE DECAY OF PARENT INERT RADIOACTIVE GASES, SUCH AS RADON, THORON, YERON, AND KRYPTON, AND (6) THE CALCULATION OF ROUTINE AND ACCIDENTAL RELEASES FROM NUCLEAR PLANTS.
- 16-3-5-345 THE ERDA RADIOLOGICAL ASSISTANCE PROGRAM  
 SMALLEY, W. L.  
 ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, OAK RIDGE, TENN.  
 THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (ERDA) RADIOLOGICAL ASSISTANCE PROGRAM PROVIDES ADVICE AND ASSISTANCE AT THE SCENE OF A RADIOLOGICAL INCIDENT WHEN ERDA BELIEVES THAT SUCH ACTION IS NECESSARY OR ON REQUEST FROM OTHER AGENCIES OR INDIVIDUALS. THIS ARTICLE DISCUSSES THE TYPES OF ASSISTANCE AVAILABLE AND MEANS OF OBTAINING THAT ASSISTANCE AND PROVIDES STATISTICS SUMMARIZING THE EXPERIENCE WITH THE PROGRAM ALONG WITH GUIDELINES FOR HANDLING RADIOLOGICAL EMERGENCIES.
- 16-3-6-354 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972  
 STEVENS-GUILLE, P. D.  
 ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, CANADA  
 DURING 1972, APPROXIMATELY ONE IN THREE OPERATING REACTORS WITH STEAM GENERATORS INCURRED TUBE FAILURES, PREDOMINANTLY NEAR THE TUBE SHEET AND IN THE BEND REGION. VARIOUS FORMS OF CORROSION WERE THE MOST FREQUENT CAUSE OF FAILURE. EDDY-CURRENT INSPECTION WAS THE PREFERRED METHOD FOR LOCATING AND INVESTIGATING THE CAUSE OF FAILURE. EXTENSIVE USE WAS MADE OF BOTH MECHANICAL AND EXPLOSIVE PLOGS FOR REPAIR. AS A CLASS, STEAM GENERATORS WITH MONEL 400 TUBES HAD THE LOWEST FAILURE RATES, AND THOSE WITH INCONEL 600 TUBES HAD THE HIGHEST.
- 16-4-1-415 THE ANSI-NSMB NUCLEAR STANDARDS PROGRAM  
 SAVOLAINEN, A. W.  
 AMERICAN NATIONAL STANDARDS INSTITUTE, NEW YORK, N.Y.  
 THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)-NUCLEAR STANDARDS MEASUREMENT BOARD (NSMB) NUCLEAR STANDARDS PROGRAM HAS, SINCE ITS INFANCY, PROCEEDED ON A BASE OF LONG TERM PLANS AND BROAD GOALS BEYOND THOSE OF THE INDIVIDUAL STANDARDS PROJECTS UNDERTAKEN. THE EFFORT IN THE DEVELOPMENT OF NUCLEAR STANDARDS HAS FOCUSED ON MANY OBJECTIVES, INCLUDING, (1) THE EXPEDITIOUS DEVELOPMENT OF HIGH QUALITY STANDARDS IN AREAS OF NEED, (2) MAXIMUM COORDINATION OF THE PROGRAM TO PROMOTE A DISCIPLINED ENGINEERING APPROACH TO DESIGN AND CONSTRUCTION OF NUCLEAR FACILITIES, TO ENSURE ADEQUATE AND SAFE PLANTS, AND TO PROVIDE UTILITY AND SAFETY IN THE USE OF RADIOACTIVE MATERIALS, (3) PARTICIPATION IN THE PROGRAM BY THOSE WHO WILL ULTIMATELY USE THE STANDARDS, (4) RELIEF OF VOLUNTEER PROFESSIONALS FROM ADMINISTRATIVE BURDENS THAT DO NOT UTILIZE THEIR TIME EFFECTIVELY, (5) INCREASED PARTICIPATION BY PROFESSIONAL STANDARDS WRITING ORGANIZATIONS. THE INFORMATIONAL TOOLS ARE NOW IN PLACE TO ASSIST STANDARDS WRITING GROUPS IN ORGANIZING AND COMPLETING THEIR TASKS, TO PROVIDE STANDARDS MANAGEMENT GROUPS WITH A BASIS FOR EVALUATING PROGRESS, AND TO AID PROGRAM PLANNERS IN ASSURING ACHIEVEMENT OF THEIR GOALS WITH A MINIMUM OF OVERLAP AND DUPLICATION. AS OF JANUARY 1975, APPROXIMATELY 1500 STANDARDS HAD BEEN IDENTIFIED AS HAVING NUCLEAR APPLICATION, AND THERE WERE 551 ACTIVE PROJECTS UNDER THE COGNIZANCE OF NSMB.
- 16-4-1-421 THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON NRC LICENSING JURISDICTION AND PROCEDURES  
 DAVIS, J. P.  
 CONSOLIDATED EDISON COMPANY OF NEW YORK, INC., N.Y.  
 PART II OF THIS ARTICLE COVERS THE INTERRELATIONSHIP OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA) AND THE U.S. NUCLEAR

REGULATORY COMMISSION (NRC) ENVIRONMENTAL REVIEWS UNDER THE FEDERAL WATER POLLUTION CONTROL ACT (FWPCA) AND OTHER STATUTES. THE SCOPE OF EPA'S AUTHORITY TO REGULATE RADIOACTIVE MATERIALS DISCHARGE UNDER FWPCA AND THE IMPACT ON NRC REGULATION UNDER THE ATOMIC ENERGY ACT ARE DISCUSSED, AND THE EFFECT OF FWPCA ON NRC ENVIRONMENTAL JURISDICTION UNDER NEPA IS CONSIDERED. IN ADDITION, THE PROBLEMS INVOLVED IN POSSIBLE OVERLAPPING AGENCY JURISDICTIONS AND THE EPA-AEC MEMORANDA OF UNDERSTANDING ARE ANALYZED. THIS ARTICLE ALSO BRIEFLY SUMMARIZES EVENTS THAT HAVE OCCURRED SINCE THE PUBLICATION OF PART I. FINALLY, THE PROSPECTS FOR A WORKABLE DISCHARGE PERMIT SYSTEM UNDER THE FWPCA ARE DISCUSSED.

- 16-4-2-436 CSNI MEETING ON FUEL - COOLANT INTERACTIONS  
PAUSKE, H. K.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
THIS ARTICLE IS A BRIEF REVIEW OF THE SECOND SPECIALIST MEETING ON FUEL-COOLANT INTERACTIONS IN FAST REACTORS. THE MEETING, SPONSORED BY THE COMMITTEE ON THE SAFETY OF NUCLEAR INSTALLATIONS (CSNI), WAS HELD IN ISPPA, ITALY, NOV. 21-23, 1973. EXPERIMENTAL DATA PRESENTED AT THE MEETING INCLUDED TESTS WITH BOTH SIMULANTS AND LIQUID METAL-COOLED FAST BREEDER REACTOR (LMFBR) MATERIALS. IN THE LATTER CATEGORY, OVER 100 INTERACTION TESTS WERE DISCUSSED, INCLUDING APPROXIMATELY 30 PROTOTYPIC REACTOR TESTS. ALL TESTS INVOLVING LMFBR MATERIALS RESULTED IN VERY MILD INTERACTIONS, EXCEPT FOR A FEW CASES WHERE SMALL QUANTITIES OF LIQUID SODIUM WERE INJECTED INTO MOLTEN URANIUM DIOXIDE (LABORATORY TESTS). THE ENERGETIC INTERACTIONS WERE GENERALLY EXPLAINED BY ENTRAPMENT AND OVERHEATING OF THE LIQUID SODIUM, ALTHOUGH SIGNIFICANT DIFFERENCES IN DETAILS OF THE PROPOSED MECHANISMS EXISTED. SEVERAL VARIATIONS OF THE ORIGINAL CHO-PADILLA ACCIDENT ANALYSIS MODEL OF FUEL-COOLANT INTERACTION WERE ALSO PRESENTED. HOWEVER, LACK OF UNDERSTANDING OF FRAGMENTATION, MIXING, AND HEAT TRANSFER PROCESSES HAS PREVENTED SUBSTANTIAL IMPROVEMENT OF THE MODEL AS ORIGINALLY PROPOSED. (FUEL-COOLANT INTERACTIONS REFERRED TO IN THIS ARTICLE ARE PHYSICAL, NOT CHEMICAL.)
- 16-4-2-443 A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES  
SWAN, S. W. + HELEIS, H.  
BECHTEL POWER CORPORATION, SAN FRANCISCO, CALIF.  
THE SIMPLE INEXPENSIVE COMPUTER CODE DESCRIBED IS USED FOR CALCULATING THE PROBABILITY OF TURBINE MISSILE DAMAGE TO SYSTEMS REQUIRED FOR SAFE SHUTDOWN OF A NUCLEAR PLANT FOLLOWING A STRUCTURAL FAILURE IN THE TURBINE GENERATOR SYSTEM. THE CODE CALCULATES THE PROBABILITY THAT A TURBINE MISSILE WILL STRIKE THE CONCRETE STRUCTURE SURROUNDING A PLANT SYSTEM AND THE PROBABILITY OF DAMAGE TO THE SYSTEM. EXAMPLE CALCULATIONS ARE PRESENTED TO ILLUSTRATE THE VARIATION IN THE CALCULATED PROBABILITIES FOR DIFFERENT PLANT ARRANGEMENTS AND DIFFERENT TARGET WALL THICKNESSES.
- 16-4-3-452 SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRUMENTS  
SOMMERS, J. F.  
IDAHO NATIONAL ENGINEERING LABORATORY, IDAHO FALLS, IDAHO  
DEVELOPMENT OF A NEW GENERATION OF PORTABLE RADIATION SURVEY INSTRUMENTS AND APPLICATION OF THE 'AS LOW AS PRACTICABLE' (ALAP) PHILOSOPHY HAVE PRESENTED A PROBLEM OF COMPLIANCE WITH GUIDES FOR RADIOACTIVE CONTAMINATION CONTROL. ISOLATED, LOW-LEVEL, DISCRETE PARTICLE BETA-GAMMA CONTAMINATION IS BEING DETECTED WITH THE NEW INSTRUMENTS. TO DETERMINE THE LIMITS OF PRACTICABILITY REQUIRES, IN TURN, THE DETERMINATION OF THE LIMITS OF DETECTION OF THESE SURFACE CONTAMINANTS. THE DATA AND CALCULATIONS INCLUDED IN THIS ARTICLE INDICATE THE SOURCE DETECTION FREQUENCIES THAT CAN BE EXPECTED USING THE NEW GENERATION OF SURVEY INSTRUMENTS. THE AUTHOR CONCLUDES THAT, IN LOW POPULATION GROUPS OF DISCRETE PARTICLES, ABOUT 5000 DIS/MIN OF BETA ACTIVITY PER PARTICLE IS THE MINIMUM LEVEL OF ACTIVITY PER PARTICLE WHICH IS APPLICABLE FOR CONFIDENT COMPLIANCE WITH SURFACE CONTAMINATION CONTROL GUIDES. LOWER CONTROL LEVELS ARE POSSIBLE WITH ADDITIONAL DEVELOPMENT OF INSTRUMENTS OR THROUGH HIGH COST CHANGES IN RADIATION SURVEY AND CONTAMINATION-CONTROL METHODS. ADDITIONAL ANALYSES ARE REQUIRED FOR ASSESSMENT OF THE HAZARD CAUSED BY WIDELY DISPersed DISCRETE PARTICLE CONTAMINANTS.
- 16-4-4-458 APPLICATION OF EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE NUCLEAR INDUSTRY  
GODDSE, S. W. + KIBREY, A. H.  
HOLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.  
A SURVEY OF EVAPORATION AS APPLIED TO RADIOACTIVE-WASTE SOLUTIONS SHOWED THAT SYSTEM DECONTAMINATION FACTORS (DFS) OF 10(3) TO 10(4) CAN BE EXPECTED FOR NONVOLATILE RADIOACTIVE CONTAMINANTS TREATED IN SINGLE STAGE EVAPORATORS. THE DFS FOR IODINE CAN BE EXPECTED TO BE A FACTOR OF 10 TO 100 LOWER THAN THOSE EXPECTED FOR NONVOLATILE SPECIES UNDER ALKALINE, BUT NOT OXIDIZING OR ACIDIC, CONDITIONS. THE DF IS REDUCED BY A FACTOR OF ABOUT 10 IF ORGANIC MATERIALS ARE MIXED WITH AQUEOUS WASTES. THESE VALUES CONSIDER THAT THE EVAPORATOR IS WELL DESIGNED, ADEQUATELY SIZED, AND OPERATED WITH REASONABLE SKILL.

16-5-4-669

PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS

WOLTER, D. W.

HARVARD UNIVERSITY, BOSTON, MASS.

THIS ARTICLE IS A REVIEW OF PUBLISHED REPORTS OF FAILURES IN AIR CLEANING AND AIRBORNE WASTE MANAGEMENT SYSTEMS AT NUCLEAR INSTALLATIONS FROM 1966 TO 1974. THE REVIEW INDICATES INSTANCES OF DISRUPTION OF MOBILE GAS ADSORPTION SYSTEMS DUE TO WINDROG EXPLOSIONS, DECREASED PERFORMANCE OF PARTICULATE FILTERS DUE TO THE PRESENCE OF CONTAMINANTS OR THE FAILURE OF SEALS, DAMPERS, AND VALVES, AND IMPROPER EVALUATION OF THE EFFICIENCY OF AIR CLEANING SYSTEMS DUE TO SAMPLING AND OTHER PROCEDURAL ERRORS. ALTHOUGH A PORTION OF THE REPORTED FAILURES CAN BE ATTRIBUTED TO MANUFACTURING AND DESIGN DEFECTS, A MAJOR SHARE (ABOUT 65 PERCENT) APPEARS TO BE DUE TO ERRORS BY THOSE RESPONSIBLE FOR THE OPERATION AND MAINTENANCE OF AIR CLEANING EQUIPMENT.

16-5-4-482

REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATORS

COLLINS, P. W.

U. S. ATOMIC ENERGY COMMISSION, WASHINGTON, D. C.

THE NUCLEAR REGULATORY COMMISSION (NRC) REQUIRES THAT ALL OPERATORS OF THE CONTROLS OF NUCLEAR FACILITIES BE LICENSED. APPLICATIONS FOR LICENSES MUST PASS WRITTEN EXAMINATIONS AND OPERATING TESTS ADMINISTERED BY NRC. SOME INDIVIDUALS MUST BE EXAMINED PRIOR TO INITIAL CREDENTIALS AT A FACILITY, WHEREAS OTHERS MUST HAVE HAD EXTENSIVE ACTUAL OPERATING EXPERIENCE AT A COMPARABLE REACTOR TO SIT FOR THESE EXAMINATIONS. OPERATING EXPERIENCE MAY BE OBTAINED THROUGH APPROVED TRAINING PROGRAMS THAT UTILIZE NUCLEAR POWER PLANT SIMULATORS. SINCE 1969, NRC'S PROGRESSOR, THE USARC, HAS ACCEPTED FOUR SUCH TRAINING PROGRAMS THAT ARE ADMINISTERED BY THE VENDORS OF NUCLEAR POWER PLANT SYSTEMS. THE PROGRAMS CONSIST OF (1) NUCLEAR FUNDAMENTALS COURSES, (2) RESEARCH-REACTOR OPERATION, (3) DECISION ON NUCLEAR POWER PLANT DESIGN, (4) OBSERVATION AT OPERATING NUCLEAR POWER PLANTS, AND (5) SIMULATOR OPERATIONS. INDIVIDUALS SEEKING LICENSES AFTER PLANTS BECOME OPERATIONAL MUST DEMONSTRATE THEIR PROFICIENCY AT REACTOR CONTROL DURING EXAMINATIONS. IN 1971, THE USARC APPROVED THE USE OF SIMULATORS IN TRAINING PROGRAMS AND DURING THE EXAMINATIONS. THESE PROGRAMS ARE LIMITED TO PERSONNEL FROM FACILITIES HAVING CONTROL ROOMS WHICH ARE CLOSELY PARALLEL TO THAT OF THE SIMULATOR. THE NRC ALSO PROVIDES LICENSES INDIVIDUALS TO PARTICIPATE IN REGULATION PROGRAMS THAT REQUIRE NUMBER OF TO VARYING DEGREE REACTOR CONTROL THROUGH A SPECIFIC NUMBER OF EXERCISES DURING THEIR LICENSE TRAINING. AT THE SIMULATOR'S OPERATING CHARACTERISTICS AND CONTROL ROOM ARE SIMILAR TO THOSE OF THE FACILITY IN WHICH, MANIPULATION OF SIMULATOR CONTROLS IS PERMITTED SO THAT THE NUMBER OF PLANT EXERCISES SOLVED FOR REGULATION CAN BE MINIMIZED. FINAL EVALUATION OF THE MERITS OF USING SIMULATORS RATHER THAN OPERATING PLANTS IS BASED ON THE KNOWLEDGE AND UNDERSTANDING EXHIBITED BY TRAINEES DURING THE ADMINISTRATION OF EXAMINATIONS. THE NRC EXAMINERS HAVE FOUND THAT INDIVIDUALS TRAINED USING SIMULATORS HAVE A BETTER UNDERSTANDING OF PLANT RESPONSES TO TRANSIENT CONDITIONS AND ABNORMAL SITUATIONS AND ALSO ARE MORE CONFIDENT IN ANSWERING QUESTIONS THAT REQUIRE PERCEPTION OF PLANT RESPONSES TO POSTULATED SITUATIONS. ALSO, SIMULATORS ARE EXTREMELY EFFECTIVE FOR EXAMINING AND EVALUATING INDIVIDUALS. THE NRC BELIEVES THAT SIMULATORS, USED IN CONNECTION WITH COMPREHENSIVE TRAINING PROGRAMS, ARE EFFECTIVE TRAINING DEVICES AND INTENDS TO ENCOURAGE THEIR USE IN FUTURE TRAINING PROGRAMS.

16-5-4-537

NUCLEAR LIABILITY INSURANCE - A SUMMARY OF RECENT YEARS

WARREN, J.

NUCLEAR ENERGY LIABILITY-PROPERTY INSURANCE ASSOCIATION, FARMINGTON, CONN.

THE NUCLEAR LIABILITY INSURANCE POOLS HAVE STABILIZED INCREASED NUCLEAR LIABILITY INSURANCE AVAILABLE TO THE NUCLEAR INDUSTRY TO ITS PRESENT \$125 MILLION, WHICH IS MORE THAN DOUBLE THE \$60 MILLION FIRST PROVIDED IN 1957. THE INSURANCE POOLS ALSO PROVIDE AN ADDITIONAL \$175 MILLION OF ALL-RISK PROPERTY INSURANCE TO PROTECT AGAINST LOSS OF PROPERTY AT A NUCLEAR FACILITY FOR A TOTAL OF \$300 MILLION. THIS AMOUNT OF LIABILITY AND PROPERTY INSURANCE AVAILABLE FOR NUCLEAR RISKS EXCEEDS THE COVERAGE THE INSURANCE INDUSTRY HAS AT RISK ANYWHERE ON A SINGLE UNIT OF RISK. THIS ASSISTING TO THE CONFIDENCE IN NUCLEAR SAFETY, THE EXHIBITIONARY SAFETY ACHIEVED AND RECORDED BY THE LOSS EXPERIENCE OF THE NUCLEAR POOLS IS DESCRIBED. THE INSURANCE POOLS HAVE PROPOSED A CHANGE IN THE PRICE-ANDERSON ACT WHICH WOULD PROVIDE SUBSTANTIAL ADDITIONAL SUMS OF NUCLEAR LIABILITY INSURANCE TO PROTECT THE PUBLIC AND WHICH IS LIKELY TO BE THE SUBJECT OF EXAMINATION BY CONGRESS DURING 1975. THE PROPOSAL, IF IMPLEMENTED, WILL GRADUALLY INCREASE THE PROTECTION AFFORDED TO THE PUBLIC AND AIRBORNALLY ELIMINATE THE ROLE OF GOVERNMENT INDEMNITY.

16-5-1-582

AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY

(EDITORS NOTE - IN AUGUST 1974 THE U.S. ATOMIC ENERGY COMMISSION RELEASED FOR REVIEW AND COMMENT A DRAFT OF NASH-1400, REACTOR SAFETY STUDY-AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS. SEE NUCLEAR SAFETY, VOL. 6, PAGES 673-675 FOR A BRIEF SUMMARY OF THAT REPORT. THAT STUDY BY THE AEC IS THE MOST COMPREHENSIVE OF

ITS KIND EVER UNDERTAKEN AND HAS SINCE BEEN EXTENSIVELY  
 CELEBRATED BY MANY INTERESTED PARTIES, THEIR COMMENTS ARE  
 AVAILABLE AT THE NRC PUBLIC DOCUMENT ROOM. CONCURRENT WITH THE  
 AEC REACTOR SAFETY STUDY, THE AMERICAN PHYSICAL SOCIETY (APS)  
 DECIDED TO SPONSOR A STUDY OF REACTOR SAFETY BECAUSE IT WAS AN  
 IMPORTANT AND CONTROVERSIAL SUBJECT WITH SUBSTANTIAL SCIENTIFIC  
 AND TECHNOLOGICAL CONTENT. TOWARD THAT END THE APS STUDY WAS  
 SUPPORTED BY THE NATIONAL SCIENCE FOUNDATION AND THE AEC. THE  
 APS STUDY WAS UNDERTAKEN IN 1974-1975 BY A STUDY GROUP  
 CONSISTING OF 12 PART-TIME PARTICIPANTS WITH VARIOUS LEVELS  
 OF PRIOR EXPERIENCE IN THE REACTOR FIELD. ITS PURPOSE WAS TO  
 MAKE A QUANTITATIVE ESTIMATE OF THE LIKELIHOOD OF ACCIDENT  
 CONSEQUENCES OF A GIVEN SEVERITY. ALTHOUGH THE APS STUDY GROUP  
 DID NOT UNDERTAKE TO REVIEW THE AEC REACTOR SAFETY STUDY, THERE  
 IS MUCH COMMON GROUND BETWEEN THE TWO, AND THE AEC STUDY IS  
 MENTIONED FREQUENTLY IN THE APS REPORT. THE DRAFT OF THE APS  
 REPORT, ENTITLED 'REPORT TO THE AMERICAN PHYSICAL SOCIETY BY  
 THE STUDY GROUP ON LIGHT WATER-REACTOR SAFETY,' WAS RELEASED IN  
 APRIL 1975, AND THE FINAL VERSION WILL BE PUBLISHED IN THE  
 REVIEWS OF MODERN PHYSICS. BECAUSE OF THE IMPORTANCE OF THE  
 SUBJECT AND BECAUSE OF THE TECHNICAL COMPETENCE AND OBJECTIVITY  
 OF THE APS STUDY GROUP, THE EDITORS OF NUCLEAR SAFETY ARE HERE  
 REPRINTING THE FIRST CHAPTER, 'SUMMARY OF CONCLUSIONS AND MAJOR  
 RECOMMENDATIONS,' OF THE DRAFT OF THE APS REPORT.)

16-5-2-546 POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HTGRS  
 TOBIAS, M.

HOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

STUDIES OF POSTULATED NEUTRONIC EVENTS OF MAJOR CONCERN IN  
 HIGH TEMPERATURE GAS COOLED REACTORS (HTGRS) ARE REVIEWED. THE  
 LITERATURE COVERED INCLUDES LICENSING REVIEWS, SAFETY ANALYSIS  
 REPORTS, AND TOPICAL REPORTS PREPARED DURING THE DESIGN AND  
 DEVELOPMENT OF THE MAJOR REACTORS OF THE GENERAL ATOMIC  
 COMPANY. INCIDENTS CONSIDERED ARE LOSS OF FISSION PRODUCTS,  
 CORE COMPRESSION DUE TO EARTHQUAKE, FUEL INSERTION DURING  
 RELOADING, AND STEAM INTRODUCTION INTO THE CORE, ALL OF WHICH  
 ARE JUDGED TO BE OF LESS IMPORTANCE THAN THE WITHDRAWAL OF A  
 SINGLE ROD PAIR. INCIDENTS SUCH AS MULTIPLE ROD WITHDRAWAL OR  
 ROD EJECTION HAVE BEEN DISMISSED AS PHYSICALLY IMPOSSIBLE.  
 ANALYSES OF REACTIVITY CHANGES FOLLOWING A LOSS OF COOLANT  
 ACCIDENT INDICATE THAT HTGRS WILL REMAIN SUBCRITICAL. OTHER  
 ITEMS THAT CONTINUE TO RECEIVE ATTENTION ARE THE REACTIVITY  
 CONSEQUENCES OF CORE SUPPORT COLLAPSE RESULTING FROM WEAKENING  
 BY SEISMIC EVENTS OR STEAM CORROSION. THE PHYSICS CALCULATIONS  
 HAVE BEEN EXTENSIVELY COMPARED WITH EXPERIMENTAL RESULTS IN  
 CRITICAL FACILITIES AND OPERATING REACTORS. DESIGNERS HAVE  
 CUSTOMARILY DEALT WITH DIFFERENCES BETWEEN OBSERVATION AND  
 CALCULATION BY USE OF PESSIMISTIC ASSUMPTIONS AND BY CONTINGUAL  
 ATTEMPTS TO IMPROVE THEORETICAL APPROACHES. INDEPENDENT  
 CHECKING IS CURRENTLY SPONSORED BY THE NUCLEAR REGULATORY  
 COMMISSION'S OFFICE OF NUCLEAR REGULATORY RESEARCH.

16-5-3-557 IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM

HAGEN, E. W.

HOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE REVIEWS THE NUCLEAR SAFETY RELATED PORTIONS OF THE  
 6TH IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM HELD IN WASHINGTON,  
 D.C., DEC. 11-13, 1974. THE MEETING, HELD CONCURRENTLY WITH THE  
 21ST NUCLEAR SCIENCE SYMPOSIUM AND THE 14TH SCINTILLATION AND  
 SEMICONDUCTOR COUNTER SYMPOSIUM, WAS SPONSORED BY THE INSTITUTE  
 OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE) AND THE U.S.  
 ATOMIC ENERGY COMMISSION. IT WAS THE LATEST IN A SERIES OF  
 MEETINGS DESIGNED SPECIFICALLY FOR ELECTRICAL ENGINEERS WHO ARE  
 INVOLVED WITH NUCLEAR POWER GENERATION. SEVERAL SESSIONS WERE  
 DEVOTED TO UPDATING INFORMATION ON STANDARDS, STARTUP AND  
 OPERATING EXPERIENCES, AND INSTRUMENTATION DEVELOPMENT.

16-5-4-564 NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER REACTOR PLANT

GRAHAM, J.

WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PA.

THIS ARTICLE REVIEWS THE DESIGN PHILOSOPHY AND SAFETY FEATURES  
 OF THE 975-MW(T) CLINCH RIVER BREEDER REACTOR (CRBR), A SODIUM  
 COOLED DEMONSTRATION REACTOR TO BE BUILT NEAR OAK RIDGE, TENN.  
 THE OVERALL SAFETY OF THE PLANT IS BASED ON THREE LEVELS OF  
 PROTECTION (1) RELIABLE OPERATION THROUGH INTRINSIC FEATURES OF  
 THE DESIGN, (2) PROTECTION PROVIDED AGAINST ANTICIPATED FAULTS  
 AND UNLIKELY EVENTS, AND (3) PROVISION FOR EXTREMELY UNLIKELY  
 EVENTS. THE PRINCIPAL FEATURES OF EACH OF THESE THREE SAFETY  
 DESIGN LEVELS ARE DISCUSSED. IN ADDITION, WORK IS CONTINUING ON  
 A PARALLEL DESIGN APPROACH THAT TREATS A CORE DISRUPTIVE  
 ACCIDENT AS A DESIGN BASIS.

16-5-4-581 SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS

KIRSEY, A. H. + GODDSE, R. W.

HOLLIFIELD NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS REVIEW OF SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR  
 POWER PLANTS THROUGH 1972 SHOWS THAT BOILING WATER REACTORS  
 (BWRs) CUMULATIVELY GENERATED OVER TWICE AS MUCH WASTE AS  
 PRESSURIZED-WATER REACTORS (PWRs) ( $3.3 \times 10^5$  VS.  $1.4 \times 10^5$ )  
 CUBIC FT) AND PRODUCED ABOUT THE SAME CUMULATIVE THERMAL OUTPUT  
 ( $2.2 \times 10^8$  VS.  $2.5 \times 10^8$ ) MWH(T). THE CUMULATIVE UNDECAYED  
 CONTENTS OF THESE WASTES WERE  $6.7 \times 10^3$  AND  $7.7 \times 10^3$  CI

FOR BWRS AND PWRS, RESPECTIVELY. GENERALLY, PWRS INCORPORATED ALL WET PROCESS WASTES EXCEPT SPENT BEAD RESINS IN CEMENT, WHEREAS SEVERAL BWRS TENDED TO DEWATER SLUDGES AND RESINS AND TO SEND EVAPORATOR CONCENTRATES ON HIGH SURFACE AREA MATERIALS WITHOUT BINDER FOR SHIPMENT AND BURIAL. A RECENT TEND FOR BWRS IS TO INCORPORATE WASTE IN SOLID MATRICES.

- 16-5-5-593 THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT  
PALMS, J. M. \* VELURI, V. P. \* BOONE, P. W.  
ALLIED-GENERAL NUCLEAR SERVICES, BARNWELL, S.C.  
THE ENVIRONMENTAL IMPACT OF IODINE-129 RELEASED BY THE ALLIED GENERAL NUCLEAR SERVICES - BARNWELL NUCLEAR FUEL PLANT (BNFP) IS ASSESSED. ON THE BASIS OF PRESENT KNOWLEDGE, IT IS EXPECTED THAT THE PREDICTED RELEASES FROM THE PLANT WILL NOT RAISE THE CONCENTRATION OF IODINE-129 TO LEVELS THAT WOULD BE HAZARDOUS TO MAN OF THE ENVIRONMENT. THIS ARTICLE SUMMARIZES THE ANALYSES ASSOCIATED WITH THE RELEASE OF IODINE-129 TO THE ENVIRONMENT, INCLUDING THE PRESENTLY ESTIMATED  $\dot{M}$  RELEASES AND CALCULATIONS OF RESULTING DOSE TO MAN USING THE STATE OF THE ART DOSE MODELS. THYROID DOSES ARE CALCULATED BY THE SPECIFIC ACTIVITY MODEL AND THE CRITICAL PATHWAY MODEL. THE DEGREE OF CONSERVATIVENESS INVOLVED IN THE SPECIFIC ACTIVITY MODEL WHICH MAKES IT UNACCEPTABLE AS A REALISTIC MODEL IS DISCUSSED, AND THE CRITICAL PATHWAY MODEL IS BRIEFLY ASSESSED. THYROID DOSES FOR ADULTS AND INFANTS DUE TO INHALATION AND INGESTION ARE PRESENTED. FOR AN AIR CONCENTRATION OF  $3.6 \times 10^{-5}$  PCI/M(3) OF IODINE-129, RESULTING FROM A RELEASE AT THE RATE OF  $1.5 \times 10^{(-9)}$  CI/SEC, THE INFANT AND THE ADULT THYROID DOSES DUE TO INGESTION VIA MILK ARE CALCULATED BY THE CRITICAL PATHWAY MODEL TO BE 0.24 AND 0.12 MREM/YEAR, RESPECTIVELY. THE ADULT THYROID DOSE DUE TO INGESTION OF LEAFY VEGETABLES IS FOUND TO BE 0.04 MREM/YEAR. THE INHALATION AND WHOLE BODY DOSES ARE ORDERS OF MAGNITUDE SMALLER.
- 16-5-6-603 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973  
STEVENS-GUILLE, P. D. \* HARE, M. G.  
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO  
THIS ARTICLE SUMMARIZES STEAM GENERATOR TUBE FAILURES IN WATER COOLED REACTORS FOR 1973. FAILURES OCCURRED IN 11 OF 49 REACTORS, MAINLY DUE TO CORROSION AND VIBRATION. THE TWO MOST IMPORTANT VARIABLES IN PREVENTING THESE FAILURES APPEAR TO BE SECONDARY WATER CHEMISTRY AND DESIGN.
- 16-5-6-614 OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER PLANTS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE SUMMARIZES THE RESULTS OF AN INVESTIGATION OF OCCUPATIONAL RADIATION EXPOSURES AT NUCLEAR POWER PLANTS CARRIED OUT BY SAI SERVICES FOR THE ATOMIC INDUSTRIAL FORUM. OCCUPATIONAL RADIATION EXPOSURES AND THEIR SOURCES WERE INVESTIGATED AT EIGHT BOILING WATER REACTORS (BWRS) AND AT SIX PRESSURIZED WATER REACTORS (PWRS) FROM 1969 TO 1973. ACTIVATION PRODUCTS RATHER THAN FISSION PRODUCTS WERE FOUND TO BE THE MAJOR SOURCES OF RADIATION EXPOSURE TO IN-PLANT PERSONNEL FOR BOTH TYPES OF REACTORS. THE SINGLE MOST IMPORTANT NUCLIDE CONTRIBUTING TO EXPOSURES AT BWRS WAS COBALT-60. NO SINGLE NUCLIDE WAS FOUND TO BE DOMINANT IN PWR EXPOSURES, BUT STEAM GENERATOR WORK WAS THE LARGEST SOURCE OF EXPOSURE. THE ANNUAL EXPOSURE RATE WAS FOUND TO INCREASE WITH PLANT AGE ON BWRS, BUT THERE IS NO CONSISTENT PATTERN FOR EXPOSURE RATE CHANGE WITH PLANT AGE ON PWRS.
- 16-6-1-659 EPRI WATER REACTOR SAFETY PROGRAM  
LOEWENSTEIN, W. B.  
ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF.  
THE RATIONALE, STRUCTURE, AND CURRENT STATUS OF THE ELECTRIC POWER RESEARCH INSTITUTE (EPRI) WATER REACTOR SAFETY PROGRAM ARE SUMMARIZED. THE EFFORTS EMPHASIZE QUANTIFIED ASSURANCE OF SAFETY, USUALLY BASED ON THE SYNTHESIS OF PERTINENT EXPERIMENTAL, ANALYTICAL, AND CALCULATIONAL RESULTS. THE SCOPE OF THE PROGRAM RANGES FROM THE QUANTIFIED DEFINITION OF THE COURSE OF THE POSTULATED LOSS OF COOLANT ACCIDENT TO CONTINUING ROUTINE MONITORING OF THE PRESSURE BOUNDARY. THIS INCLUDES RESEARCH ON SUCH DIVERSE EFFORTS AS TWO-PHASE FLOW BEHAVIOR IN COMPLEX GEOMETRIES, INTERACTION OF POTENTIAL TORNADO GENERATED MISSILES WITH REINFORCED CONCRETE STRUCTURES, ASPECTS OF PROBABILISTIC SAFETY APPRAISAL, AND TECHNIQUES TO QUANTIFY THE DIAGNOSIS OF THE PERFORMANCE OF THE PRESSURE BOUNDARY. THE EPRI PROGRAM EFFORTS ARE COORDINATED WITH THE NEEDS OF THE UTILITY INDUSTRY THROUGH SEVERAL ADVISORY COMMITTEES. THE PROGRAM IS COORDINATED WITH THE PROGRAMS OF NATIONAL SPONSORING AGENCIES AND MAINTAINS LIAISON WITH REACTOR VENDORS AND ARCHITECT ENGINEERS. PROGRAM SEGMENTS ARE IMPLEMENTED BY REACTOR VENDORS, ARCHITECT ENGINEERS, CONSULTING ORGANIZATIONS, NATIONAL LABORATORIES, INDEPENDENT RESEARCH ORGANIZATIONS, AND UNIVERSITIES. IN ADDITION TO COORDINATION WITH NATIONAL AGENCIES, ARRANGEMENTS FOR COOPERATION AND EXCHANGE HAVE BEEN INITIATED WITH SEVERAL FOREIGN NATIONAL AND UTILITY ORGANIZATIONS.



- 16-6-1-667 EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM  
HOWE, W. D. + GALPIN, F. L. + PETERSON, R. T., JR.  
U.S. ENVIRONMENTAL PROTECTION AGENCY, WASHINGTON, D.C.  
A PRINCIPAL ROLE OF THE ENVIRONMENTAL PROTECTION AGENCY'S OFFICE OF RADIATION PROGRAMS IS TO ASSESS ENVIRONMENTAL RADIOACTIVITY LEVELS AND TO ESTIMATE THE IMPACT OF RADIATION TECHNOLOGY ON MAN AND HIS ENVIRONMENT. THIS ARTICLE DESCRIBES THE APPROACH OF THE EPA AND ITS PROGRAM TO FULFILL THIS ROLE.
- 16-6-2-683 FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM  
CROWENBERG, A. W. + GROLMES, R. A.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
AN IMPORTANT ASPECT OF THE FUEL COOLANT INTERACTION PROBLEM RELATIVE TO LIQUID METAL COOLED FAST BREEDER REACTOR SAFETY ANALYSIS IS THE FRAGMENTATION OF MOLTEN OXIDE FUEL ON CONTACT WITH LIQUID SODIUM COOLANT. A PROPER DESCRIPTION OF THE KINETICS OF SUCH AN EVENT REQUIRES AN UNDERSTANDING OF THE BREAKUP PROCESS AND AN ESTIMATE OF THE SIZE AND DISPERSION OF SUCH FINELY DIVIDED FUEL IN THE COOLANT. IN RECENT YEARS, CONSIDERABLE INTEREST HAS CENTERED ON THE PROBLEM OF DETERMINING THE NATURE OF THE FRAGMENTATION PROCESS. THIS ARTICLE REVIEWS BOTH ANALYTIC AND EXPERIMENTAL STUDIES PERTAINING TO SUCH BREAKUP IN LIGHT OF RECENT DEVELOPMENTS IN THE UNDERSTANDING OF HEAT TRANSFER AND SOLIDIFICATION PHENOMENA DURING QUENCHING OF URANIUM DIOXIDE IN SODIUM. WHERE POSSIBLE, AN ATTEMPT IS MADE TO ASSESS THE WORK POTENTIAL FOR FRAGMENTATION OF THE VARIOUS PROPOSED MODELS AND TO COMPARE THE PREDICTED PARTICLE SIZE WITH EXPERIMENTAL RESULTS.
- 16-6-3-701 SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAST REACTOR  
HALL, R. S.  
BERKELEY NUCLEAR LABORATORIES, GLOUCESTERSHIRE, ENGLAND  
THE PARTICULAR SAFETY PROBLEMS OF THE FAST REACTOR AND THE ROLE OF INSTRUMENTED PROTECTION IN RELATION TO THE OVERALL SAFETY DESIGN OF THE REACTOR ARE DISCUSSED. THE IMPORTANCE OF THE ACCIDENT SEQUENCE ARISING FROM A FAULT WITHIN ONE SUBASSEMBLY IS INDICATED, AND THE PHYSICAL PHENOMENA INVOLVED ARE DISCUSSED WITH REGARD TO THE GENERATION OF DETECTABLE SIGNALS. SEVERAL POSSIBLE TECHNIQUES FOR DETECTING SUBASSEMBLY ACCIDENTS ARE DESCRIBED, INCLUDING THOSE WITH DETECTORS SITUATED AT THE OUTLET OF EACH SUBASSEMBLY AND ALSO THOSE INVOLVING WHOLE-CORE PARAMETERS. THE CURRENT STATUS OF THESE TECHNIQUES IS INDICATED, AND, WHERE APPROPRIATE, THE STEPS NECESSARY FOR THEIR FUTURE APPLICATION ARE OUTLINED. REFERENCE IS MADE TO THE WAY IN WHICH TYPES OF INSTRUMENTS WOULD HAVE TO BE COMBINED TO GIVE A HIGH DEGREE OF PROTECTION TO THE SYSTEM, THE ACTUAL PROTECTION REQUIRED BEING DEPENDENT ON THE OVERALL SAFETY INTENTIONS. ATTENTION IS DRAWN TO THE PROBLEMS OF MINIMIZING THE SPURIOUS TRIP RATE FOR A WELL INSTRUMENTED REACTOR, WHICH LEAD TO STRINGENT REQUIREMENTS ON INSTRUMENT RELIABILITY AND/OR REPLACEABILITY. THE POSSIBLE ROLE OF THE COMPUTER IN HANDLING THE MULTIPLICITY OF COMPLEX SIGNALS IS MENTIONED, TOGETHER WITH THE PROBLEMS THAT HAVE TO BE SOLVED BEFORE THIS CAN BE DONE. IT IS CONCLUDED THAT SATISFACTORY INSTRUMENT PROTECTION IS AVAILABLE FOR WHOLE-CORE FAULTS, BUT WITH REGARD TO SUBASSEMBLY FAULT DETECTION THE SITUATION IS LESS CLEAR. ALTHOUGH SOME INFORMATION IS AVAILABLE FOR GUIDANCE ON THE INSTRUMENTS AND THEIR SPECIFICATIONS, THE JUSTIFICATION AND ACHIEVABILITY OF THE LATTER ARE DEPENDENT ON DEVELOPMENT WORK THAT IS STILL PROCEEDING. IT MAY WELL BE THAT UNCERTAINTIES CONCERNING THE EFFECTS OF THE REACTOR ENVIRONMENT WILL REQUIRE THAT SOME OF THIS WORK TAKE THE FORM OF IN-REACTOR EXPERIMENTS.
- 16-6-3-714 SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT  
BHATIA, P.  
BALTIMORE GAS AND ELECTRIC COMPANY, BALTIMORE, M  
EARLY IN 1970 THE BALTIMORE GAS + ELECTRIC COMPANY DECIDED TO USE SILICONE RUBBER INSULATED CABLES, SIZE NO. 1 AWG AND SMALLER, FOR ALL LOW-VOLTAGE POWER, CONTROL, AND INSTRUMENTATION APPLICATIONS FOR THE CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2. THE DECISION WAS BASED ON EXTENSIVE TESTS MADE BY THE COMPANY TO DETERMINE THE OPTIMUM BALANCE OF PROPERTIES OF CONTROL AND POWER CABLES TO ENSURE THEIR SATISFACTORY OPERATION DURING A SEVERE FIRE AND AFTER EXPOSURE TO RADIATION. RESULTS OF THE TESTS INDICATED THAT SILICONE RUBBER INSULATED CABLES (METHYL PHENYL VINYL BASE COMPOUND) WITH GLASS BRAID OVER THE INSULATED CONDUCTORS, ASBESTOS FILLERS, AND OVERALL ASBESTOS-BRAID JACKETS WILL OPERATE SUCCESSFULLY DURING AND AFTER AN OIL FIRE AND AFTER EXPOSURE TO A TOTAL RADIATION OF 10 (8) RADS AND BORATED STEAM.
- 16-6-5-720 POPULATION EXPOSURES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY  
BARTON, C. J. + DICKSON, R. W. + PAREYCK, D. C.  
BOWEN, P. S. + TURNER, J. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY WAS HELD AT KNOXVILLE, TENN., OCT. 21-24, 1974. ALL BUT 4 OF THE 56 PAPERS PRESENTED ARE INCLUDED IN THE PRINTED PROCEEDINGS THAT WERE DISTRIBUTED AT THE MEETING. TOPICS COVERED IN THE VARIOUS SESSIONS ARE BACKGROUND RADIATION EXPOSURES, MEDICAL RADIATION EXPOSURES (NOT REVIEWED IN THIS

ARTICLE), NUCLEAR POWER EXPOSURES, DOSIMETRY, AND POPULATION EXPOSURES FROM SOURCES OTHER THAN NUCLEAR POWER. A PUBLIC FORUM ON POPULATION EXPOSURES FROM ELECTRIC POWER GENERATION NUCLEAR AND NONNUCLEAR PRODUCED SOME RATHER LIVELY INTERCHANGES BETWEEN A PANEL OF EXPERTS AND THE AUDIENCE. THE BROAD RANGE OF TOPICS COVERED IN THE SYMPOSIUM SHOWS THAT THE TASKS OF THE HEALTH PHYSICIST ARE GROWING MORE COMPLEX.

16-6-5-728 QVO VADIS, PERSONNEL MONITORING  
BECKER, K.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE TENN.  
WITH THE INCREASING USE OF NUCLEAR POWER AND RADIATION SOURCES, THE SELECTION OF OPTIMUM SYSTEMS FOR PERSONNEL MONITORING IS BECOMING A MATTER OF WORLDWIDE CONCERN. THE PRESENT STATUS OF PERSONNEL DOSIMETRY, SOMETIMES CHARACTERIZED BY UNSTABLE AND INACCURATE DETECTORS AND OVERSIMPLIFIED INTERPRETATION OF THE RESULTS, LEAVES MUCH TO BE DESIRED. IN PARTICULAR, PHOTOGRAPHIC FILM, ALTHOUGH HAVING CERTAIN ADVANTAGES WITH REGARD TO ECONOMICS AND INFORMATION CONTENT, UNDERGOES RAPID CHANGES IN WARM AND HUMID CLIMATES. CAREFUL SEALING REDUCES, BUT DOES NOT PREVENT, THESE PROBLEMS. THE REPLACEMENT OF FILM BY SOLID STATE DOSIMETERS, PRIMARILY THERMOLUMINESCENCE DOSIMETERS, IS IN PROGRESS OR BEING CONSIDERED BY AN INCREASING NUMBER OF INSTITUTIONS AND REQUIRES A NUMBER OF DECISIONS CONCERNING THE CHOICE OF THE OPTIMUM DETECTOR(S), BADGE DESIGN, AND EVALUATION SYSTEM, ORGANIZATIONAL MATTERS, SUCH AS THE DESIRABILITY OF AUTOMATION AND COMPUTERIZED BOOKKEEPING, ETC. THE CHANGE ALSO IMPLIES THE POTENTIAL USE OF SUCH ADVANCED CONCEPTS AS DIFFERENT DETECTORS AND MONITORING PERIODS FOR THE LARGE NUMBER OF LOW RISK PERSONS AND THE SMALL NUMBER OF HIGH RISK RADIATION WORKERS.

16-6-6-734 SUMMARY OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
RELEASES OF RADIOACTIVITY IN AIRBORNE AND LIQUID EFFLUENTS AND THE NUMBER OF SHIPMENTS AND ACTIVITY OF SOLID WASTE HAVE BEEN COMPILED BY THE NUCLEAR REGULATORY COMMISSION FROM LICENSEE REPORTS FOR 1973. THE WIDE VARIATIONS IN THE RADIOACTIVITY RELEASES WERE DUE TO DIFFERENCES IN PLANT SIZE, POWER LEVEL, FUEL PERFORMANCE, AND EFFLUENT TREATMENT METHODS. DATA COVERING SPECIFIC ISOTOPES OF PARTICULAR INTEREST ARE SUMMARIZED. IN ALL CASES, RELEASES OF RADIOACTIVITY WERE ONLY SMALL FRACTIONS OF PERMISSIBLE LIMITS SET BY APPLICABLE REGULATIONS OR IN TECHNICAL SPECIFICATIONS.

17-1-1-1 PLANNING FOR NUCLEAR EMERGENCIES

MOELLER, D. W. + SELBY, J. M.  
HARVARD UNIVERSITY, SCHOOL OF PUBLIC HEALTH BOSTON, MASS.  
A PROPERLY DEVELOPED AND EXECUTED EMERGENCY PLAN REPRESENTS AN ADDITIONAL LEVEL OF SAFETY IN DEALING WITH POTENTIAL ACCIDENTS IN NUCLEAR FACILITIES. THIS STATE OF THE ART REVIEW OF THE SUBJECT, BASED PRIMARILY ON MATERIAL PRESENTED BY A VARIETY OF SPEAKERS DURING A SHORT COURSE HELD AT THE HARVARD SCHOOL OF PUBLIC HEALTH IN MAY 1975, SHOWS THAT, ALTHOUGH PROGRESS IS BEING MADE, ADDITIONAL WORK REMAINS TO BE DONE. A CERTAIN DEGREE OF CONFUSION HAS EXISTED BECAUSE OF THE MULTITUDE OF FEDERAL AND STATE AGENCIES HAVING RESPONSIBILITIES IN THIS FIELD, HOWEVER, STEPS ARE BEING TAKEN TO CORRECT THIS SITUATION. ALTHOUGH UPDATED PROTECTIVE ACTION GUIDES FOR AIRBORNE RELEASES HAVE BEEN PUBLISHED, SIMILAR ACTION IS NEEDED FOR LIMITATIONS ON RADIONUCLIDE INTAKE VIA FOOD AND WATER. INDICATIONS ARE THAT, FOR A SINGLE PUFF TYPE OF AIRBORNE RELEASE, IT MAY NOT BE POSSIBLE TO EVACUATE THE NEIGHBORING POPULATION WITHIN THE SHORT TIME SPAN AVAILABLE TO AVOID EXPOSURE. FOR A LONGER TERM CONTINUOUS TYPE OF AIRBORNE RELEASE, HOWEVER, EVACUATION CAN BE VERY USEFUL. STILL IN NEED OF FURTHER EVALUATION AS AN ADJUNCT OR ALTERNATIVE TO EVACUATION IS THE USE OF PROTECTIVE SHELTER AND/OR RADIO-PROTECTIVE PROPHYLAXIS. ALSO IN NEED OF ADDITIONAL STUDY AND/OR DEVELOPMENT ARE METHODS FOR ASSESSING THE NATURE AND COURSE OF AN ACCIDENT, TECHNIQUES FOR RAPIDLY ESTIMATING THE PATHWAY OF A RELEASE AND ANTICIPATED POPULATION DOSES, ASSESSMENT OF THE LONG RANGE IMPLICATIONS OF POTENTIAL WIDESPREAD RADIOACTIVE CONTAMINATION OF LAND AREAS, AND IMPROVEMENTS IN THE CAPABILITIES OF STATE AND LOCAL AGENCIES IN PROVIDING RADIOLOGICAL EMERGENCY RESPONSE.

17-1-1-15 STATE AND LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE WAS ADAPTED FROM A REPORT THAT PROVIDES GUIDANCE TO STATE AND LOCAL GOVERNMENTS ON RADIOLOGICAL EMERGENCY RESPONSE PLANNING. THE REPORT LISTS SPECIFIC PLANNING OBJECTIVES FOR A RADIOLOGICAL EMERGENCY RESPONSE PLAN, ALONG WITH GUIDANCE FOR DETERMINING WHETHER A PLAN MEETS THESE OBJECTIVES. THE GUIDANCE DATA SHOULD BE INCLUDED IN STATE RADIOLOGICAL EMERGENCY RESPONSE PLANS AND, WHERE APPROPRIATE, IN OTHER STATE AND LOCAL GOVERNMENT EMERGENCY PLANS. A CHECKLIST OF MAJOR PLANNING ELEMENTS IS PROVIDED TO ASSIST BOTH EXPERIENCED AND INEXPERIENCED PLANNERS IN CONSTRUCTING A COMPREHENSIVE RADIOLOGICAL EMERGENCY RESPONSE PLAN. EACH

SECTION OF THE CHECKLIST IS SUPPORTED BY SPECIFIC GUIDANCE LANGUAGE. COMPLETION OF THE CHECKLIST WILL NOT IN ITSELF CONSTITUTE A RADIOLOGICAL EMERGENCY RESPONSE PLAN BUT WILL AID IN IDENTIFYING DEFICIENCIES IN CURRENT PLANS.

- 17-1-2-19 PARTIAL BLOCKAGES IN LMFBR FUEL ASSEMBLIES  
FONTANA, M. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EXPERIMENTAL AND ANALYTICAL DATA ON THE EFFECTS OF PARTIAL BLOCKAGES IN SIMULATED LIQUID METAL COOLED FAST BREEDER REACTOR ROD BUNDLES ARE REVIEWED AND THE RESULTS PRESENTED. EXPERIMENTS PERFORMED IN THE FUEL FAILURE MOCKUP AT OAK RIDGE NATIONAL LABORATORY WITH 13- AND 24-SUBCHANNEL INLET BLOCKAGES IN 19-ROD SODIUM COOLED ELECTRICALLY HEATED ROD BUNDLES INDICATE THAT EXCESSIVE TEMPERATURES DO NOT OCCUR AS A RESULT OF THE BLOCKAGES. SIMILAR EXPERIMENTS WITH NONHEAT GENERATING BLOCKAGES OF 6 CENTRAL SUBCHANNELS AND 14 EDGE SUBCHANNELS IN THE HEATED ZONE OF THE ROD BUNDLE INDICATE ACCEPTABLE LOCAL TEMPERATURE INCREASES AT OPERATING CONDITIONS. EXPERIMENTS WITH WATER MOCKUPS SHOW COMPLEX FLOW PATTERNS IN THE WAKE ZONE BEHIND BLOCKAGES. ESTIMATES OF LOCAL CONVECTIVE HEAT TRANSFER IN THE WAKE ZONE WERE MADE BY MEASURING MASS INTERCHANGE BETWEEN THE RECIRCULATING FLOW ZONE AND THE FREE STREAM BY SALT INJECTION TECHNIQUE. GENERALIZATIONS OBTAINED FROM THE WATER MOCKUPS WERE USED TO PREDICT TEMPERATURES IN SODIUM COOLED ROD BUNDLES. ESTIMATES INDICATE THAT LARGE BLOCKAGES (APPROXIMATELY 3 IN. IN DIAMETER) WOULD BE REQUIRED TO CAUSE SODIUM BOILING IN FULL SCALE REACTORS.
- 17-1-3-33 ACOUSTIC EMISSION - A CRITICAL ASSESSMENT  
STANKOFF, K. E. + DAD, G. J.  
ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF.  
THE PURPOSE OF THIS ARTICLE IS TO HIGHLIGHT THE LIMITATIONS OF ACOUSTIC EMISSION FOR USE IN HYDROSTATIC TEST MONITORING AND CONTINUOUS MONITORING OF PRESSURE VESSELS AS DETERMINED FROM A REVIEW OF PRIOR WORK. WITH THE PRESENT STATE OF THE ART FOR MONITORING STRUCTURAL INTEGRITY, ACOUSTIC EMISSION CAN PROBABLY REVEAL ABNORMAL INCIDENTS AND THEIR LOCATIONS, BUT IT CANNOT DESCRIBE THE INCIDENT OR ITS SERIOUSNESS. SPECIFIC CONCLUSIONS ABOUT THE MATURITY OF ACOUSTIC EMISSION MONITORING ARE DRAWN, AND SUGGESTIONS ARE GIVEN FOR FUTURE RESEARCH AND DEVELOPMENT EFFORTS.
- 17-1-3-43 ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QHO  
HAGEN, E. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE PURPOSE OF REPORT WASH-1270 IS TO ENSURE A HIGH DEGREE OF RELIABILITY FOR THE PLANT SAFETY SYSTEMS OF WATER COOLED NUCLEAR POWER PLANTS TO PROTECT THE HEALTH AND SAFETY OF THE PUBLIC. IMPLEMENTATION OF THE REQUIREMENTS SET FORTH IN THE COVER LETTER SENT WITH THAT REPORT TO THE POWER UTILITIES HAS BEEN PROPOSED BY THE UTILITIES, AND REVIEWS OF THESE RESPONSES AND ANALYSES ARE UNDER CONSIDERATION BY THE NUCLEAR REGULATORY COMMISSION. ACCEPTANCE OF THE UTILITIES' POSITIONS HAS NOT BEEN GRANTED, NOR HAS FURTHER GUIDANCE OR DIRECTION BEEN PROPOSED FOR POWER PLANTS NOW OPERATING OR UNDER CONSTRUCTION. FUTURE PLANTS APPARENTLY WILL HAVE TO INCORPORATE SOME AS YET UNDEFINED DESIGN FOR A DUAL ACTING PLANT SAFETY SYSTEM.
- 17-1-4-55 THE SAFETY OF REACTOR PRESSURE VESSELS  
COOPER, W. E. + LANGER, B. P.  
TELEDYNE MATERIALS RESEARCH COMPANY, WALTHAM, MASS.  
WE BELIEVE THAT NUCLEAR REACTOR VESSELS ARE SAFE. DEBATE ON THIS SUBJECT HAS RANGED FROM PURELY EMOTIONAL ARGUMENTS TO LENGTHY AND COMPLICATED STATISTICAL STUDIES. THE PRESENT PAPER WAS PREPARED AS A SUMMARY STATEMENT WITHOUT TECHNICAL DETAIL, BUT WITH A BRIEF DESCRIPTION OF THE TECHNOLOGY AND OF THE MANNER IN WHICH THE TECHNOLOGY IS IMPLEMENTED IN VESSEL CONSTRUCTION.
- 17-1-4-62 IMPROVING REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN  
COOPER, W. E.  
TELEDYNE MATERIALS RESEARCH COMPANY, WALTHAM, MASS.  
ALTHOUGH REACTOR PRESSURE VESSELS ARE SAFE, THEY PRESENTLY CONTRIBUTE TO THE UNAVAILABILITY TIME OF NUCLEAR POWER SYSTEMS. THIS EFFECT COULD BE REDUCED SIGNIFICANTLY BY BETTER APPLICATION OF THE NOW AVAILABLE DESIGN TECHNOLOGY. THIS ARTICLE BRIEFLY DESCRIBES THE STATUS OF THIS TECHNOLOGY, AS PERTINENT TO REACTOR PRESSURE VESSEL AVAILABILITY, AND THE APPLICATION OF THIS TECHNOLOGY DURING THE CONSTRUCTION AND OPERATION PHASES. RECOMMENDATIONS ARE THEN MADE AS TO HOW THIS TECHNOLOGY COULD BE APPLIED TO IMPROVING VESSEL AVAILABILITY.
- 17-1-5-69 TURBULENT DIFFUSION TYPING SCHEMES - A REVIEW  
GIFFORD, P. A.  
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, OAK RIDGE, TENN.  
RECENT ENVIRONMENTAL CONCERNS HAVE GREATLY INCREASED THE NEED FOR TURBULENT TYPING SCHEMES IN ATMOSPHERIC DIFFUSION CALCULATIONS. THE STANDARD METHODS BY BROOKHAVEN NATIONAL LABORATORY, PASQUILL, THE TENNESSEE VALLEY AUTHORITY, AND OTHERS ARE REVIEWED, AND DIFFERENCES, INCONSISTENCIES, AND

MODIFICATIONS TO THE BASIC SCHEMES ARE DISCUSSED. VARIOUS EXCEPTIONAL FLOWS OCCUR TO WHICH EXISTING TURBULENCE TYPING SCHEMES SHOULD NOT BE APPLIED DIRECTLY - DIFFUSION IN NEAR CALM, VERY STABLE CONDITIONS, DIFFUSION OVER CITIES, WATER BODIES, AND IRREGULAR TERRAIN, AND DIFFUSION IN BUILDING WAKES AND NEAR HIGHWAYS. POSSIBLE MODIFICATIONS TO TYPING SCHEMES IN THESE CASES ARE DISCUSSED. IN ALL SUCH EXCEPTIONAL CASES, MANY MORE OBSERVATIONAL DATA ARE NEEDED BEFORE RELIABLE DIFFUSION ESTIMATES CAN BE MADE.

17-1-6-87

QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLANT  
MCGLOTHLAN, C. K.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE EXAMINES THE SHOW CAUSE ORDER ISSUED BY THE DIRECTOR OF REGULATION OF THE ATOMIC ENERGY COMMISSION (AEC) IN 1973 AND THE ACTIONS TAKEN BY THE AEC (NOW NUCLEAR REGULATORY COMMISSION), THE OWNER, THE ARCHITECT ENGINEER, AND OTHERS IN IDENTIFYING AND RESOLVING CERTAIN QUALITY DEFICIENCIES THAT HAVE OCCURRED SINCE 1970 IN THE DESIGN AND CONSTRUCTION PHASES OF THE MIDLAND NUCLEAR POWER PLANT. IMPROVEMENTS IN THE MIDLAND QUALITY ASSURANCE PROGRAM, WHICH RESULTED IN A RULING BY THE AEC REGULATORY STAFF IN FAVOR OF THE OWNER, ARE DISCUSSED.

17-1-6-92

SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL  
ROTH, D. R.

GENERAL PHYSICS CORPORATION, COLUMBIA, MD.  
THIS ARTICLE IS A REVIEW OF THE SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL, HELD MAY 11-14, 1975, AT GATLINBURG, TENN. THE SYMPOSIUM, COSPONSORED BY THE OAK RIDGE NATIONAL LABORATORY AND THE AMERICAN NUCLEAR SOCIETY'S REACTOR OPERATIONS DIVISION AND OAK RIDGE SECTION, WAS ATTENDED BY UTILITY AND INDUSTRY REPRESENTATIVES AS WELL AS BY MEMBERS OF GOVERNMENT AND REGULATORY AGENCIES. IN ADDITION TO SOURCES, SELECTION, AND TRAINING OF PERSONNEL AT NUCLEAR UTILITIES, TRAINING OF OPERATORS AT FUEL PROCESSING PLANTS WAS INCLUDED. THE EDUCATIONAL COMMUNITY PRESENTED SOME NEW APPROACHES TO SUPPLYING QUALIFIED PERSONNEL FOR THE INDUSTRY, AND UTILITY PROGRAMS FOR TRAINING OF SUPPORT AND NONLICENSED PERSONNEL WERE DISCUSSED. AS EVIDENCED BY THE SYMPOSIUM, THERE IS A CONTINUING STRONG INTEREST IN EFFECTIVE TRAINING PROGRAMS. PROGRESS HAS BEEN MADE IN MANY AREAS, BUT SOURCES OF TRAINED PERSONNEL AND EVOLVING REGULATORY REQUIREMENTS CONTINUE TO BE A PROBLEM.

17-2-1-143

WATER REACTOR SAFETY RESEARCH INFORMATION MEETING  
COTTEPILL, W. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE IS A REVIEW OF THE THIRD WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION (NRC) DIVISION OF REACTOR SAFETY RESEARCH, HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., SEPT. 29-OCT. 2, 1975. THIS MEETING CONSISTED OF PARALLEL TECHNICAL PRESENTATIONS IN THE MORNING, FOLLOWED BY SEVERAL SMALLER WORKSHOPS OR DISCUSSION SESSIONS IN THE AFTERNOON. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT ACCIDENT TEST PROGRAM, (2) FUEL BEHAVIOR PROGRAM, (3) ANALYSIS DEVELOPMENT PROGRAM, AND (4) METALLURGY AND MATERIALS PROGRAM. OVER 5 PERSONS, INCLUDING SOME 95 FOREIGN VISITORS FROM 16 COUNTRIES, ATTENDED THE MEETING. SUMMARIES OF MOST OF THE MORNING SESSIONS, WHICH WERE AVAILABLE AT THE MEETING, HAVE BEEN FURTHER CONDENSED AND REFERENCED IN THIS ARTICLE, TOGETHER WITH SOME COMMENTARIES ON SOME OF THE AFTERNOON DISCUSSIONS. NO PROCEEDINGS WILL BE PUBLISHED. SPECIAL FEATURES OF THE MEETING, IN ADDITION TO THE REVIEW OF NRC SPONSORED WATER REACTOR SAFETY RESEARCH PROGRAMS, WERE EIGHT INVITED PAPERS BY INTERNATIONAL EXPERTS, AND INCREASED PARTICIPATION BY BOTH THE U.S. NUCLEAR INDUSTRY AND THE VARIOUS NRC SESSION CHAIRMEN WHO WERE ADMINISTRATIVELY RESPONSIBLE FOR THE WORK IN QUESTION. MANY PROBLEMS AND PROGRAMS WERE DISCUSSED, AND MUCH WAS LEARNED. IT IS REASSURING THAT THESE RESEARCH RESULTS CONTINUE TO SUBSTANTIATE OUR UNDERSTANDING OF REACTOR SAFETY.

17-2-1-171

COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRICAL ENERGY  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS STUDY QUANTIFIES, NORMALIZES, AND COMPILES CONVENTIONAL AND SOCIETAL COSTS ASSOCIATED WITH THE PRODUCTION OF ELECTRICAL ENERGY BY CURRENTLY AVAILABLE ALTERNATIVE SYSTEMS BASED ON COAL, GAS, NUCLEAR FUELS, AND HYDROENERGY. PARTICULAR EMPHASIS IS PLACED ON EXAMINING EACH ENERGY SYSTEM IN ITS ENTIRETY - BOTH THE POWER PLANT AND ITS SUPPORTING FUEL CYCLE. HOWEVER, THE STUDY IS RESTRICTED TO ROUTINE IMPACTS, INCLUDING ROUTINE ACCIDENTS WHOSE FREQUENCIES CAN BE ESTABLISHED FROM HISTORICAL DATA. FROM THE AVAILABLE DATA, WHICH ARE THOROUGHLY REFERENCED HEREIN, IT IS CONCLUDED THAT NATURAL GAS INCURS MINIMAL ENVIRONMENTAL- AND HUMAN-IMPACT COSTS BUT REMAINING SUPPLIES ARE SMALL, OIL PRESENTS CONSIDERABLY GREATER ENVIRONMENTAL AND HUMAN IMPACTS BUT SUBSTANTIALLY LESS THAN THOSE FROM COAL, WHICH IS BOTH THE MOST SERIOUS ENVIRONMENTAL OFFENDER AND THE MOST ABUNDANT DOMESTIC FUEL SOURCE. NUCLEAR FUELS, WHICH ARE ABUNDANT NATURAL RESOURCES, HAVE SOMEWHAT LESS ENVIRONMENTAL AND HUMAN IMPACTS THAN GAS. THE CONVENTIONAL FUEL COSTS OF COAL AND NUCLEAR FUEL CYCLES ARE COMPARABLE AND CONSIDERABLY LESS EXPENSIVE THAN GAS OR OIL, BUT IT APPEARS THAT THE COST OF

ABATEMENT AND HEALTH AND SAFETY MEASURES WILL SIGNIFICANTLY INCREASE THE COST OF ENERGY FROM COAL OVER THAT FROM NUCLEAR FUEL.

17-2-2-194 STEAM - WATER MIXING STUDIES RELATED TO EMERGENCY CORE COOLING SYSTEM PERFORMANCE

CODNIA, R. A. + CARRIFNER, W. A.

BATTELLE COLUMBUS LABORATORIES, COLUMBUS, OHIO

THIS ARTICLE IS A REVIEW OF RECENT EXPERIMENTAL WORK RELATED TO THE INTERACTIONS BETWEEN THE PRIMARY SYSTEM FLUID AND EMERGENCY CORE COOLING (ECC) WATER IN LIGHT WATER REACTOR SYSTEMS DURING RECOVERY FROM A POSTULATED LOSS OF COOLANT ACCIDENT. THE TESTING PROGRAMS ARE EXPLORATORY SEPARATE EFFECTS TESTS IN REDUCED SIZE SIMULATORS OF REACTOR SYSTEMS. THE TESTS ADDRESS THE COLD-LEG MANOMETER LOOP, THE COLD-LEG PIPE ECCS INJECTION SECTION, AND THE DOWNCOMER ANNULUS LOWER PLENUM REGIONS OF REACTOR SYSTEMS. DATA TO DATE INDICATE THE ABSENCE OF COLD-LEG PIPE PLUGGING, THE PRESENCE OF OSCILLATORY FLOW BEHAVIOR INITIATED BY FULL PIPE FLOW, AND THE PREDOMINANT ROLE OF CONDENSATION IN BOTH THE INJECTION SECTION AND ANNULUS REGIONS.

17-2-2-194

THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR REACTOR PLANT ANALYSIS

SOLBRIG, C. W. + BARNUM, D. J.

AEROJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO

THE RELAP4 COMPUTER CODE IS A VERY USEFUL TOOL FOR NUCLEAR REACTOR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE FIRST OF THREE PART SERIES WHICH DISCUSSES, RESPECTIVELY, THE RELAP4 PROGRAM, INPUT MODELING, AND TYPICAL RESULTS, AND IS DIRECTED TOWARD THE POTENTIAL CODE USER. THIS ARTICLE DESCRIBES THE BASIC FLUID MODEL, THE IMPROVEMENTS OVER ITS PREDECESSOR, RELAP3, AND A FURTHER MODIFICATION, RELAP-EM, SPECIFICALLY DESIGNED TO PRODUCE CONSERVATIVE RESULTS. RELAP4 IS COMPARED TO OTHER SIMILAR CODES, AND THE GENERIC LIMITATIONS OF THESE CODES ARE NOTED. HOWEVER, IT IS CONCLUDED THAT RELAP4 IS AN EXAMPLE OF THE BETTER CURRENT NUCLEAR SAFETY CODES.

17-2-4-208

EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTORS

CHAPMAN, R. H.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

CONCEPTS AND PRACTICES USED IN THE DESIGN OF EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTOR (LMFBR) SYSTEMS WERE SURVEYED TO ASCERTAIN THE MANNER BY WHICH THE FUNCTIONAL REQUIREMENTS WERE SATISFIED, THE SEVERITY OF SODIUM SPILLS THE LINERS WERE DESIGNED TO ACCOMMODATE, AND THE PROBLEMS ENCOUNTERED IN DESIGN AND CONSTRUCTION. THE SURVEY WAS LIMITED TO 'LOOP-TYPE' LMFBRs, WITH PRIMARY INTEREST ON RECENTLY CONSTRUCTED PLANTS. THIS ARTICLE IS ESSENTIALLY THE INTRODUCTION AND SUMMARY OF A STATE OF THE ART REPORT THAT DISCUSSES STEEL LINED CONCRETE STRUCTURES, DESCRIBES CELL LINER DESIGNS USED IN SEVERAL LMFBR PLANTS, WITH PARTICULAR EMPHASIS ON THE SOUTHWEST EXPERIMENTAL FAST OXIDE REACTOR (SEFOR), WHICH USES A FIXED LINER, AND THE FAST FLUX TEST FACILITY (PFTF), WHICH USES A FREE FLOATING LINER, AND IDENTIFIES RESEARCH AND DEVELOPMENT BELIEVED NECESSARY TO PERMIT A RATIONAL AND THOROUGH ASSESSMENT OF CELL LINER DESIGN CONCEPTS.

17-2-5-216

RADIOLOGICAL ASPECTS OF ENVIRONMENTAL TRITIUM

ROHWER, P. S. + WILCOX, W. H.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE POTENTIAL RADIOLOGICAL IMPLICATIONS OF TRITIUM RELEASED TO THE ENVIRONMENT MUST BE ASSESSED TO DEVELOP A POLICY FOR MANAGING THE TRITIUM INVENTORY PROJECTED FOR THE NUCLEAR POWER INDUSTRY, WHICH ALREADY PRODUCES TRITIUM IN MEGACURIE QUANTITIES ANNUALLY. DEVELOPMENT OF FUSION REACTORS WILL CREATE LARGE POTENTIAL SOURCES FOR CONTINUOUS AND PULSE RELEASES OF TRITIUM, MUCH OF IT AS TRITIUM GAS. AT PRESENT 90 PERCENT OF THE TRITIUM PRODUCED IS RELEASED IN GASEOUS AND LIQUID EFFLUENTS TO BE DEPOSITED IN THE HYDROSPHERE AS TRITIATED WATER. TWO ALTERNATIVES MUST BE CONSIDERED RELATIVE TO A LONG TERM POLICY FOR TRITIUM MANAGEMENT. ONE METHOD IS TO DILUTE AND DISPERSE THE TRITIUM FROM POWER STATIONS AND NUCLEAR FUEL REPROCESSING PLANTS AT A RATE COMPENSURATE WITH PRODUCTION AT THE FACILITY, AND THE SECOND METHOD IS TO TAKE STEPS TO CONTAIN THE TRITIUM FOR STORAGE. IN THIS ARTICLE A NUMBER OF FACTORS THAT INFLUENCE THE MAGNITUDE OF THE ESTIMATED RADIOLOGICAL IMPACT OF TRITIUM ON MAN ARE DISCUSSED, AND KEY POINTS CONCERNING THE BEHAVIOR OF TRITIUM ALONG THE EXPOSURE PATHWAYS TO MAN ARE SUMMARIZED. BIOACCUMULATION FACTORS FOR TRITIUM APPROXIMATE UNITY FOR ALL HYDROGEN POOLS IN SPITE OF THE LARGE MASS DIFFERENCE OF TRITIUM RELATIVE TO PROTIUM. THE QUALITY FACTOR FOR TRITIUM RELATING LINEAR ENERGY TRANSFER AND BIOLOGICAL EFFECTIVENESS IS CURRENTLY 1.0. HOWEVER, THE POSSIBLE NEED FOR A LARGER QUALITY FACTOR, PARTICULARLY FOR LOW DOSES AND DOSE RATES, IS ACKNOWLEDGED. OTHER TOPICS DISCUSSED INCLUDE TRANSMUTATION AND POSITION EFFECTS, UNCERTAINTIES CONCERNING THE OXIDATION RATE OF TRITIUM GAS IN THE ENVIRONMENT, THE POSSIBLE IMPORTANCE OF THE AGE OF THE EXPOSED INDIVIDUAL, AND CURRENT RADIATION SAFETY GUIDES THAT LIMIT THE EXPOSURE OF MAN TO TRITIUM. THE ESTIMATED DOSE TO MAN FROM ORGANICALLY BOUND TRITIUM IS THOUGHT TO INCREASE THE DOSE

ESTIMATES CALCULATED ON THE BASIS OF TISSUE WATER TRITIUM ALONE BY APPROXIMATELY 20 PERCENT. THUS THE ESTIMATED TOTAL DOSE TO MAN FOR INTAKES OF ENVIRONMENTAL TRITIUM IS 0.07 MREM/MICRO-CURIES.

- 17-2-5-223 A SURVEY OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVERSION CONDITIONS  
VAN DER HOVEN, I.  
NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION, SILVER SPRING,  
MD.  
MEASURED PLUME PEAK CONCENTRATIONS FROM FIVE SEPARATE FIELD EXPERIMENTS UNDER LOW WIND SPEED INVERSION CONDITIONS ARE ANALYZED AND COMPARED WITH COMPUTATIONS BASED ON DIFFUSION PARAMETER-TYPING PROCEDURES CURRENTLY IN USE BY THE U.S. NUCLEAR REGULATORY COMMISSION. IN ALL CASES THE MEASURED CONCENTRATIONS FROM GROUND SOURCES WERE LOWER THAN CALCULATED VALUES, THE DIFFERENCE BEING PRIMARILY DUE TO ENHANCED CROSSWIND SPREAD. MOREOVER, THE DIFFERENCES APPEARED TO BE A FUNCTION OF SURFACE ROUGHNESS, BEING GREATEST OVER HILLY FORESTED TERRAIN.
- 17-2-6-231 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974  
HARE, M. G.  
CHALK RIVER NUCLEAR LABORATORIES, ONTARIO, CANADA  
STEAM GENERATOR TUBE FAILURES WERE REPORTED AT 25 OF 59 WATER COOLED NUCLEAR POWER REACTORS SURVEYED IN 1974, COMPARED TO 11 OF 49 IN 1973. THIS ARTICLE SUMMARIZES THESE FAILURES, MOST OF WHICH, WHERE THE CAUSE IS KNOWN, WERE THE RESULT OF CORROSION. WATER CHEMISTRY CONTROL, INSPECTION AND REPAIR PROCEDURES, AND FAILURE RATES ARE DISCUSSED.
- 17-3-1-201 ATMOSPHERIC RELEASE ADVISORY CAPABILITY  
DICKERSON, M. H. + ORPHAN, R. C.  
LAWRENCE LIVERMORE LABORATORY, LIVERMORE, CALIF.  
THE ATMOSPHERIC RELEASE ADVISORY CAPABILITY (ARAC) IS A CONCEPT FOR A SERVICE TO FACILITIES REQUIRING A MEANS OF REAL TIME PREDICTION OF THE EXTENT OF HEALTH HAZARDS THAT MAY RESULT FROM A RELEASE OF RADIONUCLIDES AND OTHER TOXIC MATERIALS. THE ARAC SYSTEM, SPONSORED BY THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (ERDA), CONSISTS OF A NETWORK OF SERVICED SITE FACILITIES AND A CENTRAL FACILITY LOCATED AT THE UNIVERSITY OF CALIFORNIA, LAWRENCE LIVERMORE LABORATORY (LLL). SINCE 1973, WHEN THE CONCEPT WAS INITIATED, A JOINT FEASIBILITY STUDY OF THE ARAC SYSTEM HAS BEEN CONDUCTED BY LLL AND SAVANNAH RIVER LABORATORY (SRL). A SYSTEM OF THREE SITES, LLL, SRL, AND THE ROCKY PLATS PLANT, IS BEING TESTED AND EVALUATED DURING FY 1976. PLANS ARE READY TO IMPLEMENT THE ARAC SERVICE FOR ADDITIONAL ERDA NUCLEAR FACILITIES OVER THE NEXT 3 YEARS. THIS ARTICLE BRIEFLY DESCRIBES THE ARAC CONCEPT, DISCUSSES THE PROGRESS TO DATE, AND OUTLINES FUTURE PLANS FOR DEVELOPING THE SYSTEM.
- 17-3-1-289 AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975  
KEILHOLTZ, G. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE BRIEFLY REVIEWS THE AMERICAN NUCLEAR SOCIETY TOPICAL MEETING ON NUCLEAR SAFETY HELD AT TUCSON, ARIZ., OCT. 5-8, 1975. A COMPREHENSIVE SURVEY WAS MADE OF SAFETY ASPECTS OF THE CONTEMPORARY UTILIZATION OF NUCLEAR ENERGY, WITH EMPHASIS ON FUEL PROCESSING AND TRANSPORT, REACTOR PLANT SAFETY, AND NUCLEAR WASTE MANAGEMENT. INVITED SPEAKERS FROM INDUSTRY, UTILITIES, AND GOVERNMENT DISCUSSED SUBJECTS BASED ON THE EXPERIENCE OF THE LIGHT WATER AND GAS COOLED REACTOR INDUSTRIES. THE INTERNATIONAL PROGRAMS IN KEY AREAS WERE COVERED.
- 17-3-2-299 THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT MODEL  
BARNUM, D. J. + SOLBPIG, C. W.  
AEROSJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO  
THE RELAP4 COMPUTER CODE IS AN IMPORTANT ANALYSIS TOOL FOR NUCLEAR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE SECOND OF A THREE PART SERIES WHICH DISCUSSES, RESPECTIVELY, THE RELAP4 PROGRAM, INPUT MODELING, AND TYPICAL RESULTS. IN THIS ARTICLE IS DESCRIBED SOME OF THE CONSIDERATIONS REQUIRED TO MODEL A THERMAL AND HYDRAULIC SYSTEM WITH PARTICULAR EMPHASIS IN LIGHT WATER NUCLEAR POWER REACTORS. ENGINEERING DECISIONS REQUIRED IN PREPARING INPUT ARE AS IMPORTANT IN THE FINAL CODE RESULTS AS THE CODE ITSELF. CODES THAT ARE SIMILAR TO RELAP4 (MENTIONED IN PART 1) REQUIRE SIMILAR INPUT CONSIDERATIONS. THE ARTICLE'S CONCLUSION IS THAT THE INPUT DESCRIPTION OF A SYSTEM IS NOT UNIQUE, AND DIFFERENT MODELERS WOULD PRODUCE DIFFERENT INPUT WITH CONSEQUENT DIFFERENT OUTPUT. HOWEVER, IT IS ALWAYS POSSIBLE TO OBTAIN CONSERVATIVE RESULTS, IF DESIRED, WITH THE USE OF THE EVALUATION MODEL (EM) VERSION OF THE CODE.
- 17-3-2-312 AIRCRAFT CRASH PROBABILITIES  
(EDITOR'S NOTE - A COMPREHENSIVE REVIEW OF THE RISK OF AIRCRAFT CRASH TO NUCLEAR POWER PLANTS WAS PRESENTED IN NUCLEAR SAFETY 15(3). THE PRESENT ARTICLE IS TAKEN FROM THE NRC REACTOR SAFETY STUDY AND SUMMARIZES THE PROCEDURE FOLLOWED BY THE REGULATORY

STAFF IN ASSESSING AIRCRAFT RISK AND ALSO TABULATES CRASH PROBABILITIES. SUCH INFORMATION IS NECESSARY FOR AN AIRCRAFT HAZARDS ANALYSIS AS DESCRIBED IN THE NRC REGULATORY GUIDE.)

- 17-3-3-315 HUMAN RELIABILITY ANALYSIS  
THIS REVISED VERSION OF HUMAN RELIABILITY ANALYSIS WAS TAKEN FROM THE RISK ASSESSMENT ANALYSIS AS ORIGINALLY PRESENTED IN REPORT WASH-1400, THE REACTOR SAFETY STUDY. THE REFERENCES GIVEN IN THE REPORT ARE SUPPLEMENTED BY THOSE IN THE POSTSCRIPT, AND A SHORT BIBLIOGRAPHY IS APPENDED.
- 17-3-4-327 NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL STEELS  
STEELE, L. E.  
NAVAL RESEARCH LABORATORY, WASHINGTON, D. C.  
THE FUTURE OF NUCLEAR POWER DEPENDS IMPORTANTLY ON THE ASSURANCE OF SAFETY AND RELIABILITY. THE PRIMARY PRESSURE BOUNDARY, ESPECIALLY THE CORE REGION PRESSURE VESSEL, MUST WITHSTAND THE USUAL SERVICE CONDITIONS PLUS NEUTRON RADIATION, WHICH EMBRITTLES, HARDENS, AND STRENGTHENS THE STEEL USED IN THE PRESSURE VESSEL. THIS ARTICLE REVIEWS THE CRITICAL FACTORS ASSOCIATED WITH RADIATION EMBRITTLEMENT AND THE MEASURES THAT CAN BE TAKEN TO MINIMIZE THIS EFFECT AND THUS ENHANCE SYSTEM SAFETY FOR LIGHT WATER REACTORS.
- 17-3-5-344 IDENTIFICATION OF POTENTIAL IMPROVEMENTS IN ENVIRONMENTAL SURVEILLANCE TECHNIQUES  
WAITE, D. A. \* DENHAM, D. B.  
PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.  
IN THE LAST 2 YEARS, SEVERAL POLLS WERE TAKEN AMONG DIFFERENT COMPONENTS OF THE APPLIED ENVIRONMENTAL SURVEILLANCE COMMUNITY TO IDENTIFY AREAS OF ENVIRONMENTAL SURVEILLANCE METHODOLOGY WHICH DESERVE PRESENT AND FUTURE INVESTIGATIONAL EMPHASIS. 'PROGRAM DESIGN RATIONALE,' 'DATA HANDLING AND INTERPRETATION,' AND 'QUALITY CONTROL' CONSISTENTLY RANKED 1, 2, AND 3. 'SAMPLING' AND 'SAMPLE ANALYSIS' RANKED 4 AND 5. IMPROVEMENTS IN PROGRAM RATIONALE AND DATA INTERPRETATION METHODOLOGY ARE CURRENTLY BEING EFFECTED THROUGH THE USE OF CRITICAL PATHWAY ANALYSIS AND DISTRIBUTION ANALYSIS. THE USE OF EXISTING REGIONAL ENVIRONMENTAL SURVEILLANCE DATA AND PAST KNOWLEDGE OF CONTAMINANT TRANSPORT CHARACTERISTICS MAKES THE PROCESS OF ELIMINATING NONCRITICAL CONTAMINANTS AND MEDIA RELATIVELY SIMPLE, SO THAT FURTHER INVESTIGATION OF CRITICAL PATHWAYS AND CONTAMINANTS CAN BE EMPHASIZED. DISTRIBUTION ANALYSIS CAN BE USED WITH CONFIDENCE FOR INTERPRETING THE DATA IN TERMS OF SAMPLE REPRESENTATIVENESS AND FOR THE IDENTIFICATION OF TYPICAL ENVIRONMENTAL LEVELS (FROM GEOMETRIC MEANS) AND EXPECTED UPPER LIMITS (STANDARD GEOMETRIC DEVIATIONS).
- 17-3-5-351 RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES  
BLAYLOCK, B. G. \* WITHERSPOON, J. P.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
AQUATIC ORGANISMS ARE EXPOSED TO RADIONUCLIDES RELEASED TO THE ENVIRONMENT DURING VARIOUS STEPS OF THE NUCLEAR FUEL CYCLE. ROUTINE RELEASES FROM THESE PROCESSES ARE RESTRICTED IN COMPLIANCE WITH THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION, WHICH RECOMMENDS LIMITS FOR RADIATION DOSES TO THE GENERAL PUBLIC. IT IS GENERALLY ACCEPTED THAT AQUATIC ORGANISMS WILL NOT RECEIVE DAMAGING EXTERNAL RADIATION DOSES IN SUCH ENVIRONMENTS. BECAUSE OF THE POSSIBLE BIOACCUMULATION OF RADIONUCLIDES, HOWEVER, THERE IS CONCERN THAT AQUATIC ORGANISMS MIGHT BE ADVERSELY AFFECTED BY INTERNAL DOSES. THE OBJECTIVES OF THIS ARTICLE ARE (1) TO ESTIMATE THE RADIATION DOSE RECEIVED BY AQUATIC BIOTA FROM THE DIFFERENT PROCESSES AND TO DETERMINE THE MAJOR DOSE CONTRIBUTING RADIONUCLIDES AND (2) TO ASSESS THE IMPACT OF ESTIMATED DOSES ON AQUATIC BIOTA. DOSE ESTIMATES ARE MADE BY USING MEASUREMENTS OF RADIONUCLIDE CONCENTRATIONS IN THE LIQUID EFFLUENTS OF REPRESENTATIVE FACILITIES. WHERE SUCH MEASUREMENTS ARE NOT AVAILABLE, PREDICTED RADIOACTIVE RELEASES TO THE AQUATIC ENVIRONMENT ARE USED. ALTHOUGH RADIOACTIVE RELEASES FROM REACTORS USED TO GENERATE ELECTRICAL ENERGY HAVE RECEIVED THE MOST ATTENTION AND ARE THE BEST DOCUMENTED, THIS EVALUATION SHOWS THE POTENTIAL FOR A GREATER RADIATION DOSE TO AQUATIC BIOTA FROM THE NUCLEAR FUEL-SUPPLY FACILITIES (I.E., MINING AND MILLING). THE EFFECTS OF CHRONIC LOW LEVEL RADIATION ON AQUATIC ORGANISMS ARE DISCUSSED FROM SOMATIC AND GENETIC VIEWPOINTS. ON THE BASIS OF THE BODY OF RADIOBIOLOGICAL EVIDENCE ACCUMULATED TO DATE, NO SIGNIFICANT DELETERIOUS EFFECTS ARE PREDICTED FOR POPULATIONS OF AQUATIC ORGANISMS EXPOSED TO THE ESTIMATED DOSE RATES RESULTING FROM ROUTINE RELEASES FROM CONVERSION, ENRICHMENT, FABRICATION, REACTOR AND REPROCESSING FACILITIES. AT THE DOSES ESTIMATED FOR MILLING AND MINING OPERATIONS, IT WOULD BE DIFFICULT TO DETECT RADIATION EFFECTS ON AQUATIC POPULATIONS. HOWEVER, THE SIGNIFICANCE OF SUCH RADIATION EXPOSURES TO AQUATIC POPULATIONS CANNOT BE FULLY EVALUATED WITHOUT FURTHER RESEARCH ON EFFECTS OF CHRONIC LOW LEVEL RADIATION.

- 17-3-6-363 THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTOR INDUSTRIES  
BAKER, K. S.  
U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON,  
D.C.  
THIS ARTICLE REVIEWS SAFETY RELATED DATA FOR 1973 AND 1974  
COLLECTED FROM PRIVATE INDUSTRIES ENGAGED IN THE PRODUCTION OF  
URANIUM FUEL OR REACTOR COMPONENTS FOR COMMERCIAL NUCLEAR POWER  
REACTORS. OCCUPATIONAL INJURY AND ILLNESS INCIDENCE RATES  
CALCULATED FROM THE DATA ARE COMPARED WITH THOSE OF OTHER  
INDUSTRIES. RADIOLOGICAL HEALTH DATA ARE ALSO PRESENTED AND  
DISCUSSED.
- 17-4-1-411 NUCLFAR ENERGY CENTER SITE SURVEY - 1975  
NRC OFFICE OF SPECIAL STUDIES, WASHINGTON, DC  
(EDITOR'S NOTE - THE ENERGY REORGANIZATION ACT OF 1974 REQUIRED  
THE NEWLY ESTABLISHED U.S. NUCLEAR REGULATORY COMMISSION (NRC)  
TO UNDERTAKE A NUCLEAR ENERGY CENTER SITE SURVEY. THAT SURVEY  
AND THE CONCOMITANT CONSIDERATIONS ARE CONTAINED IN USNRC  
REPORT NUREG-0001 PUBLISHED JANUARY 1976 AND SOLD BY NTIS. THE  
FINAL REPORT INCLUDES SEVERAL SEPARATE DOCUMENTS AS FOLLOWS -  
EXECUTIVE SUMMARY (20 PAGES), \$4.00. PART I, SUMMARY AND  
CONCLUSIONS (220 PAGES), \$9.00. PART I, APPENDIX A. U.S. MAP  
COARSE SCREENING RESULTS, \$3.50. PART II, THE U.S. ELECTRIC  
POWER SYSTEM AND THE POTENTIAL ROLE OF NUCLFAR ENERGY CENTERS  
(225 PAGES), \$9.00. PART III, TECHNICAL CONSIDERATIONS (615  
PAGES), \$16.75. PART IV, PRACTICAL ISSUES OF IMPLEMENTATION  
(700 PAGES), \$18.75. PART V, RESOURCE AVAILABILITY AND SITE  
SCREENING (230 PAGES), \$8.00. INCLUDED IN THIS ARTICLE (WITH  
MINOR EDITING) ARE SEC. 1, INTRODUCTION AND RESULTS, FROM THE  
EXECUTIVE SUMMARY, A U.S. MAP CONTAINING THE COARSE SCREENING  
RESULTS, AND A BIBLIOGRAPHY OF THE LITERATURE ON NUCLEAR ENERGY  
CENTERS PREPARED BY THE NUCLEAR SAFETY INFORMATION CENTER. THE  
NRC REPORT INDICATES THAT NUCLEAR ENERGY CENTERS, WITH UP TO 20  
NUCLEAR POWER REACTORS, CAN BE FEASIBLE AND PRACTICAL IN MANY  
LOCATIONS BUT THAT FEDERAL AND STATE PARTICIPATION WOULD  
PROBABLY BE REQUIRED TO FURTHER THE DEVELOPMENT OF A  
SUBSTANTIAL NUMBER OF CENTERS.)
- 17-4-2-422 THE RELAP4 COMPUTER CODE III. LOCA ANALYSIS RESULTS OF A TYPICAL PWR PLANT  
BAENUM, D. J. + SOLBRIG, C. W.  
AEROJET NUCLEAR COMPANY, IDAHO FALLS, IDAHO  
THE RELAP4 COMPUTER PROGRAM IS A VALUABLE TOOL FOR USE IN  
NUCLEAR SAFETY ANALYSIS. IT IS USED PRINCIPALLY IN THE ANALYSIS  
OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT BUT IS ALSO USED  
IN SEVERAL OTHER APPLICATIONS. THIS ARTICLE IS THE LAST OF A  
THREE PART SERIES THAT DISCUSSES (1) THE RELAP4 PROGRAM, (2)  
INPUT MODELING, AND (3) TYPICAL RESULTS. THIS ARTICLE CONSIDERS  
THE INPUT REQUIRED TO MODEL A TYPICAL FOUR-LOOP PRESSURIZED  
WATER REACTOR, THE CALCULATIONAL RESULTS FOR THIS PLANT, AND  
THE PHYSICAL PHENOMENA THAT THESE RESULTS REPRESENT. THE  
CALCULATIONS WERE PERFORMED WITH THE STANDARD VERSION OF RELAP4  
(THE LATEST PUBLICLY AVAILABLE VERSION) INSTEAD OF THE  
CONSERVATIVE VERSION USED FOR LICENSING. THE RESULTS ARE  
REPRESENTATIVE OF LARGE WATER REACTORS, BUT DIFFERENT DESIGNS  
WILL EXHIBIT DIFFERENT PHENOMENA.
- 17-4-3-437 RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH REACTOR  
WERNER, R. A. + LOYALKA, S. E.  
UNIVERSITY OF MISSOURI, COLUMBIA, MISSOURI  
THE RELIABILITY ANALYSIS OF ANTICIPATED TRANSIENTS WITHOUT  
SCRAM IS A TOPIC OF CONSIDERABLE SIGNIFICANCE IN REACTOR SAFETY  
STUDIES. THIS ARTICLE DESCRIBES THE RESULTS OF A RECENTLY  
COMPLETED STUDY ON THE RELIABILITY OF THE MISSOURI UNIVERSITY  
RESEARCH REACTOR (MURR) SCRAM SYSTEM. FOR THIS REACTOR IT HAS  
BEEN DETERMINED THAT THE FAILURE TO INITIATE A SCRAM  
AUTOMATICALLY OR MANUALLY WITHIN 7.5 SEC OF AN ISOLATION VALVE  
CLOSURE CAN LEAD TO CORE MELTDOWN. SINCE VALVE CLOSURE IS A  
CREDIBLE ACCIDENT (IT HAS OCCURRED ONCE DURING THE PAST 5  
YEARS), IT IS IMPORTANT TO KNOW THE RELIABILITY OF THE SCRAM  
SYSTEM. THE AUTHORS HAVE USED THE EVENT AND FAULT TREE  
METHODOLOGIES TO ANALYZE ACCIDENT SEQUENCES AND THE SCRAM  
SYSTEM. SEVERAL COMMON MODE FAILURES HAVE BEEN IDENTIFIED, AND  
THE AVAILABILITY PROBABILITIES FOR EACH PRIMARY EVENT WERE  
OBTAINED BY A DETAILED EXAMINATION OF THE MURR OPERATING  
RECORDS. DETAILED ANALYSIS SHOWS THAT THE MURR SCRAM SYSTEM IS  
HIGHLY RELIABLE AND COMPARES FAVORABLY WITH THE CORRESPONDING  
RESULTS FOR SURRY I, WHICH WAS DISCUSSED IN THE REACTOR SAFETY  
STUDY.
- 17-4-4-447 RELATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR SAFETY  
NEBKLE, J. G. + WHITMAN, G. D. + BRYAN, R. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
UNDER THE AUSPICES OF THE HEAVY-SECTION STEEL TECHNOLOGY  
PROGRAM AT OAK RIDGE NATIONAL LABORATORY, EIGHT INTERMEDIATE  
SIZED (6-IN. WALL THICKNESS AND 39-IN. OUTSIDE DIAMETER) STEEL  
PRESSURE VESSELS CONTAINING CAREFULLY PREPARED AND SHARPENED  
SURFACE CRACKS HAVE BEEN TESTED TO PROVIDE AN IMPROVED  
QUANTITATIVE BASIS FOR EVALUATING THE SAFETY MARGINS AGAINST  
FRACTURE OF NUCLFAR REACTOR PRESSURE VESSELS. THE CYLINDRICAL  
REGIONS OF THE TEST VESSELS WERE FABRICATED FROM EITHER A508



CLASS 2 FORGING STEEL OR A533, GRADE B, CLASS 1 STEEL PLATE. THE FLAWS IN THE TEST VESSELS WERE 1.20 TO 5.30 IN. DEEP, AND TEST TEMPERATURES RANGED FROM 32F TO 196F. EXTENSIVE FAST FRACTURE WAS OBSERVED, AS EXPECTED, AT 32F AT A PRESSURE NEAR THE GROSS YIELD PRESSURE OF THE TEST VESSEL, AND TWO VESSELS LEAKED WITHOUT FRACTURING AT OR SLIGHTLY ABOVE 190F. EXTENSIVE FRACTURE ANALYSES WERE PERFORMED ON ALL VESSELS. THE ANALYTICAL STUDIES PERFORMED INDICATE THAT, BELOW THE UPPER-SHELF TEMPERATURE RANGE, LINEAR ELASTIC FRACTURE MECHANICS (EXPRESSED IN TERMS OF STRAIN) IS ACCURATE OR CONSERVATIVE, DEPENDING ON TRANSVERSE RESTRAINT CONDITIONS PRIOR TO THE ONSET OF THROUGH THE THICKNESS YIELDING. IN ADDITION, IN THE CYLINDRICAL REGION OF A VESSEL, WITHIN THE UPPER SHELF TEMPERATURE RANGE, FAILURE IS CONTROLLED BY THE ONSET OF PLASTIC INSTABILITY IN THE REGION SURROUNDING THE FLAW IF THE UPPER SHELF TOUGHNESS IS SUFFICIENTLY HIGH. FOR SURFACE FLAWS OF LESS THAN HALF THE TEST VESSEL WALL THICKNESS IN DEPTH, FAILURE LOADS WERE APPROXIMATELY THREE TIMES THE CODE DESIGN PRESSURE OF THE TEST VESSELS. APPLICATION OF THE ANALYSIS PROCEDURES DEVELOPED FOR THESE TESTS ON INTERMEDIATE SIZED VESSELS TO A HYPOTHETICAL REACTOR PRESSURE VESSEL INDICATES THAT A SIMILAR MARGIN OF SAFETY IS INHERENT IN FULL SCALE VESSELS.

17-4-5-469

## CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PROBLEM

RICHARD, C. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

IN FEBRUARY 1974 THE NATURAL RESOURCES DEFENSE COUNCIL, INC. (NRDC), BROUGHT A PETITION TO THE ATTENTION OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY AND THE U.S. ATOMIC ENERGY COMMISSION WHICH CALLED FOR A REDUCTION IN RADIATION STANDARDS FOR INSOLUBLE, INHALED ALPHA EMITTING TRANSURANIUM ELEMENTS BY A FACTOR OF 115,000. THE PETITION TO AMEND RADIATION PROTECTION STANDARDS AS THEY APPLY TO HOT PARTICLES WAS SUBMITTED ALONG WITH A SUPPORTING DOCUMENT ENTITLED 'RADIATION STANDARDS FOR HOT PARTICLES.' THIS ARTICLE SUMMARIZES THE RESPONSES OF VARIOUS AGENCIES, ORGANIZATIONS, AND INDIVIDUALS THAT HAVE APPEARED DURING THE TWO YEARS SINCE THE PETITION WAS SUBMITTED. THE BULK OF SCIENTIFIC EVIDENCE AVAILABLE TO DATE DOES NOT APPEAR TO SUPPORT THE PETITION OR THE SUPPORTING HYPOTHESIS. NOT CONSIDERED AT THIS TIME ARE CHANGES IN THE ORIGINAL PETITION OR REBUTTALS PREPARED IN RESPONSE TO SOME OF THE WORKS PRESENTED IN THIS ARTICLE.

17-4-5-471

## NATURAL BACKGROUND RADIATION IN THE UNITED STATES

NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS,  
WASHINGTON, D.C.

(EDITOR'S NOTE - RADIATION IN THE ENVIRONMENT FROM NATURAL SOURCES IS THE MAJOR SOURCE OF RADIATION EXPOSURE TO MAN. FOR THIS REASON IT IS FREQUENTLY USED AS A STANDARD OF COMPARISON FOR EXPOSURES FROM MEDICAL USES, WEAPONS TESTS FALLOUT, AND NUCLEAR POWER. TO MAKE NATURAL BACKGROUND RADIATION DATA MORE ADAPTABLE, THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS (NCRP) DEFINED THE SOURCES OF EXPOSURE IN EXPLICIT DETAIL IN A COMPREHENSIVE REPORT, COMPLETE WITH ABOUT 300 PERTINENT REFERENCES. THIS NUCLEAR SAFETY ARTICLE CONTAINS THE SUMMARY FROM THAT REPORT AND SOME EXCERPTS FROM APPENDIX B OF THE REPORT. THE REPORT IS ENTITLED 'NATURAL BACKGROUND RADIATION IN THE UNITED STATES' AND IS AVAILABLE AS NCRP REPORT 45 FROM NCRP PUBLICATIONS, P.O. BOX 30175, WASHINGTON D.C. 20014. AN ATTRACTIVE FEATURE IN THE PRESENTATION OF THE DATA IS THAT THEY ARE EXPRESSED IN TERMS OF THE CRITICAL ORGANS WHICH ARE EXPOSED. ALTHOUGH THE MAJOR CONTRIBUTION TO RADIATION DOSE TO HUMANS IS FROM NATURAL BACKGROUND, THE GREATEST PORTION OF MAN MADE RADIATION DOSE IS DUE TO EXPOSURES ACCRUED DURING MEDICAL DIAGNOSTIC PROCEDURES. THE ESTIMATED ANNUAL GENETICALLY SIGNIFICANT DOSE CONTRIBUTIONS FROM RADIOGRAPHIC EXAMINATIONS IN THE UNITED STATES IN 1970 IS APPROXIMATELY 20 MRADS (APPROXIMATELY EQUALS 20 MREMS) (SOURCE - GONAD DOSES AND GENETICALLY SIGNIFICANT DOSE FROM DIAGNOSTIC RADIOLOGY U.S., 1969 AND 1970, BUREAU OF RADIOLOGICAL HEALTH, EDUCATION AND WELFARE, APRIL 1976). ALSO, THE CONTRIBUTION FROM DEVELOPING NUCLEAR POWER INDUSTRY IS EXPECTED TO CONTRIBUTE A POPULATION DOSE OF LESS THAN 1 PERCENT OF NATURAL BACKGROUND.

17-4-6-475

PIPE CRACKING IN BOILING WATER REACTORS  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

(EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED FROM A NUCLEAR REGULATORY COMMISSION REPORT ENTITLED 'INVESTIGATION AND EVALUATION OF CRACKING IN AUSTENITIC STAINLESS STEEL PIPING OF BOILING WATER REACTOR PLANTS.' THIS REPORT WAS PREPARED BY THE PIPE CRACKING STUDY GROUP THAT WAS FORMED BY NRC TO INVESTIGATE THIS PROBLEM AFTER A SERIES OF SUCH CRACKS HAD OCCURRED. THE STUDY GROUP CONCLUDED THAT THE CRACKS WERE CAUSED BY INTERGRANULAR STRESS CORROSION AND MADE EXTENSIVE RECOMMENDATIONS FOR (1) THE EARLY IDENTIFICATION OF SUCH CRACKS IN OPERATING PLANTS AND (2) THE ULTIMATE REDUCTION OF THIS PHENOMENON. THE STUDY GROUP ALSO CONCLUDED THAT THE PROBABILITY WAS EXTREMELY LOW THAT THE PRESENCE OF SUCH CRACKS COULD LEAD TO A SIGNIFICANT SAFETY HAZARD TO THE PUBLIC. INCLUDED AT THE END OF THIS ARTICLE IS A BIBLIOGRAPHY PREPARED BY THE STUDY GROUP.)

17-5-1-525

COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS  
 RICHHOLZ, G. G.

GEORGIA INSTITUTE OF TECHNOLOGY, ATLANTA, GA.

A COST-BENEFIT ASSESSMENT IS AN ESSENTIAL PART OF THE ENVIRONMENTAL IMPACT STATEMENT SUBMITTED AS PART OF THE LICENSING CONSIDERATIONS FOR A NUCLEAR FACILITY. SUCH AN ASSESSMENT FORMS PART OF THE INITIAL DECISION TO BUILD A NUCLEAR FACILITY, ENTERS CRITICALLY INTO THE SELECTION OF A SUITABLE SITE, AND ULTIMATELY FORMS PART OF THE DESIGN PROCEDURES TO OPTIMIZE ENGINEERING SOLUTIONS TO DEAL WITH WASTE-HEAT DISSIPATION, TREATMENT METHODS FOR RADIOACTIVE EFFLUENT CONTROL, AND LAND AND SITE USE. WHEREAS THE INITIAL DECISION USUALLY CAN BE MADE IN PURELY ECONOMIC TERMS, THE LATTER STAGES INVOLVE ENVIRONMENTAL AND SOCIAL ISSUES THAT ARE NOT READILY QUANTIFIED AND INVOLVE A QUALITATIVE JUDGMENT OF WHAT CONSTITUTES THE LEAST, READILY ACHIEVABLE IMPACT. THE RADIOLOGICAL IMPACT OF THE PLANT ON THE SURROUNDING POPULATION FROM THE RELEASE OF LOW LEVEL EFFLUENTS CAN BE QUANTIFIED AND TREATED AS A FINANCIAL 'COST.' ALTERNATIVELY IT CAN BE TREATED AS A 'RISK' AND RELATED TO OTHER RISKS MODERN MAN IS SUBJECTED TO AND CAN BE USED AS A MEANS TO ESTABLISH SITE BOUNDARIES. BOTH COST-BENEFIT AND RISK-BENEFIT ANALYSES REPRESENT ESSENTIALLY OPTIMIZATION APPROACHES TO THE PROBLEM OF MAKING NUCLEAR POWER PLANTS ECONOMICALLY COMPETITIVE, SOCIALLY AND POLITICALLY ACCEPTABLE, AND AS SAFE OR INNOCUOUS AS ONE CAN REASONABLY MAKE THEM.

17-5-1-539

CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST  
 BRONFMAN, L. W. + MATTINGLY, T. J., JR.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

CRITICAL MASS '74 AND '75, NATIONAL CONFERENCES OF OPPONENTS OF NUCLEAR POWER CONVENED BY CONSUMER ACTIVIST RALPH NADER, WERE HELD IN WASHINGTON, D.C., IN MID-NOVEMBER 1974 AND 1975. SESSIONS OF THESE CONFERENCES WERE DEVOTED TO MAKING THE CASE AGAINST NUCLEAR POWER DEVELOPMENT IN THE UNITED STATES AND AROUND AS WELL AS TO DELINEATING STRATEGIES FOR CITIZEN ACTION AGAINST THE NUCLEAR ALTERNATIVE. THE CONFERENCES POINTED OUT THE BROADENING OF OPPONENTS' CONCERNS FROM MERELY TECHNICAL ISSUES TO A WIDE SPECTRUM OF SOCIAL, ECONOMIC, POLITICAL, AND MORAL ISSUES. THE AUTHORS, SOCIAL SCIENTISTS AT THE OAK RIDGE NATIONAL LABORATORY, DISCUSS THE IMPLICATIONS OF THIS BROADENING DEBATE FOR ENERGY POLICY.

17-5-2-550

THE ROLE OF CORE DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSING OF LMFBRs  
 FAUSKE, H. K.

ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.

THE ROLE OF CORE DISRUPTIVE ACCIDENTS (CDAs) IN DESIGN AND LICENSING OF LIQUID METAL COOLED FAST BREEDER REACTORS IS REVIEWED, INCLUDING A DESCRIPTION OF CDA INITIATORS, LIKELY ACCIDENT PATHS, CORE MELTDOWN ENERGETICS, AND RADIOLOGICAL CONSEQUENCES. IT IS CONCLUDED THAT (1) THE PROBABILITIES OF INITIATORS LEADING TO CORE MELTDOWN SHOULD AND CAN BE MADE SUFFICIENTLY LOW (OBJECTIVE, LESS THAN  $10(\text{EXP}-6)$  PER REACTOR YEAR) TO REDUCE THEM TO CLASS 9 ACCIDENTS, (2) BEST ESTIMATE ANALYSIS INCLUDING DESIGN CONSIDERATIONS SHOULD AND CAN DEMONSTRATE THE UNLIKELIHOOD (OBJECTIVE, LESS THAN  $10(\text{EXP}-2)$  OF A POSTULATED CORE MELTDOWN LEADING TO SUBSTANTIAL ENERGETICS THAT WOULD CHALLENGE THE ENERGY ABSORPTION CAPABILITY PROVIDED BY THE PRIMARY SYSTEM DESIGN, I.E., THE ABSENCE OF ENERGETIC HYDRODYNAMIC DISASSEMBLY AND/OR ENERGETIC FUEL COOLANT INTERACTIONS, (3) THE PRINCIPAL BASIS FOR THE PRIMARY SYSTEM DESIGN SHOULD BE SET BY FUNCTIONAL REQUIREMENTS WHERE ANY WEAK LINKS IN THE RESULTING DESIGN SHOULD BE UPGRADED TO GIVE AN OVERALL CONSISTENT SYSTEM WITH AN OPTIMUM ENERGY ABSORPTION CAPABILITY (ESSENTIALLY CURRENT PRACTICE) AND NOT BY ARBITRARY CDA ENERGETICS, AND (4) ON THE BASIS OF BEST ESTIMATE ANALYSIS INCLUDING DESIGN CONSIDERATIONS, THE OBJECTIVE SHOULD AND CAN BE TO DEMONSTRATE LONG-TERM CONTAINMENT CAPABILITY OF THE FUEL DEBRIS FOLLOWING A POSTULATED CORE MELTDOWN ACCIDENT. THIS BALANCED APPROACH IS BELIEVED NECESSARY, AT LEAST IN THE NEAR TERM, TO ADEQUATELY DEMONSTRATE THAT THE SAFETY OBJECTIVE THAT THE OCCURRENCE OF RADIOLOGICAL CONSEQUENCES OUTSIDE THE PLANT BOUNDARY IN EXCESS OF ACCEPTABLE LEVELS MUST BE LESS THAN  $10(\text{EXP}-6)$  PER REACTOR YEAR HAS INDEED BEEN ACHIEVED.

17-5-4-564

RELIABILITY OF PIPING IN LIGHT WATER REACTORS

BUSH, S. H.

BATTELLE PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.

THIS ARTICLE ASSESSES THE RELIABILITY OF PIPING IN LIGHT WATER REACTORS BASED ON NONNUCLEAR FAILURE DATA, CONDITIONAL FAILURE PROBABILITIES, THE ROLE OF PERIODIC INSPECTION, AND A REVIEW OF NUCLEAR SYSTEM FAILURES. FAILURE STATISTICS CONFIRM RATES OF  $10(\text{EXP}-4)$  TO  $10(\text{EXP}-6)$  PER REACTOR YEAR IN LARGE PIPES, WITH HIGHER RATES AS THE SIZE DECREASES. PERIODIC INSPECTION, A CRITICAL FACTOR, ENHANCES RELIABILITY BY FACTORS OF 10 TO 10,000. NUCLEAR FAILURES ARE CLASSIFIED INTO TWO STATISTICAL CATEGORIES (1) THOSE DUE TO INTERGRANULAR STRESS CORROSION CRACKING (IGSCC), AND (2) ALL OTHERS DUE TO CONSTRUCTION, DESIGN, OR OPERATIONAL ERRORS. THE SPECTRUM OF PIPE SIZES INFLUENCED BY IGSCC DIFFERS FROM THAT INFLUENCED BY OTHER MECHANISMS.

- 17-5-5-580 THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT  
VELURI, V. R. + BOONE, F. W. + PALMS, J. M.  
EMORY UNIVERSITY, ATLANTA, GA.  
THE ENVIRONMENTAL IMPACT OF THE PREDICTED CARBON-14 RELEASE BY THE BARNWELL NUCLEAR FUEL PLANT (BNFP) IS ASSESSED. THE EXTERNAL DOSE AND THE WHOLE-BODY DOSES DUE TO INHALATION AND INGESTION OF CARBON-14 ARE CALCULATED. FOR A PREDICTED RELEASE OF 1065 CI/YEAR, THE EXTERNAL DOSE RATE AT THE SITE BOUNDARY IS  $2.9 \times 10$  (EXP-4) MREM/YEAR, THE WHOLE-BODY INHALATION DOSE RATE IS  $7.0 \times 10$  (EXP-5) MREM/YEAR, AND THE WHOLE BODY DOSE RATE VIA INGESTION OF FOOD MATERIALS IS 0.28 MREM/YEAR. THESE RATES COMPARE WITH AN AVERAGE ANNUAL DOSE RATE PER PERSON OF 135 MREMS/YEAR DUE TO NATURAL BACKGROUND RADIATION. THE LONG TERM ASPECTS OF GLOBAL RELEASES OF CARBON-14 FROM THE NUCLEAR INDUSTRY ARE BRIEFLY DISCUSSED. THE 25-YEAR DOSE COMMITMENT TO A PERSON DUE TO CARBON-14 DISCHARGES FROM THE TOTAL WORLD NUCLEAR FACILITIES DURING THE PERIOD 1975 TO 2000 IS ESTIMATED TO BE APPROXIMATELY 1.4 MREMS. DURING THE SAME 25-YEAR PERIOD, THE BNFP CONTRIBUTION WILL BE APPROXIMATELY 0.02 MREM OF THE 1.4 MREMS. THE DOSE COMMITMENT TO A PERSON FOR THE ESTIMATED 40-YEAR LIFETIME OF BNFP WILL BE APPROXIMATELY 0.08 MREM.
- 17-5-6-592 BROWNS FERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975  
SCOTT, R. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE REVIEWS THE MAR. 22, 1975, FIRE AT THE BROWNS FERRY NUCLEAR POWER PLANT. THE FIRE ORIGINATED IN THE ELECTRICAL CABLE TRAYS AND BURNED FOR 7 HR BEFORE IT WAS EXTINGUISHED BY WATER. THE USE OF WATER WAS DELAYED UNTIL THE REACTORS WERE IN A STABLE SHUTDOWN CONDITION BECAUSE OF THE POSSIBILITY OF SHORTING CIRCUITS, WHICH MIGHT HAVE CAUSED FURTHER DEGRADATION OF CONDITIONS THAT WOULD HAVE BEEN MORE DIFFICULT TO CONTROL. HOWEVER, WHEN WATER WAS AUTHORIZED, THE FIRE WAS QUICKLY EXTINGUISHED. THE FIRE-FIGHTING EFFORTS AND THE DAMAGE CAUSED BY THE FIRE ARE DESCRIBED. THE LOSS OF ELECTRICAL POWER AND CONTROL CIRCUITS RESULTED IN THE UNAVAILABILITY OF EMERGENCY CORE COOLING SYSTEMS AND HAMPED EFFORTS TO PROVIDE NORMAL COOLING TO THE REACTOR FUEL. THE AVAILABILITY OF ALTERNATE COOLING METHODS IS REVIEWED, THE EFFORTS TO MAINTAIN COOLING OF THE REACTOR FUEL ARE DISCUSSED, AND THE BASIC REASONS FOR THE COMMON-MODE FAILURES ARE DESCRIBED. ASSESSMENTS OF THE FIRE WERE MADE BY THREE GROUPS IN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC), AS WELL AS BY AN INDEPENDENT INSURANCE GROUP. SOME OF THE DETAILS OF THESE ASSESSMENTS ARE PRESENTED, IN PARTICULAR, SOME DEFICIENCIES THAT THE NRC OFFICE OF INSPECTION AND ENFORCEMENT FOUND DURING ITS INVESTIGATION AND SOME OF THE LESSONS LEARNED FROM THE EVENTS AS DETERMINED BY THE NRC SPECIAL REVIEW GROUP.
- 17-5-6-622 OCCUPATIONAL RADIATION EXPOSURES AT LWRs, 1969-1974  
MURPHY, T. D. + HINSON, C. S.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THIS ARTICLE SUMMARIZES A REPORT BY THE NUCLEAR REGULATORY COMMISSION WHICH PRESENTS COMPILATIONS OF OCCUPATIONAL RADIATION EXPOSURES AT COMMERCIAL LIGHT WATER COOLED POWER REACTORS FROM 1969 TO 1974. THE EXPOSURE IN MAN REMS PER UNIT FOR ALL REACTORS IN 1974 WAS LESS THAN THE 1973 VALUE, BUT THE GRAND AVERAGE SINCE 1969 CONTINUED TO INCREASE. HOWEVER, NO SIGNIFICANT TREND WAS INDICATED, OVER THE PERIOD 1969-1974, IN THE MAN VALUE OF MAN REMS PER MEGAWATT YEAR.
- 17-6-1-659 ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES  
CHESTER, C. V.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE POTENTIAL FATALITIES, OR EXTENT OF POTENTIAL LETHAL CONSEQUENCES, FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES ARE ESTIMATED. THE MOST SEVERE THREAT IS FROM THEFT OF FISSIONABLE MATERIAL AND SUBSEQUENT FABRICATION OF A CLANDESTINE NUCLEAR EXPLOSIVE. A NUCLEAR EXPLOSIVE OF EFFICIENT DESIGN EXPLODED WITHOUT WARNING IN A CROWDED HIGH RISE COMMERCIAL DISTRICT COULD PRODUCE OVER A MILLION FATALITIES. THE UNCONTAINED MELTDOWN OF A POWER REACTOR AND, TO A LESSER EXTENT, THE DISPERSAL OF PLUTONIUM ARE MINOR THREATS TO HUMAN LIFE IF THERE IS ANY WARNING, BUT THEY ARE POTENTIALLY LARGE AND VERY COERCIVE THREATS TO PROPERTY. THE TOXICITY OF PLUTONIUM IS NO WORSE THAN THAT OF THE MUCH MORE EASILY AVAILABLE NERVE GAS AND REQUIRES WEEKS OR MONTHS TO KILL AS OPPOSED TO MINUTES FOR NERVE GAS. ATTACKS ON SPENT FUEL SHIPMENTS, HIGH LEVEL WASTE SHIPMENTS, REPROCESSING PLANTS, OR WASTE TANKS PRESENT MINIMAL THREATS TO HUMAN LIFE.
- 17-6-1-665 SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SABOTAGE  
SANDIA STAFF  
SANDIA LABORATORIES, ALBUQUERQUE, N.MEX., AND LIVERMORE, CALIF.  
A STUDY HAS BEEN MADE OF THE VULNERABILITY OF U.S. COMMERCIAL LIGHT WATER REACTOR POWER PLANTS TO SABOTAGE. THE SUSCEPTIBILITY OF NUCLEAR PLANTS TO SABOTAGE AND THE CONSEQUENCES OF A SUCCESSFUL ATTACK ARE COMPARED WITH RESPECT TO OTHER INDUSTRIAL AND CIVIL TARGETS. RECOMMENDATIONS ARE GIVEN TO FURTHER REDUCE THE VULNERABILITY OF NUCLEAR POWER PLANTS TO SOPHISTICATED SABOTAGE THREATS.

- 17-6-2-671 DATA SOURCES FOR LOCA CODE VERIFICATION  
 FABIC, S.  
 U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
 MATHEMATICAL MODELS IN THE CURRENT AND ADVANCED LOSS OF COOLANT ACCIDENT CODES UNDER DEVELOPMENT ARE CATEGORIZED, AND INDICATIONS ARE GIVEN OF THE DEPENDENT VARIABLES THAT COULD BE SOLVED FOR AND OF THE NUMBER AND TYPE OF CONSTITUTIVE EQUATIONS THAT NEED TO BE VERIFIED. TEST DATA SOURCES ARE CLASSIFIED ACCORDING TO THE COMPLEXITY AND DIVERSITY OF MEASUREMENTS. EXISTING DATA SOURCES, BOTH DOMESTIC AND FOREIGN, ARE LISTED FOR EACH CLASS OF TESTS. ADDITIONAL TEST DATA NEEDS ARE OUTLINED, FOLLOWED BY A DESCRIPTION OF THE EXISTING PLANS FOR CODE VALIDATION AND FOR UNCERTAINTY STUDIES ON CODE RESULTS. THE CONCLUSION IS REACHED THAT THERE IS AN EXTENSIVE DATA BASE AVAILABLE FOR CODE VERIFICATION, EXCEPT FOR THOSE BEST ESTIMATE CODES WHICH MODEL MULTIDIMENSIONAL EFFECTS AND THE LOCAL EFFECTS OF INTERPHASE MASS, MOMENTUM, AND ENERGY TRANSFER. THE NUCLEAR REGULATORY COMMISSION IS IN THE PROCESS OF CONTRACTING FOR THE ADDITIONAL RESEARCH REQUIRED TO SUPPLEMENT THE EXISTING DATA BASE.
- 17-6-3-696 COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REACTOR SAFETY  
 HAYDEN, K. C. + HAGEN, E. W.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 A BROAD CATEGORY OF FAILURE MECHANISMS THAT CAN CAUSE COMMON-MODE FAILURES IN NUCLEAR PLANT REDUNDANT SYSTEMS AND OTHER HIGH RELIABILITY SYSTEMS IS EXAMINED. THIS CLASS OF MECHANISMS INCLUDES CAUSES OF MULTIPLE FAILURES THAT HAVE NOT BEEN WIDELY RECOGNIZED AS COMMON-MODE FAILURES IN THE PAST. FAILURE MECHANISMS WERE DEDUCED FROM REACTOR OPERATING EXPERIENCES AND REPORTS. SEVERAL CATEGORIES OF MULTIPLE FAILURE MECHANISMS ARE PROPOSED AS A STARTING POINT FOR THE DEVELOPMENT OF DESIGN AND OPERATING GUIDELINES FOR REDUCING THE PROBABILITY OF COMMON-MODE FAILURES.
- 17-6-3-693 SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE  
 BELTRACCHI, L. + BULLOCK, J. B.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THE USE OF DIGITAL COMPUTERS IN REACTOR PROTECTION SYSTEMS PRESENTS NEW CONSIDERATIONS FOR THE DESIGNERS OF BOTH THE REACTOR AND THE SAFETY SYSTEM. THIS ARTICLE DISCUSSES EXPERIENCES IN THE SAFETY EVALUATION OF PROTECTION SYSTEM SOFTWARE IN TERMS OF DEVELOPED GUIDELINES, THE IMPORTANCE OF THE SOFTWARE DEVELOPMENT CYCLE, AND THE APPLICATION OF THE GUIDELINES. IMPORTANT GUIDELINES SUCH AS CRITICAL DESIGN FAULTS AND QUALITATIVE RELIABILITY ARE CURRENTLY BEING USED FOR EVALUATION PURPOSES, AND MINIMUM REQUIREMENTS FOR THE DESIGN QUALIFICATION AND ACCEPTANCE TESTING OF THE SOFTWARE HAVE BEEN IDENTIFIED. ALTHOUGH THE SAFETY REVIEW IS INCOMPLETE, MOST OF THE PROTECTION ALGORITHMS, TEST PLANS, AND SOME TEST RESULTS HAVE BEEN REVIEWED. OUR EXPERIENCES TO DATE MAY PROVE FRUITFUL FOR OTHERS CONTEMPLATING THE DEVELOPMENT AND REVIEW OF SOFTWARE IN SAFETY RELATED SYSTEMS. THE OPINIONS EXPRESSED HEREIN REFLECT THE CURRENT EXPERIENCE OF THE AUTHORS. FINAL REGULATORY GUIDANCE OF THE NUCLEAR REGULATORY COMMISSION HAS NOT BEEN DEVELOPED.
- 17-6-4-701 EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTIMUM TOWER DESIGN  
 KLEIN, S. M.  
 UNITED ENGINEERS + CONSTRUCTORS INC., PHILADELPHIA, PA.  
 THIS ARTICLE DISCUSSES THE VARIOUS REGULATORY REQUIREMENTS AND CRITERIA GOVERNING THE DESIGN OF EMERGENCY SHUTDOWN COOLING TOWERS FOR NUCLEAR POWER PLANTS. THE EFFECTS OF KEY TOWER PARAMETERS (E.G., WET BULB TEMPERATURE, FLOW RATES, AND HEAT LOAD) ON TOWER SIZE AND THEIR INTERACTIONS WITH SYSTEM AND SAFETY REQUIREMENTS ARE EXPLORED. THE EVOLUTION OF THE SEABROOK STATION TOWER AND ITS RELATIONSHIP TO A COMPANION COOLING WATER SOURCE (THE ATLANTIC OCEAN) ARE PRESENTED AS AN EXAMPLE OF OPTIMUM TOWER / SYSTEM DESIGN THAT COMPLIES WITH REGULATORY REQUIREMENTS.
- 17-6-4-710 THE ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SUPPRESSION  
 LIPARULO, W. J. + TINKLER, C. G. + GEORGE, J. A.  
 WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PA.  
 THIS ARTICLE DESCRIBES THE WESTINGHOUSE ICE CONDENSER SYSTEM FOR SUPPRESSING PRESSURE CAUSED BY THE RELEASE OF STEAM WITHIN THE CONTAINMENT SYSTEM OF A POWER REACTOR. THE BASIC CONCEPT, SYSTEM CHARACTERISTICS, CONTAINMENT LAYOUT, AND SIZE ARE PRESENTED, AND THE TEST PROGRAM FOR ICE CONDENSER HEAT TRANSFER AND A TYPICAL RESPONSE TO A LOSS OF COOLANT ACCIDENT ARE DESCRIBED.
- 17-6-5-722 RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - AN OVERVIEW  
 GOLDSMITH, W. A.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 RADIOACTIVE RESIDUES - CALLED TAILINGS - OF DISCONTINUED URANIUM MILLING OPERATIONS ARE PRESENT AT 23 LOCATIONS IN THE WESTERN UNITED STATES. THE SHORT LIVED PROGENY OF THE RADON-222 EMANATING FROM THE TAILINGS GIVES RISE TO MOST OF THE PUBLIC RADIATION EXPOSURE RESULTING FROM PRESENT MANAGEMENT OF THESE TAILINGS. SINCE PRECURSORS OF RADON-222 HAVE EXTREMELY LONG

HALF LIVES, LONG TERM MANAGEMENT POLICIES AND TECHNIQUES ARE REQUIRED IF FURTHER REDUCTION OF RADIATION EXPOSURE TO THE PUBLIC IS DESIRED.

- 17-6-6-733 IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPONENTS  
LAUTZENHEISER, C. E.  
SOUTHWEST RESEARCH INSTITUTE, SAN ANTONIA, TEXAS  
THE EARLY LIGHT WATER REACTOR SYSTEMS FOR PRODUCTION OF COMMERCIAL POWER WERE DESIGNED AND FABRICATED IN ACCORDANCE WITH THE CODES THEN BEING USED FOR FOSSIL FIRED POWER GENERATING STATIONS WITH SOME DESIGN CHANGES FOR INCREASED INSPECTABILITY DURING FABRICATION. OVER THE PAST FEW YEARS, MAJOR STRIDES HAVE BEEN MADE IN IN-SERVICE INSPECTION TECHNOLOGY. WORK HAS BEEN UNDER WAY TO DETERMINE THE RELIABILITY OF NONDESTRUCTIVE TESTING METHODS AND TO DEVELOP FORMAL INSPECTION PROGRAMS THROUGHOUT THE WORLD. THE MAJOR PROBLEMS ASSOCIATED WITH IN-SERVICE INSPECTION ARE THE SCARCITY OF QUALIFIED PERSONNEL, THE VARIABILITY IN PROCEDURES AND DATA RECORDING BETWEEN INSPECTION AGENCIES, AND EXPOSURE OF INSPECTION PERSONNEL TO RADIATION. FURTHER WORK WILL BE REQUIRED TO MORE COMPLETELY MECHANIZE PIPING INSPECTIONS TO REDUCE RADIATION EXPOSURE AND TO STANDARDIZE INSPECTION PROCEDURES, EQUIPMENT, AND CERTIFICATION OF PERSONNEL. WORLDWIDE ATTENTION TO THE REQUIREMENTS OF THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS' BOILER AND PRESSURE VESSEL CODE, THE SIZE AND INTEGRITY OF INSPECTION AGENCIES, AND EFFORTS SUCH AS THE DEVELOPMENT OF PERSONNEL QUALIFICATION AND CERTIFICATION GUIDES EMPHASIZE THE IMPORTANCE OF IN-SERVICE INSPECTION TO NUCLEAR SAFETY.
- 17-6-6-743 OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1974  
BROOKS, B. G.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
PERSONNEL OCCUPATIONAL RADIATION EXPOSURES FOR CALENDAR YEAR 1974 WERE OBTAINED FROM ANNUAL AND TERMINATION REPORTS SUBMITTED BY CERTAIN TYPES OF AEC LICENSEES, I. E., OPERATING NUCLEAR POWER FACILITIES, INDUSTRIAL RADIOGRAPHERS, FUEL PROCESSORS, FABRICATORS, AND REPROCESSORS, COMMERCIAL PROCESSORS, AND DISTRIBUTORS OF SPECIFIED QUANTITIES OF BY-PRODUCT MATERIALS. THESE DATA ARE PRESENTED IN A NUCLEAR REGULATORY COMMISSION REPORT, WHICH IS SUMMARIZED HERE. REPORTS FROM 421 LICENSEES INDICATED THAT 85,097 INDIVIDUALS WERE MONITORED FOR EXPOSURE TO RADIATION DURING 1974 AND THAT 17,627 INDIVIDUALS TERMINATED THEIR EMPLOYMENT OR WORK ASSIGNMENT WITH LICENSEES IN 1974. BOTH FIGURES SHOW AN INCREASE OF ABOUT 23 PERCENT OVER THOSE OF 1973. DESPITE THE INCREASE IN THE NUMBER OF INDIVIDUALS MONITORED DURING THE 7 YEARS, THE NUMBER OF THE MORE SIGNIFICANT EXPOSURES HAS REMAINED FAIRLY CONSTANT.
- 18-1-1-1 NRC WATER REACTOR SAFETY RESEARCH PROGRAM  
TONG, L. S. + BENNETT, G. L.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
THE WATER REACTOR SAFETY RESEARCH PROGRAM OF THE NUCLEAR REGULATORY COMMISSION IS DESCRIBED, AND THE BASIC RESULTS ARE PRESENTED. THE PROGRAM CONSISTS OF FIVE BASIC RESEARCH AREAS - INTEGRITY OF VESSEL AND PIPING, THERMAL HYDRAULIC TESTS, FUEL ROD BEHAVIOR, CODE DEVELOPMENT AND VERIFICATION, AND REACTOR OPERATIONAL SAFETY. RESULTS FROM THE VESSEL AND PIPING INTEGRITY RESEARCH HAVE DEMONSTRATED THE HIGH SAFETY MARGINS IN SCALED VESSELS AND THE ANALYTICAL PROCEDURES FOR CALCULATING VESSEL BEHAVIOR UNDER PRESSURE. NONDESTRUCTIVE EXAMINATION TECHNIQUES ARE BEING IMPROVED. WORK IS ALSO PROCEEDING TO DEFINE THE MATERIAL CONSTITUENTS WITH WHICH TO REDUCE THE SUSCEPTIBILITY OF COMPONENTS AND STRUCTURES TO IRRADIATION BRITTLENESS AND STRESS CORROSION CRACKING. THE THERMAL HYDRAULIC TESTS HAVE COVERED THE VARIOUS PHASES OF A HYPOTHETICAL LOSS OF COOLANT ACCIDENT AND ACTIVATION OF THE EMERGENCY CORE COOLING SYSTEM. THESE TESTS HAVE LED TO THE DEVELOPMENT OF MORE REALISTIC ENGINEERING CORRELATIONS TO DESCRIBE THE PHENOMENA IN ORDER TO FURTHER QUANTIFY THE SAFETY MARGINS IN COMMERCIAL NUCLEAR POWER PLANTS. THE FUEL BEHAVIOR RESEARCH HAS PROVIDED VALUABLE INFORMATION ON DECAY HEAT, CLADDING OXIDATION, FUEL ROD BEHAVIOR, AND FUEL MELTING. BOTH THE DECAY HEAT AND THE CLADDING OXIDATION HAVE BEEN SHOWN TO BE LOWER THAN ASSUMED IN THE LICENSING EVALUATIONS. THE REACTOR OPERATIONAL SAFETY RESEARCH IS JUST STARTING - INITIALLY IT ADDRESSES FIRE PROTECTION, COMPONENT AGING, AND HUMAN ENGINEERING. TO DATE, THE NRC WATER REACTOR SAFETY RESEARCH PROGRAM HAS GREATLY EXPANDED THE SAFETY DATA BASE, WHICH IN TURN IS USED FOR FURTHER QUANTIFICATION OF THE INHERENT SAFETY MARGINS IN NUCLEAR POWER PLANTS.
- 18-1-2-45 REFLECTIONS ON THE RECRITICALITY CONFERENCE AT ARGONNE NATIONAL LABORATORY  
GRIFFITH, J. D.  
U. S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D. C.  
THE CONSENSUS OF THE RECRITICALITY CONFERENCE AT ARGONNE NATIONAL LABORATORY WAS THAT THE ENERGETIC RECRITICALITY ACCIDENT IS A HIGHLY IMPROBABLE EVENT BUT THAT PROOF OF ITS IMPOSSIBILITY IS NOT YET FULLY CONVINCING TO THE INTERESTED SCIENTIFIC COMMUNITY. THE AUTHOR EXTENDS THE DISCUSSION AND

SUGGESTS THAT AN ENDLESS EFFORT TO ESTABLISH THE EXISTENCE OF VERY LOW PROBABILITY EVENTS OR TO PROVE THE IMPOSSIBILITY OF SOME POSTULATED EVENTS WOULD BE A FRUITLESS ENDEAVOR. IT IS CONCLUDED THAT THE EMPHASIS SHOULD BE SHIFTED FROM A SEARCH FOR GREATER ASSURANCE OF THE NONEXISTENCE OF LOW PROBABILITY EVENTS TO THE UNDERSTANDING OF REAL PHENOMENA AT THE VARIOUS NATURAL LINES OF ASSURANCE THAT EXIST FOR A LIQUID METAL COOLED FAST BREEDER REACTOR. THE AUTHOR PROPOSES THAT THIS BE DONE WITH AN APPROPRIATE RISK CURVE INCORPORATING THE LINES OF ASSURANCE AND A PROPOSED CRITERION. THE CRITERION PROPOSED IS THAT PHENOMENA THAT CAN BE MADE TO OCCUR EXPERIMENTALLY UNDER REALISTIC REACTOR CONDITIONS BE STUDIED AND UNDERSTOOD AND PHENOMENA THAT CANNOT BE MADE TO HAPPEN EXPERIMENTALLY BE ASSUMED TO HAVE A PROBABILITY OF OCCURRENCE LOWER BY A FACTOR OF  $10(\text{EXP}-2)$  TO  $10(\text{EXP}-3)$  AND THE CONSEQUENCES OF THESE LOWER-PROBABILITY EVENTS BE STUDIED AT THE NEXT LINE OF ASSURANCE.

18-1-3-53

LOSS OF ELECTRIC POWER COINCIDENT WITH LOCA  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE ANALYSIS CONDUCTED IN THE REACTOR SAFETY STUDY (WASH-1400) PRESENTS A METHOD FOR ESTABLISHING A RISK PROBABILITY FOR POSTULATED ACCIDENT CIRCUMSTANCES. SINCE THESE PROBABILITIES PROVIDE A MEANS FOR PLACING EVENTS INTO A RELATIVE PERSPECTIVE, THE EDITOR HAS PREPARED THAT PORTION OF THE STUDY CONCERNED WITH AND ENTITLED 'TOTAL LOSS OF ELECTRIC POWER' FOR REPUBLICATION HERE FOR A BROADER AUDIENCE. THE STUDY CONCLUDED THAT THE PROBABILITY OF THE TOTAL LOSS OF ELECTRIC POWER WAS  $10(\text{EXP}-5)$  AT THE TIME OF A LOSS OF COOLANT ACCIDENT (LOCA) AND RANGED FROM ABOUT  $10(\text{EXP}-4)$  TO  $10(\text{EXP}-8)$  FOR VARIOUS TIMES AND CONFIDENCE LEVELS FOLLOWING A LOCA. THE 'EDITOR'S POSTSCRIPT' TO THIS EDITED VERSION OF THE RISK ASSESSMENT ANALYSIS IS A STATEMENT OF THE PRIMARY PURPOSE AND FUNCTION OF THE TWO ELECTRIC POWER SYSTEMS ASSOCIATED WITH NUCLEAR POWER PLANTS. SOME ACTUAL PLANT OPERATING DATA AND BLACKOUT EXPERIENCES ARE PRESENTED FOR RELEVANCE AND TO SUPPLEMENT THE LIMITED DATA BASE CHOSEN FOR THE STUDY. THE REFERENCE LIST GIVEN IN THE REPORT IS ALSO INCLUDED AND IS SUPPLEMENTED BY REFERENCES THAT ARE CITED IN THE POSTSCRIPT. A SHORT BIBLIOGRAPHY IS APPENDED.

18-1-4-60

PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS  
DISALVO, R.

U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.

RENEWED INTEREST HAS RECENTLY DEVELOPED IN ANALYZING THE COURSE AND CONSEQUENCES OF HIGHLY IMPROBABLE, HYPOTHETICAL ACCIDENTS THAT INVOLVE MELTING OF A SIGNIFICANT PORTION OF THE FUEL IN LIGHT WATER REACTORS. PHYSICAL PHENOMENA ASSOCIATED WITH SUCH ACCIDENTS AND CURRENT TRENDS IN SAFETY RESEARCH APPLICABLE TO THEIR ANALYSIS ARE REVIEWED. THE OBJECTIVES, TECHNICAL APPROACHES, AND RECENT FINDINGS OF SELECTED PROGRAMS IN THE UNITED STATES AND THE FEDERAL REPUBLIC OF GERMANY ARE SUMMARIZED.

18-1-6-79

RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974  
NUCLEAR SAFETY STAFF

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

MEASURED RELEASES OF RADIOACTIVE MATERIALS IN AIRBORNE AND LIQUID EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS DURING 1974 ARE SUMMARIZED AND COMPARED TO FORMER YEARS. THIS REPORT SUPPLEMENTS THE EARLIER ANNUAL REPORTS ISSUED BY THE ATOMIC ENERGY COMMISSION AND THE NUCLEAR REGULATORY COMMISSION. ALTHOUGH THE 1974 RELEASES WERE IN ALL CASES BELOW THE LIMITS SET FORTH IN APPLICABLE REGULATIONS, THE AIRBORNE EFFLUENTS INCREASED ABOUT 2 PERCENT AND THE LIQUID EFFLUENTS DECREASED ABOUT 6 PERCENT IN 1974 AS COMPARED TO 1973.

18-2-1-127

LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT SITING  
BORKO, B. + JUST, J. E.

MITRE CORPORATION, WCLEAN, VA.

UNCERTAIN LONG RANGE DEMAND, RISING POWER PLANT CAPITAL AND OPERATING COSTS, INCREASING CONSTRUCTION TIME, AND THE IMPOSITION OF MORE STRINGENT REGULATORY REQUIREMENTS FOR NEW POWER PLANTS HAVE RESULTED IN AN INCREASINGLY COMPLEX PROCESS FOR SITING NEW ELECTRIC GENERATING CAPACITY. MAJOR LEGAL AND INSTITUTIONAL IMPEDIMENTS TO A MORE EXPEDITIOUS SITING PROCESS INCLUDE THE NEED FOR ENUNCIATED NATIONAL STRATEGIES ON SUCH ISSUES AS SAFETY STANDARDS, THE NUCLEAR FUEL CYCLE, AND COMMITMENT TO CONSERVATION, THE LACK OF A DEFINITIVE MECHANISM ASSIGNING SPECIFIC RESPONSIBILITY FOR SITE SELECTION, AND THE FACT THAT PUBLIC ACCESS TO SITING DECISIONS IS FIRST PROVIDED AT A LATE STAGE IN THE DECISION PROCESS.

18-2-1-133

FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING  
COTTRELL, W. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE IS A REVIEW OF THE FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION'S (NRC'S) DIVISION OF REACTOR SAFETY RESEARCH, HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., SEPT. 27-30, 1976. THIS MEETING CONSISTED OF PARALLEL TECHNICAL PRESENTATIONS IN THE MORNING, FOLLOWED BY

SEVERAL SMALLER WORKSHOPS OR DISCUSSION SESSIONS IN THE AFTERNOON. THE TECHNICAL SESSIONS WERE (1) LOSS OF COOLANT ACCIDENT STUDIES, (2) ANALYSIS DEVELOPMENT PROGRAM, (3) METALLURGY AND MATERIALS RESEARCH PROGRAM, AND (4) FUEL BEHAVIOR RESEARCH PROGRAM. SUMMARIES OF THE WORK IN EACH OF THESE FOUR MAJOR AREAS ARE PRESENTED HERE. OVER 635 PERSONS, INCLUDING SOME 146 FOREIGN VISITORS FROM 14 COUNTRIES, ATTENDED THE MEETING. IN ADDITION TO THE REVIEW OF NRC-SPONSORED WATER REACTOR SAFETY RESEARCH PROGRAMS, THE MEETING INCLUDED PRESENTATIONS ON SEVERAL FOREIGN REACTOR SAFETY PROGRAMS AS WELL AS ONE AFTERNOON SESSION DEVOTED TO RESEARCH SPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE. THE MEETING WAS NOTABLE FOR THE WEALTH OF TECHNICAL DATA AND EXPERIMENTAL RESULTS THAT WERE REPORTED. MANY TOPICS WERE DISCUSSED, AND MUCH WAS LEARNED. IT IS REASSURING THAT THESE RESEARCH RESULTS CONTINUE TO SUBSTANTIATE OUR UNDERSTANDING OF REACTOR SAFETY.

- 18-2-2-154 **BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYSTEMS**  
BERGLES, A. E.  
IOWA STATE UNIVERSITY, AMES, IOWA  
RECENT EXPERIMENTAL AND ANALYTICAL DEVELOPMENTS REGARDING BURNOUT IN SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYSTEMS ARE REVIEWED. MANY DATA HAVE BEEN ACCUMULATED WHICH CLARIFY THE PARAMETRIC TRENDS AND LEAD TO NEW DESIGN CORRELATIONS FOR WATER AND A VARIETY OF OTHER COOLANTS IN BOTH SIMPLE AND COMPLEX GEOMETRIES. A NUMBER OF CRITICAL EXPERIMENTS AND MODELS HAVE BEEN DEVELOPED TO ATTEMPT TO CLARIFY THE BURNOUT MECHANISM(S) IN SIMPLER GEOMETRIES. OTHER TOPICS DISCUSSED INCLUDE BURNOUT WITH POWER TRANSIENTS AND TECHNIQUES TO AUGMENT BURNOUT.
- 18-2-3-168 **ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC POWER**  
AITKEN, A.  
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, GREAT BRITAIN  
THIS ARTICLE OUTLINES THE PROBLEM AND THE PROBLEM AREAS AS OBSERVED IN A RECENT ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR THE PROTOTYPE FAST REACTOR, A LIQUID METAL COOLED FAST BREEDER REACTOR AT DOUNREAY. TARGETS FOR RELIABILITY IN INDIVIDUAL MEASUREMENTS, SAFETY CIRCUITS, AND SHUTDOWN DEVICES ARE DETERMINED BY RELIABILITY APPORTIONMENT WITHIN THE DIVERSE SYSTEM THAT WAS DESIGNED TO MEET WELL-RECOGNIZED BASIC PRECEPTS. SOME COMMENTS ARE MADE ON OPERATING EXPERIENCE IN RELATION TO THE HIGH REQUIREMENTS.
- 18-2-4-174 **THE FOURTEENTH ERDA AIR CLEANING CONFERENCE**  
WELLES, D. W. + UNDERHILL, D. W. + FIRST, M. W.  
HARVARD UNIVERSITY, BOSTON, MASS.  
THE FOURTEENTH ERDA AIR-CLEANING CONFERENCE WAS HELD AUG. 2-4, 1976, IN SUN VALLEY, IDAHO. THE 324 ATTENDEES INCLUDED REPRESENTATIVES FROM 13 FOREIGN COUNTRIES AND AIR CLEANING SPECIALISTS FROM ESSENTIALLY ALL SECTORS OF INDUSTRY, FROM GOVERNMENTAL AGENCIES, AND FROM EDUCATIONAL INSTITUTIONS. MAJOR TOPICS WERE RADIOIODINE SAMPLING, REMOVAL, AND RETENTION, THE CONCENTRATION AND STORAGE OF NOBLE GASES, TRITIUM, AND CARBON-14, PARTICULATE COLLECTORS, SYSTEMS PROTECTION FROM FIRES, EXPLOSIONS, AND NATURAL DISASTERS, SAMPLING AND MONITORING, AIR CLEANING AND VENTILATION SYSTEM DESIGN, AIR CLEANING PROBLEMS ASSOCIATED WITH THE TREATMENT OF RADIOACTIVE WASTES, AIR CLEANING SYSTEMS FOR THE LIQUID METAL COOLED FAST BREEDER REACTOR, AND THE REGULATORY ASPECTS OF THE AIR CLEANING FIELD. AN INTERESTING ASPECT OF THE CONFERENCE WAS THE DEGREE TO WHICH PROBLEMS ASSOCIATED WITH RADIOIODINE STILL MAINTAIN A PROMINENT PLACE IN AIR CLEANING RESEARCH AND DEVELOPMENT. NEWER CHALLENGES BECAME EVIDENT FROM THE BROWNS FERRY FIRE, WHICH REVEALED WEAKNESSES IN AIR CLEANING AND VENTILATION SYSTEMS IN NUCLEAR POWER PLANTS, AND FROM THE REACTOR SAFETY STUDY, WHICH SHOWED A NEED TO DEVELOP ADDITIONAL DATA ON THE RELIABILITY OF SUCH SYSTEMS, PARTICULARLY UNDER EMERGENCY CONDITIONS. ASSESSMENTS OF THE DEGREE TO WHICH ENGINEERED SAFETY FEATURES CAN BE USED TO COMPENSATE FOR SPECIFIC DEFICIENCIES IN NUCLEAR FACILITY SITES ALSO CONTINUE TO CHALLENGE THOSE INVOLVED IN RISK-BENEFIT EVALUATIONS.
- 18-2-4-189 **TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENT STRUCTURES AND SYSTEMS**  
MEHTA, D. S. + OSGOOD, H. W. + BINGAMAN, A. J.  
BUCHERT, K. P.  
BECHTEL POWER CORPORATION, GATHERSBURG, MD.  
THIS ARTICLE TRACES THE EVOLUTION OF PRESSURIZED WATER REACTOR (PWR) CONTAINMENT DESIGN REQUIREMENTS AND CONCEPTS SINCE THE MID-1960S, DISCUSSES THE STRUCTURES AND SYSTEMS CURRENTLY BEING USED FOR NEW PLANTS, AND PRESENTS TABULATED DATA CONCERNING SIZE AND TYPE OF CONTAINMENT STRUCTURE, INTERNAL DESIGN PRESSURE, AND SAFE SHUTDOWN GROUND ACCELERATION VALUES FOR 127 NUCLEAR POWER PLANTS. IN ADDITION, VARIOUS CONTAINMENT SYSTEMS, SUCH AS FISSION-PRODUCT REMOVAL, HEAT REMOVAL, COMBUSTIBLE GAS CONTROL, AND PURGE, ARE BRIEFLY REVIEWED.
- 18-2-5-203 **RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION POWER**  
EASTERLY, C. E. + SHANK, K. E. + SHOUP, B. L.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
FUSION REACTOR TECHNOLOGY IS PRESENTLY IN CONCEPTUAL AND EARLY DEVELOPMENTAL STAGES. CONCOMITANT WITH HARDWARE DEVELOPMENT, POTENTIAL HEALTH AND ENVIRONMENTAL IMPACTS MUST BE EVALUATED TO

ENSURE THAT TECHNOLOGISTS HAVE PERTINENT INFORMATION AVAILABLE SO THAT ADEQUATE CONSIDERATION MAY BE GIVEN TO HEALTH AND ENVIRONMENTAL PROBLEMS. THIS ARTICLE DISCUSSES PROBLEM AREAS ATTENDANT TO TRITIUM, ACTIVATION PRODUCTS, AND MAGNETIC FIELDS ASSOCIATED WITH FUSION REACTOR SYSTEMS.

- 18-2-5-215 **RADIOLOGICAL QUALITY OF THE ENVIRONMENT**  
**NUCLEAR SAFETY STAFF**  
**OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.**  
 THIS REPORT IS PART OF THE U.S. ENVIRONMENTAL PROTECTION AGENCY'S DOSE ASSESSMENT PROGRAM FOR EVALUATING THE RADIOLOGICAL QUALITY OF THE ENVIRONMENT. ITS PUBLICATION HERE DOES NOT CONSTITUTE ENDORSEMENT OF THE ORIGINAL REPORT BY THE NUCLEAR REGULATORY COMMISSION. RATHER, THE EDITORS OF NUCLEAR SAFETY BELIEVE THE AUTHORS HAVE BROUGHT TOGETHER A WEALTH OF DATA AND EXTENSIVE REFERENCES TO THE CURRENT LITERATURE, BOTH OF WHICH SHOULD BE USEFUL TO THE GENERALIST AND SPECIALIST ALIKE. THE REPORT RECOGNIZES THE NEED FOR ADDITIONAL INFORMATION, AND THE INTERESTED READER IS URGED TO CONSULT THE ORIGINAL REPORT FOR ADDITIONAL DETAILS, QUALIFICATIONS, AND SOURCES PERTINENT TO ALL OF THE DATA. AS A PROTOTYPE EFFORT, THIS REPORT IS INTENDED ONLY TO SUMMARIZE INFORMATION AVAILABLE IN THE OPEN LITERATURE. SPECIAL EMPHASIS WAS PLACED ON ACQUIRING RECENT DOSE DATA. FOR SOME SOURCE CATEGORIES, DOSE INFORMATION WAS AVAILABLE FOR CALENDAR YEAR 1975, WHEREAS FOR OTHER CATEGORIES THE MOST RECENT DATA GO BACK TO THE EARLY 1970S. IT IS NOT INTENDED IN THIS INITIAL EFFORT TO CALCULATE OR EXTRAPOLATE FROM EXISTING DATA TO SUPPLY MISSING DOSE INFORMATION. INSTEAD, THE CONCERN IS TO REVIEW THE AVAILABLE DATA AND TO DETERMINE WHAT THE EXISTING DATA PROVIDE FOR INDIVIDUAL AND POPULATION DOSE INFORMATION. SINGLE COPIES OF THE REPORT MAY BE OBTAINED FROM THE OFFICE OF RADIATION PROGRAMS, U.S. ENVIRONMENTAL PROTECTION AGENCY, WASHINGTON, D.C. 20460. IT WAS CONCLUDED, ON THE BASIS OF THE POPULATION DOSE DATA ACQUIRED IN THIS REPORT, THAT THE THREE MAJOR SOURCE CATEGORIES OF RADIATION DOSE IN THE U.S. POPULATION ARE (1) AMBIENT IONIZING RADIATION, (2) THE APPLICATION OF RADIOPHARMACEUTICALS IN MEDICINE, AND (3) TECHNOLOGICALLY ENHANCED NATURAL RADIATION.
- 18-2-6-223 **HUMAN ENGINEERING - AIDS TO SMOOTH OPERATION**  
**KANZ, G. W.**  
**U. S. NUCLEAR REGULATORY COMMISSION, BETHESDA, MD.**  
 NUCLEAR PLANT CONTROL CONSOLES ARE HUGE, COMPLEX, AND SOMETIMES CONFUSING. SURPRISINGLY, LITTLE ATTENTION TO DATE HAS BEEN PAID TO THE HUMAN ENGINEERING PRACTICES THAT MAXIMIZE RELIABLE HUMAN PERFORMANCE. MAJOR MODIFICATIONS ARE PROHIBITIVE BY COSTS AND PLANT AVAILABILITY, BUT THERE IS MUCH THE OPERATOR CAN DO TO BACKFIT OPERATOR AIDS. THIS ARTICLE PRESENTS NUMEROUS PRACTICAL APPLICATIONS OF INNOVATIVE IDEAS TO AID THE OPERATOR, INCLUDING SOME THAT ARE ALREADY IN USE AT VARIOUS NUCLEAR PLANTS. THESE INNOVATIONS ARE INTENDED TO ASSIST IN LOCATING CONSOLE COMPONENTS, TO SUPPLY ADDITIONAL OPERATING INFORMATION, TO IMPROVE THE USE OF PROCEDURES, AND TO PROVIDE VITAL CONTROLS. IF PROPERLY APPLIED, THESE AIDS SHOULD IMPROVE THE SAFETY AND EFFICIENCY OF THE NUCLEAR POWER PLANT.
- 18-3-1-281 **THE REACTOR LICENSING PROCESS - A STATUS REPORT**  
**LONG, J. A.**  
**U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.**  
 THE NUCLEAR REGULATORY COMMISSION (NRC), IN ITS REVIEW OF APPLICATIONS FOR LICENSES TO CONSTRUCT AND OPERATE NUCLEAR POWER PLANTS, IS REQUIRED TO CONSIDER THOSE MEASURES NECESSARY TO ENSURE THE PROTECTION OF THE HEALTH AND SAFETY OF THE PUBLIC AND THE ENVIRONMENT. THIS ARTICLE DISCUSSES THE NRC STAFF PROCEDURES AND POLICIES FOR CONDUCTING THE DETAILED SAFETY, ENVIRONMENTAL, AND ANTITRUST REVIEWS THAT PROVIDE THE BASIS FOR THESE ASSURANCES. INCLUDED IS A DISCUSSION OF THE IMPROVEMENTS TO THE LICENSING PROCESS CURRENTLY BEING PROPOSED OR IMPLEMENTED TO ENHANCE ITS STABILITY AND PREDICTABILITY FOR THE BENEFIT OF ALL INVOLVED WITH THE REGULATION OF NUCLEAR POWER. THE VIEWS AND OPINIONS EXPRESSED IN THIS ARTICLE ARE THOSE OF THE AUTHOR ALONE AND DO NOT REPRESENT POSITIONS OF THE NRC.
- 18-3-1-291 **TRANSPORT OF RADIOACTIVE MATERIALS IN THE UNITED STATES**  
**NUCLEAR SAFETY STAFF**  
**OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.**  
 IN 1975 THE NUCLEAR REGULATORY COMMISSION SPONSORED A SURVEY OF SHIPMENTS OF RADIOACTIVE MATERIALS IN THE UNITED STATES. THE SURVEY WAS CONDUCTED BY BATTTELLE PACIFIC NORTHWEST LABORATORIES. OF OVER 15,000 LICENSEES, 2275 WERE SENT QUESTIONNAIRES, AND 59 PERCENT OF THE RECIPIENTS RESPONDED. ON THE BASIS OF THE RESPONSES, IT IS ESTIMATED THAT THE TOTAL NUMBER OF PACKAGES TRANSPORTED IN THE UNITED STATES IS ON THE ORDER OF 2.5 MILLION PACKAGES PER YEAR. ABOUT ONE-THIRD OF THE PACKAGES CONTAIN ONLY SMALL QUANTITIES OF RADIOACTIVE MATERIALS AND ARE EXEMPT FROM PACKAGING AND LABELING REQUIREMENTS OF DEPARTMENT OF TRANSPORTATION REGULATIONS. ON THE BASIS OF THE NUMBER OF PACKAGES SHIPPED ANNUALLY, THE MAJOR RADIONUCLIDES ARE IODINE-131, IODINE-125, TECHNETIUM-99M, MOLYBDENUM-99, AND URANIUM-238, WHEREAS THOSE SHIPPED IN THE GREATEST QUANTITIES (GRAMS OR CURIES) ARE COBALT-60, IRIIDIUM-192, AND URANIUM-238.



THE MAJORITY OF PACKAGE TYPES SHIPPED ARE EXEMPT TYPES A AND LS (LOW SPECIFIC ACTIVITY), AND THE MOST COMMON MODES OF TRANSPORT WERE TRUCK, AIR, AND RAIL.

- 18-3-2-298 CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT  
GRIFFITH, P. \* PEARSON, J. F. \* LEPKOWSKI, R. J.  
MASSACHUSETTS INSTITUTE OF TECHNOLOGY, CAMBRIDGE, MASS.  
A METHOD OF CALCULATING THE MINIMUM TIME TO CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT IS DEVELOPED. THE TIMES CALCULATED IN THIS WAY ARE SHOWN TO BE CONSERVATIVE BUT ARE CLOSE TO THE EXPERIMENTAL VALUES FOR WATER AND QUITE CONSERVATIVE FOR FREON 113. THE MODEL INVOLVES CALCULATING THE TIME REQUIRED TO DRY OUT A CHANNEL IN WHICH THE FLOW IS STAGNATED IN THE MIDDLE IN THE HOT REGION.
- 18-3-2-306 RESULTS OF THE FIRST THREE NONNUCLEAR TESTS IN THE LOFT FACILITY  
MCPHERSON, G. D.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE LOFT FACILITY IS A WELL INSTRUMENTED, SCALED MODEL OF A COMMERCIAL PRESSURIZED-WATER REACTOR. THE FACILITY IS DESIGNED TO STUDY THE BEHAVIOR OF SUCH ENGINEERED SAFETY SYSTEMS AS EMERGENCY CORE-COOLING SYSTEMS DURING REACTOR ACCIDENT CONDITIONS. THIS ARTICLE DESCRIBES THE LOFT FACILITY, THE CURRENT NONNUCLEAR EXPERIMENT SERIES, AND THE FORTHCOMING NUCLEAR EXPERIMENTS. SIGNIFICANT NONNUCLEAR EXPERIMENTAL RESULTS ALSO ARE REPORTED.
- 18-3-3-317 QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER APPLICATIONS  
RHODES, E. W.  
ITE IMPERIAL CORPORATION, MONTGOMERYVILLE, PA.  
THIS ARTICLE DISCUSSES SOME OF THE PROBLEMS ENCOUNTERED AND A MEANS FOR MEETING THE REQUIREMENTS OF IEEE STANDARD 323-1974 IN DEMONSTRATING QUALIFICATION OF SWITCHGEAR FOR SAFETY RELATED APPLICATIONS IN NUCLEAR POWER GENERATING STATIONS. THE SWITCHGEAR ASSEMBLIES ARE SUBJECTED TO A NUMBER OF TESTS (E.G., SERVICE CONDITIONS, SEISMIC CONDITIONS, LIFE, AND AGING), WHICH ARE REPORTED AND EVALUATED IN A QUALIFICATION SUMMARY REPORT. THE ARTICLE CONTAINS RECOMMENDATIONS FOR MAINTENANCE, INSPECTION, AND TESTING.
- 18-3-3-322 EMP AND NUCLEAR PLANT SAFETY  
BARNES, P. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE ELECTROMAGNETIC PULSE (EMP) FROM A HIGH ALTITUDE NUCLEAR DETONATION CONSISTS OF A TRANSIENT PULSE OF HIGH INTENSITY ELECTROMAGNETIC FIELDS THAT INDUCE CURRENT AND VOLTAGE TRANSIENTS IN ELECTRICAL CONDUCTORS. ALTHOUGH MOST NUCLEAR POWER PLANT CABLES ARE NOT DIRECTLY EXPOSED TO THESE FIELDS, THE ATTENUATED EMP FIELDS THAT PROPAGATE INTO THE PLANT WILL COUPLE SOME EMP ENERGY TO THESE CABLES. THIS ARTICLE ATTEMPTS TO PREDICT THE PROBABLE EFFECTS OF THE EMP TRANSIENTS THAT COULD BE INDUCED IN CRITICAL CIRCUITS OF SAFETY RELATED SYSTEMS. IT IS CONCLUDED THAT THE MOST LIKELY CONSEQUENCE OF EMP FOR NUCLEAR PLANTS IS AN UNSCHEDULED SHUTDOWN. IN GENERAL, EMP COULD BE A NUISANCE TO NUCLEAR POWER PLANTS, BUT IT IS NOT CONSIDERED A SERIOUS THREAT TO PLANT SAFETY.
- 18-3-5-329 COLD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR POWER PLANT SITING, DESIGN, AND OPERATION  
COUTANT, C. C.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
PROBLEMS OF COLD SHOCK DAMAGES TO AQUATIC ORGANISMS HAVE ARISEN AT SOME CONDENSED COOLING WATER DISCHARGES OF THERMAL POWER STATIONS WHEN THE WARM WATER RELEASES HAVE SUDDENLY TERMINATED. THE BASIS FOR SUCH DAMAGE LIES IN THE EXPOSURE OF RESIDENT ORGANISMS TO A RAPID DECREASE IN TEMPERATURE AND A SUSTAINED EXPOSURE TO LOW TEMPERATURE THAT INDUCES ABNORMAL BEHAVIORAL OR PHYSIOLOGICAL PERFORMANCE AND OFTEN LEADS TO DEATH. ALTHOUGH SOME SPECTACULAR FISH KILLS FROM COLD SHOCK HAVE OCCURRED, THE PRESENT KNOWLEDGE OF THE HYDRAULIC AND BIOLOGICAL PROCESSES INVOLVED CAN PROVIDE GUIDANCE FOR THE SITING, DESIGN, AND OPERATION OF POWER PLANT COOLING SYSTEMS TO MINIMIZE THE LIKELIHOOD OF SIGNIFICANT COLD SHOCK EFFECTS. PREVENTING COLD-SHOCK DAMAGES IS ONE CONSIDERATION IN MINIMIZING OVERALL ENVIRONMENTAL IMPACTS OF POWER PLANT COOLING AND IN BALANCING PLANT COSTS WITH ENVIRONMENTAL BENEFITS.
- 18-3-5-343 COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASED TO THE ENVIRONMENT  
HOFFMAN, F. G. \* MILLER, C. W. \* SHAEFFER, D. L.  
GARDNER, C. T., JR.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE PRESENTS A COMPILATION OF COMPUTER CODES THAT MAY BE USED FOR THE ASSESSMENT OF ACCIDENTAL OR ROUTINE RELEASES OF RADIOACTIVITY TO THE ENVIRONMENT FROM NUCLEAR POWER FACILITIES. THE CAPABILITIES OF 83 COMPUTER CODES IN THE AREAS OF ENVIRONMENTAL TRANSPORT AND RADIATION DOSIMETRY ARE SUMMARIZED IN TABULAR FORM. THIS PRELIMINARY ANALYSIS CLEARLY INDICATES THAT THE INITIAL EFFORTS IN ASSESSMENT METHODOLOGY DEVELOPMENT HAVE CONCENTRATED ON ATMOSPHERIC DISPERSION, EXTERNAL DOSIMETRY, AND INTERNAL DOSIMETRY VIA INHALATION. THE INCORPORATION OF TERRESTRIAL AND AQUATIC FOOD-CHAIN PATHWAYS HAS BEEN A MORE RECENT DEVELOPMENT AND REFLECTS THE NEED FOR SATISFYING THE CURRENT REQUIREMENTS OF ENVIRONMENTAL

LEGISLATION AND THE NEEDS OF REGULATORY AGENCIES. THE CHARACTERISTICS OF THE CONCEPTUAL MODELS EMPLOYED BY THESE CODES ARE REVIEWED.

- 18-3-6-355 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN 1975  
HARR, M. G.  
ATOMIC ENERGY OF CANADA LIMITED, ONTARIO, CANADA  
STEAM GENERATOR TUBE FAILURES WERE REPORTED IN 22 OUT OF 62 WATER COOLED NUCLEAR POWER PLANTS SURVEYED IN 1975. THIS WAS LESS THAN THE NUMBER OF PLANTS WITH REPORTED TUBE FAILURES IN 1974, AND THE NUMBER OF TUBES AFFECTED WAS NOTICEABLY LESS. THIS ARTICLE SUMMARIZES THESE FAILURES, MOST OF WHICH WERE DUE TO CORROSION. SECONDARY WATER CHEMISTRY CONTROL, PROCEDURES FOR INSPECTION AND REPAIR, TUBE MATERIALS, AND FAILURE RATES ARE DISCUSSED.
- 18-3-6-365 OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975  
MURPHY, T. D. + DAYEN, M. J. + BLAND, J. S.  
PASCIAK, W. J.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THIS ARTICLE IS A COMPILATION OF OCCUPATIONAL RADIATION EXPOSURES AT COMMERCIAL LIGHT WATER COOLED REACTORS (LWRS) FROM 1969 TO 1975 AND UPDATES PREVIOUS INFORMATION THAT COVERED EXPOSURES THROUGH 1974. THE INFORMATION WAS DERIVED FROM REPORTS SUBMITTED TO THE NUCLEAR REGULATORY COMMISSION IN ACCORDANCE WITH REQUIREMENTS OF INDIVIDUAL PLANT TECHNICAL SPECIFICATIONS AND THE CODE OF FEDERAL REGULATIONS. THE COLLECTIVE DOSE TO PERSONNEL (MAN-REMS PER REACTOR PER YEAR) AT LWRS WAS GREATER IN 1975 THAN IN 1974. ALTHOUGH THE AVERAGE EXPOSURE PER INDIVIDUAL REMAINED AT 0.8 REM/YEAR, THE AVERAGE NUMBER OF PERSONNEL RECEIVING MEASURABLE EXPOSURES PER REACTOR INCREASED IN 1975.
- 18-3-6-370 RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
(EDITOR'S NOTE - THE PRODUCTION OF ELECTRICITY BY THE USE OF NUCLEAR POWER IS A WORLDWIDE PHENOMENON, AS IS THE CONCOMITANT CONCERN REGARDING RADIOACTIVE EFFLUENTS.) THIS ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM A RECENT REPORT BY THE COMMISSION OF EUROPEAN COMMUNITIES THAT SUMMARIZES THE DISCHARGE DATA FOR SOME 34 POWER REACTORS (LESS THAN 50 MW(E)) OPERATING WITHIN THE EUROPEAN COMMUNITY. ON THE BASIS OF THESE DISCHARGES, MAXIMUM EXPOSURE IN THE VICINITY OF POWER STATIONS IS ASSESSED AND COMPARED WITH THE DOSE LIMITS FIXED BY RADIOLOGICAL PROTECTION STANDARDS AND WITH THE NATURAL RADIATION LEVEL. ALSO, THE RADIOACTIVE WASTE DISCHARGE PER UNIT ELECTRICAL ENERGY PRODUCED IS GIVEN FOR EACH POWER STATION. IN GENERAL, THE EUROPEAN EXPERIENCE IS SIMILAR TO THAT OF THE UNITED STATES, WHERE, IN ACCORDANCE WITH NRC 'AS LOW AS REASONABLY ACHIEVABLE' REGULATIONS, INDUSTRIAL OFF-SITE EXPOSURES MUST BE KEPT BELOW 5 MREMS/YEAR.
- 18-4-1-427 THE HOMEMADE NUCLEAR BOMB SYNDROME  
MEYER, W. + LOYALKA, S. K. + NELSON, W. E.  
WILLIAMS, B. W.  
UNIVERSITY OF MISSOURI, COLUMBIA, MO.  
WITH THE PUBLICATION OF NUCLEAR THEFT - RISKS AND SAFEGUARDS BY WILLRICH AND TAYLOR, SIGNIFICANT ATTENTION HAS BEEN FOCUSED BY THE MEDIA AND THE PUBLIC ON THE POSSIBILITY OF FISSILE MATERIALS BEING STOLEN BY A TERRORIST ORGANIZATION AND DIVERTED TO THE ACTUAL BUILDING, OR THE THREAT OF BUILDING, OF A NUCLEAR EXPLOSIVE DEVICE. THE IMPLICATION HAS BEEN CREATED THAT ONE OR SEVERAL RELATIVELY INEXPERIENCED INDIVIDUALS COULD OBTAIN THE MATERIALS NECESSARY AND FABRICATE A LOW-YIELD NUCLEAR EXPLOSIVE. THIS ARTICLE EXAMINES THESE CONTENTIONS IN SOME DETAIL. THE SAFEGUARDS AND USE-DENIAL METHODS PRESENTLY USED IN THE NUCLEAR FUEL CYCLE ARE CONSIDERED, AND THE DIFFICULTIES THEY PRESENT IN OBTAINING SIGNIFICANT AMOUNTS OF STRATEGIC NUCLEAR MATERIALS ARE EXAMINED. THE CHARACTERISTICS OF REACTOR GRADE PLUTONIUM ARE DISCUSSED, AND THE DIFFICULTIES ASSOCIATED WITH THE ASSEMBLY OF AN EFFICIENT NUCLEAR EXPLOSIVE DEVICE ARE OUTLINED.
- 18-4-1-938 THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY  
LEWIN, J.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
SOVIET REACTOR AND POWER STATION DESIGN INITIALLY PROCEEDED FROM A SAFETY PHILOSOPHY THAT DID NOT ACKNOWLEDGE A LOSS OF COOLANT ACCIDENT CAUSED BY A DOUBLE ENDED PIPE BREAK NOR A MASSIVE CORE MELTDOWN AS CREDIBLE EVENTUALITIES TO BE CONSIDERED IN THE DESIGN OF SYSTEMS AND DETAILS. GENERALLY, ENGINEERED SAFEGUARDS AND CONSERVATISM IN DESIGN HAVE BEEN REGARDED AS ADEQUATE INSURANCE AGAINST ACCIDENTS THAT COULD ESCALATE TO A POINT WHERE THERE IS SIGNIFICANT RADIATION DAMAGE TO EITHER PLANT PERSONNEL OR THE PUBLIC. RECENTLY, THERE HAS BEEN SOME CHANGE IN THE ATTITUDE OF SCIENTISTS TOWARD SECONDARY CONTAINMENT IN PRESSURIZED WATER REACTOR PLANTS. IN PRESSURE TUBE BOILING WATER REACTORS AND LIQUID METAL COOLED FAST BREEDER REACTORS, SOVIET EXPERIENCE ON SEVERAL DEMONSTRATION AND 'SEMICOMMERCIAL' UNITS HAS BEEN INTERPRETED

TO MAN THAT CORE DAMAGE PROPAGATION AND ACCIDENTS INVOLVING LARGE ENERGY RELEASES ARE NOT CREDIBLE. IT APPEARS, HOWEVER, THAT THERE IS NOT COMPLETE UNANIMITY ON ALL SAFETY QUESTIONS, AND GREATER DISPERSION OF AUTHORITY AND MORE FORMAL SAFETY REVIEWS SEEM TO BE IN THE MAKING.

- 18-4-2-451 1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS  
FONTANA, M. H.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE REVIEWS SOME OF THE SIGNIFICANT SAFETY TOPICS THAT WERE DISCUSSED DURING THE INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS HELD IN CHICAGO ON OCT. 5-8, 1976, UNDER THE AUSPICES OF THE AMERICAN NUCLEAR SOCIETY AND THE NEWLY FORMED EUROPEAN NUCLEAR SOCIETY. TWENTY-NINE SESSIONS WERE HELD, INCLUDING TWO PLENARY SESSIONS, MORE THAN 226 PAPERS WERE PRESENTED. BECAUSE OF THE IMPOSSIBILITY OF REPORTING ALL THE SESSIONS, THE REVIEWER HAS ATTEMPTED TO CONVEY A CONSENSUS OF THE STATE OF THE ART OF FAST REACTOR SAFETY AS REPORTED AT THIS MEETING.
- 18-4-3-469 IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER REACTORS  
MCCLUNG, R. W. + SPANNER, J. C. + HAGEN, E. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN. AND WESTINGHOUSE  
HANFORD COMPANY, RICHLAND, WASH.  
ALTHOUGH FIRM REQUIREMENTS HAVE NOT YET BEEN ESTABLISHED IN THE UNITED STATES FOR IN-SERVICE INSPECTION OF LIQUID METAL COOLED FAST BREEDER REACTORS, SOME INITIAL DEVELOPMENT WORK ON POTENTIALLY APPLICABLE NONDESTRUCTIVE TESTING METHODS HAS BEEN CONDUCTED. THIS ARTICLE DESCRIBES PRELIMINARY INVESTIGATIONS OF SEVERAL ADVANCED NONDESTRUCTIVE TESTING CONCEPTS FOR LIQUID SODIUM SYSTEMS. THE METHODS HIGHLIGHTED FOR POTENTIAL APPLICATION ARE ULTRASONICS, EDDY CURRENTS, ELECTROTHERMAL TESTING, UNDER SODIUM VIEWING, AND RADIOGRAPHY.
- 18-4-4-481 NUCLEAR SAFETY EXPERIMENTS IN THE MARVIKEN POWER STATION  
SLAUGHTERBECK, D. C. + FRICSON, L.  
MARVIKEN, SWEDEN  
THIS ARTICLE REVIEWS THREE MULTINATIONAL PROJECTS CONCERNING FULL SCALE NUCLEAR SAFETY EXPERIMENTS AT THE MARVIKEN POWER STATION IN SWEDEN. EXPERIMENTS IN THE FIRST PROJECT, CARRIED OUT IN 1972 AND 1973, WERE RELATED TO THE RESPONSE OF THE PRESSURE SUPPRESSION CONTAINMENT TO SIMULATED RUPTURES IN PIPE SYSTEMS CONNECTED TO THE PRESSURE VESSEL. EXPERIMENTS IN THE SECOND PROJECT, CURRENTLY UNDER WAY, ARE RELATED TO PRESSURE OSCILLATIONS IN THE CONTAINMENT SYSTEM FOLLOWING SIMULATED RUPTURES IN THE PIPE SYSTEM. THE THIRD PROJECT CONCERNS A PROPOSED PROGRAM FOR THE EXPERIMENTAL INVESTIGATION OF CRITICAL MASS FLOW THROUGH SIMULATED RUPTURES IN A FULL SCALE PIPING SYSTEM.
- 18-4-5-492 CONTROLLING OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER STATIONS  
DICKSON, H. W. + OAKES, T. W. + SHANK, K. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE HISTORICAL DEVELOPMENT OF THE PHILOSOPHY OF KEEPING THE RADIATION EXPOSURE OF WORKERS AT LIGHT WATER REACTORS AS LOW AS REASONABLY ACHIEVABLE (ALARA) IS PRESENTED. A REVIEW IS MADE OF SOME OF THE ALARA ACTIVITIES OF THE NUCLEAR REGULATORY COMMISSION, THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, AND VARIOUS NUCLEAR INSTALLATIONS. DATA COMPILED BY THE NRC SHOW THAT ROUTINE AND SPECIAL MAINTENANCE AT LIGHT WATER REACTORS ACCOUNTS FOR 72 PERCENT OF ALL OCCUPATIONAL EXPOSURE AT THESE SITES. THE ROLE THAT OAK RIDGE NATIONAL LABORATORY HAS TAKEN IN ALARA RESEARCH IS PRESENTED, WITH EMPHASIS PLACED ON A STUDY OF VALVE MALFUNCTIONS AT LIGHT WATER REACTORS. THE VALVE STUDY INDICATES A TREND TOWARD DECREASING VALVE RELIABILITY OVER THE PAST FEW YEARS. FINALLY A COST BENEFIT ANALYSIS OF RADIATION DOSE REDUCTION IS DISCUSSED. THE RATIONALE FOR ASSIGNING A COST PER MAN REM BASED ON THE RADIATION EXPOSURE LEVEL THAT IS ENCOUNTERED IS PRESENTED.
- 18-4-5-502 INTERNATIONAL WASTE MANAGEMENT SYMPOSIUM  
SHOUP, R. L.  
UNION CARBIDE CORPORATION, NUCLEAR DIVISION, OAK RIDGE, TENN.  
AN INTERNATIONAL SYMPOSIUM ON THE MANAGEMENT OF WASTES FROM THE LWR FUEL CYCLE WAS HELD IN DENVER, COLO., ON JULY 11-16, 1976. THE SYMPOSIUM COVERED A BROAD RANGE OF TOPICS FROM POLICY ISSUES TO TECHNOLOGY. PRESENTATIONS WERE MADE BY NATIONAL AND INTERNATIONAL SPEAKERS INVOLVED IN ALL ASPECTS OF WASTE MANAGEMENT - GOVERNMENT AND AGENCY OFFICIALS, LABORATORY MANAGERS, DIRECTORS, AND RESEARCHERS, AND INDUSTRIAL REPRESENTATIVES. MANY SPEAKERS ADVOCATED PRAGMATIC ACTION ON PROGRAMS FOR THE MANAGEMENT OF COMMERCIAL NUCLEAR WASTES TO COMPLETE THE LIGHT WATER REACTOR (LWR) FUEL CYCLE. THE INDUSTRIALIZED NATIONS' DEMAND FOR INCREASING SUPPLIES OF ENERGY AND THEIR INCREASING DEPENDENCE ON NUCLEAR ENERGY TO FULFILL THIS DEMAND WILL NECESSITATE THE DEVELOPMENT OF AN ACCEPTABLE SOLUTION TO THE DISPOSAL OF NUCLEAR WASTES WITHIN THE NEXT DECADE FOR SOME INDUSTRIAL NATIONS. WASTE DISPOSAL TECHNOLOGY SHOULD BE IMPLEMENTED ON A COMMERCIAL SCALE, BUT THE COMMERCIALIZATION MUST BE ACCOMPANIED BY THE DECISION TO USE THE TECHNOLOGY. AN IMPORTANT ISSUE IN THE USE OF NUCLEAR

ENERGY IS THE QUESTION OF SHARING THE TECHNOLOGY WITH THE LESS INDUSTRIALIZED NATIONS AND WITH NATIONS THAT MAY NOT HAVE SUITABLE MEANS TO DISPOSE OF NUCLEAR WASTES. THE ESTABLISHMENT OF INTERNATIONAL AND MULTINATIONAL COOPERATION WILL BE AN IMPORTANT KEY IN REALIZING THIS OBJECTIVE. PRESSING ISSUES THAT INTERNATIONAL ORGANIZATIONS OR TASK GROUPS WILL HAVE TO ADDRESS ARE OCEAN DISPOSAL, PLUTONIUM RECYCLING AND SAFEGUARDS, AND DISPOSAL CRITERIA. THE IMPORTANCE OF ACHIEVING A VIABLE WASTE MANAGEMENT PROGRAM IS MADE EVIDENT BY THE INCREASED FUNDING AND ATTENTION THAT THE BACK END OF THE FUEL CYCLE IS NOW RECEIVING.

- 18-4-6-513 REACTOR VESSEL PRESSURE TRANSIENTS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
(EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY SECTION EDITOR FROM A NUCLEAR REGULATORY COMMISSION (NRC) DOCUMENT ENTITLED 'TECHNICAL REPORT ON REACTOR PRESSURE VESSEL TRANSIENTS,' WHICH WAS INCLUDED AS AN ATTACHMENT TO NUREG-D138, 'STAFF DISCUSSION OF FIFTEEN TECHNICAL ISSUES LISTED IN ATTACHMENT TO NOVEMBER 3, 1976, MEMORANDUM FROM DIRECTOR OF NRC TO NRC STAFF.' SINCE SPACE LIMITATIONS DO NOT PERMIT US TO INCLUDE THE TECHNICAL REPORT IN ITS ENTIRETY, THE EDITORS HAVE PREPARED THE FOLLOWING CONDENSED VERSION LARGELY FROM EXCERPTS FROM THE ORIGINAL. THE ORIGINAL REPORT, DATED NOV. 1, 1976, WAS PREPARED BY A TASK GROUP WORKING UNDER THE AUSPICES OF THE NRC OFFICE OF NUCLEAR REACTOR REGULATION AND CHAIRED BY D. G. EISENHUT. THIS REPORT SUMMARIZES THE RELEVANT TECHNICAL CONSIDERATIONS, DISCUSSES THE SAFETY CONCERNS AND EXISTING MARGINS AT OPERATING REACTORS, AND DESCRIBES THE REGULATORY ACTIONS BEING TAKEN TO REDUCE THE LIKELIHOOD OF FUTURE PRESSURE TRANSIENT EVENTS AT OPERATING REACTORS.)
- 18-4-6-523 OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES, 1975  
BROOKS, R. G.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
PERSONNEL OCCUPATIONAL RADIATION EXPOSURES FOR CALENDAR YEAR 1975 WERE OBTAINED FROM ANNUAL AND TERMINATION REPORTS SUBMITTED BY VARIOUS TYPES OF NUCLEAR REGULATORY COMMISSION LICENSEES, INCLUDING NUCLEAR POWER PLANTS AND INDUSTRIAL RADIOGRAPHERS, AS WELL AS FUEL AND BY-PRODUCT PROCESSORS, FABRICATORS, AND REPROCESSORS. ANNUAL REPORTS RECEIVED FROM 387 LICENSEES INDICATED THAT SOME 78,713 INDIVIDUALS, WHO INCURRED AN AVERAGE EXPOSURE OF 0.36 REM, WERE MONITORED FOR EXPOSURE TO RADIATION DURING 1975 AND THAT 21,601 INDIVIDUALS TERMINATED THEIR EMPLOYMENT OR WORK ASSIGNMENT IN 1975. THE NUMBER OF PERSONNEL OVEREXPOSURES REPORTED IN 1975 DECREASED FROM PREVIOUS YEARS.
- 18-5-1-581 TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS  
KNUTH, D. F. + MCFEEN, J. E., JR.  
KMC, INC., WASHINGTON, D. C.  
THIS ARTICLE PRESENTS A BRIEF SUMMARY OF THE U. S. NUCLEAR LICENSING EXPERIENCE AND DISCUSSES THE EFFECT ON COSTS AND TIME TO PLACE A UNIT IN SERVICE. RECENT NUCLEAR REGULATORY COMMISSION POLICY INNOVATIONS, SUCH AS STANDARD REVIEW PLANS, STANDARD FORMAT, STANDARDIZATION, AND GENERIC HEARINGS, ARE DISCUSSED ALONG WITH OBSERVATIONS OF THE IMPACT ON THE LICENSING REVIEW. TECHNICAL AND POLICY UNCERTAINTIES THAT ARE CURRENTLY FACING LICENSEES ARE ALSO DISCUSSED, AS ARE THE POTENTIAL IMPACTS OF TECHNICAL AND LEGAL INTERFACES REQUIRED BY THE INCREASING NUMBER OF GENERIC HEARINGS, STATE HEARINGS, AND FEDERAL COURT REVIEWS.
- 18-5-1-589 NPC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEARCH  
BENNETT, G. L. + SPANO, A. H. + SZAWLEWICZ, S. A.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
THE NUCLEAR REGULATORY COMMISSION AND ITS PREDECESSOR, THE ATOMIC ENERGY COMMISSION, HAVE ENTERED INTO A NUMBER OF REACTOR SAFETY RESEARCH AGREEMENTS WITH OTHER COUNTRIES. THESE AGREEMENTS INVOLVE VARIOUS FORMS OF COOPERATION INCLUDING BILATERAL INFORMATION EXCHANGE AND JOINT RESEARCH PARTICIPATION IN SPECIFIC PROJECTS ON A BILATERAL OR MULTILATERAL LEVEL. UNDER THE TERMS OF THESE AGREEMENTS, REPORTS, COMPUTER CODES, AND DATA MAY BE EXCHANGED AND PERSONNEL VISITS AND ASSIGNMENTS PERMITTED. THESE AGREEMENTS HAVE PROVED TO BE BENEFICIAL IN PROVIDING FOR A COST EFFECTIVE EXTENSION OF THE BASE OF REACTOR SAFETY INFORMATION AVAILABLE TO THE PARTIES CONCERNED. SUCH AGREEMENTS HELP TO ENHANCE REACTOR SAFETY WORLDWIDE.
- 18-5-2-596 A REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER  
BJENKE, M. A. + HOLM, J. S. + SHAY, M. R.  
SPINRAD, B. I.  
OREGON STATE UNIVERSITY, CORVALLIS, OREG.  
EXPERIMENTS ON SHORT TERM FISSION PRODUCT DECAY POWER, WHICH MAY BE IMPORTANT FOR LOSS OF COOLANT ACCIDENT ANALYSIS, ARE REVIEWED. THE MOST RECENT EXPERIMENTS GIVE SUFFICIENT DATA TO FORM THE BASIS OF REASONABLE STANDARDS, PARTICULARLY WHEN THEY ARE SUPPLEMENTED WITH RESULTS FROM SIMULATION PREDICTIONS. THE PREPARATION OF IMPROVED STANDARDS FOR SCIENTIFIC AND REGULATORY

PURPOSES IS IN AN ADVANCED STAGE. PRELIMINARY ESTIMATES INDICATE THAT THE EXISTING STANDARD PROPOSED BY THE AMERICAN NUCLEAR SOCIETY HAS AN EXTREMELY CONSERVATIVE UNCERTAINTY BAND ASSOCIATED WITH IT. NEW DATA PROVIDE FIRM JUSTIFICATION FOR REDUCING THE UNCERTAINTY ASSOCIATED WITH THE EXISTING STANDARD.

- 18-5-3-617 INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT SITES  
ALLEN, J. M. + KARNER, D. B.  
ARIZONA NUCLEAR POWER PROJECT, PHOENIX, ARIZ.  
TYPICAL INSTRUMENTATION PROGRAMS TO DETERMINE THE SUITABILITY OF A PROPOSED NUCLEAR POWER PLANT SITE ARE DESCRIBED. AN OVERVIEW OF REGULATORY REQUIREMENTS IS PRESENTED, ALONG WITH A BRIEF DISCUSSION OF TYPICAL METEOROLOGICAL, SEISMOLOGICAL, GEOLOGICAL, RADIOLOGICAL, AND SEWAGE EFFLUENT MONITORING SYSTEMS. THE DISCUSSION DEFINES THE VARIOUS PARAMETERS THAT MUST BE MEASURED AND DESCRIBES THE TYPICAL SENSORS, TRANSDUCERS, AND INSTRUMENTATION USED. PROBLEMS PRESENTED BY A REMOTE DESERT SITE, SUCH AS ONE LOCATED IN THE ARID SOUTHWESTERN UNITED STATES, ARE ALSO DISCUSSED.
- 18-5-3-624 COMMON-MODE FAILURES IN REACTOR SAFETY SYSTEMS  
JOLLY, M. E. + WEATHALL, J.  
U.K. CENTRAL ELECTRICITY GENERATING BOARD  
THIS ARTICLE DESCRIBES THE PRINCIPLES ADOPTED BY THE U.K. CENTRAL ELECTRICITY GENERATING BOARD IN TACKLING THE HAZARDS OF COMMON-MODE FAILURES IN REACTOR SAFETY EQUIPMENT AND INDICATES THE WAYS IN WHICH THE PRINCIPLES ARE IMPLEMENTED IN PRACTICE. WHERE APPROPRIATE, REFERENCE IS ALSO MADE TO APPLICATIONS IN POSTHEAT COOLING AREAS. RECOGNITION IS GIVEN TO THE FACT THAT DIVERSITY IS NOT AN ABSOLUTE MEASURE, BUT ONE WHICH HAS VARYING DEGREES OF DEPTH. THE DISCUSSION IS EXTENDED TO SHOW THAT THE USE OF EXAMINATION IN DEPTH MUST INCLUDE NOT ONLY HARDWARE BUT ALSO CALCULATIONAL METHODS AND OPERATOR ASPECTS. IT IS CONCLUDED THAT THERE IS NO OBJECTIVE WAY OF ESTABLISHING THE PROBABILITY OF COMMON-MODE FAILURE FOR HIGH INTEGRITY EQUIPMENT AND THAT THERE IS NO SUBSTITUTE FOR THE USE OF ENGINEERING EXPERIENCE IN DEPTH.
- 18-5-4-633 CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES  
MOELLER, D. W.  
HARVARD UNIVERSITY, BOSTON, MASS.  
THE SAFE OPERATION OF NUCLEAR FACILITIES IS HEAVILY DEPENDENT UPON THE ADEQUATE PERFORMANCE OF AIR CLEANING SYSTEMS. THOUGH MANY PROBLEMS HAVE BEEN SOLVED, NEW QUESTIONS AND NEW CHALLENGES CONTINUE TO ARISE. THESE ARE WELL ILLUSTRATED BY WEAKNESSES IN AIR CLEANING AND VENTILATING SYSTEMS REVEALED IN THE BROWNS FERRY FIRE AND BY THE NEED TO DEVELOP ADDITIONAL DATA ON THE RELIABILITY OF SUCH SYSTEMS, PARTICULARLY UNDER EMERGENCY CONDITIONS, AS ENUMERATED IN THE REACTOR SAFETY STUDY. ASSESSMENTS OF THE DEGREE TO WHICH ENGINEERED SAFETY FEATURES CAN COMPENSATE FOR DEFICIENCIES IN NUCLEAR POWER PLANT SITES CONTINUE TO CONCERN THOSE INVOLVED IN RISK / BENEFIT EVALUATIONS.
- 18-5-5-647 TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES - A CRITICAL ASSESSMENT  
PATRICK, C. H.  
U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION, WASHINGTON, D.C.  
TEN STUDIES THAT HAVE LOOKED SPECIFICALLY AT CHANGES IN PUBLIC HEALTH IN AREAS NEAR NUCLEAR FACILITIES ARE CRITICALLY REVIEWED. ALL BUT ONE OF THESE STUDIES HAVE BEEN UNABLE TO SHOW ADVERSE HEALTH EFFECTS IN THE LOCAL POPULATION THAT MIGHT BE RELATED TO RADIATION EXPOSURE. THE ONE STUDY THAT PURPORTS TO FIND AN ADVERSE EFFECT HAS SEVERE METHODOLOGICAL LIMITATIONS, WHICH PRECLUDE ANY MEANINGFUL INTERPRETATION OF THE DATA. ALSO PRESENTED IS AN ANALYSIS OF THE INDICATORS OF PUBLIC HEALTH IN THE AREA OF OAK RIDGE, TENN., WHICH SHOWS CANCER MORTALITY RATES THAT ARE NOT SIGNIFICANTLY HIGHER THAN WOULD BE EXPECTED IN THE GENERAL U.S. POPULATION. ALTHOUGH MUCH MORE RESEARCH IS NEEDED BEFORE ALL THE EFFECTS OF VERY LOW LEVELS OF RADIATION FROM NUCLEAR REACTORS WILL BE KNOWN, THE EXISTING STUDIES SUGGEST THAT NUCLEAR POWER PLANTS WILL NOT HAVE A SIGNIFICANT IMPACT ON PUBLIC HEALTH AS A RESULT OF NORMAL OPERATIONS.
- 18-5-6-664 NUCLEAR POWER PLANT PERFORMANCE ANALYSIS  
KUPFER, K.  
NORDOSTSCHWEIZERISCHE KRAFTWERK, BADEN, SWITZERLAND  
EDITOR'S NOTE - IN NOVEMBER 1976 THE INTERNATIONAL CONFERENCE ON WORLD NUCLEAR POWER WAS HELD IN WASHINGTON, D.C., AND WAS JOINTLY SPONSORED BY THE AMERICAN NUCLEAR SOCIETY AND THE EUROPEAN NUCLEAR SOCIETY. K. KUPFER, WHO WAS COCHAIRMAN OF ONE OF THE SESSIONS, OPENED THAT SESSION WITH THE REMARKS THAT COMPRISE THE TEXT OF THIS ARTICLE. DR. KUPFER IS ASSOCIATED WITH NORDOSTSCHWEIZERISCHE KRAFTWERK OF BADEN, SWITZERLAND, AND HAS BEEN DEEPLY INVOLVED WITH THE OPERATION OF THE BERNAU NUCLEAR POWER STATION. HIS REMARKS SUMMARIZE POWER PLANT PERFORMANCE IN EUROPE, IN THE UNITED STATES, AND ELSEWHERE AND SHOULD BE OF INTEREST TO ALL PERSONS CONCERNED WITH SUCH ACTIVITIES.

- 18-5-6-566 OPERATING EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE  
LUTE, H. R. + KUPFER, K. + SCHENK, K.  
KERNKRAFTWERK MUEHLEBERG DER BERNISCHE KRAFTWERK, MUEHLEBERG,  
SWITZERLAND / KERNKRAFTWERK BEENAU DER NORDOSTSCHWEIZERISCHE  
KRAFTWERK, DOTTINGEN, SWITZERLAND / KERNKRAFTWERK OBRIGHEIM  
GMBH, OBRIGHEIM, WETZLAR, FEDERAL REPUBLIC OF GERMANY  
THE OPERATING EXPERIENCE OF 13 EUROPEAN LIGHT WATER REACTOR  
(LWR) POWER STATIONS THAT BEGAN OPERATION PRIOR TO JANUARY  
1973 IS PRESENTED. GIVEN ARE KEY PARAMETERS, SUCH AS AVERAGE  
LOAD FACTOR, LOAD DIAGRAMS, NONAVAILABILITY ANALYSES,  
STATISTICS ON LEAKING FUEL ELEMENTS, RADIOACTIVITY DISCHARGE  
VALUES, SIZE OF POWER STATION STAFFS, MAN REM EXPOSURES,  
ADDITIONAL INVESTMENTS, ETC. SOME SPECIAL EVENTS ARE DESCRIBED  
IN DETAIL. THEORIES FOR THE DISPARITIES IN CAPACITY FACTORS  
BETWEEN EUROPEAN AND AMERICAN LWR POWER STATIONS AND BETWEEN  
PRESSURIZED WATER REACTOR AND BOILING WATER REACTOR POWER  
STATIONS ARE ALSO PRESENTED.
- 18-5-1-727 GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM  
SEIPEL, H. G. + LOMMERZHEIN, D. + BITTIG, D.  
FEDERAL MINISTRY OF RESEARCH AND TECHNOLOGY, FEDERAL REPUBLIC OF  
GERMANY  
THE LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM, WHICH IS PART  
OF THE ENERGY PROGRAM OF THE FEDERAL REPUBLIC OF GERMANY, IS  
PRESENTED IN THIS ARTICLE. THE PROGRAM, FOR WHICH THE FEDERAL  
MINISTER OF RESEARCH AND TECHNOLOGY OF THE FEDERAL REPUBLIC OF  
GERMANY IS RESPONSIBLE, IS SUBDIVIDED INTO THE FOLLOWING FOUR  
MAIN PROBLEM AREAS, WHICH IN TURN ARE SUBDIVIDED INTO PROJECTS  
(1) IMPROVEMENT OF THE OPERATIONAL SAFETY AND RELIABILITY OF  
SYSTEMS AND COMPONENTS (PROJECTS - QUALITY ASSURANCE, COMPONENT  
SAFETY) (2) ANALYSIS OF THE CONSEQUENCES OF ACCIDENTS (PROJECTS  
- EMERGENCY CORE COOLING, CONTAINMENT, EXTERNAL IMPACTS,  
PRESSURE VESSEL FAILURE, CORE MELTDOWN) (3) ANALYSIS OF  
RADIATION EXPOSURE DURING OPERATION, ACCIDENT, AND  
DECOMMISSIONING (PROJECT - FISSION PRODUCT TRANSPORT AND  
RADIATION EXPOSURE) AND (4) ANALYSIS OF THE RISK CREATED BY  
THE OPERATION OF NUCLEAR POWER PLANTS (PROJECT - RISK AND  
RELIABILITY). VARIOUS PROBLEMS, WHICH ARE INCLUDED IN THE ABOVE  
MENTIONED PROJECTS, ARE CONCURRENTLY STUDIED WITHIN THE  
HEISS-DAMPF REACTOR EXPERIMENTS. INVESTIGATIONS ON THE SAFETY  
OF PRESSURIZED REACTOR COMPONENTS IN CONNECTION WITH RESEARCH  
AND DEVELOPMENT ACTIVITIES ON NONDESTRUCTIVE TESTING HAVE  
SHOWN THAT THE HIGH SAFETY STANDARDS THAT MUST BE SET FOR  
NUCLEAR INSTALLATIONS CAN BE MET BY A COMPREHENSIVE QUALITY  
ASSURANCE SYSTEM, WHEREBY THE MATERIAL AND PROCEDURAL TESTS,  
AS WELL AS THE NONDESTRUCTIVE TESTS BEFORE AND DURING THE  
OPERATION, ARE CAREFULLY COORDINATED WITH EACH OTHER. FURTHER  
INVESTIGATIONS ARE CONCENTRATED ON THE SAFETY MARGINS DURING  
LONGTIME OPERATION.
- 18-6-1-756 NUCLEAR SAFETY AT SALZBURG  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE IS A REVIEW OF SELECTED MATERIAL FROM THE IAEA  
INTERNATIONAL CONFERENCE ON NUCLEAR POWER AND ITS FUEL CYCLE  
HELD IN SALZBURG, AUSTRIA, MAY 2-13, 1977 (IAEA-CN-36). THE  
SESSIONS CONSIDERED DEAL WITH NUCLEAR REACTOR SAFETY AND PUBLIC  
OPINION, ALTHOUGH THE SUBSEQUENT DISCUSSION INCLUDES COMMENTS  
ON THE ENTIRE MEETING. IN GENERAL, THE SAFETY PAPERS ARE OF  
VALUE BECAUSE OF THEIR COMPREHENSIVE REVIEW OF THE SUBJECT  
MATTER RATHER THAN TO ANY SIGNIFICANT NEW DEVELOPMENTS. THE  
SESSIONS ON PUBLIC OPINION NOT ONLY INDICATED THE UNIVERSALITY  
OF THIS ELEMENT BUT ALSO REVEALED DIFFERING DEGREES OF CONCERN  
AND LEVELS OF RESPONSE. DESPITE THE MANY TECHNICAL  
PRESENTATIONS OF MERIT, THE CONFERENCE WAS DOMINATED BY THE  
PREVIOUSLY ANNOUNCED U.S. POLICY CONCERNING THE RECYCLING OF  
NUCLEAR FUEL AND THE DEPLOYMENT OF THE FAST BREEDER REACTOR.  
THE GENERAL AGREEMENT WITH REGARD TO THE NEED TO PREVENT THE  
SPREAD OF NUCLEAR WEAPONS DID NOT ENCOMPASS THE NEW U.S.  
POSITION.
- 18-6-2-761 AN ASSESSMENT OF HTGR ACCIDENT CONSEQUENCES  
BARSPILL, A. W. + JOKSINOVIC, V. + SILADY, F. A.  
GENERAL ATOMIC COMPANY, SAN DIEGO, CALIF.  
ASSESSMENTS WERE MADE OF THE CONSEQUENCES OF THE HIGHER RISK  
ACCIDENT CONDITIONS POSTULATED TO OCCUR IN A REFERENCE 1975  
GENERAL ATOMIC 3000-MW(T) HIGH TEMPERATURE GAS COOLED REACTOR.  
THIS PROBABILISTIC RISK ASSESSMENT STUDY, KNOWN AS ACCIDENT  
INITIATION AND PROGRESSION ANALYSIS, IS FUNDED BY THE ENERGY  
RESEARCH AND DEVELOPMENT ADMINISTRATION. THE MOST  
REPRESENTATIVE ACCIDENT CONDITIONS ARE (1) CORE HEATUP CAUSED  
BY A LOSS OF OFF-SITE POWER OR BY A LARGE EARTHQUAKE, LEADING  
TO A LOSS OF FORCED CIRCULATION, (2) REHEATER TUBE FAILURE, (3)  
DEPRESSURIZATION OF THE PRIMARY COOLANT, AND (4) STEAM  
GENERATOR MAIN BUNDLE TUBE FAILURE. THE RADIOLOGICAL  
CONSEQUENCES, WHICH ARE BASED ON REPRESENTATIVE U.S. POPULATION  
DENSITIES, WERE ASSESSED IN REMS AS A FUNCTION OF DISTANCE FROM  
THE PLANT AND MAN-REM EXPOSURES TO THE SURROUNDING ENVIRONMENT.  
THE RESULTS INDICATE THAT THE HIGH TEMPERATURE GAS COOLED  
REACTOR HAS EXCELLENT SAFETY CHARACTERISTICS, WHICH ARE  
INHERENT IN THE CONCEPT AND ARE PRIMARILY ASSOCIATED WITH THE  
CHOICE OF COOLANT AND CORE DESIGN. OVER A WIDE RANGE OF

ACCIDENT FREQUENCIES (FROM ONE ACCIDENT PER REACTOR YEAR TO ONE ACCIDENT IN 10 MILLION REACTOR YEARS), NO ACCIDENTS CONSIDERED IN THE STUDY ARE PREDICTED TO CAUSE EARLY OR DELAYED FATALITIES OR ILLNESSES.

18-6-3-774

HUMAN FACTORS IN THE NUCLEAR CONTROL ROOM  
SEMINARA, J. L. \* PACK, R. W. \* GONZALEZ, W. R.  
PARSONS, S. O.  
ELECTRIC POWER RESEARCH INSTITUTE, PALO ALTO, CALIF. / LOCKHEED MISSILES AND SPACE COMPANY, INC., SUNNYVALE, CALIF.  
HUMAN FACTORS ENGINEERING IS AN INTERDISCIPLINARY SPECIALTY CONCERNED WITH INFLUENCING THE DESIGN OF EQUIPMENT SYSTEMS, FACILITIES, AND OPERATIONAL ENVIRONMENTS TO PROMOTE SAFE, EFFICIENT, AND RELIABLE OPERATOR PERFORMANCE. THE HUMAN FACTORS ASPECTS OF FIVE REPRESENTATIVE NUCLEAR POWER PLANT CONTROL ROOMS WERE EVALUATED USING SUCH METHODS AS A CHECKLIST GUIDED OBSERVATION SYSTEM BASED ON MILITARY STANDARDS, STRUCTURED INTERVIEWS WITH OPERATORS AND TRAINEES, DIRECT OBSERVATIONS OF OPERATOR BEHAVIOR, TASK ANALYSES, PROCEDURE EVALUATIONS, AND HISTORICAL ERROR ANALYSES. THE REVIEW HAS SURFACED A WIDE SPECTRUM OF HUMAN FACTORS PROBLEM AREAS AND NEEDED IMPROVEMENTS. THE STUDY RECOMMENDS THAT A DETAILED SET OF APPLICABLE HUMAN FACTORS STANDARDS BE DEVELOPED TO STIMULATE A UNIFORM AND SYSTEMATIC CONCERN FOR HUMAN FACTORS. IT IS FURTHER RECOMMENDED THAT DESIGN GUIDES BE DEVELOPED TO FACILITATE THE IMPLEMENTATION OF SUCH STANDARDS BOTH FOR NEW DESIGNS AND FOR UPGRADING EXISTING CONTROL ROOMS. A NUMBER OF RESEARCH AREAS ARE DELINEATED IN ORDER TO DEVELOP A MORE COMPREHENSIVE DATA BASE ON WHICH TO PREDICATE HUMAN FACTORS STANDARDS.

18-6-4-791

FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS  
JAMES, L. A.  
WESTINGHOUSE HANFORD COMPANY, RICHLAND, WASH.  
THE RESULTS OF A NUMBER OF EXPERIMENTS DEALING WITH FATIGUE CRACK PROPAGATION IN IRRADIATED REACTOR PRESSURE VESSEL STEELS ARE REVIEWED. THE STEELS INCLUDED ASTM ALLOYS A302B, A533B, A508-2, AND A543, AS WELL AS WELDMENTS IN A543 STEEL. FLUENCES AND IRRADIATION CONDITIONS WERE GENERALLY TYPICAL OF THOSE EXPERIENCED BY MOST POWER REACTORS. IN GENERAL, THE EFFECT OF NEUTRON IRRADIATION ON THE FATIGUE CRACK PROPAGATION BEHAVIOR OF THESE STEELS WAS NEITHER SIGNIFICANTLY BENEFICIAL NOR SIGNIFICANTLY DETRIMENTAL.

18-6-5-802

POWER PLANT DISCHARGES - TOWARD MORE REASONABLE EFFLUENT LIMITS ON CHLORINE  
MATTICE, J. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A METHOD IS PRESENTED FOR RESTRICTING CHLORINE IN POWER-PLANT EFFLUENTS TO ENVIRONMENTALLY SAFE LEVELS. DEVELOPMENT OF THIS METHOD WAS STIMULATED BY THE CONTROVERSY BETWEEN ELECTRIC UTILITIES AND REGULATORY AGENCIES OVER THE JUSTIFICATION OF THE PRESENT UNIVERSALLY APPLIED LIMITS. THE SCIENTIFIC LITERATURE CONCLUSIVELY DEMONSTRATES THE EFFECTS OF PHYSICAL, CHEMICAL, AND BIOTIC FACTORS ON CHLORINE TOXICITY. THE METHOD PROPOSED INCLUDES THESE FACTORS, TO THE EXTENT CURRENTLY POSSIBLE, TO SET LIMITS BASED ON SITE SPECIFIC AQUATIC CONDITIONS AND PLANT DESIGN AND OPERATION SPECIFICATIONS. IN THESE EFFLUENT LIMITS, THE ORGANISMS CONSIDERED ARE THOSE WHICH ARE ENTRAINED INTO THE PLUME OF WHICH MAINTAIN THEMSELVES WITHIN THE PLUME DURING CHLORINATION. IN EACH INSTANCE THE TIME COURSE OF EXPOSURE CONCENTRATION IS DIVIDED INTO SMALL TIME INTERVALS. WEIGHTED MEAN CONCENTRATIONS FOR SUCCESSIVELY LARGER TIME INTERVALS FOLLOWING INITIAL EXPOSURE ARE THEN CALCULATED. EXPOSURES RESULTING FROM RELEASES AT VARIOUS LEVELS ARE COMPARED EITHER GRAPHICALLY OR MATHEMATICALLY WITH ACUTE AND CHRONIC MORTALITY THRESHOLDS TO FIND THE HIGHEST DISCHARGE CONCENTRATION THAT DOES NOT CAUSE MORTALITY. THE THRESHOLDS ARE DERIVED FROM EXISTING TOXICITY DATA AND ARE DIFFERENT FOR MARINE AND FRESHWATER ORGANISMS. THIS METHOD IS BASED ON THE LATEST LITERATURE AVAILABLE AND CAN INCORPORATE FURTHER DATA CONCERNING CHEMISTRY, TOXICITY, AND BEHAVIOR AS THEY BECOME AVAILABLE. THE METHOD ALSO IS AMENABLE TO COUPLING WITH MODELS OF CHEMICAL DISPERSION AND POPULATION DYNAMICS TO PERMIT MORE COMPLETE ANALYSIS. THIS APPROACH SERVES TO PERMIT USE OF CHLORINE FOR BIOPOLLING CONTROL AT POWER PLANTS, WHILE ENSURING THAT THIS USE WILL NOT BE INIMICAL TO THE ENVIRONMENT.

19-1-1-1

THE STATE SIDE OF THE SITING EQUATION - SOME CASE STUDIES  
RYAN, R. G.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THIS ARTICLE IS A BRIEF SURVEY OF STATE ACTIVITIES IN THE SITING OF NUCLEAR PRODUCTION AND UTILIZATION FACILITIES. IT CONSISTS OF MATERIAL GATHERED BY THE OFFICE OF STATE PROGRAMS IN CONNECTION WITH A STUDY CARRIED OUT IN ACCORDANCE WITH EFFICIENCY IN FEDERAL/STATE SITING ACTIONS - DETAILED STUDY PLAN (NUREG-0128), WHICH WAS AUTHORIZED BY THE NUCLEAR REGULATORY COMMISSION (NRC) IN SEPTEMBER 1976. THE FINAL REPORT, IMPROVING REGULATORY EFFECTIVENESS IN FEDERAL/STATE SITING ACTIONS (NUREG-0195), WAS PRESENTED TO THE NRC IN MAY 1977.

- 19-1-2-10 THERMAL SHOCK STUDIES ASSOCIATED WITH INJECTION OF EMERGENCY CORE COOLANT FOLLOWING A LOSS OF COOLANT ACCIDENT IN PWRs  
CHEVERTON, R. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE THERMAL SHOCK RESULTING FROM INJECTION OF EMERGENCY CORE COOLANT FOLLOWING A LOSS OF COOLANT ACCIDENT MAY, UNDER CERTAIN CIRCUMSTANCES, RESULT IN PROPAGATION OF PREEXISTING CRACKS ON THE INNER SURFACE OF PRESSURIZED WATER REACTOR (PWR) PRESSURE VESSELS. AT OAK RIDGE NATIONAL LABORATORY, STUDIES BEING CONDUCTED IN CONNECTION WITH THIS PROBLEM INCLUDE THE THERMAL SHOCK TESTING OF 533-MM-OD BY 241-MM-ID STEEL TEST SPECIMENS. FOUR EXPERIMENTS HAVE BEEN CONDUCTED THUS FAR. THE RESULTS HAVE REVEALED NO SIGNIFICANT ANOMALIES AND TEND TO VALIDATE WITH REASONABLE ACCURACY THE METHODS OF ANALYSIS USED FOR PREDICTING THE BEHAVIOR OF PWR VESSELS UNDER THERMAL SHOCK CONDITIONS. OUR ANALYSIS OF THE PWR INDICATES THAT IN PRESENT GENERATION AND FUTURE PWR VESSELS CRACK PROPAGATION WILL NOT OCCUR AS A RESULT OF THERMAL SHOCK, BUT IN OLDER VESSELS IT MAY. HOWEVER, IT APPEARS THAT A PHENOMENON KNOWN AS WARM PRESTRESSING WILL PREVENT EXCESSIVE CRACK PENETRATION.
- 19-1-2-20 THE REFLOODING PHASE OF THE LOCA IN PWRs I. CORE HEAT TRANSFER AND FLUID FLOW  
YADIGAROGLU, G.  
UNIVERSITY OF CALIFORNIA, BERKELEY, CALIF.  
THIS IS THE FIRST OF TWO ARTICLES ON THE REFLOODING PHASE OF THE LOSS OF COOLANT ACCIDENT (LOCA) IN PRESSURIZED WATER REACTORS. (THE OTHER ARTICLE, PART II, IS SCHEDULED FOR VOL. 19, NO. 2.) THIS FIRST ARTICLE IS A GENERAL DESCRIPTION OF CORE BEHAVIOR DURING THE REFLOODING PHASE OF THE LOCA. A SUCCESSION OF HEAT TRANSFER AND TWO PHASE FLOW REGIMES MOVES ALONG THE ROD BUNDLE DURING REFLOODING OF THE CORE. PARAMETRIC RANGES AND OTHER FEATURES OF TRANSIENT REFLOODING EXPERIMENTS THAT HAVE BEEN CONDUCTED WITH ROD BUNDLES AND IN SIMPLE SINGLE CHANNEL GEOMETRIES ARE TABULATED. EXPERIMENTAL FINDINGS AND PARAMETRIC TRENDS ARE SUMMARIZED AND EXPLAINED. CORE HEAT TRANSFER AND HYDRODYNAMICS ANALYSIS METHODS INCORPORATED IN EMERGENCY CORE COOLING SYSTEM EVALUATION MODELS USED FOR LICENSING PURPOSES ARE REVIEWED, AND THE WORK ON MORE ADVANCED MODELS THAT ATTEMPT TO ESTIMATE CORE HEAT TRANSFER COEFFICIENTS ON THE BASIS OF CALCULATED LOCAL FLOW CONDITIONS IS NOTED.
- 19-1-3-38 INTERNATIONAL CONFERENCE ON NUCLEAR SYSTEMS RELIABILITY ENGINEERING AND RISK ASSESSMENT  
HAGEN, F. W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
AN INTERNATIONAL MEETING OF SPECIALISTS CONCERNED WITH THE METHODOLOGIES FOR RELIABILITY ANALYSIS AND RISK ASSESSMENT WAS HELD IN GATLINBURG, TENN., JUNE 20-24, 1977. THEORETICAL AND APPLICABLE PRESENTATIONS TREATED STATE OF THE ART TECHNIQUES IN ANALYSIS AND ASSESSMENT, FOR THE MOST PART UTILIZING REFINEMENTS BASED ON FAULT TREE STRUCTURE. SEVERAL GENERAL CATEGORIES WERE IDENTIFIED FROM THE 34 PAPERS WITH SEVERAL AUTHORS CLAIMING SOME ABILITY AT TREATMENT OF COMMON CAUSE FAILURES.
- 19-1-4-43 LOFT EMERGENCY CORE-COOLING SYSTEM EXPERIMENTS - RESULTS FROM THE L1-4 EXPERIMENT  
LEACH, L. P. + YHARRONDO, L. J.  
IDAHO NATIONAL ENGINEERING LABORATORY, IDAHO FALLS, IDAHO  
RESULTS FROM EMERGENCY CORE COOLING SYSTEM EXPERIMENTS IN THE LOSS OF FLUID TEST FACILITY ARE DESCRIBED. THE EXPERIMENTAL RESULTS ARE PUT IN PERSPECTIVE BY COMPARING THEM WITH RESULTS FROM THE MUCH SMALLER SEMISCALE FACILITY AND PRETEST PREDICTIONS MADE WITH RELAP4/MOD5 COMPUTER CODE. EMPHASIS IS PLACED ON THE MOST RECENT LOSS OF FLUID TEST NONNUCLEAR EXPERIMENT, DESIGNATED L1-4, IN WHICH THE EMERGENCY CORE COOLING WATER WAS INJECTED INTO THE REACTOR INLET PIPE, AS IT IS IN MANY COMMERCIAL NUCLEAR REACTORS. GENERAL SYSTEM BEHAVIOR DURING THE DECOMPRESSION, EMERGENCY CORE COOLING WATER MIXING PHENOMENON, AND EMERGENCY CORE COOLING WATER BYPASS ARE EVALUATED.
- 19-1-5-50 A SUMMARY OF SHALLOW LAND BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL SITES BETWEEN 1962 AND 1976, WITH PROJECTIONS  
HOLCOMB, W. F.  
U. S. ENVIRONMENTAL PROTECTION AGENCY, WASHINGTON, D. C.  
THE U. S. ENVIRONMENTAL PROTECTION AGENCY REQUESTED THE SIX STATES HAVING COMMERCIAL SHALLOW LAND BURIAL FACILITIES FOR OTHER THAN HIGH LEVEL RADIOACTIVE WASTES TO PROVIDE INVENTORIES OF THE TYPES AND QUANTITIES OF WASTES BURIED AT THESE SITES. COMPILATIONS AND INTERPRETATIONS OF THE INVENTORIES ARE PRESENTED IN TABLES AND FIGURES. PROJECTIONS TO THE YEAR 2000 ARE MADE AND COMPARED WITH OTHER PROJECTIONS OF THE QUANTITY OF FUEL CYCLE AND NONFUEL CYCLE WASTES TO BE DISPOSED OF BY SHALLOW LAND BURIAL. THESE PROJECTIONS ARE THEN COMPARED WITH THE ASSUMED AVAILABLE CAPACITY AND OPERATIONAL LIFE OF THE COMMERCIAL SITES. THE RESULTS OF THIS COMPARISON INDICATE THAT THE EXISTING SITES SHOULD HAVE ADEQUATE BURIAL CAPACITY UNTIL THE LATE 1990S.



- 19-1-5-60      **FOURTH INTERNATIONAL CONGRESS OF THE INTERNATIONAL RADIATION PROTECTION ASSOCIATION**  
 JACCOBS, D. G.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THE FOURTH INTERNATIONAL CONGRESS OF THE INTERNATIONAL RADIATION PROTECTION ASSOCIATION WAS HELD IN PARIS, FRANCE, APR. 24-30, 1977. THE CONGRESS WAS HOSTED BY THE SOCIETE FRANCAISE DE RADIOPROTECTION AND HAD AS ITS THEME 'RADIATION PROTECTION - AN EXAMPLE OF ACTION AGAINST MODERN HAZARDS.' THE MEETING WAS ATTENDED BY APPROXIMATELY 1200 SCIENTISTS REPRESENTING 25 COUNTRIES AND NUMEROUS INTERNATIONAL ORGANIZATIONS. ALL BUT 14 OF THE 222 PAPERS PRESENTED IN THE 30 ORAL SESSIONS AND ALL BUT 7 OF 119 PAPERS PRESENTED IN THE 7 POSTER SESSIONS WERE DISTRIBUTED IN THE PRINTED PROCEEDINGS AT THE MEETING. A BROAD SPECTRUM OF TOPICS WAS COVERED, RANGING FROM MOLECULAR AND CELLULAR BIOLOGY TO RADIOACTIVE WASTE MANAGEMENT AND EMERGENCY PLANS FOR NUCLEAR ACCIDENTS.
- 19-1-5-66      **ENVIRONMENTAL SURVEILLANCE FOR NUCLEAR FACILITIES**  
 MOELLER, D. W. + SELBY, J. H. + WAITE, D. A.  
 CORLEY, J. P.  
 HARVARD UNIVERSITY, BOSTON, MASS. / BATTTELLE PACIFIC NORTHWEST LABORATORY, RICHLAND, WASH.  
 ONE OF THE PRIMARY GOALS OF ENVIRONMENTAL SURVEILLANCE PROGRAMS IN THE VICINITY OF NUCLEAR FACILITIES IS TO OBTAIN INFORMATION ESSENTIAL TO ASSESSING AND CONTROLLING DOSE EXPOSURE TO THE NEIGHBORING POPULATION. EXPERIENCE HAS SHOWN, HOWEVER, THAT ENVIRONMENTAL RADIONUCLIDE CONCENTRATIONS ARE FREQUENTLY SO LOW AND SO VARIABLE THAT DOSE ESTIMATES MUST BE BASED PRIMARILY ON IN-PLANT AND EFFLUENT MEASUREMENTS, COUPLED WITH SUITABLE CALCULATIONAL TECHNIQUES FOR EXTRAPOLATING SUCH DATA TO THE GENERAL ENVIRONMENT. ALTHOUGH THE NUMBER OF PATHWAYS BY WHICH EACH OF THE RELEASED RADIONUCLIDES MAY ULTIMATELY REACH THE POPULATION ARE NUMEROUS AND COMPLEX, IN MOST SITUATIONS THE PRIMARY CONTRIBUTORS TO THE POPULATION DOSE WILL CONSIST OF NO MORE THAN SIX RADIONUCLIDES MOVING THROUGH THREE OR FOUR PATHWAYS. CURRENT PROBLEMS ASSOCIATED WITH ENVIRONMENTAL SURVEILLANCE PROGRAMS INCLUDE (1) LACK OF A DEFINITION OF DE MINIMIS DOSE LEVELS FOR MEASUREMENT OR CALCULATION, (2) DEFICIENCIES IN QUALITY ASSURANCE, DATA TREATMENT, AND SOURCE IMPACT DEFINITION, (3) LACK OF PERIODIC IN-DEPTH REVIEW AND REEVALUATION OF PROGRAMMATIC NEEDS, AND (4) LACK OF SUFFICIENT RESOURCES ON THE PART OF STATE AND LOCAL AGENCIES FOR PROVIDING AN INDEPENDENT CHECK ON THE DATA REPORTED BY NUCLEAR FACILITY OPERATORS.
- 19-1-6-91      **AN EXPLOSION AND FIRE DURING CONVERSION OF LIQUID URANYL NITRATE TO SOLID URANIUM OXIDE**  
 GRAY, L. W.  
 SAVANNAH RIVER LABORATORY, Aiken, S.C.  
 DURING THE CONVERSION OF MOLTEN URANYL NITRATE TO SOLID URANIUM OXIDE AT THE SAVANNAH RIVER PLANT, A RAPID CHEMICAL REACTION OCCURRED IN A DENITRATOR AND EXPULSED THE CONTENTS, INCLUDING COMBUSTIBLE GASES, INTO THE PROCESS ROOM. THE GASES IGNITED AND CAUSED A GAS PHASE EXPLOSION AND FIRE. AN EXCESSIVE AMOUNT OF ORGANIC MATERIAL (ABOUT 120 LITERS OF TRIBUTYL PHOSPHATE IN THE FORM OF URANYL NITRATE ADDUCT) HAD BEEN UNINTENTIONALLY TRANSFERRED, ALONG WITH NORMAL PROCESS MATERIAL, THROUGH TWO EVAPORATORS TO THE DENITRATOR. DURING HEATING OF THE DENITRATOR CONTENTS, THE ORGANIC MATERIAL DECOMPOSED RAPIDLY BETWEEN 170C AND 210C, EMITTING COMBUSTIBLE AND NONCOMBUSTIBLE GASES THAT EJECTED THE DENITRATOR CONTENTS INTO THE DENITRATOR ROOM. THE GAS COLLECTED AT THE CEILING IN THE ROOM AND IGNITED WITH A LOW EXPLOSIVE FORCE. TWO EMPLOYEES SUSTAINED MINOR INJURIES, AND THERE WAS ABOUT \$230,000 DAMAGE TO THE BUILDING AND EQUIPMENT.
- 19-2-1-135      **RISKS IN TRANSPORTING MATERIALS FOR VARIOUS ENERGY INDUSTRIES**  
 BROADS, R. E. + JOHNSON, J. F.  
 BATTTELLE PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.  
 BATTTELLE PACIFIC NORTHWEST LABORATORIES (PNL) IS CURRENTLY CONDUCTING A RESEARCH PROGRAM SPONSORED BY THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION TO ASSESS THE RISKS IN TRANSPORTING ENERGY MATERIALS. THE OBJECTIVE OF THIS PROGRAM IS TO USE A CONSISTENT METHODOLOGY TO ASSESS THE RISKS OF TRANSPORTING MATERIALS FOR ENERGY SYSTEMS WHICH ARE CURRENTLY IN USE AND FOR THOSE WHICH ARE BEING DEVELOPED OR PLANNED FOR THE FUTURE. THIS ARTICLE BRIEFLY REVIEWS THE BACKGROUND OF RISK ASSESSMENT, DESCRIBES THE RISK ASSESSMENT METHODOLOGY USED IN PNL'S TRANSPORTATION SAFETY STUDIES PROGRAM, SUMMARIZES THE WORK TO DATE, AND OUTLINES FUTURE PROGRAMS.
- 19-2-1-153      **ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY**  
 BUCHANAN, J. E.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 A TOPICAL MEETING ON THERMAL REACTOR SAFETY SPONSORED BY THE AMERICAN NUCLEAR SOCIETY WAS HELD IN SUN VALLEY, IDAHO, JULY 31-AUG. 4, 1977. PRESENTED WERE 120 PAPERS ON THE FOLLOWING TOPICS - PROBABILISTIC METHODS, COMMUNICATING REACTOR SAFETY, REACTOR SAFETY RESEARCH AND LICENSING, PLANT DIAGNOSTICS, OPERATION, RESPONSE TO ACCIDENT CONDITIONS, PREVENTION, AND MITIGATION OF ACCIDENT CONDITIONS, UNDERSTANDING THE NUCLEAR STEAM SUPPLY SYSTEM (NSSS) RESPONSE TO DESIGN BASIS EVENTS, CONTAINMENT AND PLANT DESIGN AGAINST EXTERNAL HAZARDS, AND FUEL

BEHAVIOR, FISSION PRODUCT BEHAVIOR, AND RESEARCH ON CORE MELTDOWN. ONE THIRD OF THE PAPERS WERE ON THE MSS RESPONSE TO DESIGN BASIS EVENTS, WITH EMPHASIS ON THE LOSS OF COOLANT ACCIDENT. A BRIEF REVIEW OF THE MEETING HIGHLIGHTS IS PRESENTED.

- 19-2-2-160 THE REFLOODING PHASE OF THE LOCA IN PWRs II. REWETTING AND LIQUID ENTRAINMENT  
ELIAS, E. \* YADIGAROGU, G.  
UNIVERSITY OF CALIFORNIA AT BERKELEY, BERKELEY, CALIF.  
SURFACE REWETTING AND LIQUID DROPLET ENTRAINMENT PLAY AN IMPORTANT ROLE IN THE ANALYSIS OF THE REFLOODING PHASE OF THE LOSS OF COOLANT ACCIDENT IN PRESSURIZED WATER REACTORS. THE DEFINITIONS AND THE VARIOUS INTERPRETATIONS GIVEN TO THE REWETTING TEMPERATURE AND THE REWETTING MECHANISMS OF THE FUEL RODS ARE DISCUSSED. PUBLISHED MODELS OF THE AXIAL CONDUCTION CONTROLLED REWETTING PROCESS INCLUDE ONE DIMENSIONAL SOLUTIONS IN TWO AXIAL REGIONS, ONE DIMENSIONAL SOLUTIONS IN THREE AXIAL REGIONS WITH OR WITHOUT PRECOOLING, ONE AND TWO DIMENSIONAL NUMERICAL DIFFERENCE TECHNIQUES USING TEMPERATURE DEPENDENT HEAT TRANSFER COEFFICIENTS, AND ANALYTICAL TWO DIMENSIONAL SOLUTIONS. THE BASIC PHYSICAL ASSUMPTIONS AND THE NUMERICAL VALUES ASSIGNED TO THE VARIOUS PARAMETERS, AS WELL AS EMPIRICAL REWETTING CORRELATIONS, ARE DISCUSSED. THE PHYSICAL MECHANISMS FOR LIQUID DROPLET ENTRAINMENT AND ANALYTICAL FORMULATIONS OF THE CRITICAL GAS VELOCITY AND OF THE DROPLET DIAMETER AT THE ONSET OF ENTRAINMENT ARE REVIEWED.
- 19-2-2-176 LWR FUEL BEHAVIOR RESEARCH IN THE FEDERAL REPUBLIC OF GERMANY  
FISCHER, M. \* OSBORNE, M. F.  
GESELLSCHAFT FÜR KERNFORSCHUNG, KARLSRUHE, FEDERAL REPUBLIC OF GERMANY  
CONCURRENT WITH THE DEVELOPMENT IN THE FEDERAL REPUBLIC OF GERMANY OF LARGE LIGHT WATER REACTORS FOR ELECTRIC POWER PRODUCTION, A BROAD PROGRAM FOR INVESTIGATING THE SAFETY ASPECTS OF LARGE POWER REACTORS HAS BEEN ESTABLISHED. THIS REVIEW IS CONCERNED SPECIFICALLY WITH THE BEHAVIOR OF THE FUEL RODS AND BUNDLES UNDER VARIOUS ACCIDENT CONDITIONS, SUCH AS A LOSS OF COOLANT ACCIDENT, AN ANTICIPATED TRANSIENT WITHOUT SCRAM, AND A POWER COOLANT MISMATCH. THE PROPERTIES AND DEFORMATION CHARACTERISTICS OF THE ZIRCALOY CLADDING DURING TEMPERATURE TRANSIENTS IN STEAM ARE INVESTIGATED, ESPECIALLY WITH RESPECT TO THEIR INFLUENCE ON ROD FAILURE (RESULTING IN FISSION PRODUCT RELEASE) AND POSTSHUTDOWN COOLABILITY (WHICH IS IMPORTANT IN AVOIDING CORE MELTDOWNS). EXPERIMENTAL AND THEORETICAL EFFORTS ARE CLOSELY COORDINATED, WITH THE OBJECTIVE BEING THE DEVELOPMENT OF THE VERIFIED ANALYTICAL MODELS NEEDED TO RELIABLY PREDICT FUEL BEHAVIOR UNDER ANY SPECIFIC SET OF CONDITIONS OR SEQUENCE OF EVENTS.
- 19-2-4-130 EFFECT OF ENGINEERED SAFETY FEATURES ON THE RISK OF HYPOTHETICAL LMFBR ACCIDENTS  
CYRULSKIS, P.  
BATTELLE COLUMBUS LABORATORIES, COLUMBUS, OHIO  
THE RISKS OF HYPOTHETICAL CORE DISRUPTIVE ACCIDENTS IN LIQUID METAL COOLED FAST BREEDER REACTORS WHICH INVOLVE MELT THROUGH OF THE REACTOR VESSEL ARE COMPARED FOR TWO PLANT DESIGNS - ONE DESIGN WITHOUT SPECIFIC PROVISIONS TO ACCOMMODATE SUCH AN ACCIDENT AND THE OTHER DESIGN WITH AN EX-VESSEL CORE CATCHER AND A CAVITY HOT LINER. THE APPROACH TO RISK ANALYSIS USED IS THAT DEVELOPED IN THE REACTOR SAFETY STUDY (WASH-1400). SINCE THE PROBABILITY OF OCCURRENCE OF SUCH AN EVENT HAS NOT BEEN EVALUATED, HOWEVER, INSIGHT INTO THE POTENTIAL RISK IS GAINED ONLY ON A RELATIVE BASIS. THE PRINCIPAL CONCLUSIONS OF THIS STUDY ARE - (1) ADDING A CORE CATCHER HOT LINER REDUCES THE PROBABILITY OF ACCIDENTS HAVING MAJOR CONSEQUENCES, (2) THE DEGREE TO WHICH HOT LINER CORE CATCHER SYSTEMS CAN REDUCE THE RISK OF MELT THROUGH ACCIDENTS IS LIMITED BY THE FAILURE PROBABILITY OF THESE SYSTEMS, (3) FRACTIONAL RADIOACTIVE RELEASES TO THE ENVIRONMENT IN THE LIQUID METAL COOLED FAST BREEDER REACTOR ACCIDENTS CONSIDERED ARE COMPARABLE TO THOSE FROM THE LIGHT WATER REACTORS EVALUATED IN WASH-1400, (4) SINCE SODIUM CONCRETE REACTIONS ARE A DOMINANT DRIVING FORCE DURING THE ACCIDENT, THE INTEGRITY OF THE CAVITY LINER IS AS IMPORTANT AS THE FUNCTION OF THE CORE CATCHER, (5) THERE MAY BE OTHER ACCIDENTS OR PATHS TO RADIOACTIVE RELEASES THAT ARE NOT AFFECTED BY THE ADDITION OF A HOT LINER CORE CATCHER.
- 19-2-5-205 PARAMETERIZATIONS FOR RESUSPENSION AND FOR WET AND DRY DEPOSITION OF PARTICLES AND GASES FOR USE IN RADIATION DOSE CALCULATIONS  
SLINN, W. G. W.  
OREGON STATE UNIVERSITY, CORVALLIS, OREG.  
SOME COMMENTS ARE PRESENTED ABOUT METHODS AND ACCURACIES OF PARAMETERIZING PRECIPITATION SCAVENGING, DRY DEPOSITION, AND RESUSPENSION FOR USE IN BOTH ACCIDENTAL AND LONG TERM AVERAGE RADIATION DOSE CALCULATIONS. THE PRESENTATION EMPHASIZES WET, DRY, AND RESUSPENSION VELOCITIES. THE ACCURACIES OF THESE PARAMETERIZATIONS DECREASE WITH ATTEMPTS TO OBTAIN INCREASING TIME RESOLUTION. ANNUAL AVERAGE ESTIMATES FOR THE WET DEPOSITION VELOCITY ARE KNOWN TO WITHIN A FACTOR OF ABOUT 2 TO 5. SIMILARLY, ANNUAL AVERAGE ESTIMATES FOR THE DRY DEPOSITION VELOCITY ARE KNOWN TO WITHIN A FACTOR OF ABOUT 2 TO 5, EXCEPT WHEN THEY APPLY TO SUBMICRON PARTICLES AND SLIGHTLY REACTIVE GASES DEPOSITING ON VEGETATION. IN THESE CASES THERE IS AN ORDER OF MAGNITUDE UNCERTAINTY OR MORE, ASSOCIATED WITH THE

RESUSPENSION VELOCITY PARAMETERIZATION OF RESUSPENSION, THERE ARE MANY ORDERS OF MAGNITUDE UNCERTAINTY. FURTHER RESEARCH AND ALTERNATIVE FORMULATIONS FOR DOSE CALCULATIONS ARE ENCOURAGED AND ONE ALTERNATIVE IS OUTLINED.

- 19-3-5-220 EFFECTS OF RAINSTORMS AND RUNOFF ON CONSEQUENCES OF ATMOSPHERIC RELEASES FROM NUCLEAR REACTOR ACCIDENTS  
HITCHIE, L. T. + BROWN, W. D. + WAYLAND, J. R.  
SANDIA LABORATORIES, ALBUQUERQUE, N. MEX.  
A PRELIMINARY MODEL DESCRIBING THE EFFECTS OF WASHOUT AND RUNOFF ON THE CONSEQUENCES OF A NUCLEAR REACTOR ACCIDENT IS PRESENTED. THE MOST IMPORTANT NEW FEATURE OF THIS STRUCTURED MODEL RELATIVE TO THE MODEL DESCRIBED IN REPORT WASH-1400 IS THE SPATIAL STRUCTURE OF RAINSTORMS AND RUNOFF CONSISTING OF FOUR LEVELS OF RAIN INTENSITY THAT ARE NORMALIZED BY RAIN-GAUGE DATA. THE PREDICTED CONCENTRATIONS OF RADIOACTIVITY AND RESULTANT HEALTH CONSEQUENCES OF THE STRUCTURED MODEL ARE COMPARED TO THOSE OF THE MODEL IN WASH-1400 FOR SIMPLIFIED RAINSTORMS WITH FIXED METEOROLOGICAL CONDITIONS AND FOR AN ACTUAL RAINSTORM. RUNOFF AND THE SPATIAL STRUCTURE OF THE RAIN IN THE NEW MODEL CAN RESULT IN HEALTH CONSEQUENCES THAT ARE SIGNIFICANTLY DIFFERENT FROM THOSE OF THE WASH-1400 MODEL.
- 19-3-1-269 ENERGY INVESTMENT IN NUCLEAR POWER PLANTS  
MAYS, G. T.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE ENERGY INVESTMENT IN TERMS OF ELECTRICAL AND THERMAL ENERGY REQUIREMENTS FOR NUCLEAR POWER PLANTS IS EXAMINED. THE TOTAL LIFETIME ENERGY INPUTS REQUIRED FOR A 1000-MW(E) PLANT BASED ON A 30-YEAR PLANT LIFETIME AND 0.75 PLANT FACTOR ARE PRESENTED FOR SEVERAL PRESSURIZED WATER REACTOR (PWR) AND BOILING WATER REACTOR (BWR) SYSTEMS, TWO HIGH TEMPERATURE GAS COOLED REACTOR (HTGR) SYSTEMS, AND ONE HEAVY WATER REACTOR (HWR) SYSTEM. THE ENERGY ANALYSES REVIEWED HERE HAVE DEMONSTRATED THAT THE ENERGY EXPENDITURES FOR THE VARIOUS REACTOR SYSTEMS ARE VERY MUCH LESS THAN THE ENERGY PRODUCED BY THE REACTORS AND THAT THE INITIAL ENERGY INVESTMENTS ARE RECOVERED IN A SHORT TIME AFTER STARTUP SEVERAL MONTHS TO 2 YEARS. THE ENERGY REQUIREMENTS ASSOCIATED WITH THE INDIVIDUAL PROCESSES, SUCH AS MINING, ENRICHMENT, CONSTRUCTION, AND WASTE DISPOSAL, ARE TABULATED FOR TWO DIFFERENT FUEL CYCLES FOR A PWR AND A BWR. THE ENRICHING PROCESS IS BY FAR THE LARGEST COMPONENT OF THE ELECTRICAL REQUIREMENTS, REPRESENTING 85 TO 90 PERCENT OF THE TOTAL ELECTRICAL ENERGY INVESTMENT. THE ENERGY USED IN CONSTRUCTING AND OPERATING THE REACTOR CONSTITUTES THE LARGEST SINGLE INVESTMENT OF THERMAL ENERGY, REPRESENTING 50 PERCENT OF THE TOTAL THERMAL ENERGY REQUIREMENTS. RESULTS OF SEVERAL ANALYSES ARE EXAMINED AND COMPARISONS MADE BETWEEN NUCLEAR POWER PLANTS, A COAL PLANT, AND A SOLAR THERMAL CONVERSION PLANT.
- 19-3-1-281 FIFTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING  
COTTRELL, W. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE SUMMARIZES THE FIFTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION'S DIVISION OF REACTOR SAFETY RESEARCH AND HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., NOV. 7-11, 1977. PRESENTED AT THE MEETING WERE 126 PAPERS DIVIDED AMONG THE FOLLOWING FIVE RESEARCH PROGRAM AREAS - (1) LOSS OF COOLANT ACCIDENT STUDIES, (2) METALLURGY AND MATERIALS RESEARCH PROGRAM, (3) FUEL BEHAVIOR RESEARCH PROGRAM, (4) ANALYSES DEVELOPMENT PROGRAM, AND (5) REACTOR OPERATIONAL SAFETY PROGRAM. IN ADDITION, THE MEETING INCLUDED NUMEROUS WORKSHOPS ON SELECTED TOPICS. AMONG THE MANY PRESENTATIONS WERE SIX INVITED PAPERS ON SAFETY RESEARCH IN SEVERAL FOREIGN COUNTRIES AND NUMEROUS PAPERS ON RESEARCH SPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE. FROM ALL THIS WORK, THE EVIDENCE CONTINUES TO MOUNT REGARDING THE EXTENT OF THE CONSERVATIVE APPROACH TO NUCLEAR SAFETY THAT IS TAKEN IN THIS COUNTRY.
- 19-3-1-292 WATER REACTOR SAFETY RESEARCH PROGRAM - APPLICATION OF RESEARCH RESULTS  
TONG, L. S.  
NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
(EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED FROM A PAPER PRESENTED BY DR. L. S. TONG AT THE FIFTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING (SEE PRECEDING ARTICLE). IT DESCRIBES THE PHILOSOPHY BEHIND THE NRC WATER REACTOR SAFETY RESEARCH PROGRAM, WHILE HIGHLIGHTING THE ACCOMPLISHMENTS OVER THE PAST YEAR (NOMINALLY FY 1977). FOR PERSONS DESIRING MORE BACKGROUND INFORMATION, DR. TONG COAUTHORED (WITH G. L. BENNETT) A COMPREHENSIVE REVIEW OF THE NRC WATER REACTOR SAFETY RESEARCH PROGRAM, WHICH WAS PUBLISHED IN NUCLEAR SAFETY, 18(1) - 1-39 (1977).)
- 19-3-1-297 NUCLEAR STANDARDS IN THE FEDERAL REPUBLIC OF GERMANY - THE DIN NUCLEAR STANDARDS COMMITTEE  
BECKER, K.  
FEDERAL REPUBLIC OF GERMANY  
WITHIN THE NUCLEAR TECHNOLOGY STANDARDS COMMITTEE (NKE) OF THE GERMAN STANDARDS INSTITUTE (DIN), ABOUT 40 WORKING GROUPS WITH SOME 400 EXPERTS, REPRESENTING LICENSING AND INSPECTION AUTHORITIES, MANUFACTURERS, UTILITIES, AND OTHER INTERESTED PARTIES, HAVE DEVELOPED ALMOST 100 NUCLEAR STANDARDS AND DRAFT

STANDARDS. THE MAIN AREAS OF ACTIVITY ARE COMMUNICATIVE PRINCIPLES, RADIATION PROTECTION TECHNOLOGY, THE FUEL CYCLE, AND, MOST IMPORTANT, REACTOR SAFETY AND TECHNOLOGY. EFFORTS IN THIS AREA ARE CLOSELY CONNECTED WITH THOSE OF THE MORE RECENTLY ESTABLISHED SEMIGOVERNMENTAL NUCLEAR TECHNOLOGY BOARD (NTA), WHICH IS IN CHARGE OF COORDINATING AND APPROVING BASIC NATIONAL REACTOR SAFETY STANDARDS. INTERNATIONAL NRE ACTIVITIES FOCUS ON SERVING AS THE NATIONAL COUNTERPART FOR THE INTERNATIONAL ORGANIZATION FOR STANDARDIZATION'S (ISO'S) NUCLEAR TECHNOLOGY COMMITTEE (TC95), WHOSE SECRETARIAT HAS RECENTLY BEEN TRANSFERRED FROM THE AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI) TO DIN/NRE. THE SCOPE, PROGRESS, AND PROBLEMS OF NUCLEAR STANDARDS WORK DURING THE PAST FEW YEARS IN THE FEDERAL REPUBLIC OF GERMANY ARE BRIEFLY DESCRIBED.

19-3-2-305 PROBABILITY AND RISK ASSESSMENT - THE SUBJECTIVISTIC VIEWPOINT AND SOME SUGGESTIONS  
 APOSTOLAKIS, G.  
 UNIVERSITY OF CALIFORNIA, LOS ANGELES, CALIF.

THE PURPOSE OF THIS PAPER IS TO INVESTIGATE THE PHILOSOPHICAL BASIS FOR THE USE OF THE CONCEPT OF PROBABILITY IN RISK ASSESSMENT STUDIES. IT IS ARGUED THAT THE SUBJECTIVISTIC INTERPRETATION OF PROBABILITY (I.E., PROBABILITY AS A MEASURE OF DEGREE OF BELIEF) IS THE APPROPRIATE FRAMEWORK FOR SUCH STUDIES. THE RELATIONSHIP BETWEEN RELATIVE FREQUENCY AND SUBJECTIVE PROBABILITY IS EXAMINED, AND THE IMPORTANT CONCEPTS OF COHERENCE AND EXCHANGEABILITY ARE DISCUSSED. FINALLY, THE IMPLICATIONS OF ADOPTING THE SUBJECTIVISTIC INTERPRETATION ARE INVESTIGATED, AND SOME SUGGESTIONS STEMMING FROM THE REQUIREMENT OF COHERENCE ARE GIVEN, WHICH ARE USEFUL WHEN LOW PROBABILITIES OR FREQUENCIES ARE ASSESSED.

19-3-2-316 CLINCH RIVER BREEDER REACTOR PLANT SAFETY STUDY  
 PIPER, H. B. + CONRADI, L. L. + BUHL, A. R.  
 WOOD, P. J. + LEAVER, D. E. W.  
 PROJECT MANAGEMENT CORPORATION, OAK RIDGE, TENN. / WESTINGHOUSE ELECTRIC CORPORATION, MONROEVILLE, PA. / SCIENCE APPLICATIONS, INC., PALO ALTO, CALIF.

THIS ARTICLE PRESENTS A REVIEW AND DISCUSSION OF THE OBJECTIVES, METHODS, TECHNIQUES, AND RESULTS OF A SAFETY STUDY THAT WAS CONDUCTED FOR THE CLINCH RIVER BREEDER REACTOR (CRBR) PLANT. THE OBJECTIVES OF THE STUDY WERE (1) TO PROVIDE A REALISTIC ASSESSMENT OF ACCIDENT RISKS TO THE PUBLIC ASSOCIATED WITH OPERATION OF THE CRBR, (2) TO PLACE THOSE IDENTIFIED RISKS IN PERSPECTIVE WITH OTHER LOCAL SOCIETAL RISKS, AND (3) TO AID IN DETERMINING WHETHER ACCIDENT RISKS FROM THE CRBR ARE COMPARABLE TO THOSE OF PREVIOUSLY LICENSED REACTORS.

ACHIEVEMENT OF THE OBJECTIVES OF THIS STUDY HAS REQUIRED IDENTIFICATION OF SIGNIFICANT CONTRIBUTORS TO RISK IN A LOGICAL AND ORDERLY MANNER. CONSIDERATION OF A COMPREHENSIVE SET OF ACCIDENT INITIATORS, INCLUSION OF EXPERIENCE DATA, RELIANCE ON PROVEN METHODS AND TECHNIQUES, EVALUATION OF A WIDE RANGE OF RADIONUCLIDE RELEASES AND ASSOCIATED HEALTH EFFECTS, AND UTILIZATION OF EXPERIENCED RISK ANALYSTS ARE THE SALIENT ELEMENTS EMPLOYED IN THE SYSTEMATIC APPROACH TO THIS STUDY. THIS, TOGETHER WITH HEAVY RELIANCE ON EXPERIENCE GAINED DURING YEARS OF LWR DESIGN, LICENSING, AND OPERATION, PROVIDES REASONABLE ASSURANCE THAT THE STUDY OBJECTIVES HAVE BEEN ACHIEVED.

THE RESULTS OF THE CRBR PLANT SAFETY STUDY INDICATE THAT THE RISK ARISING FROM THE OPERATION OF THE CRBR PLANT IS SMALL IN COMPARISON TO OTHER LOCAL SOCIETAL RISKS AND THAT THE RISK FROM THE CRBR PLANT IS COMPARABLE TO THE RISK FROM PREVIOUSLY LICENSED NUCLEAR POWER PLANTS, AS IDENTIFIED IN THE REACTOR SAFETY STUDY.

19-3-3-330 RELIABILITY OF D-C POWER SUPPLIES  
 HAGEN, E. W.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THE RELIABILITY OF THE D-C POWER SYSTEM IN NUCLEAR PLANTS AND THE ADEQUACY OF THE NUCLEAR REGULATORY COMMISSION (NRC) REQUIREMENTS FOR THIS SYSTEM HAVE BEEN QUESTIONED BY SAFETY ANALYSTS. CONCERN WAS EXPRESSED THAT FAILURE OF THE D-C SYSTEM WOULD CONCURRENTLY ISOLATE THE PLANT FROM THE EXTERNAL A-C POWER GRID, THE ON SITE EMERGENCY A-C SYSTEM, THE CONTROL FUNCTIONS ASSOCIATED WITH TURBINE DRIVEN PUMPS, AND ALL PROCESS INDICATION AND RECORDING FUNCTIONS, WITH THE RESULT THAT REMOVAL OF DECAY HEAT WITHOUT FUEL AND/OR CONTAMINATED DAMAGE MIGHT NOT BE POSSIBLE. THIS ARTICLE OUTLINES THE POSTULATED SCENARIO, REVIEWS THE TECHNICAL BACKGROUND ON THE DESIGN AND CRITERIA FOR D-C POWER SYSTEMS AS WELL AS THE OPERATING EXPERIENCE WITH SUCH SYSTEMS, AND PRESENTS THE NRC STAFF'S VIEW AND POSITION. IT FURTHER DELINEATES THE SAFETY SIGNIFICANCE OF SUCH FAILURES, THE BASIS FOR THE STAFF'S VIEW ON THE LIKELIHOOD OF THE POSTULATED SCENARIO, AND A PROPOSAL FOR ADDITIONAL TECHNICAL STUDIES.

- 19-3-4-339 THE SODIUM LOOP SAFETY FACILITY  
GARTSIDE, C. H. + BEZELLA, W. A. + THOMPSON, D. H.  
LENNOX, D. H. + TESSIER, J. H.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.  
AS THE ONLY FACILITY IN THE UNITED STATES CAPABLE OF CONDUCTING SAFETY TESTS ON RELATIVELY LARGE, FULL LENGTH LIQUID METAL FAST BREEDER REACTOR (LMFBR) FUEL ASSEMBLIES AT STEADY STATE POWER LEVELS, THE SODIUM LOOP SAFETY FACILITY (SLSF) IS AN IMPORTANT PART OF THE LMFBR SAFETY PROGRAM. THE IN PILE EXPERIMENTS THAT BEGAN IN SEPTEMBER 1975 IN THE ENGINEERING TEST REACTOR (ETR) ARE PROVIDING DATA NEEDED FOR ASSESSMENT OF CRITICAL SAFETY QUESTIONS. PRESENTED IN THIS ARTICLE ARE DESCRIPTIONS OF THE FACILITY, ITS EXPERIMENTAL CAPABILITIES, AND THE OVERALL RESEARCH PROGRAM.
- 19-3-5-356 HIGH LEVEL NUCLEAR WASTE MANAGEMENT IN THE UNITED STATES - A TIME FOR DECISIONS  
MALARO, J. C.  
NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
SINCE THE LATE 1950S, KNOWLEDGEABLE EXPERTS HAVE INSISTED THAT TECHNOLOGY EXISTS FOR THE SAFE DISPOSAL OF HIGH LEVEL RADIOACTIVE WASTES BUT THAT A MEANS FOR SAFE DISPOSAL HAS YET TO BE DEMONSTRATED. SAFE DISPOSAL OF THESE WASTES IS THE PRINCIPAL PUBLIC CONCERN ASSOCIATED WITH THE USE OF NUCLEAR POWER. THE ABILITY OF INDUSTRY OR GOVERNMENT TO SOLVE THIS PROBLEM HAS BEEN QUESTIONED BY MANY. SOME CRITICS ARE DEMANDING THAT LICENSING OF NUCLEAR POWER PLANTS BE SUSPENDED UNTIL SAFE AND EFFECTIVE DISPOSAL OF HIGH LEVEL RADIOACTIVE WASTE HAS BEEN DEMONSTRATED. AN INTENSE, COORDINATED, AND WELL FUNDED FEDERAL EFFORT TO SOLVE THIS PROBLEM IS UNDER WAY. NOW SOME DECISIONS ARE NEEDED.
- 19-3-6-369 THREE YEARS OF PHENIX OPERATION  
MEGY, J. M. P. + CONTE, F. + GODDET, J. L.  
COMMISSARIAT A L'ENERGIE ATOMIQUE, SCALAY, FRANCE  
PHENIX IS A 250-MW(E) SODIUM COOLED PROTOTYPE FAST BREEDER REACTOR, WHICH WAS BUILT BY THE FRENCH ATOMIC ENERGY COMMISSION AND ELECTRICITE DE FRANCE AND HAS BEEN IN COMMERCIAL OPERATION SINCE THE SUMMER OF 1974. THIS ARTICLE REVIEWS THE OPERATIONAL HISTORY OF PHENIX, WHICH MAY BE DIVIDED INTO TWO PHASES. THE FIRST 2 YEARS, BEING RELATIVELY TROUBLE FREE, PERMITTED THE AMASSING OF IMPRESSIVE OPERATIONAL STATISTICS. DURING THE THIRD YEAR, WHEN COMPONENT FAILURES WERE EXPERIENCED AND WHEN THE REACTOR WAS OPERATED WITH ONE LOOP OUT OF SERVICE, VALUABLE INFORMATION ON PLANT MAINTENANCE WAS OBTAINED. OPERATING DATA ARE ALSO GIVEN FOR THE FIRST 3 YEARS OF OPERATION.
- 19-4-1-411 FRENCH SAFETY STUDIES OF PRESSURIZED WATER REACTORS  
RINGOT, C.  
ADJOINT AU CHES DU SERVICE D'ETUDES TECHNIQUES DE SURETE NUCLEAIRE FRANCE  
SINCE THE FRENCH NUCLEAR PROGRAM IS BASED MAINLY ON PRESSURIZED WATER REACTORS (PWRs), WITH 25,000 MW(E) UNDER CONSTRUCTION, MOST OF THE NUCLEAR RESEARCH AND DEVELOPMENT IN FRANCE IS DEVOTED TO THE SPECIFIC SAFETY PROBLEMS OF PWRs. THIS ARTICLE IS A BRIEF REVIEW OF THAT PROGRAM, WHICH IS CURRENTLY FUNDED AT ABOUT \$35 MILLION (IN U.S. DOLLARS) PER YEAR. THE PRINCIPAL AREAS OF RESEARCH, AS DISCUSSED HERE, INCLUDE FUEL ELEMENT BEHAVIOR, THE PRIMARY SYSTEM, PROBABILITY STUDIES, AND RADIOLOGICAL SAFETY STUDIES.
- 19-4-1-427 AAS EXECUTIVE CONFERENCE ON SAFEGUARDS  
JENKINS, J. D.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE AMERICAN NUCLEAR SOCIETY EXECUTIVE CONFERENCE ON SAFEGUARDS IS REVIEWED. THE MEETING, WHICH WAS HELD ON OCT. 16-19, 1977, AT HYANNIS, CAPE COD, MASS., FEATURED PAPERS ON INTERNATIONAL SAFEGUARDS BY BOTH U.S. GOVERNMENT REPRESENTATIVES AND A NUMBER OF FOREIGN SPEAKERS. U.S. DOMESTIC SAFEGUARDS ISSUES, WHICH INCLUDED PROBLEMS INVOLVING PHYSICAL PROTECTION AND MATERIAL CONTROL AND ACCOUNTABILITY, WERE ALSO DISCUSSED BY REPRESENTATIVES FROM THE NUCLEAR REGULATORY COMMISSION AND INDUSTRY. IT WAS GENERALLY AGREED BY ALL SPEAKERS ADDRESSING THE INTERNATIONAL SAFEGUARDS ISSUE THAT MULTINATIONAL TREATIES AND CONTROLS (AS OPPOSED TO UNILATERAL AD HOC AGREEMENTS) WERE THE PREFERRED ROUTE TO PROLIFERATION RESISTANT NUCLEAR COMMERCE AND THAT THE INTERNATIONAL ATOMIC ENERGY AGENCY WAS THE LOGICAL BODY TO ADMINISTER AND OVERSEE THE REQUIRED INSPECTIONS. THERE WAS SOME DIVERGENCE OF OPINION BETWEEN THE FOREIGN AND U.S. PARTICIPANTS ON THE ISSUE OF PLUTONIUM RECYCLING, THE FORMER GROUP ASSUMING THAT THE INTERNATIONAL SAFEGUARDS SYSTEM WOULD HAVE TO CONFRONT THE PROBLEMS ASSOCIATED WITH PLUTONIUM RECYCLING DIRECTLY, AND THE U.S. SPEAKERS HELD OUT THE HOPE OF A LESS PROLIFERATION PRONE, AND HENCE MORE EASILY SAFEGUARDED, FUEL CYCLE. ON DOMESTIC SAFEGUARDS TOPICS, SPEAKERS FROM THE NUCLEAR REGULATORY COMMISSION AND THE DEPARTMENT OF ENERGY DESCRIBED SPECIFIC PROGRAMS UNDER WAY TO COUNTER AND CONTROL SUBNATIONAL TERRORIST THREATS AND TO ENSURE ACCURATE MATERIAL ACCOUNTING AND CONTROL. INDUSTRY SPEAKERS ADDRESSING DOMESTIC SAFEGUARDS ACQUIESCED TO THE REALITY OF THE PROBLEM BUT POINTED OUT THE NEED FOR WELL DEFINED PERFORMANCE CRITERIA AND STATIC REGULATORY GUIDELINES.

- 19-4-1-433 NRC SAFETY RESEARCH PROGRAM - A CRITIQUE AND AN EXTENSION  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EDITOR'S NOTE - TWO RECENT REPORTS ARE UNIQUELY CONCERNED WITH THE NUCLEAR SAFETY RESEARCH PROGRAM OF THE NUCLEAR REGULATORY COMMISSION (NRC) IN THAT BOTH ARE IN RESPONSE TO CONGRESSIONAL MANDATES. ONE REPORT, IN DECEMBER 1977, IS BY THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS AND IS ENTITLED REVIEW AND EVALUATION OF THE NUCLEAR REGULATORY COMMISSION SAFETY RESEARCH PROGRAM, THE SECOND REPORT, DRAFTED EARLY THIS YEAR, IS BY THE NRC STAFF AND IS ENTITLED PLAN FOR RESEARCH TO IMPROVE THE SAFETY OF LIGHT WATER NUCLEAR POWER PLANTS. ALTHOUGH THE GENESSES OF THE TWO REPORTS ARE SOMEWHAT DIFFERENT, TO SOME EXTENT BOTH REPORTS ARE CRITIQUES OF THE PRESENT NRC SAFETY RESEARCH PROGRAM, AND THEY BOTH CONTAIN RECOMMENDATIONS FOR ADDITIONAL RESEARCH. HOWEVER, THE LATTER REPORT EMPHASIZES SYSTEM IMPROVEMENTS, ALTHOUGH IT IS RESTRICTED TO LIGHT WATER REACTORS. THIS ARTICLE PRESENTS A BRIEF RESUME OF BOTH DOCUMENTS.
- 19-4-2-440 RESPONSE OF UNIRRADIATED AND IRRADIATED PWR FUEL RODS TESTED UNDER POWER COOLING MISMATCH CONDITIONS  
MACDONALD, P. E. + QUAPP, W. J. + MEHNER, A. S.  
MARTINSON, Z. R. + MCCARDELL, R. K.  
EG&G IDAHO, INC., IDAHO FALLS, IDAHO  
THIS REPORT SUMMARIZES THE RESULTS FROM THE SINGLE ROD POWER COOLING MISMATCH (PCM) AND IRRADIATION EFFECTS (IE) TESTS CONDUCTED TO DATE IN THE POWER BURST FACILITY (PBF) AT THE U.S. DEPARTMENT OF ENERGY'S IDAHO NATIONAL ENGINEERING LABORATORY. THIS WORK WAS PERFORMED FOR THE U.S. NUCLEAR REGULATORY COMMISSION UNDER CONTRACT TO THE DEPARTMENT OF ENERGY. THESE TESTS ARE PART OF THE NUCLEAR REGULATORY COMMISSION'S FUEL BEHAVIOR PROGRAM, WHICH IS DESIGNED TO PROVIDE DATA FOR THE DEVELOPMENT AND VERIFICATION OF ANALYTICAL FUEL BEHAVIOR MODELS THAT ARE USED TO PREDICT FUEL RESPONSE TO ABNORMAL OR POSTULATED ACCIDENT CONDITIONS IN COMMERCIAL LIGHT WATER REACTORS (LWRS). THE MECHANICAL, CHEMICAL, AND THERMAL RESPONSE OF BOTH PREVIOUSLY UNIRRADIATED AND PREVIOUSLY IRRADIATED LWRE TYPE FUEL RODS TESTED UNDER POWER COOLING MISMATCH CONDITIONS IS DISCUSSED. A BRIEF DESCRIPTION OF THE TEST DESIGNS IS PRESENTED. THE RESULTS OF THE PCM THERMAL HYDRAULIC STUDIES ARE SUMMARIZED. PRIMARY EMPHASIS IS PLACED ON THE BEHAVIOR OF THE FUEL AND CLADDING DURING AND AFTER STABLE FILM BOILING.
- 19-4-3-468 SECOND SPECIALISTS MEETING ON REACTOR NOISE  
BOOTH, R. S.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
GATLINBURG, TENN., WAS THE SITE OF THE SECOND SPECIALISTS MEETING ON REACTOR NOISE (SMORN-II) WHICH TOOK PLACE ON SEPT. 19-23, 1977. IN CONTRAST TO SMORN-I WHICH SUCCESSFULLY COVERED THE STATUS OF NOISE ANALYSIS IN BOTH ZERO POWER AND POWER REACTORS, SMORN-II PLACED EMPHASIS ON PRACTICAL APPLICATIONS OF NOISE ANALYSIS FOR THE PURPOSE OF INCREASING THE SAFETY AND AVAILABILITY OF NUCLEAR POWER PLANTS. FIFTY SEVEN PAPERS WERE PRESENTED TO THE 117 DELEGATES AND APPROXIMATELY 30 VISITORS WHO REPRESENTED 25 COUNTRIES AND INTERNATIONAL ORGANIZATIONS. AN IMPORTANT CONCLUSION OF THE CONFERENCE WAS THAT NOISE ANALYSIS TECHNIQUES HAVE PROVED TO BE SUCCESSFUL AND COST EFFECTIVE IN SOLVING SURVEILLANCE, DIAGNOSTIC, AND SAFETY RELATED PROBLEMS OF NUCLEAR POWER STATIONS. EQUALLY IMPORTANT WERE THE NEW AND CHALLENGING APPLICATIONS THAT WERE IDENTIFIED.
- 19-4-4-473 RECENT ADVANCES IN ALTERNATE ECCS STUDIES FOR PRESSURIZED WATER REACTORS  
CHON, W. Y.  
STATE UNIVERSITY OF NEW YORK AT BUFFALO, NEW YORK  
RESEARCH AND DEVELOPMENT WORK ON ALTERNATE METHODS IS CURRENTLY UNDER WAY TO IMPROVE THE PERFORMANCE OF EXISTING EMERGENCY CORE COOLING SYSTEMS (ECCSS) FOR PRESSURIZED WATER REACTORS (PWRs). RECENT ADVANCES IN THIS AREA IN THE UNITED STATES AND ABROAD ARE REVIEWED.
- 19-4-5-486 PLANNING AND VALIDATION OF ENVIRONMENTAL SURVEILLANCE PROGRAMS AT OPERATING NUCLEAR POWER PLANTS  
EICHHOLZ, G. G.  
GEORGIA INSTITUTE OF TECHNOLOGY, ATLANTA, GA.  
THE CONDUCT OF THE OPERATIONAL PHASE OF THE ENVIRONMENTAL SURVEILLANCE PROGRAMS AT NUCLEAR POWER PLANTS ENTAILS A WIDE VARIETY OF ECOLOGICAL STUDIES AND ANALYSES OF LOW LEVEL RADIOACTIVE SAMPLES. UNLESS A CLOSE REIN IS KEPT TO ENSURE THAT SAMPLES ARE REPRESENTATIVE IN NATURE AND COUNTING TIMES AND ACTIVITIES ARE COMMENSURATE WITH THE ACCURACY SOUGHT, MUCH OF THAT WORK MAY BE MEANINGLESS AND MAY MERELY SERVE TO MEET REGULATORY REPORTING REQUIREMENTS.  
IT IS RECOMMENDED THAT AN ACTION LEVEL PROGRAM BE ADOPTED WHEREBY ONLY THE MOST SIGNIFICANT SAMPLES ARE COLLECTED AND ANALYSED DURING ROUTINE OPERATIONS, WITH PROVISIONS TO STEP UP THE FREQUENCY OF SAMPLING AND EXTEND SAMPLE LOCATIONS WHENEVER EFFLUENT RELEASES EXCEED CERTAIN FRACTIONS OF SET LIMITS.

- 19-4-5-497 **RADIOLOGICAL IMPACT OF AIRBORNE EFFLUENTS OF COAL FIRED AND NUCLEAR POWER PLANTS**  
MCBRIDE, J. P. \* MOORE, R. E. \* WITHERSPOON, J. P.  
BLANCO, R. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE RADIOLOGICAL IMPACT OF NATURALLY OCCURRING RADIONUCLIDES IN AIRBORNE EFFLUENTS OF A MODEL COAL FIRED STEAM PLANT (1000 MW(E)) IS EVALUATED, ASSUMING A RELEASE TO THE ATMOSPHERE OF 1 PERCENT OF THE ASH IN THE COAL BURNED, AND COMPARED WITH THE IMPACT OF RADIOACTIVE MATERIALS IN THE AIRBORNE EFFLUENTS OF MODEL LIGHT WATER REACTORS (1000 MW(E)). THE PRINCIPAL EXPOSURE PATHWAY FOR RADIOACTIVE MATERIALS RELEASED FROM BOTH TYPES OF PLANTS IS INGESTION OF CONTAMINATED FOODSTUFFS. FOR NUCLEAR PLANTS, IMMERSION IN THE AIRBORNE EFFLUENTS IS ALSO A SIGNIFICANT FACTOR IN THE DOSE COMMITMENT. ASSUMING THAT THE COAL BURNED CONTAINS 1 PPM URANIUM AND 2 PPM THORIUM TOGETHER WITH THEIR DECAY PRODUCTS AND USING THE SAME IMPACT ANALYSIS METHODS USED IN EVALUATING NUCLEAR FACILITIES, THE MAXIMUM INDIVIDUAL DOSE COMMITMENTS FROM THE COAL PLANT FOR THE WHOLE BODY AND MOST ORGANS (EXCEPT THE THYROID) ARE SHOWN TO BE GREATER THAN THOSE FROM A PRESSURIZED WATER REACTOR AND, WITH THE EXCEPTION OF THE BONE AND BONE MARROW DOSES, LESS THAN THOSE FROM A BOILING WATER REACTOR. WITH THE EXCEPTION OF THE BONE DOSE, THE MAXIMUM INDIVIDUAL DOSE COMMITMENTS FROM THE COAL PLANT ARE LESS THAN THE NUMERICAL DESIGN GUIDELINE LIMITS LISTED IN 10 CFR 50, APPENDIX I, FOR LIGHT WATER REACTORS. POPULATION DOSE COMMITMENTS FROM THE COAL PLANT ARE HIGHER THAN THOSE FROM EITHER NUCLEAR PLANT, EXCEPT FOR THE THYROID DOSE FROM THE BOILING WATER REACTOR.
- 19-4-6-502 **NRC REVIEW OF LICENSED OPERATOR REQUALIFICATION PROGRAMS FOR NUCLEAR POWER PLANTS**  
COOLEY, R. A.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
PRESENTED HERE ARE THE RESULTS OF NUCLEAR REGULATORY COMMISSION (NRC) AUDITS OF THE LICENSED OPERATOR REQUALIFICATION PROGRAMS AT NUCLEAR POWER PLANTS. THE REQUALIFICATION PROGRAMS HAVE BEEN IN EFFECT FOR A LITTLE OVER 3 YEARS. THE RESULTS OF THE AUDITS CONDUCTED BY THE OPERATOR LICENSING BRANCH AND THE OFFICE OF INSPECTION AND ENFORCEMENT ARE DISCUSSED. THE PROGRAMS HAVE IMPROVED DURING THIS 3-YEAR PERIOD AND, IN THE OPINION OF MANY, ARE BENEFICIAL TO THE NUCLEAR INDUSTRY.
- 19-5-1-541 **LIGHT WATER REACTOR SAFETY RESEARCH IN JAPAN**  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS PREPARED BY THE EDITORS OF NUCLEAR SAFETY AND IS BASED ENTIRELY ON SEVERAL REPORTS OF THE JAPANESE WORK THAT HAVE BEEN RECEIVED IN THIS COUNTRY THROUGH THE AGREEMENT BETWEEN THE NUCLEAR REGULATORY COMMISSION AND JAPAN FOR THE EXCHANGE OF INFORMATION ON WATER REACTOR SAFETY RESEARCH. ALTHOUGH WE EXPECT TO PUBLISH AN ARTICLE BY A JAPANESE AUTHOR IN 1979 ON THEIR EXPERIMENTAL RESULTS, THE PRESENT ARTICLE WILL PROVIDE MUCH USEFUL BACKGROUND INFORMATION ON THEIR PROGRAM. TO THE EXTENT POSSIBLE, WE HAVE USED THE PHRASEOLOGY OF THE JAPANESE REPORTS IN DESCRIBING THEIR WORK, OUR THOUGHTS ARE INTRODUCED ONLY AT THE END OF THE ARTICLE UNDER THE SUBHEADING COMMENTARY. THE DOCUMENTS DESCRIBING THE JAPANESE PROGRAM DO NOT GIVE FUNDING LEVELS OR IDENTIFY THE RESPONSIBLE RESEARCH ORGANIZATIONS, EXCEPT FOR THE FACT THAT ALMOST ALL THE WORK IS COORDINATED WITH, OR THROUGH, THE JAPAN ATOMIC ENERGY RESEARCH INSTITUTE. HOWEVER, THE PROGRAMMATIC RESPONSIBILITIES OF VARIOUS JAPANESE RESEARCH ORGANIZATIONS CAN BE INFERRED FROM THE TOPICAL REPORTS THAT WE HAVE RECEIVED AS A PART OF THE EXCHANGE AGREEMENT. THESE DOCUMENTS ARE LISTED IN THE BIBLIOGRAPHY AND ARE DISCUSSED IN GENERAL IN THE COMMENTARY.
- 19-5-1-556 **THE ROLE OF RISK ASSESSMENT IN THE NUCLEAR REGULATORY PROCESS**  
LEVINE, SAUL  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE JUDICIOUS APPLICATION OF RISK ASSESSMENT TECHNIQUES CAN HELP TO REDUCE PRESENT REGULATORY UNCERTAINTIES, AND THE ACCEPTABILITY OF SUCH TECHNIQUES IS GAINING SUPPORT. ALTHOUGH THE APPLICATION OF THESE TECHNIQUES, IN THE MANNER OF REPORT WASH-1400 (THE REACTOR SAFETY STUDY), TO EACH PLANT WOULD BE FORTHRIGHTLY, A PROBABILISTIC APPROACH CAN GUIDE THE DECISION MAKERS INVOLVED IN THE LICENSING PROCESS. SEVERAL EXAMPLES OF THE USE OF A PROBABILISTIC APPROACH ARE GIVEN. THE RISK ASSESSMENT TOOLS WILL BE IMPROVED UNDER A PLAN SUBMITTED TO CONGRESS TO IMPROVE REACTOR SAFETY. THE QUESTION OF ACCEPTABLE RISK CRITERIA WILL BE ADDRESSED IN THE ONGOING NUCLEAR REGULATORY COMMISSION (NRC) RESEARCH PROGRAM. IT IS EXPECTED THAT THE CONTINUED USE OF RISK ASSESSMENT TECHNIQUES WILL HELP TO IMPROVE THE EFFICIENCY AND THE STABILIZATION OF THE REGULATORY PROCESS BY FOCUSING THE ATTENTION OF THE NRC STAFF ON THE IMPORTANT CONTRIBUTORS TO RISK.
- 19-5-2-565 **FRAP FUEL BEHAVIOR COMPUTER CODES**  
OENLBERG, R. N. \* JOHNSTON, W. V. \* DEARIEN, J. A.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C. / EG&G IDAHO, INC., IDAHO FALLS, IDAHO  
THE FUEL ROD ANALYSIS PROGRAM (FRAP) COMPUTER CODES BEING DEVELOPED BY THE NUCLEAR REGULATORY COMMISSION (NRC) ARE REVIEWED. THE FRAP-S (THE STEADY STATE CODE) IS DESIGNED TO

PROVIDE INITIAL CONDITIONS FOR FRAP-T (THE TRANSIENT CODE). THE MODELS CONTAINED IN EACH CODE, THE ABILITY OF THE RECENT VERSIONS OF THE CODES TO PREDICT EXPERIMENTS, AND JUDGMENTS AS TO THE CODES' STRENGTHS AND WEAKNESSES ARE PRESENTED. FUTURE DEVELOPMENT OF THE FRAP-T CODE IS DISCUSSED, AND A LISTING OF POTENTIALLY DESIRABLE MODELS FOR THE NRC TRANSIENT AND STEADY STATE CODES ARE DISPLAYED. THE CONTENT OF THE MATERIAL PROPERTIES PACKAGE (MATERIAL PROPERTIES) IS OUTLINED. THE MODULAR MATPRO IS ACTIVELY LINKED TO BOTH FRAP-T AND FRAP-S TO PROVIDE A WELL DOCUMENTED AND CONSISTENT SET OF MATERIAL PROPERTIES FOR THE FRAP CODES.

- 19-5-2-588 FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-S3  
MARINO, G. P.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
AFTER THE PRECEDING ARTICLE WAS COMPLETED, THE LATEST VERSION OF THE STEADY STATE CODE (FRAP-S3) WAS DEVELOPED AND QUALIFIED. THIS ADDENDUM DESCRIBES THE IMPROVEMENTS IN FRAP-S3 AS WELL AS ITS QUALIFICATION IN A NUMBER OF PERFORMANCE CALCULATIONS. THE STANDARD ERRORS FOR THE CALCULATION OF A NUMBER OF OUTPUT PARAMETERS ARE PRESENTED.
- 19-5-3-590 ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIAL POWER REACTORS  
CUNNINGHAM, G. E. + WELLS, J. E. + LAMBERT, H. E.  
LAWRENCE LIVERMORE LABORATORY, LIVERMORE, CALIF.  
THIS ARTICLE ASSESSES THE VALUE OF SEISMIC TRIP (SEMAN) SYSTEMS ON COMMERCIAL NUCLEAR POWER REACTORS. EXPERIENCES WITH SEISMIC TRIP SYSTEMS ON RESEARCH AND TEST REACTORS ARE REVIEWED AS ARE CURRENT REGULATIONS CONCERNING SEISMIC INSTRUMENTATION ON POWER REACTORS. THE ADVANTAGES AND DISADVANTAGES OF SEISMIC TRIPS ARE DISCUSSED, AND A COMPARATIVE RISK ASSESSMENT IS MADE USING FAULT TREE TECHNIQUES. ALSO EXPLORED IS THE POSSIBILITY OF USING A PRECURSOR SIGNAL FROM AN EARTHQUAKE TO TRIP THE REACTOR BEFORE THE ARRIVAL OF STRONG MOTION.
- 19-5-5-602 SCENARIOS OF CARBON-14 RELEASES FROM THE WORLD NUCLEAR POWER INDUSTRY FROM 1975 TO 2020 AND THE ESTIMATED RADIOLOGICAL IMPACT  
KILLOUGH, G. G. + TILL, J. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE PRESENTS AN ASSESSMENT OF THE RADIATION DOSE TO THE WORLD POPULATION AND THE ASSOCIATED POTENTIAL HEALTH EFFECTS FROM THREE SCENARIOS OF CARBON-14 RELEASES BY THE NUCLEAR INDUSTRY BETWEEN 1975 AND 2020. MEASURES OF HEALTH IMPACT ARE DERIVED FROM SOURCE TERMS THROUGH THE USE OF A MULTICOMPARTMENT MODEL OF THE GLOBAL CARBON CYCLE, DOSE RATE FACTORS BASED ON CARBON-14 SPECIFIC ACTIVITY IN VARIOUS ORGANS OF MAN, AND HEALTH EFFECT INCIDENCE FACTORS RECENTLY RECOMMENDED BY THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION (ICRP). THE THREE SCENARIOS FOR WORLDWIDE CARBON-14 RELEASES CONSIDERED ARE (1) A PESSIMISTIC SCENARIO IN WHICH ALL THE CARBON-14 PROJECTED TO BE PRODUCED IN FUEL CYCLES IS RELEASED, (2) AN OPTIMISTIC SCENARIO THAT ASSUMES A DECONTAMINATION FACTOR OF 100 FOR FUEL REPROCESSING, AND (3) AN INTERMEDIATE SCENARIO THAT SIMULATES A PHASED IMPROVEMENT IN THE EFFLUENT TREATMENT TECHNOLOGY AT REPROCESSING PLANTS. THE ESTIMATES OF CUMULATIVE POTENTIAL HEALTH EFFECTS BASED ON INTEGRATION OVER INFINITE TIME (EFFECTIVELY 46,000 YEARS OR ABOUT 8 HALF LIVES OF CARBON-14) ARE AS FOLLOWS - 110,000 CANCERS AND 75,000 GENETIC EFFECTS FROM THE PESSIMISTIC SCENARIO, 21,000 CANCERS AND 14,000 GENETIC EFFECTS FROM THE OPTIMISTIC SCENARIO, 22,000 CANCERS AND 15,000 GENETIC EFFECTS FROM THE INTERMEDIATE SCENARIO, 100,000 CANCERS AND 68,000 GENETIC EFFECTS FROM THE CARBON-14 FORMED IN NATURE BETWEEN 1975 AND 2020, AND 380,000 CANCERS AND 250,000 GENETIC EFFECTS FROM THE CARBON-14 FORMED BY THE DETONATION OF NUCLEAR EXPLOSIVES FROM 1945 TO 1974. COMPARABLE EFFECTS FROM THE NATURALLY FORMED CARBON-14 IN STEADY STATE IN THE ENVIRONMENT, ALSO INTEGRATED OVER 46,000 YEARS, ARE APPROXIMATELY 56 MILLION CANCERS AND 43 MILLION GENETIC EFFECTS. THESE ESTIMATES ARE BASED ON A WORLD POPULATION THAT IS ASSUMED TO REMAIN STATIONARY AT 12.2 BILLION AFTER 2075.
- 19-5-5-617 RADIOLOGICAL QUALITY OF THE ENVIRONMENT IN THE UNITED STATES, 1977  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM CHAP. 1, INTRODUCTION, SUMMARY, AND CONCLUSIONS, OF A REPORT OF THE SAME TITLE, WHICH WAS PUBLISHED IN SEPTEMBER 1977 BY THE ENVIRONMENTAL PROTECTION AGENCY AS EPA 520/1-009. THE REPORT AND ITS SUMMARY HERE PROVIDE SIGNIFICANT DATA ON DOSE ASSESSMENT FOR EVALUATING THE RADIOLOGICAL QUALITY OF THE ENVIRONMENT.
- 19-5-6-623 NUCLEAR REACTOR OPERATOR LICENSING  
BURSEY, R. J.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE ATOMIC ENERGY ACT OF 1954, WHICH WAS AMENDED IN 1974 BY THE ENERGY REORGANIZATION ACT, ESTABLISHED THE REQUIREMENT THAT INDIVIDUALS WHO HAD THE RESPONSIBILITY OF OPERATING THE REACTORS IN NUCLEAR POWER PLANTS MUST BE LICENSED. SECTION 107 OF THE ACT STATES THE COMMISSION SHALL (1) PRESCRIBE UNIFORM CONDITIONS FOR LICENSING INDIVIDUALS..., (2) DETERMINE THE



QUALIFICATIONS OF SUCH INDIVIDUALS, AND (3) ISSUE LICENSES TO SUCH INDIVIDUALS IN SUCH FORM AS THE COMMISSION MAY PRESCRIBE. THIS ARTICLE DISCUSSES THE TYPES OF LICENSES, THE SELECTION AND TRAINING OF INDIVIDUALS, AND THE ADMINISTRATION OF THE NUCLEAR REGULATORY COMMISSION LICENSING EXAMINATIONS.

- 19-5-6-628 RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN 1976  
DECKER, T. H.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
RELEASES OF RADIOACTIVE MATERIALS IN AIRBORNE AND LIQUID EFFLUENTS FROM COMMERCIAL LIGHT WATER REACTORS DURING 1976 HAVE BEEN COMPILED AND ARE REPORTED HERE. DATA ON SOLID-WASTE SHIPMENTS, AS WELL AS SELECTED OPERATING INFORMATION, ARE INCLUDED. THE REPORT FROM WHICH THIS ARTICLE IS ADAPTED SUPPLEMENTS EARLIER ANNUAL REPORTS ISSUED BY THE FORMER ATOMIC ENERGY COMMISSION (NOW DOE) AND THE NUCLEAR REGULATORY COMMISSION. THE 1976 RELEASE DATA ARE COMPARED WITH THE RELEASES OF PREVIOUS YEARS IN TABULAR FORM. IN ALL CASES THE TOTAL RELEASES WERE BELOW THE LIMITS SET FORTH IN APPLICABLE REGULATIONS AND IN THE TECHNICAL SPECIFICATIONS FOR EACH PLANT.
- 19-6-1-671 THE NRC PROGRAM OF INSPECTION AND ENFORCEMENT  
LEDOUX, J. C. + REHFUSS, C.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE NUCLEAR REGULATORY COMMISSION (NRC) REGULATES CIVILIAN USES OF NUCLEAR MATERIALS TO ENSURE THE PROTECTION OF THE PUBLIC HEALTH AND SAFETY AND THE ENVIRONMENT. THE OFFICE OF INSPECTION AND ENFORCEMENT (IE) DEVELOPS AND IMPLEMENTS THE INSPECTION, INVESTIGATION, AND ENFORCEMENT PROGRAMS FOR THE NRC. THE IE CONDUCTS INSPECTION PROGRAMS FOR REACTORS UNDER CONSTRUCTION AND IN OPERATION, NUCLEAR INDUSTRY VENDORS, FUEL FACILITIES AND USERS OF NUCLEAR MATERIALS, AND ALL ASPECTS OF THE SAFEGUARDING OF FACILITIES AND MATERIALS. RECENTLY THE IE BEGAN IMPLEMENTING A PROGRAM THAT WILL PLACE INSPECTORS ON SITE AT NUCLEAR POWER REACTORS AND WILL PROVIDE FOR NATIONAL APPRAISAL OF LICENSEE PERFORMANCE AND FOR AN EVALUATION OF THE EFFECTIVENESS OF THE INSPECTION PROGRAMS.
- 19-6-2-691 A REASSESSMENT OF TURBINE GENERATOR FAILURE PROBABILITY  
RUSH, S. H.  
BATTELLE PACIFIC NORTHWEST LABORATORIES, RICHLAND, WASH.  
A PREVIOUS ARTICLE IN NUCLEAR SAFETY ASSESSED THE OVERALL PROBABILITY (P4) OF NUCLEAR PLANT DAMAGE DUE TO TURBINE FAILURES AS A FUNCTION OF THE COMBINED PROBABILITIES OF TURBINE FAILURE AND EJECTION OF AN ENERGETIC MISSILE (P1), A MISSILE STRIKING A CRITICAL COMPONENT (P2), AND SIGNIFICANT DAMAGE OCCURRING TO THE COMPONENT (P3). DUE TO QUESTIONS RAISED CONCERNING THE METHODOLOGY USED, THE VALUE OF P1 HAS BEEN REASSESSED, USING A SOMEWHAT BROADER DATA BASE AND OTHER METHODS OF DATA ANALYSIS. THE RANGE OF INSTANTANEOUS TURBINE FAILURE RATES CONSIDERED RELEVANT TO NUCLEAR SYSTEMS IS  $3.3 \times 10^{-5}$  TO  $3.1 \times 10^{-4}$  PER TURBINE YEAR IN THE CURRENT ARTICLE COMPARED TO A VALUE OF  $7 \times 10^{-5}$  PER TURBINE YEAR IN THE PREVIOUS ARTICLE.
- 19-6-2-699 FISSION GAS RELEASE FROM FUEL AT HIGH BURNUP  
MEYER, R. O. + BEYER, C. E. + VOGLEWEDE, J. C.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE RELEASE OF FISSION GAS FROM FUEL PELLETS AT HIGH BURNUP IS REVIEWED IN THE CONTEXT OF THE SAFETY ANALYSIS PERFORMED FOR REACTOR LICENSE APPLICATIONS. LICENSING ACTIONS THAT WERE TAKEN TO CORRECT DEFICIENT GAS RELEASE MODELS USED IN THESE SAFETY ANALYSES ARE DESCRIBED. A CORRECTION FUNCTION, WHICH WAS DEVELOPED BY THE NUCLEAR REGULATORY COMMISSION STAFF AND ITS CONSULTANTS, IS PRESENTED. RELATED INFORMATION, INCLUDING SOME PREVIOUSLY UNPUBLISHED DATA, IS ALSO SUMMARIZED. THE ARTICLE TRUS PROVIDES GUIDANCE FOR THE ANALYSIS OF HIGH-BURNUP GAS RELEASE IN LICENSING SITUATIONS.
- 19-6-3-712 APPLICATION OF REACTOR SCRAM EXPERIENCE IN RELIABILITY ANALYSIS OF SHUTDOWN SYSTEMS  
EDISON, G. E. + GERSTNER, H. T.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
SCRAM EXPERIENCE AT A LIQUID METAL COOLED FAST BREEDER REACTOR (LMFBR) AND 14 COMMERCIAL LIGHT WATER REACTORS (LWRs) HAS BEEN REVIEWED AND ANALYZED FOR APPLICATION IN THE RELIABILITY ANALYSIS OF LMFBR SHUTDOWN SYSTEMS. THE DATE AND REACTOR POWER FOR EACH SCRAM WERE COMPILED FROM MONTHLY PLANT OPERATING REPORTS AND PERSONAL COMMUNICATIONS WITH PLANT OPERATING PERSONNEL. THE SCRAM FREQUENCY IN THE EXPERIMENTAL BREEDER REACTOR II (EBR-II) HAS BEEN HIGHER THAN THAT IN COMMERCIAL LWRs BECAUSE OF ITS CONSERVATIVE SHUTDOWN SYSTEM DESIGN WHICH LEADS TO MORE SCRAMS FROM MINOR CAUSES. THE SCRAM FREQUENCY OF THE EBR-II HAS DECLINED RAPIDLY WITH OPERATING EXPERIENCE AS SOME OF THE OVERLY CONSERVATIVE SCRAMS ARE ELIMINATED. THE EBR-II DATA TREND AND OTHER FACTS SUGGEST THAT THE SCRAM FREQUENCY FOR LARGE LMFBRs IS LIKELY TO BE IN THE SAME GENERAL RANGE AS THAT FOR COMMERCIAL LWRs. THE SCRAM FREQUENCY CURVE IN LWRs RESEMBLES A RELIABILITY BATHUB CURVE, WITH THE USEFUL LIFE PHASE OF OPERATION LEVELING OFF AT ABOUT 2.5 SCRAMS PER YEAR. A WEIBULL DISTRIBUTION APPEARS TO REPRESENT THE DATA WELL IN THE EARLY LIFE PORTION OF THE CURVE. NO SIGN OF A WEAR-OUT PHASE IS EVIDENT AFTER 16 YEARS OF OPERATION.

- 19-6-3-723 THE SEPARATION OF ELECTRICAL EQUIPMENT AND SYSTEMS IN NUCLEAR POWER PLANTS IN SWEDEN AND THE UNITED STATES  
WEISCH, F.  
SWEDISH NUCLEAR POWER INSPECTORATE, STOCKHOLM, SWEDEN  
DESIGN CRITERIA FOR THE SEPARATION OF CLASS IE EQUIPMENT AND SYSTEMS AND THE SEPARATION REQUIREMENTS AS PRACTICED IN NUCLEAR POWER PLANTS IN SWEDEN AND IN THE UNITED STATES ARE COMPARED. SOME EXAMPLES ARE USED TO SHOW HOW THESE SAFETY REQUIREMENTS INFLUENCE CABLING INSTALLATION AND CONTROL ROOM DESIGN. ALSO, BRIEFLY DISCUSSED IS A DESIGN FEATURE USED TO SHUT DOWN THE REACTOR IN SOME POWER PLANTS IN OTHER COUNTRIES WHEN ACCESS TO THE CONTROL ROOM IS CONSIDERED TO BE TOO HAZARDOUS FOR THE OPERATOR.
- 19-6-5-732 PROTECTION OF THE THYROID GLAND IN THE EVENT OF RELEASES OF RADIOIODINE  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED BY THE NUCLEAR SAFETY STAFF FROM A REPORT OF THE SAME TITLE WHICH WAS ISSUED AUG. 1, 1977, BY THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS AS NCRP REPORT NO. 55. THE REPORT AND ITS SUMMARY HERE PROVIDE USEFUL DATA ON MINIMIZING THE EFFECTS OF AN ACCIDENTAL RADIOIODINE RELEASE.
- 19-6-5-741 MEDICAL AND LEGAL IMPLICATIONS OF A LARGE RELEASE OF RADIOIODINE  
FETTLER, F. A., JR. + FELSEY, C. A. + BARAN, H. S.  
THE UNIVERSITY OF NEW MEXICO, ALBUQUERQUE, N.M. / FRANKLIN PIERCE LAW CENTER, CONCORD, N.H.  
DATA FROM NCRP REPORT NO. 55 BY THE NATIONAL COUNCIL ON RADIATION PROTECTION AND MEASUREMENTS ARE USED IN A HYPOTHETICAL RELEASE SITUATION TO DELINEATE THE POTENTIAL MEDICAL AND LEGAL PROBLEMS THAT MAY ARISE FROM SUCH A RELEASE. AN ANALYSIS OF THESE PROBLEMS INDICATES THAT THE EFFECTS OF RADIOIODINE RELEASE ARE THE MOST IMPORTANT AND THAT GUIDELINES FOR COUNTERMEASURES AND FOLLOW-UP ACTION MUST BE DEVELOPED AND PROMULGATED. MODEL GUIDELINES BASED ON THE HYPOTHETICAL RELEASE ARE PRESENTED AND DISCUSSED.
- 19-6-6-748 STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1976  
TATONE, G. S. + PATRANIA, R. S.  
CHALK RIVER NUCLEAR LABORATORIES, ONTARIO, CANADA  
A SURVEY WAS CONDUCTED OF EXPERIENCE WITH STEAM-GENERATOR TUBES AT NUCLEAR POWER STATIONS DURING 1976. FAILURES WERE REPORTED AT 25 OUT OF 68 WATER-COOLED REACTORS. THE CAUSES OF THESE FAILURES AND THE REPAIR AND INSPECTION PROCEDURES DESIGNED TO COPE WITH THEM ARE SUMMARIZED. EXAMINATION OF THE DATA INDICATES THAT CORROSION WAS THE MAJOR CAUSE OF STEAM GENERATOR TUBE FAILURES. IMPROVEMENTS ARE NEEDED IN STEAM GENERATOR DESIGN, CONDENSER INTEGRITY, AND SECONDARY WATER CHEMISTRY CONTROL.
- 19-6-6-760 OCCUPATIONAL RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEAR POWER REACTORS, 1969-1976  
JOHNSON, L. A.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THIS ARTICLE, WHICH IS ADAPTED FROM A REPORT BY THE NUCLEAR REGULATORY COMMISSION (REPORT NUREG-0323), PRESENTS AN UPDATED COMPILATION OF OCCUPATIONAL RADIATION EXPOSURES AT COMMERCIAL LIGHT WATER COOLED NUCLEAR POWER REACTORS FOR THE YEARS 1969 THROUGH 1976. THE INFORMATION IN THIS DOCUMENT WAS DERIVED FROM REPORTS SUBMITTED ANNUALLY TO THE NUCLEAR REGULATORY COMMISSION IN ACCORDANCE WITH REQUIREMENTS OF THE TECHNICAL SPECIFICATIONS FOR INDIVIDUAL PLANTS. AN ADDITIONAL 9 LIGHT WATER REACTORS COMPLETED A FULL CALENDAR YEAR OF COMMERCIAL OPERATION FOR THE FIRST TIME IN 1976, INCREASING THE TOTAL NUMBER OF OPERATING NUCLEAR POWER PLANTS TO 53. THE NUMBER OF PERSONNEL MONITORED AT LIGHT WATER REACTORS INCREASED ABOUT 34 PERCENT IN 1976, AND THE AVERAGE COLLECTIVE DOSE TO PERSONNEL (MAN-REMS PER REACTOR-YEAR) INCREASED 9 PERCENT OVER THE 1975 AVERAGE. THE AVERAGE NUMBER OF PERSONNEL RECEIVING MEASURABLE EXPOSURE PER REACTOR INCREASED 7 PERCENT, AND THE AVERAGE EXPOSURE PER INDIVIDUAL IN 1976 WAS 0.7 REM PER PERSON.
- 20-1-1-01 TWENTY YEARS OF NUCLEAR SAFETY  
COTTRELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE COMMEMORATES 20 YEARS OF NUCLEAR SAFETY BY REVIEWING THE HISTORICAL BACKGROUND SURROUNDING ITS GENESIS AND ITS EVOLUTION INTO THE REPUTABLE JOURNAL IT IS TODAY. THE JOURNAL, WHICH STARTED AS A SMALL QUARTERLY PUBLICATION, HAS GROWN TO A WIDELY RECOGNIZED PEER REVIEWED BIMONTHLY REVIEW PUBLICATION. THIS ARTICLE PRESENTS A BRIEF REVIEW OF THE PERSONNEL RESPONSIBLE FOR THE SUCCESS OF THE JOURNAL, THE MANY CHANGES THAT HAVE TAKEN PLACE, AND THE RECOGNITION THE JOURNAL HAS RECEIVED.
- 20-1-1-15 NUCLEAR POWER REACTOR DECOMMISSIONING  
LAGUARDIA, T. S.  
NUCLEAR ENERGY SERVICES, INC., DANBURY, CONN.  
THIS ARTICLE SUMMARIZES THE MAJOR FINDINGS OF AN EVALUATION OF SEVERAL ALTERNATIVES FOR DECOMMISSIONING 1,000-MW(E) NUCLEAR POWER REACTORS. THE EVALUATION INCLUDING THE TECHNICAL FEASIBILITY OF DECOMMISSIONING AND THE COSTS, SCHEDULE,

ENVIRONMENTAL IMPACTS, AND OCCUPATIONAL EXPOSURES FOR THREE DECOMMISSIONING ALTERNATIVES - MOTHBALLING, ENTOMBMENT, AND PROMPT REMOVAL OF RADIOACTIVE COMPONENTS AND DISMANTLING. IN ADDITION, TWO COMBINATIONS OF THESE ALTERNATIVES WERE EVALUATED - MOTHBALLING DELAYED REMOVAL AND DISMANTLING AND ENTOMBMENT DELAYED REMOVAL AND DISMANTLING. THE EVALUATION DEMONSTRATED THAT NO NEW TECHNOLOGY IS REQUIRED TO SAFELY DECOMMISSION A LARGE POWER REACTOR. THE PROMPT REMOVAL OF RADIOACTIVE COMPONENTS AND DISMANTLING ALTERNATIVE IS THE HIGHEST IN COST, REQUIRING APPROXIMATELY \$50 MILLION AND APPROXIMATELY 6 YEARS TO REMOVE ALL STRUCTURES AT THE END OF USEFUL LIFE. THE RADIATION EXPOSURES AND ENVIRONMENTAL IMPACTS ARE LOW FOR ALL THE ALTERNATIVES SO THAT DECOMMISSIONING CAN BE ACCOMPLISHED WITHOUT UNDUE RISK TO PUBLIC HEALTH AND SAFETY.

- 20-1-1-24 REPORT OF THE NRC RISK ASSESSMENT REVIEW GROUP ON THE REACTOR SAFETY STUDY  
NRC RISK ASSESSMENT REVIEW GR.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
EDITOR'S NOTE - THE RISK ASSESSMENT REVIEW GROUP OF THE NUCLEAR REGULATORY COMMISSION (NRC) HAS COMPLETED ITS REVIEW AND REPORT ON THE REACTOR SAFETY STUDY (REPORT WASH-1400). THE SEVEN MEMBER INDEPENDENT ASSESSMENT GROUP, HEADED BY DR. HAROLD LEWIS OF THE UNIVERSITY OF CALIFORNIA AT SANTA BARBARA, WAS APPOINTED BY NRC IN 1977 TO CLARIFY THE ACHIEVEMENTS AND LIMITATIONS OF THE REACTOR SAFETY STUDY, SOMETIMES CALLED THE RASMUSSEN REPORT, AND TO ASSESS THE COMMENTS MADE ON IT. THE REACTOR SAFETY STUDY WAS SPONSORED FIRST BY THE FORMER U.S. ATOMIC ENERGY COMMISSION AND LATER BY NRC. THE GROUP OF SCIENTISTS ALSO WAS TO DEVELOP FOR NRC ADVICE AND RECOMMENDATIONS ON THE FUTURE DEVELOPMENT AND USE OF RISK ASSESSMENT METHODOLOGY IN THE REGULATORY AND LICENSING PROCESS. THE REPORT CONTAINS NUMEROUS FINDINGS AND RECOMMENDATIONS THAT NRC IS NOW CONSIDERING. SINGLE COPIES OF THE REPORT, DESIGNATED NUREG/CR-0400, CAN BE OBTAINED BY WRITING TO THE DIVISION OF TECHNICAL INFORMATION AND DOCUMENT CONTROL, U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C. 20555.
- 20-1-2-27 SYNOPSIS OF THE BWR BLOWDOWN HEAT-TRANSFER PROGRAM  
BORENETTE, G. W. + SOZZI, G. L.  
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIF.  
SYSTEM PERFORMANCE AND THERMAL RESPONSE CHARACTERISTICS OF BOILING WATER REACTORS (BWRs) DURING THE INITIAL BLOWDOWN PHASE UNDER LOSS OF COOLANT ACCIDENT (LOCA) CONDITIONS WERE INVESTIGATED IN A SCALED TEST APPARATUS. A NUMBER OF INHERENT COOLING MECHANISMS WERE OBSERVED FOR WHICH NO CREDIT IS TAKEN IN THE CURRENT BWR LOCA EVALUATION METHOD. THE CURRENT METHOD, WHEN APPLIED TO THE TEST APPARATUS, SHOWS A SUBSTANTIAL MARGIN IN THE PREDICTION OF PEAK CLADDING TEMPERATURE. SPECIFIC PHEROMENOLOGICAL MODEL IMPROVEMENTS ARE RECOMMENDED.
- 20-1-3-44 THE DOE INTRUSION DETECTION SYSTEMS HANDBOOK  
MANGAN, D. L.  
SANDIA LABORATORIES, ALBUQUERQUE, N.M.  
THIS ARTICLE REVIEWS THE INTRUSION DETECTION SYSTEMS HANDBOOK THAT WAS PREPARED BY SANDIA LABORATORIES FOR THE U.S. DEPARTMENT OF ENERGY, OFFICE OF SAFEGUARDS AND SECURITY. THE PURPOSE OF THE HANDBOOK IS TO PROVIDE INFORMATION PERTINENT TO THE SELECTION, PROCUREMENT, INSTALLATION, TESTING, AND MAINTENANCE OF THE ELEMENTS OF AN INTRUSION DETECTION SYSTEM. THESE ELEMENTS INCLUDE INTERIOR AND EXTERIOR SENSORS, ALARM ASSESSMENT EQUIPMENT, AND ALARM REPORTING EQUIPMENT. THE HANDBOOK ALSO CONTAINS A DISCUSSION OF HOW THESE ELEMENTS CAN BE INTEGRATED INTO AN OPERATIONALLY EFFECTIVE SYSTEM.
- 20-1-4-54 HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER CTORS  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THIS ARTICLE HAS BEEN ADAPTED FROM THE EXECUTIVE SUMMARY OF THE NUCLEAR REGULATORY COMMISSION (NRC) REPORT, GENERIC ENVIRONMENTAL IMPACT STATEMENT ON HANDLING AND STORAGE OF SPENT LIGHT WATER POWER REACTOR FUEL (NUREG-0404). THE REPORT WAS PREPARED BY THE NRC STAFF IN RESPONSE TO A DIRECTIVE FROM THE COMMISSIONERS. INASMUCH AS THERE HAVE BEEN - AND CONTINUE TO BE - SIGNIFICANT POLICY DEVELOPMENTS SINCE THE NRC'S DIRECTIVE WAS ISSUED, THIS IMPACT STATEMENT IS CONSIDERED TO BE AN INTERIM ACTION, NOT A FINAL SOLUTION. THE REPORT COVERS THE FOLLOWING CONCERNS - (1) EXPECTED MAGNITUDE OF THE SHORTAGE OF STORAGE CAPACITY, (2) THE OPTIONS FOR DEALING WITH THE PROBLEM, (3) A COST BENEFIT ANALYSIS OF THESE OPTIONS, (4) THE IMPACTS OF ADDITIONAL TRANSPORTATION OF SPENT FUELS, AND (5) THE NEED FOR MORE REGULATIONS AND GUIDANCE. THE STUDY CONCLUDES THAT THE STORAGE OF SPENT FUEL IS A WELL ESTABLISHED TECHNOLOGY, THAT THE AMOUNT OF SPENT FUEL REQUIRING AWAY-FROM-REACTOR STORAGE BY YEAR 2000 IS NOT GREAT, AND THAT THE ENVIRONMENTAL IMPACT OF EITHER AT-REACTOR OR AWAY-FROM-REACTOR SPENT-FUEL STORAGE IS INSIGNIFICANT.

- 20-1-4-83 THE FIFTEENTH DOE AIR CLEANING CONFERENCE  
 BELLAMY, R. R. + MOELLER, D. W. + UNDERHILL, D. W.  
 FIEST, M. W.  
 U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C. / HARVARD  
 UNIVERSITY, BOSTON, MASS.  
 THE FIFTEENTH DOE AIR CLEANING CONFERENCE WAS HELD AUG. 7-10,  
 1978, IN BOSTON, MASS. THE 331 NUCLEAR AIR CLEANING SPECIALISTS  
 WHO ATTENDED CAME FROM GOVERNMENTAL AGENCIES, EDUCATIONAL  
 INSTITUTIONS, NATIONAL LABORATORIES, AND ALL AREAS OF INDUSTRY  
 AND INCLUDED REPRESENTATIVES FROM THE UNITED STATES AND 10  
 FOREIGN COUNTRIES. MAJOR TOPICS DISCUSSED DURING THE CONFERENCE  
 WERE WASTE TREATMENT, INCLUDING VOLUME REDUCTION AND  
 PREPARATION FOR STORAGE, THE REMOVAL OF TRITIUM, CARBON-14, AND  
 OZONE, CONTAINMENT OF ACCIDENTAL RELEASES, ADSORBENTS AND  
 ABSORBENTS, THE TREATMENT OF OFF GASES FROM CHEMICAL  
 PROCESSING, AEROSOL BEHAVIOR, LABORATORY AND IN PLACE FILTER  
 TESTING METHODS, AND PARTICULATE FILTRATION. THE CONFERENCE  
 FOCUSED ON NEW RESEARCH DEVELOPMENTS, NEEDS, AND REFINEMENTS IN  
 AIR CLEANING SYSTEMS AND COMPONENTS. RESEARCH TRENDS,  
 ESPECIALLY IN FOREIGN COUNTRIES, APPEAR TO BE MOVING AWAY FROM  
 RADIOIODINE AND TOWARD NOBLE-GAS RELEASES FROM POWER REACTORS  
 AND THE TREATMENT OF VARIOUS CHEMICALS (BOTH RADIOACTIVE AND  
 NONRADIOACTIVE) RELEASED DURING THE CHEMICAL PROCESSING OF FUEL  
 ELEMENTS. NEW CHALLENGES ARE EMERGING TO IMPROVE THE SAFETY AND  
 LOWER THE COST OF DISPOSAL OF CONTAMINATED AIR CLEANING  
 COMPONENTS AND TO REDUCE SPACE REQUIREMENTS FOR AIR CLEANING  
 SYSTEMS AT REACTOR STATIONS. RELIABLE AND ACCURATE MONITORING  
 OF RELEASES CONTINUES AS AN ELUSIVE GOAL, BUT IT HAS BEEN  
 POINTED OUT THAT CAREFUL ANALYSIS OF FAILURE DATA ON OPERATING  
 COMPONENTS IS LIKELY TO LEAD TO IMPROVEMENTS IN FUTURE DESIGNS.  
 IMPROVED TESTING TECHNIQUES FOR VERIFYING THE SUITABILITY OF  
 SYSTEMS AND COMPONENTS FOR NUCLEAR SERVICE CONTINUE TO BE  
 EMPHASIZED BY THOSE IN THE AIR CLEANING INDUSTRY. AN OVERVIEW  
 OF WESTERN EUROPEAN AIR AND GAS CLEANING CONCERNS AND PRACTICES  
 INDICATES MANY AREAS OF COMMON INTEREST WITH U.S. AND CANADIAN  
 SCIENTISTS AND ENGINEERS.
- 20-1-6-78 BROWNS FERRY CHARCOAL ADSORBER INCIDENT  
 HAYS, G. T.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THIS ARTICLE REVIEWS THE TEMPERATURE EXCURSION IN THE CHARCOAL  
 ADSORBER BEDS OF THE BROWNS FERRY UNIT 3 OFF GAS SYSTEM THAT  
 OCCURRED ON JULY 17, 1977. SIGNIFICANT TEMPERATURE INCREASES  
 WERE EXPERIENCED IN THE CHARCOAL ADSORBER BEDS WHEN CHARCOAL  
 FINES WERE IGNITED BY THE IGNITION OF A COMBUSTIBLE MIXTURE OF  
 HYDROGEN AND OXYGEN IN THE OFF GAS SYSTEM. THE BROWNS FERRY  
 OFF GAS SYSTEM IS DESCRIBED, AND EVENTS LEADING UP TO AND  
 SURROUNDING THE INCIDENT ARE DISCUSSED. THE FOLLOW-UP  
 INVESTIGATION BY TENNESSEE VALLEY AUTHORITY AND GENERAL  
 ELECTRIC COMPANY PERSONNEL AND THEIR RECOMMENDATIONS FOR  
 SYSTEM AND OPERATIONAL MODIFICATIONS ARE SUMMARIZED.
- 20-1-6-83 A REVIEW OF SAFETY RELATED EVENTS AT NUCLEAR POWER PLANTS AS REPORTED IN 1977  
 SCOTT, R. L. + GALLAHER, P. B.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 THIS ARTICLE REVIEWS THE REPORTS OF SAFETY RELATED EVENTS AT  
 LIGHT WATER REACTOR NUCLEAR POWER PLANTS SUBMITTED IN 1977 TO  
 THE U.S. NUCLEAR REGULATORY COMMISSION. THE REVIEW COVERS 1222  
 REPORTS FROM BOILING WATER REACTOR FACILITIES AND 1780 REPORTS  
 FROM PRESSURIZED WATER REACTOR FACILITIES. INFORMATION IS  
 PRESENTED IN TABLES LISTING INSTRUMENT FAILURES, EQUIPMENT  
 FAILURES, SYSTEMS INVOLVED, CAUSES, DEFICIENCIES, AND TIMES OF  
 OCCURRENCES (I.E., REFUELING, TESTING, OPERATION, OR  
 CONSTRUCTION). THE TABLES GIVE THE NUMBER OF REPORTS CONCERNED  
 WITH EACH LISTED ITEM AND THEREFORE INDICATE THE FREQUENCIES OF  
 EVENTS AND THOSE EVENTS WHICH SHOULD RECEIVE MORE ATTENTION IN  
 THE FORM OF MAINTENANCE AND TESTING TO IMPROVE PLANT  
 RELIABILITY AND SAFETY.
- 20-2-1-123 NUCLEAR POWER PLANT SAFETY IN DEVELOPING COUNTRIES  
 ROSEN, M.  
 INTERNATIONAL ATOMIC ENERGY AGENCY, VIENNA, AUSTRIA  
 BY 1990 THERE WILL BE COMMERCIAL NUCLEAR POWER PLANTS IN 17  
 COUNTRIES THAT ARE PRESENTLY CONSIDERED INDUSTRIALLY LESS  
 DEVELOPED. ONLY RECENTLY HAS SOME ATTENTION BEEN FOCUSED ON THE  
 ADDITIONAL AND SPECIAL NUCLEAR SAFETY ASPECTS OF THESE EXPORTED  
 POWER FACILITIES. THIS ARTICLE DISCUSSES THESE ASPECTS, IN  
 PARTICULAR THE NONSTANDARD NATURE OF THE EXPORTED NUCLEAR  
 FACILITY AND THE NONUNIFORM SAFETY STANDARDS AND REQUIREMENTS  
 THAT ARE USED. SUGGESTIONS ARE MADE FOR RAISING THE LEVEL OF  
 THE IMPORTANT REGULATORY EFFORT IN THE LESS DEVELOPED  
 COUNTRIES BY UPGRADING THE TRADITIONALLY SUPPLIED SAFETY  
 DOCUMENTATION, PRINCIPALLY BY THE USE OF A SUPPLEMENTARY  
 INFORMATION REPORT WRITTEN SPECIFICALLY FOR A SMALLER AND LESS  
 TECHNICALLY QUALIFIED STAFF, AND BY ADDRESSING THE NEEDS OF  
 SMALLER COUNTRIES IN THE OPERATING REGULATIONS (TECHNICAL  
 SPECIFICATIONS FOR OPERATION). FINALLY THE SAFETY ASSISTANCE  
 AVAILABLE FROM THE INTERNATIONAL ATOMIC ENERGY AGENCY (IAEA) AS  
 WELL AS FROM NATIONAL ORGANIZATIONS IS OUTLINED.

- 20-2-1-136 THE AERIAL MEASURING SYSTEMS PROGRAM  
 JOBST, J. E.  
 EG AND G, INC., NORTH LAS VEGAS, NEVADA  
 EG AND G, INC., HAS DEVELOPED FOR THE DEPARTMENT OF ENERGY (DOE) AN AERIAL MEASURING SYSTEMS (AMS) PROGRAM DEDICATED TO ENVIRONMENTAL RESEARCH AT FACILITIES OF INTEREST TO DOE, THE NUCLEAR REGULATORY COMMISSION (NRC), AND OTHER FEDERAL AGENCIES. THE AMS WAS ORIGINALLY CREATED TO MEASURE NUCLEAR RADIATION, THE PROGRAM SCOPE HAS BEEN BROADENED DRAMATICALLY TO INCLUDE A WIDE VARIETY OF REMOTE SENSORS - MULTISPECTRAL AND MAPPING CAMERAS, OPTICAL AND INFRARED MULTISPECTRAL SCANNERS, AIR SAMPLING SYSTEMS, AND METEOROLOGICAL SENSORS. THE AMS MAINTAINS SEVEN AIRCRAFT AS SURVEY PLATFORMS, BOTH FIXED WING AIRCRAFT AND HELICOPTERS. PHOTOGRAPHY, SCANNER IMAGERY, AND RADIATION DATA ARE PROCESSED IN DEDICATED, MODERN LABORATORIES AND USED FOR A BROAD RANGE OF ENVIRONMENTAL IMPACT STUDIES. A GRAPHIC OVERVIEW SYSTEM HAS BEEN DEVELOPED FOR EFFECTIVE PRESENTATION OF ALL TYPES OF REMOTELY SENSED DATA OBTAINED AT A FACILITY OF INTEREST.
- 20-2-2-148 RISK BENEFIT EVALUATION FOR LARGE TECHNOLOGICAL SYSTEMS  
 OKRENT, D.  
 UNIVERSITY OF CALIFORNIA, LOS ANGELES, CALIF.  
 THE RELATED TOPICS OF RISK BENEFIT ANALYSIS, RISK ANALYSIS, AND RISK ACCEPTANCE CRITERIA (IS SAFE IS SAFE ENOUGH) ARE OF GROWING IMPORTANCE. AN INTERDISCIPLINARY STUDY ON VARIOUS ASPECTS OF THESE TOPICS, INCLUDING APPLICATIONS TO NUCLEAR POWER, WAS RECENTLY COMPLETED AT THE UNIVERSITY OF CALIFORNIA, LOS ANGELES (UCLA), WITH THE SUPPORT OF THE NATIONAL SCIENCE FOUNDATION. IN ADDITION TO MORE THAN 30 TOPICAL REPORTS AND VARIOUS OPEN LITERATURE PUBLICATIONS, A FINAL REPORT (UCLA-ENG-7777) TO THE STUDY, TITLED A GENERALIZED EVALUATION APPROACH TO RISK BENEFIT FOR LARGE TECHNOLOGICAL SYSTEMS AND ITS APPLICATION TO NUCLEAR POWER, WAS ISSUED IN EARLY 1978. THIS ARTICLE BRIEFLY SUMMARIZES PORTIONS OF THE FINAL REPORT DEALING WITH GENERAL ASPECTS OF RISK BENEFIT METHODOLOGY, SOCIETAL KNOWLEDGE AND PERCEPTION OF RISK, AND RISK ACCEPTANCE CRITERIA.
- 20-2-3-166 IAEA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER PLANTS  
 HAGN, E. W.  
 OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
 AN INTERNATIONAL MEETING OF SPECIALISTS CONCERNED WITH ELECTRIC POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER STATIONS WAS HELD IN STOCKHOLM, SWEDEN, SEPT. 5-8, 1978, UNDER THE AUSPICES OF THE INTERNATIONAL ATOMIC ENERGY AGENCY AND THE NUCLEAR POWER INSPECTORATE OF SWEDEN. ACTUAL REQUIREMENTS AND DESIGNS AS WELL AS OPERATIONAL EXPERIENCES AT NUCLEAR POWER STATIONS WERE PRESENTED IN THE FORMAL SESSIONS AND THEN DISCUSSED IN QUESTION AND ANSWER PERIODS AND LATER IN OPEN FORUMS AND PRIVATE CONVERSATIONS.
- 20-2-4-176 FAILURES IN AIR MONITORING, AIR CLEANING, AND VENTILATION SYSTEMS IN COMMERCIAL NUCLEAR POWER PLANTS (JAN. 1, 1975-JUNE 30, 1978)  
 NOELLER, D. W.  
 HARVARD UNIVERSITY, BOSTON, MASS.  
 DURING THE PERIOD JAN. 1, 1975, TO JUNE 30, 1978, OVER 9000 LICENSEE EVENT REPORTS (LERs) PERTAINING TO THE OPERATION OF COMMERCIAL LIGHT WATER REACTOR NUCLEAR POWER PLANTS IN THE UNITED STATES WERE SUBMITTED TO THE NUCLEAR REGULATORY COMMISSION (NRC). OF THESE REPORTS, OVER 1200 (APPROXIMATELY 13 PERCENT) PERTAINED TO FAILURES IN AIR MONITORING, AIR CLEANING, AND VENTILATION SYSTEMS. FOR BOILING WATER REACTOR (BWR) INSTALLATIONS, OVER HALF (51 PERCENT) OF THE REPORTED EVENTS RELATED TO FAILURES IN EQUIPMENT FOR MONITORING THE PERFORMANCE OF AIR CLEANING SYSTEMS RATHER THAN TO FAILURES IN THE SYSTEMS THEMSELVES. IN PRESSURIZED WATER REACTOR (PWR) INSTALLATIONS, FAILURES IN MONITORING EQUIPMENT AMOUNTED TO ABOUT 32 PERCENT OF THE TOTAL. REPORTED PROBLEM AREAS IN BWR INSTALLATIONS INCLUDED THE PRIMARY CONTAINMENT AND STANDBY GAS TREATMENT AND OFF GAS SYSTEMS, AS WELL AS THE HIGH PRESSURE COOLANT INJECTION AND REACTOR CORE ISOLATION SYSTEMS. FOR PWR INSTALLATIONS, REPORTED PROBLEM AREAS INCLUDED THE PRIMARY CONTAINMENT AND ASSOCIATED SPRAY SYSTEMS AND THE WASTE PROCESSING EQUIPMENT. ALTHOUGH THIS STUDY WAS LIMITED IN SCOPE AND THE RESULTING DATA CAN BE INTERPRETED IN A VARIETY OF WAYS, SEVERAL MESSAGES ARE CLEAR. FIRST, THERE IS A NEED FOR RESEARCH ON THE DEVELOPMENT OF MORE RELIABLE EQUIPMENT FOR MONITORING OF AIR CLEANING AND VENTILATION SYSTEMS. SECOND, ALTHOUGH THERE HAS BEEN A SIGNIFICANT REDUCTION IN RECENT YEARS IN THE CONTRIBUTIONS OF HUMAN ERROR TO FAILURES IN AIR CLEANING SYSTEMS, ABOUT HALF OF ALL FAILURES CONTINUE TO RESULT DIRECTLY FROM THIS SOURCE. THIRD, THIS STUDY HAS SHOWN THAT ANALYSES OF LER INFORMATION CAN PROVIDE USEFUL DATA TO CONFIRM ESTIMATES OF THE RELIABILITY OF VARIOUS REACTOR SAFETY SYSTEMS. A PROGRAM TO DEVELOP SUCH DATA IS UNDER WAY WITHIN THE PROBABILISTIC ANALYSIS SECTION OF THE OFFICE OF NUCLEAR REGULATORY RESEARCH OF THE NRC.

20-2-5-190 ABUNDANCE AND DISTRIBUTION OF RADIONUCLIDES DISCHARGED FROM A BWR NUCLEAR POWER STATION INTO A MARINE BAY

BLANCHARD, R. L. \* KARN, B.

U. S. ENVIRONMENTAL PROTECTION AGENCY, MONTGOMERY, ALA.

THIS ARTICLE SUMMARIZES A PORTION OF ONE OF A SERIES OF RADIOLOGICAL SURVEILLANCE STUDIES CONDUCTED BY THE U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA) AT NUCLEAR POWER STATIONS. RADIONUCLIDE CONCENTRATIONS WERE MEASURED IN BARNEGAT BAY AT THE NEW JERSEY SHORE DURING EPA'S 2-YEAR RADIOLOGICAL SURVEILLANCE STUDY AT THE OYSTER CREEK NUCLEAR GENERATING STATION. THE STATION DISCHARGES BATCHES OF RADIOACTIVE LIQUID WASTE INTO EFFLUENT CONDENSER COOLING WATER, WHICH FLOWS THROUGH OYSTER CREEK TO BARNEGAT BAY 3 KM FROM THE POINT OF DISCHARGE. THE BAY IS LONG, NARROW, AND SHALLOW, WITH FEW PASSAGES TO THE ATLANTIC OCEAN. RADIONUCLIDE CONCENTRATIONS WERE MEASURED REPEATEDLY IN WATER, SEDIMENT, MARINE VEGETATION, FISH, CLAMS, AND CRABS AT VARIOUS SAMPLING POINTS. MEASURED VALUES WERE COMPARED TO CALCULATED VALUES BASED ON BIOACCUMULATION FACTORS, AND BOTH SETS WERE USED TO COMPUTE DOSE EQUIVALENT RATES TO THE MOST EXPOSED PERSONS IN THE ENVIRONMENT. THE TWO OBSERVED CRITICAL RADIATION EXPOSURE PATHWAYS - FISH CONSUMPTION AND STANDING ON BEACHES - RESULTED IN DOSE EQUIVALENTS OF LESS THAN 1 MREM/YEAR. THE CRITICAL RADIONUCLIDES WERE STRONTIUM-90 AND COBALT-60, RESPECTIVELY. INDICATOR RADIONUCLIDES WERE IDENTIFIED, AND ENVIRONMENTAL RADIOLOGICAL MONITORING ACTIVITIES WERE RECOMMENDED.

20-2-6-206 ANOTHER PERSPECTIVE OF THE 1958 SOVIET NUCLEAR ACCIDENT

TRABALKA, J. H. \* EYMAN, L. D. \* PARKER, F. L.

STRAINESS, E. G. \* AUERBACH, S. I.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN. / WANDERBILT UNIVERSITY, NASHVILLE, TENN.

THE OCCURRENCE OF A MAJOR SOVIET NUCLEAR ACCIDENT INVOLVING STORED, REPROCESSED, LONG LIVED FISSION WASTES HAS BEEN REPORTED BY FORMER SOVIET CITIZENS. Z. A. MEDVEDEV, WRITING IN THE POPULAR SCIENCE MAGAZINE NEW SCIENTIST, BELIEVED THAT THE ACCIDENT RESULTED IN SIGNIFICANT LOSS OF LIFE AND REQUIRED THE PERMANENT EVACUATION OF THE CIVILIAN POPULATION FROM A LARGE AREA (SEVERAL THOUSAND SQUARE MILES). ALTHOUGH MEDVEDEV APPEARS TO HAVE REACHED TENTATIVE CONCLUSIONS ABOUT THE EXACT ORIGIN AND EXTENT OF THE CONTAMINATED AREA, IT DOES APPEAR THAT A CREDIBLE CASE CAN BE MADE FOR AN ACCIDENTAL AIRBORNE RELEASE OF FISSION WASTES IN THE GENERAL GEOGRAPHIC LOCATION HE SUGGESTED. IN VIEW OF THE GROWING IMPORTANCE OF NUCLEAR POWER AS A WORLD ENERGY SOURCE, AN EXHAUSTIVE CRITICAL REVIEW OF THE SOVIET LITERATURE IS WARRANTED TO RESOLVE DOUBTS ABOUT THE EXACT NATURE AND CONSEQUENCES, INDEED EVEN THE OCCURRENCE, OF THE POSTULATED ACCIDENT.

20-2-6-210 OUTAGES AT LIGHT WATER REACTOR POWER PLANTS - A REVIEW OF 1973-1977 EXPERIENCE

SCOTT, R. L.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE RESULTS OF A REVIEW OF OUTAGE EXPERIENCE AT NUCLEAR POWER PLANTS FOR THE PERIOD 1973-1977 ARE GIVEN. SPECIFICALLY, THE OUTAGES EXPERIENCED WERE EXAMINED TO DETERMINE CAUSES, FREQUENCIES, TIME, ETC., TO SEE IF TRENDS WERE EVIDENT OR OTHER INSIGHTS COULD BE OBTAINED. THE DATA REVIEWED REPRESENT 230 REACTOR YEARS OF EXPERIENCE - 58 PERCENT OF THE TOTAL ACCUMULATION IN THE UNITED STATES AT THE END OF 1977. THIRTEEN TABLES AND TWO FIGURES PRESENT THE DATA, AND A SUMMARY GIVES THE IMPORTANT DEDUCTIONS.

20-3-1-249 SIXTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING

COTTRELL, W. B.

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE SUMMARIZES THE SIXTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING, SPONSORED BY THE NUCLEAR REGULATORY COMMISSION'S (NRC'S) DIVISION OF REACTOR SAFETY RESEARCH AND HELD AT THE NATIONAL BUREAU OF STANDARDS, GAITHERSBURG, MD., NOV. 6-9, 1978. PRESENTED AT THIS MEETING WERE 116 PAPERS IN THE FOLLOWING FIVE RESEARCH PROGRAM AREAS - (1) ANALYSIS DEVELOPMENT PROGRAM, (2) FUEL BEHAVIOR RESEARCH, (3) REACTOR OPERATIONAL SAFETY PROGRAM, (4) LOSS OF COOLANT ACCIDENT STUDIES, AND (5) METALLOGY AND MATERIALS RESEARCH. IN ADDITION, THE MEETING INCLUDED SEVERAL WORKSHOPS ON SELECTED TOPICS. AMONG THE MANY PRESENTATIONS WERE 12 INVITED PAPERS ON SAFETY RESEARCH IN SEVERAL FOREIGN COUNTRIES, THE RESULTS OF WHICH BOTH COMPLEMENT AND REINFORCE THOSE FROM THE NRC PROGRAM. ALTHOUGH SOME COMPONENTS OF THE NRC PROGRAM HAVE BEEN COMPLETED, THE LOSS OF COOLANT ACCIDENT (LOCA) STUDIES, WHICH CONSTITUTE THE LARGEST PORTION OF THE NRC PROGRAM, WILL CONTINUE UNTIL THE LARGE SCALE EXPERIMENTS, SUCH AS THE FLECHT-SET AND LOCA TESTS IN THE LOSS OF FLUID TEST (LOFT) FACILITY, ARE COMPLETED AND THEIR RESULTS ARE ABSORBED INTO THE ANALYTICAL PROGRAMS AND DATA BANKS FOR REACTOR LICENSING CONSIDERATIONS. FULL SCALE TESTING IN LOFT WAS TO COMMENCE WITHIN 6 WEEKS OF THE END OF THE MEETING. HOWEVER, INCREASING EMPHASIS ON OPERATIONAL SAFETY PROBLEMS IS ALREADY IN EVIDENCE. THERE WERE NO FINDINGS REPORTED THAT WOULD THREATEN OUR PRESENT UNDERSTANDING OF REACTOR SAFETY, AND THERE WAS MUCH WHICH EITHER SUPPORTED THAT UNDERSTANDING OR DEMONSTRATED CONSERVATISM.

- 20-3-1-258 REVIEW OF AUGUST 1978 CHANGES TO THE NRC'S PROGRAM FOR STANDARDIZATION OF NUCLEAR POWER PLANTS  
KANE, W. F.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
THE NUCLEAR REGULATORY COMMISSION'S (NRC'S) STANDARDIZATION PROGRAM FOR THE LICENSING OF NUCLEAR POWER PLANTS WAS INITIATED IN APRIL 1972 AND HAS BEEN USED EXTENSIVELY BY INDUSTRY SINCE THAT TIME. IN JUNE 1977 THE NRC DIRECTED THE STAFF TO UNDERTAKE A DETAILED STUDY OF THE PROGRAM. AS PART OF THAT STUDY, THE STAFF WAS TO DETERMINE STEPS THAT THE NRC MIGHT TAKE TO FURTHER ENCOURAGE STANDARDIZATION. THIS ARTICLE DISCUSSES THE CHANGES MADE TO THE STANDARDIZATION PROGRAM THAT RESULTED FROM THAT STUDY.
- 20-3-2-267 AN OVERVIEW OF NRC'S EMERGENCY CORE COOLANT BYPASS RESEARCH  
BECKNER, W. D.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
AN OVERVIEW OF RESEARCH SPONSORED BY THE NUCLEAR REGULATORY COMMISSION ON COUNTERCURRENT FLOW FLOODING IN RELATIONSHIP TO THE EMERGENCY CORE COOLANT (ECC) BYPASS PHENOMENON IS PRESENTED. PROGRESS HAS BEEN MADE IN UNDERSTANDING THE TRANSIENT ECC PENETRATION PROBLEM IN SMALL SCALE MODELS OF REACTOR PRESSURE VESSELS. EXPERIMENTS HAVE BEEN MADE TO STUDY ECC PENETRATION IN THE PRESENCE OF TRANSIENT COUNTERCURRENT STEAM FLOW AND SUPERHEATED VESSEL WALLS OVER A VARIETY OF TEST CONDITIONS. THE RESULTS OF THIS WORK HAVE BEEN USED TO DEVELOP MODELS AND CORRELATIONS TO ANALYZE THE ECC INJECTION PHASE OF THE HYPOTHETICAL LOSS OF COOLANT ACCIDENT (LOCA). THE APPLICABILITY AND LIMITATIONS OF THIS WORK IN RELATION TO BEST ESTIMATE EVALUATIONS OF THE LOCA AND IN THE LICENSING PROCESS ARE EXAMINED.
- 20-3-3-280 INSTRUMENTATION FOR MONITORING PLUTONIUM IN THE ENVIRONMENT  
NERO, A. V., JR.  
LAWRENCE BERKELEY LABORATORY, BERKELEY, CALIF.  
SUBSTANTIAL AMOUNTS OF PLUTONIUM ARE PRODUCED IN BOTH CIVILIAN AND MILITARY NUCLEAR PROGRAMS, AND PERMISSIBLE ENVIRONMENTAL PLUTONIUM CONCENTRATIONS ARE VERY LOW. THIS ARTICLE DESCRIBES INSTRUMENTATION FOR MONITORING PLUTONIUM IN THE ENVIRONMENT, WITH EMPHASIS ON ALPHA MONITORING TECHNIQUES USED FOR DIRECT AIR MONITORING OR FOLLOWING RADIOCHEMICAL ANALYSIS AND GAMMA X-RAY MONITORING TECHNIQUES FOR SURVEYING POSSIBLE CONTAMINATION OF AREAS OR HUMANS.
- 20-3-4-294 REVIEW OF FIRE PROTECTION IN THE NUCLEAR FACILITIES OF THE ATOMIC ENERGY COMMISSION, 1947-1975  
MAYBEE, W. W.  
U.S. DEPARTMENT OF ENERGY, WASHINGTON, D.C.  
IN THE 28 YEARS IN WHICH IT GREW FROM A TEMPORARY WAR TIME BOMB DEVELOPMENT PROGRAM TO A FEDERAL AGENCY WITH OVER \$3' BILLION WORTH OF FACILITIES HOUSING MUCH OF THE NATION'S ADVANCED RESEARCH EFFORTS, THE ATOMIC ENERGY COMMISSION SET MANY RECORDS FOR SAFETY. AMONG THE BEST WAS A CUMULATIVE FIRE LOSS RATIO OF 1.2 CENTS PER \$100 OF VALUE. A 1969 FIRE - ONE OF FOUR IN ITS HISTORY THAT EXCEEDED \$1 MILLION IN LOSS - INCURRED DAMAGES TOTALING \$26 MILLION AND PROMPTED MAJOR ADDITIONS TO ITS FIRE PROTECTION PROGRAMS. THE ADDED PROGRAMS ENCOMPASSING ADDITIONAL FIRE PROTECTION ENGINEERS, NEW PROTECTION SYSTEMS, INDEPENDENT INSPECTION PROGRAMS, AND NEW PERFORMANCE BASED GOALS, RESULTED IN AN ORDER OF MAGNITUDE IMPROVEMENT. THE CUMULATIVE FIRE LOSS RATIO AFTER 1969 WAS 0.06 CENTS PER \$100 OF VALUE, A RECORD FEW INDUSTRIES HAVE EVER ACHIEVED.
- 20-3-4-308 NUCLEAR PLANT FIRE INCIDENT DATA FILE  
SIDERIS, A. G. \* HOCKENRURY, R. W.  
YEATER, M. L. \* VESELY, W. E.  
AMERICAN NUCLEAR INSURERS, FARMINGTON, CONN. / RENSSELAER POLYTECHNIC INSTITUTE, TROY, N.Y. / U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
A COMPUTERIZED NUCLEAR PLANT FIRE INCIDENT DATA FILE WAS DEVELOPED BY AMERICAN NUCLEAR INSURERS AND WAS FURTHER ANALYZED BY RENSSELAER POLYTECHNIC INSTITUTE WITH TECHNICAL AND MONETARY SUPPORT PROVIDED BY THE NUCLEAR REGULATORY COMMISSION. DATA ON 214 FIRES THAT OCCURRED AT NUCLEAR FACILITIES HAVE BEEN ENTERED IN THE FILE. A COMPUTER PROGRAM HAS BEEN DEVELOPED TO SORT THE FIRE INCIDENTS ACCORDING TO VARIOUS PARAMETERS. THE PARAMETRIC SORTS THAT ARE PRESENTED IN THIS ARTICLE ARE SIGNIFICANT SINCE THEY ARE THE MOST COMPREHENSIVE STATISTICS PRESENTLY AVAILABLE ON FIRES THAT HAVE OCCURRED AT NUCLEAR FACILITIES.
- 20-3-5-319 RADIOLOGICAL IMPACT OF THORIUM MINING AND MILLING  
MEYER, H. E. \* TILL, J. E. \* BONAR, E. S.  
BOND, W. D. \* MORSE, L. E. \* TENNEY, V. J.  
YALCINTAS, M. G.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
IMPLEMENTATION OF AN ALTERNATE FUEL USAGE SCHEME INVOLVING URANIUM-233 WOULD REQUIRE VERY LARGE INCREASES IN THORIUM-232 PRODUCTION RATES, PROBABLY NECESSITATING THE MINING OF THORITE (ThSiO<sub>4</sub>) FROM WESTERN U.S. DEPOSITS. THIS ARTICLE REVIEWS CURRENT ESTIMATES OF THE EXTENT OF THAT RESOURCE AND ESTIMATES THE RADIOLOGICAL IMPACT OF OPERATING A THORIUM MINE AND MILL IN THE REGION. RADIOLOGICAL DOSES TO A HYPOTHETICAL MAXIMALLY EXPOSED INDIVIDUAL LOCATED 1.6 KM FROM THE SITE ARE ESTIMATED

TO BE 2.4 MREMS (TO TOTAL BODY), 9.5 MREMS (TO BONE), AND 35.3 MREMS (TO LUNGS). THESE DOSES ARE DUE PRIMARILY TO INGESTION AND INHALATION OF RADON-220 DAUGHTERS, RADIUM-228 AND THORIUM-232. DOSES TO THE GENERAL POPULATION IN THE AREA SURROUNDING THE SITE AND POSTOPERATIONAL DOSES DUE TO TAILINGS PILE RELEASES ARE ALSO CALCULATED.

- 20-3-5-330 RECOMMENDATIONS OF THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
EDITOR'S NOTE - THE FOLLOWING ADAPTATION BY THE NUCLEAR SAFETY EDITORIAL STAFF WAS MADE FROM A MUCH LONGER REPORT OF THE SAME NAME (ICRP PUBLICATION 26). THE REPORT IS AN AUTHORITATIVE SOURCE OF INFORMATION ON RISK ESTIMATES OF ILL HEALTH ASSOCIATED WITH IONIZING RADIATION AND PROVIDES AN ESTABLISHED BASIS FOR RADIATION PROTECTION ACTIONS AND POLICIES BOTH IN THIS COUNTRY AND ELSEWHERE. A SUMMARY IS PRESENTED HERE TO PROVIDE A PENETRATING INSIGHT INTO THIS IMPORTANT AREA.
- 20-3-6-345 OCCUPATIONAL RADIATION EXPOSURE FROM THE U.S. NAVAL REACTOR PROGRAM, 1977  
MILES, M. E.  
DEPARTMENT OF THE NAVY, WASHINGTON, D.C. 20362  
EDITOR'S NOTE - THIS ARTICLE IS ADAPTED FROM THE REPORT, OCCUPATIONAL RADIATION EXPOSURE FROM U.S. NAVAL NUCLEAR PROPULSION PLANTS AND THEIR SUPPORT FACILITIES, NT-78-2, NAVAL SEA SYSTEMS COMMAND, DEPARTMENT OF THE NAVY, MARCH 1978. THE ADAPTATION HERE INCLUDES EXCERPTS IN WHICH THE WORKING IS SUBSTANTIALLY THE SAME AS THAT IN THE NAVY REPORT, WHICH WAS CONSIDERABLY LONGER. THE ARTICLE IS INCLUDED HERE, SINCE THE SUBJECT OF OCCUPATIONAL EXPOSURES IS BECOMING OF INCREASING INTEREST WITH RESPECT TO COMMERCIAL NUCLEAR POWER EXPERIENCE. THE AVERAGE OCCUPATIONAL EXPOSURE IN THE NAVY PROGRAM IN 1977 WAS ABOUT 1/4 REM PER PERSON, WHICH IS LESS THAN THE AVERAGE ANNUAL OCCUPATIONAL EXPOSURE FOR PERSONNEL AT NUCLEAR REGULATORY COMMISSION (NRC) LICENSEE STATIONS (0.36 REM PER PERSON IN 1976 AND IS DECREASING).
- 20-4-1-387 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS - ITS ROLE IN NUCLEAR SAFETY  
LAWROSKI, S. + MOELLER, D. W.  
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL. / HARVARD UNIVERSITY, BOSTON, MASS.  
FOR OVER 25 YEARS THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) HAS HAD A CONTINUING RESPONSIBILITY FOR CONDUCTING INDEPENDENT REVIEWS AND EVALUATIONS OF THE HEALTH AND SAFETY ASPECTS OF NUCLEAR POWER REACTORS, SPENT-FUEL REPROCESSING PLANTS, AND ASSOCIATED ACTIVITIES, WHICH INCLUDE EVALUATION OF ABNORMAL OCCURRENCES AND PROPOSED CHANGES AT OPERATING FACILITIES, THE ADEQUACY OF RELATED SAFETY STANDARDS AND CRITERIA, THE ADEQUACY OF THE RELATED SAFETY RESEARCH PROGRAMS, AND SPECIFIC GENERIC QUESTIONS, SUCH AS THE RELIABILITY OF REACTOR PRESSURE VESSELS. THE ACRS NORMALLY ISSUES 40 TO 50 REPORTS ON SPECIFIC NUCLEAR FACILITIES AND SAFETY-RELATED QUESTIONS EACH YEAR. TOPICS DISCUSSED IN THIS ARTICLE INCLUDE THE VIEWS AND THOUGHTS OF THE ACRS WITH RESPECT TO EMERGENCY CORE-COOLING SYSTEMS, ANTICIPATED TRANSIENTS WITHOUT SCRAM, REACTOR PRESSURE VESSEL FAILURE, TURBINE MISSTLES, STEAMLINE BREAKS, SEISMICITY, ENVIRONMENTAL MONITORING, EMERGENCY PLANNING, WASTE MANAGEMENT, SITING, AND REACTOR SAFETY RESEARCH.
- 20-4-1-399 1978 ACRS CRITIQUE OF NRC SAFETY RESEARCH PROGRAM  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS / U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
EDITOR'S NOTE: AS REQUIRED BY STATUTE (SECTION 5 OF PUBLIC LAW 95-204), THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) ANNUALLY REVIEWS AND EVALUATES THE NRC SAFETY RESEARCH PROGRAM. THE FIRST SUCH REVIEW WAS CONDUCTED IN 1977, AND A REPORT WAS SUBMITTED TO CONGRESS IN DECEMBER 1977. EXCERPTS FROM THAT REPORT WERE PUBLISHED IN NUCLEAR SAFETY. THE EXECUTIVE SUMMARY OF THE 1978 REVIEW, WHICH WAS INCLUDED IN THE REPORT SENT TO CONGRESS IN DECEMBER 1978, IS GIVEN HERE. AS IN ITS FIRST REPORT, THE ACRS HAS INTERPRETED THE WORDS "REACTOR SAFETY RESEARCH" AS USED IN THE ENABLING LEGISLATION TO INCLUDE SAFETY-RELATED RESEARCH IN ALL PHASES OF THE NUCLEAR CYCLE.
- 20-4-2-402 THE MECHANISTIC ANALYSIS OF LMFBR ACCIDENT ENERGETICS  
BOUDREAU, J. E.  
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, N.M.  
THE STATE OF THE ART IS REVIEWED FOR LIQUID-METAL-COOLED FAST REACTOR (LMFBR) POSTDISASSEMBLY ENERGETICS ANALYSIS. PREVIOUS ATTEMPTS HAVE PROVIDED BOUNDING AND CONSERVATIVE EFFICIENCY ESTIMATES FOR CONVERTING FISSION ENERGY INTO PRIMARY-SYSTEM DAMAGE. HOWEVER, CALCULATIONAL RESULTS USING THE SIMMER-II CODE INDICATE THAT CURRENT U.S. PRIMARY-SYSTEM DESIGNS MAY WITHSTAND SUBSTANTIALLY LARGER REACTIVITY INSERTION RATES THAN PREVIOUSLY THOUGHT. DETAILED RESULTS ARE PRESENTED FOR THE ENERGETICS RESULTING FROM A VOIDED-CORE EXPANSION, ALONG WITH A DISCUSSION OF CODE-VERIFICATION ACTIVITIES. FURTHER RESULTS ARE PRESENTED FOR EXPANSIONS INVOLVING OTHER INITIAL AND BOUNDARY CONDITIONS, AND THE IMPORTANCE OF THE SODIUM INITIALLY PRESENT IN THE CORE IS DEFINED. FINALLY, THE



RANGE OF REACTIVITY INSERTION RATES THAT THE PRIMARY SYSTEM CAN ACCOMMODATE IS ESTIMATED FOR THE VOIDED-CORE CASE, AND THE REMAINING TECHNICAL ISSUES ARE DEFINED.

20-4-3-422

ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER REACTORS  
FRADANT, A. C. + HAGEN, E. W.  
U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C. / OAK RIDGE  
NATIONAL LABORATORY, OAK RIDGE, TENN.

THIS ARTICLE SUMMARIZES AN NRC STAFF REPORT (NUREG-0460) WHICH REVIEWS AND EVALUATES THE INFORMATION NOW AVAILABLE ON THE SUBJECT OF ANTICIPATED TRANSIENTS WITHOUT SCRAM (ATWS), IN PARTICULAR, THE MATERIAL DEVELOPED SUBSEQUENT TO THE PUBLICATION OF THE PREVIOUS STATUS REPORTS BY THE STAFF, WHICH WERE CRITICIZED BY THE NUCLEAR INDUSTRY. REPORT NUREG-0460 IS, IN PART, A RESPONSE TO THAT INDUSTRY CRITICISM; IT IS A STATEMENT OF THE CURRENT POSITION OF THE DGS STAFF REGARDING THE TREATMENT OF ATWS EVENTS IN THE SAFETY EVALUATION OF NUCLEAR POWER PLANTS AND AN EXPOSITION OF THE BASES FOR THAT POSITION. THE STAFF RECOMMENDS THE PROVISION OF SYSTEMS TO MITIGATE THE CONSEQUENCES OF ATWS EVENTS, SHOULD THEY OCCUR, AS THE MOST PROMISING ALTERNATIVE FOR MEETING THE SAFETY OBJECTIVE. THE REPORT CONSISTS OF THE MAIN BODY OF TEXT, APPENDICES IN WHICH THE DETAILS OF THE BASES FOR THE STAFF'S PROPOSED RECOMMENDATIONS ARE DISCUSSED, AND A SUPPLEMENT WHICH PROPOSES A COURSE OF ACTION FOR RESOLVING PROBLEMS RELATING TO ATWS.

20-4-4-434

RADIOACTIVE WASTE MANAGEMENT AT THE HANFORD RESERVATION  
NATIONAL ACADEMY OF SCIENCES  
WASHINGTON, D.C.

DURING SOME 30 YEARS OF PLUTONIUM PRODUCTION, THE HANFORD RESERVATION HAS ACCUMULATED LARGE QUANTITIES OF LOW- AND HIGH-LEVEL RADIOACTIVE WASTES. THE HIGH-LEVEL WASTES HAVE BEEN STORED IN UNDERGROUND TANKS, AND THE LOW-LEVEL WASTES HAVE BEEN PERCOLATED INTO THE SOIL. IN RECENT YEARS SOME PROGRAMS FOR SOLIDIFICATION AND SEPARATION OF THE HIGH-LEVEL WASTES HAVE BEEN INITIATED. THE HANFORD WASTE-MANAGEMENT SYSTEM WAS STUDIED BY A PANEL OF THE COMMITTEE ON RADIOACTIVE WASTE MANAGEMENT OF THE NATIONAL ACADEMY OF SCIENCES. THE PANEL CONCLUDED THAT HANFORD WASTE-MANAGEMENT PRACTICES WERE ADEQUATE AT PRESENT AND FOR THE IMMEDIATE FUTURE BUT RECOMMENDED INCREASED RESEARCH AND DEVELOPMENT PROGRAMS RELATED TO LONG-TERM ISOLATION OF THE WASTES. THE PANEL ALSO CONSIDERED SOME ALTERNATIVES FOR ON-SITE DISPOSAL OF THE WASTES. THE HANFORD RESERVATION WAS ORIGINALLY ESTABLISHED FOR THE PRODUCTION OF PLUTONIUM FOR MILITARY PURPOSES. DURING MORE THAN 30 YEARS OF OPERATION, LARGE VOLUMES OF HIGH- AND LOW-LEVEL RADIOACTIVE WASTES HAVE BEEN ACCUMULATED AND CONTAINED AT THE SITE. THE MANAGEMENT OF THESE WASTES HAS BEEN THE SUBJECT OF CONTROVERSY AND CRITICISM. TO OBTAIN A TRUE TECHNICAL EVALUATION OF THE HANFORD WASTE SITUATION, THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (NOW PART OF THE DEPARTMENT OF ENERGY) ISSUED A CONTRACT TO THE NATIONAL ACADEMY OF SCIENCES AND THE NATIONAL RESEARCH COUNCIL TO "CONDUCT AN INDEPENDENT REVIEW AND EVALUATION OF THE HANFORD WASTE-MANAGEMENT PRACTICES AND PLANS." A PANEL OF THE COMMITTEE ON RADIOACTIVE WASTE MANAGEMENT (CRWM) OF THE NATIONAL ACADEMY OF SCIENCES CONDUCTED THIS STUDY BETWEEN THE SUMMER OF 1976 AND THE SUMMER OF 1977. THIS ARTICLE IS A SUMMARY OF THE FINAL REPORT OF THAT PANEL.

20-4-5-446

ENVIRONMENTAL MONITORING AND DISPOSAL OF RADIOACTIVE WASTE FROM NAVAL NUCLEAR VESSELS AND SUPPORT FACILITIES IN 1978  
MILES, M. E. + SJOBLOM, G. L. + EAGLES, J. D.  
DEPARTMENT OF THE NAVY, WASHINGTON, D.C.

THE ENVIRONMENTAL EFFECT OF DISPOSAL OF RADIOACTIVE WASTES ORIGINATING FROM THE U.S. NAVY'S NUCLEAR PROPULSION PLANTS AND THEIR SUPPORT FACILITIES IS ASSESSED. THE TOTAL GAMMA RADIOACTIVITY IN LIQUIDS, LESS TRITIUM, DISCHARGED TO ALL PORTS AND HARBORS FROM THE MORE THAN 100 NAVAL NUCLEAR-POWERED SHIPS AND SUPPORTING TENDERS AND FROM NAVAL BASES AND SHIPYARDS WAS LESS THAN 0.002 CI IN 1978. THE TOTAL AMOUNT OF TRITIUM RELEASED TO ALL PORTS AND HARBORS WAS LESS THAN 1 CI IN 1978. THIS ARTICLE CONFIRMS THAT THE PROCEDURES USED BY THE U.S. NAVY TO CONTROL RELEASES OF RADIOACTIVITY FROM ITS NUCLEAR-POWERED SHIPS AND THEIR SUPPORT FACILITIES ARE EFFECTIVE IN PROTECTING THE ENVIRONMENT AND THE HEALTH AND SAFETY OF THE GENERAL PUBLIC.

20-4-5-458

AN ANALYSIS OF NRC METHODS FOR ESTIMATING THE EFFECTS OF DRY DEPOSITION IN ENVIRONMENTAL RADIOLOGICAL ASSESSMENTS

MILLER, C. W. + HOFFMAN, F. O.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

THE METHODS CONTAINED IN METEOROLOGY AND ATOMIC ENERGY - 1968, WHICH ARE COMMONLY USED FOR ESTIMATING THE EFFECTS OF DRY DEPOSITION IN RADIOLOGICAL ASSESSMENTS, HAVE BEEN COMPARED TO THE METHODS CONTAINED IN NUCLEAR REGULATORY COMMISSION (NRC) REGULATORY GUIDE 1.111. ALTHOUGH DESIGNED FOR USE WHEN DETERMINING COMPLIANCE WITH TITLE 10, CODE OF FEDERAL REGULATIONS, PART 50, APPENDIX 1 FOR LIGHT-WATER-COOLED REACTORS, THE NRC GUIDE HAS THE POTENTIAL OF BEING USED FOR OTHER TYPES OF NUCLEAR REACTORS AND FOR NUCLEAR FACILITIES AS WELL. THIS COMPARISON HAS RAISED A NUMBER OF CONCERNS ABOUT THE

NRC APPROACH: 1. DEPOSITION RATE ESTIMATES ARE INDEPENDENT OF THE USER'S CALCULATED AIR CONCENTRATION. 2. DEPOSITION ESTIMATES FOR ELEVATED RELEASES SEEM TOO HIGH CLOSE TO THE SOURCE. 3. THE PLUME DEPLETION CURVES IN THE GUIDE DO NOT BEHAVE AS EXPECTED RELATIVE TO THE COMMONLY USED PLUME DEPLETION METHOD. IN VIEW OF THESE CONCERNS, IT IS RECOMMENDED THAT OTHER, SIMPLER APPROACHES TO THESE PROCESSES BE CONSIDERED FOR RADIOLOGICAL ASSESSMENT PURPOSES.

- 20-4-5-468 RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS AND FUEL REPROCESSING PLANTS IN EUROPE, 1972-1976  
DAVIS, JR., W.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
DATA ON THE RADIOACTIVE GASBORNE AND LIQUID EFFLUENTS FROM 58 NUCLEAR POWER STATIONS AND 7 FUEL REPROCESSING PLANTS IN THE EUROPEAN COMMUNITY FOR THE YEARS 1972-1976 ARE PRESENTED. THERE ARE WIDE VARIATIONS IN RELEASES FROM BOTH REACTOR STATIONS AND FUEL REPROCESSING PLANTS BECAUSE OF DIFFERENCES IN REACTOR TYPE, PLANT SIZE, POWER LEVELS, AND EFFLUENT TREATMENT LEVELS. DATA COVERING SPECIFIC ISOTOPES OF PARTICULAR INTEREST ARE SUMMARIZED. IN NEARLY ALL CASES, RELEASES OF RADIOACTIVITY WERE BELOW MAXIMUM APPLICABLE VALUES OR THE TREATMENTS USED WERE CONSIDERED TO SATISFY THE REQUIREMENT THAT THE BEST PRACTICABLE MEANS BE USED TO MINIMIZE THE AMOUNT OF RADIOACTIVITY DISCHARGED. THIS ARTICLE IS ADAPTED FROM AN APRIL 1978 REPORT PREPARED BY THE COMMISSION OF THE EUROPEAN COMMUNITIES.
- 20-4-6-476 RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN 1977  
DECKER, T. B.  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D. C.  
RELEASES OF RADIOACTIVE MATERIALS IN AIRBORNE AND LIQUID EFFLUENTS FROM COMMERCIAL LIGHT-WATER REACTORS DURING 1977, AS WELL AS DATA ON SOLID-WASTE SHIPMENTS, HAVE BEEN COMPILED AND REPORTED. THIS REPORT SUPPLEMENTS EARLIER ONES ISSUED BY THE FORMER ATOMIC ENERGY COMMISSION AND THE NUCLEAR REGULATORY COMMISSION. THE 1977 RELEASE DATA ARE COMPARED WITH THE RELEASES OF PREVIOUS YEARS IN TABULAR FORM. DATA COVERING SPECIFIC RADIONUCLIDES ARE SUMMARIZED.
- 20-4-6-483 PRELIMINARY REPORT ON THE THREE MILE ISLAND INCIDENT  
CASTO, W. R. + CUTTRELL, W. ...  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
ABOUT 4:00 A.M. ON MAR. 28, 1979, UNIT 2 AT THE THREE MILE ISLAND NUCLEAR POWER STATION EXPERIENCED A TURBINE TRIP. THE SUBSEQUENT SEQUENCE OF EVENTS INVOLVING HUMAN ERRORS, DESIGN DEFICIENCIES, AND EQUIPMENT FAILURES RESULTED IN AN ACCIDENT UNIQUE IN REACTOR OPERATING EXPERIENCE TO DATE. ALTHOUGH NO ONE WAS INJURED BY THIS INCIDENT, IT HAS RESULTED IN INCREASED CONCERN FOR THE NUCLEAR OPTION AND HAS PROMPTED NUMEROUS INVESTIGATIONS. THIS PRELIMINARY REPORT SUMMARIZES THE STATUS OF THE PLANT AND RELATED ACTIVITIES THROUGH APRIL 30, PRIMARILY ON THE BASIS OF INFORMATION FROM NUCLEAR REGULATORY COMMISSION (NRC) PRESS RELEASES, PRELIMINARY NOTIFICATION OF OCCURRENCE MEMORANDUMS, AND INSPECTION AND ENFORCEMENT BULLETINS. NO CONCLUSIONS ARE DRAWN AT THIS TIME, BUT THE INCIDENT WILL BE FULLY COVERED IN A SUBSEQUENT ARTICLE WHEN THE FINDINGS FROM SOME OF THE MORE SUBSTANTIVE INVESTIGATING COMMITTEES BECOME AVAILABLE.
- 20-5-1-525 A COST-BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY PROTECTIVE MEASURES AND REGULATIONS  
O'DONNELL, E. P. + MAURO, J. J.  
EBASCO SERVICES, INC., NEW YORK, N.Y.  
THIS ARTICLE COMPARES THE COSTS AND BENEFITS OF HEALTH AND SAFETY MEASURES AND REGULATIONS IN THE NUCLEAR AND NONNUCLEAR FIELDS. A COST-BENEFIT METHODOLOGY FOR NUCLEAR SAFETY CONCERNS IS PRESENTED AND APPLIED TO EXISTING NUCLEAR PLANT ENGINEERED SAFETY FEATURES. COMPARISONS IN TERMS OF INVESTMENT COSTS TO ACHIEVE REDUCTIONS IN MORTALITY RATES ARE THEN MADE BETWEEN NUCLEAR PLANT SAFETY FEATURES AND THE PROTECTIVE MEASURES AND REGULATIONS ASSOCIATED WITH NONNUCLEAR RISKS, PARTICULARLY WITH COAL-FIRED POWER PLANTS. THESE COMPARISONS REVEAL A MARKED INCONSISTENCY IN THE COST-EFFECTIVENESS OF HEALTH AND SAFETY POLICY, IN WHICH NUCLEAR REGULATORY POLICY REQUIRES MUCH GREATER INVESTMENTS TO REDUCE THE RISK OF PUBLIC MORTALITY THAN IS REQUIRED IN NONNUCLEAR AREAS WHERE REDUCTIONS IN MORTALITY RATES COULD BE ACHIEVED AT MUCH LOWER COST. A SPECIFIC EXAMPLE OF REGULATORY DISPARITY REGARDING GASEOUS EFFLUENT LIMITS FOR NUCLEAR AND FOSSIL-FUEL POWER PLANTS IS PRESENTED. IT IS CONCLUDED THAT A CONSISTENT HEALTH AND SAFETY REGULATORY POLICY BASED ON UNIFORM RISK AND COST-BENEFIT CRITERIA SHOULD BE ADOPTED AND THAT FUTURE PROPOSED NUCLEAR REGULATORY COMMISSION REGULATORY REQUIREMENTS SHOULD BE CRITICALLY EVALUATED FROM A COST-BENEFIT VIEWPOINT.
- 20-5-2-541 SYSTEM RELIABILITY ENGINEERING METHODOLOGY - A DISCUSSION OF THE STATE OF THE ART  
FUSSELL, J. B. + ARENDT, J. S.  
UNIVERSITY OF TENNESSEE, KNOXVILLE, TENN. / J&F ASSOCIATES, INC., KNOXVILLE, TENN.  
THE SYSTEM RELIABILITY ENGINEERING METHODOLOGY THAT IS IN GENERAL USE FOR NUCLEAR SYSTEMS APPLICATIONS IS DISCUSSED. NO EFFORT IS MADE TO ADDRESS THE PRESENT STATE OF THEORETICAL DEVELOPMENT; THE APPROACHES COVERED ARE THOSE WHICH HAVE BEEN

TESTED BY EXTENSIVE APPLICATION. SINCE NUCLEAR SYSTEMS RELIABILITY ENGINEERING FREQUENTLY INVOLVES TOO MUCH INFORMATION FOR MANUAL PROCESSING TECHNIQUES, THIS ARTICLE LISTS SOME OF THE AVAILABLE COMPUTER PROGRAMS THAT CAN BE USED TO PROVIDE INPUT TO THE ENGINEERING EFFORT. ALSO, SEVERAL THEORETICAL PROBLEMS ARE PRESENTED THAT CAN RESULT IN ERRONEOUS CONCLUSIONS AND RECOMMENDATIONS WHEN CERTAIN ANALYSIS PROCEDURES ARE USED.

- 20-5-2-551 COUPLED FLUID STRUCTURE ANALYSIS FOR LWRs IN THE FEDERAL REPUBLIC OF GERMANY  
SCHLICHTENDAH, E. G.  
INSTITUT FÜR REAKTORENTWICKLUNG, FEDERAL REPUBLIC OF GERMANY  
THE DEVELOPMENT OF LARGE COMMERCIAL LIGHT-WATER REACTORS FOR ELECTRIC-POWER GENERATION IN THE FEDERAL REPUBLIC OF GERMANY IS ACCOMPANIED BY A BROAD PROGRAM FOR INVESTIGATION OF THE SAFETY ASPECTS OF NUCLEAR PLANTS. CONSIDERABLE EFFORT IS DEVOTED TO THE ANALYSIS OF TRANSIENT LOADS ON CRITICAL REACTOR COMPONENTS DURING ABNORMAL CONDITIONS AND THE RESPONSE OF THE COMPONENTS TO SUCH LOADS. THIS REVIEW CONCENTRATES ON THOSE SITUATIONS AND COMPONENTS WHERE THE INTERACTION OF FLUID AND STRUCTURES MUST BE TAKEN INTO ACCOUNT IN A BEST-ESTIMATE ANALYSIS. IN THESE CASES AN UNCOUPLED ANALYSIS WOULD PRODUCE UNREALISTIC - THOUGH GENERALLY CONSERVATIVE - RESULTS. THE WORK OF SEVERAL ORGANIZATIONS IS CLOSELY COORDINATED, BOTH WITH RESPECT TO CODE DEVELOPMENT AND WITH RESPECT TO CODE ASSESSMENT USING RESULTS FROM LARGE-SCALE EXPERIMENTS.
- 20-5-3-564 A NEW APPROACH TO THE PROBLEMS OF ELECTRICAL INTERFERENCE IN INSTRUMENTATION AND CONTROL SYSTEMS  
WILSON, I.  
ATOMIC ENERGY ESTABLISHMENT, WINFRITH, DORCHESTER, DORSET, ENGLAND  
IN THE CONTEXT OF NUCLEAR REACTOR CONTROL AND SAFETY, ELECTRICAL INTERFERENCE CAN BE POTENTIALLY DETRIMENTAL, SOMETIMES IN SUBTLE WAYS. THE MOST PROLIFIC DISTURBANCES ARE GENERATED BY SWITCHING MAINS-POWERED EQUIPMENT, THE LOCAL GROUND STRUCTURE CONSTITUTING A MAJOR COUPLING PATH VIA WHICH HIGH-FREQUENCY TRANSIENTS CAN AFFECT ELECTRONIC SYSTEMS. WHEN DESIGN CONSIDERATIONS ARE OUTLINED, THE ADVANTAGES OF USING IMPROVED SCREENED COMPONENTS, SUCH AS SUPERSCREENED CABLES, VIRTUALLY TO ELIMINATE INTERFERENCE PROBLEMS BECOME CLEAR. PROCEDURES FOR MEASURING THE INTERFERENCE IMMUNITY OF EQUIPMENT AND OF INSTALLED SYSTEMS IN SITU HAVE BEEN DEVELOPED. THEY PROVIDE POWERFUL DIAGNOSTIC, QUALITY CONTROL, AND COMMISSIONING AIDS. SEVERAL CASE HISTORIES ARE PRESENTED TO ILLUSTRATE HOW THE ESSENTIAL PRINCIPLES HAVE BEEN APPLIED SUCCESSFULLY IN PRACTICE AND TO DEMONSTRATE THAT ELECTRICAL INTERFERENCE NEED NO LONGER BE A PROBLEM.
- 20-5-5-582 UNIQUE ECOLOGICAL IMPACTS ASSOCIATED WITH OFFSHORE FLOATING NUCLEAR POWER PLANTS  
ADAMS, S. M. + MCLEAN, E. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
THE ECOLOGICAL IMPACTS THAT COULD OCCUR AS A RESULT OF SITE CONSTRUCTION AND OPERATION OF AN OFFSHORE FLOATING NUCLEAR POWER PLANT ARE IDENTIFIED BY COMPARING THE PRINCIPAL ECOLOGICAL FEATURES ASSOCIATED WITH OFFSHORE SITING WITH THOSE ASSOCIATED WITH THE SITING OF ONSHORE ESTUARINE PLANTS. IN GENERAL, THE ECOLOGICAL IMPACTS OF OFFSHORE NUCLEAR PLANTS SHOULD BE RELATIVELY SMALLER THAN THOSE OF ESTUARINE PLANTS. POSSIBLE FACTORS THAT COULD INCREASE THE RELATIVE IMPACTS OF OFFSHORE PLANTS ARE HIGH FREQUENCY OF CONTACT WITH SCHOOLS OF FISH, SITING NEAR INLETS TO ESTUARIES OR OTHER ECOLOGICALLY IMPORTANT AREAS, AND THE PERSISTENCE OF HALOGEN RESIDUALS. IDENTIFYING THE POTENTIAL ECOLOGICAL IMPACTS ASSOCIATED WITH THE SITING OF OFFSHORE PLANTS PERMITS THE DEVELOPMENT OF VARIOUS MONITORING PROGRAMS AND MEASURES TO MINIMIZE THESE IMPACTS.
- 20-5-5-591 PRELIMINARY DOSE AND HEALTH IMPACT OF THE ACCIDENT AT THE THREE MILE ISLAND NUCLEAR STATION  
AD HOC POPULATION DOSE ASSESSMENT GROUP COMPOSED OF THE NUCLEAR REGULATORY COMMISSION, THE DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE, AND THE ENVIRONMENTAL PROTECTION AGENCY / WASHINGTON, D.C.  
EDITOR'S NOTE: THE AD HOC POPULATION DOSE ASSESSMENT GROUP IS COMPOSED OF MEMBERS OF THE NUCLEAR REGULATORY COMMISSION, THE DEPARTMENT OF HEALTH, EDUCATION, AND WELFARE, AND THE ENVIRONMENTAL PROTECTION AGENCY. THIS GROUP HAS EXAMINED THE AVAILABLE DATA FOR THE PERIOD FOLLOWING THE ACCIDENT AND HAS CONCLUDED THAT THE OFF-SITE COLLECTIVE DOSE ASSOCIATED WITH THE RADIOACTIVE MATERIAL REPRESENTS MINIMAL RISKS OF ADDITIONAL HEALTH EFFECTS TO THE OFF-SITE POPULATION, E.G., AN INCREASE OF 1 CANCER DEATH OVER THE 325,000 WHICH WOULD OTHERWISE BE EXPECTED. FURTHERMORE, THE COLLECTIVE DOSE WILL NOT BE SIGNIFICANTLY INCREASED BY EXTENDING THE PERIOD PAST APRIL 7. THE 100-PAGE REPORT OF THE AD HOC GROUP, DATED MAY 10, 1979, IS ON SALE BY THE SUPERINTENDENT OF DOCUMENTS, U.S. GOVERNMENT PRINTING OFFICE, WASHINGTON, D. C. 20540, STOCK NUMBER 017-001-00408-1. PRESENTED HERE IS THE SUMMARY AND DISCUSSION OF FINDINGS FROM THAT REPORT.

- 20-5-6-595 STEAM GENERATOR TUBE PERFORMANCE - WORLD EXPERIENCE WITH WATER COOLED NUCLEAR POWER REACTORS DURING 1977  
PATRANIA, R. S. + TATONE, G. S.  
CHALK RIVER NUCLEAR LABORATORIES, ONTARIO, CANADA  
THE PERFORMANCE OF STEAM-GENERATOR TUBES IN WATER-COOLED NUCLEAR POWER REACTORS IN VARIOUS COUNTRIES IS REVIEWED FOR 1977. TUBE FAILURES WERE REPORTED AT 34 OF THE 79 REACTORS SURVEYED. THE CAUSES OF THESE FAILURES AND THE INSPECTION AND REPAIR PROCEDURES DESIGNED TO DEAL WITH THEM ARE PRESENTED. ALTHOUGH DENTING CAUSED BY CORROSION REMAINED THE LEADING CAUSE OF TUBE FAILURES, SPECIFIC MECHANISMS HAVE BEEN IDENTIFIED, AND METHODS OF DEALING WITH THEM HAVE BEEN DEVELOPED. THESE METHODS ARE BEING APPLIED AND SHOULD LEAD TO A REDUCTION OF CORROSION FAILURES IN THE FUTURE.
- 20-5-6-613 DEVELOPMENTS PERTAINING TO THE THREE MILE ISLAND ACCIDENT  
COTTRELL, W. B.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
A PRELIMINARY REPORT ON THE THREE MILE ISLAND ACCIDENT OF MARCH 28, 1979, WAS INCLUDED IN THE PREVIOUS ISSUE OF NUCLEAR SAFETY. AS WAS STATED IN THAT ARTICLE, A FINAL REPORT ON THE ACCIDENT WILL BE PRESENTED IN NUCLEAR SAFETY WHEN THE VARIOUS INVESTIGATING COMMITTEES REPORT ON THEIR FINDINGS. MOST OF THESE REPORTS SHOULD BE AVAILABLE BY THE END OF THE YEAR. HOWEVER, SOME OF THE DEVELOPMENTS OF THE PAST 2 MONTHS PERTAINING TO THE ACCIDENT ARE OF GENERAL INTEREST AND WILL BE SUMMARIZED HERE. NO ATTEMPT IS MADE HERE TO PRESENT A COMPREHENSIVE REVIEW OF THE ACCIDENT NOR EVEN TO EVALUATE THE MATERIAL THAT HAS BECOME AVAILABLE; RATHER, GIVEN THE INTEREST IN THE SUBJECT, THIS ARTICLE WILL MERELY CALL ATTENTION TO THE AVAILABLE INFORMATION. (IN ADDITION, THE REPORT BY THE AD HOC DOSE ASSESSMENT GROUP IS SUMMARIZED IN THE PREVIOUS SECTION OF THIS ISSUE OF NUCLEAR SAFETY.) THE DEVELOPMENTS REPORTED HERE FALL INTO THE FOLLOWING TOPICS: LESSONS LEARNED TASK FORCE, ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS) REPORTS ON THREE MILE ISLAND, CONGRESSIONAL INVESTIGATIONS, METROPOLITAN EDISON COMPANY INTERIM REPORT, NUCLEAR REGULATORY COMMISSION (NRC) REPORT ON BARCOCK AND WILCOX (B+W) FEEDWATER TRANSIENTS, TENNESSEE VALLEY AUTHORITY (TVA) NUCLEAR PROGRAM REVIEW, RADIOACTIVITY SAMPLING, LIABILITY INSURANCE PAYMENTS, AND A CATCHALL HEADING ENTITLED MISCELLANEOUS ACTIONS OF NOTE.
- 20-6-1-655 EDUCATION AND PUBLIC ACCEPTANCE OF NUCLEAR POWER PLANTS  
DELCOIGNE, G.  
INTERNATIONAL ATOMIC ENERGY AGENCY, VIENNA, AUSTRIA  
EDITOR'S NOTE - THE FOLLOWING ARTICLE WAS ADAPTED FROM A TALK BY MR. DELCOIGNE WHICH WAS PRESENTED AT THE EUROPEAN NUCLEAR SOCIETY/AMERICAN NUCLEAR SOCIETY (ENS/ANS) INTERNATIONAL TOPICAL MEETING ON NUCLEAR POWER REACTOR SAFETY HELD IN BRUSSELS, BELGIUM, OCT. 16-19, 1978. THOSE FAMILIAR WITH THE TOPIC WILL FIND NOTHING NEW IN THIS ARTICLE, BUT THE DISCUSSION OF THIS TOPIC FROM THE EUROPEAN PERSPECTIVE PROVIDES AMPLE EVIDENCE OF THE COMMONALITY OF THE PROBLEM ON BOTH SIDES OF THE ATLANTIC. FURTHERMORE, THE ARTICLE IS WELL DOCUMENTED NOT ONLY WITH TEXTUAL CITATIONS BUT ALSO BY THE INCLUSION OF A BIBLIOGRAPHY. THE EVOLUTION OF THE SO-CALLED NUCLEAR DEBATE FROM THE LATE 1960S TO THE PRESENT TIME IS REVIEWED, AND THE CURRENT MANIFESTATIONS OF THE ANTINUCLEAR MOVEMENT IN MANY COUNTRIES ARE DESCRIBED. DESPITE THE EMERGENCE OF PRONUCLEAR GROUPS AND DISCUSSIONS IN MANY COUNTRIES, THE AUTHOR CONCLUDES THAT PUBLIC EDUCATION IS THE CORE OF THE PROBLEM, AND HE DISCUSSES THE ROLE OF THE INTERNATIONAL ATOMIC ENERGY AGENCY (IAEA) IN THE NUCLEAR DEBATE.
- 20-6-1-664 RISKS ASSOCIATED WITH NUCLEAR POWER  
NATIONAL ACADEMY OF SCIENCES  
WASHINGTON, D.C.  
EDITOR'S NOTE: THE REPORT FROM WHICH THIS ARTICLE IS ADAPTED HAD ITS ORIGIN IN 1975 IN A REQUEST BY PHILIP HANDLER, PRESIDENT OF THE NATIONAL ACADEMY OF SCIENCES, TO ITS COMMITTEE ON SCIENCE AND PUBLIC POLICY (COSPP), TO REVIEW THE DRAFT OF THE REACTOR SAFETY STUDY (WASH-1400, ALSO KNOWN AS THE RASMUSSEN REPORT). THE COSPP WELCOMED THIS CHARGE AND DECIDED TO UNDERTAKE A SURVEY OF ALL THE TYPES OF RISKS ASSOCIATED WITH THE NUCLEAR POWER PROGRAM THROUGH A CRITICAL REVIEW OF THE LITERATURE. AT THE SAME TIME THE NATIONAL RESEARCH COUNCIL WAS ORGANIZING A COMMITTEE ON NUCLEAR AND ALTERNATIVE ENERGY SYSTEMS (CONAES) FOR A BROAD STUDY REQUESTED BY THE ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION (ERDA), NOW THE DEPARTMENT OF ENERGY (DOE). IT WAS AGREED THAT THE LITERATURE REVIEW PROPOSED BY COSPP WOULD PROVIDE INFORMATION THAT COULD CONTRIBUTE SIGNIFICANTLY TO THE CONAES STUDY. ACCORDINGLY, THE COSPP STUDY WAS SUPPORTED LARGELY BY FUNDS MADE AVAILABLE BY ERDA AND DOE FOR THE CONAES EFFORT; ADDITIONAL SUPPORT WAS PROVIDED BY THE NATIONAL ACADEMY OF SCIENCES. THIS ARTICLE CONSISTS PRIMARILY OF THE "INTRODUCTION" (SECTION I) AND "OVERALL ASSESSMENT" (SECTION VIII) OF THE "SUMMARY AND SYNTHESIS CHAPTER" OF THE COSPP LITERATURE REVIEW. THE "SUMMARY AND SYNTHESIS CHAPTER" WAS RELEASED IN APRIL 1979 - BEFORE COMPLETION OF THE FULL REPORT - BECAUSE OF THE INTENSITY OF CURRENT INTEREST IN THE SUBJECT.

- 20-6-2-671 BURNOUT IN BOILING HEAT TRANSFER III. HIGH QUALITY FORCED CONVECTION SYSTEMS  
BERGLES, A. E.  
IOWA STATE UNIVERSITY, AMES, IOWA  
THIS IS THE THIRD AND FINAL PART OF A REVIEW OF BURNOUT DURING BOILING HEAT TRANSFER. THE STATUS OF BURNOUT IN HIGH-QUALITY FORCED-CONVECTION SYSTEMS IS REVIEWED, AND RECENT DEVELOPMENTS ARE SUMMARIZED IN DETAIL. A GENERAL GUIDE TO THE CONSIDERABLE LITERATURE IS GIVEN. PARAMETRIC EFFECTS AND CORRELATIONS FOR WATER IN CIRCULAR AND NONCIRCULAR DUCTS ARE PRESENTED. OTHER TOPICS DISCUSSED INCLUDE TRANSIENTS, STEAM GENERATOR APPLICATIONS, CORRELATIONS FOR OTHER FLUIDS, FOULING, AND AUGMENTATION.
- 20-6-3-690 ASSESSMENT OF THE FREQUENCY OF FAILURE TO SCRAM IN LIGHT WATER REACTORS  
APOSTOLAKIS, G. + KAPLAN, S. + GARRICK, B. J.  
DICKTER, W.  
UNIVERSITY OF CALIFORNIA, LOS ANGELES, CALIF. / PICKARD, LOWE AND GARRICK, INC., IRVINE, CALIF.  
BAYESIAN METHODS ARE USED TO CONSTRUCT A DISTRIBUTION FOR THE PROBABILITY OF FAILURE OF THE REACTOR PROTECTION SYSTEM (RPS) PER DEMAND IN LIGHT-WATER REACTORS. THIS DISTRIBUTION EXPRESSES QUANTITATIVELY OUR CURRENT STATE OF KNOWLEDGE AS FORMED BY OUR OWN ANALYSIS OF THE RPS, BY THE AVAILABLE STATISTICAL EVIDENCE, AND BY THE WORK OF THE ELECTRIC POWER RESEARCH INSTITUTE AND THE NUCLEAR REGULATORY COMMISSION STAFF WHO PARTICIPATED IN THE SCRAM TESTS. THE DISTRIBUTION CAN BE SUMMARIZED BY THE FOLLOWING VALUES: 5TH PERCENTILE:  $6.2 \times 10^{-6}$  PER DEMAND; MEDIAN:  $2.8 \times 10^{-5}$  PER DEMAND; MEAN:  $5.4 \times 10^{-5}$  PER DEMAND; 95TH PERCENTILE:  $1.2 \times 10^{-4}$  PER DEMAND.
- 20-6-4-706 SUMMARY OF THE REPORT TO THE PRESIDENT BY THE INTERAGENCY REVIEW GROUP ON NUCLEAR WASTE MANAGEMENT  
INTERAGENCY REVIEW GROUP  
WASHINGTON, D.C.  
ON MAR. 13, 1978, IN RESPONSE TO THE FINDINGS OF AN INTERNAL DEPARTMENT OF ENERGY (DOE) TASK FORCE WHICH HAD REVIEWED THE UNITED STATES NUCLEAR WASTE MANAGEMENT PROGRAM, PRESIDENT CARTER ESTABLISHED THE INTERAGENCY REVIEW GROUP (IRG) TO FORMULATE RECOMMENDATIONS FOR THE ESTABLISHMENT OF AN ADMINISTRATIVE POLICY WITH RESPECT TO LONG-TERM MANAGEMENT OF NUCLEAR WASTES AND SUPPORTING PROGRAMS. CHAIRED BY THE SECRETARY OF ENERGY, THE IRG IS COMPOSED OF REPRESENTATIVES OF 14 GOVERNMENT ENTITIES. THE NUCLEAR REGULATORY COMMISSION (NRC) PARTICIPATED IN THE ACTIVITIES OF THE IRG AS A NONVOTING MEMBER. THE IRG ATTEMPTED TO OBTAIN A BROAD RANGE OF INPUTS AND VIEWS FROM MANY SOURCES, INCLUDING CONGRESS, STATE AND LOCAL GOVERNMENTS, INDIAN NATIONS, INDUSTRY, THE SCIENTIFIC AND TECHNICAL COMMUNITY, PUBLIC INTEREST AND ENVIRONMENTAL ORGANIZATIONS, AND THE PUBLIC. IN OCTOBER 1978 THE IRG ISSUED A DRAFT REPORT FOR PUBLIC REVIEW AND COMMENT. SOME 3300 COMMENTS WERE RECEIVED AND REVIEWED, AND THEIR FINAL REPORT, WHICH WAS PUBLISHED IN MARCH 1979, REFLECTS THEIR CONSIDERATION OF THESE COMMENTS. THIS ARTICLE SUMMARIZES THE FINAL REPORT, USING TO THE EXTENT PRACTICAL THE SAME FORMAT, WORDING, AND EMPHASIS.
- 20-6-5-722 NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES OF RADON-222  
TRAVIS, C. C. + WATSON, A. P.  
MCDOWELL-HOYER, L. M. + COIFMAN, S. J.  
BANDOLPH, M. L. + FIELDS, D. E.  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.  
AN ASSESSMENT OF RADON-222 RELEASES (CURIES/YEAR) FROM MAJOR NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES IN THE UNITED STATES IS PRESENTED. THE RESULTING INHALATION POPULATION DOSE COMMITMENTS TO THE BRONCHIAL EPITHELIUM OF THE LUNG (LUNG-REM) ARE ALSO ESTIMATED. THE COURSES OF RADON CONSIDERED ARE NATURAL SOIL, EVAPOTRANSPIRATION, POTABLE WATER SUPPLIES, BUILDING MATERIALS, NATURAL GAS, URANIUM MINING AND MILLING, COAL AND PHOSPHATE MINING, PHOSPHATE FERTILIZER, LIQUEFIED PETROLEUM GAS, GEOTHERMAL POWER FACILITIES, COAL-FIRED POWER PLANTS, AND GAS AND OIL WELLS. THE MOST IMPORTANT NATURAL SOURCE OF RADON-222 IS DECAY OF RADON-226 IN THE SOIL AND ROCKS OF THE EARTH'S CRUST. THIS COURSE RESULTS IN APPROXIMATELY 40 PERCENT OF THE TOTAL POPULATION DOSE FROM ALL SOURCES OF RADON. THE LARGEST TECHNOLOGICALLY ENHANCED CONTRIBUTOR TO POPULATION DOSE IS AIRBORNE RADON-222 IN BUILDING INTERIORS, WHICH IS ESTIMATED TO CONTRIBUTE 55 PERCENT TO THE TOTAL POPULATION EXPOSURE TO RADON-222. EACH OF THE OTHER SOURCES IS ESTIMATED TO CONTRIBUTE LESS THAN 3 PERCENT TO THE TOTAL.
- 20-6-6-729 STRESS CORROSION CRACKING IN PIPING OF LIGHT WATER REACTOR PLANTS  
PIPE CRACK STUDY GROUP  
U. S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, D.C.  
EDITOR'S NOTE: THE PIPE CRACK STUDY GROUP, ESTABLISHED BY THE NUCLEAR REGULATORY COMMISSION (NRC), REVIEWED INTERCOMPANULAR STRESS-CORROSION CRACKING (IGSCC) OF PIPING IN BOILING-WATER REACTORS (BWRs) AND IN 1975 ISSUED A REPORT, NUREG-75/067. DURING 1978 SUCH CRACKING WAS REPORTED FOR THE FIRST TIME IN LARGE-DIAMETER PIPING (GREATER THAN 20 IN.) IN A BWR IN THE FEDERAL REPUBLIC OF GERMANY. THIS DISCOVERY, TOGETHER WITH THE REPORTED QUESTIONS CONCERNING THE INTERPRETATION OF "ULTRASONIC INSPECTIONS, LED TO THE ESTABLISHMENT OF A NEW PIPE CRACK STUDY

GROUP BY THE NRC. THE CHARTER OF THE NEW GROUP WAS EXPANDED TO INCLUDE (1) A REVIEW OF THE POTENTIAL FOR STRESS-CORROSION CRACKING IN PRESSURIZED-WATER REACTORS (PWRs) AS WELL AS IN BWRs, (2) AN EXAMINATION OF THE OPERATING EXPERIENCE IN FOREIGN REACTORS RELEVANT TO IGSCC, AND (3) A RESPONSE TO FIVE SPECIFIC QUESTIONS CONCERNING IGSCC. THIS ARTICLE SUMMARIZES THE FINDINGS OF THE NEW PIPE CRACK STUDY GROUP; COMPLETE DETAILS ARE PRESENTED IN THEIR REPORT, NUREG-0531.

20-6 '75 SUMMARY OF TMI-2 LESSONS LEARNED TASK FORCE REPORT  
NUCLEAR SAFETY STAFF  
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENN.

AFTER ITS REVIEW OF THE THREE MILE ISLAND 2 ACCIDENT, THE TMI-2 LESSONS LEARNED TASK FORCE RECOMMENDED THAT A NUMBER OF ACTIONS IN THE AREAS OF DESIGN AND ANALYSIS AND PLANT OPERATIONS BE REQUIRED IN THE SHORT TERM TO PROVIDE SUBSTANTIAL ADDITIONAL PROTECTION FOR THE PUBLIC HEALTH AND SAFETY. ALL NUCLEAR POWER PLANTS IN OPERATION OR IN VARIOUS STAGES OF CONSTRUCTION OR LICENSING ACTION ARE AFFECTED TO VARYING DEGREES BY THE SPECIFIC RECOMMENDATIONS. COMMENTS BY THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS CONCERNING THE SHORT-TERM RECOMMENDATIONS ARE PRESENTED.

## Section 2

## PERMUTED-TITLE (KWIC) INDEX

A KWIC (KeyWord in Context) index is one in which article titles are permuted around the various significant words contained therein. For example, the title, "Design Basis for Nuclear Power Plant Protection Systems," is indexed under the words Design, Nuclear, Power, Plant, and Protection. The index words are arranged alphabetically in a column in the center of the page, with the titles permuted around them. In some cases, additional significant words in parentheses have been added to the title by the editors to allow more precise indexing. A slash (/) indicates the end of a title. The location of the articles listed in the main index (orange) is indicated by the seven-digit numbers in the column to the right of the page, as described in the Introduction.

ERIC INDEX

	SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER REACTOR FACILITIES	15-2-6-199
URANIUM-235 SOLUTION IN TANKS CONTAINING A FIRED NEUTRON ABSORBER/	THE SAFETY AND CONTROL OF	15-3-4-295
ROD FROM A BWR NUCLEAR POWER STATION INTO A MARINE BAY/	ABUNDANCE AND DISTRIBUTION OF RADIONUCLIDES IN SC	20-2-5-193
BY 1 SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACCELERATOR CENTER/		11-6-1-435
SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CRITERIA FOR EMERGENCY CORE COOLING S		15-2-4-173
EDUCATION AND PUBLIC ACCEPTANCE OF NUCLEAR POWER PLANTS/		20-6-1-655
SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES/		14-6-4-634
CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT/		18-3-2-298
ANOTHER PERSPECTIVE OF THE 1958 SOVIET NUCLEAR ACCIDENT/		20-2-6-286
DEVELOPMENTS PERTAINING TO THE THREE MILE ISLAND ACCIDENT/		20-5-8-613
PHENOMENOLOGICAL RESEARCH IN LWWR ACCIDENT ANALYSIS/		14-4-2-304
PRELIMINARY DOSE AND HEALTH IMPACT OF THE ACCIDENT AT THE THREE MILE ISLAND NUCLEAR STATI		20-5-5-591
STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS/		11-3-2-145
U.S. STUDIES ON LWWR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/		14-5-2-452
AN ASSESSMENT OF HIGH ACCIDENT CONSEQUENCES/		18-6-2-761
THE MECHANISTIC ANALYSIS OF LWWR ACCIDENT ENERGETICS/		20-4-2-402
ENTATION FOR MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER REACTORS/ IN		11-6-3-454
ON OF EMERGENCY CORE COOLANT FOLLOWING A LOSS OF COOLANT ACCIDENT IN PWRs/ THERMAL SHOCK STUDIES ASSOCIAT		19-1-2-10
PLANTS/ AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER		15-6-1-673
OMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY/ ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY		11-4-6-304
FROM AN LWWR/ CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT		14-4-5-325
IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION ACCIDENTS/		12-4-5-338
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/		12-5-3-461
FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR ACCIDENTS/		12-5-3-487
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/		15-5-2-535
NEERED SAFETY FEATURES ON THE RISK OF HYPOTHETICAL LWWR ACCIDENTS/	EFFECT OF ENGI	19-2-4-190
ALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS OF COOLANT PROBABILITY AN		14-1-2-014
- A COMPARISON OF THE LATE MORTALITY RISKS FROM REACTOR ACCIDENTS/	LEUKEMIA AND THYROID CARCINOMA	11-6-4-442
ONSEQUENCES OF ATMOSPHERIC RELEASES FROM NUCLEAR REACTOR ACCIDENTS/ EFFECTS OF RAINSTORMS AND WINDOFF ON C		19-2-5-220
PRESSURIZED WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL RUPTURE/		14-4-2-291
THE ROLE OF CORE DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSING OF LWWRs/		17-5-2-550
POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HWGRs/		16-5-2-546
PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS/		18-1-4-60
ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AEC STUDY		15-4-1-375
RADIOLYTIC HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER REACTORS/		13-6-2-465
EL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMEN		14-6-2-597
COOLING/ ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE		15-3-2-285
NUCLEAR PRESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION - A CRITICAL ASSESSMENT/		17-1-3-33
1978 ACOUSTIC EMISSION TO DETECT INCIDENT FAILURE IN		15-5-3-554
PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION CONTROL ACTS CRITIQUE OF NRC SAFETY RESEARCH PROGRAM/		20-4-1-399
AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS 1. A		15-3-1-262
ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART		16-4-1-421
RADIATION PROTECTION ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/		15-6-4-711
NUCLEAR TECHNOLOGY/ ACTIVITIES OF THE BUREAU OF RADIOLOGICAL HEALTH/		15-2-5-185
FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD/ ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR		14-3-1-181
ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTIVITY CONFINEMENT AND DECONTAMINATION AFTER F		14-4-6-362
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS AGAINST NUCLEAR FACILITIES/		17-6-1-654
SAFE DESIGN/ THE USE OF ACTS OF SABOTAGE/		17-6-1-665
FRAF FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-53/ ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL		12-3-3-226
FOR MANAGEMENT I/ U.S.A. STANDARD N13.2-1969 - GUIDE FOR ADDENDUM ON FRAP-53/		19-5-2-588
BROWNS FERRY CHARCOAL ADMINISTRATIVE PRACTICES IN RADIATION MONITORING		11-1-5-039
EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORBER INCIDENT/		20-1-6-78
ATIONS/ ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION BED/		13-6-4-478
ED WATER REACTORS/ RECENT ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTR		15-6-4-711
OLE IN NUCLEAR SAFETY/ ATMOSPHERIC RELEASE ADVANCES IN ALTERNATE ECCS STUDIES FOR PRESSURIZ		19-4-4-473
REACTOR LICENSING PROCESS/ THE ROLE OF THE ADVISORY CAPABILITY/		17-3-1-281
MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM THE ELEVENTH AEC ADVISORY COMMITTEE ON REACTOR SAFEGUARDS - ITS R		20-4-1-387
TORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. THE TWELFTH AEC ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE		13-1-1-001
ITORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS I. THE THIRTEENTH AEC AIR CLEANING CONFERENCE/		12-2-4-100
LE HEARING/ CONCLUDING STATEMENT OF THE AEC AIR CLEANING CONFERENCE/		14-2-4-111
IC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AEC AIR CLEANING CONFERENCE/		16-2-4-190
OR SAFETY/ AEC FUEL REPROCESSING OPERATIONS/		14-5-5-482
UCLEAR POWER PLANT SITES/ AEC GOES PUBLIC - A CASE HISTORY/		11-5-1-365
AND SCHEDULES/ THE CONTROL, MONI AEC LICENSED FACILITIES/		16-1-5-71
TORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. THE CONTROL, MONI AEC OWNED FACILITIES/		16-1-5-60
LE HEARING/ CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICAB		15-4-5-443
IC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AEC STUDY ON THE ESTIMATION OF RISKS TO THE PUBL		15-4-1-375
OR SAFETY/ AEC TESTIMONY AT THE 1973 JOCE HEARINGS ON BRAC		15-2-3-132
UCLEAR POWER PLANT SITES/ AEC WORKING PAPER ON POPULATION DENSITY AROUND N		16-1-1-1
AND SCHEDULES/ AECs NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, THE		15-2-1-127
TORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. THE AERIAL MEASURING SYSTEMS PROGRAM/		20-2-1-136
LE HEARING/ CONCLUDING STATEMENT OF THE NRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEARCH/		18-5-1-589
IC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AGRICULTURAL RESEARCH LABORATORY/ ACCIDENTAL COB		13-4-6-304
OR SAFETY/ HUMAN ENGINEERING - AIDS TO SMOOTH OPERATION/		18-2-6-223
UCLEAR POWER PLANT SITES/ CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES/		18-5-4-634
AND SCHEDULES/ THE ELEVENTH AEC AIR CLEANING CONFERENCE/		12-2-4-100
TORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. THE TWELFTH AEC AIR CLEANING CONFERENCE/		14-2-4-111
LE HEARING/ CONCLUDING STATEMENT OF THE THE THIRTEENTH AEC AIR CLEANING CONFERENCE/		16-2-4-190
IC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE THE FOURTEENTH BRDA AIR CLEANING CONFERENCE/		18-2-4-174
OR SAFETY/ THE FIFTEENTH DOE AIR CLEANING CONFERENCE/		20-1-4-63
UCLEAR POWER PLANT SITES/ PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS/		16-4-4-469
AND SCHEDULES/ SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT		14-6-4-634
TORING, AND REPORTING OF RADIOACTIVITY IN EFFLUENTS II. AIR CLEANING, AND VENTILATION SYSTEMS IN COMMERC		20-2-4-176
LE HEARING/ CONCLUDING STATEMENT OF THE AIR MONITORING, AIR CLEANING, AND VENTILATION SY		20-2-4-176
IC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ AIRBORNE EFFLUENTS OF COAL FIRED AND NUCLEAR POW		19-4-5-447
OR SAFETY/ AIRCRAFT CRASH PROBABILITIES/		17-3-2-312
UCLEAR POWER PLANT SITES/ AIRCRAFT RISK FOR NUCLEAR POWER PLANTS/		15-3-2-276
AND SCHEDULES/ PROBABILISTIC ASSESSMENT OF ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUC		12-4-2-305
TION/ RISK MINIMIZATION BY OPTIMUM		



TORS/	RECENT ADVANCES IN	ALTERNATE ECCS STUDIES FOR PRESSURIZED WATER REA	19-4-4-473
	COMPARATIVE RISK - COST - BENEFIT STUDY OF	ALTERNATIVE SOURCES OF ELECTRICAL ENERGY/	17-2-1-171
	UNEXPECTED MELTDOWN OF SCRAP URANIUM -	ALUMINUM CERMET CORES DURING OUTGASSING/	15-4-6-455
R INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCIETY OF	AMERICA/	THE FOURTEENTH POWER	13-1-3-029
AN SAFETY 1975/	NUCLEAR SAFETY IN	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLE	17-3-1-289
REACTOR SAFETY/	BENEFIT COST	AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER	16-5-1-542
	COMPARATIVE RELIABILITY	ANALYSES IN LICENSING OF NUCLEAR POWER REACTORS/	12-3-4-234
	LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS	ANALYSES OF REACTOR SAFETY SYSTEMS/	15-6-1-665
	PHENOMENOLOGICAL RESEARCH IN LMFBR ACCIDENT	ANALYSIS/	14-6-3-605
	SNEAK-CIRCUIT	ANALYSIS/	14-2-3-105
	HUMAN RELIABILITY	ANALYSIS/	14-4-2-304
	NUCLEAR POWER PLANT PERFORMANCE	ANALYSIS/	14-5-3-461
AP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT	ANALYSIS/	THE REL	17-3-3-315
OF COOLANT ACCIDENTS/	PROBABILITY	ANALYSIS APPLIED TO LIGHT WATER REACTORS - LOSS	18-5-6-664
MANY/	COUPLED FLUID STRUCTURE	ANALYSIS FOR LWRs IN THE FEDERAL REPUBLIC OF GER	14-1-2-014
DAMAGED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING/	AN	ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOM	20-5-2-551
NUCLEAR POWER REACTORS/	THE MECHANISTIC	ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN N	15-3-2-285
	ASSESSMENTS/ AN	ANALYSIS OF LMFBR ACCIDENT ENERGISTICS/	14-4-3-315
DEPOSITION IN ENVIRONMENTAL RADIOLOGICAL ASSESSMENTS/	ANALYSIS OF NRC METHODS FOR ESTIMATING THE EFFEC	ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER	20-4-2-402
CHANNEL BY RAPID HEATING/	RELIABILITY	ANALYSIS OF SHUTDOWN SYSTEMS/	20-4-5-458
APPLICATION OF REACTOR SCRAM EXPERIENCE IN RELIABILITY	ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNI	ANALYSIS RESULTS OF A TYPICAL PWR PLANT/	11-1-2-012
UNIVERSITY RESEARCH REACTOR/	COMPUTER CODES FOR	ANALYZING NUCLEAR ACCIDENTS/	19-6-3-712
	COMPUTER CODES FOR	ANALYZING NUCLEAR ACCIDENTS/	17-4-3-437
	THE 16TH	ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGE	17-4-2-422
GES FOR POWER INSTRUMENTATION/	JOINT	ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCE	12-5-3-461
CE GROUPS - 1970/	ANOMALIES/	SAN ONOPRE EXPERIENCE WITH	15-5-2-535
APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE	REPORT ON THE 1970	ANS CONFERENCE ON POWER REACTOR SYSTEMS AND COMP	15-4-3-417
TRENDS/	1974	ANS EXECUTIVE CONFERENCE ON SAFEGUARDS/	11-2-6-142
FET/	REVIEW OF	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SA	12-2-6-134
E SYSTEMS/	THE	ANS STANDARD N19.8 ON DESIGN BASES FOR PROTECTIV	19-4-1-427
G/	ANS TOPICAL MEETING ON PAST REACTOR SAFETY/	ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITIN	14-5-1-439
	ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY/	ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITIN	15-3-3-292
	THE ANSI-NRSB NUCLEAR STANDARDS PROGRAM/	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT W	16-2-1-141
O/	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT W	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER C	16-3-1-273
ATER REACTORS/	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER C	ANTIMONY - BERYLLIUM SOURCE ROD/	19-2-1-153
COOLED POWER REACTORS/	APPARENT POWER MISMATCH AND REACTOR COOLANT TEMP	APPRECIATION OF PAST REACTOR SAFETY-1970/	16-4-1-415
VITY CONFINEMENT AND DECONTAMINATION AFTER FAILURE OF AN	AN	AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FR	17-1-3-43
ERATURE ANOMALIES/	APPRECIATION OF PAST REACTOR SAFETY-1970/	AQUEOUS WASTES FROM AEC FUEL REPROCESSING OPERAT	20-4-3-422
	LE FACILITIES/ RADIATION DOSES AND EFFECTS ESTIMATED FOR	ARRANGEMENTS IN NUCLEAR POWER PLANTS/	15-2-3-151
	ING, DESIGN, AND OPERATION/	ART/	14-4-6-362
	IONS/	ARTS/	11-2-6-142
	REFLECTIONS ON THE RECRITICALITY CONFERENCE AT	ASME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR	12-2-1-83
	IAEA MEETING ON POWER SUPPLY	ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL/	17-3-5-351
GINERGING METHODOLOGY - A DISCUSSION OF THE STATE OF THE	SYMPOSIUM ON HEALTH PHYSICS IN THE HEALING	ASSEMBLIES/	18-3-5-329
REACTORS/	CONSTRUCTION OF A SITE	ASSESSMENT/	14-5-5-482
	PARTIAL BLOCKAGES IN LMFBR FUEL	ASSESSMENT/	18-1-2-45
	ACOUSTIC EMISSION - A CRITICAL	ASSESSMENT/	20-2-3-166
UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY	ASSESSMENT/	ASSESSMENT/	20-5-2-541
ENCE ON NUCLEAR SYSTEMS RELIABILITY ENGINEERING AND RISK	ASSESSMENT/	ASSESSMENT - THE SUBJECTIVISTIC VIEWPOINT AND SO	14-4-5-340
H IN THE POPULATION NEAR NUCLEAR FACILITIES - A CRITICAL	ASSESSMENT/	ASSESSMENT IN THE NUCLEAR REGULATORY PROCESS/	13-2-1-099
ME SUGGESTIONS/	COST - BENEFIT AND RISK - BENEFIT	ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM	11-2-4-119
	THE ROLE OF RISK	ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL	17-1-2-19
	FOR LOSS OF ELECTRIC POWER/	ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PL	17-1-3-33
NUCLEAR POWER PLANTS/	AN	ASSESSMENT OF FAST SODIUM-COOLED REACTORS IN THE	15-5-1-519
ANTS/	PROBABILISTIC	ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER	19-1-3-38
UNITED KINGDOM/	SAFETY	ASSESSMENT OF HTGR ACCIDENT CONSEQUENCES/	18-5-5-647
PLANTS/	PROBABILISTIC	ASSESSMENT OF RADIONUCLIDES RELEASED TO THE ENVI	19-3-2-305
	AN	ASSESSMENT OF REACTOR SYSTEMS/	17-5-1-525
ROMMENT/	COMPUTER CODES FOR THE	ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIA	19-5-1-556
	SAFETY	ASSESSMENT OF THE FREQUENCY OF FAILURE TO SCRAM	18-2-3-168
L POWER REACTORS/	SAFETY	ASSESSMENT PHILOSOPHY OF THE FAST FLUX TEST FACI	15-6-1-673
IN LIGHT WATER REACTORS/	EPA'S ENVIRONMENTAL RADIATION	ASSESSMENT PROGRAM/	15-4-2-399
LITY/	REPORT OF THE NRC RISK	ASSESSMENT REVIEW GROUP ON THE REACTOR SAFETY ST	18-6-2-761
ODY/	EFFECTS OF DRY DEPOSITION IN ENVIRONMENTAL RADIOLOGICAL	ASSESSMENTS/ AN ANALYSIS OF NRC METHODS FOR ESTI	18-3-5-343
IONAL CONGRESS OF THE INTERNATIONAL RADIATION PROTECTION	ASSOCIATION/	ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER P	15-2-3-154
PLANTS/	QUALITY	ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLAN	19-5-3-590
T/	QUALITY	ASSURANCE STANDARDS AND PRACTICES/	20-6-3-690
	THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE	ATMOSPHERE/	14-2-1-079
	REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM MIN	ATMOSPHERES/	16-6-1-667
	SION CONDITIONS/	A SURVEY OF FIELD MEASUREMENTS OF	20-1-1-24
	WTS/ EFFECTS OF RAINSTORMS AND RUNOFF ON CONSEQUENCES OF	ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVER	20-4-5-458
		ATMOSPHERIC RELEASE ADVISORY CAPABILITY/	19-1-5-60
	THE ORIGIN AND FINDINGS OF THE	ATMOSPHERIC RELEASES FROM NUCLEAR REACTOR ACCIDE	16-2-1-127
WTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE -	ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH L	ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES	17-1-6-87
VIEW OF FIRE PROTECTION IN THE NUCLEAR FACILITIES OF THE	ATOMIC ENERGY COMMISSION, 1947-1975/	ATOMIC BOMB CASUALTY COMMISSION/	12-6-1-549
	THE ROLE OF THE	ATOMIC SAFETY AND LICENSING BOARD PANEL/	15-3-5-306
BOARDIZATION OF NUCLEAR POWER PLANTS/	REVIEW OF	AUGUST 1978 CHANGES TO THE NRC'S PROGRAM FOR STA	14-6-5-651
NCE AND EXHIBIT/	INSTRUMENTATION AND	AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERE	13-4-6-304
	OBSTACLES TO COMPLETE	AUTOMATION OF REACTOR CONTROL/	20-3-1-258
			13-5-3-366
			14-2-3-095

AT ORNL/	EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY//	AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS	11-2-3-115
	U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973/		15-5-6-599
ITY OF SERVICE/	REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINU		15-6-6-738
	IMPROVING REACTOR FUEL SOURCE VESSEL AVAILABILITY BY DESIGN/		12-5-4-499
	RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK REDUCTION/		17-1-4-62
	NATURAL BACKGROUND RADIATION IN THE UNITED STATES/		12-4-2-305
NESS - THE IMPACT OF THE COURTS/	BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC PROG		17-4-5-471
	AND STANDARD NUREG ON DESIGN SAFETY DESIGN		13-3-1-204
	FISSION GAS EFFECTS IN REACTOR FUELS I. BASIC STUDIES/		15-3-3-292
ISCHARGED FROM A BWR NUCLEAR POWER STATION INTO A MARINE	BAY/ ABUNDANCE AND DISTRIBUTION OF RADIONUCLIDES		14-6-4-618
W ACCELERATOR CENTER/	BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEA		12-4-2-297
	EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION		20-2-5-190
	FRAP FUEL BEHAVIOR COMPUTER CODES/		11-6-1-435
	FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-53/		13-6-4-478
OLED FAST BREEDER REACTORS I. PRODUCTION/ RADIONUCLIDE	BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL		19-5-2-565
COOLED FAST BREEDER REACTORS II. TRANSPORT/ RADIONUCLIDE	BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL		16-1-4-41
	LMPBR SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM/		16-3-4-313
	ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE ENVIRONMENT/		11-5-3-379
SPHERE/	IRRA-WMO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIVE CONTAMINANTS IN THE ATMO		12-4-4-326
MANY/	LWR FUEL BEHAVIOR RESEARCH IN THE FEDERAL REPUBLIC OF GEP		15-3-5-306
	STUDIES OF FAST REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS/		19-2-2-176
	U.S. STUDIES ON LMPBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/		11-3-2-195
R POWER PLANTS/	COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEA		14-5-2-452
	COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS/		17-5-1-525
M AND SAFETY PROTECTIVE MEASURES AND REGULATIONS/ A COST	BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR HEA		20-5-1-525
WER REACTORS/	BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR PO		15-6-1-665
NS/	RISK BENEFIT EVALUATION FOR LARGE TECHNOLOGICAL SYST		20-2-2-148
AL ENERGY/	COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRIC		17-2-1-171
EMENT AND DECONTAMINATION AFTER FAILURE OF AN ANTIMONY -	SENSITIVITY OF PORTABLE BERYLLIUM SOURCE ROD/ ACTIVITY CONFIN		12-4-1-283
MENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS I/	BIOLOGICAL EFFECTS OF NOBLE GASES ( A REVIEW OF		14-4-6-362
ILITIES/ RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATIC	BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR F		16-4-3-452
OPERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM	ECOLOGICAL CONSI		15-6-5-732
	PARTIAL SLOWDOWN HEAT-TRANSFER PROGRAM/		17-3-5-351
	HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS/		12-1-3-025
	THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL/		17-1-2-19
	BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS/		20-1-2-27
	BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUAL		14-1-3-321
	BURNOUT IN BOILING HEAT TRANSFER III. HIGH QUALITY FORCED		15-4-1-383
ITY FORCED CONVECTION SYSTEMS/	BOILING SYSTEMS/		16-1-2-29
CONVECTION SYSTEMS/	BOILING WATER REACTORS/		18-2-2-154
	BOILING WATER REACTORS/ EVALUATIO		20-6-2-671
	THE ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY COMMISSION/		16-1-2-29
	THE HOMEMADE NUCLEAR BOMB SYNDROME/		17-4-6-475
	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM/		15-1-6-076
VIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST	BREEDER REACTORS I. PRODUCTION/ RADIONUCLIDE B		14-6-5-651
N-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST	BREEDER REACTOR FUEL SUBASSEMBLIES/	PI	18-4-1-427
NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER	BREEDER REACTOR PLANT/		16-6-2-687
	CLINCH RIVER BREEDER REACTOR PLANT SAFETY STUDY/		16-1-4-43
	THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM/		16-3-2-291
	EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTORS/		16-5-4-564
ERVICE INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FAST	BREEDER REACTORS/		19-3-2-316
CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST	BREEDER REACTORS/		11-1-1-001
VIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST	BREEDER REACTORS/	IN-52	17-2-4-208
SAFETY/	NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF NUCLEAR		18-4-3-469
	BROWNS FERRY CHARCOAL ADSORBER INCIDENT/		13-1-4-037
1975/	COMPUTER CONTROL AT REACTOR CONTAINMENT		16-3-4-318
AL/	RESEARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION PRODUCT REMOV		12-4-1-291
TORS/	RADON CONCENTRATION IN REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IODINE-131 RELEASE/		20-1-6-75
	RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGICAL HEALTH/		17-5-8-592
62 AND 1976, WITH PROJECTIONS/ A SUMMARY OF SHALLOW LAND	BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL SITES		15-6-3-691
	RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE/		12-5-5-516
G SYSTEMS/	BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILIN		11-3-4-223
AND LOW QUALITY FORCED CONVECTION SYSTEMS/	BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED		11-3-6-235
ITY FORCED CONVECTION SYSTEMS/	BURNOUT IN BOILING HEAT TRANSFER III. HIGH QUAL		15-2-5-185
	FISSION GAS RELEASE FROM FUEL AT HIGH BURNUP/		19-1-5-50
	EVOLUTION AND CURRENT STATUS OF THE BWR SLOWDOWN HEAT-TRANSFER PROGRAM/		16-2-4-180
ANCE AND DISTRIBUTION OF RADIONUCLIDES DISCHARGED FROM A	BWR CONTAINMENT SYSTEM/		16-1-2-29
	AN OVERVIEW OF NRC'S EMERGENCY CORE COOLANT BWR NUCLEAR POWER STATION INTO A MARINE BAY/ ADU		18-2-2-154
	SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT/		20-6-2-671
OBILITIES/	A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PR		19-6-2-699
	SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT/		20-1-2-27
	THE EMERGING ROLE OF THE CAMPS IN THE SAFETY OFFICES/		15-2-4-163
	ATMOSPHERIC RELEASE ADVISORY CAPABILITY/		20-2-5-190
G PLANT/	THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSIN		20-3-2-267
2020 AND THE ESTIMATED RADIOLOGICAL IMPACT/ SCENARIOS OF	CARCINOMA - A COMPARISON OF THE LATE MORTALITY R		16-6-7-714
RISKS FROM REACTOR ACCIDENTS/	CASK DESIGNERS GUIDE/		16-4-1-443
CASKS FOR IRRADIATED FUEL - A LOOK AT THE	CASKS FOR IRRADIATED FUEL - A LOOK AT THE CASK D		16-6-3-714
ESIGNERS GUIDE/	CASUALTY COMMISSION/		13-6-5-482
	CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER		17-3-1-281
REACTORS/	CENTER/		17-5-5-580
SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACCELERATOR	NUCLEAR ENERGY CENTER SITE SURVEY - 1975/		19-5-5-602
	NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITING/		11-6-4-482
	UNEXPECTED MELTDOWN OF SCRAP URANIUM - ALUMINUM CERAMIC CORES DURING OUTGASSING/		12-6-1-553
			12-6-1-553
			14-6-5-651
			17-2-4-208
			11-6-1-435
			17-4-1-411
			16-3-1-282
			15-4-6-455

TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN FOOD CHAINS/	11-1-5-043
THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION/	15-4-3-417
CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES	18-5-4-633
ANALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEATING/	11-1-2-012
BROWNS FERRY CHAPCOAL ADSORBER INCIDENT/	20-1-6-78
ENVIRONMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/	EL 15-6-4-711
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY PLATS PLANT II./	15-6-4-723
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY PLATS PLANT I./	15-5-4-572
DISCHARGES - TOWARD MORE REASONABLE EFFLUENT LIMITS ON CHLORINE/	18-6-5-802
ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES/	13-5-5-391
CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES/	18-5-4-633
THE ELEVENTH AEC AIR CLEANING CONFERENCE/	12-2-4-100
THE TWELFTH AEC AIR CLEANING CONFERENCE/	14-2-4-111
THE THIRTEENTH AEC AIR CLEANING CONFERENCE/	16-2-4-190
THE FOURTEENTH ERDA AIR CLEANING CONFERENCE/	18-2-4-174
THE FIFTEENTH DOE AIR CLEANING CONFERENCE/	20-1-4-63
PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS/	16-4-4-469
RESIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPA	14-6-4-634
FAILURES IN AIR MONITORING, AIR CLEANING, AND VENTILATION SYSTEMS IN COMMERCIAL	20-2-4-176
SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT/	16-6-3-714
NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER REACTOR PLANT/	16-5-4-564
CLINCH RIVER BREEDER REACTOR PLANT SAFETY STUDY/	19-3-2-316
RADIOLOGICAL IMPACT OF AIRBORNE EFFLUENTS OF COAL FIRED AND NUCLEAR POWER PLANTS/	19-4-5-497
HEALTH EFFECTS OF ELECTRICITY GENERATION FROM COAL, OIL, AND NUCLEAR FUEL/	14-5-1-409
PREDICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS/	12-2-5-110
COMMISSION AGRICULTURAL RESEARCH LABORATORY/ ACCIDENTAL COASTAL-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE	13-4-6-304
THE RELAP4 COMPUTER CODE III. LOCA ANALYSIS RESULTS OF A TYPICAL PWR	17-4-2-422
THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT ANAL	17-2-2-194
THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT MODEL/	17-3-2-299
THE SAME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR REACTOR	13-2-1-099
DATA SOURCES FOR LOCA CODE VERIFICATION/	17-6-2-671
FRAP FUEL BEHAVIOR COMPUTER CODES/	19-5-2-565
FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-S3/	19-5-2-588
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	12-5-3-461
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	15-5-2-535
COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASES	18-3-5-343
LOSS OF ELECTRIC POWER COINCIDENT WITH LOCA/	18-1-3-53
OWNER PLANT SITING, DESIGN, AND OPERATION/	18-3-5-329
IAEA-IAWGEP MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHMENT/	15-2-2-146
ILITIES FOR NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION/	STATE RESPONSIBILITIES 14-6-1-574
AN ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	15-6-1-673
AIR MONITORING, AIR CLEANING, AND VENTILATION SYSTEMS IN COMMERCIAL NUCLEAR POWER PLANTS ( JAN. 1, 1975-JUN	20-2-4-176
ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIAL POWER REACTORS/	19-5-3-590
SUMMARY OF SHALLOW LAND BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL SITES BETWEEN 1962 AND 1976, WITH PRO	19-1-5-50
THE ORIGIN AND FINDINGS OF THE ATOMIC BOMB CASUALTY COMMISSION/	14-6-5-651
FOR NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION/	STATE RESPONSIBILITIES 14-6-1-574
EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION AGRICULTURAL RESEARCH LABORATORY/ ACC	13-4-6-304
RECOMMENDATIONS OF THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION/	20-3-5-330
PROTECTION IN THE NUCLEAR FACILITIES OF THE ATOMIC ENERGY COMMISSION, 1947-1975/	RRVIEW OF FIRE P 20-3-4-294
FEDERAL REPUBLIC OF GERMANY - THE DIN NUCLEAR STANDARDS COMMITTEE/	NUCLEAR STANDARDS IN THE 19-3-1-297
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	14-3-1-181
CLEAR SAFETY/ ADVISORY COMMITTEE ON REACTOR SAFEGUARDS - ITS ROLE IN NU	20-4-1-387
ICENSING PROCESS/ THE ROLE OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE REACTOR L	13-1-1-001
IS IMPORTANT TO REACTOR SAFETY/ COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SIST	17-6-3-686
THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANYS ROCKY PLATS PLANT I./	18-5-3-624
IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPONENTS/	15-5-4-572
ON THE 1970 AEC CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENTS/	17-6-6-733
PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAILURE/	REPORT 12-2-6-134
TYPICAL PWR PLANT/ COMPUTER CODE III. LOCA ANALYSIS RESULTS OF A T	17-4-2-422
PLANT ANALYSIS/ THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER P	17-2-2-194
T MODEL/ THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT	17-3-2-299
FRAP FUEL BEHAVIOR COMPUTER CODES/	19-5-2-565
FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-S3/	19-5-2-588
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	12-5-3-461
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	15-5-2-535
COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDE COMPUTER CONTROL AT BRUCE NUCLEAR GENERATING STA	18-3-5-343
RELEASED TO THE ENVIRONMENT/ COMPUTER PROGRAMS/	15-6-1-691
A SURVEY OF HEAT CONDUCTION COMPUTER SOFTWARE/	12-6-2-569
SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE/	17-6-3-693
ASQUERADES AS IODINE-131 RELEASE/ RADON CONCENTRATION IN REACTOR CONTAINMENT BUILDINGS M	11-3-6-235
TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN FOOD CHAINS/	11-1-5-043
ND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/	ELEMENTAL IODINE A 15-6-4-711
IN THE, AS LOW AS PRACTICABLE HEARING/ CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF	15-4-5-443
A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS/	11-1-4-025
THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM/	11-3-4-215
THE ICE CONDENSER REACTOR CONTAINMENT SYSTEM FOR CONTAINMENT PRESSURE SUPPRE	17-6-4-710
SSION/ CONDUCTION COMPUTER PROGRAMS/	12-6-2-569
A SURVEY OF HEAT CONDUCTION CONFERENCE/	12-2-4-100
THE ELEVENTH AEC AIR CLEANING CONFERENCE/	14-2-4-111
THE TWELFTH AEC AIR CLEANING CONFERENCE/	16-2-4-190
THE THIRTEENTH AEC AIR CLEANING CONFERENCE/	18-2-4-174
THE FOURTEENTH ERDA AIR CLEANING CONFERENCE/	20-1-4-63
THE FIFTEENTH DOE AIR CLEANING CONFERENCE/	13-3-0-181
VIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH GENEVA NUCLEAR SAFETY AT GENEVA - A P	13-5-3-366
UMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH ISA CONFERENCE AND EXHIBIT/	INST 18-1-2-400
REFLECTIONS ON THE PECCITCITALITY CONFERENCE AT ARGONNE NATIONAL LABORATORY/	19-1-3-38
BRING AND RISK ASSESSMENT/ INTERNATIONAL CONFERENCE ON NUCLEAR SYSTEMS RELIABILITY ENGINE	12-2-6-134
TS/ REPORT ON THE 1970 AEC CONFERENCE ON POWER REACTOR SYSTEMS AND COMPONENT	13-4-2-287
ACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER	19-4-1-427
ANS EXECUTIVE CONFERENCE ON SAFEGUARDS/	13-3-1-216
NATIONAL CONFERENCE ON WASTE HEAT UTILIZATION/	13-2-2-107
STRUCTURAL EFFECTS OF CONFINED DYNAMIC LOADS/	



IONS/	BENEFIT	COST ANALYSES IN LICENSING OF NUCLEAR POWER REAC	15-6-1-665
HEALTH AND SAFETY PROTECTIVE MEASURES AND REGULATIONS/ A	COST	BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEA	20-5-1-525
NUCLEAR POWER PLANT SAFETY IN DEVELOPING	COUNTRIES/		20-2-1-123
FEDERAL REPUBLIC OF GERMANY/	COUPLED FLUID STRUCTURE ANALYSIS FOR LWRs IN THE		20-5-2-551
MENTAL IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE	COUPLED NEUTRONICS HYDRODYNAMICS METHODS/		14-2-2-091
PRESSURE VESSEL STEELS/	COURTS/	BALANCING ENVIRO	13-3-1-209
/	FATIGUE	CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC	18-6-4-791
SS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970	PIPE	CRACKING IN BOILING WATER REACTORS/	17-4-6-475
ON SYSTEMS/	STRESS CORROSION	CRACKING IN PIPING OF LIGHT WATER REACTOR PLANTS	20-6-6-729
IGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE	AIRCRAFT	CRASH PROBABILITIES/	17-3-2-312
GENERAL STRUCTURAL DESIGN		CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE	13-4-2-287
ACoustic EMISSION - A		CREST SUMMARY - WATER-COOLED REACTOR SAFETY/	12-3-1-196
CRITICAL ASSESSMENT/		CRITERIA AND REQUIREMENTS FOR RDT PLANT PROTECTI	11-5-2-375
CRITICAL ASSESSMENT/		CRITERIA BASED UPON RISK PROBABILITY/	13-1-2-022
TRENDS IN PUB		CRITERIA FOR EMERGENCY CORE COOLING SYSTEMS OF L	15-2-4-173
CRITICAL HEAT FLUX DURING A LOSS OF COOLANT ACCI		CRITERIA FOR PWR CONTAINMENT INTERIOR STRUCTURES	13-5-4-373
CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PO		CRITICAL ASSESSMENT/	17-1-3-33
CRITICAL REVIEW/		CRITICAL ASSESSMENT/	18-5-5-647
CRITIQUE AND AN EXTENSION/		TRENDS IN PUB	18-3-2-298
CRITIQUE OF NRC SAFETY RESEARCH PROGRAM/		CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PO	17-5-1-539
CSNI MEETING ON FUEL - COOLANT INTERACTIONS/		CRITICAL REVIEW/	12-3-3-015
CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR PA		CRITIQUE AND AN EXTENSION/	19-4-1-433
CURRENT STATUS OF THE BWR CONTAINMENT SYSTEM/		CRITIQUE OF NRC SAFETY RESEARCH PROGRAM/	20-4-1-394
CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PRO		CSNI MEETING ON FUEL - COOLANT INTERACTIONS/	16-8-2-436
D-C POWER SUPPLIES/		CTORS/	20-1-8-54
DAMAGE PROBABILITIES/		EVOLUTION AND	18-5-4-633
DAMAGE TO NUCLEAR COMPONENTS DUE TO TURBINE FAIL		RELIABILITY OF	15-2-4-163
DAUGHTER PRODUCTS FROM MINE ATMOSPHERES/		RELIABILITY OF	17-4-5-464
DECAY POWER/		PROBABILITY OF	19-3-3-330
DECISIONS/		PROBABILITY OF	16-4-2-443
DECONTAMINATION/		PROBABILITY OF	14-3-2-147
DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - B		PROBABILITY OF	14-6-5-641
DENSIFICATION OF REACTOR FUELS/		PROBABILITY OF	18-5-2-596
DENSITY AROUND NUCLEAR POWER PLANT SITES/		PROBABILITY OF	19-3-5-356
DEPOSITION FROM EVAPORATIVE COOLING TOWERS/		PROBABILITY OF	20-1-1-15
DEPOSITION IN ENVIRONMENTAL RADIOLOGICAL ASSESSM		PROBABILITY OF	14-4-6-362
DEPOSITION OF PARTICLES AND GASES FOR USE IN RAD		PROBABILITY OF	14-4-6-356
DESIGN/		PROBABILITY OF	16-1-1-1
DESIGN/		PROBABILITY OF	15-2-5-190
DESIGN/		PROBABILITY OF	20-4-5-458
DESIGN/		PROBABILITY OF	19-2-5-205
DESIGN/		PROBABILITY OF	17-1-4-62
DESIGN/		PROBABILITY OF	12-3-3-226
DESIGN/		PROBABILITY OF	17-6-4-701
DESIGN AND EVALUATION OF FFPF CONTAINMENT/		PROBABILITY OF	14-5-4-470
DESIGN AND LICENSING OF LMPFRS/		PROBABILITY OF	17-5-2-550
DESIGN BASES FOR PROTECTIVE SYSTEMS/		PROBABILITY OF	15-3-3-292
DESIGN BASES OF THE HTGR/		PROBABILITY OF	14-6-4-618
DESIGN BASIS FOR NUCLEAR POWER PLANT PROTECTION		PROBABILITY OF	11-1-3-020
DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR STR		PROBABILITY OF	13-5-4-373
DESIGN FOR NUCLEAR POWER PLANTS/		PROBABILITY OF	14-1-3-021
DESIGN OF ENGINEERING STRUCTURES/		PROBABILITY OF	14-1-1-001
DESIGN OF NUCLEAR POWER PLANT STRUCTURES/		PROBABILITY OF	15-4-4-432
DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENT		PROBABILITY OF	18-2-4-189
DESIGN OF THE CLINCH RIVER BREEDER REACTOR PLANT		PROBABILITY OF	16-5-4-564
DESIGN OF THE INPUT MODEL/		PROBABILITY OF	17-3-2-299
DESIGN, AND OPERATION/		PROBABILITY OF	18-3-5-329
DESIGNERS GUIDE/		PROBABILITY OF	12-6-1-553
DETECT INCIDENT FAILURE IN NUCLEAR PRESSURE VES		PROBABILITY OF	15-5-3-554
DETECTION OF FAILED FUEL ELEMENTS/		PROBABILITY OF	13-3-3-220
DETECTION SYSTEMS HANDBOOK/		PROBABILITY OF	20-1-3-44
DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED		PROBABILITY OF	12-2-3-90
DEVELOPING COUNTRIES/		PROBABILITY OF	20-2-1-123
DEVICES FOR TWO TYPES OF RESEARCH REACTOR FUEL/		PROBABILITY OF	11-3-6-237
DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR		PROBABILITY OF	16-2-6-224
DIFFUSION OF FISSION PRODUCTS/		PROBABILITY OF	11-4-4-315
DIFFUSION TYPING SCHEMES - A REVIEW/		PROBABILITY OF	17-1-5-64
DIFFUSION UNDER LOW WIND SPEED INVERSION CONDITI		PROBABILITY OF	17-2-5-223
DIGITAL COMPUTER SOFTWARE/		PROBABILITY OF	17-6-3-693
DIN NUCLEAR STANDARDS COMMITTEE/		PROBABILITY OF	19-3-1-297
DIOXIDE IN SODIUM/		PROBABILITY OF	16-6-2-683
DIRECTION WITHIN THE UNITED STATES/		PROBABILITY OF	11-1-5-034
DISCHARGED FROM A BWR NUCLEAR POWER STATION INTO		PROBABILITY OF	20-2-5-190
DISCHARGERS THROUGH PERMIT PROGRAMS/ THE NEW FED		PROBABILITY OF	15-3-1-262
DISCHARGES - TOWARD MORE REASONABLE EFFLUENT LIM		PROBABILITY OF	18-6-5-802
DISPERSION OVER CITIES/		PROBABILITY OF	13-5-5-391
DISPOSAL BY HYDRAULIC FRACTURING/		PROBABILITY OF	11-5-4-391
DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WAS		PROBABILITY OF	11-2-5-130
DISPOSAL OF RADIOACTIVE WASTE FROM NAVAL NUCLEAR		PROBABILITY OF	20-4-5-446
DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSING OF		PROBABILITY OF	17-3-2-550
DIVERSION OF NUCLEAR MATERIALS/		PROBABILITY OF	15-5-1-513
DOE AIR CLEANING CONFERENCE/		PROBABILITY OF	20-1-4-62
DOE INTRUSION DETECTION SYSTEMS HANDBOOK/		PROBABILITY OF	20-1-3-84
DOSE AND EFFECTS/		PROBABILITY OF	11-6-4-475
DOSE AND HEALTH IMPACT OF THE ACCIDENT AT THE TH		PROBABILITY OF	20-5-5-591
DOSE CALCULATIONS/ PARAMETERIZATIONS FOR RESUSPE		PROBABILITY OF	19-2-5-205
DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FR		PROBABILITY OF	13-2-5-130
DOSES AND EFFECTS ESTIMATED FOR AQUATIC BIODA EX		PROBABILITY OF	17-3-5-351
DOSES FROM THE NUCLEAR INDUSTRY TO 2000 A.D./		PROBABILITY OF	15-1-5-056
DOW CHEMICAL COMPANY ROCKY FLATS PLANT II./		PROBABILITY OF	15-6-4-723
DOW CHEMICAL COMPANY ROCKY FLATS PLANT I./		PROBABILITY OF	15-5-4-572
DRESDEN 2 INCIDENT OF JUNE-5, 1970/		PROBABILITY OF	12-5-7-538

	FOG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLING TOWERS	15-2-5-190
DOCUMENTATION/	SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED INST	16-2-6-221
AN ANALYSIS OF NBC METHODS FOR ESTIMATING THE EFFECTS OF	DRY DEPOSITION IN ENVIRONMENTAL RADIOLOGICAL ASS	20-4-5-858
IONS/	DRY DEPOSITION OF PARTICLES AND GASES FOR USE IN	19-2-5-205
	STRUCTURAL EFFECTS OF CONFINED	13-2-2-107
TY EFFECTS IN LARGE POWER REACTORS/	SPACE - TIME REACTOR	13-4-2-287
	STANDBY EMERGENCY POWER SYSTEMS I. THE	14-3-3-206
	SIMULATING STRONG MOTION	13-2-2-114
TUBES/	EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANTS/	14-1-1-001
	EARTHQUAKE RESISTANT DESIGN OF ENGINEERING STRUC	14-6-2-586
	EARTHQUAKES/	15-1-4-030
	RECENT ADVANCES IN ALTERNATE	19-4-4-473
ENVIRONMENT/	ECOS RULE-MAKING HEARING/	12-4-4-326
S PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM/	ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE EN	12-1-3-025
TING NUCLEAR POWER PLANTS/	ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWE	20-5-5-582
	BALANCING ENVIRONMENTAL IMPACT AND	13-3-1-204
PLANTS/	UNIQUE	20-6-1-555
	POWER PLANT DISCHARGES - TOWARD MORE REASONABLE	19-6-5-902
E CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN	EFFLUENTS I. AEC OWNED FACILITIES/	16-1-5-60
E CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN	EFFLUENTS II. AEC LICENSED FACILITIES/	16-1-5-71
NTS IN 1972/	RELASES OF RADIOACTIVITY IN	15-3-6-311
	SUMMARY OF RADIOACTIVITY RELEASED IN	16-6-6-739
EPROCESSING PLANTS IN EUROPE, 1972-1976/	RADIOACTIVE	20-4-6-468
1970-1974/	RADIOACTIVE	18-3-6-370
/	RADIOLOGICAL IMPACT OF AIRBORNE	19-4-5-497
PHYSICS SOCIETY/	POPULATION EXPOSURES - THE	16-6-5-720
SSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF	EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH P	18-2-3-168
	LOSS OF	18-1-3-53
VE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF	ELECTRICAL POWER COINCIDENT WITH LOCA/	17-2-1-171
LANTS IN SWEDEN AND THE UNITED STATES/	THE SEPARATION OF	19-6-3-723
CONTROL SYSTEMS/	A NEW APPROACH TO THE PROBLEMS OF	20-5-3-564
AN FUEL/	HEALTH EFFECTS OF	14-5-1-403
ACTIVATED CHARCOAL AT LOW CONCENTRATIONS/	THE	15-6-4-711
	NEUTRON IRRADIATION	12-2-4-100
	BRITTLENESS OF REACTOR PRESSURE VESSEL STEELS/	17-3-4-327
	EMERGENCIES/	17-1-1-1
	IN OVERVIEW OF NRC'S	11-4-6-323
PWRS/ THERMAL SHOCK STUDIES ASSOCIATED WITH INJECTION OF	EMERGENCY CORE COOLANT BYPASS RESEARCH/	20-3-2-267
MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF	EMERGENCY CORE COOLANT FOLLOWING A LOSS OF COOLA	19-1-2-10
STEAM - WATER MIXING STUDIES RELATED TO	EMERGENCY CORE COOLING/	15-3-2-285
OLED NUCLEAR POWER REACTORS/ NEW ACCEPTANCE CRITERIA FOR	EMERGENCY CORE COOLING SYSTEM PERFORMANCE/	17-2-2-185
LTS FROM THE L1-4 EXPERIMENT/	EMERGENCY CORE COOLING SYSTEMS OF LIGHT WATER CO	15-2-4-172
	EMERGENCY CORE-COOLING SYSTEM EXPERIMENTS - RESU	19-1-4-43
	NUCLEAR	14-6-1-563
LEAR FACILITIES/ STATE AND LOCAL GOVERNMENT RADIOLOGICAL	EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS/	14-3-3-206
NS IS THE EVOLUTION OF OPTIMUM TOWER DESIGN/	STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER PLANTS/	16-2-3-162
ICER/	EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUC	17-1-1-15
	EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIO	17-5-4-701
ESSURE VESSELS/ A PROGRESS REPORT ON THE USE OF ACOUSTIC	THE	13-6-5-882
TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPTON-85	EMISSION - A CRITICAL ASSESSMENT/	17-1-3-33
	EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PL	15-5-3-554
	ENERGETICS/	13-2-5-130
OST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRICAL	ENERGY/	18-3-3-322
NG/	ENERGY CENTER SITE SURVEY - 1975/	20-8-2-802
SALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC	ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITI	17-2-1-171
FIRE PROTECTION IN THE NUCLEAR FACILITIES OF THE ATOMIC	ENERGY COMMISSION AGRICULTURAL RESEARCH LABRATO	17-4-1-411
RISKS IN TRANSPORTING MATERIALS FOR VARIOUS	ENERGY COMMISSION, 1947-1975/	16-3-1-282
	ENERGY INDUSTRIES/	13-4-6-304
	ENERGY INVESTMENT IN NUCLEAR POWER PLANTS/	20-3-4-294
	ENERGY STATIONS/	19-2-1-135
ETICAL LMFBR ACCIDENTS/	THE NRC PROGRAM OF INSPECTION AND	19-3-1-269
	EFFECT OF	12-1-2-009
	HUMAN	19-6-1-671
INTERNATIONAL CONFERENCE ON NUCLEAR SYSTEMS RELIABILITY	ENGINEERED SAFETY FEATURES ON THE RISK OF HYPOTH	19-2-4-190
FISSION GAS EFFECTS IN REACTOR FUELS II.	ENGINEERING - AIDS TO SMOOTH OPERATION/	18-2-6-221
THE RELAP4 COMPUTER CODE 2.	ENGINEERING AND RISK ASSESSMENT/	19-1-3-38
NUCLEAR POWER PLANTS/	ENGINEERING APPLICATIONS/	12-6-2-562
ATE OF THE ART/	ENGINEERING DESIGN OF THE INPUT MODEL/	17-3-2-299
/	HUMAN	14-1-3-021
WEB SYSTEMS/	SYSTEM RELIABILITY	20-5-2-541
	RELIABILITY	12-5-4-496
	REVIEW OF	12-3-3-217
	EARTHQUAKE RESISTANT DESIGN OF	14-1-1-001
DING PHASE OF THE LOCA IN PWRS II. BUBBLING AND LIQUID	NATURAL AND TECHNOLOGICALLY	20-6-5-722
ICTABILITY/	EFFECTS ON ORGANISMS OF	19-2-2-160
	ECOLOGICAL ASPECTS OF TRITIUM BEHAVIOR IN THE	12-6-5-600
	NATURAL RADIATION IN THE URBAN	12-4-4-326
	RADIOLOGICAL QUALITY OF THE	13-4-1-275
	ENVIRONMENT/	18-2-5-215
	ENVIRONMENT/	20-3-3-280
ODES FOR THE ASSESSMENT OF RADIONUCLIDES RELEASED TO THE	ENVIRONMENT/	18-3-5-343
ON RADIOBIOLOGY APPLIED TO THE PROTECTION OF MAN AND HIS	ENVIRONMENT/	13-5-5-380
	SYMPOSIUM ON COOLING-TOWER	15-5-5-592
CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE	ENVIRONMENT FROM AN LMFBR/	14-4-5-325
	RADIOLOGICAL QUALITY OF THE	19-5-5-617
	RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION POWER/	18-2-5-203
	THE IAEA-AEC SYMPOSIUM ON	12-2-1-75
	THE REGULATION OF THE	14-1-1-006
	THE REGULATION OF THE	14-3-1-165
IMPACT OF THE COURTS/	BALANCING	13-3-1-209
CLEAR FUEL REPROCESSING PLANT/	THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NU	16-5-5-593
NUCLEAR FUEL REPROCESSING PLANT/	THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A	17-5-5-580

ON NAVAL NUCLEAR VESSELS AND SUPPORT FACILITIES IN 1978/ S/	ENVIRONMENTAL MONITORING AND DISPOSAL OF RADIOACT ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSI EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM/ ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACIL ENVIRONMENTAL RADIOLOGICAL ASSESSMENTS/ AN ANALY ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUEL ENVIRONMENTAL STATEMENT CONCERNING TME, AS LOW A ENVIRONMENTAL SURVEILLANCE FOR NUCLEAR FACILITIE ENVIRONMENTAL SURVEILLANCE PROGRAMS AT OPERATING ENVIRONMENTAL SURVEILLANCE TECHNIQUES/ ENVIRONMENTAL TRITIUM/ EPA'S ENVIRONMENTAL RADIATION ASSESSMENT PROGRAM EPRI WATER REACTOR SAFETY PROGRAM/ EQUATION - SOME CASE STUDIES/ EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMEN EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIE EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL/ EQUIPMENT AND SYSTEMS IN NUCLEAR POWER PLANTS IN EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED PA ERDA AIR CLEANING CONFERENCE/ ERDA RADIOLOGICAL ASSISTANCE PROGRAM/ ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTA ESTIMATED RADIOLOGICAL IMPACT/ SCENARIOS OF CARB ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULAT ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIS ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL ESTIMATING THE EFFECTS OF DRY DEPOSITION IN ENVI ESTIMATION OF RISKS TO THE PUBLIC FROM POTENTIAL EUROPE/ EUROPE, 1970-1974/ EUROPE, 1972-1976/ RADIOACTIVE EFFLUENTS FRO EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE N EVAPORATIVE COOLING TOWERS/ EVENT OF RELEASES OF RADIOIODINE/ EVENTS AT NUCLEAR POWER PLANTS AS REPORTED IN 19 EVOLUTION AND CURRENT STATUS OF THE DWR CONTAINM EVOLUTION OF OPTIMUM TOWER DESIGN/ EXCURSIONS IN IRRADIATED FAST REACTOR CORES/ EXECUTIVE CONFERENCE ON SAFEGUARDS/ EXHIBIT/ EXPERIENCE/ EXPERIENCE AT NUCLEAR POWER PLANTS/ EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR EXPERIENCE GAINED FROM RAPIDIE OPERATION/ EXPERIENCE IN RELIABILITY ANALYSIS OF SHUTDOWN S EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTOR EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN 1 EXPERIENCE WITH APPARENT POWER MISMATCH AND REAC EXPERIENCE WITH DIGITAL COMPUTER SOFTWARE/ EXPERIENCE WITH WATER COOLED NUCLEAR POWER REACT EXPERIENCE WITH 13 LIGHT WATER REACTORS IN EUROPE EXPLOSION AND FIRE DURING CONVERSION OF LIQUID U EXPOSED TO RADIOACTIVE RELEASES FROM LWR FUEL CY EXPOSURE AT LIGHT WATER COOLED NUCLEAR POWER REA EXPOSURE AT NUCLEAR POWER PLANTS/ EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/ EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC EXPOSURE BE RECORDED FOR RADIATION WORKERS/ EXPOSURE FROM THE U.S. NAVAL REACTOR PROGRAM, 19 EXPOSURE GUIDELINES/ EXPOSURE TO X-RAYS - U.S., 1970/ EXPOSURES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM EXPOSURES AT LICENSED FACILITIES, 1974/ EXPOSURES AT LICENSED FACILITIES, 1975/ EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, EXPOSURES AT LWRs, 1969-1974/ EXTENSION/ EXTINGUISHMENT/ FAIL SAFE DESIGN/ DETECTION OF THE ORR EMERGENCY COOLING FAILURE/ FAILURE/ FAILURE AND ITS EFFECTS IN LIGHT WATER REACTOR A FAILURE IN NUCLEAR PRESSURE VESSELS/ A PROGRESS FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTAN FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD/ FAILURE OF EMERGENCY CORE COOLING/ ANALYSIS FAILURE OF N REACTOR PRIMARY SCRAM SYSTEM/ FAILURE PROBABILITIES/ FAILURE PROBABILITY/ FAILURE PROPAGATION IN LIQUID METAL COOLED FAST FAILURE STATISTICS AND FAILURE PROBABILITIES/ FAILURE TO SCRAM IN LIGHT WATER REACTORS/ FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCL FAILURES AND THEIR CONSEQUENCES/ 18-2-3-105 16-6-1-667 16-2-5-204 20-4-5-458 12-3-1-185 15-4-5-440 19-1-5-66 19-4-5-486 17-3-5-344 17-2-5-216 16-6-1-667 16-6-1-659 19-1-1-1 17-3-5-337 11-6-2-450 13-6-2-467 19-6-3-723 17-2-4-238 18-2-4-174 16-3-5-345 17-3-5-351 19-5-5-602 13-2-5-130 17-6-1-659 13-1-5-054 20-4-5-458 15-4-1-375 18-5-6-666 18-3-6-370 20-4-6-469 16-4-4-458 15-2-5-190 19-6-5-732 20-1-6-83 15-2-4-163 17-6-4-701 14-3-2-201 19-4-1-427 13-5-3-366 20-2-6-210 16-2-6-224 16-1-6-79 14-1-6-027 19-6-3-712 16-3-6-354 16-5-6-603 17-2-6-231 19-6-6-748 18-3-6-355 11-2-6-142 17-6-3-693 20-5-6-595 18-5-6-666 19-1-6-91 17-3-5-351 19-6-6-760 16-5-6-614 18-4-5-492 13-4-6-304 14-3-5-220 20-3-6-345 12-5-2-456 15-4-5-453 16-6-5-720 17-6-6-743 18-4-6-523 18-3-6-365 17-5-6-622 19-4-1-433 15-2-2-146 12-3-3-226 13-3-3-220 11-4-6-323 14-3-2-187 12-5-3-487 15-5-3-554 17-6-3-686 14-4-6-362 15-3-2-285 12-6-6-604 15-4-2-387 19-6-2-681 16-3-2-291 15-4-2-387 20-6-3-690 16-3-6-354 16-5-6-603 17-2-6-231 18-3-6-355 19-6-6-748 16-2-3-150
--	--

ERICAL NUCLEAR POWER PLANTS ( JAN. 1, 1975-JUNE 30, 1978 )/ COMMON-MODE	SWITCH FAILURES AT NUCLEAR FACILITIES/ FAILURES IN AIR MONITORING, AIR CLEANING, AND VE FAILURES IN REACTOR SAFETY SYSTEMS/ FAILURES OF THREADED FITTINGS AND FASTENERS AT N FASTENERS AT NUCLEAR FACILITIES/ FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED	14-6-6-660 20-2-4-176 18-5-3-624 13-1-5-047 13-1-5-047 18-6-4-791
UCLEAR FACILITIES/ FERRITIC PRESSURE VESSEL STEELS/ PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE LWR FUEL BEHAVIOR RESEARCH IN THE COUPLED FLUID STRUCTURE ANALYSIS FOR LWRs IN THE NUCLEAR STANDARDS IN THE INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS/ THE NEW ON NRC LICENSING JURISDICTION AND PROCEDURES/ THE NEW A METHOD FOR VERIFYING REACTIVITY - FUEL MELTING INCIDENT AT THE FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED	FEDERAL REPUBLIC OF GERMANY/ FEDERAL REPUBLIC OF GERMANY/ FEDERAL REPUBLIC OF GERMANY/ FEDERAL REPUBLIC OF GERMANY - THE DIN NUCLEAR ST FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPA FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPA FEEDBACK TIME RESPONSE IN POWER REACTORS/ FERRI REACTOR ON OCT. 5, 1966/ FERRITIC PRESSURE VESSEL STEELS/ PERRY CHARCOAL ABSORBER INCIDENT/ PERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975/ DESIGN AND EVALUATION OF A SURVEY OF THE	15-4-3-909 19-2-2-176 20-5-2-551 19-3-1-297 15-3-1-262 16-4-1-821 13-4-3-295 12-2-6-123 18-6-4-791 20-1-6-78 17-5-6-592 14-5-4-470 17-2-5-223 20-1-4-63 11-6-2-463 19-3-1-281 20-3-4-308 15-4-5-440 14-6-5-651 19-1-6-91 20-3-4-308 17-5-6-592 20-3-4-294 19-4-5-497 16-3-5-337 12-4-2-297 12-6-2-562 19-6-2-699 11-5-3-379 18-5-2-596 12-2-3-90 12-5-5-516 11-4-4-315 13-1-5-054 13-1-5-047 15-7-4-295 17-1-1-15 15-5-4-572 15-6-4-723 20-5-5-582 15-4-2-399 19-1-2-20 14-2-3-105 19-1-2-20 20-5-2-551 15-6-2-676 18-3-2-298 14-2-1-079 15-2-5-190 11-1-5-043 20-6-6-735 20-6-2-671 18-2-2-154 11-2-5-130 12-3-1-185 18-2-4-174 13-1-3-029 13-3-0-181 19-1-5-60 18-2-1-133 12-5-5-523 11-5-4-391 16-6-2-693 19-5-2-565 19-5-2-588 19-5-2-584 19-4-1-411 20-6-3-690 14-5-1-409 13-6-2-467 12-6-1-533 16-4-2-436 17-1-6-363 17-1-2-19 17-6-2-699 1-5-2-565 1-5-2-588 17-2-2-176 14-5-2-452 14-6-2-597 17-3-5-351 13-3-3-220 20-1-4-54 12-1-4-035
R LOW WIND SPEED INVERSION CONDITIONS/ LOCATION OF NUCLEAR POWER PLANTS/ ION WRITING/ LOW AS PRACTICABLE HEARING/ TO SOLID URANIUM OXIDE/ ATOMIC ENERGY COMMISSION, 1947-1975/ RADIOLOGICAL IMPACT OF AIRBORNE EFFLUENTS OF COAL KINETICS EQUATION FOR LINEAR TUBES/ RING APPLICATIONS/ ATURE GAS-COOLED REACTORS/ REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR INTERNATIONAL CONGRESS ON THE DIFFUSION OF ON ESTIMATING FAILURES OF THREADED NO CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A MENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF HE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY UNIQUE ECOLOGICAL IMPACTS ASSOCIATED WITH OFFSHORE PROBABILISTIC ASSESSMENT OF CASE OF THE LOCA IN PWRs I. CORE HEAT TRANSFER AND FLUID LOW LEVEL ENVIRONMENTAL MONITORING BY ING PHASE OF THE LOCA IN PWRs I. CORE HEAT TRANSFER AND REPUBLIC OF GERMANY/ LOSS OF CRITICAL HEAT SAFETY ASSESSMENT PHILOSOPHY OF THE FAST G TOWERS/ TURNOVER AND CONCENTRATION OF RADIONUCLIDES IN SUMMARY OF TMI-2 LESSONS LEARNED TASK BURNOUT IN BOILING HEAT TRANSFER III. HIGH QUALITY IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY WER REACTOR WASTES/ STATUS OF INVESTIGATIONS OF SALT COMPARISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND THE THE FOURTEENTH IAEA AIR CLEANING CONFERENCE/ FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF TH FOURTH GENEVA CONFERENCE/ NUCLEAR SAFETY A FOURTH INTERNATIONAL CONGRESS OF THE INTERNATIONAL FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY FRAGMENTATION MODELING RELATIVE TO THE BREAKUP O FRAP FUEL BEHAVIOR COMPUTER CODES/ FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-S3/ FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP-S3/ FRENCH SAFETY STUDIES OF PRESSURIZED WATER REACT FREQUENCY OF FAILURE TO SCRAM IN LIGHT WATER REA HEALTH EFFEC SOME PRELIMINARY CONSIDERATIONS A COMPARISON OF TWO NITROGEN-16 RADIATI FUEL - A LOOK AT THE CASE DESIGNERS GUIDE/ FUEL - COOLANT INTERACTIONS/ FUEL AND REACTOR INDUSTRIES/ FUEL ASSEMBLIES/ FUEL AT HIGH BURNUP/ FRAP FUEL BEHAVIOR COMPUTER CODES/ FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP- FUEL BEHAVIOR RESEARCH IN THE FEDERAL REPUBLIC O FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/ FUEL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRAN FUEL CYCLE FACILITIES/ RADIATION DOSES AND EFFEC FUEL ELEMENTS/ FUEL FROM LIGHT WATER CTORS/ FUEL MELTDOWN AT ST. LAURENT I/	14-5-4-470 17-2-5-223 20-1-4-63 11-6-2-463 19-3-1-281 20-3-4-308 15-4-5-440 14-6-5-651 19-1-6-91 20-3-4-308 17-5-6-592 20-3-4-294 19-4-5-497 16-3-5-337 12-4-2-297 12-6-2-562 19-6-2-699 11-5-3-379 18-5-2-596 12-2-3-90 12-5-5-516 11-4-4-315 13-1-5-054 13-1-5-047 15-7-4-295 17-1-1-15 15-5-4-572 15-6-4-723 20-5-5-582 15-4-2-399 19-1-2-20 14-2-3-105 19-1-2-20 20-5-2-551 15-6-2-676 18-3-2-298 14-2-1-079 15-2-5-190 11-1-5-043 20-6-6-735 20-6-2-671 18-2-2-154 11-2-5-130 12-3-1-185 18-2-4-174 13-1-3-029 13-3-0-181 19-1-5-60 18-2-1-133 12-5-5-523 11-5-4-391 16-6-2-693 19-5-2-565 19-5-2-588 19-5-2-584 19-4-1-411 20-6-3-690 14-5-1-409 13-6-2-467 12-6-1-533 16-4-2-436 17-1-6-363 17-1-2-19 17-6-2-699 1-5-2-565 1-5-2-588 17-2-2-176 14-5-2-452 14-6-2-597 17-3-5-351 13-3-3-220 20-1-4-54 12-1-4-035	
S3/ F GERMANY/ INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR R AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM LWR DETECTION OF FAILED HANDLING AND STORAGE OF SPENT	U.S. STUDIES ON LMFBR THE SAFETY OF WORKERS IN THE NUCLEAR PARTIAL BLOCKAGES IN LMFBR FISSION GAS RELEASE FROM FRAP FUEL BEHAVIOR COMPUTER CODES/ FRAP FUEL BEHAVIOR COMPUTER CODES - ADDENDUM ON FRAP- LWR U.S. STUDIES ON LMFBR THE SAFETY OF WORKERS IN THE NUCLEAR FUEL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRAN FUEL CYCLE FACILITIES/ RADIATION DOSES AND EFFEC FUEL ELEMENTS/ FUEL FROM LIGHT WATER CTORS/ FUEL MELTDOWN AT ST. LAURENT I/	1-5-2-565 1-5-2-588 17-2-2-176 14-5-2-452 14-6-2-597 17-3-5-351 13-3-3-220 20-1-4-54 12-1-4-035



T. 5, 1956/	FUEL MELTING INCIDENT AT THE FWRMI REACTOR ON OC	12-2-6-123
MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC	FUEL REPROCESSING OPERATIONS/	14-5-5-482
HE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR	FUEL REPROCESSING PLANT/	16-5-5-593
ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR	FUEL REPROCESSING PLANT/	17-5-5-580
ATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR	FUEL REPROCESSING PLANT/ ESTIMATES OF DOSE TO NO	13-2-5-130
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS AND	FUEL REPROCESSING PLANTS IN EUROPE, 1972-1976/	20-4-6-868
REACTOR ACCIDENTS/	FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER	12-5-3-887
ADDITIONS/	FUEL RODS TESTED UNDER POWER COOLING MISMATCH CO	19-4-2-440
PROPAGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR	FUEL SUBASSEMBLIES/	16-3-2-291
IONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND POSSIBL	FUELED POWER PLANTS/ RADIATION IN PERSPECTIVE -	12-3-1-185
IARA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND	FUELING OF NUCLEAR POWER PLANTS/	16-1-6-79
DENSIFICATION OF REACTOR	FUELS/	14-4-6-356
FISSION GAS EFFECTS IN REACTOR	FUELS I. BASIC STUDIES/	12-4-2-297
FISSION GAS EFFECTS IN REACTOR	FUELS II. ENGINEERING APPLICATIONS/	12-6-2-562
PREDICTING SEA-BREEZE	FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS	12-2-5-110
RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF	FUSION POWER/	18-2-5-203
MINARY OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF	FUSION POWER/	13-5-1-353
TS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE	FWPCA AND RELATED LEGISLATION TO INDIVIDUAL DISC	15-3-1-262
S IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF	FWPCA ON NRC LICENSING JURISDICTION AND PROCEDURE	16-4-1-821
SAFETY EXPERIENCE	GAINED FROM NAPODIS OPERATION/	14-1-6-027
EFFECT OF RUPTURE IN A PRESSURIZED NOBLE	GAS ADSORPTION BED/	13-6-4-477
PLICATIONS/	FISSION GAS EFFECTS IN REACTOR FUELS I. BASIC STUDIES/	12-4-2-297
FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE	FISSION GAS EFFECTS IN REACTOR FUELS II. ENGINEERING AP	12-6-2-562
SION AT LAS VEGAS )/ SEPARATION AND CONTAINMENT OF NOBLE	FISSION GAS RELEASE FROM FUEL AT HIGH BURNUP/	19-6-2-699
ES (SYMPOSIUM AT LAS VEGAS )/ BIOLOGICAL EFFECTS OF NOBLE	GAS-COOLED REACTORS/	12-2-3-90
SPENSION AND FOR WET AND DRY DEPOSITION OF PARTICLES AND	GASES ( A REVIEW OF NINE PAPERS PRESENTED AT THE	15-3-4-302
ES ( A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE	GASES ( A REVIEW OF SELECTED PAPERS PRESENTED AT	15-6-5-732
A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE	GASES FOR USE IN RADIATION DOSE CALCULATIONS/ PA	19-2-5-205
SEQUENCES/	GASES SYMPOSIUM AT LAS VEGAS )/ SEPARATION AND C	15-3-4-302
COMPUTER CONTROL AT BRUCE NUCLEAR	GASSES SYMPOSIUM AT LAS VEGAS )/ BIOLOGICAL EFFE	15-6-5-732
TER COOLED POWER REACTORS/	GENERATION STATION/	16-2-3-150
RADIOLYTIC HYDROGEN	GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN WA	15-6-3-691
HEALTH EFFECTS OF ELECTRICITY	GENERATION FROM COAL, OIL, AND NUCLEAR FUEL/	13-6-2-459
A REASSESSMENT OF TURBINE	GENERATOR FAILURE PROBABILITY/	14-5-1-409
PLANTS/	GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER	19-6-2-681
TER COOLED NUCLEAR POWER REACTORS DURING 1972/	GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA	16-2-6-224
TER COOLED NUCLEAR POWER REACTORS IN 1973/	GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA	16-3-6-354
TER COOLED NUCLEAR POWER REACTORS IN 1974/	GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA	16-5-6-603
TER COOLED NUCLEAR REACTORS IN 1975/	GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA	17-2-6-231
TER COOLED NUCLEAR POWER REACTORS IN 1976/	GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN WA	18-3-6-355
WATER COOLED NUCLEAR POWER REACTORS DURING 1977/	GENERATOR TUBE PERFORMANCE - WORLD EXPERIENCE IN WA	19-6-6-748
OF THE FOURTH GENEVA CONFERENCE/	GENERATOR TUBE PERFORMANCE - WORLD EXPERIENCE IN	20-5-6-595
A - A REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOURTH	GENEVA - A REVIEW OF THE NUCLEAR SAFETY ASPECTS	13-3-0-181
AN/	GENEVA CONFERENCE/	13-3-0-181
Y/	GERMAN LIGHT WATER REACTOR RESEARCH PROGR	18-6-1-727
W OF NUCLEAR POWER PLANTS/	GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOG	14-3-1-181
LWR FUEL BEHAVIOR RESEARCH IN THE FEDERAL REPUBLIC OF	FIFTH	11-6-2-463
D STRUCTURE ANALYSIS FOR LWRs IN THE FEDERAL REPUBLIC OF	GERMANY/	19-2-2-176
SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL REPUBLIC OF	GERMANY/	20-5-2-551
NUCLEAR STANDARDS IN THE FEDERAL REPUBLIC OF	GERMANY/	15-4-3-409
NUCLEAR POWER IN PERSPECTIVE - THE FLIGHT OF THE BEMIG	GERMANY - THE DIN NUCLEAR STANDARDS COMMITTEE/	19-3-1-297
PROTECTION OF THE THYROID	GIANT/	12-4-1-283
IN SUPPORT OF FIXED NUCLEAR FACILITIES/ STATE AND LOCAL	GLAND IN THE EVENT OF RELEASES OF RADIOIODINE/	19-6-5-732
IZATION/	GOES PUBLIC - A CASE HISTORY/	11-5-1-365
CASKS FOR IRRADIATED FUEL - A LOOK AT THE CASK DESIGNERS	GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS	17-1-1-15
( A GUIDE FOR MANAGEMENT )/ U.S.A. STANDARD N13.2-1969	GUIDANCE FOR POWER PLANT SITING, DESIGN, AND OPE	18-3-5-329
FOR ADMINISTRATIVE PRACTICES IN RADIATION MONITORING ( A	GUIDE/	12-6-1-553
THE OUTCRY OVER EXPOSURE	GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION	11-1-5-039
THE DOE INTRUSION DETECTION SYSTEMS	GUIDE FOR MANAGEMENT )/ U.S.A. STANDARD N13.2-19	11-1-5-039
THE LEAK OF TANK 106-T AT	GUIDELINES/	12-5-2-456
RADIOACTIVE WASTE MANAGEMENT AT THE	HANDBOOKS/	20-1-3-44
PROBABILISTIC ASSESSMENT OF FLOODING	HANFORD/	15-4-6-460
E/	HANFORD RESERVATION/	20-4-4-434
SYMPOSIUM ON HEALTH PHYSICS IN THE	HAZARD FOR NUCLEAR POWER PLANTS/	15-4-2-399
RADIATION STANDARDS AND PUBLIC	HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WAST	16-2-4-190
TION PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGICAL	HEALTH/	14-4-5-340
ONS/ A COST BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR	HEALTH/	12-1-1-001
AL, OIL, AND NUCLEAR FUEL/	HEALTH AND SAFETY PROTECTIVE MEASURES AND REGOLA	15-2-5-195
ISLAND NUCLEAR STATION/	HEALTH EFFECTS OF ELECTRICITY GENERATION FROM CO	20-5-1-525
- A CRITICAL ASSESSMENT/	HEALTH IMPACT OF THE ACCIDENT AT THE THREE MILE	14-5-1-409
G/	HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES	20-5-5-591
EXPOSURES - THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE	HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITIN	18-5-5-647
PUBLIC	HEALTH PHYSICS IN THE HEALING ARTS/	12-5-6-530
THE ECCS RULE-MAKING	HEALTH PHYSICS SOCIETY/	14-4-5-340
OMMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE	HEALTH RISKS OF THERMAL POWER PLANTS/	16-6-5-720
P THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE	HEARING/	14-4-1-267
AEC TESTIMONY AT THE 1973 JCAE	HEARING/	15-1-4-030
METROLOGICAL EFFECTS OF THE	HEARING/	15-4-5-440
A SURVEY OF	HEARINGS ON REACTOR SAFETY/	15-4-5-443
BURNOUT IN BOILING	HEAT AND MOISTURE PRODUCED BY MAN/	15-2-1-132
BURNOUT IN BOILING	HEAT CONDUCTION COMPUTE PROGRAMS/	12-2-5-114
BURNOUT IN BOILING	HEAT CONDUCTION COMPUTE PROGRAMS/	12-6-2-569
BURNOUT IN BOILING	HEAT FLUX DURING A LOSS OF COOLANT ACCIDENT/	18-3-2-298
THE REFLOODING PHASE OF THE LOCA IN PWRs I. CORE	HEAT TRANSFER I. POOL BOILING SYSTEMS/	16-1-2-29
NATIONAL CONFERENCE ON WASTE	HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FOR	18-2-2-154
SYNOPSIS OF THE PWR BLOWDOWN	HEAT TRANSFER III. HIGH QUALITY FORCED CONVECTI	20-6-2-671
OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY RAPID	HEAT TRANSFER AND FLUID FLOW/	19-1-2-20
RACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM/	HEAT UTILIZATION/	13-3-1-216
R FUEL REPROCESSING PLANT/ ESTIMATES OF DOSE TO NORTHERN	HEAT-TRANSFER PROGRAM/	20-1-2-27
HEMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMI	HEATING/	11-1-2-012
	ANALYSIS	12-5-5-523
		13-2-5-130

CTRIC POWER/ D STATES - A TIME FOR DECISIONS/ BORNOUT IN BOILING HEAT TRANSFER III. FISSION PRODUCT DETECTION SYSTEMS IN ION ON RADIOECOLOGY APPLIED TO THE PROTECTION OF MAN AND / AEC GOES PUBLIC - A CASE NUCLEAR LIABILITY INSURANCE - A BRIEF THE CURRENT STATUS OF THE PLUTONIUM SAFETY DESIGN BASES OF IRE AN ASSESSMENT OF	FISSION GAS RELEASE FROM FUEL AT ASSESSMENT OF A HIGH BURNUP/ HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELE HIGH LEVEL NUCLEAR WASTE MANAGEMENT IN THE UNITE HIGH QUALITY FORCED CONVECTION SYSTEMS/ HIGH TEMPERATURE GAS-COOLED REACTORS/ HIS ENVIRONMENT/ HISTORY/ HISTORY REFLECTING THE SUCCESS OF NUCLEAR SAFETY HOMEMADE NUCLEAR BOMB SYNDROME/ HOT PARTICLE PROBLEM/ HTGR/ HTGR ACCIDENT CONSEQUENCES/ HTGR SAFETY/ HTGRS/ HUMAN ENGINEERING - AIDS TO SMOOTH OPERATION/ HUMAN ENGINEERING FACTORS IN CONTROL BOARD DESIG HUMAN FACTORS I. THE NUCLEAR CONTROL ROOM/ HUMAN RELIABILITY ANALYSIS/ HYDRAULIC FRACTURING/ HYDRODYNAMIC METHODS/ HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDE HYPOTHETICAL LWRFR ACCIDENTS/ HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE L HYPOTHETICAL VESSEL RUPTURE/ IAEA - WNC SYMPOSIUM ON HANDLING OF RADIATION AC IAEA INTERNATIONAL SYMPOSIUM ON NUCLEAR POWER P IAEA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUC IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIO IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND THE IAEA-ABC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF N IAEA-EMGR MEETING ON SODIUM COMBUSTION AND ITS IAEA-WMO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF R ICE CONDENSER REACTOR CONTAINMENT SYSTEM/ ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SU IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM/ IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970/ ILLINOIS COMMERCE COMMISSION/ IMPACT/ SCENARIOS OF CARBON-14 RELEASES FROM THE IMPACT AND ECONOMIC PROGRESS - THE IMPACT OF THE IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL REP IMPACT OF AIRBORNE EFFLUENTS OF COAL FIRED AND N IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL R IMPACT OF THE ACCIDENT AT THE THREE MILE ISLAND IMPACT OF TLE COURTS/ IMPACT OF THE PROPOSED REVISIONS TO IAEA REGULAT IMPACT OF THOR/UM MINING AND MILLING/ IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION O IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFF IMPACTS ASSOCIATED WITH OFFSHORE FLOATING NUCLEA IMPLICATIONS OF LARGE RELEASE OF RADIOIODINE/ IMPLICATIONS OF FUSION POWER/ IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PRE IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID META INACTIVE URANIUM MILLING SITES - AN OVERVIEW/ INCIDENT/ INCIDENT/ INCIDENT AT THE FERMI REACTOR ON OCT. 5, 1966/ INCIDENT AT THE LUCENS REACTOR/ INCIDENT DATA FILE/ INCIDENT OF JUNE-5, 1970/ INCIDENTS OF PRIMARY COOLANT RELEASE FROM OPERAT INCIDENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A INDIVIDUAL DISCHARGERS THROUGH PERMIT PROGRAMS/ INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS/ INDUSTRIES/ INDUSTRIES/ INDUSTRY/ INDUSTRY FROM 1975 TO 2020 AND THE ESTIMATED RAD INDUSTRY OVERVIEW/ INDUSTRY TO 2000 A.D./ INFORMATION MEETING/ INFORMATION MEETING/ INFORMATION MEETING/ INFORMATION MEETING/ INFORMATION MEETING/ INFORMATION MEETING/ INFORMATION MEETING/ INJECTION OF EMERGENCY CORE COOLANT FOLLOWING A INPUT MODEL/ INSPECTION AND ENFORCEMENT/ INSPECTION OF NUCLEAR POWER PLANT PRESSURE COMPO INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FA INSTITUTIONAL PROBLEMS IN POWER PLANT SITING/ INSTRUMENT SOCIETY OF AMERICA/ INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER REAC INSTRUMENTATION/ INSTRUMENTATION/ INSTRUMENTATION/ INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - INSTRUMENTATION AND CONTROL SYSTEMS/ A NE INSTRUMENTATION FOR MONITORING PLUTONIUM IN THE INSTRUMENTATION FOR MONITORING THE HYPOTHETICAL INSTRUMENTATION FOR THE SODIUM COOLED FAST REACT	19-6-2-698 18-2-3-168 19-3-5-356 20-6-2-671 12-2-3-90 13-5-5-389 11-5-1-365 12-4-1-291 18-4-1-427 17-4-5-464 14-6-4-618 18-6-2-761 12-5-1-438 16-5-2-546 18-2-6-223 14-1-3-021 18-6-3-774 17-3-3-315 11-5-4-391 14-2-2-091 13-6-2-459 19-2-4-190 11-6-3-464 14-4-2-291 12-4-5-314 15-1-3-015 20-2-3-166 13-2-1-103 16-1-6-79 12-2-1-75 15-2-2-146 15-3-5-306 11-3-4-215 17-6-4-710 16-5-3-557 12-4-3-310 14-6-1-574 19-5-5-602 13-3-1-209 16-5-5-593 19-4-5-497 17-5-5-580 20-5-5-591 13-3-1-209 13-2-1-103 20-3-5-319 15-3-1-262 16-4-1-421 20-5-5-582 19-6-5-741 13-5-1-353 17-6-6-733 18-4-3-469 17-6-5-722 20-1-6-78 20-4-6-483 12-2-6-123 16-1-6-76 20-3-4-308 12-5-7-538 15-1-6-076 15-5-3-554 15-3-1-262 11-2-1-107 17-3-6-363 19-2-1-135 16-4-4-854 19-5-5-602 12-5-2-444 15-1-5-056 15-3-1-241 16-1-1-8 17-2-1-143 18-2-1-133 19-3-1-281 20-3-1-249 19-1-2-10 17-3-2-299 19-6-1-671 17-6-6-733 18-4-3-469 18-2-1-127 13-1-3-029 15-6-3-702 16-2-6-223 15-1-3-015 15-4-3-417 13-5-3-366 20-5-3-564 20-3-3-280 11-6-1-468 16-6-3-701
--	---	--

SITES/ INSTRUMENTATION/ OF AMERICA/ FOR REACTOR PLANTS/ SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY	THE 16TH ANNUAL POWER THE FOURTEENTH POWER PROTECTION	INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCI INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED PO INSTRUMENTS/ INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWE INSURANCE - A BRIEF HISTORY REFLECTING THE SUCCES INSURANCE - A RESUME OF RECENT YEARS/ INTEGRAL TEST FACILITY AND PROGRAM/ INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC	18-5-3-617 15-4-3-417 13-1-3-029 11-3-3-206 16-4-3-452 16-6-3-714 12-4-1-291 16-5-1-537 15-6-2-676 18-2-3-163
PLANT/ OF NUCLEAR SAFETY/ POWER/ SUMMARY OF THE REPORT TO THE PRESIDENT BY THE A NEW APPROACH TO THE PROBLEMS OF ELECTRICAL GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT	NUCLEAR LIABILITY NUCLEAR LIABILITY LOSS OF FLUID TEST ASSESSMENT OF A HIGH CONVI MEETING ON FUEL - COOLANT SUMMARY OF THE REPORT TO THE PRESIDENT BY THE A NEW APPROACH TO THE PROBLEMS OF ELECTRICAL GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT	INTERACTIONS/ INTERAGENCY REVIEW GROUP ON NUCLEAR WASTE MANAGE INTERFERENCE IN INSTRUMENTATION AND CONTROL SYST INTERIOR STRUCTURES/ INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEA INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECT INTERNATIONAL CONFERENCE ON NUCLEAR SYSTEMS RELI INTERNATIONAL CONGRESS OF THE INTERNATIONAL RADI INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSI INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND INTERNATIONAL RADIATION PROTECTION ASSOCIATION/ INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPOR INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS INTERNATIONAL WASTE MANAGEMENT SYMPOSIUM/ INTERVENTION ON THE REACTOR LICENSING PROCESS/ INTRUSION DETECTION SYSTEMS HANDBOOK/ INVERSION CONDITIONS/ A SURVEY OF FIELD ME INVESTMENT IN NUCLEAR POWER PLANTS/ IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT LOW C IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED IODINE-129 RELEASED BY A NUCLEAR FUEL REPROCESSI IODINE-131 RELEASE/ RADON CONCEN	16-4-2-436 20-6-4-706 20-5-3-564 13-5-4-373 18-5-1-589 20-3-5-330 19-1-3-38 19-1-5-60 11-4-4-315 18-4-2-451 19-1-5-60 14-4-1-274 15-1-3-015 19-5-1-428 18-4-5-502 13-1-1-013 20-1-3-44 17-2-5-223 19-3-1-269 15-6-4-711 15-6-4-711 15-5-5-593 11-3-6-235 14-3-2-201 18-6-4-791 12-6-1-553 13-6-2-467 19-4-2-440 17-3-4-327 13-5-3-366 20-5-6-613 20-4-6-483 20-5-5-591 13-6-1-451 20-2-4-176 19-5-1-541 15-2-1-132 14-6-1-563 12-4-3-310 12-5-7-538 16-4-1-421 11-4-2-289 16-3-5-337 11-4-1-283 12-6-4-591 13-2-5-130 19-1-5-50 14-6-1-574 13-3-5-225 15-6-5-732 15-3-4-302 11-6-4-482 16-2-3-162 12-1-4-035 15-5-5-585 15-4-6-460 20-6-6-735 18-2-1-127 19-6-5-741 15-3-1-262 20-6-6-735 11-6-4-482 12-4-1-291 16-5-1-537 16-1-5-71 17-6-6-743 18-4-6-523 19-4-6-502 19-5-6-623 15-4-1-383 16-4-1-421 17-5-2-550 18-5-1-581 15-6-1-665 13-1-1-013 13-1-1-011 18-3-1-281 15-2-4-173 19-6-6-760 11-3-3-206 18-3-6-365 20-1-4-54
REACTOR PLANTS/ RELATED PHYSICS/ FOURTH INTERNATIONAL CONGRESS OF THE CONTROL AND INSTRUMENTATION/ OF REACTOR SAFETY/ SOME EFFECTS OF PUBLIC MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED CONCENTRATIONS/ CHARCOAL AT LOW CONCENTRATIONS/ NG PLANT/ NTRATION IN REACTOR CONTAINMENT BUILDINGS MASQUERADES AS FACTORS LIMITING PROBLEMS-CRITICAL EXCURSIONS IN FATIGUE CRACK PROPAGATION IN NEUTRON CASKS FOR MANY CONSIDERATIONS RELATING TO AN EQUATION OF STATE FOR ING MISMATCH CONDITIONS/ SSEL STEELS/ INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE 26TH DEVELOPMENTS PERTAINING TO THE THREE MILE PRELIMINARY REPORT ON THE THREE MILE DOSE AND HEALTH IMPACT OF THE ACCIDENT AT THE THREE MILE ISLAND NUCLEAR STATION/ ISPRAS CONTRIBUTION TO REACTOR SAFETY/ JAN. 1, 1975-JUNE-30, 1978 )/ JAPAN/ JCAE HEARINGS ON REACTOR SAFETY/ JERSEY/ JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR JUNE-5, 1970/ JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WAT KINETICS/ KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR KRYPTON - XENON REMOVAL SYSTEMS/ KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPR LAND BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION/ LAS VEGAS/ LAS VEGAS )/ BIOLOGICAL EFFECTS OF NOBLE GASES ( LAS VEGAS )/ SEPARATION AND CONTAINMENT OF NOBLE LATE MORTALITY RISKS FROM REACTOR ACCIDENTS/ ATER PLANTS/ LAURENT I/ THE LAW AND LOW LEVEL RADIATION/ THE LEAK OF TASK 106-T AT HANFORD/ LEARNED TASK FORCE REPORT/ LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT LEGAL IMPLICATIONS OF A LARGE RELEASE OF RADIOIO LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PE LESSONS LEARNED TASK FORCE REPORT/ LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING LIABILITY INSURANCE - A RESUME OF RECENT YEARS/ LICENSED FACILITIES/ THE CONTROL, MONITORI LICENSED FACILITIES, 1974/ LICENSED FACILITIES, 1975/ LICENSED OPERATOR REQUALIFICATION PROGRAMS FOR N LICENSING/ LICENSING BOARD PANEL/ LICENSING JURISDICTION AND PROCEDURES/ THE NEW F LICENSING OF LMPRES/ LICENSING OF NUCLEAR POWER PLANTS/ LICENSING OF NUCLEAR POWER REACTORS/ LICENSING PROCESS/ LICENSING PROCESS/ THE ROLE OF THE LICENSING PROCESS - A STATUS REPORT/ LIGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW A OCCUPATIONAL RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEA. POWER REACTORS, 1969- PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED POWER REACTOR PLANTS/ OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/ HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER CTORS/	1976 THIRD IAEA 1976 THIRD IAEA THE DOE ENERGY IODIDE ELEMENTAL THE ENVIRONMENTAL IMPACT NEUTRON CASKS FOR STATE FOR UNIRRADIATED AND NEUTRON ISLAND ACCIDENT/ ISLAND INCIDENT/ ISLAND NUCLEAR STATION/ PRELIMINARY JAN. 1, 1975-JUNE-30, 1978 )/ JAPAN/ JCAE HEARINGS ON REACTOR SAFETY/ JERSEY/ JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR JUNE-5, 1970/ JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WAT KINETICS/ KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR KRYPTON - XENON REMOVAL SYSTEMS/ KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPR LAND BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL LAPP REPORT TO THE ILLINOIS COMMERCE COMMISSION/ LAS VEGAS/ LAS VEGAS )/ BIOLOGICAL EFFECTS OF NOBLE GASES ( LAS VEGAS )/ SEPARATION AND CONTAINMENT OF NOBLE LATE MORTALITY RISKS FROM REACTOR ACCIDENTS/ ATER PLANTS/ LAURENT I/ THE LAW AND LOW LEVEL RADIATION/ THE LEAK OF TASK 106-T AT HANFORD/ LEARNED TASK FORCE REPORT/ LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT LEGAL IMPLICATIONS OF A LARGE RELEASE OF RADIOIO LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PE LESSONS LEARNED TASK FORCE REPORT/ LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF LIABILITY INSURANCE - A BRIEF HISTORY REFLECTING LIABILITY INSURANCE - A RESUME OF RECENT YEARS/ LICENSED FACILITIES/ THE CONTROL, MONITORI LICENSED FACILITIES, 1974/ LICENSED FACILITIES, 1975/ LICENSED OPERATOR REQUALIFICATION PROGRAMS FOR N LICENSING/ LICENSING BOARD PANEL/ LICENSING JURISDICTION AND PROCEDURES/ THE NEW F LICENSING OF LMPRES/ LICENSING OF NUCLEAR POWER PLANTS/ LICENSING OF NUCLEAR POWER REACTORS/ LICENSING PROCESS/ LICENSING PROCESS/ THE ROLE OF THE LICENSING PROCESS - A STATUS REPORT/ LIGHT WATER COOLED NUCLEAR POWER REACTORS/ NEW A OCCUPATIONAL RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEA. POWER REACTORS, 1969- PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED POWER REACTOR PLANTS/ OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS, 1969-1975/ HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER CTORS/		

BRING THE HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE	LIGHT WATER POWER REACTORS/ INSTRUMENTATION FOR	11-6-3-868
FUEL ROD FAILURE AND ITS EFFECTS IN	LIGHT WATER REACTOR ACCIDENTS/	12-5-3-487
A SURVEY OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH	LIGHT WATER REACTOR CONTAINMENTS/	15-6-3-702
STRESS CORROSION CRACKING IN PIPING OF	LIGHT WATER REACTOR PLANTS/	20-6-6-729
973-1977 EXPERIENCE/	OUTAGES AT LIGHT WATER REACTOR POWER PLANTS - A REVIEW OF 1	20-2-6-210
	LIGHT WATER REACTOR SAFETY/	12-5-1-433
AMERICAN PHYSICAL SOCIETY'S STUDY OF	LIGHT WATER REACTOR SAFETY/	16-5-1-5-2
	LIGHT WATER REACTOR SAFETY RESEARCH IN JAPAN/	19-5-1-5-41
	GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM/	18-6-1-727
	RELIABILITY OF PIPING IN LIGHT WATER REACTORS/	17-5-4-569
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR	LIGHT WATER REACTORS/	20-4-3-422
ASSESSMENT OF THE FREQUENCY OF FAILURE TO SCRAM FOR	LIGHT WATER REACTORS/	20-6-3-690
LOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN	LIGHT WATER REACTORS/	18-1-4-60
PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN	LIGHT WATER REACTORS - LOSS OF COOLANT ACCIDENTS	14-1-2-014
PROBABILITY ANALYSIS APPLIED TO	LIGHT WATER REACTORS IN EUROPE/	18-5-6-656
OPERATING EXPERIENCE WITH 13	FACTORS LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATE	14-3-2-201
D FAST REACTOR CORES/	LIMITS ON CHLORINE/	18-6-5-802
POWER PLANT DISCHARGES - TOWARD MORE REASONABLE EFFLUENT	LINEAR ACCELERATOR CENTER/	11-6-1-435
BEAM SAFETY CONSIDERATIONS AT THE STANFORD	LINEAR FIRST-ORDER NUCLEAR PHENOMENA/	16-3-5-317
	KINETICS EQUATION FOR	17-2-4-204
	EQUIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER REAC	19-2-2-160
TORS/	LIQUID ENTRAINMENT/	THE
REFLOODING PHASE OF THE LOCA IN PWRs II. FRETTING AND	LIQUID METAL COOLED FAST BREEDER REACTORS I. P	16-1-4-43
CTION/ RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF	LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SU	16-3-2-291
ASSEMBLIES/	PIN-TO-PIN FAILURE PROPAGATION IN	13-1-4-037
	CONTAMINATION CONTROL OF SODIUM RELEASES FROM	17-2-4-208
	EQUIPMENT CELL LINERS FOR	18-4-3-469
	IN-SERVICE INSPECTION TECHNIQUES FOR	16-3-4-318
NSPORT/ RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF	LIQUID METAL COOLED FAST BREEDER REACTORS II. T	11-1-1-001
	THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM	14-5-2-446
	LIQUID NITROGEN - CALCULATION AND MEASUREMENT/	19-1-6-91
	AN EXPLOSION AND FIRE DURING CONVERSION OF	16-4-4-454
	APPLICATION OF EVAPORATION TO THE TREATMENT OF	12-6-3-581
	SUBCRITICALITY MEASUREMENT IN AN	14-4-5-325
ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN	LMFBR/	14-4-2-304
	PHENOMENOLOGICAL RESEARCH IN	20-4-2-402
	THE MECHANISTIC ANALYSIS OF	19-2-4-190
F ENGINEERED SAFETY FEATURES ON THE RISK OF HYPOTHETICAL	LMFBR ACCIDENTS/	EFFECT O
	PARTIAL BLOCKAGES IN	17-1-2-19
	U.S. STUDIES ON	14-5-2-452
	LMFBR FUEL ASSEMBLIES/	12-5-1-421
	LMFBR FUEL BEHAVIOR UNDER ACCIDENT CONDITIONS/	11-5-3-374
	LMFBR SAFETY/	17-5-2-550
IUM/	LMFBR SAFETY I. FISSION PRODUCT BEHAVIOR IN SOD	13-2-2-107
OF CORE DISRUPTIVE ACCIDENTS IN DESIGN AND LICENSING OF	LMFBR/	18-1-3-53
STRUCTURAL EFFECTS OF CONFINED DYNAMIC	LOADS/	17-4-2-422
LOSS OF ELECTRIC POWER COINCIDENT WITH	LOCA/	17-6-2-671
THE RELAP4 COMPUTER CODE III.	LOCA ANALYSIS RESULTS OF A TYPICAL PWR PLANT/	19-1-2-20
	DATA SOURCES FOR	19-1-2-20
OW/	THE REFLOODING PHASE OF THE	LOCA IN PWRs I. CORE HEAT TRANSFER AND FLUID FL
NT/	THE REFLOODING PHASE OF THE	LOCA IN PWRs II. FRETTING AND LIQUID ENTRAINME
PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES/ STATE AND	LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE	17-1-1-15
ICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL	LOCATIONS/	12-2-5-110
RESULTS FROM THE LI-4 EXPERIMENT/	LOFT EMERGENCY CORE-COOLING SYSTEM EXPERIMENTS -	19-1-4-43
RESULTS OF THE FIRST THREE NONNUCLEAR TESTS IN THE	LOFT FACILITY/	18-3-2-306
	THE USE OF ACTUATORS AS	LOGIC ELEMENTS IN RELATION TO FAIL SAFE DESIGN/
CASKS FOR IRRADIATED FUEL - A	LOOK AT THE CASK DESIGNERS GUIDE/	12-3-3-226
THE SODIUM	LOOP SAFETY FACILITY/	12-6-1-551
CRITICAL HEAT FLUX DURING A	LOSS OF COOLANT ACCIDENT/	19-3-4-339
TED WITH INJECTION OF EMERGENCY CORE COOLANT FOLLOWING A	LOSS OF COOLANT ACCIDENT IN PWRs/ THERMAL SHOCK	18-3-2-298
PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REACTORS -	LOSS OF COOLANT ACCIDENTS/	19-1-2-10
ROPTURE/	LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL VESSEL	14-1-2-014
REACTORS/	RADIOLYTIC HYDROGEN GENERATION AFTER	14-4-2-291
F EMERGENCY CORE COOLING/	ANALYSIS OF A SUDDEN MAJOR	13-6-2-459
ASSESSMENT OF A HIGH INTEGRITY PROTECTIVE SYSTEM FOR	LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE O	15-3-2-285
	LOSS OF ELECTRIC POWER/	18-2-3-164
	LOSS OF ELECTRIC POWER COINCIDENT WITH LOCA/	14-1-3-53
OGRAM/	LOSS OF FLUID TEST INTEGRAL TEST FACILITY AND PR	15-6-2-676
FACTORS/ INSTRUMENTATION FOR MONITORING THE HYPOTHETICAL	LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER PO	11-6-3-463
VIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS	LOW AS PRACTICABLE HEARING/	15-4-5-440
CLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS	LOW AS PRACTICABLE HEARING/	CON
NE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL AT	LOW CONCENTRATIONS/	15-4-5-443
NS ANALYSIS/	LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIO	15-6-4-711
	THE LAW AND	14-2-3-105
BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND	LOW QUALITY FORCED CONVECTION SYSTEMS/	15-5-5-585
VEY OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER	LOW WIND SPEED INVERSION CONDITIONS/	18-2-2-154
	INCIDENT AT THE	17-2-5-223
	LUCERN REACTOR/	16-1-6-76
IC OF GERMANY/	LWR FUEL BEHAVIOR RESEARCH IN THE FEDERAL REPUBL	19-2-2-176
D FOR AQUATIC BIOTA EXPOSED TO RADIOACTIVE RELEASES FROM	LWR FUEL CYCLE FACILITIES/ RADIATION DOSES AND E	17-3-5-351
RELATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO	LWR SAFETY/	17-4-4-447
COUPLED FLUID STRUCTURE ANALYSIS FOR	LMWS IN THE FEDERAL REPUBLIC OF GERMANY/	20-5-2-551
OCCUPATIONAL RADIATION EXPOSURES AT	LWRS, 1969-1974/	17-5-6-622
GENCY CORE-COOLING SYSTEM EXPERIMENTS - RESULTS FROM THE	LI-4 EXPERIMENT/	19-1-4-43
	QUANTIFICATION OF MAN -	MACHINE SYSTEM RELIABILITY IN PROCESS CONTROL/
	VALVE	MALFUNCTIONS IN NUCLEAR POWER PLANTS/
AN ANALYSIS OF CONTROL ROD SYSTEM	MALFUNCTIONS IN NUCLEAR POWER REACTORS/	14-4-3-315
ZOOLOGICAL EFFECTS OF THE HEAT AND MOISTURE PRODUCED BY	MAN/	12-2-5-114
ROL/	QUANTIFICATION OF	MAN - MACHINE SYSTEM RELIABILITY IN PROCESS CONT
SYMPOSIUM ON RADIOECOLOGY APPLIED TO THE PROTECTION OF	MAN AND HIS ENVIRONMENT/	16-3-3-316
ESIDENT BY THE INTERAGENCY REVIEW GROUP ON NUCLEAR WASTE	MANAGEMENT/	13-5-5-380
STRATIVE PRACTICES IN RADIATION MONITORING ( A GUIDE FOR	SUMMARY OF THE REPORT TO THE PR	20-6-4-706
	MANAGEMENT ) / U.S.A. STANDARD N13.2-1969 - GUIDE	11-1-5-039
	RADIOACTIVE WASTE	MANAGEMENT AT THE HANFORD RESERVATION/
SIONS/	HIGH LEVEL NUCLEAR WASTE	MANAGEMENT IN THE UNITED STATES - A TIME FOR DEC
C FUEL REPROCESSING OPERATIONS/	INTERNATIONAL WASTE	MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AE
	MANAGEMENT SYMPOSIUM/	18-4-5-5-2
	BROWNS FERRY NUCLEAR POWER PLANT FIRE ON	MAR. 22, 1975/
LIDES DISCHARGED FROM A DWR NUCLEAR POWER STATION INTO A	MARINE BAY/ ABUNDANCE AND DISTRIBUTION OF RADION	17-5-6-592
		20-2-5-190

	NUCLEAR SAFETY EXPERIMENTS IN THE MARVIKEN POWER STATION/	18-4-4-481
RADON CONCENTRATION IN REACTOR CONTAINMENT BUILDINGS	MASQUERADES AS IODINE-131 RELEASE/	11-3-6-235
REST/	CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTE	17-5-1-539
	RADIOTOXIC HAZARD	16-2-4-180
OF NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY PROTECTIVE	MEASURES FOR BURIED SOLID RADIOACTIVE WASTE/	20-5-1-525
	THE AIRIAL MEASURING SYSTEMS PROGRAM/	20-2-1-136
CTOR SAFETY/	COMMON-MODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REA	17-6-3-686
S/	THE MECHANISTIC ANALYSIS OF LMPBR ACCIDENT PNERGETIC	20-4-2-402
OF RADIOIODINE/	MEDICAL AND LEGAL IMPLICATIONS OF A LARGE RELEAS	19-6-5-741
TION WORKERS/	MEDICAL RADIATION EXPOSURE BY RECORDED POP RADIA	14-3-5-220
TS/	SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFEC	11-6-4-475
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-3-1-241
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-8
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
	FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
	FIFTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	19-3-1-281
	SIXTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	20-3-1-249
	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	17-3-1-289
	THE THIRD RELIABILITY MEETING AT RISO/	11-4-3-309
CS/	1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	16-2-1-141
	1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELIABILITY PHYSI	18-4-2-451
	CSNI MEETING ON FUEL - COOLANT INTERACTIONS/	16-4-2-436
POWER PLANTS/	REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/	16-3-1-273
	IAEA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUCLEAR	20-2-3-166
	THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	16-3-3-308
	SECOND SPECIALISTS MEETING ON REACTOR NOISE/	19-4-3-468
ENT/	IAEA-IGFR MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHM	15-2-2-146
	ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY/	19-2-1-153
	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	14-5-1-439
	PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REACTORS/	18-1-4-60
	MELTDOWN AT ST. LAURENT I/	12-1-4-035
S DURING OUTGASSING/	UNEXPECTED MELTDOWN OF SCLAP URANIUM - ALUMINUM CERMET CORE	15-4-6-455
966/	PHENOMENOLOGICAL INVESTIGATION OF MELTING INCIDENT AT THE PERMI REACTOR ON OCT.5,1	12-2-6-123
RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID	METAL COOLED FAST BREEDER REACTORS I. PRODUCTI	16-1-4-43
LIES/	PIN-TO-PIN FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER REACTOR FUEL SUBASSEMB	16-3-2-291
	CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER REACTORS/	13-1-4-037
	EQUIPMENT CFFL LINERS FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	17-2-4-208
	IN-SERVICE INSPECTION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER REACTORS/	18-4-3-469
	RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPOR	16-3-4-318
	THE LIQUID METAL FAST BREEDER REACTOR 5 "TY PROGRAM/	11-1-1-001
PRODUCED BY MAN/	METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE	12-2-5-114
RT/	SYSTEM RELIABILITY ENGINEERING METHODOLOGY - A DISCUSSION OF THE STATE OF THE A	20-5-2-541
T LOW CONCENTRATIONS/	ELEMENTAL IODINE AND METHYL IODIDE ADSORPTION ON ACTIVATED CHARCOAL A	15-6-4-711
	QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLANT/	17-1-6-87
SOCIETY/	POPULATION EXPOSURES - THE EIGHTH MILE ISLAND ACCIDENT/	16-6-5-720
	DEVELOPMENTS PERTAINING TO THE THREE PRELIMINARY REPORT ON THE THREE	20-5-6-613
	MILE ISLAND INCIDENT/	20-4-6-483
	PRELIMINARY REPORT ON THE THREE MILE ISLAND NUCLEAR STATION/	20-5-5-591
NARY DOSE AND HEALTH IMPACT OF THE ACCIDENT AT THE THREE	MILLING/	20-3-5-319
	RADIOLOGICAL IMPACT OF THORIUM MINING AND MILLING SITES - AN OVERVIEW/	17-6-5-722
	RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MINE ATMOSPHERES/	14-6-5-643
ES FOR REMOVAL OF RADON AND RADON DAUGHTER PRODUCTS FROM	RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOURCES	12-4-2-305
AVAILABLE FOR RISK REDUCTION/	RISK MINING AND MILLING/	20-3-5-319
	RADIOLOGICAL IMPACT OF THORIUM MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALI	11-2-6-142
ES/	SAN ONOPRE EXPERIENCE WITH APPARENT POWER MISMATCH CONDITIONS/	19-4-2-440
AND IRRADIATED PWR FUEL RODS TESTED UNDER POWER COOLING	A METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE PROBABILITIES/	16-4-2-441
	RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH REACTOR/	17-4-3-437
SYSTEM PERFORMANCE/	STEAM - WATER MIXING STUDIES RELATED TO EMERGENCY CORE COOLING	17-2-2-185
RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF THE INPUT	MODEL/	17-3-2-299
UM DIOXIDE IN SODIUM/	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANI	16-6-2-683
	METEOROLOGICAL EFFECTS OF THE HEAT AND MOISTURE PRODUCED BY MAN/	12-2-5-114
	FRAGMENTATION MODELING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM/	16-6-2-683
	QUO VADIS, PERSONNEL MONITORING/	16-6-5-728
2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION	MONITORING ( A GUIDE FOR MANAGEMENT ) / U.S.A. ST	11-1-5-039
AR VESSELS AND SUPPORT FACILITIES IN 1978/ ENVIRONMENTAL	MONITORING AND DISPOSAL OF RADIOACTIVE WASTE PRO	20-4-5-446
	LOW LEVEL ENVIRONMENTAL MONITORING BY FLUCTUATIONS ANALYSIS/	14-2-3-105
	INSTRUMENTATION FOR MONITORING PLUTONIUM IN THE ENVIRONMENT/	20-3-3-280
IN LARGE LIGHT WATER POWER REACTORS/ INSTRUMENTATION FOR	MONITORING THE HYPOTHETICAL LOSS-OF-COOLANT ACCI	11-6-3-468
OWER PLANTS ( JAN. 1, 1975-JUNE-30, 1978 ) / FAILURES IN AIR	MONITORING, AIR CLEANING, AND VENTILATION SYSTEM	20-2-4-176
PLUENTS I. AEC OWNED FACILITIES/	THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EF	16-1-5-60
PLUENTS II. AEC LICENSED FACILITIES/	THE CONTROL, MONITORING, AND REPORTING OF RADIOACTIVITY IN EF	16-1-5-71
RUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE	MORTALITY RISKS FROM REACTOR ACCIDENTS/	11-6-4-482
S/	SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANT	13-2-2-114
	NATIONAL CONFERENCE ON WASTE HEAT UTILIZATION/	13-3-1-216
REFLECTIONS ON THE BECRITICALITY CONFERENCE AT ARGONNE	NATIONAL LABORATORY/	18-1-2-45
/	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY	14-5-1-439
RADON-222/	NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES OF	20-6-5-722
S/	NATURAL BACKGROUND RADIATION IN THE UNITED STATE	17-4-5-471
	NATURAL RADIATION IN THE URBAN ENVIRONMENT/	13-4-1-275
MENTAL MONITORING AND DISPOSAL OF RADIOACTIVE WASTE FROM	NAVAL NUCLEAR VESSELS AND SUPPORT FACILITIES I.	20-4-5-446
OCCUPATIONAL RADIATION EXPOSURE FROM THE U.S.	NAVAL REACTOR PROGRAM, 1977/	20-3-6-345
TROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FILLED	NEUTRON ABSORBER/	15-3-4-295
LS/	FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEE	18-6-4-791
SSURE VESSEL STEELS/	NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRE	17-3-4-327
	POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HTGRS/	16-5-2-546
	COUPLED NEUTRONICS HYDRODYNAMICS METHODS/	14-2-2-091
AN EXPLOSION AND FIRE DURING CONVERSION OF LIQUID URANYL	NITRATE TO SOLID URANIUM OXIDE/	19-1-6-91
OZONE FORMATION BY THE RADIOLYSIS OF LIQUID	NITROGEN - CALCULATION AND MEASUREMENT/	14-5-2-446
Q TYPES OF RESEARCH REACTOR FUEL/	A COMPARISON OF TWO NITROGEN-16 RADIATION SUPPRESSION DEVICES FOR TW	11-3-6-237
	EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BED/	13-6-4-478
SYMPOSIUM AT LAS VEGAS ) / SEPARATION AND CONTAINMENT OF	NOBLE GASES ( A REVIEW OF NINE PAPERS PRESENTED	15-3-4-302
E GASSES SYMPOSIUM AT LAS VEGAS ) / BIOLOGICAL EFFECTS OF	NOBLE CASES ( A REVIEW OF SELECTED PAPERS PRESEN	15-6-5-732

LE GASES ( A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS )/ SEPARATION	15-1-4-302
ASES ( A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS )/ BIOLOGICA	15-6-5-732
THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	16-1-3-308
SECOND SPECIALISTS MEETING ON REACTOR NOISE/	19-4-3-468
ND REGULATIONS/ A COST BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY PROTECTIVE MEASURES	20-5-1-525
RESULTS OF THE FIRST THREE NONNUCLEAR TESTS IN THE LOFT FACILITY/	18-3-2-306
R REACTORS I. PRODUCTION/ RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BRE	16-1-4-41
ER REACTORS II. TRANSPORT/ RADIONUCLIDE BEHAVIOR DURING NORMAL OPERATION OF LIQUID METAL COOLED FAST BRE	16-3-4-318
LE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULATION GROUPS FROM KRYPT	11-2-5-130
RESEARCH/ NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-6-1-651
ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON WRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY R	18-5-1-589
N ENVIRONMENTAL RADIOLOGICAL ASSESSMENTS/ AN ANALYSIS OF NRC LICENSING JURISDICTION AND PROCEDURES/ THE N	16-4-1-421
THE NRC METHODS FOR ESTIMATING THE EFFECTS OF DRY DE NRC PROGRAM OF INSPECTION AND ENFORCEMENT/	20-4-5-458
PROGRAMS FOR NUCLEAR POWER PLANTS/ NRC REVIEW OF LICENSED OPERATOR REQUALIFICATION	19-6-1-671
SAFETY STUDY/ REPORT OF THE NRC RISK ASSESSMENT REVIEW GROUP ON THE REACTOR	20-1-1-24
EXTENSION/ NRC SAFETY RESEARCH PROGRAM/	20-4-1-199
ETING/ NRC SAFETY RESEARCH PROGRAM - A CRITIQUE AND AN	19-4-1-433
ETING/ FIFTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION ME	19-3-1-241
ER PLANTS/ SIXTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION ME	20-3-1-249
AN OVERVIEW OF NRC WATER REACTOR SAFETY RESEARCH PROGRAM/	18-1-1-1
REVIEW OF AUGUST 1974 CHANGE IN THE NRC'S EMERGENCY CODE COOLANT BYPASS RESEARCH/	20-3-2-267
ANOTHER PERSPECTIVE OF THE 1958 SOVIET NRC'S PROGRAM FOR STANDARDIZATION OF NUCLEAR POW	20-1-1-258
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENT/	20-2-6-206
COMPUTER CODES FOR ANALYZING NUCLEAR ACCIDENTS/	12-5-3-461
PROBLEMS IN NUCLEAR AIR CLEANING SYSTEMS/	15-5-2-535
CTIVE - SOME COMPARISONS OF THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/ RADIATIO	16-4-4-469
E MEASURES AND REGULATIONS/ A COST BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY PROTECT	12-3-1-185
THE HOMEMADE NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY PROTECT	20-5-1-525
PROBABILITY OF DAMAGE TO NUCLEAR BOMB SYNDROME/	18-8-1-427
HUMAN FACTORS IN THE NUCLEAR COMPONENTS DUE TO TURBINE FAILURE/	14-3-2-187
PLANNING FOR NUCLEAR CONTROL ROOM/	18-6-3-774
ERSEY/ NUCLEAR EMERGENCIES/	17-1-1-1
FOR SITING/ NUCLEAR EMERGENCY PLANNING IN THE STATE OF NEW J	14-6-1-563
OFFSHORE SITING OF NUCLEAR ENERGY CENTER SITE SURVEY - 1975/	17-4-1-411
FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REAC	16-3-1-282
SWITCH FAILURES AT NUCLEAR ENERGY STATIONS/	12-1-2-009
CURRENT CHALLENGES IN AIR CLEANING AT NUCLEAR FACILITIES/	13-1-5-047
ENVIRONMENTAL SURVEILLANCE FOR NUCLEAR FACILITIES/	14-6-6-660
TES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES/	18-5-4-633
RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES/	19-1-5-66
TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR NUCLEAR FACILITIES/ STATE AND LOCAL GOVERNMENT R	17-6-1-659
ENVIRONMENTAL RADIATION EFFECTS OF NUCLEAR FACILITIES - A CRITICAL ASSESSMENT/ ESTIMA	17-1-1-15
ON, 1947-1975/ NUCLEAR FACILITIES IN NEW YORK STATE/	16-5-5-647
REVIEW OF FIRE PROTECTION IN THE NUCLEAR FACILITIES OF THE ATOMIC ENERGY COMMISSI	16-2-5-204
SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITIES PERSONNEL/	20-3-4-294
SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY PERSONNEL/	12-6-6-615
TH EFFECTS OF ELECTRICITY GENERATION FROM COAL, OIL, AND NUCLEAR FACILITY SITING/	17-1-6-92
RELATIONS RELATING TO AN EQUATION OF STATE FOR IRRADIATED NUCLEAR FUEL/	12-5-6-530
THE SAFETY OF WORKERS IN THE NUCLEAR FUEL/	14-5-1-409
ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL AND REACTOR INDUSTRIES/	13-6-2-467
THE ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL CYCLE/ PROBABILITY AND CONSEQUENCES	17-3-6-363
THE ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	14-6-2-597
RE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATES OF DO	16-5-5-593
CATION OF EVAPORATION TO THE TREATMENT OF LIQUIDS IN THE NUCLEAR GENERATING STATION/	17-5-5-590
PLANNING THE SUCCESS OF NUCLEAR SAFETY/ NUCLEAR INDUSTRY TO 2000 A.D./	13-2-5-130
YEARS/ NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY RE	15-6-3-691
SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUCLEAR MATERIALS/	16-4-4-458
KINETICS EQUATION FOR LINEAR FIRST-ORDER NUCLEAR PHENOMENA/	15-1-5-056
A SYSTEMS APPROACH TO NUCLEAR PLANT FIRE INCIDENT DATA FILE/	12-4-1-791
EMP AND NUCLEAR PLANT SAFETY/	16-5-1-1
UNDERGROUND NUCLEAR PLANT SAFETY - A TECHNICAL AND SAFETY AS	15-5-1-513
SIZING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES/	16-3-5-337
THE IAEA-AEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER/	20-3-4-308
RISKS ASSOCIATED WITH NUCLEAR POWER - AN INDUSTRY OVERVIEW/	11-6-1-445
PUBLIC OPPOSITION TO NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMM	18-3-3-322
STATE RESPONSIBILITIES FOR NUCLEAR POWER APPLICATIONS/	15-5-1-519
QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE	14-6-4-634
BENIGN GIANT/ NUCLEAR POWER INDUSTRY FROM 1975 TO 2020 AND THE	12-2-1-75
L IMPACT/ SCENARIOS OF CARBON-14 RELEASES FROM THE WORLD NUCLEAR POWER PLANT/	20-6-1-664
SILICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT/	12-5-2-448
QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLANT/	14-6-1-574
THE RELAP COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT ANALYSIS/	14-3-3-117
EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY/	12-4-1-283
STATISTICS FOR 1973/ U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY ST	19-5-5-602
IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT CONTROL AND INSTRUMENTATION/	16-6-3-714
BROWNS FERRY NUCLEAR POWER PLANT FIRE ON MAR. 22, 1975/	17-1-6-87
IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT PERFORMANCE ANALYSIS/	17-2-2-194
THE DESIGN BASIS FOR NUCLEAR POWER PLANT PRESSURE COMPONENTS/	15-5-6-599
RS/ NUCLEAR POWER PLANT SAFETY IN DEVELOPING COUNTRI	15-6-6-738
ON/ SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RELATED INSTRUMENTATI	15-1-3-015
REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIGNALATORS/	17-5-6-592
AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SITES/	18-5-6-664
INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT SITES/	17-6-6-733
REVIEW OF AHS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/	11-1-3-020
TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT STRUCTURES/	20-2-1-123







STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS/		14-3-3-206
PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/		14-4-1-267
MATERIALS PERFORMANCE AT NUCLEAR POWER PLANTS/		14-5-6-507
VALVE MALFUNCTIONS IN NUCLEAR POWER PLANTS/		15-3-6-316
NOVEL SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/		15-6-1-651
QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER PLANTS/		16-2-1-127
STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER PLANTS/		16-2-3-162
DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER PLANTS/		16-2-6-224
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/		16-5-4-581
OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER PLANTS/		16-5-6-614
TRENDS IN THE LICENSING OF NUCLEAR POWER PLANTS/		18-5-1-581
ENERGY INVESTMENT IN NUCLEAR POWER PLANTS/		19-3-1-269
EDUCATION AND PUBLIC ACCEPTANCE OF NUCLEAR POWER PLANTS/		20-6-1-655
EA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER PLANTS/	IA	20-2-3-166
RESS CORROSION CRACKING IN PIPING OF LIGHT WATER REACTOR PLANTS/	ST	20-6-6-729
STATISTICAL ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER PLANTS/	PRO	15-3-2-276
LATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER PLANTS/	SINU	13-2-2-114
REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	THE	14-1-1-006
REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER PLANTS/	THE	14-3-1-165
HELISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER PLANTS/	PROBA	15-4-2-399
BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLANTS/	COST -	17-5-1-525
SMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	AN ASSES	15-6-1-673
ERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER PLANTS/	HUMAN ENGIN	14-1-3-021
TRUMENTATION SYSTEMS IN LIGHT WATER COOLED POWER REACTOR PLANTS/	PROTECTION IMS	17-3-3-206
OSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER PLANTS/	FIFTH GERMAN SEM	11-6-2-463
N EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER PLANTS/	IAEA SYMPOSIUM O	16-1-6-79
CT OF AIRBORNE EFFLUENTS OF COAL FIRED AND NUCLEAR POWER PLANTS/	RADIOLOGICAL IMPA	19-4-5-497
IMPACTS ASSOCIATED WITH OFFSHORE FLOATING NUCLEAR POWER PLANTS/	UNIQUE ECOLOGICAL	20-5-5-582
NSD OPERATOR REQUALIFICATION PROGRAMS FOR NUCLEAR POWER PLANTS/	NRC REVIEW OF LICEN	19-4-6-502
D THE NRC'S PROGRAM FOR STANDARDIZATION OF NUCLEAR POWER PLANTS/	REVIEW OF AUGUST 1978 CHANGES T	20-3-1-258
ENVIRONMENTAL SURVEILLANCE PROGRAMS AT OPERATING NUCLEAR POWER PLANTS/	PLANNING AND VALIDATION OF ENVIRO	19-4-5-486
ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/ RADIATION IN PERSPECTIVE - SOME COMPARIS		12-3-1-185
TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER PLANTS/ THE AMC STUDY ON THE ESTIMATION OF RISKS		15-4-1-375
ER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS I. APPLICATION OF THE FWPCA AND RELATED		15-3-1-262
ER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER PLANTS PART II. THE EFFECT OF FWPCA ON NRC LICEN		16-4-1-421
OUTAGES AT LIGHT WATER REACTOR PLANTS - A REVIEW OF 1973-1977 EXPERIENCE/		20-2-6-210
ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM/		12-1-3-025
ING, AND VENTILATION SYSTEMS IN COMMERCIAL NUCLEAR POWER PLANTS ( JAN. 1, 1975-JUNE-30, 1978 ) / FAILURES IN		20-2-4-176
A REVIEW OF SAFETY RELATED EVENTS AT NUCLEAR POWER PLANTS AS REPORTED IN 1977/		20-1-6-83
F RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS DURING 1973/	SUMMARY O	16-6-6-734
LUENTS FROM NUCLEAR POWER STATIONS AND FUEL REPROCESSING PLANTS IN EUROPE, 1972-1976/	RADIOACTIVE EFF	20-4-6-468
ION OF ELECTRICAL EQUIPMENT AND SYSTEMS IN NUCLEAR POWER PLANTS IN SWEDEN AND THE UNITED STATES/	THE SEPA	19-6-3-723
SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR POWER PLANTS IN 1972/		15-1-6-067
ACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	RELEASES OF RADIO	15-3-6-311
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN 1974/		18-1-6-79
RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN 1976/		19-5-6-628
RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN 1977/		20-4-6-476
NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE DENIGN GIANT/		12-4-1-283
RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA/		12-1-3-015
RESTRICTED RELEASE OF PLUTONIUM II. THEORY/		12-2-2-85
CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PROBLEM/		12-3-2-203
INSTRUMENTATION FOR MONITORING PLUTONIUM IN THE ENVIRONMENT/		17-4-5-464
CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST/		20-3-3-280
SCHARGERS THROUGH PERMIT PROGRAMS/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR		17-5-1-539
NSING JURISDICTION AND PROCEDURES/ THE NEW FEDERAL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR		15-3-1-262
BURNOUT IN BOILING HEAT TRANSFER I. POOL BOILING SYSTEMS/		16-4-1-421
SITING PRACTICE AND ITS RELATION TO POPULATION/		16-1-2-29
TES/ POPULATION DENSITY AROUND NUCLEAR POWER PLANT SI		14-6-1-576
OD A.O./ POPULATION DOSES FROM THE NUCLEAR INDUSTRY TO 20		16-1-1-1
L SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/ POPULATION EXPOSURE TO X-RAYS - U.S. 1970/		15-1-5-056
CESSING PLANT/ ESTIMATES OF DOSE TO NORTHERN HEMISPHERE POPULATION EXPOSURES - THE EIGHTH MIDYEAR TOPICA		16-6-5-720
ASSESSMENT/ TRENDS IN PUBLIC HEALTH IN THE SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRUMENTS/		13-2-5-130
CTORS/ PHENOMENOLOGICAL INVESTIGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER REA		18-5-5-647
POTENTIAL EFFECTS AND CONSEQUENCES OF POSTULATED NEUTRONIC ACCIDENTS IN HTGRS/		16-4-3-452
ARC STUDY ON THE ESTIMATION OF RISKS TO THE PUBLIC FROM POSTULATED NEUTRONIC ACCIDENTS IN HTGRS/		18-1-4-60
ANCE TECHNIQUES/ IDENTIFICATION OF POTENTIAL IMPROVEMENTS IN ENVIRONMENTAL SURVEILL		16-5-2-546
RADIOLOGICAL AND ENVIRONMENTAL ASPECTS OF FUSION POWER/		17-3-5-344
A REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER/		18-2-5-203
RISKS ASSOCIATED WITH NUCLEAR POWER/		18-5-2-596
E IAEA-ABC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR POWER/	TH	20-6-1-664
OBSERVATIONS ON THE RADIOLOGICAL IMPLICATIONS OF FUSION POWER/	PRELIMINARY	12-2-1-75
A HIGH INTEGRITY PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC POWER/	ASSESSMENT OF	13-5-1-353
PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY OVERVIEW/		18-2-3-168
MISSION/ STATE RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT TO THE ILLINOIS COMMERCE COM		12-5-2-448
QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER AND NUCLEAR SCIENCE GROUPS - 1970/		14-6-1-574
LOSS OF ELECTRIC POWER COINCIDENT WITH LOCA/		12-4-3-310
UNIRRADIATED AND IRRADIATED PWR FUEL RODS TESTED UNDER POWER COOLING MISMATCH CONDITIONS/	RESPONSE O	18-3-3-317
GIANT/ NUCLEAR POWER IN PERSPECTIVE - THE PLIGHT OF THE DENIGN		18-1-3-53
/ SCENARIOS OF CARBON-14 RELEASES FROM THE WORLD NUCLEAR POWER INDUSTRY FROM 1975 TO 2020 AND THE ESTIMAT		19-4-2-41 J
ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION/	THE 16TH	12-4-1-743
POWER INSTRUMENTATION/ THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR		15-4-3-417
T SOCIETY OF AMERICA/ THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMEN		15-4-3-417
NONALIERS/ SAN ONOFRE EXPERIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE A		13-1-3-029
QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR POWER PLANT/		11-2-6-142
ICONE RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLEAR POWER PLANT/	SIL	17-1-6-87
THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR POWER PLANT ANALYSIS/		16-6-3-714
EVALUATION OF NUCLEAR POWER PLANT AVAILABILITY/		17-2-2-194
		15-5-6-599

FOR 1973/	U.S. NUCLEAR POWER	PLANT AVAILABILITY AND CAPACITY STATISTICS	15-6-6-738
IAEA INTERNATIONAL SYMPOSIUMS ON	NUCLEAR POWER	PLANT CONTROL AND INSTRUMENTATION/	15-1-3-015
EFFLUENT LIMITS ON CHLORINE/	NUCLEAR POWER	PLANT DISCHARGES - TOWARD MORE REASONABLE	18-6-5-802
	BROWNS FERRY NUCLEAR POWER	PLANT PIPE ON MAR.22,1975/	17-5-6-592
	NUCLEAR POWER	PLANT PERFORMANCE ANALYSIS/	18-5-6-664
	IN-SERVICE INSPECTION OF NUCLEAR POWER	PLANT PRESSURE COMPONENTS/	17-6-6-733
	THE DESIGN BASIS FOR NUCLEAR POWER	PLANT PROTECTION SYSTEMS/	11-1-3-020
	NUCLEAR POWER	PLANT SAFETY AND EARTHQUAKES/	14-6-2-596
	NUCLEAR POWER	PLANT SAFETY IN DEVELOPING COUNTRIES/	20-2-1-123
	SET-POINT DRIFT IN NUCLEAR POWER	PLANT SAFETY RELATED INSTRUMENTATION/	16-2-6-223
	REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER	PLANT SIMULATORS/	16-4-5-482
	AEC WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER	PLANT SITES/	16-1-1-1
	INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER	PLANT SITES/	18-5-3-617
	REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER	PLANT SITING/	16-3-1-273
	LEGAL AND INSTITUTIONAL PROBLEMS IN NUCLEAR POWER	PLANT SITING/	18-2-1-127
	COLD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR NUCLEAR POWER	PLANT SITING, DESIGN, AND OPERATION/	18-3-5-329
	TORNADO CONSIDERATIONS FOR NUCLEAR POWER	PLANT STRUCTURES/	11-4-2-296
	TORNADO RESISTANT DESIGN OF NUCLEAR POWER	PLANT STRUCTURES/	15-4-4-432
	INDUSTRIAL SABOTAGE IN NUCLEAR POWER	PLANTS/	11-2-1-107
	SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER	PLANTS/	13-2-2-114
	THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER	PLANTS/	14-1-1-006
	THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLEAR POWER	PLANTS/	14-3-1-165
	PUBLIC HEALTH RISKS OF THERMAL NUCLEAR POWER	PLANTS/	14-4-1-267
	MATERIALS PERFORMANCE AT NUCLEAR POWER	PLANTS/	14-5-6-507
	PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NUCLEAR POWER	PLANTS/	15-3-2-276
	VALVE MALFUNCTIONS IN NUCLEAR POWER	PLANTS/	15-3-6-316
	PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR NUCLEAR POWER	PLANTS/	15-4-2-399
	NOVEL SITING SOLUTIONS FOR NUCLEAR POWER	PLANTS/	15-6-1-651
	QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR POWER	PLANTS/	16-2-1-127
	DIESEL GENERATOR OPERATING EXPERIENCE AT NUCLEAR POWER	PLANTS/	16-2-6-224
	SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER	PLANTS/	16-5-4-581
	OCCUPATIONAL RADIATION EXPOSURE AT NUCLEAR POWER	PLANTS/	16-5-6-614
	COST - BENEFIT AND RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER	PLANTS/	17-5-1-525
	TRENDS IN THE LICENSING OF NUCLEAR POWER	PLANTS/	18-5-1-581
	ENERGY INVESTMENT IN NUCLEAR POWER	PLANTS/	19-3-1-269
	IAEA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER	PLANTS/	20-2-3-166
	EDUCATION AND PUBLIC ACCEPTANCE OF NUCLEAR POWER	PLANTS/	20-6-1-655
	ASSESSMENT OF ACCIDENT RISKS IN U.S. COMMERCIAL NUCLEAR POWER	PLANTS/	AN 15-6-3-673
	ENGINEERING FACTORS IN CONTROL BOARD DESIGN FOR NUCLEAR POWER	PLANTS/	HUMAN 14-1-3-021
	AN SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER	PLANTS/	FIFTH GERM 11-6-2-463
	SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELING OF NUCLEAR POWER	PLANTS/	IAEA SYMPO 16-1-6-79
	IMPACT OF AIRBORNE EFFLUENTS OF COAL FIRED AND NUCLEAR POWER	PLANTS/	RADIOLOGICA 19-4-5-497
	ECOLOGICAL IMPACTS ASSOCIATED WITH OFFSHORE FLOATING NUCLEAR POWER	PLANTS/	UNIQUE ECOL 20-5-5-582
	FOR LICENSED OPERATOR REQUALIFICATION PROGRAMS FOR NUCLEAR POWER	PLANTS/	NRC REVIEW O 19-4-6-502
	ANGES TO THE NRC'S PROGRAM FOR STANDARDIZATION OF NUCLEAR POWER	PLANTS/	REVIEW OF AUGUST 1978 CHA 20-3-1-258
	ENVIRONMENTAL SURVEILLANCE PROGRAMS AT OPERATING NUCLEAR POWER	PLANTS/	PLANNING AND VALIDATION OF 19-4-5-486
	THE ENVIRONMENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED NUCLEAR POWER	PLANTS/	RADIATION IN PERSPECTIVE - SOME CO 12-3-1-185
	RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER	PLANTS/	THE AEC STUDY ON THE ESTIMATION OF 15-4-1-375
	AL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER	PLANTS	1. APPLICATION OF THE FWPCA AND RE 15-3-1-262
	AL WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER	PLANTS	PART II. THE EFFECT OF FWPCA ON RE 16-4-1-421
	OUTAGES AT LIGHT WATER REACTOR NUCLEAR POWER	PLANTS	- A REVIEW OF 1973-1977 EXPERIENCE/ 20-2-6-210
	LEAK/ ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER	PLANTS	- THE LONG TERM BIOTIC EFFECTS PROB 12-1-3-025
	CLEANING, AND VENTILATION SYSTEMS IN COMMERCIAL NUCLEAR POWER	PLANTS	{ JAN.1,1975-JUNE-30,1978 }/ FAILUR 20-2-4-176
	A REVIEW OF SAFETY RELATED EVENTS AT NUCLEAR POWER	PLANTS	AS REPORTED IN 1977/ 20-1-6-83
	AMOUNT OF RADIOACTIVITY RELEASED IN EFFLUENTS FROM NUCLEAR POWER	PLANTS	DURING 1973/ SUM 16-6-6-734
	COMPARISON OF ELECTRICAL EQUIPMENT AND SYSTEMS IN NUCLEAR POWER	PLANTS	IN SWEDEN AND THE UNITED STATES/ TH 19-6-3-723
	SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR NUCLEAR POWER	PLANTS	IN 1972/ 15-1-6-067
	RADIOACTIVITY IN EFFLUENTS AND SOLID WASTE FROM NUCLEAR POWER	PLANTS	IN 1972/ RELEASES OF 15-3-6-311
	RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER	PLANTS	IN 1974/ 18-1-6-79
	RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER	PLANTS	IN 1976/ 19-5-6-628
	RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER	PLANTS	IN 1977/ 20-4-6-476
	NUCLEAR POWER	REACTOR DECOMMISSIONING/	20-1-1-15
	SUMMARY OF RECENT ABNORMAL OCCURRENCES AT NUCLEAR POWER	REACTOR FACILITIES/	15-2-6-198
	PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED NUCLEAR POWER	REACTOR PLANTS/	11-3-3-206
	REPORT ON THE 1970 ANS CONFERENCE ON NUCLEAR POWER	REACTOR SYSTEMS AND COMPONENTS/	12-2-6-134
	ASPECTS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE NUCLEAR POWER	REACTOR WASTES/	STATUS OF INVESTIGATION 11-2-5-130
	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED NUCLEAR POWER	REACTORS/	15-2-3-151
	BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER	REACTORS/	15-6-1-665
	ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIAL NUCLEAR POWER	REACTORS/	19-5-3-590
	ANALYSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER	REACTORS/	A 14-4-3-315
	MODE FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN NUCLEAR POWER	REACTORS/	A MET 13-4-3-295
	OPERATION AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED NUCLEAR POWER	REACTORS/	RADIOLYTIC HYDROGEN GE 13-6-2-459
	POTENTIAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER NUCLEAR POWER	REACTORS/	INSTRUMENTATION FOR MONITORING T 11-6-3-468
	GENUINE CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER	REACTORS/	NEW ACCEPTANCE CRITERIA FOR EMER 15-2-4-173
	THE 1970 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE NUCLEAR POWER	REACTORS/	SPACE - TIME REACTOR DYNAMICS - 13-4-2-287
	REGULATION OF NUCLEAR POWER	REACTORS AND RELATED FACILITIES/	15-1-1-001
	TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS	DURING 1972/ STEAM GENERATOR 16-3-6-354
	PERFORMANCE - WORLD EXPERIENCE WITH WATER COOLED NUCLEAR POWER	REACTORS	DURING 1977/ STEAM GENERATOR TUBE 20-5-6-595
	TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS	IN 1973/ STEAM GENERATOR 16-5-6-601
	TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS	IN 1974/ STEAM GENERATOR 17-2-6-231
	TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS	IN 1976/ STEAM GENERATOR 19-6-6-748
	SAFETY AND SECURITY OF NUCLEAR POWER	REACTORS	TO ACTS OF SABOTAGE/ 17-6-1-665
	OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED NUCLEAR POWER	REACTORS,	1969-1975/ 18-3-6-365
	NATIONAL RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEAR POWER	REACTORS,	1969-1976/ OCCRP 19-6-6-760
	ON ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL NUCLEAR POWER	SOURCE STRENGTH/	13-1-5-054
	NUCLEAR SAFETY EXPERIMENTS IN THE MARVIKEN NUCLEAR POWER	STATION/	18-4-4-481
	DISTRIBUTION OF RADIONUCLIDES DISCHARGED FROM A BWR NUCLEAR POWER	STATION INTO A MARINE BAY/	ABUNDANCE AND D 20-2-5-190
	LONG OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER	STATIONS/	CONTROL 18-4-5-492
	EUROPE, 1972-1976/ RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER	STATIONS AND FUEL REPROCESSING PLANTS IN E	20-4-6-468
	RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER	STATIONS IN EUROPE, 1970-1974/	18-3-6-370
	RELIABILITY OF D-C NUCLEAR POWER	SUPPLIES/	19-3-7-330

5/	IAEA MEETING ON POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER PLANT	20-2-3-166
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/		12-3-3-217
STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PLANTS/		14-3-3-206
IEEE NUCLEAR POWER SYSTEMS SYMPOSIUM/		16-5-3-557
STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER PLANTS/		16-2-3-162
FINAL ENVIRONMENTAL STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE HEARING/	REVIEW OF	15-4-5-440
STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE HEARING/	CONCLUDING	15-4-5-443
SITING PRACTICE AND ITS RELATION TO POPULATION/		14-6-1-576
QUALITY ASSURANCE STANDARDS AND PRACTICES/		12-6-1-549
SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POWER PLANTS/		16-5-4-581
U.S.A. STANDARD N13.7-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIATION MONITORING ( A GUIDE FOR		11-1-5-039
ORGANISMS OF ENTAINMENT IN COOLING WATER - STEPS TOWARD PREDICTABILITY/	EFFECTS ON	12-6-5-600
S AT COASTAL LOCATIONS/		12-2-5-110
ON OF STATE FOR IRRADIATED NUCLEAR FUEL/	SOME	13-6-2-467
NT AT THE THREE MILE ISLAND NUCLEAR STATION/	PRELIMINARY CONSIDERATIONS RELATING TO AN EQUATI	20-5-5-591
LOCATIONS OF FUSION POWER/	PRELIMINARY OBSERVATIONS ON THE RADIOLOGICAL IMP	13-5-1-353
ORNT/	PRELIMINARY REPORT ON THE THREE MILE ISLAND INCI	20-4-6-483
AND CONTAINMENT OF NOBLE GASES ( A REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT L		15-3-4-302
CAL EFFECTS OF NOBLE GASES ( A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT L		15-6-5-732
LEAR WASTE MANAGEMENT/	SUMMARY OF THE REPORT TO THE	20-8-4-706
IN-SERVICE INSPECTION OF NUCLEAR POWER PLANT	PRESIDENT BY THE INTERAGENCY REVIEW GROUP ON NUC	17-6-6-733
RAPID HEATING/	ANALYSIS OF	11-1-2-012
THE ICE CONDENSER SYSTEM FOR CONTAINMENT	PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY R	17-6-4-710
REACTOR VESSEL	PRESSURE SUPPRESSION/	18-4-6-513
CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR	PRESSURE TRANSIENTS/	11-2-4-119
IMPROVING REACTOR	PRESSURE VESSEL/	17-1-4-62
ROBABILITIES/	PRESSURE VESSEL AVAILABILITY BY DESIGN/	15-4-2-387
NEUTRON IRRADIATION EMBRITTLMENT OF REACTOR	PRESSURE VESSEL FAILURE STATISTICS AND FAILURE P	17-3-4-327
FATIGUE CRACK PROPAGATION IN NEUTRON IRRADIATED FERRITIC	PRESSURE VESSEL STEELS/	18-6-4-791
RELATION OF INTERMEDIATE SIZED	PRESSURE VESSEL STEELS/	17-4-4-447
THE SAFETY OF REACTOR	PRESSURE VESSEL TESTS TO LWR SAFETY/	17-1-4-55
REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR	PRESSURE VESSELS/	11-1-4-025
ACOUSTIC EMISSION TO DETECT INCIPENT FAILURE IN NUCLEAR	PRESSURE VESSELS/	A
EFFECT OF RUPTURE IN A	PRESSURE VESSELS/ A PROGRESS REPORT ON THE USE O	15-5-3-554
TRENDS IN THE DESIGN OF	PRESSURIZED NOBLE GAS ADSORPTION BED/	13-6-4-478
AND SYSTEMS/	PRESSURIZED WATER REACTOR CONTAINMENT STRUCTURES	18-2-4-189
NTS BY HYPOTHETICAL VESSEL RUPTURE/	PRESSURIZED WATER REACTOR LOSS OF COOLANT ACCIDE	14-4-2-291
FRENCH SAFETY STUDIES OF	PRESSURIZED WATER REACTORS/	19-4-1-411
RECENT ADVANCES IN ALTERNATE ECCS STUDIES FOR	PRESSURIZED WATER REACTORS/	19-4-4-473
ARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN	PRESSURIZED WATER REACTORS/	11-3-4-223
A REVIEW OF THE TECHNOLOGY OF	PRESTRESSED CONCRETE REACTOR PRESSURE VESSELS/	11-1-4-025
EVALUATION OF INCIDENTS OF	PRIMARY COOLANT RELPASE FROM OPERATING BOILING W	15-1-6-076
FAILURE OF N REACTOR	PRIMARY SCRAM SYSTEM/	12-6-6-608
NUCLEAR ENERGY CENTERS - A	PRIME ELEMENT IN REACTOR SITING/	16-3-1-282
CLEAR POWER PLANTS/	PROBABILISTIC ASSESSMENT OF AIRCRAFT RISK FOR NU	15-3-2-276
NUCLEAR POWER PLANTS/	PROBABILISTIC ASSESSMENT OF FLOODING HAZARD FOR	15-4-2-399
PRESSURE VESSEL FAILURE STATISTICS AND FAILURE	PROBABILITIES/	15-4-2-387
AIRCRAFT CRASH	PROBABILITIES/	17-3-2-312
METHOD OF CALCULATING TURBINE MISSILE STRIKE AND DAMAGE	PROBABILITIES/	A
A REASSESSMENT OF TURBINE GENERATOR FAILURE	PROBABILITY/	16-4-2-843
RE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON RISK	PROBABILITY/	19-6-2-681
LOSS OF COOLANT ACCIDENTS/	PROBABILITY/	13-1-2-022
RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE/	PROBABILITY ANALYSIS APPLIED TO LIGHT WATER REAC	14-1-2-014
STIC VIEWPOINT AND SOME SUGGESTIONS/	PROBABILITY AND CONSEQUENCES OF TRANSPORTATION A	14-6-2-597
TO TURBINE FAILURE/	PROBABILITY AND RISK ASSESSMENT - THE SUBJECTIVE	19-3-2-305
INTERNATIONAL CONGRESS ON THE DIFFUSION OF FISSION	PROBABILITY OF DAMAGE TO NUCLEAR COMPONENTS DUE	14-3-2-187
S AND TECHNIQUES FOR REMOVAL OF RADON AND RADON DAUGHTER	PRODUCTS/	11-4-4-315
A SURVEY OF HEAT CONDUCTION COMPUTER	PRODUCTS FROM MINE ATMOSPHERES/	PROBLEM
TED LEGISLATION TO INDIVIDUAL DISCHARGERS THROUGH PERMIT	PROGRAMS/	14-6-5-643
PLANNING AND VALIDATION OF ENVIRONMENTAL SURVEILLANCE	PROGRAMS/	12-6-2-569
INSTRUMENTATION	PROGRAMS AT OPERATING NUCLEAR POWER PLANTS/	15-3-1-262
NRC REVIEW OF LICENSED OPERATOR REQUALIFICATION	PROGRAMS FOR NUCLEAR POWER PLANT SITES/	19-4-5-486
REACTOR OPERATOR TRAINING	PROGRAMS FOR NUCLEAR POWER PLANTS/	18-5-3-617
BALANCING ENVIRONMENTAL IMPACT AND ECONOMIC	PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATOR	19-4-6-502
FIFTH GERMAN SYMPOSIUM ON	PROGRESS - THE IMPACT OF THE COURTS/	16-4-5-492
DEFECT INCIPENT FAILURE IN NUCLEAR PRESSURE VESSELS/ A	PROGRESS IN SAFETY EVALUATION OF NUCLEAR POWER P	13-3-1-209
WASTES AT COMMERCIAL SITES BETWEEN 1962 AND 1976, WITH	PROGRESS REPORT ON THE USE OF ACOUSTIC EMISSION	11-6-2-463
ACTOR CORES/	PROJECTIONS/ A SUMMARY OF SHALLOW LAND BURIAL OF	19-1-5-50
REACTOR FUEL SUBASSEMBLIES/	PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST RE	14-3-2-201
URE VESSEL STEELS/	PROPAGATION IN LIQUID METAL COOLED FAST BREEDER	16-3-2-291
NDATIONS OF THE INTERNATIONAL COMMISSION ON RADIOLOGICAL	PROPAGATION IN NEUTRON IRRADIATED FERRITIC PRESS	18-6-4-791
CAL HEALTH/	PROTECTION/	RECOMMEN
TH INTERNATIONAL CONGRESS OF THE BUREAU OF RADIOLOGI	PROTECTION ACTIVITIES OF THE BUREAU OF RADIOLOGI	15-2-5-185
IC ENERGY COMMISSION, 1947-1975/	PROTECTION ASSOCIATION/	FOUR
R COOLED POWER REACTOR PLANTS/	PROTECTION IN THE NUCLEAR FACILITIES OF THE ATOM	19-1-5-60
SYMPOSIUM ON RADIOECOLOGY APPLIED TO THE	PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATE	20-3-4-294
RELEASES OF RADIOIODINE/	PROTECTION OF MAN AND HIS ENVIRONMENT/	11-3-3-206
FEDERAL REPUBLIC OF GERMANY/	PROTECTION OF THE THYROID GLAND IN THE EVENT OF	13-5-5-380
THE DESIGN BASIS FOR NUCLEAR POWER PLANT	PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE	19-6-5-732
CRITERIA AND REQUIREMENTS FOR BDT PLANT	PROTECTION SYSTEMS/	15-4-3-409
GRR-4	PROTECTION SYSTEMS/	11-1-3-020
T COMPARISON OF NUCLEAR AND NONNUCLEAR HEALTH AND SAFETY	PROTECTION SYSTEMS - FAILURES AND THEIR CONSEQUO	11-5-2-375
ASSESSMENT OF A HIGH INTEGRITY	PROTECTIVE MEASURES AND REGULATIONS/ A COST BENE	16-2-3-150
ANS STANDARD N13.8 ON DESIGN BASES FOR	PROTECTIVE SYSTEM FOR LOSS OF ELECTRIC POWER/	20-5-1-525
ABC GOES	PROTECTIVE SYSTEMS/	18-2-3-168
EDUCATION AND	PUBLIC - A CASE HISTORY/	15-3-3-292
PLANTS/ THE AEC STUDY ON THE ESTIMATION OF RISKS TO THE	PUBLIC ACCEPTANCE OF NUCLEAR POWER PLANTS/	11-5-1-365
ESTIMATES OF THREATS TO THE	PUBLIC FROM POTENTIAL ACCIDENTS IN NUCLEAR POWER	20-6-1-655
RADIATION STANDARDS AND	PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACIL	13-4-1-775
TRENDS IN	PUBLIC HEALTH/	17-6-1-659
PUBLIC HEALTH IN THE POPULATION NEAR NUCLEAR PAC		12-1-1-001
PUBLIC HEALTH RISKS OF THERMAL POWER PLANTS/		18-5-5-647
PUBLIC INTEREST/		14-4-1-267
CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE		17-5-1-539
SOME EFFECTS OF	PUBLIC INTERVENTION ON THE REACTOR LICENSING PRO	13-1-1-013

OVERVIEW/ ING/	ANALYSIS OF PRESSURE GENERAL STRUCTURAL DESIGN CRITERIA FOR RESPONSE OF UNIRRADIATED AND IRRADIATED	PUBLIC OPPOSITION TO NUCLEAR POWER - AN INDUSTRY PULSES PRODUCED IN A WATER CHANNEL BY RAPID HEAT PWR CONTAINMENT INTERIOR STRUCTURES/	12-5-2-448 11-1-2-012 13-5-4-373
H CONDITIONS/ N COMPUTER CODE N CY CORE COOLANT	III. LOCA ANALYSIS RESULTS OF A TYPICAL FOLLOWING A LOSS OF COOLANT ACCIDENT IN THE REFLOODING PHASE OF THE LOCA IN THE REFLOODING PHASE OF THE LOCA IN	PWR FUEL RODS TESTED UNDER POWER COOLING MISMATCH THE RELAP PWRs/ THERMAL SHOCK STUDIES ASSOCIATED WITH INJE PWRs I. CORE HEAT TRANSFER AND FLUID FLOW/ PWRs II. REWETTING AND LIQUID ENTRAINMENT/	19-4-2-440 17-4-2-422 19-1-2-10 19-1-2-20 19-2-2-160
UCLEAR POWER APPLICATIONS/ POWER PLANTS/ WER PLANT/		QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR N QUALITY ASSURANCE IN THE CONSTRUCTION OF NUCLEAR QUALITY ASSURANCE PROBLEMS AT MIDLAND NUCLEAR PO QUALITY ASSURANCE STANDARDS AND PRACTICES/	18-3-3-317 16-2-1-127 17-1-6-87 12-6-1-544
	BURNOUT IN BOILING HEAT TRANSFER II. SUBCOOLED AND LOW BURNOUT IN BOILING HEAT TRANSFER III. HIGH	QUALITY FORCED CONVECTION SYSTEMS/ QUALITY FORCED CONVECTION SYSTEMS/ QUALITY OF THE ENVIRONMENT/ QUALITY OF THE ENVIRONMENT IN THE UNITED STATES, THE ASME CODE	18-2-2-154 20-6-2-671 18-2-5-215 19-5-5-617
1977/		QUANTIFICATION OF MAN - MACHINE SYSTEM RELIABILITY QUO/	13-2-1-099 16-3-3-316 17-1-3-43
TY IN PROCESS CONTROL/ ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS		QUO VADIS, PERSONNEL MONITORING/ RADIATION/ RADIATION ACCIDENTS/ RADIATION AND THERMAL POWER SOURCE STRENGTH/ RADIATION ASSESSMENT PROGRAM/ RADIATION DOSE AND EFFECTS/ RADIATION DOSE CALCULATIONS/ PARAMETERIZATIONS F RADIATION DOSES AND EFFECTS ESTIMATED FOR AQUATI RADIATION EFFECTS OF NUCLEAR FACILITIES IN NEW Y RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEA RADIATION EXPOSURE AT NUCLEAR POWER PLANTS/ RADIATION EXPOSURE AT OPERATING NUCLEAR POWER ST RADIATION EXPOSURE BE RECORDED FOR RADIATION WOR RADIATION EXPOSURE FROM THE U.S. NAVAL REACTOR P RADIATION EXPOSURES AT LICENSED FACILITIES, 1974 RADIATION EXPOSURES AT LICENSED FACILITIES, 1975 RADIATION EXPOSURES AT LIGHT WATER COOLED POWER RADIATION EXPOSURES AT LWRS, 1969-1974/ RADIATION IN PERSPECTIVE - SOME COMPARISONS OF T RADIATION IN THE UNITED STATES/ RADIATION IN THE URBAN ENVIRONMENT/ RADIATION MONITORING ( A GUIDE FOR MANAGEMENT )/ RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF RADIATION PROTECTION ASSOCIATION/ RADIATION SAFETY OFFICER/ RADIATION STANDARDS AND PUBLIC HEALTH/ RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF R RADIATION WORKERS/	16-6-5-728 15-5-5-585 12-4-5-338 13-1-5-054 16-6-1-667 11-6-4-475 19-2-5-205 17-3-5-351 16-2-5-204 19-6-6-760 16-5-6-614 18-4-5-492 14-3-5-220 20-3-6-345 17-6-6-743 18-4-6-523 18-3-6-365 17-5-6-622 12-3-1-185 17-4-5-471 13-4-1-275 11-1-5-039 15-2-5-185 19-1-5-60 13-6-5-482 12-1-1-001 11-3-6-237 14-3-5-220 14-5-5-482 15-3-5-305 18-3-6-370 20-4-6-468 18-1-6-79 14-6-2-597 14-4-1-274 13-2-1-103 18-3-1-291 19-5-6-628 20-4-6-476 11-2-5-130 17-3-5-351 16-2-4-180 11-5-4-391 20-4-5-446 20-4-4-434 16-5-4-581 19-1-5-50 16-1-5-60 16-1-5-71 15-3-6-311 16-6-6-734 12-3-4-234 13-5-5-380 19-6-5-741 19-6-5-732 18-2-5-203 17-2-5-216 17-6-5-722 20-4-5-858 16-3-5-345 17-1-1-15 15-2-5-185 19-5-5-802 19-4-5-497 20-3-5-317 13-5-1-353 20-3-5-330 18-2-5-215 19-5-5-617 14-5-2-446 13-6-2-459 16-1-4-43 16-3-4-318
	THE LAW AND LOW LEVEL IAEA - WHO SYMPOSIUM ON HANDLING OF ON ESTIMATING FISSION-PRODUCT EPA'S ENVIRONMENTAL SYMPOSIUM ON MEDICAL RADIONUCLIDES - WET AND DRY DEPOSITION OF PARTICLES AND GASES FOR USE IN TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES/ ENVIRONMENTAL OCCUPATIONAL OCCUPATIONAL CONTROLLING OCCUPATIONAL SHOULD MEDICAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL		
WET AND DRY DEPOSITION OF PARTICLES AND GASES FOR USE IN TO RADIOACTIVE RELEASES FROM LWR FUEL CYCLE FACILITIES/ ENVIRONMENTAL OCCUPATIONAL OCCUPATIONAL CONTROLLING OCCUPATIONAL SHOULD MEDICAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL OCCUPATIONAL			
ORK STATE/ POWER REACTORS, 1969-1976/			
ATIONS/ KERS/ ROGRAM, 1977/ / / REACTORS, 1969-1975/			
ENTAL RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANTS/ NATURAL BACKGROUND NATURAL			
NDARD N13.2-1969 - GUIDE FOR ADMINISTRATIVE PRACTICES IN RADIOLOGICAL HEALTH/ FOURTH INTERNATIONAL CONGRESS OF THE INTERNATIONAL THE EMERGING ROLE OF THE CAMPUS			
RESEARCH REACTOR FUEL/ A COMPARISON OF TWO NITROGEN-16 SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FOR SSING OPERATIONS/ MANAGEMENT OF IAEA-WHO SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF S IN EUROPE, 1970-1974/ S AND FUEL REPROCESSING PLANTS IN EUROPE, 1972-1976/ PLANTS IN 1974/ Y AND CONSEQUENCES OF TRANSPORTATION ACCIDENTS INVOLVING INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANSPORT OF TRANSPORT OF			
R PLANTS IN 1976/ N PLANTS IN 1977/ INVESTIGATIONS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY DOSES AND EFFECTS ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID			
NG/ LITIES IN 1978/ ENVIRONMENTAL MONITORING AND DISPOSAL OF EVATION/ SOLID S WITH PROJECTIONS/ A SUMMARY OF SHALLOW LAND BURIAL OF RES/ ILITIES/ NUCLEAR POWER PLANTS IN 1972/ POWER PLANTS DURING 1973/ NUCLEAR SAFETY IN AMERICAN SYMPOSIUM ON MEDICAL AND LEGAL IMPLICATIONS OF A LARGE RELEASE OF PROTECTION OF THE THYROID GLAND IN THE EVENT OF RELEASES OF POWER/			
SITES - AN OVERVIEW/ ESTIMATING THE EFFECTS OF DRY DEPOSITION IN ENVIRONMENTAL THE ERDA RADIATION PROTECTION ACTIVITIES OF THE BUREAU OF CLEAR POWER INDUSTRY FROM 1975 TO 2020 AND THE ESTIMATED L FIRED AND NUCLEAR POWER PLANTS/ G/ PRELIMINARY OBSERVATIONS ON THE RECOMMENDATIONS OF THE INTERNATIONAL COMMISSION ON UNITED STATES, 1977/ MEASUREMENT/ LANT ACCIDENTS IN WATER COOLED POWER REACTORS/ QUID METAL COOLED FAST BREEDER REACTORS I. PRODUCTION/ LIQUID METAL COOLED FAST BREEDER REACTORS III. TRANSPORT/			

STATION INTO A MARINE BAY/ ABUNDANCE AND DISTRIBUTION OF	SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION DOSE AND EFFECTS/	11-6-4-475
TURNOVERS AND CONCENTRATION OF	RADIONUCLIDES DISCHARGED FROM A BWR NUCLEAR POWER	20-2-5-199
COMPUTER CODES FOR THE ASSESSMENT OF	RADIONUCLIDES IN FOOD CHAINS/	11-1-5-043
ACTIVE WASTE/	RADIONUCLIDES RELEASED TO THE ENVIRONMENT/	18-3-5-341
SPHERES/	RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIO	16-2-4-180
INGRS MASQUEPADES AS IODINE-131 RELEASE/	RADON AND RADON DAUGHTER PRODUCTS FROM NINE ATMO	14-6-5-643
PROBLEMS AND TECHNIQUES FOR REMOVAL OF	RADON CONCENTRATION IN REACTOR CONTAINMENT BUILD	11-3-6-235
PROBLEMS AND TECHNIQUES FOR REMOVAL OF RADON AND	RADON DAUGHTER PRODUCTS FROM NINE ATMOSPHERES/	14-6-5-643
NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES OF	RADON-222/	20-6-5-722
ERIC RELEASES FROM NUCLEAR REACTOR ACCIDENTS/ EFFECTS OF	RAINSTORMS AND RUNOFF ON CONSEQUENCES OF ATMOSPHERIC	19-2-5-220
ALYSIS OF PRESSURE PULSES PRODUCED IN A WATER CHANNEL BY	RAPID HEATING/	11-1-2-012
SAFETY EXPERIENCE GAINED FROM	RAPSODIE OPERATION/	14-1-6-027
CRITERIA AND REQUIREMENTS FOR	RDT PLANT PROTECTION SYSTEMS/	11-5-2-375
ING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER	REACTIONS I. PRODUCTION/ RADIONUCLIDE BEHAVIOR	16-1-4-43
CTORS/	ACTIVITY - FEEDBACK TIME RESPONSE IN POWER REA	13-4-3-295
CTOR DYNAMICS - A REVIEW OF THE 1970 CREST CONFERENCE ON	REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPAC	13-4-2-287
INCIDENT AT THE LUCRNS	REACTOR/	16-1-6-76
SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAST	REACTOR/	16-6-3-701
OF THE SCAR SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH	REACTOR/	17-4-3-437
FUEL ROD FAILURE AND ITS EFFECTS IN LIGHT WATER	REACTOR ACCIDENTS/	12-5-3-487
ARCINOMA - A COMPARISON OF THE LATE MORTALITY RISKS FROM	REACTOR ACCIDENTS/	11-6-4-482
OFF ON CONSEQUENCES OF ATMOSPHERIC RELEASES FROM NUCLEAR	REACTOR ACCIDENTS/ EFFECTS OF RAINSTORMS AND RUN	19-2-5-220
CONTINUITY OF SERVICES/	REACTOR AVAILABILITY AND STATION RELIABILITY FOR	12-5-4-899
SSION PRODUCT REMOVAL/	REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR F	12-5-5-516
INE-131 RELEASE/	REACTOR CONTAINMENT BUILDINGS MASQUEPADES AS IOD	11-3-6-235
TRENDS IN THE DESIGN OF PRESSURIZED WATER	REACTOR CONTAINMENT STRUCTURES AND SYSTEMS/	18-2-4-189
THE ICE CONDENSER	REACTOR CONTAINMENT SYSTEM/	11-3-4-215
Y OF APPLIED INSTRUMENT SYSTEMS FOR USE WITH LIGHT WATER	REACTOR CONTAINMENTS/	15-6-3-702
OBSTACLES TO COMPLETE AUTOMATION OF	REACTOR CONTROL/	14-2-3-095
AUTOMATION OF	REACTOR CONTROL AND SAFETY SYSTEMS AT ORNL/	11-2-3-115
SAV ONOFFER EXPERIENCE WITH APPARENT POWER MISMATCH AND	COOLANT TEMPERATURE ANOMALIES/	11-2-6-142
STUDIES OF FAST	REACTOR CORE BEHAVIOR UNDER ACCIDENT CONDITIONS/	11-3-2-195
S LIMITING PROMPT-CRITICAL EXCURSIONS IN IRRADIATED FAST	REACTOR CORES/	14-3-2-201
NUCLEAR POWER	REACTOR DECOMMISSIONING/	20-1-1-15
REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPAC - TIME	REACTOR DYNAMICS - A REVIEW OF THE 1970 CREST CO	13-4-2-287
SUMMARY OF RECENT ABNORMAL OCCURRENCES AT POWER	REACTOR FACILITIES/	15-2-6-198
RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH	REACTOR FUEL/ A COMPARISON OF TWO NITROGEN-16	11-3-6-237
FAILURE PROPAGATION IN LIQUID METAL COOLED FAST BREEDER	REACTOR FUEL SUBASSEMBLIES/	16-3-2-291
DENSIFICATION OF	REACTOR FUELS/	14-4-6-356
FISSION GAS EFFECTS IN	REACTOR FUELS I. BASIC STUDIES/	12-4-2-297
FISSION GAS EFFECTS IN	REACTOR FUELS II. ENGINEERING APPLICATIONS/	12-6-2-562
THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND	REACTOR INDUSTRIES/	17-3-6-361
RECENT DEVELOPMENTS IN FAST	REACTOR KINETICS/	11-4-2-289
SOME EFFECTS OF PUBLIC INTERVENTION ON THE	REACTOR LICENSING PROCESS/	13-1-1-013
E OF THE ADVISORY COMMITTEE ON REACTOR SAFEGUARDS IN THE	REACTOR LICENSING PROCESS/	13-1-1-001
THE REACTOR	REACTOR LICENSING PROCESS - A STATUS REPORT/	18-3-1-281
L VESSEL RUPTURE/	REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICA	14-4-2-291
PRESSURIZED WATER	REACTOR NOISE/	16-3-3-308
THE 1974 SPECIALISTS MEETING ON	REACTOR NOISE/	19-4-3-468
SECOND SPECIALISTS MEETING ON	REACTOR ON OCT. 5, 1966/	12-2-6-123
FUEL MELTING INCIDENT AT THE FERMI	REACTOR OPERATOR LICENSING/	19-5-6-623
NUCLEAR	REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUC	16-4-5-482
LEAR POWER PLANT SIMULATORS/	REACTOR PLANT/	16-5-4-564
NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER	REACTOR PLANT SAFETY STUDY/	19-3-2-316
CLINCH RIVER BREEDER	REACTOR PLANTS/	20-6-6-729
STRESS CORROSION CRACKING IN PIPING OF LIGHT WATER	REACTOR PLANTS/	11-3-3-206
TION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED POWER	REACTOR POWER PLANTS - A REVIEW OF 1973-1977 EXP	20-2-6-210
RIENCE/	REACTOR POWER PLANTS IN 1972/	15-1-6-067
OUTAGES AT LIGHT WATER	REACTOR PRESSURE VESSEL/	11-2-4-119
SAFETY RELATED OCCURRENCES IN NUCLEAR	REACTOR PRESSURE VESSEL AVAILABILITY BY DESIGN/	17-1-4-62
CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR	REACTOR PRESSURE VESSEL STEELS/	17-3-4-327
IMPROVING	REACTOR PRESSURE VESSELS/	11-1-4-025
NEUTRON IRRADIATION EMBRITTLEMENT OF	REACTOR PRESSURE VESSELS/	17-1-4-55
A REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE	REACTOR PRIMARY SCRAM SYSTEM/	12-6-6-608
THE SAFETY OF	REACTOR PROGRAM, 1977/	20-3-6-345
FAILURE OF N	REACTOR SAFEGUARDS - ITS ROLE IN NUCLEAR SAFETY/	20-4-1-387
OCCUPATIONAL RADIATION EXPOSURE FROM THE U.S. NAVAL	REACTOR SAFEGUARDS IN THE REACTOR LICENSING PROC	13-1-1-001
ADVISORY COMMITTEE ON	REACTOR SAFETY/	12-3-1-196
THE ROLE OF THE ADVISORY COMMITTEE ON	REACTOR SAFETY/	12-5-1-433
CREST SUMMARY - WATER-COOLED	REACTOR SAFETY/	13-6-1-451
LIGHT WATER	REACTOR SAFETY/	14-5-1-428
ISPEAS CONTRIBUTION TO	REACTOR SAFETY/	14-5-1-439
INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF	REACTOR SAFETY/	15-2-1-132
ANS NATIONAL TOPICAL MEETING ON WATER	REACTOR SAFETY/	16-2-1-141
AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON	REACTOR SAFETY/	16-5-1-542
1974 ANS TOPICAL MEETING ON FAST	REACTOR SAFETY/	18-4-1-438
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER	REACTOR SAFETY/	19-2-1-153
THE RUSSIAN APPROACH TO NUCLEAR	REACTOR SAFETY/	17-6-3-686
ANS TOPICAL MEETING ON THERMAL	REACTOR SAFETY AND RELATED PHYSICS/	18-4-2-451
ODE FAILURE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO	REACTOR SAFETY PROGRAM/	11-1-1-001
1976 INTERNATIONAL MEETING ON FAST	REACTOR SAFETY PROGRAM/	16-6-1-659
THE LIQUID METAL FAST BREEDER	REACTOR SAFETY PROGRAM PLAN/	11-5-1-369
EPRI WATER	REACTOR SAFETY RESEARCH/	18-5-1-589
THE WATER	REACTOR SAFETY RESEARCH IN JAPAN/	19-5-1-541
NRC INTERNATIONAL AGREEMENTS ON	REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-3-1-241
LIGHT WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-8
WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
FOURTH WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	19-3-1-281
FIFTH NRC WATER	REACTOR SAFETY RESEARCH INFORMATION MEETING/	20-3-1-249
SIXTH NRC WATER	REACTOR SAFETY RESEARCH PROGRAM/	18-1-1-1
NRC WATER	REACTOR SAFETY RESEARCH PROGRAM/	18-6-1-727
GERMAN LIGHT WATER		

RESEARCH RESULTS/	WATER REACTOR SAFETY RESEARCH PROGRAM - APPLICATION OF	19-3-1-292
	EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS	11-6-2-450
REPORT OF THE NRC RISK ASSESSMENT REVIEW GROUP ON THE	REACTOR SAFETY STUDY/	20-1-1-24
COMPARATIVE RELIABILITY ANALYSES OF	REACTOR SAFETY SYSTEMS/	14-6-3-605
COMMON-MODE FAILURES IN	REACTOR SAFETY SYSTEMS/	18-5-3-624
RELIABILITY ENGINEERING METHODS IN	REACTOR SAFETY TECHNOLOGY/	12-5-4-496
AN APPRECIATION OF FAST	REACTOR SAFETY-1970/	12-2-1-83
OF SHUTDOWN SYSTEMS/	APPLICATION OF	19-6-3-712
	REACTOR SCRAM EXPERIENCE IN RELIABILITY ANALYSIS	16-3-1-282
NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN	REACTOR SITING/	13-1-2-022
THE DEVELOPMENT OF	REACTOR SITING CRITERIA BASED UPON RISK PROBABIL	15-2-3-154
SAFETY ASSESSMENT OF	REACTOR SYSTEMS/	12-2-6-134
REPORT ON THE 1970 AEC CONFERENCE ON POWER	REACTOR SYSTEMS AND COMPONENTS/	18-4-6-513
	REACTOR VESSEL PRESSURE TRANSIENTS/	11-2-5-130
SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTIVE POWER	REACTOR WASTES/	13-2-1-099
THE ASME CODE QUALITY-ASSURANCE PROGRAM FOR NUCLEAR	REACTORS/	15-6-3-665
BENEFIT COST ANALYSES IN LICENSING OF NUCLEAR POWER	REACTORS/	17-4-6-475
PIPE CRACKING IN BOILING WATER	REACTORS/	17-5-4-568
RELIABILITY OF PIPING IN LIGHT WATER	REACTORS/	19-4-1-411
FRENCH SAFETY STUDIES OF PRESSURIZED WATER	REACTORS/	19-5-3-590
ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIAL POWER	REACTORS/	20-4-3-422
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER	REACTORS/	17-2-4-208
SHIPMENT CELL LINERS FOR LIQUID METAL COOLED FAST BREEDER	REACTORS/	EQ
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER	REACTORS/	ANT
MENT OF THE FREQUENCY OF FAILURE TO SCRAM IN LIGHT WATER	REACTORS/	ASSESS
YSIS OF CONTROL ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER	REACTORS/	AN ANAL
ADVANCES IN ALTERNATE ECCS STUDIES FOR PRESSURIZED WATER	REACTORS/	RECENT
PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED	REACTORS/	FISSION
RE VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER	REACTORS/	A METHOD FO
SECTION TECHNIQUES FOR LIQUID METAL COOLED FAST BREEDER	REACTORS/	IN-SERVICE IN
OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BREEDER	REACTORS/	CONTAMINATION CONTROL
IGATION OF POSTULATED MELTDOWN ACCIDENTS IN LIGHT WATER	REACTORS/	PHENOMENOLOGICAL INVS
CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER	REACTORS/	RESEARCH ON THE USE OF
OF PRIMARY COOLANT RELEASE FROM OPERATING BOILING WATER	REACTORS/	EVALUATION OF INCIDENTS
ON AFTER LOSS OF COOLANT ACCIDENTS IN WATER COOLED POWER	REACTORS/	RADIOLYTIC HYDROGEN GENERATI
ICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER POWER	REACTORS/	INSTRUMENTATION FOR MONITORING THE HYP
CORE COOLING SYSTEMS OF LIGHT WATER COOLED NUCLEAR POWER	REACTORS/	NEW ACCEPTANCE CRITERIA FOR EMERGENCY
70 CREST CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER	REACTORS/	SPACE - TIME REACTOR DYNAMICS - A REVI
ING NORMAL OPERATION OF LIQUID METAL COOLED FAST BREEDER	REACTORS	II. TRANSPORT/ RADIONUCLIDE BEHAVIOR D
PROBABILITY ANALYSIS APPLIED TO LIGHT WATER	REACTORS	- LOSS OF COOLANT ACCIDENTS/
REGULATION OF NUCLEAR POWER	REACTORS AND RELATED FACILITIES/	
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS DURING 1972/	STEAM GENERATOR TUBE F
ANCE - WORLD EXPERIENCE WITH WATER COOLED NUCLEAR POWER	REACTORS DURING 1977/	STEAM GENERATOR TUBE PERFO
OPERATING EXPERIENCE WITH 13 LIGHT WATER	REACTORS IN EUROPE/	
SAFETY ASSESSMENT OF FAST SODIUM-COOLED	REACTORS IN THE UNITED KINGDOM/	
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS IN 1973/	STEAM GENERATOR TUBE F
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS IN 1974/	STEAM GENERATOR TUBE F
TUBE FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR	REACTORS IN 1975/	STEAM GENERATOR
FAILURES - WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER	REACTORS IN 1976/	STEAM GENERATOR TUBE F
SAFETY AND SECURITY OF NUCLEAR POWER	REACTORS TO ACTS OF SABOTAGE/	
NATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER	REACTORS, 1969-1975/	OCCA
L RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEAR POWER	REACTORS, 1969-1976/	OCCUPATIONA
POWER PLANT DISCHARGES - TOWARD MORE	REASONABLE EFFLUENT LIMITS ON CHLORINE/	
ILITY/	A REASSESSMENT OF TURBINE GENERATOR FAILURE PROBAB	
ON RADIOLOGICAL PROTECTION/	RECOMMENDATIONS OF THE INTERNATIONAL COMMISSION	
SHOULD MEDICAL RADIATION EXPOSURE BE	RECORDED FOR RADIATION WORKERS/	
ORATORY/	REFLECTIONS ON THE	
ON BY OPTIMUM ALLOCATION OF RESOURCES AVAILABLE FOR RISK	REDUCTION/	RISK MINIMIZATI
COMMON-MODE FAILURE MECHANISMS IN	REDUNDANT SYSTEMS IMPORTANT TO REACTOR SAFETY/	
NUCLEAR LIABILITY INSURANCE - A BRIEF HISTORY	REFLECTING THE SUCCESS OF NUCLEAR SAFETY/	
RGONNE NATIONAL LABORATORY/	REFLECTIONS ON THE REACTIVITY CONFERENCE AT A	
AT TRANSFER AND FLUID FLOW/	THE REFLOODING PHASE OF THE LOCA IN PWRs I. CORE HE	
ING AND LIQUID ENTRAINMENT/	THE REFLOODING PHASE OF THE LOCA IN PWRs II. REWET	
FACILITIES/	REGULATION OF NUCLEAR POWER REACTORS AND RELATED	
AR POWER PLANTS/	THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLE	
AR POWER PLANTS/	THE REGULATION OF THE ENVIRONMENTAL EFFECTS OF NUCLE	
AND NONNUCLEAR HEALTH AND SAFETY PROTECTIVE MEASURES AND	REGULATIONS/ A COST BENEFIT COMPARISON OF NUCLEA	
MATERIALS/ THE IMPACT OF THE PROPOSED REVISIONS TO IAEA	REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIV	
THE ROLE OF RISK ASSESSMENT IN THE NUCLEAR	REGULATORY PROCESS/	
REGARDING/	CONCLUDING STATEMENT OF THE AEC	
OF A TYPICAL PWR PLANT/	THE RELAP4 COMPUTER CODE III. LOCA ANALYSIS RESULTS	
POWER PLANT ANALYSIS/	THE RELAP4 COMPUTER CODE 1. APPLICATION TO NUCLEAR	
HE INPUT MODEL/	THE RELAP4 COMPUTER CODE 2. ENGINEERING DESIGN OF T	
REACTOR CONTAINMENT BUILDINGS MASQUERADES AS IODINE-131	RELEASE/	RATON CONCENTRATION IN
ATMOSPHERIC	RELEASE ADVISORY CAPABILITY/	
FISSION GAS	RELEASE FROM FUEL AT HIGH BURNUP/	
EVALUATION OF INCIDENTS OF PRIMARY COOLANT	RELEASE FROM OPERATING BOILING WATER REACTORS/	
RESTRICTED	RELEASE OF PLUTONIUM I. OBSERVATIONAL DATA/	
RESTRICTED	RELEASE OF PLUTONIUM II. THEORY/	
MEDICAL AND LEGAL IMPLICATIONS OF A LARGE	RELEASE C <sup>137</sup> RADIOIODINE/	
CONSEQUENCES OF AN ACCIDENTAL	RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN LMF	
THE ENVIRONMENTAL IMPACT IODINE-129	RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	
THE ENVIRONMENTAL IMPACT OF CARBON-14	RELEASED BY A NUCLEAR FUEL REPROCESSING PLANT/	
RADIOACTIVE MATERIAL	RELEASED FROM NUCLEAR POWER PLANTS IN 1974/	
RADIOACTIVE MATERIALS	RELEASED FROM NUCLEAR POWER PLANTS IN 1976/	
RADIOACTIVE MATERIALS	RELEASED FROM NUCLEAR POWER PLANTS IN 1977/	
DURING 1973/	SUMMARY OF RADIOACTIVITY	
COMPUTER CODES FOR THE ASSESSMENT OF RADIONUCLIDES	RELEASED IN EFFLUENTS FROM NUCLEAR POWER PLANTS	
FACTORS/	RELEASED TO THE ENVIRONMENT/	
EFFECTS ESTIMATED FOR AQUATIC BIOTA EXPOSED TO RADIOACTIVE	RELEASES FROM LIQUID METAL COOLED FAST BREEDER R	
OF RAINSTORMS AND RUNOFF ON CONSEQUENCES OF ATMOSPHERIC	RELEASES FROM LWR FUEL CYCLE FACILITIES/ RADIATI	
HE ESTIMATED RADIOLOGICAL IMPACT/ SCENARIOS OF CARBON-14	RELEASES FROM NUCLEAR REACTOR ACCIDENTS/ EFFECTS	
WASTE FROM NUCLEAR POWER PLANTS IN 1972/	RELEASES FROM THE WORLD NUCLEAR POWER INDUSTRY F	
	RELEASES OF RADIOACTIVITY IN EFFLUENTS AND SOLID	15-3-6-311

PROTECTION OF THE THYROID GLAND IN THE EVENT OF	RELEASES OF RADIOIODINE/	19-6-5-732
RS/	RELIABILITY OF PIPING IN LIGHT WATER REACTOR	17-5-4-568
	RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS/	14-6-3-605
	HUMAN RELIABILITY ANALYSIS/	17-3-3-315
APPLICATION OF REACTOR SCRAM EXPERIENCE IN	RELIABILITY ANALYSIS OF SHUTDOWN SYSTEMS/	19-6-3-712
MISSOURI UNIVERSITY RESEARCH REACTOR/	RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE	17-4-3-437
INTERNATIONAL CONFERENCE ON NUCLEAR SYSTEMS	RELIABILITY ENGINEERING AND RISK ASSESSMENT/	19-1-3-38
ON OF THE STATE OF THE ART/	SYSTEM RELIABILITY ENGINEERING METHODOLOGY - A DISCUSS	20-5-2-541
Y TECHNOLOGY/	RELIABILITY ENGINEERING METHODS IN REACTOR SA	12-5-4-496
	RELIABILITY FOR CONTINUITY OF SERVICE/	12-5-4-499
	RELIABILITY IN PROCESS CONTROL/	16-3-3-316
	RELIABILITY MEETING AT RISO/	11-4-3-309
	RELIABILITY OF D-C POWER SUPPLIES/	19-3-3-330
	REPORTED IN 1977/	20-1-6-83
VIEW OF SAFETY RELATED EVENTS AT NUCLEAR POWER PLANTS AS	REPORTING OF RADIOACTIVITY IN EFFLUENTS I. ARC	16-1-5-60
OWNED FACILITIES/	THE CONTROL, MONITORING, AND	16-1-5-71
LICENSED FACILITIES/	THE CONTROL, MONITORING, AND	18-5-5-482
MANAGEMENT OF RADIOACTIVE AQUEOUS WASTES FROM AEC FUEL	REPROCESSING OPERATIONS/	16-5-5-593
ENVIRONMENTAL IMPACT IODINE-129 RELEASED BY A NUCLEAR FUEL	REPROCESSING PLANT/	17-5-5-580
ENVIRONMENTAL IMPACT OF CARBON-14 RELEASED BY A NUCLEAR FUEL	REPROCESSING PLANT/	13-2-5-130
GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL	REPROCESSING PLANT/ ESTIMATES OF DOSE TO NORTHERN	20-4-6-868
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS AND FUEL	REPUBLIC OF GERMANY/	15-4-3-409
PROTECTION SYSTEM DEVELOPMENTS AND TRENDS IN THE FEDERAL	REPUBLIC OF GERMANY/	19-2-2-176
LWR FUEL BEHAVIOR RESEARCH IN THE FEDERAL	REPUBLIC OF GERMANY/	20-5-2-551
COUPLED FLUID STRUCTURE ANALYSIS FOR LWRs IN THE FEDERAL	REPUBLIC OF GERMANY - THE DIN NUCLEAR STANDARDS	19-3-1-297
COMMITTEE/	REQUALIFICATION PROGRAMS FOR NUCLEAR POWER PLANT	19-4-6-502
S/	RESERVATION/	20-4-4-434
	RESISTANT DESIGN OF ENGINEERING STRUCTURES/	14-1-1-001
RS/	RESISTANT DESIGN OF NUCLEAR POWER PLANT STRUCTUR	15-4-4-432
	RESOURCES AVAILABLE FOR RISK REDUCTION/	12-4-2-305
RISK MINIMIZATION BY OPTIMUM ALLOCATION OF	RESPONSE IN POWER REACTORS/	13-4-3-295
A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME	RESPONSE OF UNIRRADIATED AND IRRADIATED PWR FUEL	19-4-2-440
RODS TESTED UNDER POWER COOLING MISMATCH CONDITIONS/	RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACIL	17-1-1-15
ITIES/ STATE AND LOCAL GOVERNMENT RADIOLOGICAL EMERGENCY	RESPONSIBILITIES FOR NUCLEAR POWER - LAPP REPORT	14-6-1-574
TO THE ILLINOIS COMMERCE COMMISSION/	RESTRICTED RELEASE OF PLUTONIUM I. OBSERVATIONA	12-2-2-85
L DATA/	RESTRICTED RELEASE OF PLUTONIUM II. THEORY/	12-3-2-203
	RESUME OF RECENT YEARS/	16-5-1-537
	RESUSPENSION AND FOR WET AND DRY DEPOSITION OF P	19-2-5-205
	REVIEW/	12-1-3-015
	REVIEW/	17-1-5-68
	REVIEW GROUP ON NUCLEAR WASTE MANAGEMENT/	20-6-4-706
	REVIEW GROUP ON THE REACTOR SAFETY STUDY/	20-1-1-24
	REVIEW OF AEC TOPICAL MEETING ON NUCLEAR POWER P	16-3-1-273
	REVIEW OF AUGUST 1978 CHANGES TO THE NRC'S PROGR	20-3-1-258
	REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR	12-3-3-217
	REVIEW OF FINAL ENVIRONMENTAL STATEMENT CONCERNI	15-4-5-440
	REVIEW OF FIRE PROTECTION IN THE NUCLEAR FACILIT	20-3-4-294
	REVIEW OF LICENSED OPERATOR REQUALIFICATION PROG	19-4-6-502
	REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBL	15-3-4-302
	REVIEW OF SAFETY RELATED EVENTS AT NUCLEAR POWER	20-1-6-83
	REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973	15-6-5-732
	REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER	18-5-2-596
	REVIEW OF THE NUCLEAR SAFETY ASPECTS OF THE FOUR	13-3-0-181
	REVIEW OF THE TECHNOLOGY OF PRESTRESSED CONCRETE	11-1-4-025
	REVIEW OF THE 1970 CREST CONFERENCE ON REACTIVIT	13-4-2-287
	REVIEW OF 1973-1977 EXPERIENCE/	20-2-6-210
	REVISIONS TO IARA REGULATIONS FOR THE SAFE TRANS	13-2-1-103
	REWETTING AND LIQUID ENTRAINMENT/	19-2-2-160
	RISK - A RECENT CRITICAL REVIEW/	12-1-3-015
	RISK - BENEFIT ASSESSMENT FOR NUCLEAR POWER PLAN	17-5-1-525
	RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURC	17-2-1-171
	RISK ASSESSMENT/	19-1-3-38
	RISK ASSESSMENT - THE SUBJECTIVISTIC VIEWPOINT A	19-3-2-305
	RISK ASSESSMENT IN THE NUCLEAR REGULATORY PROCES	19-5-1-556
	RISK ASSESSMENT REVIEW GROUP ON THE REACTOR SAFE	20-1-1-24
	RISK BENEFIT EVALUATION FOR LARGE TECHNOLOGICAL	20-2-2-148
	RISK FOR NUCLEAR POWER PLANTS/	15-3-2-276
	RISK MINIMIZATION BY OPTIMUM ALLOCATION OF RESOU	12-4-2-305
	RISK OF HYPOTHETICAL LMPBR ACCIDENTS/	19-2-4-190
	RISK PROBABILITY/	13-1-2-022
	RISK REDUCTION/	12-4-2-305
	RISKS ASSOCIATED WITH NUCLEAR POWER/	20-6-1-664
	RISKS FROM NUCLEAR AND FOSSIL FUELED POWER PLANT	12-3-1-185
	RISKS FROM REACTOR ACCIDENTS/	11-6-4-482
	RISKS IN TRANSPORTING MATERIALS FOR VARIOUS ENER	19-2-1-135
	RISKS IN U.S. COMMERCIAL NUCLEAR POWER PLANTS/	15-6-1-673
	RISKS OF THERMAL POWER PLANTS/	14-4-1-267
	RISKS TO THE PUBLIC FROM POTENTIAL ACCIDENTS IN	15-4-1-375
	RISO/	11-4-3-309
	RIVER BREEDER REACTOR PLANT/	16-5-4-564
	RIVER BREEDER REACTOR PLANT SAFETY STUDY/	19-3-2-316
	ROCKY FLATS PLANT I./	15-5-4-572
	ROCKY FLATS PLANT II./	15-6-4-723
	ROD/	14-4-6-362
	ROD FAILURE AND ITS EFFECTS IN LIGHT WATER REACT	12-5-3-487
	ROD SYSTEM MALFUNCTIONS IN NUCLEAR POWER REACTO	14-4-3-315
	RODS TESTED UNDER POWER COOLING MISMATCH CONDI	19-4-2-440
	ROOM/	18-6-3-778
	RUBBER INSULATED CABLES FOR CALVERT CLIFFS NUCLE	16-6-3-714
	RULE-MAKING HEARING/	15-1-4-030
	RUNOFF ON CONSEQUENCES OF ATMOSPHERIC RELEASES F	19-2-5-220
	RUPTURE/	14-4-2-291
	PRESSURIZED WATER	

0/	EFFECT OF RUPTURE IN A PRESSURIZED NOBLE GAS ADSORPTION BE	13-6-4-474
	PIPE RUPTURE STUDY - 1971/	13-2-4-122
	THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY/	18-4-1-439
SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF	SABOTAGE/	17-6-1-665
	INDUSTRIAL SABOTAGE IN NUCLEAR POWER PLANTS/	11-2-1-107
USE OF ACTUATORS AS LOGIC ELEMENTS IN RELATION TO FAIL SAFE DESIGN/		TH 12-3-3-226
CT OF THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE	SAFE TRANSPORT OF RADIOACTIVE MATERIALS/ THE IMP	13-2-1-103
	ANS EXECUTIVE CONFERENCE ON SAFEGUARDS/	19-4-1-427
	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS - ITS ROLE IN NUCLEAR SAFETY/	20-4-1-397
LEAR MATERIALS/	SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUC	15-5-1-513
	SAFEGUARDS IN THE REACTOR LICENSING PROCESS/	13-1-1-001
	A SYSTEMS APPROACH TO NUCLEAR PLANT SAFETY/	11-6-1-445
	CHEST SUMMARY - WATER-COOLED REACTOR SAFETY/	12-3-1-196
	LMPBR SAFETY/	12-5-1-421
	LIGHT WATER REACTOR SAFETY/	12-5-1-433
	HTGR SAFETY/	12-5-1-438
	ISPRAS CONTRIBUTION TO REACTOR SAFETY/	13-6-1-451
	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	14-5-1-439
	AEC TESTIMONY AT THE 1973 JCAE HEARINGS ON REACTOR SAFETY/	15-2-1-132
	1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	16-2-1-141
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR	SAFETY/	16-5-1-542
	EMP AND NUCLEAR PLANT SAFETY/	18-3-3-322
	THE RUSSIAN APPROACH TO NUCLEAR REACTOR SAFETY/	18-4-1-438
	ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY/	19-2-1-153
	TWENTY YEARS OF NUCLEAR SAFETY/	20-1-1-001
TERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR	SAFETY/	IN 14-5-1-428
ATION OF INTERMEDIATE SIZED PRESSURE VESSEL TESTS TO LWR	SAFETY/	REL 17-8-4-447
RY COMMITTEE ON REACTOR SAFEGUARDS - ITS ROLE IN NUCLEAR	SAFETY/	ADVISO 20-4-1-387
REE MECHANISMS IN REDUNDANT SYSTEMS IMPORTANT TO REACTOR	SAFETY/	COMMON-MODE FAIL 17-6-3-686
ANCE - A BRIEF HISTORY REFLECTING THE SUCCESS OF NUCLEAR	SAFETY/	NUCLEAR LIABILITY INSUR 12-4-1-291
	LMPBR SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM/	11-5-3-379
RES CONTAINING A FIXED NEUTRON ABSORBER/	THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TA	15-3-4-295
	POWER PLANT SAFETY AND EARTHQUAKES/	14-6-2-586
	THE ROLE OF THE ATOMIC SAFETY AND LICENSING BOARD PANEL/	15-4-1-383
	1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY AND RELATED PHYSICS/	18-4-2-451
ACTS OF SABOTAGE/	SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO	17-6-1-665
	NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR	SAFETY ASPECTS OF THE FOURTH GENEVA CONFERENCE/
	UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND	SAFETY ASSESSMENT/
	IN THE UNITED KINGDOM/	SAFETY ASSESSMENT OF FAST SODIUM-COOLED REACTORS
		SAFETY ASSESSMENT OF REACTOR SYSTEMS/
		SAFETY ASSESSMENT PHILOSOPHY OF THE FAST FLUX TR
ST FACILITY/	NUCLEAR SAFETY AT GENEVA - A REVIEW OF THE NUCLEAR SAFET	13-3-0-181
Y ASPECTS OF THE FOURTH GENEVA CONFERENCE/	NUCLEAR SAFETY AT SALZBURG/	18-6-1-756
	BEAM SAFETY CONSIDERATIONS AT THE STANFORD LINEAR ACC	11-6-1-435
ELEATOR CENTER/	SAFETY DESIGN BASES OF THE HTGR/	14-6-4-618
	NUCLEAR SAFETY DESIGN OF THE CLINCH RIVER BREEDER REACTO	16-5-4-564
R PLANT/	SAFETY EVALUATION EXPERIENCE WITH DIGITAL COMPUT	17-6-3-693
ER SOFTWARE/	FIFTH GERMAN SYMPOSIUM ON PROGRESS IN	SAFETY EVALUATION OF NUCLEAR POWER PLANTS/
		SAFETY EXPERIENCE GAINED FROM RAPSODIE OPERATION
/	NUCLEAR SAFETY EXPERIMENTS IN THE HARVIKEN POWER STATION	18-4-4-481
/	THE SODIUM LOOP SAFETY FACILITY/	19-3-4-139
R ACCIDENTS/	EFFECT OF ENGINEERED SAFETY FEATURES ON THE RISK OF HYPOTHETICAL LMPB	19-2-4-140
TS/	NUCLEAR SAFETY IN AMERICAN RADIOCHEMICAL PROCESSING PLAN	12-3-4-234
	NUCLEAR POWER PLANT SAFETY IN DEVELOPING COUNTRIES/	20-2-1-123
T REACTOR/	SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAS	16-6-3-701
	THE SAFETY OF REACTOR PRESSURE VESSELS/	17-1-4-55
R INDUSTRIES/	THE SAFETY OF WORKERS IN THE NUCLEAR FUEL AND REACTO	17-3-6-363
	THE EMERGING ROLE OF THE CAMPAUS RADIATION SAFETY OFFICES/	13-6-5-482
	THE LIQUID METAL FAST BREEDER REACTOR SAFETY PROGRAM/	11-1-1-001
	EPRI WATER REACTOR SAFETY PROGRAM/	16-6-1-654
TS PLANT II./	THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY ROCKY PLA	15-6-4-723
ATS PLANT I./	THE NUCLEAR SAFETY PROGRAM AT DOW CHEMICAL COMPANY'S ROCKY PL	15-5-4-572
	THE WATER REACTOR SAFETY PROGRAM PLAN/	11-5-1-369
	BENEFIT COMPARISON OF NUCLEAR AND NONNUCLEAR HEALTH AND	SAFETY PROTECTIVE MEASURES AND REGULATIONS/ A CO
	REPORTED IN 1977/	SAFETY RELATED EVENTS AT NUCLEAR POWER PLANTS AG
	SET-POINT DRIFT IN NUCLEAR POWER PLANT	SAFETY RELATED INSTRUMENTATION/
		SAFETY RELATED OCCURRENCES IN NUCLEAR REACTOR PO
WER PLANTS IN 1972/	QUALIFICATION OF	SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER APPL
ICATIONS/	NRC INTERNATIONAL AGREEMENTS ON REACTOR SAFETY RESEARCH/	18-3-3-317
	THE UTILITY'S ROLE IN NUCLEAR SAFETY RESEARCH AND DEVELOPMENT/	18-5-1-589
	LIGHT WATER REACTOR SAFETY RESEARCH IN JAPAN/	11-3-1-185
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	19-5-1-541
	WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-3-1-241
	WATPP REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-8
	FOURTH WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
	FIFTH JRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
	SIXTH NRC WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	19-3-1-281
	AEC'S NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND SCHEDULES	20-3-1-249
	NRC WATER REACTOR SAFETY RESEARCH PROGRAM/	15-2-1-127
	GERMAN LIGHT WATER REACTOR SAFETY RESEARCH PROGRAM/	18-1-1-1
	1978 ACRS CRITIQUE OF NRC SAFETY RESEARCH PROGRAM/	18-6-1-727
NSION/	WATER REACTOR SAFETY RESEARCH PROGRAM - A CRITIQUE AND AN EXT	20-4-1-399
N RESULTS/	EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS/	19-4-1-433
	FRENCH SAFETY STUDIES OF PRESSURIZED WATER REACTORS/	19-4-1-411
	CLINCH RIVER BREEDER REACTOR PLANT SAFETY STUDY/	19-3-2-316
T OF THE NRC RISK ASSESSMENT REVIEW GROUP ON THE REACTOR	SAFETY STUDY/	20-1-1-24
	COMPARATIVE RELIABILITY ANALYSES OF REACTOR SAFETY SYSTEMS/	REPOR 14-6-3-605
	COMMON-MODE FAILURES IN REACTOR SAFETY SYSTEMS/	18-5-3-624
	AUTOMATION OF REACTOR CONTROL AND SAFETY SYSTEMS AT ORNL/	11-2-3-115
	RELIABILITY ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY/	12-5-4-496
	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	17-3-1-289



AN APPRECIATION OF PAST REACTOR SAFETY-1970/	12-2-1-83
VE POWER REACTOR WASTES/ STATUS OF INVESTIGATIONS OF SALT FORMATIONS FOR DISPOSAL OF HIGHLY RADIOACTI	11-2-5-130
CH AND REACTOR COOLANT TEMPERATURE ANOMALIES/ SALZBURG/	18-6-1-756
FROM 1975 TO 2020 AND THE ESTIMATED RADIOLOGICAL IMPACT/ SAN ONOPPE EXPERIENCE WITH APPARENT 'DOWN' MISMAT	11-2-6-142
ABC'S NUCLEAR SAFETY RESEARCH OBJECTIVES, PLANS, AND SCHEDULES/	19-5-5-602
TURBULENT DIFFUSION TYPING SCHEMES - A REVIEW/	15-2-1-127
JOINT ANNUAL SYMPOSIUM OF IEEE POWER AND NUCLEAR SCIENCE GROUPS - 1970/	17-1-5-68
ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QUO/	12-4-3-310
APPLICATION OF REACTOR SCRAM EXPERIENCE IN RELIABILITY ANALYSIS OF SHUT	19-6-3-712
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER REACTORS/	20-4-3-422
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR WATER COOLED POWER REACTORS/	15-2-3-151
ASSESSMENT OF THE FREQUENCY OF FAILURE TO SCRAM IN LIGHT WATER REACTORS/	20-6-3-690
FAILURE OF A REACTOR PRIMARY SCRAM SYSTEM/	12-6-6-608
REACTOR/ RELIABILITY ANALYSIS OF THE SCRAM SYSTEM OF THE MISSOURI UNIVERSITY RESEARCH	17-4-3-437
GASSING/ UNEXPECTED MELTDOWN OF THE SCRAP URANIUM - ALUMINUM CERMET CORES DURING OUT	15-4-6-455
L LOCATIONS/ PREDICTING SEA-BREEZE PUMIGATION FROM TALL STACKS AT COASTA	12-2-5-110
BOTAGE/ SAFETY AND SECURITY OF NUCLEAR POWER REACTORS TO ACTS OF SA	17-6-1-665
RS/ ASSESSMENT OF SEISMIC TRIP SYSTEMS FOR COMMERCIAL POWER REACTO	19-5-3-590
VEGAS )/ BIOLOGICAL EFFECTS OF NOBLE GASES ( A REVIEW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASS	15-6-5-732
REPORT ON SEMINAR OF TRIGA OWNERS/	11-6-5-493
MENTS/ SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRU	16-4-3-452
SENT AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS )/ SEPARATION AND CONTAINMENT OF NOBLE GASES ( A RE	15-3-4-302
NUCLEAR POWER PLANTS IN SWEDEN AND THE UNITED STATES/ THE SEPARATION OF ELECTRICAL EQUIPMENT AND SYSTEMS I	19-6-3-723
ANALYSIS OF A SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERIOUS FAILURE OF EMERGENCY CORE COOLING/ A	15-3-2-285
R AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE/	12-5-4-499
LATED INSTRUMENTATION/ SET-POINT DRIFT IN NUCLEAR POWER PLANT SAFETY RE	16-2-6-223
ES BETWEEN 1962 AND 1976, WITH PROJECTIONS/ A SUMMARY OF SHALLOW LAND BURIAL OF RADIOACTIVE WASTES AT COM	19-1-5-50
TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE MATERIAL SHIPMENTS IN THE NUCLEAR FUEL CYCLE/ PROBABILITY	14-6-2-597
NT FOLLOWING A LOSS OF COOLANT ACCIDENT IN PWRs/ THERMAL SHOCK STUDIES ASSOCIATED WITH INJECTION OF EMERG	19-1-2-10
PLANT SITING, DESIGN, AND OPERATION/ COLD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR POWER	18-3-5-329
R RADIATION WORKERS/ SHOULD MEDICAL RADIATION EXPOSURE BE RECORDED FO	14-3-5-220
EVOLUTION OF OPTIMUM TOWER DESIGN/ EMERGENCY SHUTDOWN COOLING TOWERS - CONSIDERATIONS IN THE	17-6-4-701
N OF REACTOR SCRAM EXPERIENCE IN RELIABILITY ANALYSIS OF SHUTDOWN SYSTEMS/	19-6-3-712
THE STATE SIDE OF THE SITING EQUATION - SOME CASE STUDIES/	19-1-1-1
FFS NUCLEAR POWER PLANT/ SILICONE RUBBER INSULATED CABLES FOR CALVERT CBI	16-6-3-714
NUCLEAR POWER PLANTS/ SIMULATING STRONG MOTION EARTHQUAKE EFFECTS ON N	13-2-2-114
OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT SIMULATORS/	16-4-5-482
EMISPHERE POPULATION GROUPS FROM KRYPTON-85 EMITTED BY A SINGLE NUCLEAR FUEL REPROCESSING PLANT/ ESTIMATE	13-2-5-130
CONSTRUCTION OF A SITE ASSEMBLED NUCLEAR REACTOR PRESSURE VESSEL/	11-2-4-119
NUCLEAR ENERGY CENTER SITE SURVEY - 1975/	17-4-1-411
INSTRUMENTATION PROGRAMS FOR NUCLEAR POWER PLANT SITES/	18-5-3-617
G PAPER ON POPULATION DENSITY AROUND NUCLEAR POWER PLANT SITES/	16-1-1-1
RADIOLOGICAL ASPECTS OF INACTIVE URANIUM MILLING SITES - IN OVERVIEW/	17-6-5-722
SHALLOW LAND BURIAL OF RADIOACTIVE WASTES AT COMMERCIAL SITES RE-OPEN 1962 AND 1976, WITH PROJECTIONS/ A	19-1-5-50
SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR FACILITY SITING/	12-5-6-530
REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/	16-3-1-273
NUCLEAR ENERGY CENTERS - A PRIME ELEMENT IN REACTOR SITING/	16-3-1-282
LEGAL AND INSTITUTIONAL PROBLEMS IN POWER PLANT SITING/	18-2-1-127
UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY ASSESSMENT/	15-5-1-519
THE DEVELOPMENT OF REACTOR SITING CRITERIA BASED UPON RISK PROBABILITY/	13-1-2-022
THE STATE SIDE OF THE SITING EQUATION - SOME CASE STUDIES/	19-1-1-1
IC EFFECTS PROBLEM/ ECOLOGICAL CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOT	12-1-3-025
OFFSHORE SITING OF NUCLEAR ENERGY STATIONS/	12-1-2-009
NOVEL SITING PRACTICE AND ITS RELATION TO POPULATION/	14-6-1-576
LD SHOCK TO AQUATIC ORGANISMS - GUIDANCE FOR POWER PLANT SITING SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-6-1-651
ION MEETING/ SITING, DESIGN, AND OPERATION/	18-3-5-329
LEAR PLANT SPACERS/ SIXTH NRC WATER REACTOR SAFETY RESEARCH INFORMAT	20-3-1-249
HUMAN ENGINEERING - AIDS TO SIZED PRESSURE VESSEL TESTS TO LOW SAFETY/	17-4-4-447
THE EIGHTH MIDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/	14-6-4-634
TEENTH POWER INSTRUMENTATION SYMPOSIUM OF THE INSTRUMENT SOCIETY OF AMERICA/	18-2-6-223
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	14-5-3-461
AMERICAN PHYSICAL SOCIETY'S STUDY OF LIGHT WATER REACTOR SAFETY/	16-6-5-720
LMPBR SAFETY I. FISSION PRODUCT BEHAVIOR IN SODIUM/	13-1-3-029
ING RELATIVE TO THE BREAKUP OF MOLTEN URANIUM DIOXIDE IN SODIUM/	17-3-1-289
IAEA-1WGPR MEETING ON SODIUM COMBUSTION AND ITS EXTINGUISHMENT/	16-5-1-542
SAFETY INSTRUMENTATION FOR THE SODIUM COOLED FAST REACTOR/	11-5-3-379
THE SODIUM LOOP SAFETY FACILITY/	16-6-2-683
REDER REACTORS/ CONTAMINATION CONTROL OF SODIUM RELEASES FROM LIQUID METAL COOLED FAST BR	15-2-2-146
CONSEQUENCES OF AN ACCIDENTAL RELEASE OF SODIUM TO THE ENVIRONMENT FROM AN LMPBR/	16-6-3-701
SAFETY ASSESSMENT OF PAST SODIUM-COOLED REACTORS IN THE UNITED KINGDOM/	19-3-4-339
SOFTWARE/	13-1-4-037
NEUTRATION TESTING FOR THE DETERMINATION OF PROPERTIES OF SOILS/	14-4-5-325
RADIOTOXIC HAZARD MEASURE FOR BURIED SOLID RADIOACTIVE WASTE/	11-4-1-283
ER PLANTS/ SOLID RADIOACTIVE WASTE PRACTICES AT NUCLEAR POW	17-6-3-693
N AND FIRE DURING CONVERSION OF LIQUID URANYL NITRATE TO SOLID URANIUM OXIDE/	15-4-4-423
RELEASES OF RADIOACTIVITY IN EFFLUENTS AND AN EXPLOSION	16-2-4-180
ORDER/ THE SAFETY AND CONTROL OF URANIUM-235 SOLID WASTE FROM NUCLEAR POWER PLANTS IN 1972/	16-5-4-581
NOVEL SITING SOLUTIONS IN TANKS CONTAINING A FIXED NEUTRON ADS	19-1-6-91
SOLUTIONS FOR NUCLEAR POWER PLANTS/	15-3-6-311
DECONTAMINATION AFTER FAILURE OF AN ANTIMONY - BERYLLIUM SOURCE ROD/	15-6-1-651
N ESTIMATING FISSION-PRODUCT RADIATION AND THERMAL POWER SOURCE STRENGTH/	14-4-6-362
DATA SOURCES FOR LOCA CODE VERIFICATION/	13-1-5-054
COMPARATIVE RISK - COST - BENEFIT STUDY OF ALTERNATIVE SOURCES OF ELECTRICAL ENERGY/	17-6-2-671
NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES OF RADON-222/	17-2-1-171
ANOTHER PERSPECTIVE OF THE 1958 SOVIET NUCLEAR ACCIDENT/	20-6-5-722
CONFERENCE ON REACTIVITY EFFECTS IN LARGE POWER REACTORS/ SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE	20-2-6-206
SITING OF AIR CLEANING SYSTEMS FOR ACCESS TO NUCLEAR PLANT SPACES/	13-4-2-287
THE 1974 SPECIALISTS MEETING ON REACTOR NOISE/	14-6-4-634
SECOND SPECIALISTS MEETING ON REACTOR NOISE/	16-3-3-308
	19-4-3-468

FIELD MEASUREMENTS OF ATMOSPHERIC DIFFUSION UNDER LOW WIND SPEED INVERSION CONDITIONS/	A SURVEY OF FI	17-2-5-223
HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER REACTORS/		20-1-4-54
REACTOR CONTAINMENT BUILDING SPRAY SYSTEMS FOR FISSION PRODUCT REMOVAL/		12-5-5-516
RESEARCH ON THE USE OF CONTAINMENT BUILDING SPRAY SYSTEMS IN PRESSURIZED WATER REACTORS/		11-3-4-223
FUEL MELTDOWN AT ST. LAURENT I/		12-1-4-035
PREDICTING SEA-BREEZE FUMIGATION FROM TALL STACKS AT COASTAL LOCATIONS/		12-2-5-110
CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS LOW AS PRACTICABLE HEARING/		15-4-5-443
RADIATION MONITORING ( A GUIDE FOR MANAGEMENT )/ U.S.A. STANDARD N13.2-1969 - GUIDE FOR ADMINISTRATIVE P		11-7-5-039
SYSTEMS/	ANS STANDARD N13.8 ON DESIGN BASES FOR PROTECTIVE SY	15-3-3-292
REVIEW OF AUGUST 1978 CHANGES TO THE NRC'S PROGRAM FOR STANDARDIZATION OF NUCLEAR POWER PLANTS/		20-3-1-258
QUALITY ASSURANCE STANDARDS AND PRACTICES/		12-6-1-549
RADIATION STANDARDS AND PUBLIC HEALTH/		12-1-1-001
STANDARDS COMMITTEE/	NUCLEAR STANDARDS	19-3-1-297
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/		14-3-1-181
REVIEW OF ENGINEERING STANDARDS DEVELOPMENT FOR NUCLEAR POWER SYSTEMS/		12-3-3-217
HE DIN NUCLEAR STANDARDS COMMITTEE/	STANDARDS IN THE FEDERAL REPUBLIC OF GERMANY - I	19-3-1-297
INTERNATIONAL VIEWS ON PRINCIPLES AND STANDARDS OF REACTOR SAFETY/		14-5-1-428
THE ANSI-NSMB NUCLEAR STANDARDS PROGRAM/		16-4-1-415
STANDBY EMERGENCY POWER SYSTEMS I. THE EARLY PL		14-3-3-206
PLANTS/	STANDBY EMERGENCY POWER SYSTEMS, II. THE LATER	16-2-3-162
STANFORD LINEAR ACCELERATOR CENTER/		11-6-1-435
HEARING/	STATEMENT CONCERNING THE, AS LOW AS PRACTICABLE	15-4-5-440
LOW AS PRACTICABLE HEARING/	CONCLUDING STATEMENT OF THE AEC REGULATORY STAFF IN THE, AS	15-4-5-443
COMPUTER CONTROL AT BRUCE NUCLEAR GENERATING STATION/		15-6-3-691
NUCLEAR SAFETY EXPERIMENTS IN THE MARVIKEN POWER STATION/		18-4-4-481
IMPACT OF THE ACCIDENT AT THE THREE MILE ISLAND NUCLEAR STATION/	PRELIMINARY DOSE AND HEALTH	20-5-5-591
FLOW OF RADIONUCLIDES DISCHARGED FROM A BWR NUCLEAR POWER STATION INTO A MARINE BAY/	ABUNDANCE AND DISTRIB	20-2-5-190
REACTOR AVAILABILITY AND STATION RELIABILITY FOR CONTINUITY OF SERVICE/		12-5-4-499
OFFSHORE SITING OF NUCLEAR ENERGY STATIONS/		12-1-2-009
OCCUPATIONAL RADIATION EXPOSURE AT OPERATING NUCLEAR POWER STATIONS/	CONTROLLING OC	18-4-5-492
1972-1976/	RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS AND FUEL REPROCESSING PLANTS IN EUROPE,	20-4-6-469
RADIOACTIVE EFFLUENTS FROM NUCLEAR POWER STATIONS IN EUROPE, 1970-1974/		18-3-6-373
PRESSURE VESSEL FAILURE STATISTICS AND FAILURE PROBABILITIES/		15-4-2-187
U.S. NUCLEAR POWER PLANT AVAILABILITY AND CAPACITY STATISTICS FOR 1973/		15-6-6-738
DISPOSAL OF HIGHLY RADIOACTIVE POWER REACTOR WASTES/	STATUS OF INVESTIGATIONS OF SALT FORMATIONS FOR	11-2-5-130
EVOLUTION AND CURRENT STATUS OF THE BWR CONTAINMENT SYSTEM/		15-2-4-163
GRAM/	STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PRO	12-5-5-523
FRACTURE INVESTIGATIONS AND CURRENT STATUS OF THE PLUTONIUM HOT PARTICLE PROBLEM/		17-4-5-464
ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QUO/		17-1-3-43
THE REACTOR LICENSING PROCESS - A STATUS REPORT/		18-3-1-281
REACTOR CORE COOLING SYSTEM PERFORMANCE/	STEAM - WATER MIXING STUDIES RELATED TO EMERGENC	17-2-2-185
IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE	16-3-6-354
IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE	16-5-6-603
IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE	17-2-6-231
IN WATER COOLED NUCLEAR POWER REACTORS IN 1975/	STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE	18-3-6-355
IN WATER COOLED NUCLEAR POWER REACTORS IN 1976/	STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE	19-6-6-748
OPERATION WITH WATER COOLED NUCLEAR POWER REACTORS DURING 1977/	STEAM GENERATOR TUBE PERFORMANCE - WORLD EXPERIE	20-5-6-595
FRACTURE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM/		12-5-5-523
NEUTRON IRRADIATION EMBRITTLEMENT OF REACTOR PRESSURE VESSEL STEELS/	NEUT	17-3-4-327
OPERATION IN NEUTRON IRRADIATED FERRITIC PRESSURE VESSEL STEELS/	FATIGUE CRACK PR	18-6-4-791
EFFECTS ON ORGANISMS OF ENTRAINMENT IN COOLING WATER - HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER REACTORS/	STRENGTH/	12-6-5-600
ON ESTIM		20-1-4-54
STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER STRIKE AND DAMAGE PROBABILITIES/		16-4-2-843
R PLANTS/	STRONG MOTION EARTHQUAKE EFFECTS ON NUCLEAR POWER	13-2-2-114
INTERIOR STRUCTURES/	GENERAL STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT I	13-5-4-373
STRUCTURE ANALYSIS FOR LWRS IN THE FEDERAL REPUB		13-2-2-107
COUPLED FLUID STRUCTURES/		20-5-2-551
TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT STRUCTURES/		11-4-2-296
EARTHQUAKE RESISTANT DESIGN OF ENGINEERING STRUCTURES/		14-1-1-001
TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT STRUCTURES/		15-4-4-432
STRUCTURAL DESIGN CRITERIA FOR PWR CONTAINMENT INTERIOR GENERAL		13-5-4-373
S IN THE DESIGN OF PRESSURIZED WATER REACTOR CONTAINMENT TREND		18-2-4-189
AGINATION IN LIQUID COOLED FAST BREEDER REACTOR FUEL SUBASSEMBLIES/	PIN-TO-PIN FAILURE PROP	16-3-2-291
BURNOUT IN ROLLING HEAT TRANSFER II. SUBCOOLED AND LOW QUALITY FORCED CONVECTION SYST		18-2-2-154
PROBABILITY AND RISK ASSESSMENT - THE SUBJECTIVISTIC VIEWPOINT AND SOME SUGGESTIONS/		12-6-3-583
HEAVY LIABILIY INSURANCE - THE HISTORY REFLECTING THE SUCCESS OF NUCLEAR SAFETY/	NUCL	19-3-2-305
SUDDEN MAJOR LOSS OF COOLANT ACCOMPANIED BY SERI		12-4-1-291
CREST SUMMARY - WATER-COOLED REACTOR SAFETY/		15-3-2-285
NON NUCLEAR POWER PLANTS DURING 1973/ SUMMARY OF RADIOACTIVITY RELEASED IN EFFLUENTS F		12-3-1-196
REACTOR FACILITIES/ SUMMARY OF SCENT ABNORMAL OCCURRENCES AT POWER		16-6-6-734
REACTOR SITES BETWEEN 1962 AND 1976, WITH PROJECTIONS/ A SUMMARY OF SHALLOW LAND BURIAL OF RADIOACTIVE WA		15-2-6-198
AGENCY REVIEW GROUP ON NUCLEAR WASTE MANAGEMENT/ SUMMARY OF THE REPORT TO THE PRESIDENT BY THE IN		19-1-5-50
RT/ SUMMARY OF TMI-2 LESSONS LEARNED TASK FORCE REPO		20-6-4-706
SUPPLIES/		20-6-6-735
RELIABILITY OF D-C POWER SUPPLY ARRANGEMENTS IN NUCLEAR POWER PLANTS/		19-3-3-330
OSAL OF RADIOACTIVE WASTE FROM NAVAL NUCLEAR VESSELS AND SUPPORT FACILITIES IN 1978/ ENVIRONMENTAL MONITO		20-2-3-166
OCAL GOVERNMENT RADIOLOGICAL EMERGENCY RESPONSE PLANS IN SUPPORT OF FIXED NUCLEAR FACILITIES/ STATE AND L		20-4-5-446
THE ICE CONDENSER SYSTEM FOR CONTAINMENT PRESSURE SUPPRESSION/		17-1-1-15
ACTOR FUEL/ A COMPARISON OF TWO NITROGEN-16 RADIATION SUPPRESSION DEVICES FOR TWO TYPES OF RESEARCH RE		17-6-4-710
ENVIRONMENTAL SURVEILLANCE FOR NUCLEAR FACILITIES/		11-3-6-237
PLANTS/ PLANNING AND VALIDATION OF ENVIRONMENTAL SURVEILLANCE PROGRAMS AT OPERATING NUCLEAR POWER		19-1-5-66
IDENTIFICATION OF POTENTIAL IMPROVEMENTS IN ENVIRONMENTAL SURVEILLANCE TECHNIQUES/	I	19-4-5-486
NUCLEAR ENERGY CENTER SITE SURVEY - 1975/		17-3-5-344
SENSITIVITY OF PORTABLE BETA-GAMMA SURVEY INSTRUMENTS/		17-4-1-411
IN LIGHT WATER REACTOR CONTAINMENTS/ A SURVEY OF APPLIED INSTRUMENT SYSTEMS FOR USE WIT		16-4-3-452
USTION UNDER LOW WIND SPEED INVERSION CONDITIONS/ A SURVEY OF FIELD MEASUREMENTS OF ATMOSPHERIC DIFF		15-6-3-702
CTRICAL EQUIPMENT AND SYSTEMS IN NUCLEAR POWER PLANTS IN SWEDEN AND THE UNITED STATES/ THE SEPARATION OF		17-2-5-223
SWITCH FAILURES AT NUCLEAR FACILITIES/		12-6-2-569
		19-6-3-723
		14-6-6-660

	QUALIFICATION OF SAFETY RELATED SWITCHGEAR FOR NUCLEAR POWER APPLICATIONS/	18-3-3-317
	THREE NUCLEAR POWER SYSTEMS SYMPOSIUM/	16-5-3-557
	INTERNATIONAL WASTE MANAGEMENT SYMPOSIUM/	18-4-5-502
	THE 16TH ANNUAL POWER INSTRUMENTATION SYMPOSIUM - CHALLENGES FOR POWER INSTRUMENTATION	15-4-3-417
	THE 1971 TRITIUM SYMPOSIUM AT LAS VEGAS/	13-3-5-225
EW OF SELECTED PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS //	BIOLOGICAL EFFECTS OF	15-6-5-732
REVIEW OF NINE PAPERS PRESENTED AT THE 1973 NOBLE GASES SYMPOSIUM AT LAS VEGAS //	SEPARATION AND CONTAIN	15-3-4-302
PS - 1973/	SYMPOSIUM OF THESE POWER AND NUCLEAR SCIENCE GROU	12-4-3-310
	JOINT ANNUAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/	16-6-5-720
	POPULATION EXPOSURES - THE EIGHTH MIDDYEAR TOPICAL SYMPOSIUM OF THE INSTRUMENT SOCIETY OF AMERICA/	13-1-3-029
	THE FOURTEENTH POWER INSTRUMENTATION SYMPOSIUM ON COOLING-TOWER ENVIRONMENT - 1974/	15-5-5-592
WEB/	THE IAEA-IEC SYMPOSIUM ON ENVIRONMENTAL ASPECTS OF NUCLEAR PO	12-2-1-75
ING OF NUCLEAR POWER PLANTS/	IAEA SYMPOSIUM ON EXPERIENCE FROM OPERATING AND FUELI	16-1-6-79
	IAEA - WHO SYMPOSIUM ON HANDLING OF RADIATION ACCIDENTS/	12-4-5-338
ACTIVITY SITING/	SYMPOSIUM ON HEALTH PHYSICS ASPECTS OF NUCLEAR P	12-5-6-530
	SYMPOSIUM ON HEALTH PHYSICS IN THE HEALING ARTS/	14-4-5-340
USE AND EFFECTS/	THIRD INTERNATIONAL SYMPOSIUM ON MEDICAL RADIONUCLIDES - RADIATION D	11-6-4-475
IOACTIVE MATERIALS/	FIFTH GERMAN SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RAD	14-4-1-274
LEAR POWER PLANTS/	SYMPOSIUM ON PROGRESS IN SAFETY EVALUATION OF NU	11-6-2-463
ION OF MAN AND HIS ENVIRONMENT/	IAEA-WMO SYMPOSIUM ON RADIOECOLOGY APPLIED TO THE PROTECT	13-5-5-380
E CONTAMINANTS IN THE ATMOSPHERE/	SYMPOSIUM ON THE PHYSICAL BEHAVIOR OF RADIOACTIV	15-3-5-306
PERSONNEL/	SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PE	12-6-6-615
REL/	SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSON	17-1-6-92
STRUMENTATION/	IAEA INTERNATIONAL SYMPOSIUMS ON NUCLEAR POWER PLANT CONTROL AND IN	15-1-3-015
	THE HOMEMADE NUCLEAR BOMB SYNDROME/	18-4-1-427
AR/	SYNOPSIS OF THE BWR BLOWDOWN HEAT-TRANSFER PROGR	20-1-2-27
	PREDICTING SRA-BREEZE FOMIGATION FROM TALL STACKS AT COASTAL LOCATIONS/	12-2-5-110
	THE LEAK OF TANK 106-T AT HANFORD/	15-4-6-860
	THE SAFETY AND CONTROL OF URANIUM-235 SOLUTION IN TANKS CONTAINING A FIXED NEUTRON ABSORBER/	15-3-4-295
	SUMMARY OF TMI-2 LESSONS LEARNED TASK FORCE REPORT/	20-6-6-735
	UNDERGROUND NUCLEAR PLANT SITING - A TECHNICAL AND SAFETY ASSESSMENT/	15-5-1-519
	RISK BENEFIT EVALUATION FOR LARGE TECHNOLOGICAL SYSTEMS/	20-2-2-144
	NATURAL AND TECHNOLOGICALLY ENHANCED SOURCES OF RADON-222/	20-6-5-722
	RELIABILITY ENGINEERING METHODS IN REACTOR SAFETY TECHNOLOGY/	12-5-4-496
ACTIVITIES OF THE GERMAN STANDARDS COMMITTEE FOR NUCLEAR TECHNOLOGY/	TECHNOLOGY OF PRESTRESSED CONCRETE REACTOR PRESS	14-3-1-181
THE VESSELS/	A REVIEW OF THE HEAVY SECTION STEEL TECHNOLOGY PROGRAM/	11-1-4-025
URE INVESTIGATIONS AND STATUS OF THE HEAVY SECTION STEEL CRITICAL MASS - POLITICS, TECHNOLOGY, AND THE PUBLIC INTEREST/	FRACT	12-5-5-523
SCIENCE WITH APPARENT POWER MISMATCH AND REACTOR COOLANT TEMPERATURE ANOMALIES/	SAN ONOPRE REP	17-5-1-539
FISSION PRODUCT DETECTION SYSTEMS IN HIGH TEMPERATURE GAS-COOLED REACTORS/		11-2-6-142
TEORY/ ACCIDENTAL COBALT-60 EXPOSURE AT THE UNIVERSITY OF TENNESSEE - ATOMIC ENERGY COMMISSION AGRICULTURA		12-2-3-90
CONSIDERATIONS IN SITING NUCLEAR POWER PLANTS - THE LONG TERM BIOTIC EFFECTS PROBLEM/	ECOLOGICAL	13-4-6-304
	A REVIEW OF SHORT TERM FISSION PRODUCT DECAY POWER/	12-1-3-025
	ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAINST NUCLEAR FACILITIES/	18-5-2-546
RESPONSE OF UNIRRADIATED AND IRRADIATED PWR FUEL RODS TESTED UNDER POWER COOLING MISMATCH CONDITIONS/		17-6-1-659
SAFETY/	IEC SAFEGUARDS AGAINST THE THEFT OR DIVERSION OF NUCLEAR MATERIALS/	19-4-2-440
	EQUATION OF STATE FOR FAST REACTOR SAFETY STUDIES I. THEORETICAL RELATIONS/	15-2-1-132
	RESTRICTED RELEASE OF PLUTONIUM II. THEORY/	15-5-1-513
	PUBLIC HEALTH RISKS OF THERMAL POWER SOURCES/	11-6-2-450
	OR ESTIMATING FISSION-PRODUCT RADIATION AND INTERNAL POWER SOURCE STRENGTH/	12-3-1-203
	ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY/	14-4-1-267
YE COOLANT FOLLOWING A LOSS OF COOLANT ACCIDENT IN PWRs/	THERMAL SHOCK STUDIES ASSOCIATED WITH INJECTION	13-1-5-054
TRANSPORTATION OF RADIOACTIVE MATERIALS/	THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND T	19-2-1-151
	THE THIRD RELIABILITY MEETING AT RISO/	19-1-2-10
	THE TRISTERENTH AEC AIR CLEANING CONFERENCE/	14-4-1-274
	RADIOLOGICAL IMPACT OF THORIUM MINING AND MILLING/	11-4-3-309
ITERS/	FAILURES OF THREADED FITTINGS AND FASTENERS AT NUCLEAR FACIL	16-2-4-190
T NUCLEAR FACILITIES/	ESTIMATES OF THREATS TO THE PUBLIC FROM TERRORIST ACTS AGAIN	20-7-5-319
FALTY RISKS FROM REACTOR ACCIDENTS/	LEUKEMIA AND THYROID CARCINOMA - A COMPARISON OF THE LATE MOR	13-1-5-047
ODINE/	PROTECTION OF THE THYROID GLAND IN THE EVENT OF RELEASES OF RADIODI	17-6-1-659
	LEVEL NUCLEAR WASTE MANAGEMENT IN THE UNITED STATES - A TIME FOR DECISIONS/	11-6-4-482
S ON REACTIVITY: EFFECTS IN LARGE POWER REACTORS/	SPACE - TIME REACTOR DYNAMICS - A REVIEW OF THE 1970 CRE	19-6-5-732
A METHOD FOR VERIFYING REACTIVITY - FEEDBACK TIME RESPONSE IN POWER REACTORS/		19-3-5-356
	SUMMARY OF TMI-2 LESSONS LEARNED TASK FORCE REPORT/	13-4-2-287
	AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY 1975/	13-4-3-295
	1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/	20-6-6-735
	REVIEW OF ANS TOPICAL MEETING ON NUCLEAR POWER PLANT SITING/	17-3-1-289
	ANS TOPICAL MEETING ON THERMAL REACTOR SAFETY/	16-2-1-141
	ANS NATIONAL TOPICAL MEETING ON WATER REACTOR SAFETY/	16-3-1-273
	POPULATION EXPOSURES - THE EIGHTH MIDDYEAR TOPICAL SYMPOSIUM OF THE HEALTH PHYSICS SOCIETY/	19-2-1-153
STRUCTURES/	TORNADO CONSIDERATIONS FOR NUCLEAR POWER PLANT S	14-5-1-439
STRUCTURES/	TORNADO RESISTANT DESIGN OF NUCLEAR POWER PLANT	16-6-5-720
LING TOWERS - CONSIDERATIONS IN THE EVOLUTION OF OPTIMUM TOWER DESIGN/	EMERGENCY SHUTDOWN COO	11-4-2-296
POG AND DRIFT DEPOSITION FROM EVAPORATIVE COOLING TOWERS/		15-4-4-432
NUM TOWER DESIGN/	EMERGENCY SHUTDOWN COO	17-6-4-701
	SYMPOSIUM ON THE TRAINING OF NUCLEAR FACILITY PERSONNEL/	15-2-5-190
	SECOND SYMPOSIUM ON TRAINING OF NUCLEAR FACILITY PERSONNEL/	17-6-4-701
SIMULATORS/	REACTOR OPERATOR TRAINING PROGRAMS UTILIZING NUCLEAR POWER PLANT	12-6-6-615
	REACTOR VESSEL PRESSURE TRANSIENTS/	17-1-6-92
S/	ANTICIPATED TRANSIENTS WITHOUT SCRAM - STATUS QOO/	16-4-5-482
REACTORS/	ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER REACTOR	18-4-6-513
RATION OF LIQUID METAL COOLED FAST BREEDER REACTORS II. TRANSPORT/	RADIONUCLIDE BEHAVIOR DURING NORMAL O	17-1-3-43
	ATMOSPHERIC TRANSPORT AND DISPERSION OVER CITIES/	15-2-3-151
THE PROPOSED REVISIONS TO IAEA REGULATIONS FOR THE SAFE TRANSPORT OF RADIOACTIVE MATERIALS/	THE IMPACT O	*8-3-4-318
STATES/	TRANSPORT OF RADIOACTIVE MATERIALS IN THE UNITED	13-5-5-391
THE NUCLEAR FUEL CYCLE/ PROBABILITY AND CONSEQUENCES OF TRANSPORTATION ACCIDENTS INVOLVING RADIOACTIVE M		13-2-1-103
	THIRD INTERNATIONAL SYMPOSIUM ON PACKAGING AND TRANSPORTATION OF RADIOACTIVE MATERIALS/	18-3-1-291
RISKS IN TRANSPORTING MATERIALS FOR VARIOUS ENERGY INDUST		14-6-2-597
RIES/	TRENDS IN PUBLIC HEALTH IN THE POPULATION NEAR N	14-4-1-274
UCLEAR FACILITIES - A CRITICAL ASSESSMENT/	TRENDS IN THE DESIGN OF PRESSURIZED WATER REACTO	19-2-1-135
R CONTAINMENT STRUCTURES AND SYSTEMS/		18-5-5-647
		18-2-4-189



STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN OCCUPATIONAL RADIATION EXPOSURE AT LIGHT WATER COOLED NUCLEAR POWER REACTORS, 1969-1976/	19-6-6-748
STEAM GENERATOR TUBE FAILURES - WORLD EXPERIENCE IN PROTECTION INSTRUMENTATION SYSTEMS IN LIGHT WATER COOLED NUCLEAR POWER REACTORS, 1975/	19-6-6-760
ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER COOLED NUCLEAR POWER REACTORS IN 1975/	18-3-6-355
C HYDROGEN GENERATION AFTER LOSS OF COOLANT ACCIDENTS IN ANTICIPATED TRANSIENTS WITHOUT SCRAM FOR LIGHT WATER COOLED POWER REACTOR PLANTS/	11-3-3-206
OCCUPATIONAL RADIATION EXPOSURES AT LIGHT WATER COOLED POWER REACTORS/	15-2-3-151
HANDLING AND STORAGE OF SPENT FUEL FROM LIGHT WATER COOLED POWER REACTORS/	13-6-2-459
COOLING SYSTEM PERFORMANCE/	18-3-6-365
WATER MIXING STUDIES RELATED TO EMERGENCY CORE CLOSURE/	20-1-4-54
WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER REACTORS/	17-2-2-185
WATER POLLUTION CONTROL ACT AND ITS IMPACT ON NUCLEAR POWER REACTORS/ INSTRUMENTATION FOR MONITORING REACTOR ACCIDENTS/	15-3-1-262
WATER REACTOR CONTAINMENT STRUCTURES AND SYSTEMS/	16-4-1-421
WATER REACTOR LOSS OF COOLANT ACCIDENTS BY HYPOTHETICAL LOSS-OF-COOLANT ACCIDENT IN LARGE LIGHT WATER REACTORS/	11-6-3-268
WATER REACTOR POWER PLANTS - A REVIEW OF EXPERIENCE/	12-5-3-487
WATER REACTOR SAFETY/	18-2-4-189
WATER REACTOR SAFETY/	15-6-3-702
WATER REACTOR SAFETY/	14-4-2-291
WATER REACTOR SAFETY/	20-6-6-729
WATER REACTOR SAFETY/	20-2-6-210
WATER REACTOR SAFETY/	12-5-1-433
WATER REACTOR SAFETY/	14-5-1-439
WATER REACTOR SAFETY/	16-5-1-542
WATER REACTOR SAFETY PROGRAM/	16-6-1-659
WATER REACTOR SAFETY PROGRAM PLAN/	11-5-1-369
WATER REACTOR SAFETY RESEARCH IN JAPAN/	19-5-1-541
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	15-3-1-241
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	16-1-1-8
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	17-2-1-143
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	18-2-1-133
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	19-3-1-281
WATER REACTOR SAFETY RESEARCH INFORMATION MEETING/	20-3-1-249
WATER REACTOR SAFETY RESEARCH PROGRAM/	18-1-1-1
WATER REACTOR SAFETY RESEARCH PROGRAM/	18-6-1-727
WATER REACTOR SAFETY RESEARCH PROGRAM - APPLICATION OF RESEARCH RESULTS/	19-3-1-292
WATER REACTORS/	17-4-6-475
WATER REACTORS/	17-5-4-568
WATER REACTORS/	19-4-1-411
WATER REACTORS/	20-4-3-422
WATER REACTORS/	20-6-3-690
WATER REACTORS/	19-4-4-873
WATER REACTORS/	18-1-4-860
WATER REACTORS/	11-3-4-223
WATER REACTORS/	15-1-6-076
WATER REACTORS - LOSS OF COOLANT ACCIDENTS/	14-1-2-014
WATER REACTORS IN EUROPE/	18-5-6-666
WATER-COOLED REACTOR SAFETY/	12-3-1-196
WET AND DRY DEPOSITION OF PARTICLES AND GASES FROM REACTOR ACCIDENTS/	19-2-5-205
WIND DIRECTION WITHIN THE UNITED STATES/	12-4-5-338
WIND SPEED INVERSION CONDITIONS/	11-1-5-034
WORKERS/	17-2-5-223
WORKERS IN THE NUCLEAR FUEL AND REACTOR INDUSTRY/	14-3-5-220
WORKING PAPER ON POPULATION DENSITY AROUND NUCLEAR PLANTS/	17-3-6-363
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1972/	16-1-1-1
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1973/	16-3-6-354
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1974/	16-5-6-603
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN 1976/	17-2-6-231
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS DURING 1977/	19-6-6-748
WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTOR PLANTS DURING 1977/	18-3-6-355
WORLD EXPERIENCE WITH WATER COOLED NUCLEAR POWER REACTORS/	20-5-6-595
WORLD NUCLEAR POWER INDUSTRY FROM 1975 TO 2020 A SCENARIO/	19-5-5-602
X-RAYS - U.S. 1970/	15-4-5-453
Y-1235 - KRYPTON REMOVAL SYSTEMS/	12-6-4-591
Y-1235 - KRYPTON REMOVAL SYSTEMS/	16-5-1-537
Y-1235 - KRYPTON REMOVAL SYSTEMS/	20-1-1-01
Y-1235 - KRYPTON REMOVAL SYSTEMS/	19-3-6-369
Y-1235 - KRYPTON REMOVAL SYSTEMS/	16-2-5-204
Y-1235 - KRYPTON REMOVAL SYSTEMS/	17-2-2-194
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-4-6-460
Y-1235 - KRYPTON REMOVAL SYSTEMS/	18-5-6-666
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-4-3-417
Y-1235 - KRYPTON REMOVAL SYSTEMS/	20-3-4-294
Y-1235 - KRYPTON REMOVAL SYSTEMS/	20-2-6-206
Y-1235 - KRYPTON REMOVAL SYSTEMS/	19-1-5-50
Y-1235 - KRYPTON REMOVAL SYSTEMS/	17-5-6-622
Y-1235 - KRYPTON REMOVAL SYSTEMS/	18-3-6-365
Y-1235 - KRYPTON REMOVAL SYSTEMS/	19-6-6-760
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-4-5-453
Y-1235 - KRYPTON REMOVAL SYSTEMS/	12-4-3-310
Y-1235 - KRYPTON REMOVAL SYSTEMS/	12-2-6-134
Y-1235 - KRYPTON REMOVAL SYSTEMS/	13-4-2-287
Y-1235 - KRYPTON REMOVAL SYSTEMS/	18-3-6-370
Y-1235 - KRYPTON REMOVAL SYSTEMS/	13-2-4-122
Y-1235 - KRYPTON REMOVAL SYSTEMS/	13-3-5-225
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-1-6-067
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-3-6-311
Y-1235 - KRYPTON REMOVAL SYSTEMS/	16-3-6-354
Y-1235 - KRYPTON REMOVAL SYSTEMS/	20-4-6-468
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-6-6-738
Y-1235 - KRYPTON REMOVAL SYSTEMS/	16-6-6-734
Y-1235 - KRYPTON REMOVAL SYSTEMS/	16-5-6-603
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-2-1-132
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-3-4-302
Y-1235 - KRYPTON REMOVAL SYSTEMS/	15-6-5-732

STAGES AT LIGHT WATER REACTOR POWER PLANTS - A REVIEW OF	1973-1977 EXPERIENCE/	O	20-2-6-210
	SYMPOSIUM ON COOLING-TOWER ENVIRONMENT -		15-5-5-592
OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES,	1974/		17-6-6-743
RADIOACTIVE MATERIAL RELEASED FROM NUCLEAR POWER PLANTS IN	1974/	RA	18-1-6-79
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN	1974/		17-2-6-231
	THE 1974 ANS TOPICAL MEETING ON FAST REACTOR SAFETY/		18-2-1-141
	1974 SPECIALISTS MEETING ON REACTOR NOISE/		16-3-3-708
	NUCLEAR ENERGY CENTER SITE SURVEY -		17-4-1-411
OCCUPATIONAL RADIATION EXPOSURES AT LICENSED FACILITIES,	1975/		18-4-6-523
AMERICAN NUCLEAR SOCIETY TOPICAL MEETING - NUCLEAR SAFETY	1975/		17-3-1-289
S - WORLD EXPERIENCE IN WATER COOLED NUCLEAR REACTORS IN	1975/		18-3-6-355
W-14 RELEASES FROM THE WORLD NUCLEAR POWER INDUSTRY FROM	1975 TO 2020 AND THE ESTIMATED RADIOLOGICAL IMPACT		19-5-5-602
RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN	1976/	RA	19-5-6-628
WORLD EXPERIENCE IN WATER COOLED NUCLEAR POWER REACTORS IN	1976/		19-6-6-748
AND RELATED PHYSICS/	1976 INTERNATIONAL MEETING ON FAST REACTOR SAFETY		18-4-2-451
RADIOACTIVE WASTES AT COMMERCIAL SITES BETWEEN 1962 AND	1976, WITH PROJECTIONS/ A SUMMARY OF SHALLOW LAND		19-1-5-50
RADIOACTIVE MATERIALS RELEASED FROM NUCLEAR POWER PLANTS IN	1977/	RA	20-4-6-476
LOGICAL QUALITY OF THE ENVIRONMENT IN THE UNITED STATES,	1977/	RADIO	19-5-5-617
RADIATION EXPOSURE FROM THE U.S. NAVAL REACTOR PROGRAM,	1977/	OCCUPATIONAL	20-3-6-345
AND RELATED EVENTS AT NUCLEAR POWER PLANTS AS REPORTED IN	1977/	A REVIEW OF SAFE	20-1-6-83
EXPERIENCE WITH WATER COOLED NUCLEAR POWER REACTORS DURING	1977/	STEAM GENERATOR TUBE PERFORMANCE - WORLD	20-5-6-595
OPERATIONS FROM NAVAL NUCLEAR VESSELS AND SUPPORT FACILITIES IN	1978/	ENVIRONMENTAL MONITORING AND DISPOSAL OF	20-4-5-446
REACTORS/	1978 ACRS CRITIQUE OF NRC SAFETY RESEARCH PROGRAM		20-4-1-399
OPERATION OF NUCLEAR POWER PLANTS/	REVIEW OF AUGUST 1978 CHANGES TO THE NRC'S PROGRAM FOR STANDARDIZING		20-3-1-258
	DRESDEN 2 INCIDENT OF JUNE-5, 1970/		12-5-7-538
	THE RELAP4 COMPUTER CODE		17-3-2-299
	POPULATION DOSES FROM THE NUCLEAR INDUSTRY TO 2000 A.D./		15-1-5-056
OPERATIONS FROM THE WORLD NUCLEAR POWER INDUSTRY FROM 1975 TO	2020 AND THE ESTIMATED RADIOLOGICAL IMPACT/ SCENARIOS		19-5-5-602
INSTRUMENTATION AND AUTOMATIC CONTROL SYSTEMS - THE	26TH ISA CONFERENCE AND EXHIBIT/		13-5-3-366

END KWIC-INDEX

## Section 3

## AUTHOR INDEX

Authors of *Nuclear Safety* articles are indexed here in alphabetical order. The seven-digit index number following each name provides entry to the main (orange) index. The same numbering system is used in the other index sections and is explained in the Introduction. If an author has prepared more than one article for *Nuclear Safety*, his name appears with a specific index number for each article: for example, D. W. Moeller (see index) has had articles in Vol. 11, No. 1, Sect. 5, p. 39; Vol. 12, No. 2, Sect. 4, p. 100; Vol. 13, No. 4, Sect. 1, p. 275; Vol. 14, No. 2, Sect. 4, p. 111; Vol. 16, No. 4, Sect. 4, p. 469; Vol. 17, No. 1, Sect. 1, p. 1; Vol. 18, No. 2, Sect. 4, p. 174; Vol. 18, No. 5, Sect. 4, p. 633; Vol. 19, No. 1, Sect. 5, p. 66; and Vol. 20, No. 2, Sect. 4, p. 176.

## AUTHOR LIST

ACKERMAN, N. J., JR. 12-6-3-583  
 ADAMS, G. H. 20-5-5-582  
 AEC REGULATORY STAFF 15-2-2-151  
 ALKEN, A. H. 18-2-3-154  
 ALLEN, J. H. 18-5-3-617  
 ALVAREZ, O. L. 17-3-8-284  
 ANATO, C. G. 14-6-1-563  
 ANAVIS, R. J. 11-5-5-380  
 ANDERSEN, S. O. 13-6-1-651  
 ANDERSON, T. D. 12-1-1-009  
 APOSTOLAKIS, G. 19-3-7-305  
 APOSTOLAKIS, G. 20-6-3-690  
 ARBON, J. E. 20-5-2-541  
 ARDREY, J. P. 14-1-6-027  
 ADEBACH, S. L. 12-1-3-025  
 ADEBACH, S. L. 20-2-6-206  
 AUBIER, J. A. 12-5-2-456  
 BAKER, A. R. 17-3-6-363  
 BAKER, L. JR. 11-1-8-001  
 BAKAN, W. S. 19-6-3-741  
 BARKER, P. E. 18-3-3-322  
 BARNUM, D. J. 17-2-2-139  
 BARNUM, D. J. 17-3-2-289  
 BARNUM, D. J. 17-4-2-422  
 BARSELL, A. W. 18-6-2-761  
 BARTON, C. J. 13-3-5-235  
 BARTON, C. J. 15-3-8-302  
 BARTON, C. J. 15-6-3-712  
 BARTON, C. J. 16-6-5-720  
 BASKIN, K. P. 11-2-6-182  
 BASSETT, T. G. 13-1-3-029  
 BAYMAN, R. 16-3-1-273  
 BAYMAN, C. D. 12-2-1-900  
 BECKER, K. 16-6-5-728  
 BECKER, K. 19-3-1-207  
 BECKNER, W. D. 20-3-2-267  
 BELL, C. O. 14-1-1-001  
 BELL, E. L. 15-5-3-554  
 BELLAMY, R. E. 15-6-6-711  
 BELTRACCHI, L. 20-1-4-633  
 BENNETT, G. L. 17-6-6-693  
 BENNETT, G. L. 18-5-1-589  
 BENNETT, G. L. 16-1-2-29  
 BENNETT, G. L. 18-2-2-154  
 BENNETT, G. L. 20-6-2-671  
 BELLAMY, R. E. 13-5-5-380  
 BELTRACCHI, L. 16-2-1-177  
 BERNSEN, S. A. 19-6-2-699  
 BEYER, C. E. 19-3-6-339  
 BEZELLA, W. A. 16-6-3-719  
 BILES, W. B. 16-1-5-60  
 BISHMAN, A. J. 18-2-4-189  
 BISHOP, M. A. 19-5-2-596  
 BLANCHARD, R. L. 20-2-5-190  
 BLANCO, R. E. 19-4-5-497  
 BLAND, J. S. 18-3-6-365  
 BLAYLOCK, R. G. 17-3-8-351  
 BOMAN, E. S. 20-3-5-319  
 BOND, W. D. 20-3-5-319  
 BOONE, F. W. 16-5-5-593  
 BOONE, F. W. 17-1-5-589  
 BOOTH, R. S. 19-9-3-468  
 BORKO, B. 18-2-1-177  
 BOURBAU, J. E. 20-9-2-402  
 BRADSHAW, H. P. 11-5-1-368  
 BRADSHAW, C. L. 11-2-5-130  
 BRADSHAW, C. L. 12-1-3-015  
 BRIGHT, G. O. 12-5-1-433  
 BRIGHT, G. O. 13-1-1-013  
 BOBBS, W. A. 14-6-2-597  
 BOBMAN, L. H. 17-5-1-530  
 BOONE, A. J. 13-6-2-477  
 BOOKS, D. G. 14-3-5-220  
 BOOKS, N. G. 17-6-6-783  
 BOOKS, B. G. 18-4-6-523  
 BROWDER, F. H. 12-3-4-234  
 BROWN, H. C., JR. 11-5-1-365  
 BROWN, H. C., JR. 19-2-5-271  
 BRYAN, R. H. 15-6-1-665  
 BRYAN, R. H. 17-4-4-447  
 BUCHANAN, J. E. 16-1-1-1  
 BUCHANAN, J. E. 19-2-1-133  
 BUCHERT, K. P. 18-2-4-489  
 BULL, A. E. 19-3-2-316  
 BULLOCK, J. B. 17-6-6-693  
 BURGSMULKE, P. 16-2-1-150  
 BURDETTE, G. W. 20-1-2-27  
 BURDETTE, E. J. 19-5-6-623  
 BUSH, S. H. 13-1-1-001  
 BUSH, S. H. 18-3-2-187  
 BUSH, S. H. 17-5-4-568  
 BUSH, S. H. 19-6-2-681  
 BUTLER, D. A. 11-4-2-289  
 BUTLER, H. H. 13-3-5-225  
 CAGLE, C. D. 12-5-7-518  
 CANNON, W. A. 17-2-2-185  
 CARROLL, E. W. 12-4-2-207  
 CARROLL, E. W. 12-6-2-562  
 CASP, E. G. 15-3-2-285  
 CASTLEMAN, A. W., JR. 11-5-3-379  
 CASTO, W. P. 20-4-6-483  
 CHADOT, G. 16-3-5-337  
 CHANTOT, R. 14-1-6-027  
 CHAPMAN, R. H. 17-2-8-208  
 CHAMIA, T. C. 16-3-2-291  
 CHESTER, C. 17-6-1-659  
 CHEVETON, K. 16-1-2-10  
 CHON, W. Y. 19-8-4-473  
 CLACK, R. W. 11-3-6-235  
 CLACK, R. W. 11-1-8-058  
 CLOUTIER, R. J. 11-6-8-475  
 COPMAN, F. E. 16-1-5-60  
 COLLINS, G. Y. 12-2-5-110  
 COLLINS, J. T. 16-1-5-71  
 COLLINS, E. P. 16-4-5-482  
 COLLINS, E. P. 12-1-4-035  
 CORLEY, S. J. 19-1-5-66  
 COTTER, S. J. 20-6-5-72  
 COUPE, F. A. 12-3-1-196  
 COUPE, F. A. 14-5-1-439  
 COTRELL, W. B. 15-1-4-030  
 COTRELL, W. B. 15-2-1-132  
 COTRELL, W. B. 15-3-1-241  
 COTRELL, W. B. 16-1-1-8  
 COTRELL, W. B. 17-2-1-183  
 COTRELL, W. B. 18-2-1-133  
 COTRELL, W. B. 19-3-1-281  
 COTRELL, W. B. 20-1-1-01  
 COTRELL, W. B. 20-3-1-249  
 COTRELL, W. B. 20-4-6-483  
 COTRELL, W. B. 20-5-6-613  
 COUANT, C. C. 12-6-5-600  
 COUANT, C. C. 18-3-5-328  
 CROMBERG, A. W. 16-6-2-683  
 CROLEY, J. L. 16-2-6-224  
 CROLEY, J. L. 15-5-1-519  
 CUDRIS, R. A. 17-2-2-185  
 CULBERT, W. H. 14-4-6-356  
 CULBERT, W. H. 14-6-6-660  
 CUMMINGS, R. B. 13-3-5-225  
 CUMMINGS, G. E. 19-5-3-690  
 CYBULSKIS, P. 19-2-4-190  
 DANWER, H. B. 18-5-2-446  
 DAU, G. J. 17-1-3-23  
 DAVIS, J. P. 14-1-1-006  
 DAVIS, J. P. 14-3-1-165  
 DAVIS, J. P. 15-3-1-262  
 DAVIS, J. P. 16-8-1-821  
 DAVIS, J. P. 20-4-6-668  
 DAVIS, B. J. 11-4-4-315  
 DAYEN, M. J. 18-3-6-365  
 DE LAGUNA, W. 11-5-4-291  
 DEARLEN, J. A. 19-5-2-565  
 DECKER, T. R. 19-5-6-628  
 DECKER, T. R. 20-8-6-676  
 DEKAIS, J. J. 16-2-3-150  
 DELCOIN, G. 20-6-1-655  
 DEBAM, D. B. 17-3-5-344  
 DEFORE, P. T. 15-2-5-185  
 DICKERMAN, C. S. 11-3-2-195  
 DICKERMAN, C. E. 14-5-2-452  
 DICKSON, H. H. 17-3-1-241  
 DICKSON, H. H. 16-5-5-220  
 DICKSON, H. H. 18-4-5-82  
 DIALOVO, R. 20-6-3-690  
 DICHO, S. J. 12-3-3-226  
 DOAN, P. L. 11-4-2-394



COAN, P. L.	14-4-2-291	HAGEN, E. W.	16-5-3-557
DOAN, P. L.	15-5-1-519	HAGEN, E. W.	17-1-3-43
DUGGINS, B. C.	11-6-3-468	HAGEN, E. W.	17-6-3-686
DUGGINS, B. C.	13-5-3-366	HAGEN, E. W.	18-4-3-469
DUMA, D. W.	14-4-3-315	HAGEN, E. W.	19-1-3-38
DUNAWAY, P. B.	11-1-5-043	HAGEN, E. W.	19-3-3-330
EADS, B. G.	13-5-3-366	HAGEN, E. W.	20-2-3-166
EAGLES, J. D.	20-4-5-446	HAGEN, E. W.	20-4-3-422
EASON, C. F.	14-3-5-220	HALL, V. S.	16-6-3-701
EASON, C. F.	15-5-5-585	HAMSTRA, J.	16-2-4-190
EASTERLY, C. E.	18-2-5-203	HANNA, S. R.	12-2-5-114
ECKHOFF, W. D.	11-3-6-235	HANNA, S. R.	15-2-5-190
ECKHOFF, W. D.	13-1-5-054	HARE, M. G.	16-5-6-603
EDISON, G. E.	19-6-3-712	HARE, M. G.	17-2-6-231
EICHHOLZ, G. G.	17-5-1-525	HARE, M. G.	18-3-6-355
EICHHOLZ, G. G.	19-4-5-486	HARLEY, P. H.	13-1-5-047
EISENHOD, M.	12-1-1-001	HART, J. C.	11-1-5-039
ELIAS, E.	19-2-2-160	HART, J. C.	14-4-5-340
ELWOOD, J. W.	12-4-4-326	HAYDEN, K. C.	17-6-3-686
EPLER, E. P.	11-4-6-323	HEDDLERSON, F. A.	14-6-1-576
EPLER, E. P.	12-3-3-226	HESS, D. N.	12-4-1-283
EPLER, E. P.	14-2-3-095	HIGGINBOTHAM, L. B.	16-1-5-71
ERDMAN, C. A.	16-1-4-43	HILL, R. M.	15-6-1-665
ERDMAN, C. A.	16-3-4-318	HILLIARD, R. K.	15-2-2-146
ERDMANN, R. C.	11-6-4-482	HINSON, C. S.	17-5-6-622
ERDMANN, R. C.	13-1-2-022	HOBSON, D. U.	16-1-1-8
ERICSON, L.	18-4-4-481	HOCKENBURY, R. W.	20-3-4-308
ESTREICH, P. J.	14-6-4-634	HOFFMAN, F. O.	18-3-5-343
EYMAN, L. D.	20-2-6-206	HOFFMAN, F. O.	20-4-5-458
FABIC, S.	17-6-2-671	HOLCOMB, W. P.	19-1-5-50
FARNER, F. R.	11-4-1-283	HOLM, J. S.	18-5-2-596
FAUSKE, H. K.	16-3-2-291	HOSNER, R. P., JR.	15-3-5-306
FAUSKE, H. K.	16-4-2-436	HOWARD, R. S.	14-6-3-605
FAUSKE, H. K.	17-5-2-550	HULL, A. P.	12-3-1-185
FERGUSON, B. L.	15-3-3-292	HUNT, D. C.	12-2-2-85
FETV PROJECT PERSONNEL	14-2-1-079	HUNT, D. C.	12-3-2-203
FIELDS, D. E.	20-6-5-722	INTERAGENCY REVIEW GROUP	20-6-4-706
FIRST, M. W.	13-1-4-037	JABLON, S.	14-6-5-651
FIRST, M. W.	14-2-4-111	JACOBS, D. G.	19-1-5-60
FIRST, M. W.	16-2-4-190	JAMES, L. A.	18-6-4-791
FIRST, M. W.	18-2-4-174	JENKINS, J. D.	19-4-1-427
FIRST, M. W.	20-1-4-63	JENKINS, T. M.	11-6-1-435
FISCHER, A.	19-2-2-176	JOBST, J. E.	20-2-1-136
FONTANA, M. H.	16-2-1-141	JOHNSON, C. G.	11-2-6-142
FONTANA, M. H.	17-1-2-19	JOHNSON, J. P.	19-2-1-135
FONTANA, M. H.	18-4-2-451	JOHNSON, L. A.	19-6-6-760
FRAAS, A. P.	13-5-1-353	JOHNSON, W. V.	19-5-2-565
FRANK P. LEES	16-3-3-316	JOKSIMOVIC, V.	18-6-2-761
FREIBURG, L. C.	14-5-1-409	JOLLY, M. E.	18-5-3-624
FRENCH, C.	16-3-5-337	JORGENSEN, B. L.	16-2-5-204
FRY, D. W.	13-4-3-295	JOSEPH, J. W., JR.	14-4-6-362
FUSSELL, J. B.	20-5-2-541	JOSLIN, W. M.	12-3-3-217
GALLAGHER, G. E.	12-6-6-608	JUST, J. E.	18-2-1-127
GALLAGHER, H. B.	20-1-6-83	KAHN, B.	20-2-5-190
GALPIN, F. L.	16-6-1-667	KANE, W. F.	20-3-1-258
GARRICK, B. J.	20-6-3-690	KAPLAN, S.	20-6-3-690
GARTEN, C. T., JR.	18-3-5-343	KAPLAN, S. I.	12-5-1-438
GARTSIDE, C. H.	19-3-4-339	KARNER, D. B.	18-5-3-617
GAULT, J. D.	14-5-2-446	KEILHOLTZ, G. W.	12-6-4-591
GEORGE, J. A.	17-6-4-710	KEILHOLTZ, G. W.	17-3-1-289
GERSTNER, M. T.	19-6-3-712	KELBER, C. W.	14-4-2-304
GIFFORD, P. A.	17-1-5-68	KELLY, J. L.	16-1-4-318
GIFFORD, P. A., JR.	12-2-1-75	KELSEY, C. A.	19-6-5-741
GIFFORD, P. A., JR.	13-5-5-391	KEBLIN, T. W.	15-1-3-015
GILMORE, C. E.	11-5-1-369	KIBBEY, A. H.	16-4-4-458
GODBEE, H. W.	16-4-4-458	KIBBEY, A. H.	16-5-4-581
GODBEE, H. W.	16-5-4-581	KILLOUGH, G. G.	19-5-5-602
GODDET, J. L.	19-3-6-369	KLEIN, S. M.	17-6-4-701
GOLDIN, A. S.	13-4-1-275	KNOX, J. H.	13-2-5-130
GOLDSMITH, W. A.	17-6-5-722	KNUTH, D. P.	18-5-1-581
GONZALEZ, W. R.	18-6-3-774	KOUTS, H. J. C.	15-2-1-127
GOODRICH, W. H.	15-4-1-383	KNARE, A.	16-2-3-150
GOODWIN, A.	14-6-5-643	KRAKER, P.	11-6-5-493
GRAHAM, J.	16-5-4-564	KUPFER, K.	18-5-6-664
GRAY, L. W.	15-4-6-455	KUPFER, K.	18-5-6-666
GRAY, L. W.	19-1-6-91	LAGUARDIA, T. S.	20-1-1-15
GREEN, A. E.	15-2-3-154	LANBERT, H. E.	19-5-3-590
GREENFIELD, N. A.	14-4-1-267	LANGER, B. P.	17-1-4-55
GRIFFITH, J. D.	18-1-2-45	LANGHAAR, J. W.	12-6-1-553
GRIFFITH, P.	18-3-2-298	LANGHAAR, J. W.	14-6-2-597
GROLMES, H. A.	16-6-2-683	LANGSTON, M. E.	12-6-1-549
GROOS, E.	13-3-3-220	LANNING, D. D.	14-4-2-201
HABIP, L. M.	13-2-2-107	LAUTZENREISER, C. E.	17-6-6-731
HAGA, P. B.	11-3-4-215	LAVE, L. B.	14-5-1-409
HAGEN, E. W.	12-4-3-310	LAWROSKI, S.	20-4-1-387
HAGEN, E. W.	12-5-4-499	LEACH, L. P.	19-1-4-43
HAGEN, E. W.	13-1-3-029	LEAVY, J. E. W.	19-3-2-316
HAGEN, E. W.	13-5-3-366	LEDoux, J. C.	19-6-1-671
HAGEN, E. W.	14-3-3-206	LENNEMANN, W. L.	14-5-5-482
HAGEN, E. W.	15-1-3-015	LENOX, D. H.	19-3-4-339
HAGEN, H. W.	15-4-3-417	LEONARDINI, L.	11-4-3-309
HAGEN, H. W.	16-2-3-162	LEPKOWSKI, H. J.	18-3-2-298

LEVINE, SAUL	19-5-1-556	NATIONAL ACADEMY OF SCIENCES	20-4-4-434
LEWIN, J.	18-4-1-438	NATIONAL ACADEMY OF SCIENCES	20-6-1-664
LINDACKERS, K-H	14-1-2-014	NEIDER, R. J. A.	14-3-1-181
LIPARULO, N. J.	17-6-4-710	NELSON, D. J.	11-1-5-043
LISSE, C. S.	13-5-3-366	NELSON, W. E.	18-4-1-427
LITTLE, J. W., JR.	14-4-6-362	NEPHEW, E. A.	11-6-2-463
LOEWENSTEIN, W. B.	16-6-1-659	NERO, A. V., JR.	20-3-3-280
LOGAN, K. W.	18-5-2-446	NICHOLS, B. L.	13-3-1-209
LONG, J. A.	18-3-1-281	NICHOLS, B. L.	15-6-1-665
LOYALKA, S. K.	17-4-3-437	NRC RISK ASSESSMENT REVIEW GR.	20-1-1-24
LOYALKA, S. K.	18-4-1-427	NUCLEAR SAFETY EDITORIAL STAFF	13-3-0-181
LUMMERZHEIN, D.	18-6-1-727	NUCLEAR SAFETY STAFF	15-1-1-001
LUTZ, H. R.	18-5-6-666	NUCLEAR SAFETY STAFF	15-1-5-056
LYERLY, R. L.	11-2-1-107	NUCLEAR SAFETY STAFF	15-1-6-076
LYMAN, V. G.	11-3-4-215	NUCLEAR SAFETY STAFF	15-2-4-173
MACDONALD, P. E.	19-4-2-440	NUCLEAR SAFETY STAFF	15-3-6-311
MAJOR, A.	16-3-5-337	NUCLEAR SAFETY STAFF	15-3-6-316
MALARO, J. C.	19-3-5-356	NUCLEAR SAFETY STAFF	15-5-1-513
MANGAN, D. L.	20-1-3-44	NUCLEAR SAFETY STAFF	15-5-6-599
MANN, S.	12-3-4-234	NUCLEAR SAFETY STAFF	15-6-1-673
MANZ, G. W.	18-2-6-223	NUCLEAR SAFETY STAFF	15-6-6-738
MARINO, G. P.	19-5-2-588	NUCLEAR SAFETY STAFF	16-2-6-223
MARRONE, J.	12-4-1-291	NUCLEAR SAFETY STAFF	16-5-6-614
MARRONE, J.	16-5-1-537	NUCLEAR SAFETY STAFF	16-6-6-734
MARTINSON, Z. R.	19-4-2-440	NUCLEAR SAFETY STAFF	17-1-1-15
MATHER, D. J.	14-3-2-201	NUCLEAR SAFETY STAFF	17-2-1-171
MATTHIENSEN, R. B.	13-2-2-114	NUCLEAR SAFETY STAFF	17-4-6-475
MATTICE, J. S.	18-6-5-802	NUCLEAR SAFETY STAFF	18-1-3-53
MATTINGLY, T. J., JR.	17-5-1-539	NUCLEAR SAFETY STAFF	18-1-6-79
MAURO, J. J.	20-5-1-525	NUCLEAR SAFETY STAFF	18-2-5-215
MAYBER, W. W.	20-3-4-294	NUCLEAR SAFETY STAFF	18-3-1-291
MAYS, G. T.	19-3-1-269	NUCLEAR SAFETY STAFF	18-3-6-370
MAYS, G. T.	20-1-6-78	NUCLEAR SAFETY STAFF	18-4-6-513
MCBRIDE, J. P.	19-4-5-497	NUCLEAR SAFETY STAFF	18-6-1-75L
MCCARDLELL, R. K.	19-4-2-440	NUCLEAR SAFETY STAFF	19-4-1-433
MCCARTHY, J. D.	15-5-4-572	NUCLEAR SAFETY STAFF	19-5-1-541
MCCARTHY, J. D.	15-6-4-723	NUCLEAR SAFETY STAFF	19-5-5-617
MCCLAINE, W. C.	11-2-5-130	NUCLEAR SAFETY STAFF	19-6-5-732
MCCLEUNG, R. W.	18-4-3-469	NUCLEAR SAFETY STAFF	20-1-4-54
MCCORD, R. V.	12-6-6-615	NUCLEAR SAFETY STAFF	20-3-5-330
MCCRATH, D. R.	15-5-1-519	NUCLEAR SAFETY STAFF	20-6-6-735
MCCULLOUGH, C. R.	11-2-1-107	O'DONNELL, E. P.	20-5-1-525
MCDONALD, J. R.	15-4-4-432	OAKES, L. C.	11-2-3-115
MCDONNELL-BOYER, L. M.	20-6-5-722	OAKES, L. C.	14-2-3-095
MCEWEN, J. E., JR.	18-5-1-581	OAKES, T. W.	18-4-5-492
MCGLOTHLAN, C. K.	17-1-6-87	OBRIEN, H. G.	11-3-3-206
MCGUFFEY, J. R.	13-2-1-099	OEHLBERG, E. N.	19-5-2-565
MCLEAN, W. B.	20-5-5-592	OKRENT, D.	20-2-2-148
MCPHERSON, G. D.	18-3-2-306	ORPHAN, R. C.	17-3-1-281
MEGY, J. M. P.	19-3-6-369	ORTEGA, O. J.	11-2-6-142
MEHNER, A. S.	19-4-2-440	OSBORNE, N. F.	19-2-2-176
MERTA, D. S.	18-2-4-189	OSGOOD, H. W.	18-2-4-189
MERTA, K. C.	15-4-4-432	OTWAY, H. J.	11-6-4-482
MELEIS, M.	13-1-2-022	PACK, R. W.	18-6-3-774
MELETS, M.	16-4-2-443	PALNER, J. F.	14-5-1-429
MENNELY, D. A.	11-4-2-289	PALMS, J. M.	16-5-5-593
MERKLE, J. G.	17-4-4-447	PALMS, J. M.	17-5-5-580
METTLER, F. A., JR.	19-6-5-741	PARKER, P. L.	20-2-6-206
MEYER, H. R.	20-3-5-319	PARSONS, S. O.	18-6-3-774
MEYER, R. O.	19-6-2-699	PARSYCK, D. C.	16-6-5-720
MEYER, W.	18-4-1-427	PASCIAK, W. J.	18-3-6-365
MILES, M. E.	20-3-6-345	PATHANIA, R. S.	19-6-6-744
MILES, M. E.	20-4-5-446	PATHANIA, R. S.	20-5-6-595
MILLER, C. E., JR.	11-1-1-001	PATRICK, C. H.	18-5-5-647
MILLER, C. W.	16-3-5-343	PEARSON, J. F.	18-3-2-299
MILLER, C. W.	20-4-5-458	PELLE, E.	16-3-1-273
MILLER, D.	11-6-2-450	PELLETIER, C. A.	12-5-6-530
MILLER, J. M.	16-1-6-76	PETERSON, H. T., JR.	16-6-1-667
MINDER, J. E.	15-4-4-432	PETERSON, K. R.	13-2-5-130
MOELLEN, D. W.	11-1-5-039	PETIT, J.	14-1-6-027
MOELLER, D. W.	12-2-4-100	PIGNATELLI, R.	16-2-3-150
MOELLER, D. W.	13-4-1-275	PIPE CRACK STUDY GROUP	20-6-6-729
MOELLER, D. W.	14-2-4-111	PIPER, H. B.	14-6-1-576
MOELLER, D. W.	16-2-4-190	PIPER, H. B.	19-3-2-316
MOELLER, D. W.	16-4-4-469	POSTON, J. W.	14-4-5-340
MOELLER, D. W.	17-1-1-1	PRIOR, W. A.	14-4-1-274
MOELLER, D. W.	18-2-4-174	PRIOR, W. A.	16-1-6-79
MOELLER, D. W.	18-5-4-633	QUAPP, W. J.	19-4-2-440
MOELLER, D. W.	19-1-5-66	RANDLES, J.	13-6-1-451
MOELLER, D. W.	20-1-4-63	RANDOLPH, H. L.	20-6-5-722
MOELLER, D. W.	20-2-4-176	RANKIN, J. P.	14-5-3-461
MOELLER, D. W.	20-4-1-387	RASMUSSEN, W. C.	14-4-2-291
MOFFETTE, T. R.	14-6-4-618	RASMUSSEN, W. C.	15-4-1-375
MOORE, J. B.	11-3-1-185	RASMUSSEN, W. C.	12-2-1-83
MOORE, J. S.	12-3-3-217	RADDENBUSH, W. H.	14-1-3-021
MOORE, R. E.	19-4-5-497	REBOY, R. P.	11-2-4-119
MORGAN, J. G.	13-3-1-216	REHFUSS, C.	19-5-1-671
MORRIS, D. I.	15-6-3-691	REICHEL, D. E.	11-1-5-043
MORSE, L. E.	20-3-5-319	REISCH, F.	19-6-3-723
MURPHY, T. D.	17-5-6-622	REYNOLDS, A. B.	16-1-4-43
MURPHY, T. D.	18-3-6-365	REYNOLDS, A. B.	16-3-4-318
NAGLE, C. M.	11-1-5-034	RHOADS, R. W.	18-3-3-317

RHOADS, R. E.	19-2-1-135	STEVENS-GUILLE, P. D.	16-3-6-350
RHODE, G. K.	13-1-3-029	STEVENS LLE, P. D.	16-5-6-603
RICHMOND, C. R.	17-4-5-464	STOBEL, W.	14-1-2-014
RINGOTT, C.	19-4-1-411	STONE, R. S.	11-1-3-020
RITCHIE, L. T.	19-2-5-220	STRYKNESS, E. G.	20-2-6-206
RITTEHOUSE, P. L.	12-5-3-487	SULOFF, M. D.	15-4-3-417
RITTIG, D.	18-6-1-727	SWAN, S. W.	16-4-2-443
RIVARD, J. B.	12-4-2-305	SWISHER, S. D.	12-2-5-114
ROBINSON, G. C., JR.	15-4-4-423	SZAWLEWICZ, S. A.	18-5-1-589
ROBINSON, R. A.	15-4-6-460	TADROS, J.	14-4-5-325
ROBINSON, T. G.	11-6-3-468	TAN, C. P.	11-1-4-025
ROHNER, P. S.	12-4-5-338	TATONE, O. S.	19-6-6-748
ROHNER, P. S.	13-3-5-225	TATONE, O. S.	20-5-6-595
ROHNER, P. S.	15-6-5-732	TAYLOR, P. G., JR.	15-5-5-592
ROHNER, P. S.	16-6-5-720	TEAGUE, H. J.	14-3-2-201
ROHNER, P. S.	17-2-5-216	TENNERY, V. J.	20-3-5-319
ROSE, D.	11-1-1-001	TERPILAK, M. S.	16-2-5-204
ROSE, D.	12-5-1-421	TESSIER, J. H.	19-3-4-339
ROSEN, M.	20-2-1-123	THADANI, A. C.	20-4-3-422
ROTH, D. R.	17-1-6-92	THIE, J. A.	14-2-3-105
ROTH, R. E.	15-3-4-295	THIE, J. A.	16-3-3-308
ROW, T. H.	11-3-4-223	THOMPSON, D.	15-2-6-198
ROW, T. H.	11-4-4-315	THOMPSON, D. H.	19-3-4-339
ROW, T. H.	12-5-5-516	TILL, J. E.	19-5-5-602
ROWE, W. D.	16-6-1-667	TILL, J. E.	20-3-5-319
RODEL, P.	12-5-4-496	TINKLER, C. G.	17-6-4-710
RUSS, J. C.	12-3-3-217	TOBIAS, M.	14-2-2-091
RYAN, R. G.	19-1-1-1	TOBIAS, M.	16-5-2-546
SANDIA STAPP	17-6-1-565	TONG, L. S.	18-1-1-1
SAVOLAINEN, A. W.	16-4-1-415	TONG, L. S.	19-3-1-292
SAKE, R. F.	14-4-3-315	TRABALKA, J. R.	20-2-6-206
SCHALLOPP, B.	15-4-3-409	TRAVIS, C. C.	20-6-5-722
SCHENK, K.	18-5-6-666	TURNER, J. E.	16-6-5-720
SCHLECHTENDAHL, E. G.	20-5-2-551	TURNER, S. E.	11-2-1-107
SCHULTE, N. A.	14-6-3-605	TUXEN-NEYSER, H.	15-6-3-702
SCHUSKE, C. L.	15-5-4-572	UCHIDA, H.	11-1-2-012
SCHUSKE, C. L.	15-6-4-723	UNDERHILL, D. W.	13-6-4-478
SCOTT, R. L.	13-1-5-047	UNDERHILL, D. W.	16-2-4-190
SCOTT, R. L.	15-1-6-067	UNDERHILL, D. W.	14-2-4-174
SCOTT, R. L.	17-5-6-592	UNDERHILL, D. W.	20-1-4-63
SCOTT, R. L.	20-1-6-83	UNGER, W. E.	12-3-4-234
SCOTT, R. L.	20-2-6-210	VAN DER HOVEN, I.	17-2-5-223
SCOTT, R. L., JR.	12-2-6-123	VAN ERP, J. B.	16-3-2-291
SCOTT, R. L., JR.	12-2-6-134	VANDEBERG, S. P.	13-2-4-122
SCOTT, R. L., JR.	14-5-6-507	VELOPI, V. R.	16-5-5-593
SEAGREN, R. D.	13-2-1-103	VELURI, V. R.	17-5-5-580
SEIPEL, H. G.	18-6-1-727	VESELY, W. E.	20-3-4-308
SELBY, J. M.	17-1-1-1	VIEDER, G.	16-2-3-150
SELBY, J. M.	19-1-5-66	VISSING, G. S.	16-2-6-224
SEMINANA, J. L.	18-6-3-774	VOGLEWEDE, J. C.	19-6-2-699
SHAEPFEL, D. L.	18-3-5-343	WADE, G. E.	15-2-4-163
SHANK, K. E.	18-2-5-203	WADE, L. JP.	13-4-6-304
SHANK, K. E.	18-4-5-492	WAITE, D. A.	17-3-5-344
SHAPPERT, L. B.	14-6-2-597	WAITE, D. A.	19-1-5-66
SHAY, H. R.	18-5-2-596	WALKER, C. S.	11-3-3-206
SHOUP, R. L.	18-2-5-203	WALKER, C. S.	11-5-2-375
SHOUP, R. L.	18-4-5-502	WALL, I. B.	15-3-2-276
SHUKER, W. A.	12-6-2-569	WALL, I. B.	15-4-2-399
SIDERIS, A. G.	20-3-4-308	WARD, K.	16-3-5-337
SINWELL, I. S.	13-5-4-373	WATSON, A. P.	20-6-5-722
SILADY, P. A.	18-6-2-761	WAYLAND, J. H.	19-2-5-220
SIMPSON, D. R.	14-5-4-470	WEERMS, S. J.	11-3-4-215
SINS, J. E.	11-2-4-119	WELLS, J. E.	19-5-3-590
SINGER, I. A.	11-1-5-034	WEBNER, R. A.	17-4-3-437
SISLER, J. A.	14-6-2-597	WESSMAN, G. L.	14-6-4-618
SJOBLOM, G. L.	20-4-5-446	WHITMAN, G. D.	12-5-5-523
SKRABLE, K.	16-3-5-337	WHITMAN, G. D.	16-1-1-8
SLATER, H. G.	12-5-2-448	WHITMAN, G. D.	17-4-4-447
SLAUGHTERBECK, D. C.	18-4-4-481	WILCOX, W. H.	17-2-5-216
SLINN, W. G. M.	19-2-5-205	WILLIAMS, R. W.	18-4-1-427
SMALLEY, W. L.	16-3-5-345	WILSON, I.	20-5-3-564
SMEETS, J. G. P. M.	13-5-5-380	WILSON, R. E.	16-3-2-291
SMEETS, H. B.	13-4-2-287	WINTON, M. L.	12-5-3-461
SMITH, C. B.	13-2-2-114	WINTON, M. L.	15-5-2-535
SMITH, C. B.	14-6-2-586	WITHERSPOON, J. P.	17-3-5-351
SNEDEKER, J. T.	11-6-1-445	WITHERSPOON, J. P.	14-4-5-497
SNYDER, W. S.	15-4-5-440	WITT, F. J.	12-5-5-523
SOLBRIG, C. W.	17-2-2-194	WOOD, P. J.	19-3-2-316
SOLBRIG, C. W.	17-3-2-299	WREATHALL, J.	18-5-3-624
SOLBRIG, C. W.	17-4-2-422	YADIGAROGLU, G.	15-6-1-651
SOMNERS, J. P.	16-4-3-452	YADIGAROGLU, G.	19-1-1-20
SOZZI, G. L.	20-1-2-27	YADIGAROGLU, G.	19-2-2-160
SPANNER, J. C.	18-4-3-469	YALCINTAS, M. G.	20-3-5-319
SPANO, A. H.	18-5-1-589	YANURA, T.	11-1-2-012
SPINRAD, B. I.	18-5-2-596	YBARRODO, L. J.	15-6-2-676
ST. DENIS, W. Y.	15-5-5-585	YBARRODO, L. J.	19-1-4-43
STACHURA, S. J.	14-1-6-027	YEATER, M. L.	20-3-4-308
STAHLKOPP, K. E.	17-1-3-33	YEATES, D. B.	13-4-1-275
STARR, C.	14-4-1-267	ZIEMER, P. L.	13-6-5-482
STERLE, L. E.	17-3-4-327	ZITTEL, H. E.	13-6-2-459
STEINER, D.	13-5-1-353		

NUREG/CR-1417  
 ORNL/NUREG/NSIC-175  
 Dist. Category AE

## INTERNAL DISTRIBUTION

- |                     |   |
|---------------------|---|
| 1. J. R. Buchanan   | 16. F. R. Mynatt  |
| 2. C. A. Burchsted  | 17. D. S. Queener   |
| 3. W. R. Casto      | 18. J. L. Rich  |
| 4. R. O. Chester    | 19. R. L. Scott   |
| 5. W. B. Cottrell   | 20. S. D. Swisher   |
| 6. A. B. Crawford   | 21. H. E. Trammell  |
| 7. M. H. Fontana    | 22. D. B. Trauger   |
| 8. R. B. Gallaher   | 23-24. Central Research Library                           |
| 9. C. T. Garten     | 25. Y-12 Document Reference<br>Section (DRS)              |
| 10. P. M. Haas      | 26. Laboratory Records Department<br>Record Copy (LRD-RC) |
| 11. E. W. Hagen     | 27-46. Nuclear Safety Information<br>Center (NSIC)        |
| 12. J. A. Haried    | 47-48. Laboratory Records Department                      |
| 13. F. A. Heddleson |   |
| 14. W. H. Jordan    |   |
| 15. G. T. Mays      |   |

## EXTERNAL DISTRIBUTION

49. Office of Assistant Manager, Energy Research and Development,  
Oak Ridge Operations Office, Oak Ridge, TN 37830
50. E. L. Zebroski, Nuclear Safety Analysis Center, Electric Power  
Research Institute, Palo Alto, CA 94303
- 51-52. DOE Technical Information Center, P.O. Box 62, Oak Ridge, TN  
37830
- 53-386. Given distribution as shown in Category AE (10-NTIS)

NUCLEAR SAFETY

A BIMONTHLY REVIEW JOURNAL PREPARED BY NSIC

*Nuclear Safety* covers significant developments in the field of nuclear safety.

The scope is limited to topics relevant to the analysis and control of hazards associated with nuclear reactors, operations involving fissionable materials, and the products of nuclear fission.

Primary emphasis is on safety in reactor design, construction, and operation; however, safety considerations in reactor fuel fabrication, spent-fuel processing, nuclear waste disposal, handling of radioisotopes, and related operations are also treated.

Qualified authors are invited to submit interpretive review articles, which will be reviewed for technical accuracy and pertinency. Authors will be advised as soon as possible of acceptance or suggested changes. Send inquiries or 3 copies of manuscripts (with the draftsman's original line drawing plus 2 copies, and with continuous-tone glossy prints of photographs plus 2 copies) to Wm. B. Cottrell, Oak Ridge National Laboratory, P.O. Box Y, Oak Ridge, Tennessee 37830.

*Nuclear Safety* is prepared by the Nuclear Safety Information Center at Oak Ridge National Laboratory for the U.S. Nuclear Regulatory Commission and the U.S. Department of Energy. For subscriptions, address Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. The subscription rate is \$14.00 per year. Below is an order blank for your convenience.

U.S. GOVERNMENT PRINTING OFFICE  
DIVISION OF PUBLIC DOCUMENTS  
WASHINGTON, D.C. 20402

OFFICIAL BUSINESS

RETURN AFTER 5 DAYS

POSTAGE AND FEES PAID  
U.S. GOVERNMENT PRINTING OFFICE

Name \_\_\_\_\_  
Street \_\_\_\_\_  
City \_\_\_\_\_ State \_\_\_\_\_ ZIP \_\_\_\_\_

To Ensure Prompt, Accurate Shipment, Please Print or Type Address on Mailing Label Above

MAIL ORDER FORM TO:

Superintendent of Documents, U.S. Government Printing Office, Washington, D.C., 20402

Enclosed find \$ \_\_\_\_\_ (check, money order, or Superintendent of Documents coupons).

Please send me \_\_\_\_\_ subscriptions to *Nuclear Safety* at  
\$14.00 per subscription. (Single issues are sold at \$2.40 per issue.)

Please charge this order to my Deposit Account No. \_\_\_\_\_  
Name \_\_\_\_\_  
Street \_\_\_\_\_  
City \_\_\_\_\_ State \_\_\_\_\_ ZIP \_\_\_\_\_

FOR USE OF SUPT. DOCS.

\_\_\_ Enclosed \_\_\_  
\_\_\_ To be mailed \_\_\_  
\_\_\_ later \_\_\_  
\_\_\_ Subscription \_\_\_  
\_\_\_ Refund \_\_\_  
\_\_\_ Coupon refund \_\_\_  
\_\_\_ Postage \_\_\_

POSTAGE AND REMITTANCE: Postpaid within the United States, Canada, Mexico, and all Central and South American countries except Argentina, Brazil, Guyana, French Guiana, Surinam, and British Honduras. For these and all other countries, add \$3.50 for each annual subscription; for a single issue, add one-fourth of the single-issue price. Payment should be by check, money order, or document coupons, and MUST accompany order. Remittances from foreign countries should be made by international money order or draft on an American bank payable to the Superintendent of Documents or by UNESCO book coupons.

AVAILABILITY OF NSIC DOCUMENTS (Continued)

ORNL/ NSIC	Title	Price*
142	Reports Distributed Under the NRC Light-Water Reactor Safety Technical Exchange, Vol. III (Jan.-June 1977), D. S. Sharp and Wm. B. Cottrell, Oct. 1977	\$ 4.00
143	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research - Jan.-June 1977, J. R. Buchanan, Oct. 1977	\$ 3.50
144	Reactor Operating Experiences 1975-1977, U.S. Nuclear Regulatory Commission	
145	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research - July-Dec. 1977, J. R. Buchanan	
146	Reports Distributed in 1977 Under the NRC Light-Water Reactor Safety Technical Exchange, Wm. B. Cottrell and D. S. Sharp	
147	Index to Nuclear Safety, A Technical Progress Review by Chronology, Permuted Title, and Author, Vol. II, No. 1 Through Vol. 18, No. 6, Wm. B. Cottrell and Ann Klein	
148	Common-Mode/Common-Cause Failure: A Review and Bibliography, E. W. Hagen, May 1979	\$11.00
149	Annotated Bibliography of Licensee Event Reports in Boiling-Water Nuclear Power Plants as Reported in 1977, R. L. Scott and R. B. Gallaher, November 1978	\$ 7.50
150	Annotated Bibliography of Licensee Event Reports in Pressurized-Water Nuclear Power Plants as Reported in 1977, R. L. Scott and R. B. Gallaher, November 1978	\$ 7.50
151	Breeder Reactor Safety: Review of Current Issues and Bibliography of Literature 1977, J. R. Buchanan and G. W. Keilholtz, September 1978	\$ 8.00
154	Bibliography of Microfiche Foreign Reports Distributed Under the NRC Reactor Safety Research Foreign Technical Exchange Program, 1975-1977, D. S. Queener, January 1979	\$ 8.00
155	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, January-June 1978, J. R. Buchanan, November 1978	\$ 7.25
156	Reports Distributed Under the NRC Reactor Safety Research Foreign Technical Exchange Program, Vol. V (January-June 1978), D. S. Queener and Wm. B. Cottrell, November 1978	\$ 8.00
157	Analytical Techniques for Stress Analysis of the Nuclear Steam Supply-System, A Bibliography, F. A. Heddleson, May 1979	\$13.00
158	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, July-December 1978, J. R. Buchanan, May 1979	\$ 6.50
159	Reports Distributed Under the NRC Reactor Safety Research Foreign Technical Exchange Program, Vol. VI (July-December 1978), D. S. Queener, May 1979	\$ 8.00
160	Annotated Bibliography on the Safeguards Against Proliferation of Nuclear Materials, E. D. Blakeman, March 1980	\$10.00
161	Nuclear Power and Radiation in Perspective -- Revised, J. R. Buchanan	
162	Index to Nuclear Safety, A Technical Progress Review by Chronology, Permuted Title, and Author, Vol. II, No. 1 through Vol. 19, No. 6, Wm. B. Cottrell and Margaret Passiakos, May 1979	\$10.00
163	Bibliography of Microfiche Foreign Reports Distributed Under the NRC Reactor Safety Research Foreign Technical Exchange, 1978, D. S. Queener, August 1979	\$10.00
164	Summary and Bibliography of Safety-Related Events at Boiling-Water Nuclear Power Plants as Reported in 1978, R. L. Scott and R. B. Gallaher, September 1979	\$ 8.50
165	Summary and Bibliography of Safety-Related Events at Pressurized-Water Nuclear Power Plants as Reported in 1978, R. L. Scott and R. B. Gallaher, September 1979	\$ 8.50
166	LMFRS Safety 7. Review of Current Issues and Bibliography of Literature 1978, J. R. Buchanan and G. W. Keilholtz, January 1980	\$ 7.00
169	Bibliography of Reports on Research Sponsored by the NRC Office of Nuclear Regulatory Research, January-June 1979, J. R. Buchanan, February 1980	\$ 9.00
170	Reports Distributed Under the NRC Reactor Safety Research Foreign Technical Exchange Program, Vol. VII (January-June 1979), D. S. Queener, November 1979	\$ 7.00
171	Summary and Bibliography of Operating Experience with Valves in Light-Water-Reactors Nuclear Power Plants 1965-1978, R. L. Scott and R. B. Gallaher, July 1979	\$ 8.50
176	Descriptions of Selected Accidents that Have Occurred at Nuclear Reactor Facilities, R. W. Bertini and Members of the Staff of NSIC, April 1980	\$10.00

\*Due to additional mailing and handling costs, the foreign price per document is double that of the domestic price.

Reports after this date are published as ORNL/NUREG/NSIC reports.