



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TIC

JUL 10 1980

Docket No. 50-546
Docket No. 50-547

Public Service of Indiana
ATTN: Mr. S. W. Shields
Senior Vice President
Nuclear Division
1000 East Main Street
Plainfield, IN 46168

Gentlemen:

Thank you for your interim report dated June 27, 1980, pursuant to 10 CFR 50.55(e) regarding incorrect weld filler used in welding of safety-related pipe spool pieces. We will review your final report on this matter upon receipt.

Your cooperation with us is appreciated.

Sincerely,

G. Fiorelli, Chief
Reactor Construction and
Engineering Support Branch

cc: C. Kammerer, CA
H. Thornburg, IE
Mr. G. N. Brown, Project
Director
Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC
LeBoeuf, Lamb, Leiby & MacRae
Mr. Dave Martin, Office of
Attorney General
Mr. John R. Galloway, Staff
Director, Environment, Energy
and Natural Resources Subcommittee

8007240 319

3