

NSS-3
SPR 533

TITLE Loss of FW Incident (ALL B&W PLANTS)

RELATED SPRs _____

This SFR has been reviewed by Task Engineering Groups and is applicable to _____ . The following
NSS- _____ is the status and/or resolution of this SFR on other contracts.

REMARKS

Action complete. See attached

ACTION COMPLETE
ON ALL CONTRACTS

NSS- _____

7910040552

NSS - 03

SAR 533

LOSS OF FW INCIDENT, 5-18-73

ISOLATED PRESSURE SWITCH ON LOSS OF MAIN
FEED PUMP - NO EMERGENCY FEED PUMP START -

- 1) NSS - 11 - NO PROBLEM
- 2) NSS - 03 - CORRECTED -
- 3) NSS - 09 - 18-00 - 00397 F07
- 4) NSS - 07 - 10-00 - 00279 05
- 5) NSS - 08 - 18-00 - 00017 C 15
- 6) NSS - 05 - 18-00 - 00751 D02
- 7) NSS - 06 - NOT FOUND
- 8) NSS - 07 - 18-00 - 00413 C01
- 9) NSS - 14 - 18-00 - 00157 F12 (162 F11)
- 10) NSS - 12 - 01-001-02 - 5002 N000
- 11) NSS - 13 - 01-001-02 - 5005 N000

THE ABOVE IS A LIST OF AE PRINTS THAT WILL REQUIRE
REVIEW FOR SENSOR LOCATION TO INSURE NON ISOLATION -
I BELIEVE THAT ALL CONTRACTS IN TESTING AROUND
THE TIME OF SAR ORIGINION HAVE SITE CHECKED
AND CORRECTED IF REQUIRED. (CONTRACTS LISTED ABOVE
) HAVE BEEN REVIEWED (AE P&ID DRW.) AND SWITCH/WRITER
LOCATIONS ARE FREE OF CONNE PROBLEM.

F. J. Thibault

4-15-75

SPR CROSS-CONTRACT IMPLEMENTATION

ORIGINATING CONTRACT NSS ³~~533~~ SPR ~~5~~ 533

TITLE: LOSS OF FEED WATER INCIDENT

FOR IMPLEMENTATION ON NSS ALL

TASK ENGINEER

IMPLEMENT RESOLUTION: Yes No

IF YES, PRIORITY: DIRECTLY AFFECTS SYSTEM AND PLANT RELIABILITY
 IMPROVES SYSTEM PERFORMANCE
 COULD POSSIBLY AFFECT SYSTEM AND PLANT RELIABILITY

BRIEF DESCRIPTION OF RESOLUTION:

CHECK SECONDARY PLANT P&ID FOR LOCATION OF TAP, RELOCATE IF NECESSARY

IF NO, REASON FOR NOT IMPLEMENTING:

must see

ART McBRAIDE → TASK ENGINEER'S SIGNATURE

PROJECT MANAGER

IMPLEMENT: Yes No

ESTIMATED DATE FOR IMPLEMENTATION _____

IF NO, REASON FOR NOT IMPLEMENTING:

PROJECT MANAGER'S SIGNATURE

TITLE Loss of Feed Water Flow incident
RELATED SFRs _____

This SFR has been reviewed by Task Engineering Groups and is applicable to
NSS- 04 - D14 . The following
is the status and/or resolution of this SFR on other contracts.

REMARKS

This is a generic problem.
Upon loss of both Fd. pumps with
isolation valves shut there should
be a turbine trip.

NSS-3- Has trip now

Letter sent to all P.M.'s to inform
cust. of this potential problem by
B.A. Kanaski. (He reports all cust. have
been notified).

NSS- 4&9 _____
has trip.

Generically closed
JLB

NSS- 5&6

Per J.D. Phinney Met ED & Jersey
Central has turbine trip

NSS-

7 - Informed Clyde Barksdale
Letter has not been sent yet.
Eric handling A P + L report

NSS-

8 - Letters have been sent to cust.
Taken care of by Fred A. East says problem
not applicable
Lund, Albert

EXTD NOV 1974

NSS-

11 - Per Roger Maggi cust. has
been notified.

NSS-

12 & 13 E. Coppola will revise procedures
via letter from Winks on same problem
from A P + L.

NSS-

14 - Letter has been sent to cust.

Refer to card index for status

NSS 3

PR 533

SPR APPLICABILITY REVIEW

FEB 14 1974

TO: BA Kwasche ←

FROM: D.L. Allison

Please review the attached SPR for applicability to other contracts. This is a general review and is intended to eliminate sending commitments to every task engineer in determining applicability.

Task Engineer's Comments:

Bence, Please return SPR, and include in reply why not or why applicable.

The SPR is applicable to all contracts. Recommendation has already been made to initiate Turbine trip and Emergency Feed on a positive signal indicating loss of main feedwater. Recent letter to RL Pittman on SPR 158 (NSS-4) also re-emphasizes the need to check out Emergency feed system.

Task Engineer: Bef.

Return to: D.L. Allison

Return to ESN

File NSS- 3

TRANSMITTAL SLIP

12M2-SPP- 533

FIELD OPERATIONS SITE PROBLEM REPORT

To _____ for Action

CONTRACT 620-00 -03

SPP 533

TITLE LOSS OF

FW INCIDENT

DATE 6-1-73

To R.J. McConnell - S.O.H. (2) For Information

J. Kaclin

J. Kennedy

J. Plinney

K. Suhrke

Date Reply to be Submitted To
Nuclear Service Support Engineer

Action Requested: Duke has moved the pressure sensing location upstream (Feed Pump discharge) to preclude any possibility of the check valve interfering with pressure decay. The 1" bypass valve has also been opened.

R. Pittman
Nuclear Service Support Engineer

- cc: G. E. Kuljczyk
- E. G. Ward
- T. M. Ellis
- R. T. Schorer
- N. S. Ambrey
- J. McFarland
- C. C. Plunkett - Contract Admin.
- Central Engineering Files
- E. V. DeCarli - Quality Assurance

H. Washam

J. D. Carlton

G. QUALE

MANOUR LIMITS _____

COST LIMITS _____

CHARGE No. _____

APPROVED: _____
Project Manager

OWNER Duke Power Company CONTRACT NO. NSG-3 SPR NO. 533 SPR REV NO. 0

ENDOR P.O. NO. COMP. NO. 22 GROUP NO. 02 SEQ NO. 01

PRIMARY DOCUMENTS: SPEC NOS. PRIORITY
 DWG NO. EQUIP CODE/LEVEL/DATE
 QA LEVEL QA SPEC NO.

SITE ENGINEER ER Richard J.D. Phinney EARLY START DATE ACTUAL START DATE REQ'D COMP. DATE

TITLE (MAX. 30 SPACES) Loss of FW Incident (5/16/73)

DESCRIPTION OF PROBLEM

See attachment.

STATUS-ACTION TO DATE INCLUDING PERSONS CONTACTED, COMMITMENTS MADE, ETC.

1. Conducted ~~at~~ test to establish why the Emergency FW pump did not start.
2. Opened bypass around FW pump discharge valves.

FURTHER ACTION REQUIRED BY OTHER THAN SITE PERSONNEL

Evaluate system transient. (Reactimeter tape sent to Lynchburg.)

RECOMMENDED ACTION

1. Provide positive means of sensing loss of FW pumps to initiate Emergency FW flow and main turbine trip. (CUSTOMER)
2. Evaluate the SEM failure and correct. (CUSTOMER)
3. ADVISE OTHER CONTRACTS OF THIS PROBLEM (N.S)

TITLE	SIGNATURE	DATE	COMMENTS	ACTION
ORIGINATOR	<i>[Signature]</i>	5/18/73	<input type="checkbox"/> Drawings	
SITE CONSTR. REP.	<i>[Signature]</i>	5/18/73	<input type="checkbox"/> Proc. Specs	
SITE OPER. MGR.	<i>[Signature]</i>	5/18/73	<input type="checkbox"/> Instr. Books	
NS SUPPORT ENGR.	<i>[Signature]</i>	5/31/73	<input type="checkbox"/> Operating Procedures	
			<input type="checkbox"/> Tech. Specs	
			<input type="checkbox"/> PSAR/FSAR	
			<input type="checkbox"/> Recommended	
			<input type="checkbox"/> Side Change	
			Field Change Req. <input type="checkbox"/>	
			Field Change No. <u> </u>	

DISTRIBUTION SITE OPS MANAGER PROJECT MANAGER S. SUPPORT ENGR. COGNIZANT ENGR. CONTRACT ADMIN. NPG CA FILE 12M2 <u>NSG 3</u> <u>SPRS 33</u>	Cost Category <input type="checkbox"/> Main <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	Auth. Charge No. <u> </u>
	RESPONSIBILITY ASSIGN. <u>DUKE</u>	Date Completed <u> </u> By: <u> </u>
	OTHER CONTRACTS AFFECTED <u> </u>	DEVIATIONS <input type="checkbox"/> NONE <input type="checkbox"/> SEE REV. <u> </u>

LOSS OF FW INCIDENT (5/16/73)

Description of Problem

At approximately 1540 hrs. the "A" main FW pump tripped due to loss of suction pressure. Sequence of events as follows:

1. Loss of all condensate booster pumps (operator error).
2. Main FW pump trip.
3. Loss of OTSG water inventory.
4. RCS temperature and pressure high.
5. Electromechanical relief valve lifted.
6. Reactor trip on high pressure.
7. Main turbine trip.
8. Emergency FW pump started manually (auto start command not received).


Two automatic actions did not occur. The Emergency FW pump did not start on loss of FW pumps and the main turbine did not trip on loss of FW pumps. The device to initiate these actions is a pressure sensor on the main FW header downstream of the FW pump discharge valves and upstream of the FW line RB penetration check valves. The FW pump discharge valve automatically closed on FW pump trip and isolated the section of FW header that the pressure sensor is located in. The header remained above the 800 psig setpoint which, if reached, would have started the emergency FW pump (Main turbine trip setpoint is 700 psig.) A 1" bypass around the FW pump discharge valves is provided, but the bypass valve was closed.

Analysis of this incident is complicated by the failure of the Sequence of Events Monitor to log real time correctly. At the time of the FW pump trip, an error of +30 minutes occurred.

Attached are system parameter curves produced from reactor data.

JDE/attachment.

FIGURE 1 LOOP (BI) PARAMETER AS A FUNCTION OF TIME 3 MINUTES AFTER REACTOR TRIP



(Loop Param)

TIME (MINUTES)


REACTOR OUTLET PRESSURE

LOOP PARAMETER

REACTOR TEMP

SCALE 5/10 LEVEL

FIGURE 2 LOOP (A) PARAMETERS AS A FUNCTION OF TIME & AIRWAYS ALTITUDE



(% p.p.)

TRANSMITTAL SLIP

FIELD OPERATIONS SITE PROBLEM REPORT

*** CLEARED ***

To R. J. McConnell For Information FILE: 1242
J. D. CARLTON Contract 620-00 -03
G. E. Kulynych - Sr. Project Manager SFR 533
C. C. Plunkett - Contract Admin. TITLE LOSS OF
Central Engineering Files E.W. INCIDENT
E. V. DeCarli - Quality Assurance DATE 8/27/73

The attached, cleared SFR is submitted for your information.

TO: J. N. Kaelin-Arkansas _____
 J. P. Kennedy-SMID _____
 K. E. Suhrke _____
 ~~H. J. Worshaw~~ _____
 J. D. Phinney-Met Ed _____

Attached is one copy of Site Problem Report No. 533 which has been processed on Contract 620-00 -03. Your contract or contracts may have the potential for a similar problem. The Site Problem Report is being forwarded for your information and use to prevent problems from recurring on following contracts. A more complete file on the problem is available in the Nuclear Service area.

REMARKS: OTHER sites are advised of this problem at Ocawee via transmittal of the SFR

cc: G. QUALE

R. L. Pittman
 NUCLEAR SERVICE SUPPORT ENGINEER

LOSS OF FW INCIDENT (5/16/73)

Description of Problem

At approximately 1540 hrs. the "A" main FW pump tripped due to loss of suction pressure. Sequence of events as follows:

1. Loss of all condensate booster pumps (operator error).
2. Main FW pump trip.
3. Loss of OTSG water inventory.
4. RCS temperature and pressure high.
5. Electromatic relief valve lifted.
6. Reactor trip on high pressure.
7. Main turbine trip.
8. Emergency FW pump started manually (auto start command not received).

Two automatic actions did not occur. The Emergency FW pump did not start on loss of FW pumps and the main turbine did not trip on loss of FW pumps. The device to initiate these actions is a pressure sensor on the main FW header downstream of the FW pump discharge valve, and upstream of the FW line RB penetration check valves. The FW pump discharge valve automatically closed on FW pump trip and isolated the section of FW header that the pressure sensor is located in. The header remained above the 600 psig setpoint which, if reached, would have started the emergency FW pump (Main turbine trip setpoint is 700 psig.) A 1" bypass around the FW pump discharge valves is provided, but the bypass valve was closed.

Analysis of this incident is complicated by the failure of the Sequence of Events Monitor to log real time correctly. At the time of the FW pump trip, an error of 30 minutes occurred.

Attached are system parameter curves produced from reactimeter data.

JDP/attachment.

FIGURE (1) LOOP (B) PARAMETER AS A FUNCTION OF TIME 3 MINUTES BEFORE REACTOR TRIP





FIGURE 2. LOOP (A) PARAMETERS AS A FUNCTION OF TIME 3 MINUTES BEFORE REACTOR TRIP



File NSS- 3
12M2-SPR- 533

TRANSMITTAL SLIP

FIELD OPERATIONS SITE PROBLEM REPORT

To _____ For Action

CONTRACT 620-00 -03

SPR 533

TITLE LOSS OF

To R.J. McConnell - S.O.H. (2) For Information

FW INCIDENT

J. Kaclin

DATE 6-1-73

J. Kennedy

Date Reply to Be Submitted To
Nuclear Service Support Engineer

J. Phinney

K. Subrke

Action Requested: DUKE has moved the pressure sensing location upstream (Foot Pump discharge) to preclude any possibility of the check valve interfering with pressure decay. The 1" bypass valve has also been opened.

- cc: G. E. Kulynych
- E. G. Ward
- G. M. Olds
- R. T. Schomer
- N. S. Embrey
- J. McFarland
- C. C. Plunkett - Contract Admin.
- Central Engineering Files
- E. V. DeCarli - Quality Assurance

R. L. Pittman
Nuclear Service Support Engineer

H. Woodsham
J. D. Carlton
G. QUALE

MAN-HOUR LIMITS	_____
COST LIMITS	_____
CHARGE No.	_____
APPROVED:	_____
	Project Manager

SITE PROBLEM REPORT

BABCOCK & WILCOX-NPG

CUSTOMER Duke Power Company CONTRACT NO. NSS-3 SPR NO. 533 SPR REV. NO. C

VENDOR _____ P.O. NO. _____ COMP. NO. 22 GROUP NO. 02 SEQ. NO. 01

PRIMARY DOCUMENTS: SPEC NOS. _____ PRIORITY _____
 DRG NO. _____ EQUIP CODE/LEVEL/DATE _____
 QA LEVEL _____ QA SPEC NO. _____

SITE ENGINEER ERMicheal/J.D. Phinney EARLY START DATE _____ ACTUAL START DATE _____ REQ'D COMP. DATE _____

TITLE (MAX. 30 SPACES) Loss of FW Incident (5/16/73)

DESCRIPTION OF PROBLEM

See attachment.

STATUS-ACTION TO DATE INCLUDING PERSONS CONTACTED, COMMITMENTS MADE, ETC.

1. Conducted ~~ax~~ test to establish why the Emergency FW pump did not start.
2. Opened bypass around FW pump discharge valves.

FURTHER ACTION REQUIRED BY OTHER THAN SITE PERSONNEL

Evaluate system transient. (Reactimeter tape sent to Lynchburg.)

RECOMMENDED ACTION

1. Provide positive means of sensing loss of FW pumps to initiate Emergency FW flow and main turbine trip. (Customer)
2. Evaluate the SEM failure and correct. (CUSTOMER)
3. ADVISE OTHER CONTRACT OF THIS PROBLEM (N.S)

APPROVALS	TITLE	APPROVA SIGNATURE	DATE	DOCUMENTS AFFECTED	ACTION TAKEN
	ORIGINATOR	<i>G.D. Pittman</i>	<i>G.D. Pittman</i>	<u>5/18/73</u>	<input type="checkbox"/> Drawings
SITE CONSTR. REP.				<input type="checkbox"/> Proc. Specs.	
SITE OPER. MGR.	<i>R. J. Phinney</i>	<i>R. J. Phinney</i>	<u>5/18/73</u>	<input type="checkbox"/> Instr. Books	
N.S. SUPPORT ENGR.	<i>R. L. Pittman</i>	<i>R. L. Pittman</i>	<u>5/31/73</u>	<input type="checkbox"/> Operating Procedures	
				<input type="checkbox"/> Tech. Specs.	
PROJECT MANAGER				<input type="checkbox"/> PSAB/FSAB	
				<input type="checkbox"/> Recommended Sids. Change	
DISTRIBUTION		Cost Category <input type="checkbox"/> Mech <input type="checkbox"/> C <input type="checkbox"/> E <input type="checkbox"/> S <input type="checkbox"/> O <input type="checkbox"/> I	Work Charge No. _____	<input type="checkbox"/> Field Change Req. <input type="checkbox"/>	
SITE OPS MANAGER	RESPONSIBILITY ASSIGN.		Date Completed _____	Field Change No. _____	
PROJECT MANAGER	<u>DUKE</u>		By: _____		
N.S. SUPPORT ENGR.	OTHER CONTRACTS AFFECTED		DEVIATIONS		
COGNIZANT ENGR.			<input type="checkbox"/> NONE		
CONTRACT ADMIN.			<input type="checkbox"/> SEE REV _____		
NPG QA					
FILE 12M2 <u>NSS 3</u>					
<u>SPRS 33</u>					

INSTRUCTIONS FOR FDS-21091 - SITE PROBLEM REPORT

Initiated by Site Personnel

1. ORIGINATOR - FILL IN: Customer; Contract No.; Vendor; PO No.; Component No.; Group No.; Sequence No.; Drawing No.; Title; Description of Problem; Status; Further Action Required by Other Than Site Personnel; Recommended Action; Approval Signature; Date.
2. SITE OPERATIONS MANAGER - FILL IN: SPR No. and Rev. No.; Priority; Site Engineer; Early Start Date; Required Completion Date; Approval Signature; Date.
 Note: Assign priority No. 1 or 2 defined as follows:
 1. Implementation must be complete by required completion date to avoid delay in project completion.
 2. Implementation must be complete by required completion date to obtain maximum project effectiveness.
3. NUCLEAR SERVICE SUPPORT ENGINEER - FILL IN: Primary Documents; Documents Affected; Cost Category; Authorized Charge No.; Responsibility Assignment; Other Contracts Affected.
 Verify or establish proposed resolution working with appropriate engineering units, purchasing, and others as required.
 If field change is not required and additional costs (over and above normal nuclear service expenditures) are not to be incurred, take the following steps: (a) Approve SPR, (b) Indicate "Not Required" in space provided for project manager's approval, and (c) Distribute as indicated in step 5 below.
 If field change is not required but additional costs (over and above normal nuclear service expenditures) are to be incurred, approve SPR and forward to project manager for approval (step 4).
 If field change is required, see procedure No. NPG-0402-03; obtain field change No. from project manager, and indicate field change No. on SPR.
4. PROJECT MANAGER - Approve SPR and Return to Nuclear Service Support Engineer.
5. NUCLEAR SERVICE SUPPORT ENGINEER - Distribute in Accordance With Procedure No. NPG-0402-04; Initial Action Taken Box (on Support Engineer's File Copy) When Documents Affected Have Been Corrected.
6. SITE OPERATIONS MANAGER - Implement Resolution; Upon Completion, Fill in Actual Start Date, Date Completed, and By.
 Note: If necessary to deviate from the approved SPR, note deviation on approved SPR and obtain revised SPR in accordance with procedure No. NPG-0402-04. Return completed SPR to nuclear service support engineer.

Initiated by RAW Construction Company

1. ORIGINATOR - FILL IN: Customer; Contract No.; Vendor; PO No.; Component No.; Group No.; Sequence No.; Drawing No.; Title; Description of Problem; Status; Further Action Required by Other Than Site Personnel; Recommended Action; Approval Signature; Date.
2. SENIOR CONSTR. CO. SITE REPRESENTATIVE - FILL IN: SPR No. and Rev. No.; Priority; Site Engineer; Early Start Date; Required Completion Date; Approval Signature; Date.
 Note: Assign priority No. 1 or 2 defined as follows:
 1. Implementation must be complete by required completion date to avoid delay in project completion.
 2. Implementation must be complete by required completion date to obtain maximum project effectiveness.
3. PROJECT MANAGER - FILL IN: Primary Documents; Documents Affected; Cost Category; Authorized Charge No.; Responsibility Assignment; Other Contracts Affected.
 Verify or establish proposed resolution working with appropriate engineering units, purchasing, and others as required.
 If field change is not required and additional costs (over and above normal construction Co. expenditures) are not to be incurred, take the following steps: (a) Approve SPR, and (b) Distribute in accordance with procedure No. NPG-0402-05.
 If field change is not required but additional costs (over and above normal construction Co. expenditures) are to be incurred, obtain abnormal cost charge No. from contract administration; approve and distribute in accordance with procedure No. NPG-0402-05.
 If field change is required, see procedure No. NPG-0402-07; assign field change No., have approved and distribute in accordance with procedure No. NPG-0402-03.
4. SENIOR CONSTR. CO. SITE REPRESENTATIVE - Implement Resolution; Upon Completion, Fill in Actual Start Date, Date Completed, and By.
 Note: If necessary to deviate from the approved SPR, note deviation on approved SPR and obtain revised SPR in accordance with procedure No. NPG-0402-05. Return completed SPR to the project manager.

LOSS OF FW INCIDENT (5/16/73)

Description of Problem

At approximately 1540 hrs. the "A" main FW pump tripped due to loss of suction pressure. Sequence of events as follows:

1. Loss of all condensate booster pumps (operator error).
2. Main FW pump trip.
3. Loss of OTSG water inventory.
4. RCS temperature and pressure high.
5. Electromatic relief valve lifted.
6. Reactor trip on high pressure.
7. Main turbine trip.
8. Emergency FW pump started manually (auto start command not received).

Two automatic actions did not occur. The Emergency FW pump did not start on loss of FW pumps and the main turbine did not trip on loss of FW pumps. The device to initiate these actions is a pressure sensor on the main FW header downstream of the FW pump discharge valves and upstream of the FW line RB penetration check valves. The FW pump discharge valve automatically closed on FW pump trip and isolated the section of FW header that the pressure sensor is located in. The header remained above the 800 psig setpoint, which, if reached, would have started the emergency FW pump (Main turbine trip setpoint is 700 psig.) A 1" bypass around the FW pump discharge valves is provided, but the bypass valve was closed.

Analysis of this incident is complicated by the failure of the Sequence of Events Monitor to log real time correctly. At the time of the FW pump trip, an error of 430 minutes occurred.

Attached are system parameter curves produced from reactimeter data.

DP/attachment.

FIGURE (C) LOOP (B) PARAMETER AS A FUNCTION OF TIME 3 MINUTES BEFORE TRIP




FIGURE 2. LOOP (A) PARAMETERS AS A FUNCTION OF TIME 2 HOURS BEFORE REACTOR TRIP

