

JAN 27 1977

DISTRIBUTION:

✓ CENTRAL FILE
EP-1 Reading
DSE Reading
NRR Reading

MEMORANDUM FOR: Harold R. Denton, Director, Division of Site Safety
and Environmental Analysis

FROM: Richard S. Cleveland, State/Siting, Environmental
Projects Branch 1

SUBJECT: THREE MILE ISLAND ETS (DRAFT CIRCULATED VIA 1/17/77
BALLARD MEMO)

Re your query as to these ETS being consistent with the decisions
of the 1/17/77 Rusche meeting on ETS vs. NPDES requirements, the
draft ETS is not consistent, as indicated below.

- 1) LCO 2.1.1 prescribes 3.0°C maximum ΔT across condenser
vs. 2.8°C set in the NPDES permit. While the difference
is small, there is a difference.
- 2) LCO's are established for non-radiological environmental
issues.
- 3) Water quality requirements duplicate those covered in
the NPDES permit.
- 4) There appears to be no reflection of the 401 certification
and its requirements.

Original signed by
R. S. Cleveland

Richard S. Cleveland, State/Siting *EPM*
Environmental Projects Branch 1
Division of Site Safety and
Environmental Analysis

cc: G. Knighton
W. Regan
V. Moore
R. Ballard
D. Muller

POOR
ORIGINAL

289
orig 2

x36950 OFFICE	DSE:EP-1 <i>RSC</i>	DSE:MP-1 <i>AK</i>				
SURNAMES	RCleveland/1	GKnighton				
DATE	1/26/77	1/27/77				