

September 19, 1979

X

NOTE TO: J. T. Collins, Deputy Director
TMI-2 Support

FROM: Al Ignatonis

ETC 1 2 100

SUBJECT: OTSG SECONDARY SIDE SAMPLING VALVE CAV-4A

The status of valve CAV-4A inside the reactor building is as follows:

Megger readings: "0" reading on the limit switch circuit. This would be proper indication when valve is open.

"0" reading on the motor. This is an anomaly unless there is a fault in the circuitry or water is in the motor.

Valve CAV-4A is at 290.5' level. Current sump level is at 290.1'. Thus the valve motor may be partially submerged or very close to it. It is within the uncertainty range of sump level readings.

Valve CAV-4A is open. Branch Elam will check to make sure that this valve is tagged open.

Al Ignatonis
TMI-2 Support

cc: R. Vollmer

POOR
ORIGINAL

REGULATORY DOCKET FILE COPY

OFFICE ▶	NRR				
SURNAME ▶	Algnatonis:mg				
DATE ▶	9/19/79				7911080470