

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-287

OCONEE NUCLEAR STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9
License No. DPR-55

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duke Power Company (the licensee) dated June 10, 1975, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; and
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 3.B of Facility License No. DPR-55 is hereby amended to read as follows:



7912020 257

" B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Change No. 9 ."

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Alfred Burger

for | Robert A. Purple, Chief
Operating Reactors Branch #1
Division of Reactor Licensing

Attachment:
Change No. 9 to the
Technical Specifications

Date of Issuance: August 29, 1975

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 12 TO FACILITY LICENSE NO. DPR-38,
CHANGE NO. 22 TO TECHNICAL SPECIFICATIONS;

AMENDMENT NO. 12 TO FACILITY LICENSE NO. DPR-47,
CHANGE NO. 17 TO TECHNICAL SPECIFICATIONS;

AMENDMENT NO. 9 TO FACILITY LICENSE NO. DPR-55,
CHANGE NO. 9 TO TECHNICAL SPECIFICATIONS;

DOCKET NOS. 50-269, 50-270 AND 50-287

Revise Appendix A as follows:

Remove Pages

1-4

3.5-27

3.5-28

Insert Pages

1-4

3.5-27

--

7912020 258

1.5.5 Heat Balance Check

A heat balance check is a comparison of the indicated neutron power and core thermal power.

1.5.6 Heat Balance Calibration

An adjustment of the power range channel amplifiers output to agree with the core thermal power as determined by a heat balance on the secondary side of the steam generator considering all heat losses and additions.

1.6 POWER DISTRIBUTION

1.6.1 Quadrant Power Tilt

Quadrant power tilt is defined by the following equation and is expressed in percent.

$$100 \left(\frac{\text{Power in any core quadrant}}{\text{Average power of all quadrants}} - 1 \right)$$

22/17/
9

1.6.2 Reactor Power Imbalance

Reactor power imbalance is the power in the top half of the core minus the power in the bottom half of the core expressed as a percentage of rated power. Imbalance is monitored continuously by the RPS using input from the power range channels. Imbalance limits are defined in Specification 2.1 and imbalance setpoints are defined in Specification 2.3.

1.7 CONTAINMENT INTEGRITY

Containment integrity exists when the following conditions are satisfied:

- a. The equipment hatch is closed and sealed and both doors of the personnel hatch and emergency hatch are closed and sealed except as in b below.
- b. At least one door of the personnel hatch and the emergency hatch is closed and sealed during refueling or during personnel passage through these hatches.
- c. All non-automatic containment isolation valves and blind flanges are closed as required.
- d. All automatic containment isolation valves are operable or locked closed.
- e. The containment leakage determined at the last testing interval satisfies Specification 4.4.1.

3.5.4 Incore Instrumentation

Applicability

Applies to the operability of the incore instrumentation system

Objective

To specify the functional and operational requirements of the incore instrumentation system.

Specification

3.5.4.1 At or above 80 percent of the power allowable for the existing reactor coolant pump operating combination, incore detectors shall be operable as necessary to meet the following:

a. For axial imbalance measurements:

At least three detectors in each of at least three strings shall lie in the same axial plane, with one plane in each axial core half. The axial planes in each core half shall be symmetrical about the core mid-plane. The detector strings shall not have radial symmetry.

b. For quadrant power tilt measurements:

At least two sets of at least four detectors shall lie in each axial core half. Each set of detectors shall lie in the same axial plane. The two sets in the same core half may lie in the same axial plane. Detectors in the same plane shall have quarter core radial symmetry.

3.5.4.2 If requirements of 3.5.4.1 are not met, power shall be reduced below 80 percent of the power allowable for the existing reactor coolant pump combination within eight hours and incore detector measurements shall not be used to determine axial imbalance or quadrant power tilt.

Bases

The operability of the incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core. See Figures 3.5.4-1, 3.5.4-2, and 3.5.4-3 for satisfactory incore detector arrangements.

The safety of reactor operation at or below 80 percent of the power allowable for the reactor coolant pump combination⁽¹⁾ without the axial imbalance trip system has been determined by extensive 3-D calculations, and was verified during the physics startup testing program.

(1) FSAR, Section 4.1.1.3