

Paulus

PRELIMINARY NOTIFICATION

November 15, 1979

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- 450-14-79-14

This preliminary notification constitutes EARLY notice of events of POSSIBLE HAZARD of a high interest significance. The information presented is as available without further verification or evaluation and is basically all that is known at this time.

Location: Missouri Public Power District
Cooper Station
Troyville, Missouri
Contact No. 50-293

SUBJECT: PLANT SHUTDOWN DUE TO INCORRECTIVE DIESEL GENERATOR

The licensee reported on November 14, 1979, that since they had been unable to determine the cause of the malfunction of the number 2 Emergency Diesel Generator, the generator was taken off the line at 4:15 p.m. on November 14, 1979, and the plant shutdown. The diesel had been out of service for an extended duration and a number of other damages had been experienced during the subsequent acceptance testing.

The length of time required to determine the cause of the diesel malfunction is unknown at this time. The licensee has made a press release. Region IV (Missouri) does not plan to issue a press release at this time.

Cooper Station is a boiling water reactor.

Licensee: L. Constable (RTV) 334-2714; T. E. Westerman (RTV) 334-2781

Commissioners:
William Fiedler
Commissioner Kennedy
Commissioner Gilinsky

Commissioner H. St.
Commissioner Bradford
Commissioner Ahearne
ACRS

S. J. Chalk, SECT
C. C. Kernerer, CA
(For Distribution)

Transmitted: NRR
1. W. Szwed, NRR
2. L. Constable, EID
3. J. Blackard, PA
4. M. Keller, IEA
5. I. Spatz, OEP
6. K. Stigis, EID

5. Bldg.
6. R. Denton
7. C. DeYoung, NRR
8. J. Mattson, NRR
9. Vassallo, NRR
10. Risenkoff, NRR
11. Bldg.
12. J. Dircks, NRRS
13. Levine, RES

IE:XSOS (TR:CS) DA
Lindow (6) info/ppt
J. J. Cummings, OIA
(MAIL)
R. Minogue, CS
IE:XSOS

PRELIMINARY NOTIFICATION

POOR ORIGINAL

7912²⁰0019