

Attachment 2

Proposed Technical Specification Revision Pages

7912200711

Applicability

Applies to instruments monitoring reactor power, reactor power imbalance, reactor coolant system pressure, reactor coolant outlet temperature, flow, number of pumps in operation, and high reactor building pressure.

Objective

To provide automatic protective action to prevent any combination of process variables from exceeding a safety limit.

Specification

The reactor protective system trip setting limits and the permissible bypasses for the instrument channels shall be as stated in Table 2.3.1A-Unit 1 and

2.3-1B-Unit 2

2.3-1C-Unit 3

Figure 2.3-2A-Unit 1

2.3-2B-Unit 2

2.3-2C-Unit 3

The pump monitors shall produce a reactor trip for the following conditions:

- a. Loss of two pumps and reactor power level is greater than 55% of rated power.
- b. Loss of two pumps in one reactor coolant loop and reactor power level is greater than 0.0% of rated power.
- c. Loss of one or two pumps during two-pump operation.

Bases

The reactor protective system consists of four instrument channels to monitor each of several selected plant conditions which will cause a reactor trip if any one of these conditions deviates from a pre-selected operating range to the degree that a safety limit may be reached.

The trip setting limits for protective system instrumentation are listed in Table 2.3-1A-Unit 1. The safety analysis has been based upon these protective

2.3-1B-Unit 2

2.3-1C-Unit 3

system instrumentation trip setpoints plus calibration and instrumentation errors.

Nuclear Overpower

A reactor trip at high power level (neutron flux) is provided to prevent damage to the fuel cladding from reactivity excursions too rapid to be detected by pressure and temperature measurements.

level trip and associated reactor power/reactor power-imbalance boundaries by 1.055% for 1% flow reduction.

Pump Monitors

The pump monitors prevent the minimum core DNBR from decreasing below 1.3 by tripping the reactor due to the loss of reactor coolant pump(s). The circuitry monitoring pump operational status provides redundant trip protection for DNB by tripping the reactor on a signal diverse from that of the power-to-flow ratio. The pump monitors also restrict the power level for the number of pumps in operation.

Reactor Coolant System Pressure

During a startup accident from low power or a slow rod withdrawal from high power, the system high pressure setpoint is reached before the nuclear overpower trip setpoint. The trip setting limit shown in Figure 2.3-1A - Unit 1

2.3-1B - Unit 2

2.3-1C - Unit 3

for high reactor coolant system pressure (2355 psig) has been established to maintain the system pressure below the safety limit (2750 psig) for any design transient. (1)

The low pressure (1800) psig and variable low pressure (11.14 T_{out}^{out}) -4706 trip
(1800) psig (11.14 T_{out}^{out}) -4706)
(1800) psig (11.14 T_{out}^{out}) -4706)

setpoints shown in Figure 2.3-1A have been established to maintain the DNB

2.3-1B

2.3-1C

ratio greater than or equal to 1.3 for those design accidents that result in a pressure reduction. (2,3)

Due to the calibration and instrumentation errors the safety analysis used a variable low reactor coolant system pressure trip value of (11.14 T_{out}^{out}) -4746)
(11.14 T_{out}^{out}) -4746)
(11.14 T_{out}^{out}) -4746)

Coolant Outlet Temperature

The high reactor coolant outlet temperature trip setting limit ($619^{\circ}F$) shown in Figure 2.3-1A has been established to prevent excessive core coolant

2.3-1B

2.3-1C

temperatures in the operating range. Due to calibration and instrumentation errors, the safety analysis used a trip setpoint of $620^{\circ}F$.

Table 2.3-1A
Unit 1

Reactor Protective System Trip Setting Limits

RPS Segment	Four Reactor Coolant Pumps Operating (Operating Power 100% Rated)	Three Reactor Coolant Pumps Operating (Operating Power -75% Rated)	One Reactor Coolant Pump Operating In Each Loop (Operating Power -49% Rated)	Shutdown Bypass
1. Nuclear Power Max. (% Rated)	105.5	105.5	105.5	5.0 ⁽³⁾
2. Nuclear Power Max. Based on Flow (2) and Imbalance, (% Rated)	1.055 times flow minus reduction due to imbalance	1.055 times flow minus reduction due to imbalance	1.055 times flow minus reduction due to imbalance	Bypassed
3. Nuclear Power Max. Based on Pump Monitors, (% Rated)	NA	NA	55%	Bypassed
4. High Reactor Coolant System Pressure, psig, Max.	2355	2355	2355	1720 ⁽⁴⁾
5. Low Reactor Coolant System Pressure, psig, Min.	1800	1800	1800	Bypassed
6. Variable Low Reactor Coolant System Pressure psig, Min.	$(11.14T_{out} - 4706)^{(1)}$	$(11.14T_{out} - 4706)^{(1)}$	$(11.14T_{out} - 4706)^{(1)}$	Bypassed
7. Reactor Coolant Temp. F., Max.	619	619	619	619
8. High Reactor Building Pressure, psig, Max.	4	4	4	4

(1) T_{out} is in degrees Fahrenheit ($^{\circ}$ F).

(2) Reactor Coolant System Flow, %.

(3) Administratively controlled reduction set
only during reactor shutdown.

(4) Automatically set when other segments of
the RPS are bypassed.