

Docket Nos. 50-269, 50-270
and 50-287

FEB 6 1975

Robert A. Purple, Chief, Operating Reactors Branch #1, RL

ORB-1-119, OCONEE UNITS 1, 2, AND 3 TECHNICAL ASSISTANCE REQUEST
NO. 9015, QUALITY ASSURANCE

In response to TAR ORB-1-119 we have reviewed the procedures described in the letter from Duke Power Company dated December 26, 1974 to determine (a) if they fulfill the intent of the current Oconee Technical Specifications (TS) and (b) if the Oconee TS, in respect to procedure review and approval, meet the intent of the Standard TS being issued.

We have concluded that:

- (a) The procedures described in the Duke Power Company letter dated December 26, 1974 comply with Section 6.1.2.1.d.1 of the Oconee TS. We consider that this specification means that the Station Manager or his designate is the sole determinate in deciding which procedures shall require review by the Station Review Committee. Therefore, we consider that their actions are within the TS.
- (b) The mechanism described in the Oconee TS for procedure review does not comply with the intent of the Standard TS now being issued.
- (c) The current Administrative Section of Oconee TS dealing with the review and approval of safety related procedures is inadequate.

We understand that Duke Power Company has been requested to submit a proposed revision to Section 6 of their TS for the Oconee facility to conform to the Standard TS Section 6. We recommend that the deficiencies noted above be corrected as part of this action.

Original signed by:
Richard H. Vollmer

Richard H. Vollmer, Chief
Quality Assurance Branch
Division of Reactor Licensing

Memo
4

OFFICE →					
SURNAME →					
DATE →					

FEB 6 1975

cc: D. Skovholt
 K. Goller
 J. Sniezek
 T. Carter
 L. McDonough

DISTRIBUTION
 Central Files
 QA Readng
 NRRR Reading
 Fallenspach
 JGilray
 RVollmer
 AGarland

OFFICE →	RL:QA	RL:QA <i>WJ</i>	RL:QA <i>WJ</i>			
SURNAME →	Fallenspach:dp	JGilray	RVollmer			
DATE →	2/6/75	2/ 175	2/5/75			