

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO: Mr. Norman C. Moseley

FROM: Duke Power Company
Charlotte, N.C. 28242
Wm. O. Parker, Jr.

DATE OF DOCUMENT
7-27-76

DATE RECEIVED
8-6-76

LETTER NOTORIZED
 ORIGINAL UNCLASSIFIED
 COPY

PROP INPUT FORM

NUMBER OF COPIES RECEIVED
1 signed

DESCRIPTION Ltr trans the following:

ENCLOSURE Reportable Occurrence RO-287/76-9
on 7-13-76 refailure of feedwater transient
resulting from a spurious 80 per cent
decrease in feedwater demand for approxima-
tely two seconds....

(1 cy encl rec'd)

ACKNOWLEDGED

PLANT NAME: Oconee Unit 3

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

DHL 8-9-76

BRANCH CHIEF: Schwencer
W/3 CYS FOR ACTION
LIC. ASST.: Sheppard
W/1 CYS
ACRS 16 CYS / SENT TO LA

INTERNAL DISTRIBUTION

- REG FILE
- NRC PDR
- I & E (2)
- MIPC
- SCHROEDER/IPPOLITO
- HOUSTON
- NOVAK/CHECK
- GRIMES
- CASE
- BUTLER
- HANAUER
- TEDESCO/MACCARY
- EISENHUT
- BAER
- SHAO
- VOLLMER/BUNCH
- KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Waltham, S.C.
TIC:
NSIC:

7963

8001090562 J

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

Regulatory Docket File

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

July 27, 1976




Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 3
Docket No. 50-287

Dear Mr. Moseley:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station
Technical Specifications, please find attached Reportable Occurrence
Report RO-287/76-9.

Very truly yours,


William O. Parker, Jr.

EDB:vr
Attachment

cc: Director, Office of Management Information
and Program Control

7960