

30 267  
FEB 23 1973

13-269  
R. R. Maccary, Assistant Director for Engineering, L

OCONEE UNIT 1 - VESSEL INTERNALS VIBRATION DATA

Per agreement reached in the January 31, 1973, meeting with Duke Power Company and Babcock and Wilcox, Duke has submitted a letter report (enclosed) dated February 15, 1973, summarizing the vessel internals vibration data acquired during preoperational tests and the results of the post-test inspection of the internals.

We will require a statement for the record that we find the re-designed internals acceptable as the basis for removing the 5% power restriction now imposed in the technical specification until such finding is made.

In order that the 5% power restriction not be unduly restrictive time wise, we need your evaluation by March 13, 1973.

*Haller/zo*

R. C. DeYoung, Assistant Director  
for Pressurized Water Reactors  
Directorate of Licensing

Enclosure:  
Ltr. dtd. 2/15/73

cc: I. Peltier (2)  
J. Knight  
S. Hou

DISTRIBUTION  
Suppl  
RP Reading  
PWR-4 Reading  
ASchwencer  
RCDeYoung

OFFICE ▶	PWR-4:L <i>JAP</i> IAPeltier:bp	PWR-4:L <i>AS</i> ASchwencer	ADPWR:L <i>KRG/RS</i> RCDeYoung			<i>Nemo</i>
SURNAME ▶						
DATE ▶	2/28/73	2/27/73	2/22/73			