MEMORANDUM

TO: SAFETY REVIEW COMMITTEE

Mr. J. H. Woodward Mr. E. P. Fitzgerald Mr. W. Cavanaugh Dr. C. G. Chezem Mr. J. W. Anderson Dr. D. Mathews Mr. J. Holman

FROM:

Marshall L. Pendergrass, Secretary

SUBJECT:

ARKANSAS MUCLEAR ONE - UNIT 1 SAFETY REVIEW COMMITTEE MEETING MI. JUTES OF PEBRUARY 4, 1975

(FILE: 0280.3)

Attached are the Minutes of the February 4, 1975, meeting of the Safety Review Committee. If you have any comments or corrections to these Minutes, please bring them to my attention at the next meeting.

Mushall filter bry me

MLP: tw

Attachment

ec: Mr. J. D. Phillips

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

8001160708

A

## SAFETY REVIEW COMMITTEE MEETING FEBRUARY 4, 1975

Attendees: Woodward, McClintock, Cavanaugh, Fitzgerald, Pendergrass, Holman

## OLD BUSINESS

 The committee reviewed and approved the minutes from the following meetings: December 20, January 7, January 8, January 23, and January 30.

## NEW BUSINESS

- The committee reviewed and approved Plant Safety Committee Meeting minutes from the following dates: December 2, 17, 30, 31, January 2, 7, 10, 21, 24.
- The committee reviewed letters sent to the AEC on the following dates concerning the noted subjects:
  - A. December 20, 1974 Industrial Security Plan revisions page 11 and Figure 5.
  - B. December 30, 1974 response to apparent violation cited in AEC letter of November 29, 1974
  - C. January 6, 1975 revision 1 to Quality Assurance Manual-Operations
  - D. January 6, 1975 response to AEC questions concerning SLBIC
  - E. January 8, 1975 negative response to DRO Bulletin 74-15
  - F. January 14, 1975 justification for deletion of generator separation test from 100% full power.
  - G. January 16, 1975 response to AEC's recommendations for an expanded fish monitoring program.
  - H. January 17, 1975 response to violation cited in AEC letter of January 6, 1975.
  - January 31, 1975 concurred with B&W's calculational parameters used in BAW-10099, "Babcock and Wilcox Anticipated Transients Without Scram Analysis".

- 3. ANO-1 response to the SRC Audit Report was reviewed and the following actions were recommended:
  - A. Some SRC members should return to the plant to determine if the corrective measures taken were adequate. Particular emphasis should be paid to any possible violations of the Industrial Security Plan.
  - B. Determine who supplies certain materials (such as gloves and/or gowns) to the emergency kit at St. Mary's Hospital.
  - C. A letter should be written to the plant to determine what decontamination supplies are available and where they are located.
- 4. The committee reviewed and approved Unusual Event Report No. 50-313/75-1.
  The report was filed due to the error in B&W's analysis to predict ejected rod worth at hot zero power.
- 5. Abnormal Occurrence Report No. 50-313/74-10A was reviewed and approved. This was a follow-up report on 50-313/74-10 describing a leak in a 1½ inch drain line from the cold leg of the RCS.
- 6. Abnormal Occurrence Report No. 50-313/74-11A was reviewed and approved. This was a follow-up metallurgical report on the cracks that occured in RCS drain line HCB-6-1.
- 7. The committee reviewed and approved the Environmental Tech. Spec. changes to paragraph 4.2.2. This change would delete the references to a specific type, future Tech. Spec. changes will not be required if TLD technology may indicate some new type of material other than TLD 100 or TLD 200 should be used.
- 8. The committee reviewed and approved the Environmental Tech. Spec.

  hange to paragraph 4.1.2.a(3). The change would require biological
  and water samples to be taken quarterly after commencement of plant
  operation to correspond to the interval specified in the UALR contract.

Marshall L. Pendergrass, Secretary

Safety Review Committee