

# ARKANSAS POWER & LIGHT COMPANY

INTRA COMPANY CORRESPONDENCE

March 18, 1975

MEMORANDUM

TO: SAFETY REVIEW COMMITTEE

Mr. J.H. Woodward	Mr. E. P. Fitzgerald
Mr. W. McClintock	Mr. T. Cogburn
Mr. W. Cavanaugh	Dr. C. G. Chezem
Mr. J. W. Anderson	Mr. T. Baker
Dr. D. Mathews	Mr. J. Holman

*File*

FROM: Marshall L. Pendergrass, Secretary

SUBJECT: ARKANSAS NUCLEAR ONE - UNIT 1  
SAFETY REVIEW COMMITTEE MEETING  
MINUTES OF MARCH 17, 1975  
(FILE: 0280.3)

Attached are the Minutes of the March 17, 1975, meeting of the Safety Review Committee. If you have any comments or corrections to these Minutes, please bring them to my attention at the next meeting.

*Marshall L. Pendergrass*

MLP:jp

Attachment

cc: Mr. J. D. Phillips

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8001160718

A

MINUTES OF THE  
SAFETY REVIEW COMMITTEE MEETING

MARCH 17, 1975

ATTENDEES: McClintock, Cavanaugh, Fitzgerald, Holman,  
Pendergrass

OLD BUSINESS:

1. The committee reviewed SRC minutes from meetings on the following dates:  
March 3, 1975  
March 7, 1975  
March 10, 1975  
March 14, 1975
2. The committee reviewed Plant Safety Committee meeting minutes from meetings on the following dates:  
February 25, 1975  
March 3, 1975
3. Operating Procedure 1602.13, shipment of radioactive materials, was reviewed and approved as written.
4. Operating Procedure 1602.14, Inventory of Emergency Kits, was reviewed and approved with comments.
5. The committee reviewed the report on the unannounced audit performed at ANO on February 19, 1975.

NEW BUSINESS:

1. The committee reviewed the letter to the NRC (February 28, 1975) revising the date the solid radioactive waste system was expected to be operable from March 1, 1975 to August 1, 1975.
2. The following letters from the NRC were reviewed by the committee:  
February 25, 1975 - clarification on procedure to determine maximum permissible concentration in air for radioisotopes not listed in Appendix B to 10CFR20.  
February 25, 1975 - reporting acceptability of Revision 8 to the Security Plan for ANO-1.  
February 26, 1975 - request for additional information to establish conformance with Regulatory Guide 1.20, "Vibration Measurements on Reactor Internals".  
March 4, 1975 - correction to letter of 2/26/75 plus request to CE to supply similar information for Fort Calhoun and Maine Yankee.
3. The committee reviewed and approved revision 2 to operating procedure 1202.34, Personnel Response and Accountability.

4. The committee reviewed an information copy of operating procedure 1304.60, RC Pump Under-Power Relay Test. Although SRC approval was not required for this procedure, it was reviewed because it was generated as a result of an Abnormal Occurrence.
5. The committee reviewed the regulatory report "Reactor Building Tendon End Anchorage Concrete Surveillance".
6. The committee reviewed and approved the Technical Specification change to the bases of Technical Specification 3.1.2. The change involved a clarification in the RCS heating and cooldown rates.

*Marshall L. Pendergrass*  
M. L. Pendergrass, Secretary  
Safety Review Committee