

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

To F. R. Faist - Acting SOM

SITE INSTRUCTION NO. 1523 150.1

DISTRIBUTION 14

RESPONSE REQ'D FROM 14

From G. K. Wandling - Plant Startup Services Section

BOS 603.5

Cust. TECO

File No. NSS-14/T3.55
or Ref.

Subj. Revised Instructions for Control of Steam Generator Level

Date November 30, 1978

This letter to cover one customer and one subject only.

Reference: Site Instruction 14-323, dated 11/22/78.

Revised interim operating instructions (attached) have been developed that will permit TECO to continue interim operation until adjustments to the steam generator level setpoint or other design changes can be permanently made. These revised instructions replace those originally transmitted in the referenced site instruction.

The attached instructions address required operator actions following SFRCs actuation of the auxiliary feedwater only. No operator actions are required to modify ICS control of main feedwater (Case 2 of the Referenced Site Instruction). TECO reviewed the attached instructions while in Lynchburg on 11/27/78 and they concur that the operating instructions are adequate for interim safe operation.

Please forward this information to the customer and contact me if there are any questions.

GKW:NF
Attachment

cc: W. H. Spangler*
H. A. Baker
D. F. Hallman
R. C. Luken*
E. W. Swanson* ←
E. A. Womack*
R. W. Winks*
E. R. Kane
J. R. Bohart
J. A. Lind
Central Files

*w/o attachment

POOR ORIGINAL

REVIEWED FOR ACCURACY	
ENGINEERING: <i>[Signature]</i>	DATE: <i>[Date]</i>
NUCLEAR SERVICE: <i>[Signature]</i>	DATE: <i>[Date]</i>

8001160833 P