-Nuclear, 4th Ld - Writethru, 2277,890 is: Tops with 12 new grafs to update, moving Hart statements to 7th, oth and 9th grafs, edits throughout to tighten and consolidate previous leads and inserts.
Laserphotos HX1, 2, LAN1, 2, REA2, Map NY24
By BOB DVORCHAK Associated Press Writer HARRISBURG, Pa. AP - An accident at the Three Mile Island nuclear power plant apparently damaged the reactor core and allowed radioactive material to leak into the stmosphere, the government said Wednesday. Officials said their readings indicated there was no immediate danger to the public, and there were no plans to evacuate the 15,000 people living within a mile of the plant. Fison Case, a Nuclear Regulatory Commission spokesman, said radiation levels inside the plant, s reactor building registered at 1,000 times normal. But George Troffer, manager of generation quality assurance for Metropolitan Edison, one of the consortium of companies that runs the plant, said he thought that figure was too high. He said the level was perhaps 10 times more than normal. Company employees and NRC officials worked at the plant to reduce the temperature and pressure inside the reactor dome to allow engineers to enter and check the reactor for damage.
A plant spokesman said 'a handful, of workers were exposed to radiation in the accident; but none was seriously contaminated or hospitalized. In Washington, Sen. Gary Hart, D-Colo., said human error appeared to have been a factor in the incident.

""" am informed by the NRC that the emergency core cooling system was turned off prematurely - resulting in partial blockage of water needed to cool the nuclear core and keep it under control,, said Hart, chairman of the Senate subcommittee on nuclear radiation. * Some human error seems to have been involved in responding to the emergency situation,,, he said, adding the NRC had told him radiation levels outside the plant did not pose a health hazard.
Case said radioactive gases from the plant, s nuclear fuel may have leaked out of the plant, which was shut down by the accident. There was no word when the electric facility would resume operation.

A statement from General Public Utilities, the consortium which operates the plant, said there was some low-level release of radioactive gas beyond the site boundary . . . Despite this release, the company does not believe the level constitutes a danger to the health and safety of the public.,

Earlier, the consortium said the accident may have damaged the fuel cladding, metal tubes which contain the pellets of radioactive The cause of the accident - or the precise sequence of events that led to the radiation, s release - could not be immediately determined. But Lt. Gov. William Scranton III said steam containing radioactive material was released into the air for over two hours to frelieve potentially dangerous pressure , in the reactor. . The situation is more complex than the company first led us to believe,, Scranton Baid. filt the release of the steam was done to relieve potentially dangerous pressure in the reactor chamber,, Scranton said. (Because of an apparent leak in the primary cooling system, radioactive material was discharged into the air along with the steam,, he said. Company officials could not be reached for comment on Scranton,s statement, but Leonard Matt, a spokesman for the consortium, said . . Some damage to the fuel cladding may have occurred . , , The extent of the damage, if any, was not known. Case said heat-caused pressure inside the dome had risen temporarily to four or five pounds per square inch above outside atmospheric pressure - enough to cause leakage. The leaking gases may have included iodine and xenon, he said, but not uranium or plutonium. A nuclear engineer for the state Department of Environmental Resources, William Dornsife, said the core became overheated during the incident. *The core was covered. The core was flooded. Something caused the core to overheat,, he said, The consortium reported the possible damage to the cladding after 80011 70503

the accident, but none was seriously contaminated or hospitalized . In Washington, Sen. Gary Hart; D-Colo., said human error appeared have been a factor in the incident.

I am informed by the NRC that the emergency core cooling system was turned off prematurely - resulting in partial blockage of water needed to cool the nuclear core and keep it under control,, said Hart, chairman of the Senate subcommittee on nuclear radiation, emergency situation,, he said, adding the NRC had told him radiation levels outside the plant did not pose a health hazard. Case said radioactive gases from the plant, s nuclear fuel may have leaked out of the plant, which was shut down by the accident. There was no word when the electric facility would resume operation.

A statement from General Public Utilities, the consortium which operates the plant, said there was "some low-level release of redicactive gas beyond the site boundary . . . Despite this release the company does not believe the level constitutes a danger to the health and safety of the public., Earlier: the consortium said the accident may have damaged the fuel cladding, metal tubes which contain the pellets of radioactive The cause of the accident - or the precise sequence of events that led to the radiation, s release - could not be immediately determined Gov. William Scranton III said steam containing radioactive material was released into the air for over two hours to "relieve potentially dangerous pressuress in the reactor. The situation is more complex than the company first led us to pelieve,, Scranton said. the release of the steam was done to relieve potentially dangerous pressure in the reactor chamber,, Scranton said. (Becaus of an apparent leak in the primary cooling system, radioactive material was discharged into the air along with the steam,, he said company officials could not be reached for comment on Scranton,s statement, but Leonard Matt, a spokesman for the consortium, said . . Some damage to the fuel cladding may have occurred ... The extent of the damage, if any, was not known. Case said heat-caused pressure inside the dome had risen temporaril; to four or five pounds per square inch above outside atmospheric pressure - enough to cause leakage. The leaking gases may have included iodine and xenon, he said, but not uranium or plutonium. A nuclear engineer for the state Department of Environmental Resources, William Dornsife, said the core became overheated during the incident. (The core was covered. The core was flooded. Something caused the core to overheat,, he said The consortium reported the possible damage to the cladding after an NRC spokesman said the accident sent radiation beaming up to a mile away through the 4-foot-thick walls of the power plant. Joe Fouchard, the spokesman, said the amount of radiation was relatively small, adding that what registered a mile from the plant was comparable to that given off during a medical X-ray. Plant officials had said only a small amount of radioactive steam escaped when a valve blew out on a water pump that cools one of the plant's two reactors. A second reactor was shut down earlier for refueling Plant officials said some workers may have teen contaminated. "I'm sure some of them got exposure, but positively none were over-exposed ,, said Jack Herbein, vice president for generation at Metropolitan Mison. The plant employs 500 persons.
Plant spokesman Blaine Fabian said: "There is absolutely no danger of a meltdown. We are not in a China Syndrome, type situation., He referred to a movie that dramatizes the possibility of an uncooled nuclear reactor core melting and burning into the earth.
The \$1 billion plant, on an island in the Susquehanna River 10 miles southeast of here, began operation in 1974.
Dornsife said initial readings showed the amount of radiation that escaped was 1 millirem per hour. But a plant spokesman said readings later increased to 2 to 3 millirems per hour at the edge of the site. Normally, Americans are exposed to between 100 and 120 millirems per year from such things as the sun and X-rays. A chest X-ray could give a person up to 30 millirems.