

CC: W. R. Gibson
E. R. Kane
G. M. Olds
J. D. Phinney

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505
Telephone: (804) 384-5111

February 2, 1979
TMI-79-16

73

Mr. J. F. Hilbisch
Manager, Licensing
Metropolitan Edison Company
Post Office Box 542
Reading, PA 19603

Subject: Three Mile Island Nuclear Station
Loss of Pressurizer Level Indication

Reference: NRC Letter, J. E. Foster to J. H. Taylor, dated 1/31/79

Dear Mr. Hilbisch:


B&W has received the attached request for information concerning the loss of pressurizer level indication at B&W plants from the NRC Region III office. The Region III office is requesting this information based on their feeling that a loss of pressurizer level indication violates Criterion 13 - Instrumentation and Control, which states, "Instrumentation shall be provided to monitor variables and systems over their anticipated range for normal operation, for anticipated operational occurrences, and for accident conditions as appropriate to ensure adequate safety,...."

Because of the tight schedule of their request, we would appreciate your prompt response to this request. If you choose to supply the requested information for your plant(s), it would be desirable for the information to be in our hands by February 8, 1979, so we can compile the information and develop the proper strategy.

Present plans call for a strategy meeting on Tuesday, February 13, 1979, in Lynchburg to discuss the concern for utilities that plan to attend the February 14, 1979, meeting.

Please contact us by February 8 if you plan to attend and indicate whether you will investigate past occurrences at your plant.

Very truly


Joel T. Janis
Service Manager

POOR ORIGINAL

JTJ/web
Attachment

cc: R. M. Klingaman
G. P. Miller
J. B. Logan
L. C. Rogers
S. L. Smith

L. L. Lawyer
J. L. Seelinger
C. R. Montgomery

8001170 863

P

DOMINA FRYE

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

February 2, 1979
ANO-79-13

Mr. D. H. Williams
Manager, Licensing
Arkansas Power & Light Company
P.O. Box 551
Little Rock, Arkansas 72203

Subject: Arkansas Nuclear One - Unit 1
Pressurizer Level Meeting With NRC

Dear Mr. Williams:

As discussed with you in a telecon on February 2, 1979, B&W has received the attached request for information concerning the loss of pressurizer level indication at B&W plants from the NRC Region III office. The Region III office is requesting this information based on their feeling that a loss of pressurizer level indication violates Criterion 13 - Instrumentation and Control which states "Instrumentation shall be provided to monitor variables and systems over their anticipated range for normal operations, for anticipated operational occurrences, and for accident conditions as appropriate to ensure adequate safety...".

Because of the tight schedule of their request, we would appreciate your prompt response to this request. If you choose to supply the requested information for your plant, it would be desirable for the information to be in our hands by 2/8/79 so we can compile the information and develop the proper strategy.

Present plans call for a strategy meeting on Tuesday, February 13, 1979, in Lynchburg to discuss the concern for utilities that plan to attend the February 14, 1979 meeting.

We understand you plan to attend both of these meetings.

If you have any questions in this matter, please advise.

Very truly yours,

R. C. Luken

R. C. Luken
Service Manager

RCL/dsv
Attach.

cc: J.P. O'Hanlon G.H. Miller
D.R. Sikes T.F. Scott
R.P. Lockett, Jr.

Licensing
bcc: J.T. Willse
J.D. Phinney

POOR ORIGINAL

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

February 2, 1979
RS -79-12

Mr. D.G. Raasch
Manager Generation Engineering
Sacramento Municipal Utility District
Rancho Seco Nuclear Station
Route 1, Box 550
Herald, California 95638

Subject: Rancho Seco Nuclear Generating Station - Unit No. 1 Loss of Pressurizer Level Indication

Ref: NRC Letter, J.E. Foster to J.H. Taylor dated 1/31/79

Dear Mr. Raasch:


B&W has received the attached request for information concerning the loss of pressurizer level indication at B&W plants from the NRC Region III office. The Region III office is requesting this information based on their feeling that a loss of pressurizer level indication violates Criterion 13 - Instrumentation and Control which states "Instrumentation shall be provided to monitor variables and systems over their anticipated range for normal operations, for anticipated operational occurrences, and for accident conditions as appropriate to ensure adequate safety, - - -".

Because of the tight schedule of their request, we would appreciate your prompt response to this request. If you choose to supply the requested information for your plant (s) it would be desirable for the information to be in our hands by 2/8/79 so we can compile the information and develop the proper strategy.

Present plans call for a strategy meeting Tuesday February 13, 1979 in Lynchburg to discuss the concern for utilities that plan to attend the February 14, 1979 meeting.

Please contact us by February 8 if you plan to attend and indicate whether you will investigate past occurrences at your plant.

Very truly yours,


J.T. Janis

Service Manager

bcc: R. Berchin

ER Kane

GM Olds

JD Phinney

Record Ctr. NSS-11/T1.2

JTJ/krd

CC: R.P. Dubre' C.A. Creacy
R.J. Rodriguez J.H. Johnston

POOR ORIGINAL

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

bcc: CD Russell
JD Phinney
RC Luken
JH Taylor
Record Ctr. NSS-3/4/9/T1.2

February 2, 1979
ONS-79-35

Mr. K. S. Canady
Manager, Projects & Licensing
Duke Power Company
P.O. Box 33189
Charlotte, NC

Subject: Oconee Nuclear Station
Loss of Pressurizer Level During Transients

Reference: Letter, James E. Foster (NRC) to J. H. Taylor (B&W),
January 31, 1979 (attached).

Dear Mr. Canady:

B&W has received the attached request for information concerning the loss of pressurizer level indication at B&W plants from the NRC Region III office. The Region III office is requesting this information based on their feeling that a loss of pressurizer level indication violates Criterion 13 - Instrumentation and Control which states "Instrumentation shall be provided to monitor variables and systems over their anticipated range for normal operations, for anticipated operational occurrences, and for accident conditions as appropriate to ensure adequate safety...".

Because of the tight schedule of their request, we would appreciate your prompt response to this request. If you choose to supply the requested information for your plant(s), it would be desirable for the information to be in our hands by February 8, 1979 so we can compile the information and develop the proper strategy.

Present plans call for a strategy meeting Tuesday, February 13, 1979, in Lynchburg to discuss the concern for utilities that plan to attend the February 14, 1979 meeting.

Please notify CD Russell or myself if you plan to attend and indicate whether you will investigate past occurrences at your plant.

Very truly yours,

R. P. Williamson

R. P. Williamson
Associate Service Manager

RPW/hh

cc: RL G111

POOR ORIGINAL