

FIELD CHANGE AUTHORIZATION **04 2257 00** BARCOCK & WILCOX

CUSTOMER: Jersey Cent. CONTRACT NO. 620-0006 FCA NO. 122 REV. NO. 0

VENDOR: Dresser P.O. NO. 0226601S TASK NO. 28 GROUP NO. 041 SEQ. NO. 006

ORIGINATOR: J. L. Wilsher DATE: EXPEDITE NORMAL

F.C. TITLE (MAX. 30 SPACES) Electromatic Relief Valve Mod.

DESCRIPTION OF FIELD CHANGE:

Modify Electromatic Relief Valve, B&W mark no. RC-RV2 per the attached procedure 03 6918 00.

Description: Two bushings are added to lever and one to solenoid bracket. This will ensure freedom of motion of lever pin using corrosion resistant bushings.

POOR ORIGINAL

REASON FOR CHANGE: SITE PROBLEM ENGRG. REQ'T CUSTOMER REQUEST
 IMPROVEMENT OTHER (SPECIFY) Vendor requirement - Equipment Improv.
 SPR. DOC. OR LETTER NO/REF SPR-107, NSS-9

TASKS AFFECTED

TASK NO.	TASK ENGINEER	TASK NO.	TASK ENGINEER
28	J. L. Wilsher		

APPROVALS	TITLE	FC AUTHORIZATION APPROVAL	DATE	FC PACKAGE APPROVAL	DATE
	TASK ENGINEER	<i>H. P. ...</i>	11-17-76	<i>J. L. Wilsher</i>	11-17-76
	INTEGRATOR			<i>W. M. ...</i>	11-17-76
	ENGRG. UNIT MGR.			<i>[Signature]</i>	11-17-76
	NUCLEAR SERV.			<i>R. ...</i>	11-22-76
	PROJECT MGR.	<i>LR Plothe</i>		<i>LR Plothe</i>	11-22-76

OTHER SUGGESTED APPLICABILITY:
 CONTRACTS NSS -3, 4, 5, 6, 7, 8, 9, 11, 12 & 13
 SID. PLANT Yes No
 INTEGRATOR _____ DATE _____

CUSTOMER/CUSTOMER AGENT AUTH. CHARGE NO. _____
 DISPOSITION OF FIELD CHANGE:
 IMPLEMENTED
 NOT IMPLEMENTED
 REF. *LR Plothe* *4/29/77*
 PROJECT MGR. _____ DATE _____

FILE NUMBER _____ SHEET 1 of 2

