

BAW-1514

November 1978

SMUD TRANSIENT EVALUATION - RAPID
COOLDOWN INCIDENT OF 3/20/78

BABCOCK & WILCOX
Power Generation Group
Nuclear Power Generation Division
P. . Box 1260
Lynchburg, Virginia 24505

8001210554

1. INTRODUCTION

On March 20, 1978, the Sacramento Municipal Utility District's Rancho Seco Nuclear Generating Station, Unit No. 1 experienced a loss of power to a substantial portion of its non-nuclear instrumentation. The plant was operating at approximately 72% of full power at the time. Although the reactor protection system functioned properly, the plant experienced a severe thermal transient. This report addresses the investigation of the effects of that transient on the reactor coolant system and discusses that system's ability to continue unrestricted operation for the remaining design lifetime of the unit.

2. DISCUSSION

On March 23, 1978, B&W concurred with SMUD's intent to return the Rancho Seco plant to power operation at a power level at or below 75% of full power. B&W concurrence with the operation of Rancho Seco above 75% full power was contingent upon QA evaluation of the data input provided by SMUD and of the analyses performed by B&W Engineering. That evaluation was completed to the point at which B&W concurred with operation of the plant at full power on June 14, 1978 (references 1-4, attached). The following steps were involved in the evaluation:

1. Travel to the plant site to gather data for input to the investigation.
2. Determination of the specific cause(s) of the non-nuclear instrumentation (NNI) power failure and development of a list of instrumentation signals that were valid throughout the power failure.
3. Development of a sequence of events for the cooldown incident based on the valid signal list and data input.
4. Development of the probable plant transient response during the cooldown using the sequence of events and valid data. The transient response was displayed in various curves of temperature, pressure, and level versus time.
5. These curves were used to analyze the effects of the transient on the reactor vessel, the pressurizer, the reactor coolant piping, the once-through steam generators, the reactor coolant pumps, the control rod drive mechanisms, the nuclear fuel, and the clamping force on the reactor internals.

3. RESULTS

1. The cause of the power failure in the NNI is described in reference 5 (summary attached).
2. Reference 5 also contains a list of the instrumentation signals that remained valid throughout the transient (summary attached).
3. The integrated control system response to the various false and valid signals is described in reference 6 (summary attached).
4. Reference 6 discusses the most probable sequence of events during the incident (summary attached).
5. The curves showing the reactor coolant system response (major parameters) are developed in references 7-9 (curves attached).
6. The fracture mechanics analysis performed on the reactor vessel using the conservative approach outlined in the ASME Code, Section III, Appendix G, resulted in a calculated factor of safety of 1.8 for the beltline region and 1.2 for the outlet nozzles (reference 10, attached).
7. A review of the transient effects on the reactor coolant pump seals concluded that there were no apparent effects on seal performance, and continued operation of the pumps was permissible (reference 11). Cyclic stresses and lifetime usage factor changes for the reactor coolant pump casings are not expected to be affected; however, they are currently being evaluated by the consultant who prepared the original stress report. The report of that evaluation will be filed as an addendum to this document.
8. The transient was found to be less severe than the control rod drive mechanism (CRDM) transient that normally follows a reactor trip. There are no concerns about long-term damage to the CRDMs or about their ability to continue to perform as designed (reference 12, attached).
9. Evaluation of the transient's effects on the nuclear fuel has concluded that it will not adversely affect fuel performance for the remainder of its design life (reference 13, attached).

10. Neutron noise data from SMUD were evaluated to verify that clamping force still existed between the core support assembly and the reactor vessel. This evaluation indicated that a post-transient beam mode existed in the vicinity of 9-11 Hz, strongly suggesting that reactor vessel/core support assembly clamping still exists (references 14, 15, attached).
11. The study of the increase in usage factor for the reactor vessel resulted in a maximum usage factor (in the instrumentation tube area) of 0.58 (reference 16, attached).
12. None of the cumulative usage factors for the components of the pressurizer were increased by the transient except for that of the pressurizer spray nozzle. The new cumulative usage factor for this nozzle is 0.345 (reference 17, attached).
13. The highest cumulative usage factor in the reactor coolant piping is 0.762; this is found in the surge line (reference 18, attached).
14. The OTSG support skirt stress evaluation resulted in a new cumulative usage factor of 0.91 (reference 19, attached).
15. The OTSG lower tubesheet and tube stress evaluation shows that the stresses and usage factors, including the results of the rapid cooldown, remain well within the Code-allowables, and the structural adequacy of these areas has not been impaired (reference 20, attached).

4. CONCLUSIONS

The total effect of the rapid cooldown transient on the reactor coolant system components was not severe enough to reduce the design life of any of the system components.*

*Cyclic stresses and lifetime usage factor changes for the reactor coolant pump casings are not expected to be affected; however, they are being evaluated by the consultant who prepared the original stress report. The results of that evaluation will be reported in an addendum to this document.

5. REFERENCES

1. J. T. Janis (B&W) to R. J. Rodriguez (SMUD), Letter, "Rancho Seco Nuclear Generating Station - Unit No. 1, Evaluation of NSS Cooldown Transient," March 23, 1978.
2. R. P. Oubre (SMUD) to J. T. Janis (B&W), Letter Requesting Evaluation of SMUD Maneuvering Rates During Startup, March 28, 1978.
3. J. T. Janis to R. P. Oubre, Letter, "Rancho Seco Nuclear Generating Station - Unit No. 1, Plant Startup Following 3/20/78 Trip Transient," April 5, 1978.
4. J. T. Janis to R. J. Rodriguez, Letter, "Rancho Seco Nuclear Generating Station - Unit No. 1, Evaluation of NSS Cooldown Transient," June 14, 1978.
5. B. J. Shepherd to J. A. Castanes, Memorandum, "Loss of NNI Power at Rancho Seco," Babcock & Wilcox, May 1, 1978.
6. R. W. Moore to J. J. Kelly, Memorandum, "QA of Cooldown Incident Analysis," Babcock & Wilcox, June 8, 1978.
7. S. G. Shell, Temperatures - SMUD Rapid Cooldown Incident, Calculation No. 32-8053-00, Babcock & Wilcox, May 1, 1978.
8. J. R. Burris to J. J. Kelly, Memorandum, "SMUD March 20, 1978 Cooldown," Babcock & Wilcox, May 8, 1978.
9. B. A. Karrasch to G. M. Olds, Memorandum, "SMUD Cooldown Incident," Babcock & Wilcox, March 29, 1978.
10. Fracture Mechanics Evaluation of the Reactor Vessel of the SMUD Unit at Rancho Seco for the Unanticipated Transient on 3/20/78, Babcock & Wilcox, Document No. 32-9801-00, October 12, 1978.
11. G. G. Anderson to J. J. Kelly, Memorandum, "Effect of Pressure and Cooldown Transient on RC Pumps," Babcock & Wilcox, April 19, 1978.

12. CRDM Evaluation of SMUD Cooldown, Babcock & Wilcox, Document No. 32-9016-00, April 25, 1978.
13. SMUD Depressurization Transient, Babcock & Wilcox, Document No. 86-1863-00, May 10, 1978.
14. D. E. Thoren to D. M. Stevens, Memorandum, "Neutron Noise Data Related to the Cooldown Transient of 3/20/78," Babcock & Wilcox, September 26, 1978.
15. C. W. Mayo/D. M. Stevens to D. E. Thoren, "Neutron Noise Data at SMUD," October 3, 1978.
16. "Rapid Cooldown Transient Fatigue Analysis (Reactor Vessel)," Babcock & Wilcox, Mt. Vernon, Indiana, May 31, 1978.
17. "SMUD Cooldown Incident Justification of Pressurizer for SMUD, B&W Contract No. 620-011-59," Babcock & Wilcox, Mt. Vernon, Indiana, June 7, 1978.
18. "SMUD Cooldown Incident Justification of Primary Piping," Babcock & Wilcox, Mt. Vernon, Indiana, June 9, 1978.
19. "OTSG Support Skirt Stress Evaluation of Rapid Cooldown Event of March 20, 1978," Babcock & Wilcox, Mt. Vernon, Indiana, August 29, 1978.
20. "OTSG Lower Tubesheet Area and Tube Stress Evaluation Due to the Rapid Cooldown Event of March 20, 1978," Babcock & Wilcox, Mt. Vernon, Indiana, June 9, 1978.

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

March 23, 1978

Mr. R. J. Rodriguez
Manager, Nuclear Operations
Sacramento Municipal Utility District
6201 S. Street
Sacramento, California

Subject: Rancho Seco Nuclear Generating Station - Unit No. 1
Evaluation of NSS Cooldown Transient

Dear Mr. Rodriguez:

B&W has reviewed the data provided by SMUD regarding the March 20, 1978 reactor trip and resulting cooldown transient, and have performed the following evaluations:

1. Evaluation of RCP seal performance data prior, during and subsequent to the transient.
2. Evaluation of transient conditions with respect to RCPs and CRDMs.
3. Evaluation of transient conditions with respect to fuel assemblies.
4. Evaluation of transient conditions with respect to RV, RC piping, pressurizer, and OTSGs.

As a result of these evaluations, B&W concurs with SMUD's intent to return Rancho Seco to power operation at a power level at or below 75% full power with the following recommendations:

1. The following maneuvering limits be applied for this plant startup:
 - a. The maximum rate of power increase below 20% full power shall be 10% per hour.
 - b. The maximum rate of power increase between 20% and 40% full power shall be 30% per hour.
 - c. Above 40% full power, escalation shall be limited to 3% per hour.
2. Increased surveillance of the loose parts monitoring system for at least a one-week period.
3. Performance of an operability check of on-line and redundant NNI instrumentation.

MARCH 23, 1978

4. Establishment of a procedure for restoring NNI power in the event of a power loss and a commitment to establish by April 7, 1978 operator instructions for immediate action to limit NSS transient if NNI power cannot be immediately restored.
5. Surveillance of primary and secondary radiochemistry on a minimum of a daily basis for at least one week following startup.

B&W NPGD's concurrence with operation of Rancho Seco above 75% full power is contingent upon our QA evaluation of data input provided by SMUD and analyses performed by B&W Engineering, and you will be informed of completion of these activities and our concurrence in a timely manner.

In addition, B&W is performing an evaluation to determine the effects of the transient conditions on the Reactor Coolant System accumulative usage factor and will advise you of those results. As a further measure of verification of OTSG tube integrity, B&W requests additional inspection of the OTSG tubes during your next refueling outage. Those inspection recommendations will be forwarded to SMUD along with B&W's proposed refueling inspection plan prior to the outage.

If you have any questions or require additional information, please advise.

Very truly yours,

Joel T. Janis
Service Manager

JTJ/hh

cc: JJ Mattimoe
DG Raasch
RP Oubré
JH Johnston

bcc: RM Ball
R Berchin
JA Castanes
JC Deddens
BA Karrasch
ER Kane
JH MacMillan
GM Olds
JD Phinney
T Schuler
KE Suhrke
JH Taylor
Record Center NSS-11 T1.2



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

RPO 78-28

March 28, 1978

Mr. Joel Janis
Babcock & Wilcox
P. O. Box 1260
Lynchburg, Virginia 24505

Dear Joel:

Per discussion with you on Monday, March 27, you requested a chronology of our rise to power over the past weekend. Listed below is that chronology showing the rate of change of power level for the three rises in power.

Criticality @ 1607	3/24/78
0-20% 8%/hr	3/24/78
20-42.5% 6%/hr	3/24/78
Turbine/Reactor Trip at 2230	3/24/78

Criticality @ 0112	3/25/78
0-20% 8%/hr	3/25/78
20-40% 26%/hr	3/25/78
40-55% 3%/hr	3/25/78
55-62% essentially 0%/hr	
over a 20-hour period	
extending into 3/26/78	

Reactor reduced to 10^{-8}	
intermediate range amps	3/26/78
0-20% 10%/hr	3/26/78
20-30% 17%/hr	3/27/78
50-55% 3%/hr	3/27/78
55-72% 12%/hr	3/27/78

You will note that on the rise to power from 55 to 72% on Monday, March 27, the rate of change was at 12% per hour. This exceeded the recommended rate of change given to SMUD in your letter of March 23, 1978. I request B&W review this rate of change and respond to SMUD on any effect which it may have had. I would appreciate your response as soon as possible.

Respectfully,

R.P. Oubre
Plant Superintendent

RPO:sal

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

April 5, 1978

Mr. R. P. Oubre'
Plant Superintendent
Sacramento Municipal Utility District
6201 S. Street
Sacramento, CA

Subject: Rancho Seco Nuclear Generating Station - Unit No. 1
Plant Startup Following 3/20/78 Trip Transient

Reference: SMUD letter, RP Oubre' to JT Janis, RPO 78-28, dated
3/28/78


Dear Mr. Oubre':

The chronology of SMUD's rise to power beginning March 24, 1978, as outlined in the reference, has been reviewed by B&W. The extended period at 55-62% power starting March 25, 1978 served to prepare the fuel for the 12%/hour increase between 55 and 72% power on March 27, 1978. Therefore, the intent of the maneuvering recommendations has been met.

As a precautionary measure, coolant chemistry analysis should be performed frequently until equilibrium conditions are achieved.

If you have any questions or require additional information, please advise.

Very truly yours,



Joel T. Janis
Service Manager

JTJ/hh

cc: DG Raasch
RJ Rodriguez
JH Johnston

bcc: R. Berchin
RV DeMars
GL Knock
BA Karrasch
JD Phinney
GM Olds
Record Center - NSS-11/T1.2

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

June 14, 1978

Mr. R. J. Rodriguez
Manager, Nuclear Operations
Sacramento Municipal Utility District
6201 S. Street
Sacramento, California

Subject: Rancho Seco Nuclear Generating Station - Unit No. 1
Evaluation of NSS Cooldown Transient

Reference: B&W letter, JT Janis to RJ Rodriguez, dated March 23, 1978


Dear Mr. Rodriguez:

The referenced letter provided B&W's concurrence to operate Rancho Seco at power levels below 75% full power following our evaluation of the March 20, 1978 reactor trip and resulting rapid cooldown transient. This letter also stated that B&W's concurrence with operation above 75% power was contingent upon our QA evaluation of data input provided by SMUD and analysis performed by B&W engineering. These functions have been completed to the point where B&W now concurs with operation of Rancho Seco at full power.

It is recommended that for the initial escalation the maximum rate of power increase above 70% full power shall be 3% per hour with a ten (10) hour hold at the power level cut-off. Above the power level cut-off, the maximum rate of power increase shall continue to be 3% per hour to 100% full power.

If you have any questions or require additional information, please advise.

Very truly yours,


Joel T. Janis
Service Manager

JTJ/hh

cc: JJ Mattimoe
DG Raasch
RP Oubre'
JH Johnston

Reference 5 - Summary

DESCRIPTION OF CAUSE OF POWER FAILURE TO NON-NUCLEAR INSTRUMENTATION

B&W NNI System Design

The NNI system is divided into two sets of cabinets, called X and Y. Power is provided to the X and Y cabinets as shown in Figures A-1 and A-2, respectively. The X cabinets have one 120-V a-c power source, and the Y cabinets have two. One of the two Y cabinet power sources provides power only to signal select switches; this power enables selection of both X and Y sensor signals.

SMUD Modification of NNI System Design

After delivery of the NNI system, SMUD modified the Y cabinet power design as shown in Figure A-3.

Loss of NNI Power

On March 20, 1978, at approximately 0426 hours, an operator in the Rancho Seco control room was changing an indicating light bulb in the signal select switch (SP10-MS) for the turbine throttle pressure transmitters. The bulb was inadvertently dropped into this switch, causing a short on the 24-volt power supply. With the SMUD modification to the NNI power supply, this resulted in loss of all 24-volt power in the Y cabinets.

The Y cabinet power distribution, as shown in Figure A-3, consists of primary and backup positive and negative 24-V d-c power supplies provided with 120-V a-c power via input breakers S1 and S2, located on the 24-volt power auctioneer panel. The primary and backup 24-volt power supplies are current-limited to 7.5 amperes. Upon overload of either positive or negative 24-volt bus, the power supply monitor trips input breakers S1 and S2 to protect the power supplies.

Subsequent measurement of the current load on the negative 24-volt power supplies revealed 2.3 and 3.5 amperes at steady-state conditions. The power source to signal select switch (SP10-MS) was fused with a Bussman CLD 5-amp 125 V (or less) rated fuse.

When the short occurred and current reached 7.5 amps, current-limiting of the power supplies went into effect until the power supply monitor tripped power

input breakers S1 and S2. During this time current through the 5-amp fuse for signal select switch SP10-MS could reach only 4 amps; therefore, it did not blow.

When breakers S1 and S2 opened, all signal select switch functions were inoperative and the 820 auxiliary relay contacts went to the de-energized state because the relay coils were powered from the Y 24-volt power. Sensors that operated from Y 120-V a-c power continued to function although all modules in the NNI cabinets that used 24-volt power were inoperative. These modules provided erroneous outputs over the signal range of -10 to +10 V dc, depending on the characteristics and design of each module. Sensors and modules in the X cabinet were affected by the inoperative Y power signal select auxiliary relays.


LIST OF SIGNALS VALID THROUGHOUT TRANSIENT

<u>Parameter</u>	<u>Cabinet power source</u>	<u>Valid signal available to:</u>				<u>ICS</u>
		<u>Computer</u>	<u>Control room operator</u>	<u>Hot shutdown panel oper</u>		
RC5A-TT1 -- Tc narrow-range (SMUD loop B)	X	Yes	No	No	No	
RC5B-TT1 -- Tc narrow-range (SMUD loop A)	X	Yes	No	No	No	
RC5A-TT2 -- Tc wide-range (SMUD loop B)	X	Yes	No	No	No	
RC1-LT1 -- Pressurizer level	X	Yes	No	Indicator	No	
RC1-LT2 -- Pressurizer level	X	Yes	No	No	No	
RC1-LT3 -- Pressurizer level	Y	No	No	Indicator	No	
RC2-TT1 -- Pressurizer temperature	X	Yes	No	No	No	
RC4A-TT1 -- Th narrow range (SMUD loop B)	X	Yes	No	No	No	
RC3A-PT3 (ESFAS) -- RC pressure, wide range (SMUD loop B)	X	None derived from NNI	Recorder	Indicator	No	

Parameter	Cabinet power source	Valid signal available to			
		Computer	Control room operator	Hot shutdown panel oper	ICS
RC3A-PT1 (RPS) - RC pressure, narrow range (SMUT loop B)	X	None derived from NNI	Recorder	No	No
RC3B-PT1 (RPS) -- RC pressure, narrow range (SMUD loop A)	Y	None derived from NNI	Recorder	No	No
RC pump seal & brg temperatures (all four RC pumps)	X	No	Recorder	No	No
RC pump seal cavity pressure (all four RC pumps)	X	No	Recorder	No	No
SP1A-LT4 - SG start-up level (SMUD loop B)	X	Yes	No	Indicator	No
SP1B-LT4 - SG start-up level (SMUD loop A)	Y	No	No	Indicator	No
SP1A-LT1 - SG full-range level (SMUD loop B)	X	Yes	Indicator	No	No
SP1B-LT1 - SG full-range level (SMUD loop A)	X	Yes	Indicator	No	No
SP4A-TT - SG outlet temp (SMUD loop B)	X	Yes	Indicator	No	No
SP6A-PT1 - SG outlet pressure (SMUD loop B)	X	Yes	No	Indicator	No
SP3A-TT1 - SG lower downcomer temp (SMUD loop B)	X	Yes	No	No	No
SP1A-LT2 - SG operate level (SMUD loop B)	X	Yes	No	No	No
SP10A-PT - turbine throttle pressure	X	Yes	No	No	No
SP5A-TT1 - FW temp (SMUD loop B)	X	Yes	No	No	No
SP8A-dpT1 - main FW flow (SMUD loop B)	X	Xmtr ΔP & temp-comp FW flow	No	No	No

<u>Parameter</u>	<u>Cabinet power source</u>	<u>Valid signal available to</u>			
		<u>Computer</u>	<u>Control room operator</u>	<u>Hot shutdown panel oper</u>	<u>ICS</u>
SP7A-dpT - startup FW flow (SMUD loop B)	X	Yes	No	No	No
MU42-dpT - RC pump seal injection flow	X	No	Indicator	No	No
MU7-dpT 1-4 - RC pump seal water flow	X	No	Indicator	No	No
MU37-FT1-4 - RC pump seal bleed-off flow	X	Yes	No	No	No
MU23-dpT1 & 2 - HPI flow	X	No	Indicator	No	No
MU14-LT1 - makeup tank level	X	Yes	No	Indicator	No
MU4-dpT - makeup letdown flow	X	Yes	Indicator	No	No
MU5-TT - letdown cooler outlet temp	X	No	Indicator	No	No
MU24-dpT - RC makeup flow	X	No	Indicator	No	No
DH1-dpT1 - LPI flow	X	No	Indicator	No	No
DH6-TT1 - DH pump suction temp	X	No	Indicator	No	No
CF1-PT1 - CFT B press	X	No	Indicator	No	No
CF1-PT3 - CFT A press	X	No	Indicator	No	No
CF2-LT1 - CFT B level	X	No	Indicator	No	No
CF2-LT3 - CFT A level	X	No	Indicator	No	No
DH7-TT1 - DH cooler outlet temp	X	No	Indicator	No	No
DH9-TT1 - DH cooler cooling water outlet temp	X	No	Indicator	No	No

FIGURE A-1
 NNI "X" POWER B&W DESIGN



POOR ORIGINAL

FIGURE A-2
 NNI "Y" POWER B&W DESIGN





FIGURE A-3
SMUD NNI "Y" POWER DESIGN



POOR ORIGINAL

Reference 6 - Summary

ICS ACTIONS FOLLOWING LOSS OF POWER TO NNI

1. Partial loss of feedwater due to ICS limiting feedwater to SG A on Btu limits.
2. Turbine valve position demand increased.
3. ICS initiates runback in tracking mode.
4. Following reactor trip, ICS runs back FW demand to both generators.
5. Reduction of FW demand and/or invalid feed valve ΔP signal causes runback of main FW pump speed by ICS.
6. Reduction of FW demand by ICS closes SG A and B main FW control valves.
7. Reduction of FW demand by ICS closes SG A and B startup FW control valves to less than 50% open and main block valves receive signals to close.
8. Invalid SG B outlet pressure signal opens B condenser dump valves and/or invalid generator level signal closes B feed valves.*
 - Steam line failure logic closes ICS-controlled SG B startup valve; not an ICS action.
 - ~~Operator takes manual control of the speed of one main feed pump.~~
9. Following SFAS actuation, ICS continues to influence FW flows to the generators through the startup valves when the valve controls are not overridden by the steam line failure logic. ~~# Also, any ICS actuation of turbine bypass valves continues after SFAS actuation.~~
10. Upon restoration of NNI power and of valid signals to the ICS, all startup valve and emergency feed valve position demands are returned to zero, and any steam dump valves open to the condenser are closed based on SG level signals and steam line pressure signals.

- - - - -
*Accounts for observed depressurization of SG B.


#Steam line failure logic closes loop A (B) main control and startup valves to SG A (B) when A (B) steam line pressure falls below 425 psig.

SEQUENCE OF EVENTS AT RANCHO SECO
MARCH 20, 1978 - 0425 to 0534


Time	Event
0425:35	Lost NNI power supply cabinets 5, 6, and 7. This caused a loss of valid signals to the ICS. Btu limits ran back feedwater, resulting in a partial loss of feedwater (actual reactor power was 72%). Probable opening of B turbine bypass valves to the condenser (timing uncertain).
0425:44	Reactor trip on high pressure, turbine trip on interlock. Pressurizer code relief setting was known to be low (about 2225 psig). The electromatic relief was isolated due to previous leakage problems. The data indicate primary pressure went \approx 2400 psig => code relief valve lifted. ICS closes main control and startup feed valves and drives main feed pumps to minimum speed following trip. Decay heat and RC pump energy removal accomplished through generators by inventory boiloff and the addition of main feedwater.
0426:15	Pressurizer code relief valve reseats at about 2100 psig. Operator starts HPI pump B.
0428:23	Operator stops HPI pump B.
0430	OTSG B pressure reaches 435 psig setpoint of steam line failure logic. OTSG B goes dry. Operator increases speed of an MFP and feeds OTSG A, which starts RCS on pressure and temperature decrease.
0434:25	RC pressure \approx 1900 psi.
0437:16	SFAS actuation at 1600 psig. This starts HPI, LPI and initiates emergency feed. The emergency FW pump is started and the bypass emergency FW valves are opened to full-open position. The system makes no automatic attempt to control SG water level.
0440	RC pressure at 1475 psig. It starts to recover from this point due to HPI. $T_{avg} = 528F$.
0443:56	HPI pump A secured.
0446:09	LPI secured.
0449:34	HPI A initiated. From this point on, the operator started and stopped HPI pumps as necessary to maintain pressurizer level.
0450	Steam line failure logic closes ICS-controlled startup feed valves to each OTSG when the corresponding OTSG pressure falls below 435 psig.

<u>Time</u>	<u>Event</u>
0451:25	Secured RCP D ($T_{avg} = 435F$). This reduced the number of RC pumps to three.
0457:27	OTSG A water level = 599.7 inches. Speculate that about 2 feet of tubes are not flooded (at top) due to steam line arrangement.
0500:00	Hourly computer log printout - steam temp 380F (OTSG B), steam pressure 171 psig (OTSG B), assuming that $T_{avg} = T_{sat} = >T_{avg} = 380F$.
0513:47	OTSG B level = 599.1 inches.
0534	Power restored to NNI cabinets 5, 6, and 7. $T_{avg} = 285F$; RCS pressure = 2000 psig; both OTSG full level ranges pegged high. Operator begins to reduce RC pressure using pressurizer spray. ICS closes turbine bypass valves to condenser. Operator stops emergency feedwater flow. Operator stops main feedwater pumps.


Reference 9 - Pressure, Temperature, Level Vs Time Curves



POOR ORIGINAL



POOR ORIGINAL



POOR ORIGINAL

Reference 10 - Document Release Notice

CONTRACT/STANDARD NO. 620-0011		DOCUMENT RELEASE NOTICE (DRN) *	
RELEASE DATE Oct 12, 1977	PAGE 1	OF 1	

PART/TASK-GROUP-SEQ.	B&W DOCUMENT NO.	DOCUMENT TITLE	PUL STAT.	RRL NO.
62-01-001	32-9801-00	EVALUATION OF B&W DOCUMENTS		

FILE COPY

POOR ORIGINAL

DISTRIBUTION	NO COPIES		RELEASER'S INITIAL	NO COPIES		RELEASED BY	
	DRN	DOC		DRN	DOC	NAME	DATE
AF 118200	1	1	2	1	J. F. Lyons	Oct 12, 1977	
SB SWAR	1	1					
J. M. BURTON	1	1					
J. S. KELLY	1	1					

REVIEWED BY	
SB Swar	Oct 12, 1977
NAME	DATE

CALCULATION DATA/TRANSMITTAL SHEET

DOCUMENT IDENTIFIER

CALC. 32 - 9801 - 20 *
 TRANS. 86 - _____

TYPE: RESEARCH & DEVELOPMENT SAFETY ANALYSIS REPORT WOC. SERV. INPUT DESIGN RPT. DESIGN VERIF. OTHER

TITLE EVALUATION OF RAUCHO SECO TRANSIENT

PREPARED BY C E Harris REVIEWED BY S. B. SKAAR

TITLE Engineer DATE 10/12/78 TITLE Associate Engineer DATE 10/12/78

PURPOSE:

To analyze RAUCHO SECO transient from a structure mechanics viewpoint using guidelines of ASME Code, Section II, Appendix A.

SUMMARY OF RESULTS (INCLUDE DOC. ID'S OF PREVIOUS TRANSMITTALS & SOURCE CALCULATIONAL PACKAGES FOR THIS TRANSMITTAL)

The bellline region throughout the transient was determined to be structure-safe with a factor of safety of 1.8, and the outlet nozzle was determined to have a factor of safety of 1.2.

POOR ORIGINAL

DISTRIBUTION

- CE HARRIS
- SB SKAAR
- JM BURNETT

FRACTURE MECHANICS EVALUATION OF THE REACTOR VESSEL OF THE SHUD UNIT AT RANCHO
SECO FOR THE UNANTICIPATED TRANSIENT ON 3/20/78

A fracture mechanics analysis of the reactor vessel has been performed using the conservative approach outlined in the ASME Code, Section III, Appendix G. Specific details of the analytical approach are documented in B&W Topical Report BAW-10046A, Rev. 1.

Analyses were performed on the two most critical areas of the reactor vessel - the beltline region and the outlet nozzle region. At the lowest temperature during the transient the material is still in the upper shelf region (ductile behavior). Due to the low level of radiation, degradation to beltline region materials is not significant enough to produce a shift in the transition reference temperature. Consequently, the beltline region materials are also at the upper shelf toughness region.

Factors-of-safety for the beltline region and outlet nozzles have been calculated as follows:

$$F. \text{ of } S. = \frac{K_{IR}}{K_{Im} + K_{It}}$$

where K_{IR} is the reference stress intensity factor

K_{Im} is the stress intensity factor due to pressure

K_{It} is the stress intensity factor due to the thermal gradient through the thickness

The factor-of-safety for the beltline region is 1.8.
The factor-of-safety for the outlet nozzles is 1.2.

Detailed calculations are provided on sheet 3 of 3.

It should be recognized that this is a very conservative analysis. A postulated flaw size of $1/4t$ is assumed for the beltline region and the 3.0" nozzle corner flaw is assumed for the outlet nozzle. The material fracture toughness (reference stress intensity value) used is $200 \text{ ksi}\sqrt{\text{in}}$. Finally, the calculation of the stresses associated with the transient is conservative.

Charles E. Harris

Charles E. Harris, PE
March 23, 1978

Henrik S. Palme

Henrik S. Palme
March 23, 1978

ADJUSTED REFERENCE TEMPERATURE OF BELTLINE REGION

WF-70 in the longitudinal seam of the lower shell is the governing weld in the beltline region. Approximately 75% of this weld from the I.D. is WF-70, therefore, the $1/4T$ and $3/4T$ RTNDT will be determined for WF-70.

Number of EFPD ACCUMULATED

AT TIME OF TRANSIENT 3/20/78 = 567 = 1.55 EFPY

This corresponds to a conservative max. fluence at the vessel inner surface = $1.1 \times 10^{18} \text{ n/cm}^2$ †

$$F_{1/4T} = 6.1 \times 10^{17} \text{ n/cm}^2$$

$$F_{3/4T} = 8.1 \times 10^{16} \text{ n/cm}^2$$

For WF-70

% Cu = 0.27

% P = 0.014

$$F_{1/4T} = 4.7 \times 10^{17} \text{ n/cm}^2$$

$$F_{3/4T} = 6.3 \times 10^{16} \text{ n/cm}^2$$

Note that the longitudinal seam is not at the same azimuthal location as the maximum fluence.

From Reg. G.1.99

$$\Delta RT_{NDT} \bigg|_{1/4T} = 56^\circ\text{F}$$

$$\Delta RT_{NDT} \bigg|_{3/4T} = 21^\circ\text{F}$$

$$RT_{NDT} = 20^\circ\text{F unadjusted}$$

The adjusted reference temperatures are:

$1/4T$	Adj. $RT_{NDT} = 76^\circ\text{F}$
$3/4T$	Adj. $RT_{NDT} = 41^\circ\text{F}$

POOR ORIGINAL

† Design curve is from the report for Phase Ib of the User's Group Program for the evaluation of reactor vessel material properties.

Charles E. Harris, PE
March 22, 1978

CALCULATIONS:

BASIC RELATIONSHIP $2K_{IM} + K_{IT} \leq K_{SR}$

BELTLINER REGION

$(2K_{IM} + K_{IT})_{MAX} = 174.366 \text{ Ksi}\sqrt{in}$ (M13CCAJ)*
LQ41 3/22/78

$K_{IM} = P M_m \frac{r_i^2 + r_o^2}{r_o^2 - r_i^2}$ (BAW-10046A, Rev. 1)
Removing the F.o.S. of 2

time = 40 mins.
temp $T = 468^\circ F$

$P = 2100 \text{ Psi}$

$r_i = 85.5 \text{ in.}$

$r_o = 94.0 \text{ in.}$

$M_m = 2.9$ (ASME Code Appendix G, Fig G-2214.1)

$K_{IM} = 64.45 \text{ Ksi}\sqrt{in}$

$K_{IT} = 174.366 - 2(64.45) = 45.47 \text{ Ksi}\sqrt{in}$

F. of S. = $\frac{200 \text{ Ksi}\sqrt{in}}{64.45 + 45.47} = 1.82$

F. of S. = 1.82

NOZZLE REGION

$(2K_{IM} + K_{IT})_{MAX} = 247.286 \text{ Ksi}\sqrt{in}$ (M14CCAH)*
LQ41 3/22/78

time = 75 mins
temp $T = 392^\circ F$

$K_{IM} = P F \left(\frac{a}{r_o}\right) \frac{r_i^2 + r_o^2}{r_o^2 - r_i^2} \sqrt{tA}$ (BAW-10046A, Rev. 1)
Removing F.o.S. of 2

Computer runs M13CCAJ and M14CCAH are based on a computer code developed to perform the BAW-10046A, Rev. 1 calculations. It should be noted that the thermal stress intensities are based on a predefined temperature distribution through the vessel thickness that may not be the same as for this transient.

$P = 2100 \text{ Psi}$

$r_i = 84.1875 \text{ in}$

$r_o = 96.3130 \text{ in}$

$F(a/r_o) = 1.74$ (WRC Bulletin 175, Fig. A5-1)

$a = 3.0 \text{ in}$ (Appendix G, Section III, ASME Code)

$K_{IM} = 83.9 \text{ Ksi}\sqrt{in}$

$K_{IT} = 247.286 - 2(83.9) = 79.49 \text{ Ksi}\sqrt{in}$

F. of S. = $\frac{200 \text{ Ksi}\sqrt{in}}{83.9 + 79.49} = 1.22$

F. of S. = 1.22

POOR ORIGINAL

Charles E. Harris, PE
March 22, 1978

FIGURE 1


SM110 RAPID COOLDOWN 3/20/73

DC TEMPERATURE



POOR ORIGINAL

PKS 3/24/73



POOR ORIGINAL

CONTRACT/STANDARD NO. 620-0011		DOCUMENT RELEASE NOTICE (DRN)	
RELEASE DATE 5/3/78	PAGE 1 OF 15		

PART/TASK-GROUP-SEQ.	B&W DOCUMENT NO.	DOCUMENT TITLE	PUL STAT.	RRL NO.
43-53-001	32-9016-00	CRDM EVALUATION OF SMVD COOLDOWN	NO	

POOR ORIGINAL

DISTRIBUTION	NO COPIES		NO COPIES		RELEASED BY	NAME	DATE
	DRN	DOC	DRN	DOC			
Originator	1	1			R. A. Cox	5-1-78	DATE
G. E. Rothberger		1					
J J Kelly	1	1					
J T Lewis	1	1			A. E. Rothberger	5-2-78	DATE
W R Gray	1	1					
Central Files	1	1					

CALCULATION DATA/TRANSMITTAL SHEET

DOCUMENT IDENTIFIER
 CALC. 32 - 9016 - 00
 TRANS. 86 - - -

TYPE: RESEARCH & DEVELOPMENT SAFETY ANALYSIS REPORT MOC. SERV. INPUT DESIGN EQMT. DESIGN VERIF. OTHER

TITLE CRDM EVALUATION OF SMVD COOLDOWN

PREPARED BY R.A. Coe REVIEWED BY Jay E. Rothberger

TITLE Asst. Eng. DATE 4-14-78 TITLE Test Eng. DATE 4/25/78

PURPOSE: The purpose of this calculation is to evaluate the CRDM performance during the cooldown transient which occurred at the SMVD site on March 20, 1978.

SUMMARY OF RESULTS (INCLUDE DOC. ID'S OF PREVIOUS TRANSMITTALS & SOURCE CALCULATIONAL PACKAGES FOR THIS TRANSMITTAL)

The RCS cooldown transient of March 20, 1978 was found to be not as severe as the CRDM cooldown transient that normally follows a trip. There are no concerns about long term damage to the CRDMs or about their ability to continue to perform as designed.

POOR ORIGINAL

DISTRIBUTION

BABCOCK & WILCOX
GENERAL CALCULATIONS

32-9016-00

The purpose of this calculation is to evaluate the CRDM performance during the cool down transient which occurred at the SMVD site on March 20, 1978. Data from this transient was transmitted to the Mechanical Equipment Unit via letter from J.J. Kelly to Distribution on March 30, 1978. A short summary of the time-history events which affect the CRDMs is presented here:

4:25:44 Drives trip; RCS @ 565°F

4:35:16 RCS Cold leg temp. begins to drop at 119.5°F/hr. Cool down continues until 5:40

5:40 RCS cold leg temp. begins to increase to hot standby.

The CRDM temp. history will be evaluated in two parts. The trip transient occurs first followed by the RCS transient after ten minutes.

POOR ORIGINAL

CUSTOMER	SMVD	PROP. NO.	CONT. NO.
SUBJECT	RCS COOLDOWN	DWG. NO.	FILE NO.
		COMP. NO.	GROUP NO.
CALC BY	RAC DATE 4-7-78	BY	4/25/78
		SHEET NO.	2 of 14

FROM E. W. Swanson 3/21/78

ATTACHMENT 3 of Kelly's letter 3 of 14

RAC 4-17-78

RE/12/5

3

32-9016-00

SMUD TRIP

RC TEMPERATURE

TIME OF EVENT

COLD LEC. RC TEMPERATURE, F



POOR ORIGINAL

The Trip Transient**POOR ORIGINAL**

The RCS temperature before the trip was 565°F. At this RCS temperature, the maximum temperature of the motor tube is about 265°F per Topical Report BAW-10047-01, Figure A-4. The trip, occurring at 4:25, caused the usual hot water (565°F) to be injected into the motor tube. This would cause the motor tube temperature to rise to 350°F max in about one minute. The motor tube temperature then would drop exponentially at a rate determined from Figure A-4 of the above report. This temperature rate is approximated by the following equation:

$$T(t) = (T_{max} - T_{ss}) e^{-5.5 \times 10^{-3} t} + T_{ss}$$

where $T_{max} \equiv$ maximum motor tube temperature


$T_{ss} \equiv$ steady-state motor tube temp.

$t \equiv$ time (seconds)

The above equation was determined from the curves of Figure A-4.

CUSTOMER	SMVD	PROP. NO.	CONT. NO.
SUBJECT	RCS COOLDOWN	DWG. NO.	FILE NO.
		COMP. NO.	GROUP NO.
CALC BY	RAC 4-17-78	DESIGN	4/25/78
			SHEET NO 4 of 14

Figure A-4. Maximum Extension Temperature Vs Time for Test D



BADCOCK & WILCOX
GENERAL CALCULATIONS

32-9016-00

The maximum motor tube temperature as a function of time for the first ten minutes after a trip is tabulated as follows and shown in Figure 1.

$$T(t) = (350 - 265) e^{-5.5 \times 10^{-3} t} + 265$$

time	T(t)
0	265
60	350
120 (t = 60)	326
180 (t = 120)	309
240 (t = 180)	297
300 (t = 240)	288
360 (t = 300)	281
420 (t = 360)	277
480 (t = 420)	273
540 (t = 480)	271
600 (t = 540)	269

← trip occurs
← max. temp. reached in 60 sec.


POOR ORIGINAL!

← ten minutes after trip

It is apparent from the above table that the motor tube temperature has decayed to 95% of the steady-state motor tube temperature after 10 minutes, i.e. the trip transient is nearly dissipated when the RCS cooldown begins.

CUSTOMER	SMUD	PROP NO.	CONT NO.
SUBJECT	RCS COOLDOWN	DWG. NO.	FILE NO.
		COMP NO.	GROUP NO.
CRIC BY	RAC	DATE	4-17-78
		BY	SLR
		DATE	4/25/78
		SHEET NO.	6 of 14

3 24"



BABCOCK & WILCOX	DATE 4-17-78	BY RAC	REVISION
DEPARTMENT	CHECKED DATE 4-25-78	BY <i>[Signature]</i>	
SMUD RCS COOLDOWN	JOB NO.		SHEET 7 of 14

BABCOCK & WILCOX
GENERAL CALCULATIONS


32-9016-00

RCS Cooldown Transient

The RCS dropped 325°F in 65 minutes as shown in attachment 3 of Mr. Kelly's letter. The maximum motor tube temperature at the beginning of the RCS cooldown was 270°F . If a conservative ambient temperature of 90°F is assumed to surround the motor tube, the maximum motor tube temperature can not drop more than $270 - 90 = 180^{\circ}\text{F}$ during the RCS cooldown transient. The rate of motor tube temperature decrease is a determining factor since, if this rate exceeds the normal cooldown rate following a trip, thermal stresses will be greater than the trip transient's. The purpose of the following development is to show that the cooldown rate for the motor tube during the RCS transient does not exceed the cooldown rate following a trip.

POOR ORIGINAL

CUSTOMER	SMVD	PROP NO	CONT. NO
SUBJECT	RCS COOLDOWN	DWG NO	FILE NO.
		COMP NO	GROUP NO
CALC BY	RAC 4-17-78	DR	SHEET NO 8 of 14



$$T(x) = (T_{RCS} - T_{AMB}) \frac{\cosh m(L-x)}{\cosh mL} + T_{AMB}$$

The CRDM can be thought of as a fin of some length, L , where L is the distance from the end of the motor tube to the point where the temperature equals the RCS temperature. The above equation describes this physical situation and is taken from Heat Transfer, A.J. Chapman, 3rd ed., Chapter 3, equation 3.54. The hyperbolic cosine term is a function only of (x) and can be evaluated at the point where the motor tube temperature is a maximum, $T_{MT(max)}$.

CUSTOMER SMUD	PROP NO.	CONT NO.
SUBJECT RCS COOLDOWN	DWG NO.	FILE NO.
	COMP. NO.	GROUP NO.
CALC BY RAC DATE 4-17-78	BY SSA	4/15/78
		SHEET NO 9 of 14

BABCOCK & WILCOX
GENERAL CALCULATIONS

32-9016-00

$$\frac{\cosh m(L-x)}{\cosh mL} = \frac{T_{MT(max)} - T_{AMB}}{T_{RCS} - T_{AMB}}$$

$$= \frac{270 - 90}{600 - 90} = \frac{180}{510} = \underline{\underline{0.353}}$$

where: $T_{MT(max)} = 270^\circ F$ (i.e. motor tube temp. at begin. of RCS transient)
 $T_{RCS} = 600^\circ F$ @ begin. of RCS transient
 $T_{AMB} = 90^\circ F$ conservative ambient temp

It is now possible to evaluate the maximum motor tube temperature as a function of RCS temperature.

$$T_{MT(max)} = (T_{RCS} - 90) 0.353 + 90$$

The following table lists maximum motor tube temperatures for various RCS temperatures.

The times listed are taken from attachment 3 of Mr. Kelly's letter for RCS temperature versus time. As a comparison, max. motor tube temperatures are also included for an ambient temp of $194^\circ F$.

POOR ORIGINAL

CUSTOMER	SMUD	PROP. NO.	CONT. NO.
SUBJECT	RCS COOLDOWN	DWG. NO.	FILE NO.
		COMP. NO.	GROUP NO.
CALC. BY:	RAC 4-17-78	SEA 4/21/78	SHEET NO. 10 of 14

BARCOCK & WILCOX
GENERAL CALCULATIONS

32-9016-00

for $T_{AMB} = 194$

$$\frac{\cosh m(L-x)}{\cosh mL} = \frac{270-194}{600-194} = \frac{76}{406} = \underline{0.187}$$

$$T_{MT(max)} = (T_{RCS} - 194) 0.187 + 194$$

RCS TEMP °F	TIME (MIN)	$T_{MT(max)}$ $T_{AMB} = 90$	$T_{MT(max)}$ $T_{AMB} = 194$
600	10	270	270
575	12	261	265
550	14	252	261
525	16	244	256
500	18.5	235	251
475	21	226	246
450	24	217	242
425	27	208	237
400	31	199	233
375	35	191	228
350	40	182	223
325	47	173	218

POOR ORIGINAL

CUSTOMER	SMVD	PROP. NO.	CONT. NO.
SUBJECT	RCS COOLDOWN	DWG. NO.	FILE NO.
		COMP. NO.	GROUP NO.
CALC BY	RAC 4-17-78	BY	DSR 4/17/78
		SHEET NO.	22 of 14

BABCOCK & WILCOX
 GENERAL CALCULATIONS

32-9016-00

Conclusion


The conclusion of this calculation is that the RCS cooldown transient of March 20, 1978 was not as severe as the cooldown transient that normally follows a trip. Since this transient was less severe than a normal transient, there are no concerns about long term damage to the CRDMS or about their ability to continue to perform as designed. Figure 2 shows the best estimation of the actual motor tube temperature during the cooldown incident. The ambient temperature surrounding the drive was within the 90 - 194°F range, but was not precisely known. Figure 3 gives a comparison of the motor tube response to the RCS transient versus the trip transient.

POOR ORIGINAL!

CUSTOMER	SMUD	PROP NO.	CONT. NO.
SUBJECT	RCS COOLDOWN	DWG NO.	FILE NO.
		COMP NO.	GROUP NO.
CALC BY	RAC DATE 4-17-78	ASR	4/25/78
			SHEET NO 12 of 14


5 247-1

FIGURE 2
MOTOR TUBE
MAXIMUM TEMPERATURE
TIME HISTORY



BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE 4-17-78 BY RAC	_____
SMUD RCS COOLDOWN	CHECKED DATE 4/25/78 BY BSR	_____
JOB NO.		SHEET 13 OF 14

FIGURE 3
COMPARISON OF
COOL DOWN TRANSIENTS



POOR ORIGINAL

BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE 4-17-78 BY RAL	
SMVD RCS COOLDOWN	CHECKED DATE 4/21/78 BY SEA	
JOB NO.		SHEET 14 OF 14

CONTRACT/STANDARD NO. 660-018B		DOCUMENT RELEASE NOTICE (DRN)
RELEASE DATE	PAGE 1 OF 1	

PART/TASK-GROUP-SEQ.	B&W DOCUMENT NO.	DOCUMENT TITLE	PUL STAT.	RRL NO.
15-001-001	86-1863-00	SMUD Transient	N	NA

DISTRIBUTION	NO COPIES			NO COPIES		RELEASED BY	
	DRN	DOC		DRN	DOC	NAME	DATE
J. J. Kelly	1	1	J. R. Smotrel	1	1	<i>W. J. Kelly</i>	5/10/88
For Information Only			R. A. Turner	1	1		
G. A. Meyer	1	1	D. D. Shelburne	1	1		
J. T. Willse	1	1	S. G. Harris	2	2		
A. B. Jackson	1	1	Return Original to me			<i>R. J. DeMars</i>	5/10/88
J. S. Tulenko	1	1	R. J. Parekh	1	1		
W. T. Brunson	1	1	R. V. DeMars	1	1		

CALCULATION DATA/TRANSMITTAL SHEET

DOCUMENT IDENTIFIER CALC. 32 - _____ - _____
 TRANS. 15 - 1863 - 00

TYPE: RESEARCH & DEVELOPMENT SAFETY ANALYSIS REPORT P.C. SERV. INPUT DESIGN EQPT. DESIGN VERIF.
 OTHER

TITLE SMUD Depressurization Transient

PREPARED BY W. J. West *W.J.W.* REVIEWED BY J.T. Willis
 TITLE Assistant Engineer DATE 5/10/78 TITLE Sup Eng. DATE 5/10/78

PURPOSE:

T-H evaluation of SMUD depressurization transient.

SUMMARY OF RESULTS (INCLUDE DOC. ID'S OF PREVIOUS TRANSMITTALS & SOURCE CALCULATIONAL PACKAGES FOR THIS TRANSMITTAL)

See attached memo.

See calculational file 32-9120-00.

DISTRIBUTION

See DRN.

THE PABCOCK & WILCOX COMPANY		
PWR GENERATION GROUP		
To	J. J. KELLY, PLANT INTEGRATION	THE-78-227
From	W. J. WEST, T-H ENGINEERING UNIT, EXT. 3243	12E12.04 BDS 663.5
Cust.	SMUD	File No. 86-1863-00 or Ref. 660-018B
Subj.	DEPRESSURIZATION TRANSIENT/FUEL EFFECTS	Date MAY 10, 1978

This letter to cover one customer and one subject only.

- References:
- 1) Memo, J. J. Kelly to Distribution, "Q.A. of Cooldown Incident Analysis," March 30, 1978.
 - 2) Computational file 32-9120-00.

A complete review of the March 30, 1978 SMUD depressurization transient has been completed. The following three areas of concern were evaluated:

I. Fuel Rod Compression Criteria

The fuel rod cladding did not experience a tensile force at any time during the depressurization transient.

II. Transient DNBR

No concern for DNBR magnitudes existed due to the combination of reactor trip with full flow conditions.

III. Fuel Assembly Lift

Review of the sequence of events during the transient indicate that most probably fuel assembly lift off occurred for a period of approximately ten minutes. This condition violated B&W's no lift criteria; however, the liftoff condition is not a safety concern.

Overall, the depressurization incident as outlined in Reference 1 will not adversely effect fuel performance for the remainder of it's design life, provided plant startup subsequent to the transient did follow the attached mechanical maneuvering recommendations.

WJW/sg

cc: G. A. Meyer
J. T. Willse
A. B. Jackson
J. S. Tulenko
W. T. Brunson
J. R. Smotrei
R. A. Turner
D. D. Shelburne
R. J. Parekh
R. V. DeMars

QA: The conclusions stated in this memo are correct.

John T. Willse Date 5/10/78

MECHANICAL MANEUVERING RECOMMENDATIONS

RANCHO SECO

CONTRACT

REVISION 0

DATE JUNE 3, 1977

The following are the recommended maneuvering limits for SMUD, Cycle 2:

1. The maximum rate of power increase below 20% full power shall be 10% per hour.
2. Above 20% power, normal operating procedures (Tech. Spec Limits) will apply unless the reactor has operated at less than 20% power for more than 48 hours.
3. If the power level has been below 20% full power for greater than forty-eight (48) hours, the maximum rate of power increase above 20% full power shall be 30% per hour with a five (5) hour hold at 20% full power below the power level cutoff and a five (5) hour hold at the power level cutoff. These holds can run concurrently with holds required by the Technical Specification.
4. During the initial power escalation at cycle startup or immediately following a control rod interchange, the initial escalation above the ~~75%~~ full power shall be limited to 3% per hour, with a five (5) hour hold at the power level cutoff. This hold can run concurrently with Technical Specification holds where applicable.
5. With the exception of item 4 above, no restrictions are placed on required physics startup tests.

J. B. Anderson, Jr.
FUEL ENGINEERING SECTION MANAGER

THE BABCOCK & WILCOX COMPANY POWER GENERATION GROUP		
To	D. M. STEVENS, LRC	
From	D. E. THOREN, STRUCTURAL MECHANICS UNIT (x2206)	BDS 663-5
Cust.	SMUD	File No. or Ref.
Subj.	NEUTRON NOISE DATA RELATED TO THE COOLDOWN TRANSIENT OF 3/20/78	Date SEPTEMBER 26, 1978

This letter to cover one customer and one subject only.

This memo is in follow up to our telecon of last week about the above subject.

Enclosed are the following:

- A. Two (2) sets of data obtained from signals from NI-7 and NI-5. Each set consists of,
 - PSD at 100% power before the cooldown transient in November 1977.
 - PSD, phase, coherence at 100% power. These results were obtained from signals recorded 5 months after the cooldown transient.
- B. A copy of a figure, Nuclear Instrumentation Detector Locations - Plan View, which shows the location of the NIs.

When we briefly examined these 2 sets several weeks ago, I believe we mutually agreed they indicated a beam mode of the core support assembly, in the vicinity of 9-11 Hz, still existed after the cooldown transient.

I request that you re-examine the two (2) sets and briefly document your conclusion derived from them.

DET:jvg

D. E. Thoren

cc: w/o attachments
J. M. Burnett
F. R. Burke

B-cock & Wilcox

Research and Development Division
LYNCHBURG RESEARCH CENTER
LYNCHBURG, VIRGINIA

To	D. E. THOREN, STRUCTURAL MECHANICS, NPGD ✓	File No. or Ref.
From	C. W. MAYO/D. M. STEVENS, NUCLEAR PHYSICS, LRC	Date
Cust.	SMUD	OCTOBER 3, 1978
Subj.	NEUTRON NOISE DATA AT SMUD	

This letter to cover one customer and one subject only.

Reference: Memo "Neutron Noise Data Related To the Cooldown Transient of March 20, 1978," D. E. Thoren to D. M. Stevens, September 26, 1978.

We have reviewed the data contained in the above reference and our conclusions are as follows:

1. The general shape of the PSDs of the excore detectors indicate that a beam mode resonance of the core support assembly exists after the cooldown transient. This fact is supported by the presence of high coherence and 180° phase.
2. Because of the arbitrary scaling of the data, changes in the magnitude of the beam mode resonance before and after the transient can not be determined.
3. Identification of detailed spectral features is not possible due to the limited resolution and dynamic range of the data.

C. W. Mayo / D. M. Stevens
C. W. Mayo/D. M. Stevens

jg

cc: T. C. Engelder
R. N. Kubik
R. H. Lewis

CONTRACT NO. 595-7072 620-0011		DOCUMENT COMMENT FORM		RELEASED BY <i>J.M. Burnett</i> 11/8/78	
SUPPLIER B&W		PREPARED BY: <i>J.M. Burnett</i>		TASK ENGINEER DATE	
PO. NO.		NAME DATE 11/8/78		REL. DATE PAGE 11-17-78 1 OF 1	

<u>PART/TGS</u>	<u>B&W DOC. NO.</u>	<u>DOCUMENT TITLE</u>	<u>CUSTOMER/ SUPPLIER DOC. NO.</u>	<u>STATUS</u>	<u>RRL NUMBER</u>
51-01-001		REACTOR VESSEL RAPID COOLDOWN TRANSIENT FATIGUE ANALYSIS FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT (RANCHO SECO)	620-0011- 51 CONTRACT #3075	APPROVED	N/A
33 0275 00					

DISTRIBUTION:

J.M. BURNETT (w/1 ATTACH)
 A.D. McKIM (w/1 ATTACH) - MTV
 J.J. Kelly (w/6 ATTACH)
 J.T. Janis (w/o ATTACH)

REACTOR VESSEL
Rapid Cool-down Transient
Fatigue Analysis

FCR

Sacramento Municipal Utility District
Rancho Seco

User Contract No. 3075
B&W Contract No. 620-0011-51

Prepared By: Alvin D. McKim 5-15-78
F. L. Boyer 5-15-78
Checked By: Douglas D. Huston 5/16/78
Approved By: H. Helmer 5/31/78

B & W DOCUMENT NUMBER

33 0275 00

8001210

554

TABLE OF CONTENTS

	<u>PAGE NO.</u>
Discussion.....	1
Results.....	2
References.....	3
Nomenclature.....	4
Transient Description.....	5
Nozzle Belt-Core Shell-Lower Head Analysis.....	7
Instrumentation Tube Analysis.....	13
Control Rod Drive Mechanism Housing Write Off.....	25
Closure Dome-Closure Flange Analysis.....	26
Closure Stud Write-Off.....	31
Nozzles-Nozzle Belt Analysis.....	32
Support Skirt Analysis.....	44
Core Flooding Venturi Write Off.....	50

APPENDIX A

<u>Computer Program</u>	<u>Page No.</u>
1) 91232 - Nozzle Belt	A-1 to A-8
2) 91232 - Shell.....	A-9 to A-16
3) 91232 - Lower Head.....	A-17 to A-24
4) 91206 - Nozzle Belt -Shell-Lower Head.....	A-25 to A-39
5) 91232 - Instrumentation Tube.....	A-40 to A-47
6) 91206 - Instrumentation Tube.....	A-48 to A-61
7) 91232 - Upper Head (Closure Dome).....	A-62 to A-69
8) 91232 - Closure Flange.....	A-70 to A-77
9) 91232 - Core Flooding Nozzle.....	A-78 to A-85
10) 91232 - Outlet Nozzle.....	A-86 to A-91

Discussion:

The upset transient information presented in reference #5 was used to analyze reactor vessel pressure retaining areas that experience high fatigue usage factors and/or high primary + secondary stress intensity ranges.

Primary + Secondary and the resulting fatigue usage factor are the only concern of this analysis; since, a brittle fracture analysis was previously completed and found to be acceptable and a ductile failure is not a credible mode of failure for pressures less than design pressure.

A conservative fatigue evaluation is performed at these locations assuming that three (3) cycles of this transient can occur over the forty years plant life. Each area that is analyzed will have a discussion of the conservative analysis method utilized.

Below is the list of the pressure retaining areas that are analyzed to account for the fatigue affect of the "cool-down incident":

- 1) Nozzle belt - core shell - lower head remote from attachments.
- 2) Instrumentation tube - lower head
- 3) Nozzles to nozzle belt
- 4) Support Skirt

Below is the list of areas that are justified by explanation which did not warrant calculations to be made.

- 1) Control rod drive mechanism housing
- 2) Closure studs
- 3) Core flooding venturi

The computer output used in this analysis is contained in Appendix A. The information used in the analysis from this output is easily obtainable by going to the table of contents which indicates where the appropriate computer run is in Appendix A.

SMUD RAPID COOLDOWN

A. D. McKIM

Results - Usage Factor Increases Due to Three Cycles of RCT

	Usage Factor original analysis	Usage Factor w/RCT	Usage Factor Increase
Nozzle belt-shell-lower head	0.0213	0.0219	0.0600
Instrumentation Tube	0.5700	0.5800	0.0100
Closure Dome-Flange	0.0343	0.0643	0.0300
Nozzles - Nozzle Belt	0.3500	0.4360	0.0860
Support Skirt	0.0700	0.2200	0.1500

Conclusion - All usage factors are less than one; therefore, acceptable.

SMUD RAPID COOLDOWN

A. D. McKIM

References

- 1.) Criteria of the ASME Boiler and Pressure Vessel Code for Design by Analysis in Sections III and VIII, Division 2 by The American Society of Mechanical Engineers United Engineering Center, 1969.
- 2.) Design Report for Sacramento Municipal Utility District, B&W Contract No. 620-0011-51/52, Customer Order No. 3075, dated March 1974.
- 3.) Computer Program 91232 - "Temperature Distribution In Long Cylinder."
- 4.) Computer Program 91206 - "Seal Shell Analysis with Axisymmetric Mechanical and Thermal Loading."
- 5.) J.M. Burnett memo to Distribution dated 4/4/78; Subject: SMUD Cooldown Incident.
- 6.) 1977 Edition ASME Section III with Addenda through Winter 1977.
- 7.) Design Report #6 - "Thermal Mechanical Stress Analysis of Reactor Lower Head and Support Skirt", Revision 1 dated 9-73.
- 8.) Program 91060 - "General Interaction Analysis for Shells of Revolution With Axisymmetric Loading".
- 9.) Design Report #4 - "Thermal/Mechanical Analysis of Primary Inlet & Outlet Nozzle", revision 1, dated 5-74.
- 10.) Design Report #5 - "Thermal/Mechanical Analysis of the Core Flooding Nozzle", revision 2 dated 5-74.
- 11.) Design Report #2 - "Closure Analysis", revision 1 dated 5-74.
- 12.) Design Report #11 - "Thermal/Mechanical Analysis of the Reactor Vessel Shell", revision 1 dated 5-73.
- 13.) Design Report #8 "Reactor Vessel Instrumentation Tubes", revision 1 dated 5-73.
- 14.) Computer Program 91425, B&W Material Properties Standard, Revision 4, June 1976.
- 15.) J.M. Burnett memo to Distribution dated 4/20/78; Subject SMUD Cooldown Incident.
- 16.) J.M. Burnett memo to Distribution dated 4/20/78; Subject: SMUD Cooldown Incident.
- 17.) Calculation Package 32-9801-00, "Fracture Mechanics Evaluation - RV", dated 10/12/78.

SMUD RAPID COOLDOWN


A. D. McKIM

Nomenclature

- σ_{disc} = Thermal discontinuity stress intensity
- σ_{RGS} = Thermal radial gradient stress intensity
- $\sigma_{therm\ peak}$ = Thermal peak stress intensity
- σ_{P+S} = Total primary + secondary intensity range.
- σ_{alt} = Alternating stress as defined in NB3216 of reference #6
- σ_{peak} = Peak stress intensity range.
-
- K_e = Correction factor for fatigue evaluation for cases when the $3 S_m$ limit is not met (NB-3228.3 of ref. #6).
- P+S = Primary plus secondary stress intensity
- RCT = Rapid Cooldown Transient
- P = pressure, psi.
- $P_1 + P_b$ = Primary membrane plus primary bending stress intensity as defined in NB-3221.3 of reference #6.
- OBE = Operational Basis Earthquake
- SCF = Stress concentration factor
- M = Bending moment, in-lbs./in.
- t = Thickness, in.
- r_i = Inside radius, in.
- r_o = Outside radius, in.

SMUD RAPID COOLDOWN

A. D. McKIM



A. D. McKIM

CUSTOMER	JOB NO
SUBJECT	Sheet 5
SMUD RAPID COOLDOWN	BY
	DATE

TRANSIENT POINT DESCRIPTION

POINT	TIME (MIN.)	TEMP. (°F)	POINT	TIME (MIN.)	PRESSURE (PSI)
A	0.0	565	L	0.0	2150
B	5.0	565	M	2.5	2300
C	10.0	590	N	14.0	1950
D	15.0	590	O	20.0	1500
E	20.0	525	P	30.0	1900
F	40.0	380	Q	35.0	1650
G	60.0	300	R	40.0	2100
H	80.0	280	S	46.0	1900
I	95.0	290	T	55.0	2150
J	110.0	305	U	75.0	2100
K	140.0	340	V	80.0	2000
			W	100.0	1900
			X	104.0	1650
			Y	140.0	1500

POOR ORIGINAL

Time, Temperatures, and pressures are representative of information contained in reference #5.

J. D. McRIV

BABCOCK & WILCOX		REVISION	
DEPARTMENT	DATE	BY	
STEAM RAPID COOLDOWN	CHECKED DATE	BY	
JOB NO.	SHEET 6 OF		

Nozzle Belt - Shell - Lower Head

Analysis Discussion

The description of the method used to analyze the nozzle-belt-shell lower head for P + S and fatigue effects of the RCT are described below:

- 1.) Program 91232 (reference #3) is used to obtain the temperature distribution for the nozzle belt, shell, and lower head.
- 2.) Times for analysis were chosen using the following criteria:
 - a) Maximum σ_{disc} - times in which the ΔT between the midpoint temperatures of the nozzle belt-shell and shell-lower head are a maximum. See the graph on sheet 10 for this determination.
 - b) Maximum RGS - times in which the RGS calculated by Program 91232 are a maximum for the different sections.
- 3.) Program 91206 (reference #4) was run for the times of analysis using the temperatures obtained from 91232 in conjunction with the appropriate pressure to obtain P + S and σ_{peak} for the RCT (See sheet 3 in reference #11 for the 91206 model). The only alteration to this model was at the "N" end. The "N" end was modeled to represent the opening in the head for an instrumentation tube. The motions at this end are used in instrumentation tube analysis in another section of this analysis.
- 4.) The P + S and peak stress intensities for the RCT are combined with the P + S and peak stress intensities for iterations analyzed in reference #12 (see sheet #53 of reference #12) to obtain maximum σ_{p+s} and σ_{alt} . Segment #13 is the location of maximum stress.
- 5.) Fatigue analysis is performed in accordance with reference #6.

SMUD RAPID COOLDOWN

A. D. McKIM

POOR ORIGINAL

Times of Analysis

Four times from the RCT were chosen to analyze.

- Time 40 - maximum RGS in lower head
- Time 60 - maximum RGS in shell and maximum Δ_{ax} between shell and lower head
- Time 100 - maximum Δ_{disc} between nozzle belt and shell
- Time 20 - time necessary to analyze instrumentation tube - lower head (lower head motions used in instrumentation interaction analysis)

Pressures for times of analysis are listed below

Time (Minutes)	Pressure (Psi)
20	2100
40	2050
60	1680
100	1500

A. D. McKIM

BABCOCK & WILCOX

DEPARTMENT

SINUS RAPID COOLDOWN

DATE

CHECKED DATE

JOB NO.

BY

BY

REVISION

SHEET 8 OF

RADIAL GRADIENT STRESS VS. TIME
FROM 91232 RUNS



SEE APPENDIX A FOR 91232'S
INPUT AND OUTPUT

BABCOCK & WILCOX

DEPARTMENT

MUD COOLDOWN INCIDENT

SHELL CALCULATIONS

DATE

4-78

CHECKED DATE

JOB NO.

BY

F.L.B

BY

REVISION

SHEET


9

OF

DISCONTINUITY TEMPERATURES VS. TIME @ NPDS

FROM 91722 RUNS

NOZZLE BELT TO SHELL
SHELL TO LOWER HEAD



POOR ORIGINAL

BABCOCK & WILCOX

DEPARTMENT

DATE 4-78

BY F.L.B.

SMUD COOLDOWN INCIDENT

CHECKED DATE

BY

SHELL CALCULATIONS

JOB NO.

REVISION

SHEET 10 OF

T_{PT5} STRESS CALCULATIONS

COMBINE ITER 20, 40, 60, & 100 WITH THOSE IN SHELL ANALYSIS & OBTAIN MAX T_{PT5} AT CRITICAL JUNCTURES.

MAXIMUM FROM 91206 @ JUNCTURE 13 = 54.0 KSI
ON INSIDE
GAMMA HEATING ON INSIDE = 3.2 KSI (PG 107, ref # 11)

TOTAL MAX $T_{PT5} = 54 + 3.2 = 57.2 \text{ KSI}$

$P_{TS} = 57.2 \text{ KSI} < 3S_m = 80 \text{ KSI}$

PEAK STRESS INTENSITY RANGE

MAXIMUM PEAK STRESS @ JUNCTURE 13 = 67.2 KSI
ON INSIDE

GAMMA HEATING STRESS ON INSIDE = 3.2 KSI

SKIN STRESS ON INSIDE DUE TO 0-15-0% PUR.

$S_H = S_L = \frac{E \alpha \Delta T}{1 - \mu} = \frac{27.5 \text{ IE} + 6(716 \text{ E} - 6)(86)}{.7} = 24.2 \text{ KSI}$

ALTERNATING STRESS = $\frac{67.2 + 3.2 + 24.2}{2} = 47.3 \text{ KSI}$

$n_i = 3 \text{ CYCLES}$

$U_i = n_i / N_i = 3 / 5000 = .0006$

POOR ORIGINAL

BABCOCK & WILCOX	DATE 4-79	BY F.L.B	REVISION
DEPARTMENT	CHECKED DATE	BY	
SMUD COOLDOWN INCIDENT	JOB NO.		SHEET 11 OF
SHELL CALCULATIONS			

$$U_2 = n_2 / N_2$$

ALTERNATING STRESS = 28.5 PG. 10B, ref. #11

$n_2 = 640$ CYCLES (CONSERVATIVE)

$$U_2 = 640 / 30000 = .0213$$

FOR REMAINING TRANSIENTS USAGE FACTOR U_3
IS 0 PER PG. 109.

$$U_T = U_1 + U_2 + U_3 = .0006 + .0213 + 0.0 = .0219$$

POOR ORIGINAL

BABCOCK & WILCOX

DEPARTMENT

DATE

4-78

BY

F.L.B.

REVISION

SMUD COOLDOWN INCIDENT

CHECKED DATE

BY

SHELL CALCULATIONS

JOB NO.

SHEET

12

OF

Instrumentation Tube

Analysis Discussion

The analogy and description of the method used to analyze the instrumentation tube for P+S and fatigue effects of the RCT are described below:

- 1.) Program 91232 (reference #3) is used to obtain the temperature distribution for the instrumentation tube. Film coefficient from reference #13 is used.
- 2.) Times of analysis for the RCT are determined using the following criteria:
 - a.) Maximum σ_{disc} - time of maximum midpoint ΔT between the instrumentation tube and lower head (Program 91232 for the lower head was run for the nozzle-belt - shell-lower head analysis.)
 - b.) Maximum RGS - time of maximum RGS calculated by Program 91232.
- 3.) For times of RCT analysis the following was done to determine the interaction between the tube and lower head.
 - a.) Free thermal motions of the tube were determined by using the midpoint temperature of the tube in $\epsilon R(\Delta T)$ equation.
 - b.) Tube pressure motions were determined by ratioing the pressure motions calculated in reference #13 (sheet B-8-2) by the appropriate pressure for time of analysis.
 - c.) Head motions due to thermal and pressure were taken from Program 91206 which was run for the nozzle belt-shell-lower head analysis.
 - d.) The "interaction analysis" method in Section B-10 of reference #13 was followed in obtaining "M" and "Q" values.

SMUD RAPID COOLDOWN

A. D. McKIM

4. Program 91206 was run for the tube with the appropriate temperature, pressure, "M", and "Q" for times of analysis to obtain pressure + thermal P+S for tube.
5. Earthquake stresses from reference #13, sheet are added to P+S from 4) to obtain total P+S for RCT.
6. The P+S of 5) are combined with P+S from reference #13 to obtain $\sqrt{P+S}$.
7. A conservative S.C.F. of four is multiplied times σ_{P+S} of 6) to obtain the maximum peak stress intensity range to be analyzed for three fatigue cycles. This high S.C.F. is used to make this analysis inclusive of the weld juncture also. The weld is designed to develop more strength than the tube; therefore, this approach is conservative.
8. A fatigue analysis is performed in accordance with reference #6.

SMUD RAPID COOLDOWN

A. D. McKIM

MS 7-1

Times of Analysis

Two times from the RCT were chosen to analyze.

Time 20 - maximum RGS in tube

Time 40 - maximum ∇_{disc} , i.e. maximum ΔT between tube and head

Pressure for times of analysis are listed below with the corresponding 91206 pressure load inputs.


Time (Minutes)	Pressure (PSI)	H* (LBS)	L* (LBS)	L/G (LBS)
20	1500	1259.6	4712.4	785.4
40	2100	1763.4	6597.3	1099.5

POOR ORIGINAL

* As defined on sheet B-8-2 of reference # 13

BABCOCK & WILCOX		E. D. Mottis		REVISION
DEPARTMENT	DATE	BY		
SMUD RAPID COOLDOWN	CHECKED DATE	BY		
	JOB NO.			SHEET 15 OF

RADIAL GRADIENT STRESS VS. TIME
FROM 91232 RUN ON TUBE




POOR ORIGINAL

SEE APPENDIX A FOR 91232
INPUT & OUTPUT

BABCOCK & WILCOX	DATE 4-78	BY F.L.B.	REVISION
DEPARTMENT	CHECKED DATE	BY	
SMUD COOLDOWN INCIDENT	JOB NO.		SHEET 16 OF
INSTRUMENTATION CALL			

DISCONTINUITY TEMPERATURES VS. TIME @ NODE 5
FROM 01002 RUMBAF TUBE & LOWER HEAD OF SHELL & MIDPT



POOR ORIGINAL

BABCOCK & WILCOX	DATE 4-78	BY F.L.B.
DEPARTMENT	CHECKED DATE	BY
SMUD COOLDOWN INCIDENT	JOB NO.	
INSTRUMENTATION CALC.		

REVISION
SHEET 17 OF

CALCULATION OF LOADS FOR 91206 RUN

COMPATIBILITY EQUATIONS PG. B-10-2 of ref. #13

$$\delta_{PT} + \delta_{TT} + Q\left(\frac{\delta}{Q}\right)_T - M\left(\frac{\delta}{M}\right)_T = \delta_{PH} + \delta_{TH} - Q\left(\frac{\delta}{Q}\right)_H - M\left(\frac{\delta}{M}\right)_H$$

$$\delta_{PT} + \delta_{TT} + Q\left(\frac{\delta}{Q}\right)_T - M\left(\frac{\delta}{M}\right)_T = \delta_{PH} + \delta_{TH} + Q\left(\frac{\delta}{Q}\right)_H + M\left(\frac{\delta}{M}\right)_H$$

INFLUENCE COEFFICIENTS - AVE. OF COEF. OF PG. B-2-B #
B-2-12 of reference #13

TUBE

$$\left(\frac{\delta}{Q}\right)_T = .00909E-6$$

$$\left(\frac{\delta}{M}\right)_T = .00139E-6$$

$$\left(\frac{\theta}{Q}\right)_T = .00958E-6$$

$$\left(\frac{\theta}{M}\right)_T = .0745E-6$$

HEAD

$$\left(\frac{\delta}{Q}\right)_H = .0123E-6$$

$$\left(\frac{\delta}{M}\right)_H = .0106E-6$$

$$\left(\frac{\theta}{Q}\right)_H = .0106E-6$$

$$\left(\frac{\theta}{M}\right)_H = .0572E-6$$

TUBE THERMAL DEFL. δ_T^T PG. B-7-2 of ref. #13

$$\delta_T^T = \alpha R \Delta T$$

α @ TEMP OF NODES OF TUBE 91237

$$R = 7575" \quad \Delta T = T - 70$$

ITER 20 (20 min.)

$$\delta_T^T = 7.86E-6 (7575) (490)$$

$$\alpha @ 560^\circ = 7.86E-6 \quad \Delta T = 490^\circ$$

$$= .00292$$

POOR ORIGINAL

ITER 40 (40 min.)

$$\delta_T^T = 7.7E-6 (7575) (337) = .00197" \quad \alpha @ 407^\circ = 7.7E-6 \quad \Delta T = 337^\circ$$

BABCOCK & WILCOX

DEPARTMENT

= MUD-COOLDOWN-INCIDENT

INSTRUMENTATION CALC.

DATE

4-78

BY

FLB

CHECKED DATE

BY

JOB NO.

REVISION

SHEET 18 OF

TUBE PRESSURE MOTIONS 3-8-2 of ref. #13

$$\delta_P^T = \sum_{\text{PROGRAM}}^{91206} \left(\frac{\text{PRES}}{1000} \right) \left(\frac{E@70^\circ\text{F}}{E@TEMP} \right)$$

$$\theta_P^T = \theta_{\text{PROGRAM}}^{91206} \left(\frac{\text{PRES}}{1000} \right) \left(\frac{E@70^\circ\text{F}}{E@TEMP} \right)$$

ITER 20 P₂ = 1500 PSI

E@70 = 31.42E+6

E@560 = 29.201E+6

$$\delta_P^T = 6.1378E-6 (1.5) \left(\frac{31.42}{29.201} \right) = 9.506E-6 \text{ IN.}$$

$$\delta^{91206} = 6.1378E-6 \text{ IN.}$$

$$\theta^{91206} = -35.674E-6 \text{ RAD.}$$

$$\theta_P^T = -35.674E-6 (1.5) \left(\frac{31.42}{29.201} \right) = -57.577E-6 \text{ RAD.}$$

ITER 40 P₂ = 2100 PSI

E@407 = 29.695E+6

$$\delta_P^T = 6.1378E-6 (2.1) \left(\frac{31.42}{29.695} \right) = 13.638E-6 \text{ IN.}$$

$$\theta_P^T = -35.674E-6 (2.1) \left(\frac{31.42}{29.695} \right) = -79.267E-6$$

HEAD MOTIONS DUE TO THERMAL + PRESSURE

USE 91206 RUN OF SHELL ANALYSIS FOR ITER 20 + 40

$$\theta_P^H + \theta_T^H = \theta_{91206}^H @ \text{SEG. TO Pg. B-3-14}$$

$$\delta_P^H + \delta_T^H = \sum_{91206}^H \left(\frac{R_2}{R_1} \right) - \theta_{91206}^H \left(\frac{t_H}{2} \right)$$

t_H = 5"

R₂ = .7575"

R₁ = .5175"

SEG. TO

POOR ORIGINAL

BABCOCK & WILCOX	DATE 4-78	BY F.L.B.	REVISION
DEPARTMENT	CHECKED DATE	BY	
SMUD COOLDOWN INCIDENT	JOB NO.		SHEET 19 OF
INSTRUMENTATION CALC.			

ITER 20

$$\theta_p^H + \theta_T^H = -17.55E-6 \text{ RAD.}$$

$$\begin{aligned} \delta_p^H + \delta_T^H &= .2120E-2 \left(\frac{.7575}{.5175} \right) - (-17.55E-4)(2.5) \\ &= 3147.1E-6 \text{ IN.} \end{aligned}$$

ITER 40

$$\theta_p^H + \theta_T^H = -43.02E-6 \text{ RAD.}$$

$$\begin{aligned} \delta_p^H + \delta_T^H &= .1763E-2 \left(\frac{.7575}{.5175} \right) - (-43.02E-4)(2.5) \\ &= 2638.2E-6 \text{ IN.} \end{aligned}$$

BY SUBSTITUTING ALL KNOWN VALUES INTO COMPATIBILITY EQUATIONS AND SOLVE SIMILAR EQUATIONS. FOR $M \neq Q$.

$$\delta^H = \delta^T \quad \theta^H = \theta^T$$

POOR ORIGINAL

ITER 20

$$\delta_p^T + \delta_T^T + Q \left(\frac{\delta}{Q} \right)_T - M \left(\frac{\delta}{M} \right)_T = \delta_p^H + \delta_T^H + Q \left(\frac{\delta}{Q} \right)_H - M \left(\frac{\delta}{M} \right)_H$$

$$9.906E-6 + .00292 + Q(.00909E-6) - M(.00139E-6) = 3147.1E-6 - Q(.0123E-6) - M(.0106E-6)$$

$$Q(.0239E-6) + M(.00921E-6) = 217.2E-6 \quad (1)$$

$$\theta_p^T + \theta_T^T + Q \left(\frac{\theta}{Q} \right)_T - M \left(\frac{\theta}{M} \right)_T = \theta_p^H + \theta_T^H + Q \left(\frac{\theta}{Q} \right)_H - M \left(\frac{\theta}{M} \right)_H$$

$$-57.577E-6 + Q(.00959E-6) - M(.0745E-6) = -17.55E-6 + Q(.0106E-6) + M(.0572E-6)$$

$$-Q(.00102E-6) - M(.1317E-6) = 40.027E-6 \quad (2)$$

BABCOCK & WILCOX

DEPARTMENT

DATE 4-78

BY F.L.B.

REVISION

STUD COOLDOWN INCIDENT

CHECKED DATE

BY

INSTRUMENTATION-CALC.

JOB NO.

SHEET 20 OF

ITER 20

SOLVE SIMO. EQU. 1#2 FOR M & Q

$$Q(.02139E-6) + M(.00921E-6) = 217.2E-6$$

$$\text{MULT. BY } \frac{.02139}{.00192} \quad \underline{-Q(.02139E-6) - M(2.76183E-6) = 139.4E-6}$$

$$-M(2.75262E-6) = 1056.6E-6$$

$$M = -383.9$$

$$Q(.02139E-6) = 217.2E-6 - (-383.9)(.00921E-6)$$

$$Q = 10319.6$$

POOR ORIGINAL

ITER 40

$$13.638E-6 + .00197 + Q(.00909E-6) - M(.00139E-6) = 2689.2E-6 - Q(.01236E-6) - M(.0106E-6)$$

$$Q(.02139E-6) + M(.00921E-6) = 704.6E-6 \quad (1)$$

$$-79.287E-6 + Q(.00958E-6) - M(.0745E-6) = -43.02E-6 + Q(.0106E-6) + M(.0572E-6)$$

$$-Q(.00102E-6) - M(.1317E-6) = 36.247E-6 \quad (2)$$

SOLVE SIMO. EQU. 1#2 FOR M & Q

$$Q(.02139E-6) + M(.00921E-6) = 704.6E-6$$

$$\text{MULT. BY } \frac{.02139}{.00182} \quad \underline{-Q(.02139E-6) - M(2.76183E-6) = 760.121E-6}$$

$$-M(2.75262E-6) = 1464.721E-6$$

$$M = -532.1$$

BABCOCK & WILCOX

DEPARTMENT

SMUD RAPID-COOLDOWN

DATE

4-78

BY

F.L.S.

CHECKED DATE

BY

JOB NO.

REVISION

SHEET

21

OF

ITER 40

$$Q(0.02139E-6) = 709.6E-6 - (-532.1)(0.00921E-6)$$

$$Q = 33169.7$$

DISTRIBUTION OF M \neq Q LOADS ON WELD FOR 91206
 REF. PG. B-10-6 SEE 17-22 (ref. #13)

ITER 20

$$RATIO = 383.9 / 217.8 = 1.76263 \quad Q_{LOAD} = Q/6$$

SEG #	RAD LOAD	MOD. LOAD	Q LOAD	MOD Q LOAD
17	376.0	662.7	1719.9	2382.6
18	250.67	441.8		2161.7
19	125.33	220.9		1940.8
20	-125.33	-220.9		1499.0
21	-250.67	-441.8		1278.1
22	-376.0	-662.7		1057.2

POOR ORIGINAL

ITER 40

$$RATIO = 532.1 / 217.8 = 2.44307$$

SEG.#	RAD LOAD	MOD. LOAD	Q LOAD	MOD Q LOAD
17	376.0	918.6	5528.3	6446.9
18	250.67	612.4		6140.7
19	125.33	306.2		5834.5
20	125.33	-306.2		5222.1
21	250.67	-612.4		4915.9
22	376.0	-918.6		4609.7

BABCOCK & WILCOX

DEPARTMENT

SMUD RAPID-COOLDOWN

DATE

4-78

BY

F.F.B.

CHECKED DATE

BY

JOB NO.

REVISION

SHEET 22 OF

σ_{P+S} determination

σ_{P+S} is obtained by combining P+S from the RCT with P+S from reference #13 (See sheet B-12-38 of reference #13). Segment 22 is the highest stressed location.

Maximum from 91206 combination = 54.2 ksi

P+S due to earthquake loads = ± 3.0 ksi (See sheet B-12-43 of reference #13)

Total P+S = $54.2 + 6 = 60.2$ ksi $< 35_m = 69$ ksi

Fatigue Analysis

POOR ORIGINAL

Peak earthquake intensity = 17.6 ksi (see sheet B-13-5 of ref #13)

$\sigma_{alt} = [S.C.F. (P+S) + (2)(17.6)] [0.5]$

S.C.F. = 4.0 for weld (see discussion)

BABCOCK & WILCOX		A. D. McKim		REVISION	
DEPARTMENT	DATE	BY			
SMUD RAPID COOLDOWN		CHECKED DATE	BY		
JOB NO.			SHEET 23 OF		

$$\sigma_{alt} = [(4.0)(60.2) + (2)(17.6)] [0.5] = 138 \text{ ksi}$$

Allowable cycles = 300 from ref. #6, Fig I-9.2

Required cycles = 3

Usage factor = $3/300 = .01$

Maximum usage factor from ref. #13 for the weld = 0.57; therefore, maximum

cumulative usage factor = $0.57 + 0.01 = 0.58$
 $< 1.0 \rightarrow$ acceptable

POOR ORIGINAL

A. D. McKIM

BABCOCK & WILCOX		REVISION	
DEPARTMENT	DATE	BY	_____
S.MJD RAPID COOLDOWN	CHECKED DATE	BY	_____
JOB NO.	SHEET <u>24</u> OF		_____

CRDM DISCUSSION

P + S STRESSES

In analyzing the instrumentation tubes it was determined the max P + S did not increase due to the RCT. Since the CRDM's and instrumentation tubes are thin tubes, in thick heads, it is felt that the CRDM's P + S similarly will not increase significantly.

PEAK STRESSES

Since this incident was a fast transient the only significant affect was on the peak stresses. The cumulative usage factor of the instrumentation tube weld increased from 0.57 to 0.58 (insignificant). By using the similarities of instrumentation tubes and CRDM's, the usage factor for the CRDM would not increase significantly.

POOR ORIGINAL

SMUD RAPID COOLDOWN

A. D. McKIM

Closure Dome - Closure Flange

Analysis Discussion


The analogy and description of the conservative method used to analyze the closure dome - closure flange juncture for P+S and fatigue effects of the RCT are described below:

- 1.) Program 91232 (reference #3) is used to obtain the temperature distribution for the closure head dome and flange. A time-temperature graph of the mid-point temperatures is presented on sheet 26a.
- 2.) The maximum ΔT between the mid-point temperatures of the closure dome and flange is factored into the upper bound discontinuity stress equation, $1.83 E = \Delta T$.
- 3.) The RGS is taken from Program 91323 (reference #3) at the time of analysis.
- 4.) By comparing the maximum intensities ranges in which a cooldown iteration contributes to the range (see sheet B-15-2 of reference #11), it was determined that the L-H inside intensity is the controlling intensity.
- 5.) (P+S) RCT is determined by conservatively adding the absolute values of σ_{disc} , RGS, and the intensity for iteration #1 (boltup + design pressure) in reference #11.
- 6.) The maximum σ_{P+S} is determined by adding (P+S)^{RCT} to the L-H intensity from iteration 920.
- 7.) $\sigma_{other\ peak}$ is taken from Program 91232.
- 8.) Fatigue analysis is performed in accordance with reference #6.

The time in which the maximum RGS occurred for the closure flange and other intensities for the times analyzed in reference #11 were also considered, but yielded a smaller usage factor than the case analyzed.

SMUD RAPID COOLDOWN

A. D. McKIM



BABCOCK & WILCOX
 DEPARTMENT

SMUD RAPID COOLDOWN

DATE: BY

CHECKED DATE BY

JOB NO.

REVISION

SHEET 26a OF

Closure Analysis

$$\sigma_{\text{Disc}}^{\text{RCT}} = 1.83 E \alpha \Delta T \quad (\text{reference \# 1})$$

$$\Delta T = 197^\circ \text{F} \quad (\text{See graph on sheet 26a})$$

$$\alpha = 7.04 \times 10^{-6} \quad \text{Mag Moly at } 520^\circ \text{F}$$

$$E = 27.91 \times 10^6$$

$$\sigma_{\text{Disc}}^{\text{RCT}} = (1.83)(28.0 \times 10^6)(7.40 \times 10^{-6})(197) = 74.7 \text{ ksi}$$

$$\sigma_{\text{RGS}}^{\text{RCT}} = 3.2 \text{ ksi} \quad (\text{from 91232 output for dome})$$

$$\sigma_{\text{BL+DP}}^{\text{RCT}} = \text{L-H intensity for bolt-up + design pressure}$$

$$= -17.0 \text{ ksi} \quad (\text{from sheet B-15-2 of reference \# 11})$$

$$(P+S)^{\text{RCT}} = |\sigma_{\text{Disc}}^{\text{RCT}}| + |\sigma_{\text{RGS}}^{\text{RCT}}| + |\sigma_{\text{BL+DP}}^{\text{RCT}}|$$

$$= 74.7 + 3.2 + 17 = 94.9 \text{ ksi}$$

$$\sigma_{P+S} = (P+S)^{\text{RCT}} + 8.8^*$$

POOR ORIGINAL

* 8.8 Is the L-H inside stress intensity for iteration 920 (see sheet B-15-2 of reference #11). This is to account for the stress reversal.

BABCOCK & WILCOX	A. D. McKIM	REVISION
DEPARTMENT	DATE	BY
SMUD RAPID COOLDOWN	CHECKED DATE	BY
	JOB NO.	SHEET 27 OF

Closure Analysis (Continued)

$$\sigma_{pts} = 94.9 + 8.8 = 103.7 \text{ ksi} > 3S_m = 80.0 \text{ ksi}$$

The $3S_m$ limit is not met; therefore, the simplified elastic plastic analysis of NB-3228.3 in reference # 6 is used for the fatigue analysis.

$$\sigma_{peak} = \pm \text{S.C.F.} (\sigma_{pts}) - \sigma_{RGS}^{RCT} + \sigma_{peak}^{therm, RCT}$$

where: $\pm \text{S.C.F.} = 1.77$ (See sheet B-16-1 of reference # 11)

$$\sigma_{peak}^{therm, RCT} = 3.6 \text{ ksi}$$

$$= (1.77)(103.7) - 3.2 + 3.6 = 183.9 \text{ ksi}$$

\pm For conservatism the maximum SCF at the juncture is used.

Fatigue Analysis

Reference # 6 NB-3228.3 (a) requirement

$$\sigma_{pts} - \sigma_{Disc}^{RCT} = 103.7 - 74.7 = 29 \text{ ksi} << 3S_m$$

* σ_{Disc}^{RCT} is a thermal bending stress as well as the RGS

POOR ORIGINAL

BABCOCK & WILCOX	DATE	A. D. McKIM	REVISION
DEPARTMENT	CHECKED DATE	BY	
SMUD RAPID COOLDOWN	JOB NO.		SHEET 28 OF

Closure Analysis (Continued)

Reference # 6 NB-3228.3 (b) & (c) requirements

$$K_e = 1.0 + \frac{1-0.2}{0.2(2-1)} \left(\frac{103.7}{80} - 1.0 \right)$$

$$K_e = 2.185$$

$$\sigma_{alt} = (\sigma_{peak}) (K_e) (0.5)$$

$$\sigma_{alt} = (183.9) (2.185) (0.5) = 200.9 \text{ ksi}$$

Allowable cycles from Figure I-9-1
of reference # 6 ≈ 100

$$\text{Usage factor for 3 cycles of RCT} \\ = \frac{3}{100} = 0.03$$

Maximum usage factor from reference
11 (except studs) = 0.0343 (See
sheet A-2 of reference # 11)

$$\text{Total cumulative usage factor is} \\ 0.0343 + 0.030 = 0.0643 < 1.0$$

POOR ORIGINAL

BABCOCK & WILCOX	A. D. McKIN		REVISION
DEPARTMENT	DATE	BY	
SMUD RAPID COOLDOWN	CHECKED DATE	BY	
JOB NO.			SHEET 29 OF

Closure Analysis (Continued)

Reference #6 NB 3228.3 (d) requirement

Reference #6 NB 3222.5 a)

$x = (Pr_1/2t) / S_y$ where: $p = 2500 \text{ ksi}$
 $r_1 = 87.25''$
 $t = 6.5''$
 $S_y = 41.4 \text{ ksi}$

$x = \frac{(2.5)(87.25)}{(2)(6.5)} / 41.4$

$x = 0.405$

Case 2 of NB-3222.5 (a) applies because of the severe rate of cooldown

$y' = 3.55$; therefore, allowable range of thermal stress = $(3.55)(41.4) = 146.97 \text{ ksi}$
 $> \sqrt{p_{ts}}$ which includes pressure stresses

Thermal stress ratchet criteria is met.

Reference #6 NB-3228.3 (e) & (f) requirement

Maximum temperature $< 700^\circ\text{F}$

$T_{\text{yield}} / T_{\text{tensile}} \approx 50/80 = 0.625 < 0.8$

criterion met

POOR ORIGINAL

BABCOCK & WILCOX		DATE		BY	
DEPARTMENT		CHECKED DATE		BY	
SMUD RAPID COOLDOWN		JOB NO.			

REVISION	
SHEET	30 OF

Closure Studs

Discussion

From reference #11, sheet B-15-6 it can be seen that the times of maximum stress for the studs are heatup times. During a cooldown transient the studs are hotter than the flange; therefore, the net stud stresses are lower than the boltup stresses. Consequently, P+S and σ_{P+S} and σ_{peak} are not affected by the RCT.

SMUD RAPID COOLDOWN

A. D. McKIM

11 1970


Nozzles - Nozzle Belt Analysis

Discussion

The analogy and description of the conservative method used to analyze the nozzles to nozzle belt for P+S and fatigue effects of the RCT are described below:

Analysis #1 (maximum discontinuity)

- 1.) Program 91232 (reference #3) is used to obtain the temperature distribution for the thin mag moly end of the core flooding nozzle and the nozzle belt. A time-temperature graph of the midpoint temperatures is presented on sheet 35.



The σ_{disc} resulting from this nozzle attachment conservatively represents all nozzles-nozzle belt attachments.

- 2.) The maximum ΔT between the midpoint temperatures of the thin nozzle section and the nozzle belt section is factored into the upper bound discontinuity stress equation, $1.83 E = \Delta T$.
- 3.) The maximum RGS is taken from Program 91232 (reference 3) irregardless of time.
- 4.) The maximum $P_a + P_b$ from any nozzle at any location for seismic + thermal load + design pressure is used as the mechanical load $P + S$.
- 5.) The summation of the absolute values of 2), 3) and 4) is conservatively used as the P+S.

SMUD RAPID COOLDOWN

A. D. McKIM

- 6.) The maximum P+S from program 91060 (reference #8 from reference #9 or #10 for any heatup iteration at any location is added to P+S of 5) to obtain σ_{P+S} .
- 7.) Maximum σ_{peak}^{therm} is taken from program 91232.
- 8.) Fatigue analysis is performed in accordance with reference #6 using the maximum S.C.F. of any nozzle.

Analysis #2 (maximum RGS)

- 1.) Program 91232 (reference #3) is used to obtain the maximum RGS in any nozzle. The thick portion of the outlet nozzle is used for this analysis.
- 2. σ_{disc} is determined by multiplying the σ_{disc} from analysis #1 by the ratio of the thickness squared of the thin core flooding nozzle to the thickness squared of the thick outlet nozzle. σ_{disc} is a bending stress determined by $6M/\ell^2$; therefore, the ratio above is correct assuming the ΔT between the thin thickness of nozzle and the thick thickness of nozzle is the same as the ΔT between the thin thickness of the nozzle and the nozzle belt.
- 3.) The maximum $P_a + P_b$ from any nozzle at any location for seismic + thermal load + design pressure is used as the mechanical load P+S.
- 4.) The summation of the absolute values of 1), 2), and 3) is conservatively used as the P+S.
- 5.) The maximum P+S from Program 91060 (reference #8 from reference #9 or #10 for any heatup iteration at any location is added to P+S of 5 to obtain σ_{P+S} .
- 6.) Maximum σ_{peak}^{therm} is taken from Program 91232.
- 7.) Fatigue analysis is performed in accordance with reference #6 using the maximum S.C.F. of any nozzle.

SMUD RAPID COOLDOWN

A. D. McFITZ


List of conservatisms in these analyses

- 1.) Geometries assumed are highly conservative from σ_{disc} standpoint.
- 2.) Time of maximum RGS is conservatively assumed to occur at the time σ_{disc} is the highest.
- 3.) Stress intensities are not kept separate when combining the different effects (RGS, σ_{disc} , $P_e + P_b$).
- 4.) The absolute values of RGS, σ_{disc} , and $P_e + P_b$ are used to obtain P+S.
- 5.) To obtain σ_{P+S} the maximum stress intensity from references 9 & 10 are used irregardless of sign or intensity to obtain P+S.
- 6.) The maximum SCF from any nozzle is used.
- 7.) The usage factor calculated is added to the maximum nozzle usage factor irregardless of nozzle or location.

SMUD RAPID COOLDOWN

A. D. McKIM

SEE Appendix A for 91232
Input and Output



BABCOCK & WILCOX

DEPARTMENT

STEAD RAPID COOLDOWN

DATE 12/1/54 BY D. Mc...

CHECKED DATE _____ BY _____

JOB NO. _____

REVISION

SHEET 35 OF _____

No331e - Analysis #1

$$\underline{\sigma_{DISC}^{RCT}} \text{ for RCT} = \sigma_{DISC}^{RCT}$$

$$\sigma_{DISC}^{RCT} = 1.83 E \alpha \Delta T \quad (\text{reference 1})$$

$$\Delta T = 485 - 306 = 179^{\circ}F \quad (\text{see graph on sheet 35})$$

$$\alpha = 7.21 \times 10^{-6}$$

$$E = 29.036 \times 10^6$$

> Mag Moly at 306°F
(Code 12, reference #14)

$$\sigma_{DISC}^{RCT} = (1.83)(29.036 \times 10^6)(7.21 \times 10^{-6})(179)$$

$$\sigma_{DISC}^{RCT} = 68.6 \text{ ksi}$$

$$\underline{\sigma_{RGS}^{RCT}} = 2.7 \text{ ksi} \quad (\text{from 91232 output for thin section})$$

$$\underline{(P_2 + P_0)^{RCT}} = 19.7 \text{ ksi} \quad (\text{from sheet A-3 of reference #9})$$

$$\begin{aligned} \underline{(P+S)^{RCT}} &= |\sigma_{DISC}^{RCT}| + |\sigma_{RGS}^{RCT}| + |(P_2 + P_0)^{RCT}| \\ &= 68.6 + 2.7 + 19.7 = 91.0 \text{ ksi} \end{aligned}$$

POOR ORIGINAL

BABCOCK & WILCOX	E. D. McKIM		REVISION
DEPARTMENT	DATE	BY	
SMUD RAPID COOLDOWN	CHECKED DATE	BY	
	JOB NO.		SHEET 36 OF

Nozzle - Analysis #1 (Continued)

$$\begin{aligned} \underline{\sigma_{P+S}} &= (P+S)^{RCT} + 30.1^* \\ &= 91.0 + 30.1 = 121.1 \text{ ksi} > 3S_m = 80 \text{ ksi} \end{aligned}$$

* 30.1 ksi is the maximum P+S from program 91060 (reference 8) output in references #9 & #10. See sheet B-14-53 of reference #10 for the 30.1 ksi value.

The $3S_m$ limit is not met; therefore, the simplified elastic plastic analysis of NB-3228.3 in reference #6 is used for the fatigue analysis.

$$\underline{\sigma'_{peak}} = \text{S.C.F.} (\sigma_{P+S}) - \sigma_{RGS}^{RCT} + \sigma_{peak}^{RCT \text{ Therm}}$$

where:

S.C.F. = 1.89 (The maximum S.C.F. from any nozzle. See sheet B-13-4 in reference #9 for 1.89 value)

$$\sigma_{peak}^{RCT \text{ Therm}} = 3.7 \text{ ksi (from 91232 of thin part)}$$

$$= (1.89)(121.1) - 2.7 + 3.7 = 229.8 \text{ ksi}$$

POOR ORIGINAL

BABCOCK & WILCOX	DATE <u>E. D. McMillan</u>	REVISION
DEPARTMENT	BY	
SMUD RAPID COOLDOWN	CHECKED DATE	
	BY	
JOB NO.		SHEET <u>37</u> OF

Nozzle - Analysis #1 (Continued)

Fatigue Analysis

Reference #6 NB-3228.3 (a) requirement

$$\sigma_{pts} - \sigma_{disc}^{RCT} = 121.1 - 68.6 = 52.5 \text{ ksi} < 80.0 \text{ ksi}$$

* σ_{disc}^{RCT} is a thermal bending stress as well as the RGS

Reference #6 NB-3228.3 (b)+(c) requirements

$$K_e = 1.0 + \frac{(1-0.2)}{0.2(2-1)} \left(\frac{121.1}{80.0} - 1 \right) \quad \text{for low alloy steel}$$

$$K_e = 3.06$$

$$\sigma_{alt} = (\sigma_{peak})(K_e)(0.5)$$

$$\sigma_{alt} = (229.8)(3.06)(0.5) = 352 \text{ ksi}$$

Allowable cycles from Figure I-9-1 = 35

Usage Factor for 3 cycles of RCT = $\frac{3}{35}$
= 0.086

POOR ORIGINAL

BABCOCK & WILCOX	D. McKIM		REVISION
DEPARTMENT	DATE	BY	
SMUD RAPID COOLDOWN	CHECKED DATE	BY	
JOB NO.			SHEET 38 OF

BMS 7-1
 No331e - Analysis #1 (Continued)

Maximum usage factor from references #9 and #10 = 0.35 (See sheet A-1-3 of reference #9)

Total cumulative usage factor is $0.35 + 0.086 = 0.436 < 1.0$

Reference #6 NB-3228.3 (d) requirement
 NB 3222.5 (a)

$$X = \left(\frac{p r_i}{t} \right) / S_y$$

where $p = 2500 \text{ psi}$

$r_i = 6.3125''$

$t = 1.5''$

$S_y = 41,400 \text{ psi at } 650^\circ\text{F}$

$$X = \left(\frac{(2500)(6.3125)}{1.5} \right) / 41,400$$

$$X = 0.254$$

Case 2 of NB-3222.5 (a) applies because of the severe rate of cooldown

$y' = 4.65$; therefore allowable range of thermal stress = $(4.65)(41,400) = 192,510 \text{ psi}$
 $> \sigma_{pts}$ which includes pressure stresses

Thermal stress ratchet criteria is met.

POOR ORIGINAL

BABCOCK & WILCOX	D. McMillan	REVISION
DEPARTMENT	DATE	BY
SMUD RAPID COOLDOWN	CHECKED DATE	BY
JOB NO.		SHEET 39 OF

Nozzle - Analysis #1 (Continued)

Reference # 6 NB-3228.3(e) & (f) requirements

Maximum temperature < 700 °F

$$\left(\frac{\sigma_{\text{yield}}}{\sigma_{\text{tensile}}} \right) = \frac{50}{80} = 0.625 < 0.8$$

criterion met

POOR ORIGINAL

BABCOCK & WILCOX		DATE <u>L. D. McKim</u>		REVISION
DEPARTMENT		BY		
SMUD RAPID COOLDOWN		CHECKED DATE		
JOB NO.		BY		SHEET <u>40</u> OF

BMS 7-1

No331c - Analysis #2

$$\underline{\sigma_{DISC}^{RCT}} = (\sigma_{DISC}^{RCT} \text{ from analysis \#1}) \times \frac{t_{thin}^2}{t_{thick}^2}$$

where: σ_{DISC}^{RCT} from analysis #1 = 68.6 ksi
(See Sheet 36)

$$t_{thin}^2 = 1.5^2 = 2.25 \text{ in.}^2$$

$$t_{thick}^2 = 11.6875^2 = 136.6 \text{ in.}^2 \rightarrow \text{conservatively use } 100 \text{ in.}^2$$

$$\sigma_{DISC}^{RCT} = 68.6 \left(\frac{2.25}{100} \right) = 1.5 \text{ ksi}$$

$$\underline{\sigma_{RGS}^{RCT}} = 40.3 \text{ ksi (from 91232 output for thick section)}$$

$$\underline{P_L + P_b} = 19.7 \text{ ksi (same as analysis 1)}$$

$$\underline{(P+S)^{RCT}} = |\sigma_{DISC}^{RCT}| + |\sigma_{RGS}^{RCT}| + (P_L + P_b)$$

$$= 1.5 + 40.3 + 19.7 = 61.5 \text{ ksi}$$

POOR ORIGINAL

$$\underline{\sigma_{P+S}} = (P+S)^{RCT} + 30.1^* \quad * \text{ Same as analysis 1}$$

$$= 61.5 + 30.1 = 91.6 \text{ ksi} > 3S_n = 80.0 \text{ ksi}$$

\(\therefore\) elastic plastic analysis (ref. 6, NB3228.3) is performed

E. COCK & WILCOX		DATE		REVISION	
DEPARTMENT		BY			
SIMUD RAPID COOLDOWN		CHECKED DATE		BY	
		JOB NO.		SHEET 41 OF	

No33/c - Analysis #2

$$\underline{\sigma_{\text{peak}}} = \text{S.C.F.} (\sigma_{\text{pts}}) - \sigma_{\text{RGS}}^{\text{RCT}} + \sigma_{\text{peak}}^{\text{RCT + Ther}}$$

where: S.C.F. = 1.89 (Same as analysis 1)

$$\sigma_{\text{peak}}^{\text{RCT + Ther}} = 64.3 \text{ ksi (from 91232 thick part)}$$

$$\sigma_{\text{RGS}}^{\text{RCT}} = 40.3 \text{ ksi (from 91232 thin part)}$$

$$\sigma_{\text{peak}} = (1.89)(91.6) - 40.3 + 64.3 = 197.1 \text{ ksi}$$

Fatigue Analysis

Reference #6 NB-3228.3 (a) requirement

$$\sigma_{\text{pts}} - \sigma_{\text{RGS}}^{\text{RCT}} = 91.6 - 40.3 = 51.3 \text{ ksi} < 3S_m = 80 \text{ ksi}$$

* $\sigma_{\text{RGS}}^{\text{RCT}}$ is a thermal bending stress

Reference #6 NB-3228.3 (b) & (c) requirements

$$K_e = 1.0 + \frac{(1-0.2)}{(0.2)(2-1)} \left(\frac{91.6}{80.0} - 1 \right) \text{ for low alloy steel}$$

$$K_e = 1.58$$

POOR ORIGINAL

BABCOCK & WILCOX	BY D. McFIM	REVISION
DEPARTMENT	DATE	
SMUD RAPID COOLDOWN	CHECKED DATE	
	JOB NO.	SHEET 42 OF

8MS 7-1

Nozzle - Analysis #2

$$\begin{aligned}\sigma_{alt} &= (\sigma_{peak})(K_e)(0.5) \\ &= (197.1)(1.58)(0.5) = 155.7 \text{ ksi}\end{aligned}$$

σ_{alt} for analysis 2 is less than σ_{alt} for case 1; therefore, case 2 cumulative usage factor is less. The remainder of the reference #6 NB 3228.3 requirements are also met for case 2

POOR ORIGINAL

BABCOCK & WILCOX	DATE <u>J. D. McFinn</u>	REVISION
DEPARTMENT	BY	
SMUD RAPID COOLDOWN	CHECKED DATE	
	BY	
JOB NO.		SHEET <u>43</u> OF


SUPPORT SKIRT ANALYSIS DISCUSSION

The analogy and description of the conservative method used to analyze the support skirt for P+S and fatigue effects of the RCT are shown below:

- 1.) Juncture #1 of the 91206 model in reference #7 was determined to be the highest stressed juncture. This determination was made by comparing the stress intensity information shown on page B-16-38 through B-16-47 of reference #7. The maximum σ_{P+S} occurred at the inside (H-L) and was a combination of a heat-up iteration (iteration 5777) and a cooldown iteration (iteration 4709).
- 2.) The σ_{Disc} at juncture #1 for cooldown (iteration 4709) is determined by subtracting the pressure stress due to 175 psi pressure (pressure for this iteration) from the total stress. The pressure stress is determined by multiplying the hydrotest condition stress intensity by the ratio of the pressures (175/3125). This stress intensity is then subtracted from the stress intensity for iteration 4709 to obtain σ_{Disc} .
- 3.) σ_{Disc} for RCT is obtained by assuming the σ_{Disc} calculated in 2) above is due to the temperature differential between 91167 nodes 212 and 276 (See reference #7-Sheet B-4.2 for locations and B-7-10 for temperatures) and multiplying σ_{Disc} for iteration 4709 by ratios of the assumed ΔT for RCT ($300^{\circ}F$) to this ΔT .
- 4.) The pressure stress intensity for RCT is obtained by multiplying the stress intensity for hydrotest times the ratio of pressure (2200/3125).
- 5.) The total P+S for RCT is then obtained by adding the values of the pressure stress, σ_{Disc} , and the maximum $P_1 + P_b$ for dead weight plus OBE loads (See sheet B-16-7 of reference 7).
- 6.) The P+S in 5) above is then combined with P+S for other times (iterations) in the analysis to obtain the maximum σ_{P+S} .
- 7.) The fatigue analysis is performed assuming 3 cycles of RCT and following the method of reference 6.

A. D. McKIM

Support Skirt - Vessel



POOR ORIGINAL

BABCOCK & WILCOX	D. D. McKIM		REVISION
DEPARTMENT	DATE	BY	
SWUD RAPID COOLDOWN	CHECKED DATE	BY	
JOB NO.			SHEET 45 OF

$$\underline{\nabla_{Disc} \text{ at juncture \#1 for iteration 4709} = \nabla_{Disc}^{4709}}$$

Following the method described in 2) of the Support Skirt Analysis Discussion

$$\nabla_{Disc} = -10.5 - 175/3125 (17.4) = -11.5 \text{ ksi}$$

$$\underline{\nabla_{Disc} \text{ for RCT} = \nabla_{Disc}^{RCT}}$$

Following the method outlined in 3) of the Support Skirt Analysis Discussion.

Temperature of mode 212 for iteration 4709 = 320 °F

Temperature of mode 276 for iteration 4709 = 373 °F

ΔT_{4709} = temperature differential between modes 211 and 373 = 53

$$\nabla_{Disc}^{RCT} = \frac{300}{53} (\nabla_{Disc}^{4709}) = \frac{300}{53} (-11.5) = -65.1 \text{ ksi}$$

POOR ORIGINAL

SMUD RAPID COOLDOWN

BABCOCK & WILCOX	DATE 5-1-78	BY ADM	REVISION
DEPARTMENT	CHECKED DATE	BY	
SUPPORT SKIRT	JOB NO. SMUD		SHEET 46 OF
ANALYSIS			

Pressure Stress for RCT = ∇_p^{RCT}

Following the method described in 4) of the Support Skirt Analysis Discussion

$$\nabla_p^{RCT} = (2200/3125)(17.4) = 12.3 \text{ ksi}$$

P+S for RCT = $P+S^{RCT}$

$$P+S^{RCT} = -\nabla_{disc}^{RCT} + \nabla_p^{RCT} - (P_e + P_b)^*$$
$$= -65.1 + 12.3 - 8.43 = -61.23 \text{ ksi}$$

∇_{P+S} for RCT and iteration

Maximum P+S for 3 cycles is $|P+S^{RCT}| + |P+S^{other}| = 61.23 + 67.70 = 128.95 \text{ ksi}$
 $> 3S_m = 80.0 \text{ ksi}$

PDOR ORIGINAL

$\pm P+S^{other}$ is the maximum intensity for other iterations (See sheet B-16-38 of reference #7 for value)
* $P_e + P_b$ is the maximum intensity for OBE + dead weight (See sheet B-16-1 of reference #7)

BABCOCK & WILCOX	REVISION
DEPARTMENT SMUD RAPID COOLDOWN DATE 5-1-78 BY ADM	
Support Skirt	CHECKED DATE BY
Analysis	JOB NO. SMUD
	SHEET 47 OF

Fatigue Analysis

$\sqrt{P_{ts}} > 3S_m$; Therefore, the simplified elastic plastic analysis of NB-3228.3 in reference 6 is used.

$$K_e = 1.0 + \frac{(1-n)}{(n)(m-1)} \left(\frac{S_n}{3S_m} - 1 \right)$$

$n = 0.2$, $m = 2.0$, $S_n = \sqrt{P_{ts}} = 107.23$,
and $3S_m = 80.0$ for mag moly

$$K_e = 1.0 + \frac{(1-0.2)}{(0.2)(2-1)} \left(\frac{128.93}{80.0} - 1 \right)$$

$$K_e = 3.447$$

$$\sigma_{alt} = (K_e)(SCF)^*(\sqrt{P_{ts}})(0.5) = (3.447)(1.86)(128.93)(0.5)$$

$$\sigma_{alt} = 413.3 \text{ ksi}$$

Allowable cycle for a $\sigma_{alt} = 413.3 = 2\sigma$
from Figure I-9.1 of reference #6

Usage factor = $\frac{3}{20} = 0.150$ for RCT

Maximum usage factor from the results of
reference #7 is .07

* SCF is from sheet B-13-3 of reference #7.

BABCOCK & WILCOX	DATE 5-2-78	BY ADM	REVISION
DEPARTMENT	CHECKED DATE	BY	
SMUD RAPID COOLDOWN	JOB NO.		SHEET 48 OF

Therefore, maximum cumulative usage factor is $0.150 + 0.07 = 0.22 < 1.0 \rightarrow$ criteria of reference #6 is met

Note: Below is additional requirements which must be met to use the simplified elastic plastic analysis of NB-3228.3 in reference 6.

3228.3 (a) - σ_{DISC}^{ACT} is a thermal bending stress.
 $|\sigma_{PRSL} - \sigma_{DISC}^{ACT}| = 128.93 - 65.1 = 63.83 \text{ ksi} < 3S_m = 80 \text{ ksi}$
 \therefore requirement is met.

3228.3 (d) - Does not apply since the support skirt does not experience any pressure general membrane stress

3228.3 (e) - Maximum temperature is less than 700°F

3228.3 (f) - For mag molg portion of support skirt, $\sigma_{45} / \sigma_{UIT} = 50 / 80 = .625 < 0.8$

BABCOCK & WILCOX DEPARTMENT	SMUD RAPID COOLDOWN	DATE 5-2-78	BY ADM
SUPPORT SKIRT	CHECKED DATE	BY	
ANALYSIS	JOB NO. SMUD		

REVISION

SHEET 49 OF

Core Flooding Nozzle Venturi Discussion

The Core Flood Nozzle Venturi Sleeve is not analyzed in detail because reference #10 contains an evaluation of the core flood check valve transient which is more severe thermally than the RCT. The pressure during the RCT is higher than the check valve transients pressure, but pressure stresses in the venturi are insignificant when compared to the thermal stresses. See sheets D-85 through D-94 of reference #10, for detailed primary plus secondary stresses and fatigue evaluation.

The fatigue analysis of reference #10 would not be affected significantly by assuming three more cycles of the check valve transients to account for the three cycles of RCT.

SMUD RAPID COOLDOWN

A. D. McKIM

APPENDIX A

	<u>Computer Program</u>	<u>Page No.</u>
1)	91232 - Nozzle Belt.....	A-1 to A-8
2)	91232 - Shell.....	A-9 to A-16
3)	91232 - Lower Head.....	A-17 to A-24
4)	91206 - Nozzle Belt - Shell - Lower Head.....	A-25 to A-39
5)	91232 - Instrumentation Tube.....	A-40 to A-47
6)	91206 - Instrumentation Tube.....	A-48 to A-61
7)	91232 - Upper Head (Closure Dome).....	A-62 to A-69
8)	91232 - Closure Flange.....	A-70 to A-77
9)	91232 - Core Flooding Nozzle.....	A-78 to A-85
10)	91232 - Outlet Nozzle.....	A-86 to A-91

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT

DATE 04/18/78

DIMENSIONS

INSIDE RADIUS = 84.1875 INCHES OUTSIDE RADIUS = 96.1875 INCHES
NO. OF NODES = 9 RADIAL INCREMENT = 1.5000 INCHES
MATERIAL CODE = 12 POISSON S RATIO = .3000
L = -0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	84.1875	565.0
2	85.6875	565.0
3	87.1875	565.0
4	88.6875	565.0
5	90.1875	565.0
6	91.6875	565.0
7	93.1875	565.0
8	94.6875	565.0
9	96.1875	565.0

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT
F. L. BOYER
A-1

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT DATE 04/18/78

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE TIME APPROXIMATION (MINUTES)	INSIDE FLUID TEMPERATURE	FILM COEFF. CURVE TIME APPROXIMATION (MINUTES)	INSIDE FILM COEFFICIENT	PRESSURE CURVE TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	565.0	0.0000	900.0	0.0000	0.
5.0000	565.0	14.0000	900.0	0.0000	0.
10.0000	590.0	0.0000	0.0	0.0000	0.
15.0000	590.0	0.0000	0.0	0.0000	0.
20.0000	525.0	0.0000	0.0	0.0000	0.
40.0000	380.0	0.0000	0.0	0.0000	0.
60.0000	300.0	0.0000	0.0	0.0000	0.
80.0000	280.0	0.0000	0.0	0.0000	0.
95.0000	290.0	0.0000	0.0	0.0000	0.
110.0000	305.0	0.0000	0.0	0.0000	0.
140.0000	340.0	0.0000	0.0	0.0000	0.

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE TIME INCREMENT (MINUTES)	TIME LIMIT (MINUTES)	NUMBER OF PRINTOUTS
2.000	20.000	20.
5.000	60.000	120.
1.0000	140.000	160.

SMUD RAPID COOLDOWN

F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT

DATE 04/18/78

TIME	EQUIV RAD	LN. SIR	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE10	NODE11
0.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
0.5000		-0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
1.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
1.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
2.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
2.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
3.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
3.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
4.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
4.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
5.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
5.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
6.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
6.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
7.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
7.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
8.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
8.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
9.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
9.5000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65
10.0000		0.00	-0.00	-0.00	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65	55.65

F. L. BOYER
A-3
D R-APID COOLDOWN

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT

DATE 04/18/78

TIME	EQUIV RAD	IN. WALL THICK.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
00.0000		176.	24607.	-5917.	462.5	502.5	533.	498.8	500.	500.	500.	500.	500.	500.	500.
00.5000		176.	25301.	-6233.	459.5	500.	531.	487.5	500.	500.	500.	500.	500.	500.	500.
01.0000		176.	25990.	-6549.	455.5	500.	529.	477.5	500.	500.	500.	500.	500.	500.	500.
01.5000		176.	26675.	-6867.	452.0	500.	525.	467.5	500.	500.	500.	500.	500.	500.	500.
02.0000		176.	27356.	-7185.	444.6	494.5	520.	457.5	500.	500.	500.	500.	500.	500.	500.
02.5000		176.	28032.	-7503.	441.0	491.5	515.	447.5	500.	500.	500.	500.	500.	500.	500.
03.0000		176.	28706.	-7822.	434.0	488.5	510.	437.5	500.	500.	500.	500.	500.	500.	500.
03.5000		176.	29377.	-8140.	431.0	485.5	505.	427.5	500.	500.	500.	500.	500.	500.	500.
04.0000		176.	30045.	-8459.	434.6	482.5	500.	417.5	500.	500.	500.	500.	500.	500.	500.
04.5000		176.	30710.	-8778.	431.2	479.5	495.	407.5	500.	500.	500.	500.	500.	500.	500.
05.0000		176.	31372.	-9096.	427.7	477.0	490.	397.5	500.	500.	500.	500.	500.	500.	500.
05.5000		176.	32031.	-9415.	424.2	474.5	485.	387.5	500.	500.	500.	500.	500.	500.	500.
06.0000		176.	32687.	-9732.	420.7	472.0	480.	377.5	500.	500.	500.	500.	500.	500.	500.
06.5000		176.	33340.	-10050.	417.2	469.5	475.	367.5	500.	500.	500.	500.	500.	500.	500.
07.0000		176.	33989.	-10366.	413.7	467.0	470.	357.5	500.	500.	500.	500.	500.	500.	500.
07.5000		176.	34633.	-10683.	410.2	464.5	465.	347.5	500.	500.	500.	500.	500.	500.	500.
08.0000		176.	35271.	-10998.	406.7	462.0	460.	337.5	500.	500.	500.	500.	500.	500.	500.
08.5000		176.	35903.	-11313.	403.2	459.5	455.	327.5	500.	500.	500.	500.	500.	500.	500.
09.0000		176.	36529.	-11626.	399.7	457.0	450.	317.5	500.	500.	500.	500.	500.	500.	500.
09.5000		176.	37150.	-11939.	396.2	454.5	445.	307.5	500.	500.	500.	500.	500.	500.	500.
10.0000		176.	37767.	-12251.	392.7	452.0	440.	297.5	500.	500.	500.	500.	500.	500.	500.
10.5000		176.	38380.	-12562.	389.2	449.5	435.	287.5	500.	500.	500.	500.	500.	500.	500.
11.0000		176.	38989.	-12871.	385.7	447.0	430.	277.5	500.	500.	500.	500.	500.	500.	500.
11.5000		176.	39594.	-13179.	382.2	444.5	425.	267.5	500.	500.	500.	500.	500.	500.	500.
12.0000		176.	40195.	-13486.	378.7	442.0	420.	257.5	500.	500.	500.	500.	500.	500.	500.
12.5000		176.	40791.	-13792.	375.2	439.5	415.	247.5	500.	500.	500.	500.	500.	500.	500.
13.0000		176.	41382.	-14097.	371.7	437.0	410.	237.5	500.	500.	500.	500.	500.	500.	500.
13.5000		176.	41968.	-14401.	368.2	434.5	405.	227.5	500.	500.	500.	500.	500.	500.	500.
14.0000		176.	42550.	-14704.	364.7	432.0	400.	217.5	500.	500.	500.	500.	500.	500.	500.
14.5000		176.	43127.	-15006.	361.2	429.5	395.	207.5	500.	500.	500.	500.	500.	500.	500.
15.0000		176.	43700.	-15307.	357.7	427.0	390.	197.5	500.	500.	500.	500.	500.	500.	500.
15.5000		176.	44268.	-15607.	354.2	424.5	385.	187.5	500.	500.	500.	500.	500.	500.	500.
16.0000		176.	44832.	-15906.	350.7	422.0	380.	177.5	500.	500.	500.	500.	500.	500.	500.
16.5000		176.	45391.	-16204.	347.2	419.5	375.	167.5	500.	500.	500.	500.	500.	500.	500.
17.0000		176.	45945.	-16501.	343.7	417.0	370.	157.5	500.	500.	500.	500.	500.	500.	500.
17.5000		176.	46494.	-16797.	340.2	414.5	365.	147.5	500.	500.	500.	500.	500.	500.	500.
18.0000		176.	47038.	-17092.	336.7	412.0	360.	137.5	500.	500.	500.	500.	500.	500.	500.
18.5000		176.	47577.	-17386.	333.2	409.5	355.	127.5	500.	500.	500.	500.	500.	500.	500.
19.0000		176.	48111.	-17679.	329.7	407.0	350.	117.5	500.	500.	500.	500.	500.	500.	500.
19.5000		176.	48640.	-17971.	326.2	404.5	345.	107.5	500.	500.	500.	500.	500.	500.	500.
20.0000		176.	49164.	-18262.	322.7	402.0	340.	97.5	500.	500.	500.	500.	500.	500.	500.
20.5000		176.	49683.	-18552.	319.2	399.5	335.	87.5	500.	500.	500.	500.	500.	500.	500.
21.0000		176.	50197.	-18841.	315.7	397.0	330.	77.5	500.	500.	500.	500.	500.	500.	500.
21.5000		176.	50706.	-19129.	312.2	394.5	325.	67.5	500.	500.	500.	500.	500.	500.	500.
22.0000		176.	51210.	-19416.	308.7	392.0	320.	57.5	500.	500.	500.	500.	500.	500.	500.
22.5000		176.	51710.	-19703.	305.2	389.5	315.	47.5	500.	500.	500.	500.	500.	500.	500.
23.0000		176.	52205.	-19989.	301.7	387.0	310.	37.5	500.	500.	500.	500.	500.	500.	500.
23.5000		176.	52695.	-20274.	298.2	384.5	305.	27.5	500.	500.	500.	500.	500.	500.	500.
24.0000		176.	53180.	-20558.	294.7	382.0	300.	17.5	500.	500.	500.	500.	500.	500.	500.
24.5000		176.	53660.	-20841.	291.2	379.5	295.	7.5	500.	500.	500.	500.	500.	500.	500.
25.0000		176.	54135.	-21123.	287.7	377.0	290.	0.0	500.	500.	500.	500.	500.	500.	500.

SMUD RAPID COOLDOWN

F. L. BOYER

TIME	EQUIV LIN. RAD	TRIP TEMPERATURE	INSIDE THERMAL STRESS	OUTSIDE THERMAL STRESS	NOZZLE 1	NOZZLE 2	NOZZLE 3	NOZZLE 4	NOZZLE 5	NOZZLE 6	NOZZLE 7	NOZZLE 8	NOZZLE 9	MODE 10	MODE 11
50.0000	27968	42035	16753	17091	351.8	407.5	451.6	486.6	511.0	529.8	541.7	548.1	550.0	550.0	550.0
51.0000	28398	42237	17091	17439	347.8	407.5	448.1	483.1	507.0	526.6	538.0	544.5	549.0	549.0	549.0
52.0000	28606	42623	17439	17887	345.8	399.7	446.9	480.0	505.0	524.9	536.3	542.8	547.3	547.3	547.3
53.0000	29012	43017	17887	18335	341.9	395.8	442.9	475.9	500.0	520.0	531.4	537.9	542.4	542.4	542.4
54.0000	29406	43407	18335	18783	337.9	392.0	437.8	471.0	495.0	515.0	526.4	532.9	537.4	537.4	537.4
55.0000	29799	43795	18783	19231	333.9	388.1	432.7	466.1	490.0	510.0	521.4	527.9	532.4	532.4	532.4
56.0000	30192	44183	19231	19679	330.0	384.2	427.6	461.0	485.0	505.0	516.4	522.9	527.4	527.4	527.4
57.0000	30585	44571	19679	20127	326.0	379.3	422.5	455.9	480.0	500.0	511.4	517.9	522.4	522.4	522.4
58.0000	30978	44959	20127	20575	322.0	375.4	417.4	450.8	475.0	495.0	506.4	512.9	517.4	517.4	517.4
59.0000	31371	45347	20575	21023	318.0	371.5	412.3	445.7	470.0	490.0	501.4	507.9	512.4	512.4	512.4
60.0000	31764	45735	21023	21471	314.0	367.6	407.2	440.6	465.0	485.0	496.4	502.9	507.4	507.4	507.4
61.0000	32157	46123	21471	21919	310.0	363.7	402.1	435.5	460.0	480.0	491.4	497.9	502.4	502.4	502.4
62.0000	32550	46511	21919	22367	306.0	359.8	397.0	430.4	455.0	475.0	486.4	492.9	497.4	497.4	497.4
63.0000	32943	46899	22367	22815	302.0	355.9	391.9	425.3	450.0	470.0	481.4	487.9	492.4	492.4	492.4
64.0000	33336	47287	22815	23263	300.0	352.0	386.8	420.2	445.0	465.0	476.4	482.9	487.4	487.4	487.4
65.0000	33729	47675	23263	23711	296.0	348.1	381.7	415.1	440.0	460.0	471.4	477.9	482.4	482.4	482.4
66.0000	34122	48063	23711	24159	292.0	344.2	376.6	410.0	435.0	455.0	466.4	472.9	477.4	477.4	477.4
67.0000	34515	48451	24159	24607	288.0	340.3	371.5	404.9	430.0	450.0	461.4	467.9	472.4	472.4	472.4
68.0000	34908	48839	24607	25055	284.0	336.4	366.4	399.8	425.0	445.0	456.4	462.9	467.4	467.4	467.4
69.0000	35301	49227	25055	25503	280.0	332.5	361.3	394.7	420.0	440.0	451.4	457.9	462.4	462.4	462.4
70.0000	35694	49615	25503	25951	276.0	328.6	356.2	389.6	415.0	435.0	446.4	452.9	457.4	457.4	457.4

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT DATE 04/18/78

SMUD RAPID COOLDOWN

F. L. BOYER

DATE 04/18/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT

TIME	EQUIV RAD	THERMAL STRESS INSIDE LIN.	THERMAL STRESS OUTSIDE LIN.	MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9
70.0000	315937	425043	-202327	299.826	347.035	391.121	427.920	457.209	481.420	497.179	507.325	510.713
71.0000	315259	423343	-202502	299.898	346.579	390.790	427.997	456.497	480.920	496.753	506.208	509.532
72.0000	313977	421873	-201154	299.971	344.922	389.346	424.436	453.221	478.097	493.975	502.006	505.208
73.0000	312711	420563	-200377	299.995	342.922	387.922	422.122	450.875	475.753	491.625	500.000	503.208
74.0000	311002	419262	-199030	299.994	341.008	386.584	420.910	448.753	473.625	489.500	498.000	501.208
75.0000	309336	418112	-197955	299.994	340.000	385.246	418.753	446.625	471.500	487.375	496.000	500.000
76.0000	307665	417163	-197133	299.993	339.000	383.908	417.500	444.500	469.375	485.250	494.000	498.000
77.0000	305978	416213	-196493	299.992	337.000	382.570	416.250	442.375	467.250	483.125	492.000	496.000
78.0000	304402	415332	-196039	299.991	336.000	381.232	415.000	440.250	465.125	481.000	490.000	494.000
79.0000	302940	414465	-195736	299.990	334.000	380.000	413.750	438.125	463.000	478.875	488.000	492.000
80.0000	301490	413624	-195483	299.989	332.000	378.762	412.500	436.000	460.875	476.750	486.000	490.000
81.0000	299701	412820	-195280	299.988	331.000	377.523	411.250	433.875	458.750	474.625	484.000	488.000
82.0000	297907	412044	-195116	299.987	329.000	376.285	410.000	431.750	456.625	472.500	482.000	486.000
83.0000	296130	411295	-194986	299.986	327.000	375.047	408.750	429.625	454.500	470.375	480.000	484.000
84.0000	294367	410572	-194886	299.985	325.000	373.809	407.500	427.500	452.375	468.250	478.000	482.000
85.0000	292619	409876	-194806	299.984	323.000	372.571	406.250	425.375	450.250	466.125	476.000	480.000
86.0000	290886	409206	-194746	299.983	321.000	371.333	405.000	423.250	448.125	464.000	474.000	478.000
87.0000	289167	408561	-194706	299.982	319.000	370.095	403.750	421.125	446.000	461.875	472.000	476.000
88.0000	287462	407940	-194686	299.981	317.000	368.857	402.500	419.000	443.875	459.750	470.000	474.000
89.0000	285771	407343	-194686	299.980	315.000	367.619	401.250	416.875	441.750	457.625	468.000	472.000
90.0000	284094	406770	-194706	299.979	313.000	366.381	400.000	414.750	439.625	455.500	466.000	470.000
91.0000	282431	406221	-194746	299.978	311.000	365.143	398.750	412.625	437.500	453.375	464.000	468.000
92.0000	280782	405696	-194806	299.977	309.000	363.905	397.500	410.500	435.375	451.250	462.000	466.000
93.0000	279147	405195	-194886	299.976	307.000	362.667	396.250	408.375	433.250	449.125	460.000	464.000
94.0000	277526	404718	-194986	299.975	305.000	361.429	394.625	406.250	431.125	447.000	458.000	462.000
95.0000	275919	404265	-195116	299.974	303.000	360.191	393.000	404.125	429.000	444.875	456.000	460.000
96.0000	274326	403836	-195280	299.973	301.000	358.953	391.375	402.000	426.875	442.750	454.000	458.000
97.0000	272747	403431	-195486	299.972	299.000	357.715	389.625	400.000	424.750	440.625	452.000	456.000
98.0000	271182	403050	-195736	299.971	297.000	356.477	387.875	398.125	422.625	438.500	450.000	454.000
99.0000	269631	402703	-196039	299.970	295.000	355.239	386.125	396.625	420.500	436.375	448.000	452.000

SMUD RAPID COOLDOWN

F. L. BOYER A-6

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT FULL CERTIFICATION

DATE 04/18/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE BELT

TIME 140.0000
 EQUV LIN: 340 7.31%
 RAD 5.16%
 THERMAL STRESS INSIDE 7.27%
 THERMAL STRESS OUTSIDE -5.27%

MODE 1 340.0 MODE 2 346.1 MODE 3 353.1 MODE 4 360.7 MODE 5 368.2 MODE 6 374.9 MODE 7 380.0 MODE 8 383.3 MODE 9 384.3 MODE 10 384.3

SMUD RAPID COOLDOWN

F. L. BOYER

A-S

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL DIMENSIONS DATE 04/20/78

INSIDE RADIUS = 85.6875 INCHES OUTSIDE RADIUS = 94.2500 INCHES
 NO. OF NODES = 9 RADIAL INCREMENT = 1.0703 INCHES
 MATERIAL CODE = 2 POISSON'S RATIO = .3000
 L = -0.0000

NODE	INITIAL RADIUS	TEMPERATURE
1	85.6875	565.0
2	86.7578	565.0
3	87.8281	565.0
4	88.8984	565.0
5	89.9688	565.0
6	91.0391	565.0
7	92.1094	565.0
8	93.1797	565.0
9	94.2500	565.0

SMUD RAPID COOLDOWN
 F. L. BOYER A-9

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL DATE 04/20/78

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE TIME APPROX (MINUTES)	INSIDE FLUID TEMPERATURE	FILM COEFF. CURVE TIME APPROXIMATION (MINUTES)	INSIDE FILM COEFFICIENT	PRESSURE CURVE TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	565.0	0.0000	900.0	0.0000	0.0
5.0000	565.0	140.0000	900.0	0.0000	0.0
10.0000	560.0	0.0000	0.0	0.0000	0.0
15.0000	560.0	0.0000	0.0	0.0000	0.0
20.0000	525.0	0.0000	0.0	0.0000	0.0
40.0000	360.0	0.0000	0.0	0.0000	0.0
60.0000	300.0	0.0000	0.0	0.0000	0.0
80.0000	280.0	0.0000	0.0	0.0000	0.0
95.0000	290.0	0.0000	0.0	0.0000	0.0
110.0000	305.0	0.0000	0.0	0.0000	0.0
140.0000	340.0	0.0000	0.0	0.0000	0.0

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE TIME INCREMENT (MINUTES)	TIME LIMIT (MINUTES)	NUMB'R OF PRINTOUTS
.5000	20.000	120.
1.0000	80.000	160.

SMUD-RAPID COOLDOWN
F. L. BOYER
A-10

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL

DATE 04/20/78

TIME	EQUIV AD	LINE	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
00.0000		9775.	206336.	176688.	463	463	463	463	463	463	463	463	463	463	463
00.5000		3319.	176688.	176688.	459	459	459	459	459	459	459	459	459	459	459
01.0000		3777.	176688.	176688.	456	456	456	456	456	456	456	456	456	456	456
01.5000		4169.	176688.	176688.	452	452	452	452	452	452	452	452	452	452	452
02.0000		4554.	176688.	176688.	449	449	449	449	449	449	449	449	449	449	449
02.5000		4934.	176688.	176688.	445	445	445	445	445	445	445	445	445	445	445
03.0000		5307.	176688.	176688.	442	442	442	442	442	442	442	442	442	442	442
03.5000		5675.	176688.	176688.	438	438	438	438	438	438	438	438	438	438	438
04.0000		6037.	176688.	176688.	435	435	435	435	435	435	435	435	435	435	435
04.5000		6398.	176688.	176688.	431	431	431	431	431	431	431	431	431	431	431
05.0000		6745.	176688.	176688.	428	428	428	428	428	428	428	428	428	428	428
05.5000		7091.	176688.	176688.	424	424	424	424	424	424	424	424	424	424	424
06.0000		7432.	176688.	176688.	421	421	421	421	421	421	421	421	421	421	421
06.5000		7767.	176688.	176688.	417	417	417	417	417	417	417	417	417	417	417
07.0000		8098.	176688.	176688.	414	414	414	414	414	414	414	414	414	414	414
07.5000		8423.	176688.	176688.	410	410	410	410	410	410	410	410	410	410	410
08.0000		8744.	176688.	176688.	407	407	407	407	407	407	407	407	407	407	407
08.5000		9059.	176688.	176688.	404	404	404	404	404	404	404	404	404	404	404
09.0000		9370.	176688.	176688.	400	400	400	400	400	400	400	400	400	400	400
09.5000		9676.	176688.	176688.	397	397	397	397	397	397	397	397	397	397	397
10.0000		9977.	176688.	176688.	393	393	393	393	393	393	393	393	393	393	393
10.5000		0224.	176688.	176688.	389	389	389	389	389	389	389	389	389	389	389
11.0000		0421.	176688.	176688.	386	386	386	386	386	386	386	386	386	386	386
11.5000		0589.	176688.	176688.	382	382	382	382	382	382	382	382	382	382	382
12.0000		0731.	176688.	176688.	378	378	378	378	378	378	378	378	378	378	378
12.5000		0856.	176688.	176688.	374	374	374	374	374	374	374	374	374	374	374
13.0000		0965.	176688.	176688.	370	370	370	370	370	370	370	370	370	370	370
13.5000		1063.	176688.	176688.	366	366	366	366	366	366	366	366	366	366	366
14.0000		1147.	176688.	176688.	362	362	362	362	362	362	362	362	362	362	362
14.5000		1222.	176688.	176688.	358	358	358	358	358	358	358	358	358	358	358
15.0000		1290.	176688.	176688.	354	354	354	354	354	354	354	354	354	354	354
15.5000		1350.	176688.	176688.	350	350	350	350	350	350	350	350	350	350	350
16.0000		1403.	176688.	176688.	346	346	346	346	346	346	346	346	346	346	346
16.5000		1451.	176688.	176688.	342	342	342	342	342	342	342	342	342	342	342
17.0000		1495.	176688.	176688.	338	338	338	338	338	338	338	338	338	338	338
17.5000		1532.	176688.	176688.	334	334	334	334	334	334	334	334	334	334	334
18.0000		1565.	176688.	176688.	330	330	330	330	330	330	330	330	330	330	330
18.5000		1597.	176688.	176688.	326	326	326	326	326	326	326	326	326	326	326
19.0000		1626.	176688.	176688.	322	322	322	322	322	322	322	322	322	322	322
19.5000		1652.	176688.	176688.	318	318	318	318	318	318	318	318	318	318	318
20.0000		1677.	176688.	176688.	314	314	314	314	314	314	314	314	314	314	314

SMUD RAPID COOLDOWN

F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL FULL CERTIFICATION

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL FULL CERTIFICATION

TIME	EQUIV	LN	THERMAL STRESS INSIDE	THERMAL STRESS SURFACE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	MODE 10	MODE 11
70.0000	8597	8597	33710	33710	33710	33710	33710	33710	33710	33710	33710	33710	33710	33710	33710
71.0000	8404	8404	33296	33296	33296	33296	33296	33296	33296	33296	33296	33296	33296	33296	33296
72.0000	7866	7866	32764	32764	32764	32764	32764	32764	32764	32764	32764	32764	32764	32764	32764
73.0000	7506	7506	32535	32535	32535	32535	32535	32535	32535	32535	32535	32535	32535	32535	32535
74.0000	7331	7331	32306	32306	32306	32306	32306	32306	32306	32306	32306	32306	32306	32306	32306
75.0000	6986	6986	31850	31850	31850	31850	31850	31850	31850	31850	31850	31850	31850	31850	31850
76.0000	6649	6649	31350	31350	31350	31350	31350	31350	31350	31350	31350	31350	31350	31350	31350
77.0000	6319	6319	30850	30850	30850	30850	30850	30850	30850	30850	30850	30850	30850	30850	30850
78.0000	6158	6158	30610	30610	30610	30610	30610	30610	30610	30610	30610	30610	30610	30610	30610
79.0000	5848	5848	30210	30210	30210	30210	30210	30210	30210	30210	30210	30210	30210	30210	30210
80.0000	5531	5531	29820	29820	29820	29820	29820	29820	29820	29820	29820	29820	29820	29820	29820
81.0000	5230	5230	29440	29440	29440	29440	29440	29440	29440	29440	29440	29440	29440	29440	29440
82.0000	4861	4861	28960	28960	28960	28960	28960	28960	28960	28960	28960	28960	28960	28960	28960
83.0000	4441	4441	28460	28460	28460	28460	28460	28460	28460	28460	28460	28460	28460	28460	28460
84.0000	3997	3997	27940	27940	27940	27940	27940	27940	27940	27940	27940	27940	27940	27940	27940
85.0000	3542	3542	27400	27400	27400	27400	27400	27400	27400	27400	27400	27400	27400	27400	27400
86.0000	2639	2639	26790	26790	26790	26790	26790	26790	26790	26790	26790	26790	26790	26790	26790
87.0000	2190	2190	26170	26170	26170	26170	26170	26170	26170	26170	26170	26170	26170	26170	26170
88.0000	1744	1744	25540	25540	25540	25540	25540	25540	25540	25540	25540	25540	25540	25540	25540
89.0000	1317	1317	24900	24900	24900	24900	24900	24900	24900	24900	24900	24900	24900	24900	24900
90.0000	0871	0871	24250	24250	24250	24250	24250	24250	24250	24250	24250	24250	24250	24250	24250
91.0000	0669	0669	23600	23600	23600	23600	23600	23600	23600	23600	23600	23600	23600	23600	23600
92.0000	9283	9283	22950	22950	22950	22950	22950	22950	22950	22950	22950	22950	22950	22950	22950
93.0000	8908	8908	22300	22300	22300	22300	22300	22300	22300	22300	22300	22300	22300	22300	22300
94.0000	8529	8529	21650	21650	21650	21650	21650	21650	21650	21650	21650	21650	21650	21650	21650
95.0000	8148	8148	21000	21000	21000	21000	21000	21000	21000	21000	21000	21000	21000	21000	21000
96.0000	7769	7769	20350	20350	20350	20350	20350	20350	20350	20350	20350	20350	20350	20350	20350
97.0000	7390	7390	19700	19700	19700	19700	19700	19700	19700	19700	19700	19700	19700	19700	19700
98.0000	7011	7011	19050	19050	19050	19050	19050	19050	19050	19050	19050	19050	19050	19050	19050
99.0000	6632	6632	18400	18400	18400	18400	18400	18400	18400	18400	18400	18400	18400	18400	18400

SMUD RAPID COOLDOWN
F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION SHELL

DATE 04/20/78

TIME 140.0000
 EQUIV LIN: 314
 RAD -1967.
 THERMAL THERMAL STRESS INSIDE OUTSIDE
 -3079. 1169. 338.4

MODE 1 333.7 MODE 2 330.2 MODE 3 327.6 MODE 4 325.7 MODE 5 324.4 MODE 6 323.6 MODE 7 323.1 MODE 8 323.0 MODE 9 323.0 MODE 10 323.0

SMUD RAPID COOLDOWN
 F. L. BOYER

A-16

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD

DATE 04/18/78

DIMENSIONS

INSIDE RADIUS = 87.2500 INCHES OUTSIDE RADIUS = 92.2500 INCHES
NO. OF NODES = 9 RADIAL INCREMENT = .6250 INCHES
MATERIAL CODE = 2 POISSON S RATIO = .3000
L = -0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	87.2500	565.0
2	87.8750	565.0
3	88.5000	565.0
4	89.1250	565.0
5	89.7500	565.0
6	90.3750	565.0
7	91.0000	565.0
8	91.6250	565.0
9	92.2500	565.0

SMUD RAPID COOLDOWN
F. L. BOYER A-17

DATE 04/18/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE APPROXIMATION INSIDE FLUID TEMPERATURE (MINUTES)	FILM COEFF. CURVE APPROXIMATION INSIDE FILM COEFFICIENT (MINUTES)	PRESSURE CURVE APPROXIMATION PRESSURE (PSI)
0.0000	900.0	0.0000
5.0000	900.0	0.0000
10.0000	0.0	0.0000
15.0000	0.0	0.0000
20.0000	0.0	0.0000
40.0000	0.0	0.0000
60.0000	0.0	0.0000
80.0000	0.0	0.0000
95.0000	0.0	0.0000
110.0000	0.0	0.0000
140.0000	0.0	0.0000

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE INCREMENT (MINUTES)	NUMBER OF PRINTOUTS
1.0000	120
5.0000	120
140.0000	60

SMUD RAPID COOLDOWN
F. L. BOYER
A-18

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD

DATE 04/18/78

TIME	EQUIV RAD	LIN. STR.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE10	NODE11
30.0000		0451.	4411.	-6766.	462.8	481.4	497.1	510.0	520.4	533.9	537.2	538.3	538.3	538.3	538.3
30.5000		0588.	4579.	-6850.	459.2	470.0	493.9	507.0	517.6	528.8	533.9	534.0	534.0	534.0	534.0
31.0000		0719.	4740.	-6950.	455.7	474.7	490.7	504.0	514.6	525.8	530.9	531.0	531.0	531.0	531.0
31.5000		0844.	4894.	-7036.	452.2	471.3	487.5	497.9	508.5	519.7	524.8	524.9	524.9	524.9	524.9
32.0000		0964.	5040.	-7119.	448.7	467.9	484.1	494.8	505.4	516.6	521.7	521.8	521.8	521.8	521.8
32.5000		1079.	5180.	-7197.	445.1	466.6	481.8	491.7	502.2	513.4	518.5	518.6	518.6	518.6	518.6
33.0000		1187.	5314.	-7272.	441.6	461.2	477.8	491.5	501.8	512.8	517.9	518.0	518.0	518.0	518.0
33.5000		1291.	5441.	-7344.	438.0	457.8	474.6	488.5	498.6	509.5	514.6	514.7	514.7	514.7	514.7
34.0000		1390.	5562.	-7412.	434.5	456.4	471.3	482.2	493.3	504.0	509.1	509.2	509.2	509.2	509.2
34.5000		1485.	5677.	-7477.	430.9	450.9	468.0	479.0	490.0	500.8	505.9	506.0	506.0	506.0	506.0
35.0000		1574.	5786.	-7539.	427.4	450.5	466.7	477.0	487.6	498.2	503.3	503.4	503.4	503.4	503.4
35.5000		1660.	5890.	-7599.	423.8	446.0	465.9	475.5	486.3	496.7	501.8	501.9	501.9	501.9	501.9
36.0000		1741.	5989.	-7654.	420.3	440.6	465.2	474.2	484.7	495.0	500.1	500.2	500.2	500.2	500.2
36.5000		1819.	6083.	-7707.	416.7	437.2	464.6	472.5	483.1	493.3	498.4	498.5	498.5	498.5	498.5
37.0000		1892.	6171.	-7757.	413.1	433.3	464.1	471.7	481.6	491.7	496.8	496.9	496.9	496.9	496.9
37.5000		1961.	6255.	-7805.	409.6	430.2	463.7	470.2	480.3	490.3	495.4	495.5	495.5	495.5	495.5
38.0000		2026.	6335.	-7851.	406.0	426.6	463.5	468.7	477.5	487.3	492.4	492.5	492.5	492.5	492.5
38.5000		2088.	6410.	-7894.	402.4	423.3	463.4	466.0	475.8	485.5	490.6	490.7	490.7	490.7	490.7
39.0000		2147.	6480.	-7935.	398.9	419.8	463.3	464.7	473.6	482.2	487.3	487.4	487.4	487.4	487.4
39.5000		2203.	6547.	-7973.	395.3	416.6	463.0	463.6	471.3	479.7	484.8	484.9	484.9	484.9	484.9
40.0000		2255.	6609.	-8009.	391.7	413.7	462.8	462.6	469.0	477.1	482.2	482.3	482.3	482.3	482.3
40.5000		2303.	6669.	-8044.	388.0	410.9	462.7	462.2	466.2	474.8	480.0	480.1	480.1	480.1	480.1
41.0000		2348.	6723.	-8078.	384.6	408.6	462.5	461.7	464.6	472.6	477.7	477.8	477.8	477.8	477.8
41.5000		2391.	6773.	-8111.	381.2	406.6	462.4	461.4	463.0	470.7	475.8	475.9	475.9	475.9	475.9
42.0000		2433.	6818.	-8143.	377.8	404.7	462.3	461.2	461.5	468.8	474.0	474.1	474.1	474.1	474.1
42.5000		2473.	6858.	-8174.	374.7	402.9	462.2	461.0	460.7	467.0	472.2	472.3	472.3	472.3	472.3
43.0000		2511.	6893.	-8204.	371.9	401.6	462.1	460.8	460.5	465.2	470.4	470.5	470.5	470.5	470.5
43.5000		2547.	6923.	-8233.	369.1	400.1	462.0	460.6	460.4	463.5	468.6	468.7	468.7	468.7	468.7
44.0000		2581.	6948.	-8261.	366.7	399.4	461.9	460.5	460.2	461.8	466.8	466.9	466.9	466.9	466.9
44.5000		2613.	6968.	-8288.	364.5	399.1	461.8	460.4	460.1	460.6	465.0	465.1	465.1	465.1	465.1
45.0000		2644.	6983.	-8314.	362.5	398.6	461.7	460.3	460.0	459.0	463.2	463.3	463.3	463.3	463.3
45.5000		2674.	6994.	-8339.	360.6	398.5	461.6	460.2	459.9	458.1	461.4	461.5	461.5	461.5	461.5
46.0000		2703.	7000.	-8363.	358.8	398.4	461.5	460.1	459.8	457.3	459.6	459.7	459.7	459.7	459.7
46.5000		2731.	7002.	-8386.	357.1	398.3	461.4	460.0	459.7	456.8	457.9	458.0	458.0	458.0	458.0
47.0000		2758.	7000.	-8408.	355.5	398.2	461.3	460.0	459.6	455.9	456.0	456.1	456.1	456.1	456.1
47.5000		2784.	7000.	-8429.	354.0	398.1	461.2	460.0	459.5	455.0	455.1	455.2	455.2	455.2	455.2
48.0000		2809.	7000.	-8449.	352.6	398.0	461.1	460.0	459.4	454.9	455.0	455.1	455.1	455.1	455.1
48.5000		2833.	7000.	-8468.	351.2	397.9	461.0	460.0	459.3	454.8	454.9	455.0	455.0	455.0	455.0
49.0000		2856.	7000.	-8486.	350.0	397.8	460.9	460.0	459.2	454.7	454.8	454.9	454.9	454.9	454.9
49.5000		2878.	7000.	-8503.	348.8	397.7	460.8	460.0	459.1	454.6	454.7	454.8	454.8	454.8	454.8

SMUD P.P.P.D. COLDDOWN
 F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD

TIME	EQUIV RAD	THERMAL STRESS IN	THERMAL STRESS OUTSIDE	MODE 1 A	MODE 2 S	MODE 3 S	MODE 4 A	MODE 5 A	MODE 6 S	MODE 7 B	MODE 8 A	MODE 9 A	MODE 10 A	MODE 11 A
50.0000	96212	2714	-6493	348.7	364.5	376.5	390.4	400.8	408.5	413.0	417.1	415.8	415.8	415.8
51.0000	96232	2719	-6376	344.7	360.5	371.5	385.1	395.2	402.9	408.9	414.7	412.0	412.0	412.0
52.0000	96252	2724	-6241	340.5	357.5	366.5	380.2	388.5	397.1	403.6	409.3	407.7	407.7	407.7
53.0000	96272	2729	-6117	336.4	353.2	362.0	375.5	382.5	392.0	397.8	403.6	402.0	402.0	402.0
54.0000	96292	2734	-6002	332.2	349.0	357.5	371.1	378.0	387.5	392.7	398.4	396.8	396.8	396.8
55.0000	96312	2739	-5895	328.1	344.2	352.0	366.4	373.0	382.5	387.1	392.7	391.1	391.1	391.1
56.0000	96332	2744	-5795	324.0	340.5	348.5	362.9	369.5	378.0	382.5	388.1	386.6	386.6	386.6
57.0000	96352	2749	-5702	320.0	336.2	344.2	359.5	366.0	374.5	378.5	384.1	382.6	382.6	382.6
58.0000	96372	2754	-5615	316.0	332.0	340.5	355.9	362.5	371.0	375.0	380.5	379.0	379.0	379.0
59.0000	96392	2759	-5534	312.0	327.7	337.5	352.9	359.5	368.0	372.0	377.5	376.0	376.0	376.0
60.0000	96412	2764	-5458	308.0	323.5	333.5	349.4	356.0	364.5	368.5	374.0	372.5	372.5	372.5
61.0000	96432	2769	-5386	304.0	319.2	329.5	345.7	352.5	361.0	365.0	370.5	369.0	369.0	369.0
62.0000	96452	2774	-5319	300.0	315.0	325.5	341.9	348.5	357.0	361.0	366.5	365.0	365.0	365.0
63.0000	96472	2779	-5256	296.0	310.7	321.5	338.2	345.0	353.5	357.5	363.0	361.5	361.5	361.5
64.0000	96492	2784	-5197	292.0	306.5	317.5	334.2	341.0	349.5	353.5	359.0	357.5	357.5	357.5
65.0000	96512	2789	-5142	288.0	302.3	313.5	329.7	336.5	345.0	349.0	354.5	353.0	353.0	353.0
66.0000	96532	2794	-5090	284.0	298.1	309.5	325.6	332.5	341.0	345.0	350.5	349.0	349.0	349.0
67.0000	96552	2799	-5041	280.0	294.0	305.5	321.6	328.5	337.0	341.0	346.5	345.0	345.0	345.0
68.0000	96572	2804	-4995	276.0	290.0	301.5	317.6	324.5	333.0	337.0	342.5	341.0	341.0	341.0
69.0000	96592	2809	-4952	272.0	286.0	297.5	313.6	320.5	329.0	333.0	338.5	337.0	337.0	337.0
70.0000	96612	2814	-4912	268.0	282.0	293.5	309.6	316.5	325.0	329.0	334.5	333.0	333.0	333.0
71.0000	96632	2819	-4874	264.0	278.0	289.5	305.6	312.5	321.0	325.0	330.5	329.0	329.0	329.0
72.0000	96652	2824	-4838	260.0	274.0	285.5	301.6	308.5	317.0	321.0	326.5	325.0	325.0	325.0
73.0000	96672	2829	-4804	256.0	270.0	281.5	297.6	304.5	313.0	317.0	322.5	321.0	321.0	321.0
74.0000	96692	2834	-4772	252.0	266.0	277.5	293.6	300.5	309.0	313.0	318.5	317.0	317.0	317.0
75.0000	96712	2839	-4742	248.0	262.0	273.5	289.6	296.5	305.0	309.0	314.5	313.0	313.0	313.0
76.0000	96732	2844	-4714	244.0	258.0	269.5	285.6	292.5	301.0	305.0	310.5	309.0	309.0	309.0
77.0000	96752	2849	-4688	240.0	254.0	265.5	281.6	288.5	297.0	301.0	306.5	305.0	305.0	305.0
78.0000	96772	2854	-4664	236.0	250.0	261.5	277.6	284.5	293.0	297.0	302.5	301.0	301.0	301.0
79.0000	96792	2859	-4642	232.0	246.0	257.5	273.6	280.5	289.0	293.0	298.5	297.0	297.0	297.0
80.0000	96812	2864	-4622	228.0	242.0	253.5	269.6	276.5	285.0	289.0	294.5	293.0	293.0	293.0
81.0000	96832	2869	-4604	224.0	238.0	249.5	265.6	272.5	281.0	285.0	290.5	289.0	289.0	289.0
82.0000	96852	2874	-4588	220.0	234.0	245.5	261.6	268.5	277.0	281.0	286.5	285.0	285.0	285.0
83.0000	96872	2879	-4574	216.0	230.0	241.5	257.6	264.5	273.0	277.0	282.5	281.0	281.0	281.0
84.0000	96892	2884	-4562	212.0	226.0	237.5	253.6	260.5	269.0	273.0	278.5	277.0	277.0	277.0
85.0000	96912	2889	-4552	208.0	222.0	233.5	249.6	256.5	265.0	269.0	274.5	273.0	273.0	273.0
86.0000	96932	2894	-4544	204.0	218.0	229.5	245.6	252.5	261.0	265.0	270.5	269.0	269.0	269.0
87.0000	96952	2899	-4538	200.0	214.0	225.5	241.6	248.5	257.0	261.0	266.5	265.0	265.0	265.0
88.0000	96972	2904	-4534	196.0	210.0	221.5	237.6	244.5	253.0	257.0	262.5	261.0	261.0	261.0
89.0000	96992	2909	-4532	192.0	206.0	217.5	233.6	240.5	249.0	253.0	258.5	257.0	257.0	257.0
90.0000	97012	2914	-4532	188.0	202.0	213.5	229.6	236.5	245.0	249.0	254.5	253.0	253.0	253.0

SMUD RAPID COOLDOWN
F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD FULL CERTIFICATION

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD

TIME	EQUIV RAD	TRIP	TEMPERATURE	THERMAL INSIDE	THERMAL OUTSIDE	STRIP	DATE	NO10	NO211
70.0000	4680	6	94.9	301.4	307.7	304.7	04/18/78	06	07
70.5000	4555	6	92.2	309.2	305.8	304.0		6	7
71.0000	4434	6	91.0	299.9	304.0	302.7		6	8
71.5000	4319	6	90.4	299.1	304.0	302.7		6	8
72.0000	4208	6	89.9	296.6	302.9	302.4		6	8
72.5000	4102	6	89.4	295.2	300.6	301.2		6	8
73.0000	3980	6	88.9	294.4	300.4	301.0		6	8
73.5000	3860	6	88.9	294.4	300.4	301.0		6	8
74.0000	3740	6	88.9	292.7	300.2	300.8		6	8
74.5000	3624	6	88.9	292.7	300.2	300.8		6	8
75.0000	3512	6	88.9	292.7	300.2	300.8		6	8
75.5000	3400	6	88.9	292.7	300.2	300.8		6	8
76.0000	3288	6	88.9	292.7	300.2	300.8		6	8
76.5000	3176	6	88.9	292.7	300.2	300.8		6	8
77.0000	3064	6	88.9	292.7	300.2	300.8		6	8
77.5000	2952	6	88.9	292.7	300.2	300.8		6	8
78.0000	2840	6	88.9	292.7	300.2	300.8		6	8
78.5000	2728	6	88.9	292.7	300.2	300.8		6	8
79.0000	2616	6	88.9	292.7	300.2	300.8		6	8
79.5000	2504	6	88.9	292.7	300.2	300.8		6	8
80.0000	2392	6	88.9	292.7	300.2	300.8		6	8
80.5000	2280	6	88.9	292.7	300.2	300.8		6	8
81.0000	2168	6	88.9	292.7	300.2	300.8		6	8
81.5000	2056	6	88.9	292.7	300.2	300.8		6	8
82.0000	1944	6	88.9	292.7	300.2	300.8		6	8
82.5000	1832	6	88.9	292.7	300.2	300.8		6	8
83.0000	1720	6	88.9	292.7	300.2	300.8		6	8
83.5000	1608	6	88.9	292.7	300.2	300.8		6	8
84.0000	1496	6	88.9	292.7	300.2	300.8		6	8
84.5000	1384	6	88.9	292.7	300.2	300.8		6	8
85.0000	1272	6	88.9	292.7	300.2	300.8		6	8
85.5000	1160	6	88.9	292.7	300.2	300.8		6	8
86.0000	1048	6	88.9	292.7	300.2	300.8		6	8
86.5000	936	6	88.9	292.7	300.2	300.8		6	8
87.0000	824	6	88.9	292.7	300.2	300.8		6	8
87.5000	712	6	88.9	292.7	300.2	300.8		6	8
88.0000	600	6	88.9	292.7	300.2	300.8		6	8
88.5000	488	6	88.9	292.7	300.2	300.8		6	8
89.0000	376	6	88.9	292.7	300.2	300.8		6	8
89.5000	264	6	88.9	292.7	300.2	300.8		6	8
90.0000	152	6	88.9	292.7	300.2	300.8		6	8
90.5000	40	6	88.9	292.7	300.2	300.8		6	8
91.0000		6	88.9	292.7	300.2	300.8		6	8
91.5000		6	88.9	292.7	300.2	300.8		6	8
92.0000		6	88.9	292.7	300.2	300.8		6	8
92.5000		6	88.9	292.7	300.2	300.8		6	8
93.0000		6	88.9	292.7	300.2	300.8		6	8
93.5000		6	88.9	292.7	300.2	300.8		6	8
94.0000		6	88.9	292.7	300.2	300.8		6	8
94.5000		6	88.9	292.7	300.2	300.8		6	8
95.0000		6	88.9	292.7	300.2	300.8		6	8
95.5000		6	88.9	292.7	300.2	300.8		6	8
96.0000		6	88.9	292.7	300.2	300.8		6	8
96.5000		6	88.9	292.7	300.2	300.8		6	8
97.0000		6	88.9	292.7	300.2	300.8		6	8
97.5000		6	88.9	292.7	300.2	300.8		6	8
98.0000		6	88.9	292.7	300.2	300.8		6	8
98.5000		6	88.9	292.7	300.2	300.8		6	8
99.0000		6	88.9	292.7	300.2	300.8		6	8
99.5000		6	88.9	292.7	300.2	300.8		6	8

SMUD RAPID COOLDOWN
 F. L. BOYER

TIME	EQUIV RAD	TRIP LIM.	TEMPERATURE DISTRIBUTION LOWER HEAD	DATE	04/18/78
00.0000			MODE 1		MODE 9
01.0000			MODE 2		MODE 8
02.0000			MODE 3		MODE 7
03.0000			MODE 4		MODE 6
04.0000			MODE 5		MODE 5
05.0000			MODE 6		MODE 4
06.0000			MODE 7		MODE 3
07.0000			MODE 8		MODE 2
08.0000			MODE 9		MODE 1
09.0000			MODE 10		
10.0000			MODE 11		
11.0000			MODE 12		
12.0000			MODE 13		
13.0000			MODE 14		
14.0000			MODE 15		
15.0000			MODE 16		
16.0000			MODE 17		
17.0000			MODE 18		
18.0000			MODE 19		
19.0000			MODE 20		
20.0000			MODE 21		
21.0000			MODE 22		
22.0000			MODE 23		
23.0000			MODE 24		
24.0000			MODE 25		
25.0000			MODE 26		
26.0000			MODE 27		
27.0000			MODE 28		
28.0000			MODE 29		
29.0000			MODE 30		
30.0000			MODE 31		
31.0000			MODE 32		
32.0000			MODE 33		
33.0000			MODE 34		
34.0000			MODE 35		
35.0000			MODE 36		
36.0000			MODE 37		
37.0000			MODE 38		
38.0000			MODE 39		
39.0000			MODE 40		

SMUD RAPID COOLDOWN
 F. L. BOYER

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION LOWER HEAD DATE 06/18/78

EQUIV LIN: THERMAL STRESS SYNTHESIS
 RAD 51H: INSIDE OUTSIDE
 -1937. -2621. 1268.

TIME	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	MODE10	MODE11
140.0000	338.1	336.8	331.9	329.5	327.5	326.0	324.9	324.2	324.0		

SMUD RAPID COOLDOWN
 F. L. BOYER

SMUD COOLDOWN INCIDENT-SHELL ITERATION 20 PAGE 1 DATE 04/24/78

INPUT DATA DATE 04/24/78

TOTAL NO. OF SEGMENTS = 70

BOUNDARY CONDITIONS AT THE TOP (U) END

- 1. A RADIAL SHEAR OF 0.0000 POUNDS
- 2. A MOMENT OF 0.0000 INCH-LBS.

BOUNDARY CONDITIONS AT THE BOTTOM (V) END

- 1. AN AXIAL FORCE OF 1259.6000 POUNDS
- 2. A RADIAL SHEAR OF 0.0000 POUNDS
- 3. A MOMENT OF 0.0000 INCH-LBS.

NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.
ALL LOADS ABOVE, ARE ON A TOTAL LOAD BASIS.

SMUD RAPID COOLDOWN
F. L. BOYER A-25

SMUD COOLDOWN INCIDENT-SHELL *****
ITERATION 20 PAGE 2 DATE 04/24/78

MID-SURFACE GEOMETRY
AT TOP BOUNDARY, MEAN RADIUS = 90.1880 Z COORDINATE = 297.7910

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	SEGMENT DATA		CENTER OF CURVATURE DATA		CURVATURE IDENTIFIER
	BOTTOM	MEAN	RADIUS	Z	
10.0	90.188	255.541	0.000	0.000	0.0
13.0	90.906	250.372	0.000	0.000	0.0
44.0	90.906	85.688	0.000	0.000	0.0
55.0	88.638	73.415	0.000	0.000	0.0
70.0	85.517	81.013	0.000	89.949	1.0

NOTE - CURVATURE IDENTIFIER
+1 = POSITIVE CURVATURE
0 = NO CURVATURE
-1 = NEGATIVE CURVATURE

SMUD COOLDOWN INCIDENT-SHELL

ITERATION 20 PAGE 3 DATE 04/24/78

SEGMENTAL GEOMETRY BY SEGMENTS (K= SEGMENT NO.)

MEAN RADIUS										
K	R(K-1)	R(K)	R(K+1)	R(K+2)	R(K+3)	R(K+4)	R(K+5)	R(K+6)	R(K+7)	R(K+8)
1	40.19	40.19	40.19	40.19	40.19	40.19	40.19	40.19	40.19	40.19
2	40.19	40.09	40.00	49.91	49.91	49.91	49.91	49.91	49.91	49.91
3	40.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91
4	40.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91	49.91
5	49.91	49.91	48.84	48.70	48.57	48.44	48.54	48.92	48.54	76.56
6	71.90	66.63	60.79	54.44	47.62	40.41	32.45	25.02	16.97	8.78
7	.52									

Z COORDINATE										
K	Z(K-1)	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)
1	97.79	243.57	284.34	245.12	240.89	275.67	272.44	268.22	203.99	259.77
2	255.54	251.80	252.06	250.32	245.01	239.78	236.34	229.08	223.77	218.46
3	213.15	207.84	202.53	197.21	191.90	186.59	181.28	175.97	170.66	165.35
4	160.04	154.73	149.42	144.11	138.80	133.49	128.17	122.86	117.55	112.24
5	106.93	101.62	95.31	91.00	85.69	84.57	83.46	82.34	81.23	80.11
6	78.39	77.88	76.76	75.65	74.53	73.42	65.36	57.32	49.95	42.72
7	35.88	29.51	23.64	18.34	13.64	7.59	6.22	3.36	1.63	.44

SMUD F. L. BOYER COOLDOWN
 F. L. BOYER A-27

SMUD COOLDOWN INCIDENT-SHELL ITERATION 20 PAGE 4 DATE 04/24/78

SEGMENT THICKNESS DATA BY GROUPS

SEG. NO.	TOP THICK. OF SEG.	THICK. OF TOP SEG.	THICK. OF BOTTOM SEG.
1	12.00	12.00	12.00
2	10.81	13.00	19.44
3	8.44	8.44	8.44
4	8.44	8.44	5.50
5	6.57	8.44	5.38
6	5.38	5.38	5.38

SEGMENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (HA)	HA(K+1)	HA(K+2)	HA(K+3)	HA(K+4)	HA(K+5)	HA(K+6)	HA(K+7)	HA(K+8)	HA(K+9)
1	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00
2	10.81	10.81	10.81	10.81	10.81	10.81	10.81	10.81	10.81
3	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44
4	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44
5	6.57	6.57	6.57	6.57	6.57	6.57	6.57	6.57	6.57
6	5.38	5.38	5.38	5.38	5.38	5.38	5.38	5.38	5.38

THICKNESS AT BOTTOM OF SEGMENT (HB)

THICKNESS AT BOTTOM OF SEGMENT (HB)	HB(K+1)	HB(K+2)	HB(K+3)	HB(K+4)	HB(K+5)	HB(K+6)	HB(K+7)	HB(K+8)	HB(K+9)
1	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00	12.00
2	10.81	10.81	10.81	10.81	10.81	10.81	10.81	10.81	10.81
3	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44
4	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44	8.44
5	6.57	6.57	6.57	6.57	6.57	6.57	6.57	6.57	6.57
6	5.38	5.38	5.38	5.38	5.38	5.38	5.38	5.38	5.38

SMUD COOLDOWN INCIDENT
 F. L. BOYER
 A-28

SMUD COOLDOWN INCIDENT-SHELL ITEMATION 20 PAGE 5 DATE 04/24/78

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO.	ALPHA	MODULUS OF TENSION	MODULUS OF SHEAR	POISSON'S RATIO
1	745AE-05	2762E+08	062E+08	3000E+00
2	745RE-05	2762E+08	062E+08	3000E+00
3	745RE-05	2762E+08	062E+08	3000E+00
4	745RE-05	2762E+08	062E+08	3000E+00
5	745RE-05	2762E+08	062E+08	3000E+00
6	745RE-05	2762E+08	062E+08	3000E+00
7	745RE-05	2762E+08	062E+08	3000E+00
8	745RE-05	2762E+08	062E+08	3000E+00
9	745RE-05	2762E+08	062E+08	3000E+00
10	745RE-05	2762E+08	062E+08	3000E+00
11	745RE-05	2762E+08	062E+08	3000E+00
12	745RE-05	2762E+08	062E+08	3000E+00
13	745RE-05	2762E+08	062E+08	3000E+00
14	745RE-05	2762E+08	062E+08	3000E+00
15	745RE-05	2762E+08	062E+08	3000E+00
16	745RE-05	2762E+08	062E+08	3000E+00
17	745RE-05	2762E+08	062E+08	3000E+00
18	745RE-05	2762E+08	062E+08	3000E+00
19	745RE-05	2762E+08	062E+08	3000E+00
20	745RE-05	2762E+08	062E+08	3000E+00
21	745RE-05	2762E+08	062E+08	3000E+00
22	745RE-05	2762E+08	062E+08	3000E+00
23	745RE-05	2762E+08	062E+08	3000E+00
24	745RE-05	2762E+08	062E+08	3000E+00
25	745RE-05	2762E+08	062E+08	3000E+00
26	745RE-05	2762E+08	062E+08	3000E+00
27	745RE-05	2762E+08	062E+08	3000E+00
28	745RE-05	2762E+08	062E+08	3000E+00
29	745RE-05	2762E+08	062E+08	3000E+00
30	745RE-05	2762E+08	062E+08	3000E+00
31	745RE-05	2762E+08	062E+08	3000E+00
32	745RE-05	2762E+08	062E+08	3000E+00
33	745RE-05	2762E+08	062E+08	3000E+00
34	745RE-05	2762E+08	062E+08	3000E+00
35	745RE-05	2762E+08	062E+08	3000E+00
36	745RE-05	2762E+08	062E+08	3000E+00
37	745RE-05	2762E+08	062E+08	3000E+00
38	745RE-05	2762E+08	062E+08	3000E+00
39	745RE-05	2762E+08	062E+08	3000E+00
40	745RE-05	2762E+08	062E+08	3000E+00
41	745RE-05	2762E+08	062E+08	3000E+00
42	745RE-05	2762E+08	062E+08	3000E+00

SMUD RAPID COOLDOWN L. BOYER
A-29

SMUD COOLDOWN INCIDENT-SHELL
 FULL CERTIFICATION

SMUD COOLDOWN INCIDENT-SHELL
 FULL CERTIFICATION

ITERATION 20 PAGE 6 DATE 04/24/78

SMUD COOLDOWN INCIDENT-SHELL

43	7460E-05	2761E+08	062E+08	3000E+00
44	7460E-05	2761E+08	062E+08	3000E+00
45	7460E-05	2761E+08	062E+08	3000E+00
46	7460E-05	2761E+08	062E+08	3000E+00
47	7460E-05	2761E+08	062E+08	3000E+00
48	7460E-05	2761E+08	062E+08	3000E+00
49	7460E-05	2761E+08	062E+08	3000E+00
50	7460E-05	2761E+08	062E+08	3000E+00
51	7460E-05	2761E+08	062E+08	3000E+00
52	7460E-05	2761E+08	062E+08	3000E+00
53	7460E-05	2761E+08	062E+08	3000E+00
54	7460E-05	2761E+08	062E+08	3000E+00
55	7460E-05	2761E+08	062E+08	3000E+00
56	7460E-05	2761E+08	062E+08	3000E+00
57	7460E-05	2761E+08	062E+08	3000E+00
58	7460E-05	2761E+08	062E+08	3000E+00
59	7460E-05	2761E+08	062E+08	3000E+00
60	7460E-05	2761E+08	062E+08	3000E+00
61	7460E-05	2761E+08	062E+08	3000E+00
62	7460E-05	2761E+08	062E+08	3000E+00
63	7460E-05	2761E+08	062E+08	3000E+00
64	7460E-05	2761E+08	062E+08	3000E+00
65	7460E-05	2761E+08	062E+08	3000E+00
66	7460E-05	2761E+08	062E+08	3000E+00
67	7460E-05	2761E+08	062E+08	3000E+00
68	7460E-05	2761E+08	062E+08	3000E+00
69	7460E-05	2761E+08	062E+08	3000E+00
70	7460E-05	2761E+08	062E+08	3000E+00

SMUD COOLDOWN INCIDENT-SHELL

ITERATION 20 PAGE 7 DATE 04/24/78

PRESSURE INPUT DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INTERNAL PRESSURE	EXTERNAL PRESSURE
1.0	70.0	1500.0	0.0

MECHANICAL LOADING ON SEGMENTAL GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	70.0	0.	0.	0.

STRESS CONCENTRATION FACTORS BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INSIDE		OUTSIDE	
		TENSION	BENDING	TENSION	BENDING
1	0	.00	.00	.00	.00
1	3	.57	.35	.57	.35
1	70	.00	.00	.00	.00

SMUD RAPID COOLDOWN
 F. L. BOYER

A-31

SMUD COOLDOWN INCIDENT-SHELL ITERATION 20 PAGE 8 DATE 04/24/78

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

SEGMENT	OUTSIDE	T1	T2	T3	T4	INSIDE	T5	SEGMENT	OUTSIDE	T1	T2	T3	T4	INSIDE	T5
1	506	506	499	495	491	484	484	15	506	506	500	492	489	484	484
2	506	506	499	495	491	484	484	16	506	506	500	492	489	484	484
3	506	506	499	495	491	484	484	17	506	506	500	492	489	484	484
4	506	506	499	495	491	484	484	18	506	506	500	492	489	484	484
5	506	506	499	495	491	484	484	19	506	506	500	492	489	484	484
6	506	506	499	495	491	484	484	20	506	506	500	492	489	484	484
7	506	506	499	495	491	484	484	21	506	506	500	492	489	484	484
8	506	506	499	495	491	484	484	22	506	506	500	492	489	484	484
9	506	506	499	495	491	484	484	23	506	506	500	492	489	484	484
10	506	506	499	495	491	484	484	24	506	506	500	492	489	484	484
11	506	506	499	495	491	484	484	25	506	506	500	492	489	484	484
12	506	506	499	495	491	484	484	26	506	506	500	492	489	484	484
13	506	506	499	495	491	484	484	27	506	506	500	492	489	484	484
14	506	506	499	495	491	484	484	28	506	506	500	492	489	484	484
15	506	506	499	495	491	484	484	29	506	506	500	492	489	484	484
16	506	506	499	495	491	484	484	30	506	506	500	492	489	484	484
17	506	506	499	495	491	484	484	31	506	506	500	492	489	484	484
18	506	506	499	495	491	484	484	32	506	506	500	492	489	484	484
19	506	506	499	495	491	484	484	33	506	506	500	492	489	484	484
20	506	506	499	495	491	484	484	34	506	506	500	492	489	484	484
21	506	506	499	495	491	484	484	35	506	506	500	492	489	484	484

SMUD COOLDOWN INCIDENT-SHELL ITERATION 20 PAGE 9 DATE 04/24/78

PRIMARY + SECONDARY BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (IN)	SUM
AXIAL FORCE (N)	0.	0.	1260E+04	0.	0.	0.	0.	1260E+04
RADIAL SHEAR (O)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (O)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (IN)
AXIAL DEFL. (N)	1095E+01	4706E-01	1506E-06	124E-09	2139E-11	726E-09	6854E-09
RADIAL DEFL. (O)	329E+00	263E-01	124E-09	32E-09	125E-09	547E-18	259E-18
ROTATION (O)	281E-03	44E-04	213E-11	12E-09	107E-10	109E-18	481E-18
RADIAL DEFL. (N)	81E-02	22E-03	24E-09	55E-14	10E-14	64E-19	52E-19
ROTATION (N)	185E-04	23E-04	465E-09	252E-17	14E-18	52E-11	22E-10

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (IN)	SUM
AXIAL DEFL. (N)	1095E+01	4706E-01	189E-03	0.	0.	0.	0.	113E+01
RADIAL DEFL. (O)	329E+00	263E-01	156E-06	0.	0.	0.	0.	52E+00
ROTATION (O)	281E-03	44E-04	204E-08	0.	0.	0.	0.	265E+03
RADIAL DEFL. (N)	81E-02	22E-03	914E-06	0.	0.	0.	0.	220E+02
ROTATION (N)	185E-04	23E-04	463E-06	0.	0.	0.	0.	155E+04

F. L. BOYER

SMUD COOLDOWN INCIDENT-SHELL

ITERATION 20 PAGE 10 DATE 04/24/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
(THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	U(O)	U(I)	M(I)	Q(I)
ROTATION(U)	.673543E-10	.832500E-09	.930326E-10	.685644E-10
DEFLECTION(U)	.432500E-09	.22615E-07	.162864E-16	-.342867E-17
ROTATION(I)	.930326E-10	.162864E-16	.52149E-08	.359504E-10
DEFLECTION(I)	.685644E-10	-.342867E-17	.359504E-10	.417684E-08

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

SMUD RAPID COOLDOWN
F. L. BOYER
A-34

SMUD COOLDOWN INCIDENT-SHELL ITERATION 20 PAGE 11 DATE 04/24/78

PRIMARY & SECONDARY FORCES AND MOTIONS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS

RADIAL----- TO THE LEFT
 ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- UPWARD

TO THE RIGHT
 COUNTERCLOCKWISE
 DOWNSWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
0	TOP	0.	0.	0.	TOP	0.	0.	0.
1	ROI	4358E+06	9734E+06	3350E+08	ROI	3574E+00	3655E-03	1595E-01
2	ROI	7390E+06	3503E+07	3350E+08	ROI	3584E+00	3307E-03	3147E-01
3	ROI	9214E+06	7054E+07	3350E+08	ROI	3611E+00	3298E-03	4179E-01
4	ROI	9473E+06	1152E+08	3350E+08	ROI	3623E+00	2502E-03	6368E-01
5	ROI	9766E+06	1575E+08	3350E+08	ROI	3633E+00	2360E-03	7456E-01
6	ROI	4574E+06	1925E+08	3350E+08	ROI	3642E+00	2264E-03	9544E-01
7	ROI	6543E+06	2429E+08	3350E+08	ROI	3651E+00	2269E-03	1113E+00
8	ROI	3598E+06	2665E+08	3350E+08	ROI	3660E+00	2297E-03	1271E+00
9	ROI	2451E+06	2532E+08	3350E+08	ROI	3670E+00	2367E-03	1430E+00
10	ROI	1577E+06	2427E+08	3350E+08	ROI	3680E+00	2392E-03	1588E+00
11	ROI	1104E+06	2439E+08	3389E+08	ROI	3692E+00	2400E-03	1653E+00
12	ROI	1190E+07	2335E+08	3629E+08	ROI	3692E+00	2417E-03	1719E+00
13	ROI	7161E+06	2162E+08	3669E+08	ROI	3692E+00	2456E-03	1786E+00
14	ROI	3635E+06	1652E+08	3669E+08	ROI	3692E+00	2476E-03	1948E+00
15	ROI	1177E+06	3755E+08	3669E+08	ROI	3713E+00	2269E-03	2191E+00
16	ROI	5170E+05	2518E+08	3669E+08	ROI	3724E+00	1897E-03	2393E+00
17	ROI	1464E+06	2044E+08	3669E+08	ROI	3733E+00	1502E-03	2545E+00
18	ROI	1910E+06	348E+08	3669E+08	ROI	3749E+00	1118E-03	2747E+00
19	ROI	2094E+06	348E+08	3669E+08	ROI	3758E+00	775E-04	2994E+00
20	ROI	4732E+06	493E+08	3669E+08	ROI	3768E+00	501E-04	3209E+00
21	ROI	6502E+06	542E+08	3669E+08	ROI	3782E+00	281E-04	3402E+00
22	ROI	8376E+06	642E+08	3669E+08	ROI	3791E+00	1349E-04	3604E+00
23	ROI	911E+05	773E+08	3669E+08	ROI	3791E+00	804E-05	3805E+00
24	ROI	5571E+05	825E+08	3669E+08	ROI	3791E+00	461E-05	4007E+00
25	ROI	2713E+05	942E+08	3669E+08	ROI	3791E+00	2360E-05	4209E+00
26	ROI	2731E+04	942E+08	3669E+08	ROI	3791E+00	990E-05	4412E+00
27	ROI	4731E+04	957E+08	3669E+08	ROI	3791E+00	690E-05	4612E+00
28	ROI	4704E+05	940E+08	3669E+08	ROI	3791E+00	452E-05	4814E+00
29	ROI	4704E+05	940E+08	3669E+08	ROI	3791E+00	298E-04	5015E+00
30	ROI	4704E+05	940E+08	3669E+08	ROI	3791E+00	120E-04	5217E+00
31	ROI	4756E+06	1851E+08	3669E+08	ROI	3791E+00	404E-04	5418E+00
32	ROI	4756E+06	1851E+08	3669E+08	ROI	3791E+00	132E-04	5620E+00

F. L. BOYER

A-35

33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70			
1754E+06	2307E+06	2450E+06	3339E+06	3420E+06	2527E+06	2427E+06	1405E+07	6943E+07	7013E+07	4953E+08	1374E+08	2247E+08	2112E+08	2003E+08	1913E+08	1823E+08	1823E+08	1467E+08	1947E+08	2065E+08	2227E+08	2434E+08	1414E+09	1434E+09	1039E+09	9707E+09	1085E+09	1404E+09	785E+09	717E+09	1014E+09	8007E+09	6264E+09	631E+09	1215E+09	9550E+09	3337E+09	3477E+09		
3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	3469E+08	
901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901	901
3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00	3754E+00
9224E+05	2097E+04	4771E+04	729E+04	1375E+03	1989E+03	2490E+03	3422E+03	4090E+03	4547E+03	4537E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	4508E+03	
5822E+00	6023E+00	6225E+00	6626E+00	6830E+00	7032E+00	7234E+00	7436E+00	7638E+00	7841E+00	8043E+00	8245E+00	8447E+00	8649E+00	8851E+00	9053E+00	9255E+00	9457E+00	9659E+00	9861E+00	10063E+00	10265E+00	10467E+00	10669E+00	10871E+00	11073E+00	11275E+00	11477E+00	11679E+00	11881E+00	12083E+00	12285E+00	12487E+00	12689E+00	12891E+00	13093E+00	13295E+00	13497E+00	13699E+00		

IFORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

SMUD COOLDOWN INCIDENT-SHELL

ITERATION 20 PAGE 13 DATE 04/24/78

PRIMARY & SECONDARY STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAI.	LONG	HOOP	RAI.	LONG	HOOP	RAI.
1	7362.6	7362.6	0.0	6972.1	9373.1	-543.9	5349.4	1574.8	478.2
2	7556.2	7556.2	0.0	4977.2	9774.2	-538.2	5538.9	2069.7	475.2
3	7907.3	7907.3	0.0	4944.4	0111.1	-530.9	5805.5	2539.3	472.2
4	8114.3	8114.3	0.0	4942.4	0453.3	-522.8	6113.3	2983.3	469.2
5	8246.8	8246.8	0.0	5001.4	0751.2	-514.4	6424.0	3403.3	466.6
6	8472.9	8472.9	0.0	5007.4	1075.4	-506.3	6722.8	3801.3	463.6
7	8660.0	8660.0	0.0	5016.5	1315.5	-498.4	6965.5	4174.5	461.1
8	8874.0	8874.0	0.0	5021.6	1600.3	-492.8	7124.5	4534.5	458.4
9	9128.9	9128.9	0.0	5023.9	1895.3	-488.5	7182.5	4875.4	456.6
10	9437.6	9437.6	0.0	5022.4	2207.5	-486.5	7097.3	5186.5	454.7
11	9635.0	9635.0	0.0	5529.4	2547.2	-368.4	8089.6	5452.3	448.2
12	9836.3	9836.3	0.0	6381.1	2907.2	-376.1	9333.2	5556.4	494.2
13	9846.4	9846.4	0.0	7354.8	3317.2	-387.2	10170.7	7351.3	201.3
14	9846.4	9846.4	0.0	7365.5	3714.0	-522.8	1132.6	7518.3	473.8
15	9846.4	9846.4	0.0	7357.1	4149.8	-529.5	1707.2	7449.7	473.6
16	9846.4	9846.4	0.0	7353.1	4591.8	-532.4	2526.3	8170.7	472.5
17	9846.4	9846.4	0.0	7351.9	4793.3	-532.4	3518.7	8466.2	471.3
18	9846.4	9846.4	0.0	7354.5	4906.3	-531.0	4597.5	8714.8	469.4
19	9846.4	9846.4	0.0	7357.0	5166.6	-524.4	5734.6	8970.6	469.4
20	9846.4	9846.4	0.0	7360.0	5244.4	-523.2	6949.7	9071.3	469.4
21	9846.4	9846.4	0.0	7363.0	5301.4	-523.7	8009.9	9182.3	468.4
22	9846.4	9846.4	0.0	7365.9	5329.8	-523.5	8823.4	9253.6	467.5
23	9846.4	9846.4	0.0	7368.0	5314.8	-524.0	9425.0	9324.9	466.6
24	9846.4	9846.4	0.0	7370.4	5336.8	-524.4	10475.0	9324.9	466.6
25	9846.4	9846.4	0.0	7371.4	5337.0	-524.8	10501.0	9341.4	466.6
26	9846.4	9846.4	0.0	7372.4	5319.5	-525.4	11535.5	9344.8	466.6
27	9846.4	9846.4	0.0	7373.3	5315.0	-525.3	10572.3	9356.7	465.5
28	9846.4	9846.4	0.0	7373.3	5314.4	-525.0	10648.3	9364.6	465.5
29	9846.4	9846.4	0.0	7373.3	5320.1	-525.6	10605.3	9374.5	466.6
30	9846.4	9846.4	0.0	7373.3	5316.9	-525.0	10574.0	9383.3	466.6
31	9846.4	9846.4	0.0	7372.4	5316.7	-525.0	10524.2	9374.5	466.6
32	9846.4	9846.4	0.0	7371.4	5304.0	-525.3	10446.4	9346.6	466.6
33	9846.4	9846.4	0.0	7366.0	5297.7	-525.0	10324.0	9343.3	466.6
34	9846.4	9846.4	0.0	7362.4	5296.8	-525.1	10165.3	9343.3	466.6
35	9846.4	9846.4	0.0	7362.4	5296.8	-525.1	9955.3	9271.3	467.5
36	9846.4	9846.4	0.0	7357.0	5297.0	-525.1	9702.3	9166.6	467.5
37	9846.4	9846.4	0.0	7352.7	5297.0	-525.1	9419.3	8955.3	468.6
38	9846.4	9846.4	0.0	7347.3	5297.0	-525.1	9126.3	8685.3	469.4
39	9846.4	9846.4	0.0	7342.3	5297.0	-525.1	8803.3	8327.3	471.0
40	9846.4	9846.4	0.0	7337.6	5297.0	-525.1	8505.3	7879.3	473.0
41	9846.4	9846.4	0.0	7333.7	5297.0	-525.1	8240.3	7353.3	474.4
42	9846.4	9846.4	0.0	7331.0	5297.0	-525.1	8018.3	6780.3	476.4
43	9846.4	9846.4	0.0	7326.3	5297.0	-525.1	7847.3	6222.3	478.6

SMUD RAPID COOLDOWN

F. L. BOYER

A-37

ITEM	ITERATION	ZU	PAGE 14	DATE 04/24/78
44	8052.6	113.3	5777.7	-479.6
45	7760.6	137.6	5906.5	-438.5
46	7582.7	155.8	5984.8	-440.2
47	7396.0	204.7	6082.4	-441.4
48	7194.7	250.5	6211.7	-443.4
49	6978.7	307.9	6367.5	-444.9
50	6736.6	376.9	6557.4	-447.3
51	6463.3	457.0	6784.2	-447.6
52	6144.9	549.0	7047.4	-448.7
53	5782.0	653.0	7461.3	-449.6
54	5350.4	778.2	7930.3	-450.3
55	4835.7	919.4	8525.1	-450.7
56	5004.4	1074.6	9194.6	-431.0
57	5405.0	1242.2	9893.0	-443.1
58	5228.3	1403.4	10645.1	-451.6
59	5058.1	1559.7	11455.6	-455.6
60	4857.4	1703.9	12300.7	-454.9
61	4738.9	1846.5	13194.2	-439.4
62	4593.9	1977.6	14125.2	-437.5
63	4445.9	2076.6	14886.6	-439.7
64	4283.1	2140.5	15494.3	-442.1
65	4125.1	2176.7	16043.5	-444.7
66	3940.9	2190.6	16541.5	-446.5
67	3745.6	2180.1	17000.5	-447.5
68	3513.9	2149.9	17382.0	-449.0
69	3238.8	2105.1	17677.5	-449.2
70	10998.8	2034.0	17948.5	-448.3

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

SMUD COOLDOWN INCIDENT-SHELL

STRESS INTENSITY PROGRAM OUT (IN KIPS)

STRESS AT BOTTOM OF SEGMENT NO. 13.

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - R		R - H		H - L		L - R		R - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
20	12.1	3.8	-18.5	-9.5	6.5	5.7	23.6	9.0	-25.1	-11.4	1.5	2.4
40	37.1	-14.4	-48.0	.6	10.8	13.8	61.0	-9.2	-50.7	-4.6	-1.2	13.8
60	42.7	-20.3	-54.0	1.5	11.3	18.7	67.2	-17.0	-65.0	-3.2	-2.2	20.2
100	25.5	-7.4	-36.3	-10.8	4.4	18.3	37.1	-4.0	-37.8	-11.4	.7	17.3

STRESS OUTPUT ANALYSIS

STRESS	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	42.7	3.8	0.0	1.6	11.3	18.7	67.2	9.0	0.0	0.0	1.5	20.2
MINIMUM	0.0	-20.3	-54.0	-10.8	0.0	0.0	0.0	-17.0	-65.0	-11.4	-2.2	0.0
RANGE	42.7	24.1	54.0	12.5	11.3	16.7	67.2	26.0	65.0	11.4	3.6	20.2

SMUD RAPID COOLDOWN
 F. L. BOYER

A-39

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION

DATE 04/20/78

DIMENSIONS

INSIDE RADIUS = .3125 INCHES OUTSIDE RADIUS = 1.0000 INCHES
 NO. OF NODES = 9 RADIAL INCREMENT = .0859 INCHES
 MATERIAL CODE = 5 POISSON'S RATIO = .3000
 L = -0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	.3125	565.0
2	.3984	565.0
3	.4844	565.0
4	.5703	565.0
5	.6563	565.0
6	.7422	565.0
7	.8281	565.0
8	.9141	565.0
9	1.0000	565.0

SMUD RAPID COOLDOWN
 F. L. BOYER
 A-40

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION DATE 04/20/78

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATE (MINUTES)	INSIDE FLUID TEMPERATURE	TIME APPROXIMATE (MINUTES)	INSIDE FILM COEFFICIENT	TIME APPROXIMATE (MINUTES)	PRESSURE APPROXIMATION (PSI)
0.0000	565.0	0.0000	150.0	0.0000	0.0000
5.0000	565.0	140.0000	150.0	0.0000	0.0000
10.0000	590.0	0.0000	0.0	0.0000	0.0000
15.0000	590.0	0.0000	0.0	0.0000	0.0000
20.0000	525.0	0.0000	0.0	0.0000	0.0000
40.0000	340.0	0.0000	0.0	0.0000	0.0000
60.0000	300.0	0.0000	0.0	0.0000	0.0000
80.0000	280.0	0.0000	0.0	0.0000	0.0000
95.0000	290.0	0.0000	0.0	0.0000	0.0000
110.0000	305.0	0.0000	0.0	0.0000	0.0000
140.0000	340.0	0.0000	0.0	0.0000	0.0000

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE INCREMENT (MINUTES)	NUMBER OF PRINTOUTS
5.000	20.
1.5000	120.
1.0000	60.

SMUD RAPID COOLDOWN
F. L. BOYER
A-41

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION

DATE 04/20/78

TIME	EQUIV RAD	LIN. STR.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
0.0000		-0.	-0.	0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
0.0000		-0.	-0.	0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
0.0000		-0.	-0.	0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
0.0000		-0.	-0.	0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
0.0000		-149.	-261.	5.5	566.6	566.6	566.6	566.6	566.6	566.6	566.6	566.6	566.6	566.6	566.6
0.0000		-272.	-464.	5.5	571.7	571.0	570.4	570.0	570.0	570.0	570.0	570.0	570.0	570.0	570.0
0.0000		-365.	-727.	5.5	575.7	574.7	573.6	573.3	573.3	573.3	573.3	573.3	573.3	573.3	573.3
0.0000		-637.	-1339.	5.5	581.5	580.8	577.2	576.7	576.3	576.3	576.3	576.3	576.3	576.3	576.3
0.0000		-1387.	-3222.	5.5	585.0	584.6	582.2	582.2	582.2	582.2	582.2	582.2	582.2	582.2	582.2
0.0000		-2233.	-5380.	5.5	585.0	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6	584.6
0.0000		-3722.	-8839.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-5291.	-13066.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-7491.	-22777.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-11399.	-38473.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-17623.	-60421.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-26957.	-95746.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-41111.	-149577.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-60444.	-22424.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-86297.	-34659.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-121450.	-52866.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-170113.	-81127.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-247266.	-121910.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-362939.	-186677.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-534472.	-279933.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-787005.	-411077.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-1154538.	-604444.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-1697071.	-883977.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-2472604.	-1306611.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-3629137.	-1957464.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-5344670.	-2842497.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-7870203.	-4111331.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-11545766.	-6044664.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-16971299.	-8839997.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-24726832.	-13067331.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-36292365.	-19575964.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-53447998.	-28425597.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-78703531.	-41114231.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-115459444.	-60447864.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-169724777.	-88391197.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-247279110.	-13067831.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-362934443.	-19576464.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-534489776.	-28426097.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-787045109.	-41114731.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-1154606042.	-60448364.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-1697309375.	-88391797.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-2472852708.	-13068463.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-3629406041.	-19577096.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-5344959374.	-28426729.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-7870512707.	-41115231.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-11546180440.	-60449364.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-16973763773.	-88391997.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-24729197106.	-13069063.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-36294730439.	-19577696.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-53450263772.	-28427329.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-78705797105.	-41115731.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-115462740440.	-60449964.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5
0.0000		-169743503773.	-88392197.	5.5	585.0	584.6	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5	585.5

SMUD RAPID COLDOW
 F. L. BOYER
 A-42

S4UD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION DATE 04/20/78

TIME	EQUIV LIN. RAD	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9	MODE 10	MODE 11
30.0000	0.17	731	-456	474.6	476.6	477.8	478.9	479.7	480.3	480.7	480.7	480.7	481.0	481.0
31.0000	0.15	726	-455	470.6	468.9	474.1	471.8	476.2	472.9	473.3	473.3	473.3	473.3	473.3
32.0000	0.13	723	-434	463.0	462.5	466.0	464.1	468.9	465.2	465.6	465.6	465.6	465.6	465.6
33.0000	0.12	722	-434	457.9	454.5	459.3	458.8	461.2	458.8	458.8	458.8	458.8	458.8	458.8
34.0000	0.11	722	-433	448.8	450.9	452.0	449.4	453.0	450.9	451.3	451.3	451.3	451.3	451.3
35.0000	0.11	721	-433	441.6	443.2	444.0	445.4	446.9	444.0	443.9	443.9	443.9	443.9	443.9
36.0000	0.11	722	-434	433.3	435.2	433.7	434.4	435.5	433.6	433.6	433.6	433.6	433.6	433.6
37.0000	0.11	725	-434	428.6	429.6	430.1	431.5	432.9	430.9	430.9	430.9	430.9	430.9	430.9
38.0000	0.11	726	-435	422.9	421.3	422.8	423.2	424.0	422.6	422.6	422.6	422.6	422.6	422.6
39.0000	0.11	727	-435	415.5	416.0	415.9	416.9	417.4	416.0	416.0	416.0	416.0	416.0	416.0
40.0000	0.11	729	-435	408.2	410.7	408.2	409.3	410.5	408.7	407.7	407.7	407.7	407.7	407.7
41.0000	0.11	739	-435	403.1	403.1	404.1	405.2	405.9	403.5	403.5	403.5	403.5	403.5	403.5
42.0000	0.15	55	-432	395.5	395.5	397.9	398.7	399.6	397.0	397.0	397.0	397.0	397.0	397.0
43.0000	0.12	412	-374	390.0	390.0	394.0	392.4	395.6	393.9	393.9	393.9	393.9	393.9	393.9
44.0000	0.12	355	-359	385.3	385.3	386.3	387.2	388.5	385.9	385.9	385.9	385.9	385.9	385.9
45.0000	0.12	221	-334	381.2	381.2	383.1	384.5	385.5	382.9	382.9	382.9	382.9	382.9	382.9
46.0000	0.12	190	-314	376.3	376.3	378.1	379.4	380.4	377.8	377.8	377.8	377.8	377.8	377.8
47.0000	0.11	161	-300	375.9	375.9	376.9	377.0	378.0	375.0	375.0	375.0	375.0	375.0	375.0
48.0000	0.14	114	-279	371.6	370.6	371.4	372.3	373.0	370.6	370.6	370.6	370.6	370.6	370.6
49.0000	0.17	079	-255	369.4	365.1	367.1	367.5	368.8	366.6	366.6	366.6	366.6	366.6	366.6
50.0000	0.26	052	-228	365.9	363.9	364.7	365.5	366.3	364.9	364.9	364.9	364.9	364.9	364.9
51.0000	0.12	041	-222	362.0	361.6	362.0	361.2	361.7	360.9	360.9	360.9	360.9	360.9	360.9
52.0000	0.02	023	-22	356.6	355.5	356.6	356.6	357.5	355.7	355.7	355.7	355.7	355.7	355.7

SMUD RAPID COOLDOWN
F. L. BOYER A-43

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION FULL CERTIFICATION

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION FULL CERTIFICATION

DATE 04/20/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION

TIME	EJUV LIN. TAD	THermal STRESS INSIDE	THermal STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	MODE10	MODE11
50.0000	594.	016.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
50.5000	594.	010.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
51.0000	594.	005.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
51.5000	594.	000.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
52.0000	594.	997.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
52.5000	594.	993.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
53.0000	594.	988.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
53.5000	594.	984.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
54.0000	594.	980.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
54.5000	594.	976.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
55.0000	594.	972.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
55.5000	594.	968.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
56.0000	594.	964.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
56.5000	594.	960.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
57.0000	594.	956.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
57.5000	594.	952.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
58.0000	594.	948.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
58.5000	594.	944.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
59.0000	594.	940.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
59.5000	594.	936.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
60.0000	594.	932.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
60.5000	594.	928.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
61.0000	594.	924.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
61.5000	594.	920.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
62.0000	594.	916.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
62.5000	594.	912.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
63.0000	594.	908.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
63.5000	594.	904.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
64.0000	594.	900.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
64.5000	594.	896.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
65.0000	594.	892.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
65.5000	594.	888.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
66.0000	594.	884.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
66.5000	594.	880.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
67.0000	594.	876.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
67.5000	594.	872.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
68.0000	594.	868.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
68.5000	594.	864.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
69.0000	594.	860.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0
69.5000	594.	856.	594.	352.0	353.2	354.0	354.7	355.0	355.5	355.8	356.0	356.0	356.0	356.0

SMUD RAPID COOLDOWN
F. L. BOYER
A-44

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION

TIME	EQUIV L IN.	THERMAL STRESS INS	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
70.0000	12	289	-77	291.9	293.7	294.4	294.6	294.7	294.8	294.9	294.9	294.9
70.5000	69	289	-75	292.0	293.8	294.5	294.7	294.8	294.9	295.0	295.0	295.0
71.0000	62	289	-74	291.7	292.6	293.4	293.6	293.7	293.8	293.9	293.9	293.9
71.5000	62	289	-74	291.7	292.6	293.4	293.6	293.7	293.8	293.9	293.9	293.9
72.0000	59	289	-72	291.6	290.5	291.3	291.5	291.6	291.7	291.8	291.8	291.8
72.5000	50	289	-70	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
73.0000	53	289	-69	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
73.5000	52	289	-69	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
74.0000	51	289	-68	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
74.5000	51	289	-68	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
75.0000	50	289	-67	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
75.5000	49	289	-67	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
76.0000	49	289	-67	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
76.5000	49	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
77.0000	49	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
77.5000	47	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
78.0000	47	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
78.5000	46	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
79.0000	46	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
79.5000	46	289	-66	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
80.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
80.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
81.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
81.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
82.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
82.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
83.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
83.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
84.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
84.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
85.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
85.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
86.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
86.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
87.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
87.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
88.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
88.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
89.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
89.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
90.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
90.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
91.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
91.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
92.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
92.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
93.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
93.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
94.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
94.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
95.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
95.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
96.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
96.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
97.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
97.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
98.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
98.5000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7
99.0000	45	289	-65	290.5	289.4	290.2	290.4	290.5	290.6	290.7	290.7	290.7

SMUD RAPID COOLDOWN
F. L. BOYER
A-45

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION DATE 04/20/78

TIME	EVJY	TRIP	TEMPERATURE	DISTRIBUTION	INSTRUMENTATION	MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9	MODE 10	MODE 11
00.0000	31.	34.	31.	34.	59.	292.2	292.2	292.0	291.0	291.7	291.6	291.6	291.5	291.5	291.5	291.5
01.0000	35.	35.	31.	34.	59.	293.9	293.9	293.9	293.7	293.6	293.5	293.5	293.5	293.5	293.5	293.5
02.0000	38.	35.	31.	34.	59.	295.4	295.4	295.4	295.4	295.4	295.4	295.4	295.4	295.4	295.4	295.4
03.0000	39.	37.	31.	34.	63.	297.0	297.0	297.0	297.0	297.0	297.0	297.0	297.0	297.0	297.0	297.0
04.0000	40.	39.	31.	34.	63.	298.7	298.7	298.7	298.7	298.7	298.7	298.7	298.7	298.7	298.7	298.7
05.0000	41.	41.	31.	34.	63.	299.9	299.9	299.9	299.9	299.9	299.9	299.9	299.9	299.9	299.9	299.9
06.0000	42.	42.	31.	34.	64.	301.7	301.7	301.7	301.7	301.7	301.7	301.7	301.7	301.7	301.7	301.7
07.0000	42.	43.	31.	34.	64.	302.7	302.7	302.7	302.7	302.7	302.7	302.7	302.7	302.7	302.7	302.7
08.0000	43.	43.	31.	34.	64.	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3	303.3
09.0000	44.	44.	31.	34.	64.	304.9	304.9	304.9	304.9	304.9	304.9	304.9	304.9	304.9	304.9	304.9
10.0000	44.	45.	31.	34.	64.	305.4	305.4	305.4	305.4	305.4	305.4	305.4	305.4	305.4	305.4	305.4
11.0000	45.	45.	31.	34.	64.	306.7	306.7	306.7	306.7	306.7	306.7	306.7	306.7	306.7	306.7	306.7
12.0000	45.	45.	31.	34.	71.	307.1	307.1	307.1	307.1	307.1	307.1	307.1	307.1	307.1	307.1	307.1
13.0000	46.	46.	31.	34.	72.	308.8	308.8	308.8	308.8	308.8	308.8	308.8	308.8	308.8	308.8	308.8
14.0000	46.	46.	31.	34.	73.	309.0	309.0	309.0	309.0	309.0	309.0	309.0	309.0	309.0	309.0	309.0
15.0000	47.	47.	31.	34.	74.	311.2	311.2	311.2	311.2	311.2	311.2	311.2	311.2	311.2	311.2	311.2
16.0000	47.	47.	31.	34.	74.	312.4	312.4	312.4	312.4	312.4	312.4	312.4	312.4	312.4	312.4	312.4
17.0000	47.	47.	31.	34.	74.	313.6	313.6	313.6	313.6	313.6	313.6	313.6	313.6	313.6	313.6	313.6
18.0000	47.	47.	31.	34.	74.	314.9	314.9	314.9	314.9	314.9	314.9	314.9	314.9	314.9	314.9	314.9
19.0000	47.	47.	31.	34.	74.	316.7	316.7	316.7	316.7	316.7	316.7	316.7	316.7	316.7	316.7	316.7
20.0000	48.	48.	31.	34.	74.	318.0	318.0	318.0	318.0	318.0	318.0	318.0	318.0	318.0	318.0	318.0
21.0000	48.	48.	31.	34.	74.	321.4	321.4	321.4	321.4	321.4	321.4	321.4	321.4	321.4	321.4	321.4
22.0000	48.	48.	31.	34.	74.	323.6	323.6	323.6	323.6	323.6	323.6	323.6	323.6	323.6	323.6	323.6
23.0000	48.	48.	31.	34.	74.	325.0	325.0	325.0	325.0	325.0	325.0	325.0	325.0	325.0	325.0	325.0
24.0000	48.	48.	31.	34.	75.	327.9	327.9	327.9	327.9	327.9	327.9	327.9	327.9	327.9	327.9	327.9
25.0000	48.	48.	31.	34.	75.	329.0	329.0	329.0	329.0	329.0	329.0	329.0	329.0	329.0	329.0	329.0
26.0000	48.	48.	31.	34.	75.	331.0	331.0	331.0	331.0	331.0	331.0	331.0	331.0	331.0	331.0	331.0
27.0000	48.	48.	31.	34.	75.	332.4	332.4	332.4	332.4	332.4	332.4	332.4	332.4	332.4	332.4	332.4
28.0000	48.	48.	31.	34.	75.	334.0	334.0	334.0	334.0	334.0	334.0	334.0	334.0	334.0	334.0	334.0
29.0000	48.	48.	31.	34.	74.	335.0	335.0	335.0	335.0	335.0	335.0	335.0	335.0	335.0	335.0	335.0
30.0000	48.	48.	31.	34.	74.	336.0	336.0	336.0	336.0	336.0	336.0	336.0	336.0	336.0	336.0	336.0
31.0000	48.	48.	31.	34.	74.	337.0	337.0	337.0	337.0	337.0	337.0	337.0	337.0	337.0	337.0	337.0
32.0000	48.	48.	31.	34.	74.	338.0	338.0	338.0	338.0	338.0	338.0	338.0	338.0	338.0	338.0	338.0
33.0000	48.	48.	31.	34.	74.	339.0	339.0	339.0	339.0	339.0	339.0	339.0	339.0	339.0	339.0	339.0
34.0000	48.	48.	31.	34.	74.	340.0	340.0	340.0	340.0	340.0	340.0	340.0	340.0	340.0	340.0	340.0
35.0000	48.	48.	31.	34.	74.	341.0	341.0	341.0	341.0	341.0	341.0	341.0	341.0	341.0	341.0	341.0
36.0000	48.	48.	31.	34.	74.	342.0	342.0	342.0	342.0	342.0	342.0	342.0	342.0	342.0	342.0	342.0
37.0000	48.	48.	31.	34.	74.	343.0	343.0	343.0	343.0	343.0	343.0	343.0	343.0	343.0	343.0	343.0
38.0000	48.	48.	31.	34.	74.	344.0	344.0	344.0	344.0	344.0	344.0	344.0	344.0	344.0	344.0	344.0
39.0000	48.	48.	31.	34.	74.	345.0	345.0	345.0	345.0	345.0	345.0	345.0	345.0	345.0	345.0	345.0

SMUD RAPID COOLDOV
F. L. BOYER
A-46

SHUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION
 FULL CERTIFICATION

DATE 04/20/76

SHUD REACTOR TRIP TEMPERATURE DISTRIBUTION INSTRUMENTATION

EQUIV LIN: THERMAL THERMAL
 440 SIN: STRESS STRESS
 -165. INSIDE OUTSIDE
 -282.

TIME 140.0000
 MODE 1 336.7 MODE 2 336.4 MODE 3 336.1 MODE 4 335.9 MODE 5 335.8 MODE 6 335.7 MODE 7 335.7 MODE 8 335.6 MODE 9 335.6 MODE 10 335.6

SMUD RAPID COOLDOWN
 F. L. BOYER A-47

SMUD COOLODOW INCIDENT-INSTRUMENTATION

ITERATION 20 PAGE 1 DATE 05/04/78

INPUT DATA

DATE 05/04/78

TOTAL NO. OF SEGMENTS = 39

BOUNDARY CONDITIONS AT THE TOP (0) END

- 1. A RADIAL SHEAR OF 0.0000 POUNDS
- 2. A MOMENT OF 0.0000 INCH-LBS.

BOUNDARY CONDITIONS AT THE BOTTOM (N) END

- 1. AN AXIAL FORCE OF 444.1000 POUNDS
- 2. A RADIAL SHEAR OF 0.0000 POUNDS
- 3. A ROTATION OF 0.0000 RADIAN

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.
ALL LOADS ABOVE, ARE ON A TOTAL LOAD BASIS.

SMUD RAPID COOLDOWN
F. L. BOYER A-48

*** FULL CERTIFICATION ***

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 2 DATE 05/04/78

MID-SURFACE GEOMETRY

AT TOP BOUNDARY, MEAN RADIUS = .6563 Z COORDINATE = 30.0000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	MEAN RADIUS	Z COORD.	TOP-CENTER COORD.	CURVATURE IDENTIFIER
10.0	.656	20.000	0.000	0.000
13.0	.656	18.500	0.000	0.000
16.0	.656	18.125	0.000	0.000
22.0	.414	17.651	0.000	0.000
23.0	.411	17.644	0.000	0.000
24.0	.411	17.500	0.000	0.000
29.0	.411	10.000	0.000	0.000

NOTE- CURVATURE IDENTIFIER *1= POSITIVE CURVATURE
 0= NO CURVATURE
 -1= NEGATIVE CURVATURE

SMUD RAPID COOLDOWN
 F. L. BOYER
 A-49

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 3 DATE 05/04/78

SEGMENTAL GEOMETRY BY SEGMENTS (K= SEGMENT NO.)

MEAN RADIUS	R(K)	R(K+1)	R(K+2)	R(K+3)	R(K+4)	R(K+5)	R(K+6)	R(K+7)	R(K+8)	
K	R(K-1)	R(K)	R(K+1)	R(K+2)	R(K+3)	R(K+4)	R(K+5)	R(K+6)	R(K+7)	R(K+8)
1	.66	.66	.66	.66	.66	.66	.66	.66	.66	.66
2	.41	.41	.41	.41	.41	.41	.41	.41	.41	.41
3	.41	.41	.41	.41	.41	.41	.41	.41	.41	.41

Z COORDINATE	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)	
K	Z(K-1)	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)
1	30.00	29.00	28.00	26.00	25.00	24.00	23.00	22.00	21.00	21.00
2	20.00	19.50	19.00	18.50	18.25	18.00	18.00	18.00	18.00	18.00
3	17.91	17.73	17.65	17.50	17.00	16.50	16.00	15.50	15.00	15.00
	14.50	14.00	13.00	12.50	12.00	11.50	11.00	10.50	10.00	10.00

SMUD RAPID COOLDOWN
 F. L. BOYER A-50

SMUD COOLDOWN INCIDENT-INSTRUMENTATION

ITERATION 20 PAGE 4 DATE 05/04/78

SEGMENT THICKNESS DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TOP THICK. OF TOP SEG.	BOTTOM THICK. OF BOTTOM SEG.
1.00	15.00	.69	.69
17.00	22.00	.69	.20
23.00	23.00	.20	.21
24.00	39.00	.21	.21

SEGMENTAL THICKNESS BY SEGMENTS

K	THICKNESS AT TOP OF SEGMENT (HA)									
	HA(K)	HA(K+1)	HA(K+2)	HA(K+3)	HA(K+4)	HA(K+5)	HA(K+6)	HA(K+7)	HA(K+8)	HA(K+9)
1	.69	.69	.69	.69	.69	.69	.69	.69	.69	.69
2	.69	.69	.69	.69	.69	.69	.69	.69	.69	.69
3	.36	.28	.20	.21	.21	.21	.21	.21	.21	.21
4	.21	.21	.21	.21	.21	.21	.21	.21	.21	.21

K	THICKNESS AT BOTTOM OF SEGMENT (HB)									
	HB(K)	HB(K+1)	HB(K+2)	HB(K+3)	HB(K+4)	HB(K+5)	HB(K+6)	HB(K+7)	HB(K+8)	HB(K+9)
1	.69	.69	.69	.69	.69	.69	.69	.69	.69	.69
2	.69	.69	.69	.69	.69	.69	.69	.69	.69	.69
3	.28	.20	.21	.21	.21	.21	.21	.21	.21	.21
4	.21	.21	.21	.21	.21	.21	.21	.21	.21	.21

SMUD RAPID COOLDOWN
 F. L. BOYER
 A-51

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 5 DATE 05/04/78

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO.	ALPHA	MODULUS OF TENSION	MODULUS OF SHEAR	POISSON'S RATIO
1	7856E-05	2922E+08	24E+08	3000E+00
2	7856E-05	2922E+08	24E+08	3000E+00
3	7856E-05	2922E+08	24E+08	3000E+00
4	7856E-05	2922E+08	24E+08	3000E+00
5	7856E-05	2922E+08	24E+08	3000E+00
6	7856E-05	2922E+08	24E+08	3000E+00
7	7856E-05	2922E+08	24E+08	3000E+00
8	7856E-05	2922E+08	24E+08	3000E+00
9	7856E-05	2922E+08	24E+08	3000E+00
10	7856E-05	2922E+08	24E+08	3000E+00
11	7856E-05	2922E+08	24E+08	3000E+00
12	7856E-05	2922E+08	24E+08	3000E+00
13	7856E-05	2922E+08	24E+08	3000E+00
14	7856E-05	2922E+08	24E+08	3000E+00
15	7856E-05	2922E+08	24E+08	3000E+00
16	7856E-05	2922E+08	24E+08	3000E+00
17	7856E-05	2922E+08	24E+08	3000E+00
18	7856E-05	2922E+08	24E+08	3000E+00
19	7856E-05	2922E+08	24E+08	3000E+00
20	7856E-05	2922E+08	24E+08	3000E+00
21	7856E-05	2922E+08	24E+08	3000E+00
22	7856E-05	2922E+08	24E+08	3000E+00
23	7856E-05	2922E+08	24E+08	3000E+00
24	7856E-05	2922E+08	24E+08	3000E+00
25	7856E-05	2922E+08	24E+08	3000E+00
26	7856E-05	2922E+08	24E+08	3000E+00
27	7856E-05	2922E+08	24E+08	3000E+00
28	7856E-05	2922E+08	24E+08	3000E+00
29	7856E-05	2922E+08	24E+08	3000E+00
30	7856E-05	2922E+08	24E+08	3000E+00

SMUD RAPID COOLDOWN
 F. L. BOYER

SMUD COOLDOWN INCIDENT-INSTRUMENTATION

ITERATION 20 PAGE 6 DATE 05/06/78

PRESSURE INPJT DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INTERNAL PRESSURE	EXTERNAL PRESSURE
1.0	16.0	1500.0	1500.0
17.0	39.0	1500.0	0.0

MECHANICAL LOADING ON SEGMENTAL GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	16.0	0.	0.	0.
17.0	17.0	.234E+04	0.	-.785E+03
18.0	18.0	.216E+04	0.	-.785E+03
19.0	19.0	.196E+04	0.	-.785E+03
20.0	20.0	.150E+04	0.	-.785E+03
21.0	21.0	.128E+04	0.	-.785E+03
22.0	22.0	.106E+04	0.	-.785E+03
23.0	39.0	0.	0.	0.

STRESS CONCENTRATION FACTORS BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INSIDE		OUTSIDE	
		TENSION	BENDING	TENSION	BENDING
1	5	1.00	1.00	1.00	1.00
17	16	4.00	4.00	2.00	1.00
18	21	2.00	2.00	1.00	1.00

SMUD RAPID COOLDOWN
 F. L. BOYER

A-53

..... FULL CERTIFICATION

ITERATION 20 PAGE 7 DATE 05/04/78

SMUD COOLDOWN INCIDENT-INSTRUMENTATION

23	2.00	2.00	4.00	4.00
24	1.00	1.00	1.00	1.00

SMUD RAPID COOLDOWN
F. L. BOYER

A-54

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 8 DATE 05/04/78

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

SEGMENT	OUTSIDE I	T2	T3	T4	INSIDE T5	SEGMENT	OUTSIDE T1	T7	T8	T9	INSIDE T5
1	483	483	483	483	483	20	490	486	487	487	486
2	483	483	483	483	483	21	491	487	487	487	486
3	483	483	483	483	483	22	493	487	487	487	486
4	483	483	483	483	483	23	493	487	487	487	486
5	483	483	483	483	483	24	493	487	487	487	486
6	483	483	483	483	483	25	493	487	487	487	486
7	483	483	483	483	483	26	493	487	487	487	486
8	483	483	483	483	483	27	493	487	487	487	486
9	483	483	483	483	483	28	493	487	487	487	486
0	483	483	483	483	483	29	493	487	487	487	486
1	483	483	483	483	483	30	493	487	487	487	486
2	483	483	483	483	483	31	493	487	487	487	486
3	483	483	483	483	483	32	493	487	487	487	486
4	483	483	483	483	483	33	493	487	487	487	486
5	483	483	483	483	483	34	493	487	487	487	486
6	483	483	483	483	483	35	493	487	487	487	486
7	483	483	483	483	483	36	493	487	487	487	486
8	483	483	483	483	483	37	493	487	487	487	486
9	483	483	483	483	483	38	493	487	487	487	486
0	483	483	483	483	483	39	493	487	487	487	486

SMUD RAPID COOLDOWN
F. L. BOYER A-55

***** FULL CERTIFICATION *****

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 9 DATE 05/04/78

***** PRIMARY * SECONDARY BOUNDARY AND FLEXIBILITY MATRICES *****

----- BOUNDARY FORCES DUE TO THE END CONDITIONS -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	ROTATION (N)	SUM
0.	0.	0.	.4441E+03	0.	0.	0.	0.	.4441E+03
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.
.2432E+02	-.4380E-01	.1030E-11	-.3971E+01	0.	0.	0.	0.	-.2030E+02

----- FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS) -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)
.7631E-01	.2605E-03	-.7545E-03	.6485E-06	.6865E-09	.8006E-09	-.4539E-08	.3061E-07
-.2491E-07	.3368E-04	-.3735E-05	.8006E-08	.2622E-07	-.2782E-07	-.8031E-03	-.2200E-02
.4971E-07	.7234E-06	-.3773E-04	-.4539E-08	-.2782E-07	.1324E-06	.2601E-06	.1644E-01
.1569E-02	.3151E-04	-.5995E-10	-.3061E-07	-.8031E-03	.2601E-06	.1324E-06	.3423E-05
-.8323E-04	.1499E-06	-.3524E-17	-.3061E-07	-.5200E-02	.1668E-01	.3631E-06	.3423E-05

----- BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	ROTATION (N)	SUM
.7631E-01	.2605E-03	-.7545E-03	.2879E-03	0.	0.	0.	0.	.7610E-01
-.2491E-07	.3368E-04	-.3735E-05	.3049E-06	0.	0.	0.	0.	-.2491E-07
.4971E-07	.7234E-06	-.3773E-04	.3550E-05	0.	0.	0.	0.	.3402E-04
.1576E-02	.3149E-04	-.1857E-10	-.3459E-05	0.	0.	0.	0.	.1606E-02
-.4337E-10	.8470E-21	-.2465E-01	.1084E-10	0.	0.	0.	0.	-.4337E-10

F. L. BOYER

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 10 DATE 05/04/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
(THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

ROTATION(O)	DEFLECTION(O)	M(O)	Q(O)	M(N)	Q(N)
ROTATION(I)	DEFLECTION(I)	M(I)	Q(I)	M(N)	Q(N)
ROTATION(II)	DEFLECTION(II)	M(II)	Q(II)	M(N)	Q(N)
ROTATION(III)	DEFLECTION(III)	M(III)	Q(III)	M(N)	Q(N)
ROTATION(IV)	DEFLECTION(IV)	M(IV)	Q(IV)	M(N)	Q(N)
ROTATION(V)	DEFLECTION(V)	M(V)	Q(V)	M(N)	Q(N)
ROTATION(VI)	DEFLECTION(VI)	M(VI)	Q(VI)	M(N)	Q(N)
ROTATION(VII)	DEFLECTION(VII)	M(VII)	Q(VII)	M(N)	Q(N)
ROTATION(VIII)	DEFLECTION(VIII)	M(VIII)	Q(VIII)	M(N)	Q(N)
ROTATION(IX)	DEFLECTION(IX)	M(IX)	Q(IX)	M(N)	Q(N)
ROTATION(X)	DEFLECTION(X)	M(X)	Q(X)	M(N)	Q(N)
ROTATION(XI)	DEFLECTION(XI)	M(XI)	Q(XI)	M(N)	Q(N)
ROTATION(XII)	DEFLECTION(XII)	M(XII)	Q(XII)	M(N)	Q(N)
ROTATION(XIII)	DEFLECTION(XIII)	M(XIII)	Q(XIII)	M(N)	Q(N)
ROTATION(XIV)	DEFLECTION(XIV)	M(XIV)	Q(XIV)	M(N)	Q(N)
ROTATION(XV)	DEFLECTION(XV)	M(XV)	Q(XV)	M(N)	Q(N)
ROTATION(XVI)	DEFLECTION(XVI)	M(XVI)	Q(XVI)	M(N)	Q(N)
ROTATION(XVII)	DEFLECTION(XVII)	M(XVII)	Q(XVII)	M(N)	Q(N)
ROTATION(XVIII)	DEFLECTION(XVIII)	M(XVIII)	Q(XVIII)	M(N)	Q(N)
ROTATION(XIX)	DEFLECTION(XIX)	M(XIX)	Q(XIX)	M(N)	Q(N)
ROTATION(XX)	DEFLECTION(XX)	M(XX)	Q(XX)	M(N)	Q(N)
ROTATION(XXI)	DEFLECTION(XXI)	M(XXI)	Q(XXI)	M(N)	Q(N)
ROTATION(XXII)	DEFLECTION(XXII)	M(XXII)	Q(XXII)	M(N)	Q(N)
ROTATION(XXIII)	DEFLECTION(XXIII)	M(XXIII)	Q(XXIII)	M(N)	Q(N)
ROTATION(XXIV)	DEFLECTION(XXIV)	M(XXIV)	Q(XXIV)	M(N)	Q(N)
ROTATION(XXV)	DEFLECTION(XXV)	M(XXV)	Q(XXV)	M(N)	Q(N)
ROTATION(XXVI)	DEFLECTION(XXVI)	M(XXVI)	Q(XXVI)	M(N)	Q(N)
ROTATION(XXVII)	DEFLECTION(XXVII)	M(XXVII)	Q(XXVII)	M(N)	Q(N)
ROTATION(XXVIII)	DEFLECTION(XXVIII)	M(XXVIII)	Q(XXVIII)	M(N)	Q(N)
ROTATION(XXIX)	DEFLECTION(XXIX)	M(XXIX)	Q(XXIX)	M(N)	Q(N)
ROTATION(XXX)	DEFLECTION(XXX)	M(XXX)	Q(XXX)	M(N)	Q(N)

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

***** FULL CERTIFICATION *****

SMUD COOLDOWN INCIDENT-INSTRUMENTATION ITERATION 20 PAGE 11 DATE 05/04/78

***** PRIMARY & SECONDARY FORCES AND MOTIONS *****

***** POSITIVE DIRECTIONS (+) ARE AS FOLLOWS *****

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
 RADIAL----- TO THE RIGHT
 ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- DOWNWARD

***** SIGH CONVENTIONS ARE FOR A RIGHT HAND VIEW *****

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	HAZIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	0.	0.	TOP	0.	0.	0.
1	ROT	657E-02	42E+03	471E+04	ROT	247E-02	340E-04	377E-02
2	ROT	154E+01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
3	ROT	232E+00	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
4	ROT	492E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
5	ROT	202E-00	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
6	ROT	143E-00	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
7	ROT	135E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
8	ROT	179E-02	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
9	ROT	299E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
10	ROT	599E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
11	ROT	127E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
12	ROT	959E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
13	ROT	226E-04	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
14	ROT	260E-04	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
15	ROT	140E-04	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
16	ROT	504E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
17	ROT	110E-02	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
18	ROT	404E-02	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
19	ROT	843E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
20	ROT	145E-02	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
21	ROT	643E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
22	ROT	153E-02	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
23	ROT	754E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
24	ROT	1086E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
25	ROT	1390E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
26	ROT	1962E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
27	ROT	2202E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
28	ROT	2403E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
29	ROT	2030E-01	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
30	ROT	444E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
31	ROT	444E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02
32	ROT	444E-03	255E+03	471E+04	ROT	247E-02	340E-04	377E-02

F. L. BOYER

SMUD COOLDOWN INCIDENT-INSTRUMENTATION
 FULL CERTIFICATION

FULL CERTIFICATION

20 PAGE 12 DATE 05/04/78

SMUD COOLDOWN INCIDENT-INSTRUMENTATION

Iteration	ROT	Force	Motion	Iteration	ROT	Force	Motion
33	ROT: .2030E+02	.4441E+03	.6029E-02	33	ROT: .6453E-01		
34	ROT: .2655E-06	.4441E+03	.606E-02	34	ROT: .6646E-01		
35	ROT: .2722E-07	.4441E+03	.606E-02	35	ROT: .6839E-01		
36	ROT: .2362E-08	.4441E+03	.606E-02	36	ROT: .7032E-01		
37	ROT: .4461E-09	.4441E+03	.606E-02	37	ROT: .7225E-01		
38	ROT: .3093E-09	.4441E+03	.606E-02	38	ROT: .7417E-01		
39	ROT: 0.	.4441E+03	.606E-02	39	ROT: .7610E-01		

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

PRIMARY + SECONDARY STRESSES

SEQ. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
475.6	432.3	727.6	111.1	514.1	275.5	604.7	429.5	169.7	526.8
490.0	497.7	699.9	111.1	475.5	333.3	537.0	443.0	517.9	551.5
490.0	689.9	699.9	111.1	484.4	329.3	549.4	444.4	523.1	557.7
490.0	690.0	690.0	111.1	484.4	329.3	547.7	474.5	518.6	560.8
490.0	690.0	690.0	111.1	484.4	329.3	547.7	476.3	514.1	560.8
490.0	690.0	690.0	111.1	484.4	329.3	547.7	476.0	517.8	560.8
490.0	690.0	690.0	111.1	484.4	329.3	547.7	476.3	517.9	560.8
490.0	690.0	690.0	111.1	484.4	329.3	547.7	475.2	518.3	560.9
490.0	690.0	690.0	111.1	484.4	329.3	547.9	476.7	518.8	560.9
490.0	690.0	690.0	111.1	484.4	329.3	552.5	523.0	601.4	571.6
490.0	690.0	690.0	111.1	468.8	303.0	575.5	306.4	1313.3	521.1
490.0	690.0	690.0	111.1	364.6	222.2	555.5	301.4	933.2	515.5
490.0	690.0	690.0	111.1	204.9	142.4	227.2	HH0.4	1034.8	452.5
490.0	690.0	690.0	111.1	073.7	202.3	745.9	341.4	2657.2	385.8
490.0	690.0	690.0	111.1	160.7	177.8	678.2	451.8	4051.6	346.3
490.0	690.0	690.0	111.1	332.8	315.0	144.3	-211.9	5675.7	244.8
490.0	690.0	690.0	111.1	2586.2	144.0	555.9	3907.2	4723.5	705.8
490.0	690.0	690.0	111.1	468.8	145.6	315.0	4131.2	6477.3	511.7
490.0	690.0	690.0	111.1	2307.7	505.2	582.2	4234.4	7974.0	575.1
490.0	690.0	690.0	111.1	2030.3	653.7	657.7	4047.8	4114.2	595.3
490.0	690.0	690.0	111.1	1610.9	653.7	654.1	3546.2	4705.0	668.6
490.0	690.0	690.0	111.1	577.1	716.3	656.4	1723.9	4813.9	777.6
490.0	690.0	690.0	111.1	697.0	716.3	656.4	760.7	10732.5	375.6
490.0	690.0	690.0	111.1	304.0	624.2	704.6	662.8	8755.8	186.7
490.0	690.0	690.0	111.1	118.6	619.2	704.6	547.2	4355.8	311.0
490.0	690.0	690.0	111.1	047.2	176.7	8.6	170.0	4579.9	348.7
490.0	690.0	690.0	111.1	066.5	178.0	4.7	337.0	4633.7	343.2
490.0	690.0	690.0	111.1	063.5	178.0	4.7	311.4	4620.2	343.0
490.0	690.0	690.0	111.1	064.0	178.0	4.9	330.8	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0
490.0	690.0	690.0	111.1	063.0	178.0	4.9	331.0	4622.2	343.0

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

SMUD RAPID COOLDOWN

F. L. BOYER

A-60

SMUD COOLDOWN INCIDENT-INSTRUMENTATION

STRESS INTENSITY PROGRAM OUT (IN KIPS)

STRESS AT BOTTOM OF SEGMENT NO. 22.

PRIMARY + SECONDARY STRESS INTENSITIES

L - R R - H H - L L - R H - H H - L H - L

INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE

20 -16.2 11.0 -30.5 -4.0 11.5 3.7 -2.1 1.8 -19.3 -5.5 13.9 3.7
 40 -16.2 11.0 -30.5 -19.8 44.7 8.8 -28.3 44.6 27.3 31.9 55.9 -12.7

STRESS OUTPUT ANALYSIS

STRESS INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE INSIDE OUTSIDE

MAXIMUM 0.0 11.0 0.0 44.7 8.8 0.0 44.6 0.0 0.0 55.7 3.7
 MINIMUM -16.2 0.0 -30.5 -19.8 0.0 -28.3 0.0 -27.3 -31.9 0.0 -12.7
 RANGE 16.2 11.0 30.5 19.8 44.7 28.3 44.6 27.3 31.9 55.7 16.4

SMUD RAPID COOLDOWN
 F. L. BOYER
 A-61

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD

DATE 04/20/78

DIMENSIONS

INSIDE RADIUS = 87.2500 INCHES OUTSIDE RADIUS = 93.8750 INCHES
NO. OF NODES = 9 RADIAL INCREMENT = .8281 INCHES
MATERIAL CODE = 12 POISSON'S RATIO = .3000
L = -0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	87.2500	565.0
2	88.0781	565.0
3	88.9063	565.0
4	89.7344	565.0
5	90.5625	565.0
6	91.3906	565.0
7	92.2188	565.0
8	93.0469	565.0
9	93.8750	565.0

SMUD RAPID COOLDOWN

I. D. McKim

A-62

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD DATE 04/20/78

FLUID TEMP. CURVE		INSIDE FLOW TEMPERATURE		INSIDE FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATION (MINUTES)	TEMPERATURE	TIME APPROXIMATION (MINUTES)	COEFFICIENT	TIME APPROXIMATION (MINUTES)	COEFFICIENT	TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	565.0	0.0000	500.0	0.0000	500.0	0.0000	0.
5.0000	565.0	140.0000	500.0	0.0000	500.0	0.0000	0.
10.0000	540.0	0.0000	0.0	0.0000	0.0	0.0000	0.
15.0000	525.0	0.0000	0.0	0.0000	0.0	0.0000	0.
20.0000	380.0	0.0000	0.0	0.0000	0.0	0.0000	0.
40.0000	300.0	0.0000	0.0	0.0000	0.0	0.0000	0.
60.0000	280.0	0.0000	0.0	0.0000	0.0	0.0000	0.
95.0000	290.0	0.0000	0.0	0.0000	0.0	0.0000	0.
110.0000	305.0	0.0000	0.0	0.0000	0.0	0.0000	0.
140.0000	340.0	0.0000	0.0	0.0000	0.0	0.0000	0.

TEMPERATURE CALCULATION TIMES AND PRINTOUTS OF
 TIME INCREMENT (MINUTES) NUMBER OF PRINTOUTS
 .5000 20
 .5000 60
 1.0000 120

SMUD RAPID COOLDOWN
 A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD

DATE 04/20/78

TIME	EQUIV IN. STR. RAD	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
30.0000	2519.	18531.	-7740.	469.6	494.2	513.8	529.9	540.5	548.8	554.4	557.6	558.8	559.8	560.8
30.5000	2847.	18935.	-7966.	466.2	491.3	511.1	527.2	538.7	547.0	553.3	556.3	557.4	558.4	559.4
31.0000	3169.	19331.	-8186.	462.9	488.3	508.5	524.6	536.1	544.4	550.7	553.7	554.8	555.8	556.8
31.5000	3483.	19719.	-8402.	459.5	485.4	506.1	522.2	533.7	542.0	548.3	551.3	552.4	553.4	554.4
32.0000	3792.	20100.	-8613.	456.1	482.4	503.5	519.6	531.1	540.0	546.3	549.3	550.4	551.4	552.4
32.5000	4093.	20473.	-8819.	452.7	479.4	500.9	517.0	528.5	537.4	543.7	546.7	547.8	548.8	549.8
33.0000	4389.	20839.	-9021.	449.4	475.4	498.2	514.3	525.8	534.7	541.0	544.0	545.1	546.1	547.1
33.5000	4679.	21198.	-9219.	446.0	471.4	495.5	510.4	521.9	530.8	537.1	540.1	541.2	542.2	543.2
34.0000	4963.	21551.	-9412.	442.6	467.3	492.9	506.5	518.0	526.9	533.2	536.2	537.3	538.3	539.3
34.5000	5241.	21896.	-9602.	439.2	463.3	490.2	502.6	514.1	523.0	529.3	532.3	533.4	534.4	535.4
35.0000	5514.	22235.	-9788.	435.8	459.2	487.4	498.7	510.2	519.1	525.4	528.4	529.5	530.5	531.5
35.5000	5781.	22567.	-9970.	432.4	455.1	484.7	494.8	506.3	515.2	521.5	524.5	525.6	526.6	527.6
36.0000	6043.	22893.	-10149.	429.0	451.0	481.9	490.9	502.4	511.3	517.6	520.6	521.7	522.7	523.7
36.5000	6300.	23212.	-10323.	425.6	446.9	479.2	487.0	498.5	507.4	513.7	516.7	517.8	518.8	519.8
37.0000	6552.	23525.	-10495.	422.1	442.9	476.4	484.2	495.7	504.6	510.9	513.9	515.0	516.0	517.0
37.5000	6799.	23832.	-10663.	418.7	438.8	473.6	481.4	492.9	501.8	508.1	511.1	512.2	513.2	514.2
38.0000	7041.	24133.	-10828.	415.3	434.7	470.7	478.5	490.0	498.9	505.2	508.2	509.3	510.3	511.3
38.5000	7278.	24428.	-10989.	411.9	430.5	467.9	475.3	486.8	495.7	502.0	505.0	506.1	507.1	508.1
39.0000	7510.	24717.	-11147.	408.4	426.4	465.0	472.0	483.5	492.4	498.7	501.7	502.8	503.8	504.8
39.5000	7738.	25000.	-11302.	405.0	422.2	462.2	468.8	480.3	489.2	495.5	498.5	499.6	500.6	501.6
40.0000	7961.	25278.	-11454.	401.6	418.0	459.3	465.5	477.0	485.9	492.2	495.2	496.3	497.3	498.3
40.5000	8174.	25553.	-11603.	398.1	413.9	456.4	461.7	473.2	482.1	488.4	491.4	492.5	493.5	494.5
41.0000	8382.	25824.	-11749.	394.6	409.7	453.6	457.9	469.4	478.3	484.6	487.6	488.7	489.7	490.7
41.5000	8585.	26091.	-11893.	391.1	405.5	450.7	454.0	465.5	474.4	480.7	483.7	484.8	485.8	486.8
42.0000	8784.	26354.	-12035.	387.6	401.3	447.8	450.1	461.6	470.5	476.8	479.8	480.9	481.9	482.9
42.5000	8978.	26613.	-12175.	384.1	397.1	444.9	446.2	457.7	466.6	472.9	475.9	477.0	478.0	479.0
43.0000	9167.	26868.	-12313.	380.5	392.9	442.0	442.3	453.8	462.7	469.0	472.0	473.1	474.1	475.1
43.5000	9351.	27119.	-12449.	377.0	388.7	439.1	438.4	450.0	458.9	465.2	468.2	469.3	470.3	471.3
44.0000	9530.	27366.	-12583.	373.4	384.5	436.2	434.5	446.1	455.0	461.3	464.3	465.4	466.4	467.4
44.5000	9704.	27609.	-12715.	369.8	380.3	433.3	430.6	442.2	451.1	457.4	460.4	461.5	462.5	463.5
45.0000	9873.	27848.	-12845.	366.2	376.1	430.4	426.7	438.3	446.2	452.5	455.5	456.6	457.6	458.6
45.5000	10037.	28083.	-12973.	362.6	371.9	427.5	422.8	434.4	441.3	447.6	450.6	451.7	452.7	453.7
46.0000	10196.	28314.	-13100.	359.0	367.7	424.6	418.9	430.5	437.2	443.5	446.5	447.6	448.6	449.6
46.5000	10350.	28541.	-13225.	355.4	363.5	421.7	415.0	426.6	433.3	439.6	442.6	443.7	444.7	445.7
47.0000	10499.	28764.	-13349.	351.8	359.3	418.8	411.1	422.7	429.4	435.7	438.7	439.8	440.8	441.8
47.5000	10643.	28983.	-13471.	348.2	355.1	415.9	407.2	418.8	425.5	431.8	434.8	435.9	436.9	437.9
48.0000	10782.	29198.	-13592.	344.6	350.9	413.0	403.3	414.9	422.2	428.5	431.5	432.6	433.6	434.6
48.5000	10916.	29409.	-13712.	341.0	346.7	410.1	399.4	411.0	418.9	425.2	428.2	429.3	430.3	431.3
49.0000	11045.	29616.	-13831.	337.4	342.5	407.2	395.5	407.1	415.0	421.7	424.7	425.8	426.8	427.8
49.5000	11169.	29819.	-13949.	333.8	338.3	404.3	391.6	403.2	411.1	417.8	420.8	421.9	422.9	423.9

SMUD RAPID COOLDOWN

L. D. McKIM

A-65

TIME	EQUIV LIN: RAD	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	MODE10	MODE11
50.0000	8140:	24297	186	358.8	385.0	411.8	432.5	447.7	463.3	472.9	478.6	480.5	480.5	480.5
50.5000	8064:	24190	183	356.8	383.9	409.6	430.5	445.4	461.0	470.6	476.3	478.3	478.3	478.3
51.0000	8026:	24137	181	354.8	382.0	407.3	428.1	443.0	458.5	468.0	473.7	475.7	475.7	475.7
51.5000	7998:	24085	179	352.8	380.1	405.3	426.0	440.9	456.2	465.6	471.4	473.4	473.4	473.4
52.0000	7950:	24033	176	350.8	378.2	403.4	424.9	439.8	455.0	464.4	470.2	472.2	472.2	472.2
53.0000	7912:	23982	174	348.8	376.4	401.5	422.8	437.7	452.9	462.2	468.0	470.0	470.0	470.0
54.0000	7874:	23932	171	346.8	374.6	399.6	420.7	435.6	450.7	459.9	465.7	467.7	467.7	467.7
54.5000	7836:	23883	169	344.8	372.8	397.6	418.6	433.5	448.6	457.8	463.6	465.6	465.6	465.6
55.0000	7799:	23834	167	342.8	371.0	395.6	416.5	431.4	446.5	455.7	461.5	463.5	463.5	463.5
55.5000	7762:	23787	165	340.8	369.2	393.6	414.4	429.3	444.4	453.6	459.4	461.4	461.4	461.4
56.0000	7725:	23740	163	338.8	367.4	391.6	412.3	427.2	442.3	451.5	457.3	459.3	459.3	459.3
56.5000	7689:	23693	161	336.8	365.6	389.6	410.2	425.1	440.2	449.4	455.2	457.2	457.2	457.2
57.0000	7653:	23647	159	334.8	363.8	387.6	408.1	423.0	438.1	447.3	453.1	455.1	455.1	455.1
57.5000	7617:	23602	157	332.8	362.0	385.6	406.0	420.9	436.0	445.2	451.0	453.0	453.0	453.0
58.0000	7582:	23557	155	330.8	360.2	383.6	403.9	418.8	433.9	443.0	448.8	450.8	450.8	450.8
58.5000	7547:	23512	153	328.8	358.4	381.6	401.8	416.7	431.8	440.9	446.7	448.7	448.7	448.7
59.0000	7512:	23468	151	326.8	356.6	379.6	399.7	414.6	429.7	438.8	444.6	446.6	446.6	446.6
59.5000	7477:	23424	149	324.8	354.8	377.6	397.6	412.5	427.6	436.7	442.5	444.5	444.5	444.5
60.0000	7444:	23382	147	322.8	353.0	375.6	395.6	410.4	425.5	434.6	440.4	442.4	442.4	442.4
60.5000	7411:	23342	145	320.8	351.2	373.6	393.6	408.3	423.4	432.5	438.3	440.3	440.3	440.3
61.0000	7379:	23302	143	318.8	349.4	371.6	391.6	406.2	421.3	430.4	436.2	438.2	438.2	438.2
61.5000	7359:	23264	141	316.8	347.6	369.6	389.6	404.1	419.2	428.3	434.1	436.1	436.1	436.1
62.0000	7349:	23227	139	314.8	345.8	367.6	387.6	402.0	417.1	426.2	432.0	434.0	434.0	434.0
62.5000	7340:	23191	137	312.8	344.0	365.6	385.6	400.0	415.0	424.1	430.0	432.0	432.0	432.0
63.0000	7332:	23157	135	310.8	342.2	363.6	383.6	397.9	412.9	422.0	427.9	429.9	429.9	429.9
63.5000	7325:	23124	133	308.8	340.4	361.6	381.6	395.8	410.8	420.1	426.0	428.0	428.0	428.0
64.0000	7319:	23092	131	306.8	338.6	359.6	379.6	393.7	408.7	418.0	423.9	425.9	425.9	425.9
64.5000	7315:	23061	129	304.8	336.8	357.6	377.6	391.6	406.6	416.0	421.9	423.9	423.9	423.9
65.0000	7311:	23032	127	302.8	335.0	355.6	375.6	389.5	404.5	414.0	419.9	421.9	421.9	421.9
65.5000	7309:	23005	125	300.8	333.2	353.6	373.6	387.4	402.4	412.0	417.9	419.9	419.9	419.9
66.0000	7308:	22979	123	298.8	331.4	351.6	371.6	385.3	400.3	410.0	415.9	417.9	417.9	417.9
66.5000	7307:	22954	121	296.8	329.6	349.6	369.6	383.2	398.2	408.0	413.9	415.9	415.9	415.9
67.0000	7307:	22930	119	294.8	327.8	347.6	367.6	381.1	396.1	406.0	411.9	413.9	413.9	413.9
67.5000	7307:	22907	117	292.8	326.0	345.6	365.6	379.0	394.0	404.0	409.9	411.9	411.9	411.9
68.0000	7307:	22885	115	290.8	324.2	343.6	363.6	376.9	392.0	402.0	407.9	409.9	409.9	409.9
68.5000	7307:	22864	113	288.8	322.4	341.6	361.6	374.8	390.0	400.0	405.9	407.9	407.9	407.9
69.0000	7307:	22844	111	286.8	320.6	339.6	359.6	372.7	388.0	398.0	403.9	405.9	405.9	405.9
69.5000	7307:	22825	109	284.8	318.8	337.6	357.6	370.6	386.0	396.0	401.9	403.9	403.9	403.9
70.0000	7307:	22807	107	282.8	317.0	335.6	355.6	368.5	384.0	394.0	399.9	401.9	401.9	401.9

SMUD RAPID COOLDOWN
A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD DATE 04/20/78

TIME	EQUIV RAD	INSTR	INSIDE	OUTSIDE	THERMAL STRESS	MODE 1 5	MODE 2 5	MODE 3 9	MODE 4 3	MODE 5 4	MODE 6 9	MODE 7 5	MODE 8 1	MODE 9 6	MODE 10 0	MODE 11 1
70.0000						302.1	317.6	334.9	354.9	367.4	377.9	385.5	390.1	391.6		
70.5000						301.8	319.7	336.6	351.5	365.2	375.4	383.0	388.2	389.7		
71.0000						301.5	319.7	335.4	350.2	364.2	372.0	380.0	384.4	385.9		
71.5000						300.5	317.9	333.2	347.5	359.7	369.4	376.8	380.0	382.0		
72.0000						299.8	316.0	330.9	344.9	356.5	366.3	373.1	375.5	378.0		
72.5000						299.2	314.2	328.9	342.4	353.3	363.0	369.1	373.8	376.2		
73.0000						298.7	312.4	327.7	340.1	350.2	359.5	365.5	370.4	372.8		
73.5000						298.2	310.6	325.6	337.4	347.7	356.0	362.0	366.4	370.1		
74.0000						297.7	308.8	324.4	335.1	345.4	353.7	360.0	364.4	368.1		
74.5000						297.2	307.0	323.2	333.8	344.1	352.4	358.8	363.2	366.9		
75.0000						296.7	305.2	322.0	332.6	342.9	351.2	357.8	362.2	365.9		
75.5000						296.2	303.4	320.6	331.2	341.5	349.8	356.5	360.9	364.6		
76.0000						295.7	301.6	319.4	330.0	340.3	348.6	355.4	359.8	363.5		
76.5000						295.2	300.0	317.8	329.2	339.5	347.8	354.7	359.1	362.8		
77.0000						294.7	298.2	315.8	328.4	338.7	347.0	354.0	358.4	362.1		
77.5000						294.2	296.6	314.3	327.8	338.1	346.4	353.4	357.8	361.5		
78.0000						293.7	295.0	312.8	327.3	337.6	345.9	352.9	357.3	361.0		
78.5000						293.2	293.4	311.3	326.8	337.1	345.4	352.4	356.8	360.5		
79.0000						292.7	291.6	309.8	326.3	336.6	344.9	351.9	356.3	360.0		
80.0000						292.2	290.0	308.3	325.8	336.1	344.4	351.4	355.8	359.5		
81.0000						291.7	288.4	306.8	325.3	335.6	343.9	350.9	355.3	359.0		
82.0000						291.2	286.6	305.3	324.8	335.1	343.4	350.4	354.8	358.5		
83.0000						290.7	284.8	303.8	324.3	334.6	342.9	349.9	354.3	358.0		
84.0000						290.2	283.0	302.3	323.8	334.1	342.4	349.4	353.8	357.5		
85.0000						289.7	281.2	300.8	323.3	333.6	341.9	348.9	353.3	357.0		
86.0000						289.2	279.4	299.3	322.8	333.1	341.4	348.4	352.8	356.5		
87.0000						288.7	277.6	297.8	322.3	332.6	340.9	347.9	352.3	356.0		
88.0000						288.2	275.8	296.3	321.8	332.1	340.4	347.4	351.8	355.5		
89.0000						287.7	274.0	294.8	321.3	331.6	339.9	346.9	351.3	355.0		
90.0000						287.2	272.2	293.3	320.8	331.1	339.4	346.4	350.8	354.5		
91.0000						286.7	270.4	291.8	320.3	330.6	338.9	345.9	350.3	354.0		
92.0000						286.2	268.6	290.3	319.8	330.1	338.4	345.4	349.8	353.5		
93.0000						285.7	266.8	288.8	319.3	329.6	337.9	344.9	349.3	353.0		
94.0000						285.2	265.0	287.3	318.8	329.1	337.4	344.4	348.8	352.5		
95.0000						284.7	263.2	285.8	318.3	328.6	336.9	343.9	348.3	352.0		
96.0000						284.2	261.4	284.3	317.8	328.1	336.4	343.4	347.8	351.5		
97.0000						283.7	259.6	282.8	317.3	327.6	335.9	343.4	347.8	351.0		
98.0000						283.2	257.8	281.3	316.8	327.1	335.4	343.4	347.8	350.5		
99.0000						282.7	256.0	279.8	316.3	326.6	334.9	343.4	347.8	350.0		

SMUD RAPID COOLDOWN
L. D. McKIM

A-67

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD

TIME	EQUIV HEAD	IN	THRESHOLD	OUTSIDE	THRESHOLD	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9	MODE10	MODE11
100.0000		3206.	3697.	-2253.	29.0	300.2	303.8	307.2	310.4	312.0	314.0	316.4	318.8	321.2	323.6
101.0000		32925.	3396.	-2066.	27.5	301.0	303.9	306.7	309.5	311.0	312.5	314.0	315.5	317.0	318.5
102.0000		22656.	2396.	-1710.	299.3	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
103.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
104.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
105.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
106.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
107.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
108.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
109.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
110.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
111.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
112.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
113.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
114.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
115.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
116.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
117.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
118.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
119.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
120.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
121.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
122.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
123.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
124.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
125.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
126.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
127.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
128.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
129.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
130.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
131.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
132.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
133.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
134.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
135.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
136.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
137.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
138.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9
139.0000		2396.	2350.	-1710.	300.8	301.0	304.3	306.5	308.5	310.4	311.9	313.4	314.9	316.4	317.9

DATE 04/20/78

A. D. McKIM

SMUD RAPID COOLDOWN

A-68

*** FULL CERTIFICATION ***

*** FULL CERTIFICATION ***

*** FULL CERTIFICATION ***

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION UPPER HEAD DATE 04/20/78

TIME	EQUIV LIN. RAD	INSIDE	OUTSIDE	MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9	MODE 10	MODE 11
140.0030	-2872.	-4032.	1835.	336.6	331.6	327.5	324.2	321.5	319.5	318.1	317.3	317.0		

THERMAL STRESS
INSIDE OUTSIDE

SMUD RAPID COOLDOWN
A. D. McKIM

A-69

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

DATE 05/12/78

DIMENSIONS

INSIDE RADIUS = 76.1875 INCHES OUTSIDE RADIUS = 100.0000 INCHES
NO. OF NODES = 9 RADIAL INCREMENT = 2.9766 INCHES
MATERIAL CODE = 12 POISSON'S RATIO = .3000
L = 0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	76.1875	565.0
2	79.1641	565.0
3	82.1406	565.0
4	85.1172	565.0
5	88.0938	565.0
6	91.0703	565.0
7	94.0469	565.0
8	97.0234	565.0
9	100.0000	565.0

SMUD RAPID COOLDOWN
D. MCKIN

A-70

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE DATE 05/12/78

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATION (MINUTES)	INSIDE FLUID TEMPERATURE	TIME APPROXIMATION (MINUTES)	INSIDE FILM COEFFICIENT	TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	565.0	0.0000	500.0	0.0000	0.
5.0000	565.0	140.0000	500.0	0.0000	0.
10.0000	590.0	0.0000	0.0	0.0000	0.
15.0000	590.0	0.0000	0.0	0.0000	0.
20.0000	525.0	0.0000	0.0	0.0000	0.
40.0000	380.0	0.0000	0.0	0.0000	0.
60.0000	280.0	0.0000	0.0	0.0000	0.
80.0000	290.0	0.0000	0.0	0.0000	0.
95.0000	305.0	0.0000	0.0	0.0000	0.
140.0000	340.0	0.0000	0.0	0.0000	0.

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE CALCULATION TIME (MINUTES)	LIMIT (MINUTES)	NUMBER OF PRINTOUTS
.5000	20.000	20.
1.0000	80.000	120.
	140.000	

SMUD RAPID COOLDOWN
A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE FULL CERTIFICATION

1232 REV 4 12-15-74 05/12/78 09-13-41 PAGE 10
FULL CERTIFICATION *** J12CCCE

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

DATE 05/12/78

TIME	EQUIV RAD	LIN. STR.	THERMAL STRESS		NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
			INSIDE	OUTSIDE											
1.0000		-0.	-0.	-0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
2.0000		-0.	-0.	-0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
3.0000		-0.	-0.	-0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
4.0000		-0.	-0.	-0.	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0	565.0
5.0000		76.	531.	273.	566.0	567.0	568.0	569.0	570.0	571.0	572.0	573.0	574.0	575.0	576.0
6.0000		240.	593.	334.	570.0	571.0	572.0	573.0	574.0	575.0	576.0	577.0	578.0	579.0	580.0
7.0000		456.	673.	404.	574.0	575.0	576.0	577.0	578.0	579.0	580.0	581.0	582.0	583.0	584.0
8.0000		703.	784.	475.	583.0	584.0	585.0	586.0	587.0	588.0	589.0	590.0	591.0	592.0	593.0
9.0000		940.	835.	546.	587.0	588.0	589.0	590.0	591.0	592.0	593.0	594.0	595.0	596.0	597.0
10.0000		990.	886.	617.	593.0	594.0	595.0	596.0	597.0	598.0	599.0	600.0	601.0	602.0	603.0
11.0000		225.	964.	688.	597.0	598.0	599.0	600.0	601.0	602.0	603.0	604.0	605.0	606.0	607.0
12.0000		344.	1014.	759.	604.0	605.0	606.0	607.0	608.0	609.0	610.0	611.0	612.0	613.0	614.0
13.0000		535.	1027.	830.	610.0	611.0	612.0	613.0	614.0	615.0	616.0	617.0	618.0	619.0	620.0
14.0000		654.	1033.	901.	617.0	618.0	619.0	620.0	621.0	622.0	623.0	624.0	625.0	626.0	627.0
15.0000		763.	1039.	972.	623.0	624.0	625.0	626.0	627.0	628.0	629.0	630.0	631.0	632.0	633.0
16.0000		872.	1045.	1043.	630.0	631.0	632.0	633.0	634.0	635.0	636.0	637.0	638.0	639.0	640.0
17.0000		981.	1051.	1114.	636.0	637.0	638.0	639.0	640.0	641.0	642.0	643.0	644.0	645.0	646.0
18.0000		986.	1057.	1185.	642.0	643.0	644.0	645.0	646.0	647.0	648.0	649.0	650.0	651.0	652.0
19.0000		991.	1063.	1256.	648.0	649.0	650.0	651.0	652.0	653.0	654.0	655.0	656.0	657.0	658.0
20.0000		996.	1069.	1327.	654.0	655.0	656.0	657.0	658.0	659.0	660.0	661.0	662.0	663.0	664.0
21.0000		1001.	1075.	1398.	660.0	661.0	662.0	663.0	664.0	665.0	666.0	667.0	668.0	669.0	670.0
22.0000		1006.	1081.	1469.	666.0	667.0	668.0	669.0	670.0	671.0	672.0	673.0	674.0	675.0	676.0
23.0000		1011.	1087.	1540.	672.0	673.0	674.0	675.0	676.0	677.0	678.0	679.0	680.0	681.0	682.0
24.0000		1016.	1093.	1611.	678.0	679.0	680.0	681.0	682.0	683.0	684.0	685.0	686.0	687.0	688.0
25.0000		1021.	1099.	1682.	684.0	685.0	686.0	687.0	688.0	689.0	690.0	691.0	692.0	693.0	694.0
26.0000		1026.	1105.	1753.	690.0	691.0	692.0	693.0	694.0	695.0	696.0	697.0	698.0	699.0	700.0
27.0000		1031.	1111.	1824.	696.0	697.0	698.0	699.0	700.0	701.0	702.0	703.0	704.0	705.0	706.0
28.0000		1036.	1117.	1895.	702.0	703.0	704.0	705.0	706.0	707.0	708.0	709.0	710.0	711.0	712.0
29.0000		1041.	1123.	1966.	708.0	709.0	710.0	711.0	712.0	713.0	714.0	715.0	716.0	717.0	718.0
30.0000		1046.	1129.	2037.	714.0	715.0	716.0	717.0	718.0	719.0	720.0	721.0	722.0	723.0	724.0
31.0000		1051.	1135.	2108.	720.0	721.0	722.0	723.0	724.0	725.0	726.0	727.0	728.0	729.0	730.0
32.0000		1056.	1141.	2179.	726.0	727.0	728.0	729.0	730.0	731.0	732.0	733.0	734.0	735.0	736.0
33.0000		1061.	1147.	2250.	732.0	733.0	734.0	735.0	736.0	737.0	738.0	739.0	740.0	741.0	742.0
34.0000		1066.	1153.	2321.	738.0	739.0	740.0	741.0	742.0	743.0	744.0	745.0	746.0	747.0	748.0
35.0000		1071.	1159.	2392.	744.0	745.0	746.0	747.0	748.0	749.0	750.0	751.0	752.0	753.0	754.0
36.0000		1076.	1165.	2463.	750.0	751.0	752.0	753.0	754.0	755.0	756.0	757.0	758.0	759.0	760.0
37.0000		1081.	1171.	2534.	756.0	757.0	758.0	759.0	760.0	761.0	762.0	763.0	764.0	765.0	766.0
38.0000		1086.	1177.	2605.	762.0	763.0	764.0	765.0	766.0	767.0	768.0	769.0	770.0	771.0	772.0
39.0000		1091.	1183.	2676.	768.0	769.0	770.0	771.0	772.0	773.0	774.0	775.0	776.0	777.0	778.0
40.0000		1096.	1189.	2747.	774.0	775.0	776.0	777.0	778.0	779.0	780.0	781.0	782.0	783.0	784.0
41.0000		1101.	1195.	2818.	780.0	781.0	782.0	783.0	784.0	785.0	786.0	787.0	788.0	789.0	790.0
42.0000		1106.	1201.	2889.	786.0	787.0	788.0	789.0	790.0	791.0	792.0	793.0	794.0	795.0	796.0
43.0000		1111.	1207.	2960.	792.0	793.0	794.0	795.0	796.0	797.0	798.0	799.0	800.0	801.0	802.0
44.0000		1116.	1213.	3031.	798.0	799.0	800.0	801.0	802.0	803.0	804.0	805.0	806.0	807.0	808.0
45.0000		1121.	1219.	3102.	804.0	805.0	806.0	807.0	808.0	809.0	810.0	811.0	812.0	813.0	814.0
46.0000		1126.	1225.	3173.	810.0	811.0	812.0	813.0	814.0	815.0	816.0	817.0	818.0	819.0	820.0
47.0000		1131.	1231.	3244.	816.0	817.0	818.0	819.0	820.0	821.0	822.0	823.0	824.0	825.0	826.0
48.0000		1136.	1237.	3315.	822.0	823.0	824.0	825.0	826.0	827.0	828.0	829.0	830.0	831.0	832.0
49.0000		1141.	1243.	3386.	828.0	829.0	830.0	831.0	832.0	833.0	834.0	835.0	836.0	837.0	838.0
50.0000		1146.	1249.	3457.	834.0	835.0	836.0	837.0	838.0	839.0	840.0	841.0	842.0	843.0	844.0

SMUD RAPID COLDOW

A. D. McKIM

A-72

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

DATE 05/12/78

TIME	EQUIV RAD	LN. STN.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
30.0000		7036.	25480.	-2467.	470.2	533.3	558.6	644.3	569.2	565.2	565.2	565.2	565.2	565.2	565.2
30.5000		7405.	26322.	-2016.	466.8	533.3	557.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
31.0000		7779.	27163.	-2767.	463.6	531.6	557.0	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
31.5000		8154.	28002.	-2921.	460.1	529.7	556.2	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
32.0000		8533.	28840.	-3077.	455.7	527.7	555.3	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
32.5000		8915.	29676.	-3236.	453.3	525.8	554.5	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
33.0000		9301.	30511.	-3396.	450.0	523.8	553.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
33.5000		9690.	31344.	-3559.	446.6	521.8	552.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
34.0000		10082.	32176.	-3725.	443.2	519.4	551.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
34.5000		10477.	33007.	-3892.	439.8	517.9	550.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
35.0000		10874.	33836.	-4052.	436.5	515.8	549.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
35.5000		11274.	34664.	-4234.	433.	513.8	548.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
36.0000		11679.	35490.	-4408.	429.7	511.8	547.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
36.5000		2083.	36315.	-4586.	426.	509.7	546.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
37.0000		2492.	37138.	-4752.	422.	507.6	545.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
37.5000		2903.	37960.	-4943.	419.5	505.5	544.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
38.0000		3316.	38781.	-5125.	416.	503.4	543.5	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
38.5000		3732.	39600.	-5310.	412.7	501.3	542.4	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
39.0000		4150.	40414.	-5497.	409.	499.2	541.3	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
39.5000		4571.	41235.	-5685.	405.9	497.0	540.2	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
40.0000		4994.	42050.	-5876.	402.	494.9	539.0	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
40.5000		5404.	42853.	-6068.	399.	492.7	537.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
41.0000		5795.	43619.	-6268.	397.	490.6	536.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
41.5000		6175.	43815.	-6429.	394.	488.5	535.5	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
42.0000		6546.	44275.	-6589.	392.	486.4	534.2	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
42.5000		6911.	44714.	-6787.	390.	484.4	533.0	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
43.0000		7272.	45143.	-6985.	388.	482.4	531.8	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
43.5000		7624.	45565.	-7162.	386.	480.4	530.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
44.0000		7981.	45983.	-7319.	384.	478.5	529.3	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
44.5000		8330.	46399.	-7495.	382.	476.6	528.1	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
45.0000		8677.	46813.	-7671.	380.	474.7	526.9	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
45.5000		9020.	47225.	-7841.	378.	472.8	525.6	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
46.0000		9361.	47636.	-8023.	376.	471.0	524.4	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
46.5000		9700.	48046.	-8199.	374.	469.2	523.1	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
47.0000		20037.	48455.	-8374.	372.	467.4	521.9	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
47.5000		30171.	48863.	-8550.	370.	465.6	520.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
48.0000		40704.	49270.	-8726.	368.	463.8	519.4	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
48.5000		51935.	49676.	-8901.	366.	462.1	518.2	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
49.0000		6366.	50081.	-9077.	364.	460.3	517.0	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2
49.5000		1691.	50485.	-9253.	362.7	458.6	515.7	644.3	565.2	565.2	565.2	565.2	565.2	565.2	565.2

SMUD RAPID COLDOWN

L. D. McKIN

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

DATE 05/12/78

TIME	EQUIV RAD	LIN. SIN.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE10	NODE11
70.0000	32552.	59812.	-15950.	307.5	399.1	467.5	502.4	538.8	559.3	559.8	562.8	563.5	563.5	563.5	563.5
70.5000	32719.	59834.	-16081.	308.9	398.1	466.5	501.0	537.8	558.3	559.8	562.8	563.5	563.5	563.5	563.5
71.0000	32882.	59856.	-16211.	308.8	397.7	465.5	500.0	537.2	557.8	559.3	562.3	563.0	563.0	563.0	563.0
71.5000	33043.	59877.	-16339.	305.2	396.6	464.4	498.0	536.6	556.8	558.3	561.3	562.0	562.0	562.0	562.0
72.0000	33201.	59899.	-16466.	304.7	395.3	463.5	496.6	535.5	556.0	557.5	560.5	561.2	561.2	561.2	561.2
72.5000	33356.	59920.	-16591.	303.5	394.3	462.5	495.4	534.4	555.0	556.5	559.5	560.2	560.2	560.2	560.2
73.0000	33509.	59941.	-16716.	303.5	393.2	460.6	494.2	533.2	554.0	555.5	558.5	559.2	559.2	559.2	559.2
73.5000	33658.	59962.	-16839.	303.0	392.1	459.7	493.1	532.1	553.0	554.5	557.5	558.2	558.2	558.2	558.2
74.0000	33806.	59984.	-16961.	302.4	390.8	458.8	492.0	531.0	552.0	553.5	556.5	557.2	557.2	557.2	557.2
74.5000	33951.	60005.	-17081.	301.9	390.0	457.8	490.9	529.9	551.0	552.5	555.5	556.2	556.2	556.2	556.2
75.0000	34094.	60026.	-17201.	301.3	390.1	456.9	489.8	528.8	550.0	551.5	554.5	555.2	555.2	555.2	555.2
75.5000	34234.	60047.	-17319.	300.8	390.3	456.0	488.7	527.7	549.0	550.5	553.5	554.2	554.2	554.2	554.2
76.0000	34372.	60068.	-17436.	300.3	390.4	455.0	487.6	526.6	548.0	549.5	552.5	553.2	553.2	553.2	553.2
76.5000	34508.	60090.	-17552.	300.2	390.5	454.1	486.5	525.5	547.0	548.5	551.5	552.2	552.2	552.2	552.2
77.0000	34642.	60111.	-17666.	299.9	390.6	453.3	485.4	524.4	546.0	547.5	550.5	551.2	551.2	551.2	551.2
77.5000	34774.	60132.	-17780.	299.1	390.8	452.5	484.3	523.3	545.0	546.5	549.5	550.2	550.2	550.2	550.2
78.0000	34904.	60153.	-17892.	298.5	390.9	451.7	483.2	522.2	544.0	545.5	548.5	549.2	549.2	549.2	549.2
78.5000	35032.	60174.	-18004.	297.7	390.9	451.0	482.1	521.1	543.0	544.5	547.5	548.2	548.2	548.2	548.2
79.0000	35158.	60195.	-18114.	297.0	390.7	450.0	481.0	520.0	542.0	543.5	546.5	547.2	547.2	547.2	547.2
79.5000	35282.	60217.	-18223.	296.9	390.7	449.0	480.0	518.9	541.0	542.5	545.5	546.2	546.2	546.2	546.2
80.0000	35405.	60238.	-18331.	296.0	390.5	447.5	479.0	517.8	540.0	541.5	544.5	545.2	545.2	545.2	545.2
81.0000	35526.	60091.	-18435.	296.1	390.5	446.5	478.0	516.7	539.0	540.5	543.5	544.2	544.2	544.2	544.2
81.5000	35646.	59787.	-18535.	296.6	390.6	445.9	477.0	515.6	538.0	539.5	542.5	543.2	543.2	543.2	543.2
82.0000	35760.	59787.	-18635.	296.6	390.6	445.0	476.0	514.5	537.0	538.5	541.5	542.2	542.2	542.2	542.2
82.5000	35874.	59444.	-18735.	296.6	390.6	444.2	475.0	513.4	536.0	537.5	540.5	541.2	541.2	541.2	541.2
83.0000	36073.	59091.	-18905.	296.6	390.6	443.7	474.0	512.3	535.0	536.5	539.5	540.2	540.2	540.2	540.2
83.5000	36188.	58736.	-19237.	297.0	390.7	443.0	473.0	511.2	534.0	535.5	538.5	539.2	539.2	539.2	539.2
84.0000	36288.	58381.	-19591.	297.5	390.8	442.5	472.0	510.1	533.0	534.5	537.5	538.2	538.2	538.2	538.2
84.5000	36375.	58027.	-19951.	298.0	390.9	441.8	471.0	509.0	532.0	533.5	536.5	537.2	537.2	537.2	537.2
85.0000	36444.	57673.	-20317.	299.0	390.9	441.0	470.0	508.0	531.0	532.5	535.5	536.2	536.2	536.2	536.2
85.5000	36510.	57321.	-20686.	299.9	390.9	440.5	469.0	507.0	530.0	531.5	534.5	535.2	535.2	535.2	535.2
86.0000	36560.	56969.	-21049.	299.9	390.9	440.0	468.0	506.0	529.0	530.5	533.5	534.2	534.2	534.2	534.2
86.5000	36600.	56619.	-21416.	299.9	390.9	439.5	467.0	505.0	528.0	529.5	532.5	533.2	533.2	533.2	533.2
87.0000	36630.	56270.	-21780.	300.0	390.9	439.0	466.0	504.0	527.0	528.5	531.5	532.2	532.2	532.2	532.2
87.5000	36650.	55922.	-22146.	300.0	390.9	438.5	465.0	503.0	526.0	527.5	530.5	531.2	531.2	531.2	531.2
88.0000	36662.	55575.	-22515.	300.0	390.9	438.0	464.0	502.0	525.0	526.5	529.5	530.2	530.2	530.2	530.2
88.5000	36666.	55230.	-22886.	300.0	390.9	437.5	463.0	501.0	524.0	525.5	528.5	529.2	529.2	529.2	529.2
89.0000	36666.	54886.	-23261.	300.0	390.9	437.0	462.0	500.0	523.0	524.5	527.5	528.2	528.2	528.2	528.2
89.5000	36631.	54536.	-23641.	300.0	390.9	436.5	461.0	499.0	522.0	523.5	526.5	527.2	527.2	527.2	527.2
90.0000	36546.	54187.	-24028.	300.0	390.9	436.0	460.0	498.0	521.0	522.5	525.5	526.2	526.2	526.2	526.2
90.5000	36552.	53839.	-24423.	304.7	367.5	425.5	472.0	497.0	520.0	521.5	524.5	525.2	525.2	525.2	525.2

SMUD RAPID COOLDOWN
I. D. McKIN

A-75

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

DATE 05/12/78

TIME	EQUIV RAD	LN. SIH.	THERMAL SIH. INSIDE	THERMAL SIH. OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE10	NODE11
00.0000		36500.	53141.	-20411.	305.5	347.3	424.7	471.8	506.8	530.5	545.0	552.7	555.9	555.9	555.9
01.0000		36639.	52764.	-20853.	305.3	347.0	423.9	470.4	505.8	529.2	544.4	552.2	555.5	555.5	555.5
02.0000		36370.	52344.	-20409.	307.1	346.6	423.0	469.0	504.6	528.8	543.8	551.7	555.0	555.0	555.0
03.0000		36295.	51935.	-20449.	307.9	346.8	422.4	468.4	503.3	527.7	542.6	551.0	554.3	554.3	554.3
04.0000		36212.	51523.	-20484.	308.8	347.7	421.7	467.4	502.0	526.5	541.6	550.0	553.6	553.6	553.6
05.0000		36123.	51113.	-2014.	309.6	346.6	421.0	466.7	500.8	525.3	540.6	549.0	552.4	552.4	552.4
06.0000		36027.	50704.	-2037.	311.3	346.6	419.8	465.3	500.0	524.2	539.0	547.7	551.3	551.3	551.3
07.0000		35926.	50297.	-2037.	311.3	346.6	419.8	465.3	499.9	523.3	538.0	546.6	550.2	550.2	550.2
08.0000		35819.	49891.	-2071.	312.1	346.6	418.7	463.8	498.8	522.3	536.9	545.4	549.0	549.0	549.0
09.0000		35707.	49487.	-2080.	313.0	346.6	418.3	463.2	497.7	521.3	535.7	544.2	547.8	547.8	547.8
10.0000		35589.	49084.	-2035.	313.9	346.6	417.2	462.0	496.6	520.2	534.6	543.0	546.5	546.5	546.5
11.0000		35466.	48684.	-2084.	314.8	346.6	416.3	461.1	495.5	519.1	533.5	541.8	545.2	545.2	545.2
12.0000		35331.	48229.	-2077.	315.7	347.0	415.3	460.2	494.4	518.0	532.4	540.6	543.9	543.9	543.9
13.0000		35192.	47793.	-2066.	316.7	347.0	414.3	459.0	493.3	516.9	531.3	539.4	542.7	542.7	542.7
14.0000		35048.	47357.	-2069.	317.7	347.0	413.3	457.9	492.2	515.8	530.2	538.2	541.5	541.5	541.5
15.0000		34899.	46922.	-2029.	318.8	347.0	412.3	456.6	491.1	514.7	529.1	537.0	540.3	540.3	540.3
16.0000		34743.	46489.	-2003.	320.0	347.0	411.3	455.3	490.0	513.6	528.0	535.8	539.0	539.0	539.0
17.0000		34584.	46057.	-2074.	322.0	347.0	410.3	454.0	488.9	512.5	526.9	534.6	537.7	537.7	537.7
18.0000		34420.	45627.	-2040.	323.1	347.0	409.3	452.7	487.8	511.4	525.8	533.4	536.5	536.5	536.5
19.0000		34252.	45198.	-2040.	324.3	347.0	408.3	451.4	486.7	510.3	524.7	532.2	535.2	535.2	535.2
20.0000		34081.	44771.	-2045.	325.9	347.0	407.3	450.1	485.6	509.2	523.6	531.0	534.0	534.0	534.0
21.0000		33905.	44346.	-2015.	327.9	347.0	406.3	448.8	484.5	508.1	522.5	529.8	532.8	532.8	532.8
22.0000		33726.	43922.	-2076.	329.7	347.0	405.3	447.5	483.4	507.0	521.4	528.6	531.6	531.6	531.6
23.0000		33543.	43500.	-2012.	331.9	347.0	404.3	446.2	482.3	505.9	520.3	527.4	530.4	530.4	530.4
24.0000		33358.	43079.	-2036.	334.0	347.0	403.3	444.9	481.2	504.8	519.2	526.2	529.2	529.2	529.2
25.0000		33169.	42660.	-2036.	336.0	347.0	402.3	443.6	480.1	503.7	518.1	525.0	528.0	528.0	528.0
26.0000		32977.	42242.	-2033.	338.0	347.0	401.3	442.3	479.0	502.6	517.0	523.8	526.8	526.8	526.8
27.0000		32782.	41824.	-2066.	339.9	347.0	400.3	441.0	477.9	501.5	515.9	522.6	525.6	525.6	525.6
28.0000		32585.	41411.	-2037.	342.0	347.0	399.3	439.7	476.8	500.4	514.8	521.4	524.4	524.4	524.4
29.0000		32385.	40998.	-2032.	344.0	347.0	398.3	438.4	475.7	499.3	513.7	520.2	523.2	523.2	523.2
30.0000		32183.	40587.	-2042.	346.0	347.0	397.3	437.1	474.6	498.2	512.6	519.0	522.0	522.0	522.0
31.0000		31979.	40176.	-2071.	348.0	347.0	396.3	435.8	473.5	497.1	511.5	517.8	520.8	520.8	520.8
32.0000		31771.	39768.	-2070.	350.0	347.0	395.3	434.5	472.4	496.0	510.4	516.6	519.6	519.6	519.6
33.0000		31556.	39361.	-2006.	352.0	347.0	394.3	433.2	471.3	494.9	509.3	515.4	518.4	518.4	518.4
34.0000		31337.	38955.	-2020.	354.0	347.0	393.3	431.9	470.2	493.8	508.2	514.2	517.2	517.2	517.2
35.0000		31113.	38550.	-2040.	356.0	347.0	392.3	430.6	469.1	492.7	507.1	513.0	516.0	516.0	516.0
36.0000		30922.	38148.	-2040.	358.0	347.0	391.3	429.3	468.0	491.6	506.0	511.8	514.8	514.8	514.8
37.0000		30705.	37746.	-2040.	360.0	347.0	390.3	428.0	466.9	490.5	504.9	510.6	513.6	513.6	513.6
38.0000		30487.	37346.	-2050.	362.0	347.0	389.3	426.7	465.8	489.4	503.8	509.4	512.4	512.4	512.4
39.0000		30267.	36947.	-2050.	363.0	347.0	388.3	425.4	464.7	488.3	502.7	508.2	511.2	511.2	511.2

SMUD RAPID COOLDOWN
 D. McKim

DATE 05/12/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION CLOSURE FLANGE

TIME	EQUIV LIN	THERMAL STRESS	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
140.0000	30045.	INSIDE	344.8	376.7	412.4	447.2	474.8	502.2	519.5	529.8	533.1		
		OUTSIDE											
			36550.										

SMUD RAPID COOLDOWN
 A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFN DATE 04/25/78

DIMENSIONS
 INSIDE RADIUS = 6.3125 INCHES
 NO. OF VODES = 9
 MATERIAL CODE = 12
 L = 0.0000
 OUTSIDE RADIUS = 7.8125 INCHES
 RADIAL INCREMENT = .1875 INCHES
 POISSON S RATIO = .3000

INITIAL CONDITIONS	
VODE	TEMPERATURE
1	565.0
2	565.0
3	565.0
4	565.0
5	565.0
6	565.0
7	565.0
8	565.0
9	565.0

SMUD RAPID COOLDOWN
 A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFV DATE 04/25/78

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROX (MINUTES)	INSIDE FLUID TEMPERATURE	TIME APPROX (MINUTES)	INSIDE FILM COEFFICIENT	TIME APPROX (MINUTES)	PRESSURE (PSI)
0.0000	555.0	0.0000	900.0	0.0000	0.0
5.0000	565.0	140.0000	900.0	0.0000	0.0
10.0000	590.0	0.0000	0.0	0.0000	0.0
15.0000	590.0	0.0000	0.0	0.0000	0.0
20.0000	525.0	0.0000	0.0	0.0000	0.0
40.0000	380.0	0.0000	0.0	0.0000	0.0
60.0000	300.0	0.0000	0.0	0.0000	0.0
80.0000	280.0	0.0000	0.0	0.0000	0.0
95.0000	290.0	0.0000	0.0	0.0000	0.0
110.0000	305.0	0.0000	0.0	0.0000	0.0
140.0000	340.0	0.0000	0.0	0.0000	0.0

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE TIME INCREMENT (MINUTES)	1.0000
TIME LIMIT (MINUTES)	140.000
NUMBER OF PRINTOUTS	120.
	60.

SMUD RAPID COOLDOWN
E. D. McKIM

TIME	EQVY FRAD	THRMAL STRESS INSIDE	THRMAL STRESS OUTSIDE	NOZZLE 1 5	NOZZLE 2 0	NOZZLE 3 2	NOZZLE 4 0	NOZZLE 5 4	NOZZLE 6 6	NOZZLE 7 3	NOZZLE 8 8	NOZZLE 9 0	NOZZLE 10 0	NOZZLE 11 0
30.0000	1539.	1539.	1539.	456.0	459.0	461.2	463.0	466.4	465.6	466.7	466.8	467.0	467.0	467.0
31.5000	1537.	1537.	1537.	452.9	457.4	453.6	455.7	460.8	458.9	462.7	463.5	463.7	463.7	463.7
33.0000	1535.	1535.	1535.	448.1	444.5	450.3	452.1	457.5	454.6	457.4	458.2	458.0	458.0	458.0
34.5000	1531.	1531.	1531.	442.0	440.9	446.6	444.8	445.2	443.3	448.1	444.9	445.1	445.1	445.1
36.0000	1527.	1527.	1527.	433.7	437.2	435.7	441.2	438.9	440.1	440.5	444.3	441.4	441.4	441.4
37.5000	1524.	1524.	1524.	423.0	430.0	428.5	433.9	431.7	436.4	433.7	436.0	434.5	434.5	434.5
39.0000	1521.	1521.	1521.	410.0	424.7	424.4	429.6	428.0	429.1	429.9	430.9	430.5	430.5	430.5
40.5000	1517.	1517.	1517.	406.0	419.4	417.6	423.0	420.4	425.8	425.3	426.7	425.2	425.2	425.2
42.0000	1513.	1513.	1513.	402.1	411.4	413.9	415.7	413.5	414.2	415.7	415.4	415.9	415.9	415.9
43.5000	1509.	1509.	1509.	399.4	406.2	406.7	408.8	406.8	410.9	411.1	412.5	412.5	412.5	412.5
45.0000	1507.	1507.	1507.	397.6	400.9	403.0	404.8	402.6	403.6	404.1	404.9	405.0	405.0	405.0
46.5000	1504.	1504.	1504.	392.1	393.6	395.4	397.5	395.3	400.0	400.4	401.6	401.7	401.7	401.7
48.0000	1502.	1502.	1502.	385.5	388.0	388.5	390.2	388.2	392.7	393.9	393.9	394.1	394.1	394.1
49.5000	1498.	1498.	1498.	381.4	385.0	385.4	386.4	384.2	389.1	389.9	389.4	390.4	390.4	390.4
51.0000	1494.	1494.	1494.	374.6	376.3	377.5	381.4	379.5	386.3	386.8	384.1	384.3	384.3	384.3
52.5000	1491.	1491.	1491.	371.9	374.1	375.2	376.6	374.9	380.2	381.2	379.5	379.6	379.6	379.6
54.0000	1487.	1487.	1487.	368.3	371.9	373.1	374.3	372.0	375.6	376.4	376.7	376.5	376.5	376.5
55.5000	1484.	1484.	1484.	366.9	366.9	366.9	367.9	368.7	371.5	371.9	370.0	370.1	370.1	370.1
57.0000	1480.	1480.	1480.	364.8	364.8	364.8	365.4	366.6	367.2	367.7	367.9	368.0	368.0	368.0
58.5000	1476.	1476.	1476.	362.7	362.7	362.7	363.7	364.5	365.1	365.6	365.8	365.9	365.9	365.9
60.0000	1472.	1472.	1472.	356.7	356.7	356.7	357.6	358.4	361.0	361.5	361.7	361.8	361.8	361.8
61.5000	1468.	1468.	1468.	354.4	354.4	354.4	355.7	356.4	357.0	357.4	357.7	357.7	357.7	357.7
63.0000	1464.	1464.	1464.	352.0	352.0	352.0	353.6	354.4	355.0	355.4	355.6	355.6	355.6	355.6
64.5000	1460.	1460.	1460.	346.6	346.6	346.6	347.6	348.3	350.9	351.6	351.9	351.9	351.9	351.9
66.0000	1456.	1456.	1456.	344.4	344.4	344.4	346.6	347.3	350.0	350.9	351.6	351.6	351.6	351.6
67.5000	1452.	1452.	1452.	342.1	342.1	342.1	344.4	345.1	348.8	349.4	349.6	349.6	349.6	349.6
69.0000	1448.	1448.	1448.	340.0	340.0	340.0	342.1	342.8	346.8	347.3	347.6	347.6	347.6	347.6

SMUD RAPID COOLDOWN
D. McKIM

DATE 04/25/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFV

TIME	EQUIV LN.	THermal STRESS INSIDE	THermal STRESS OUTSIDE	NOZZLE 1	NOZZLE 2	NOZZLE 3	NOZZLE 4	NOZZLE 5	NOZZLE 6	NOZZLE 7	NOZZLE 8	NOZZLE 9	MODEL10	MODEL11
50.0000	RA19.	40.	511.	342.	343.	344.	345.	346.	346.	347.	347.	347.	347.	347.
50.5000	RA18.	38.	510.	340.	341.	342.	343.	344.	344.	345.	345.	345.	345.	345.
51.0000	RA17.	35.	509.	336.	337.	338.	339.	340.	340.	341.	341.	341.	341.	341.
51.5000	RA16.	34.	508.	332.	333.	334.	335.	336.	336.	337.	337.	337.	337.	337.
52.0000	RA15.	33.	507.	328.	329.	330.	331.	332.	332.	333.	333.	333.	333.	333.
53.0000	RA14.	31.	506.	324.	325.	326.	327.	328.	328.	329.	329.	329.	329.	329.
54.0000	RA13.	29.	505.	320.	321.	322.	323.	324.	324.	325.	325.	325.	325.	325.
55.0000	RA12.	28.	504.	316.	317.	318.	319.	320.	320.	321.	321.	321.	321.	321.
56.0000	RA11.	27.	503.	312.	313.	314.	315.	316.	316.	317.	317.	317.	317.	317.
57.0000	RA10.	26.	502.	308.	309.	310.	311.	312.	312.	313.	313.	313.	313.	313.
58.0000	RA09.	24.	501.	304.	305.	306.	307.	308.	308.	309.	309.	309.	309.	309.
59.0000	RA08.	22.	500.	300.	301.	302.	303.	304.	304.	305.	305.	305.	305.	305.
60.0000	RA07.	21.	499.	296.	297.	298.	299.	300.	300.	301.	301.	301.	301.	301.
61.0000	RA06.	20.	498.	292.	293.	294.	295.	296.	296.	297.	297.	297.	297.	297.
62.0000	RA05.	18.	497.	288.	289.	290.	291.	292.	292.	293.	293.	293.	293.	293.
63.0000	RA04.	17.	496.	284.	285.	286.	287.	288.	288.	289.	289.	289.	289.	289.
64.0000	RA03.	16.	495.	280.	281.	282.	283.	284.	284.	285.	285.	285.	285.	285.
65.0000	RA02.	15.	494.	276.	277.	278.	279.	280.	280.	281.	281.	281.	281.	281.
66.0000	RA01.	14.	493.	272.	273.	274.	275.	276.	276.	277.	277.	277.	277.	277.
67.0000	RA00.	13.	492.	268.	269.	270.	271.	272.	272.	273.	273.	273.	273.	273.
68.0000	RA00.	12.	491.	264.	265.	266.	267.	268.	268.	269.	269.	269.	269.	269.
69.0000	RA00.	11.	490.	260.	261.	262.	263.	264.	264.	265.	265.	265.	265.	265.
70.0000	RA00.	10.	489.	256.	257.	258.	259.	260.	260.	261.	261.	261.	261.	261.

SMUD RAPID COOLDOWN
... D. McKIM

DATE 04/25/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFN

TIME	EQUIV LIN. RAD	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	MODE 1 5	MODE 2 9	MODE 3	MODE 4	MODE 5 6	MODE 6 7	MODE 7 8	MODE 8 9	MODE 9 9
70.0000	201.	279.	255.	290.4	290.4	291.1	291.4	291.0	291.7	291.3	291.4	291.9
71.0000	200.	278.	255.	289.9	289.9	290.6	290.4	290.0	290.7	290.3	290.4	290.9
72.0000	200.	278.	255.	289.4	289.4	288.6	289.4	289.0	289.7	289.3	289.4	289.9
73.0000	199.	277.	254.	288.9	288.9	288.1	288.9	288.5	289.2	288.8	288.9	289.4
74.0000	199.	277.	254.	288.4	288.4	287.6	288.4	288.0	288.7	288.3	288.4	288.9
75.0000	199.	277.	254.	287.9	287.9	287.1	287.9	287.5	288.2	287.8	287.9	288.4
76.0000	199.	277.	254.	287.4	287.4	286.6	287.4	287.0	287.7	287.3	287.4	287.9
77.0000	199.	277.	254.	286.9	286.9	286.1	286.9	286.5	287.2	286.8	286.9	287.4
78.0000	199.	277.	254.	286.4	286.4	285.6	286.4	286.0	286.7	286.3	286.4	286.9
79.0000	199.	277.	254.	285.9	285.9	285.1	285.9	285.5	286.2	285.8	285.9	286.4
80.0000	199.	277.	254.	285.4	285.4	284.6	285.4	285.0	285.7	285.3	285.4	285.9
81.0000	199.	277.	254.	284.9	284.9	284.1	284.9	284.5	285.2	284.8	284.9	285.4
82.0000	199.	277.	254.	284.4	284.4	283.6	284.4	284.0	284.7	284.3	284.4	284.9
83.0000	199.	277.	254.	283.9	283.9	283.1	283.9	283.5	284.2	283.8	283.9	284.4
84.0000	199.	277.	254.	283.4	283.4	282.6	283.4	283.0	283.7	283.3	283.4	283.9
85.0000	199.	277.	254.	282.9	282.9	282.1	282.9	282.5	283.2	282.8	282.9	283.4
86.0000	199.	277.	254.	282.4	282.4	281.6	282.4	282.0	282.7	282.3	282.4	282.9
87.0000	199.	277.	254.	281.9	281.9	281.1	281.9	281.5	282.2	281.8	281.9	282.4
88.0000	199.	277.	254.	281.4	281.4	280.6	281.4	281.0	281.7	281.3	281.4	281.9
89.0000	199.	277.	254.	280.9	280.9	280.1	280.9	280.5	281.2	280.8	280.9	281.4
90.0000	199.	277.	254.	280.4	280.4	279.6	280.4	280.0	280.7	280.3	280.4	280.9
91.0000	199.	277.	254.	279.9	279.9	279.1	279.9	279.5	280.2	279.8	279.9	280.4
92.0000	199.	277.	254.	279.4	279.4	278.6	279.4	279.0	279.7	279.3	279.4	279.9
93.0000	199.	277.	254.	278.9	278.9	278.1	278.9	278.5	279.2	278.8	278.9	279.4
94.0000	199.	277.	254.	278.4	278.4	277.6	278.4	278.0	278.7	278.3	278.4	278.9

SMUD RAPID COOLDOWN
L. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFN DATE 04/25/78

TIME	EQUIL 5 IN.	INSIDE	THERMAL STRESS	MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9	MODE 10	MODE 11
00.0000	95.	276.	48.	294.	294.	293.	293.	293.	293.	293.	293.	293.	293.	293.
01.0000	98.	276.	48.	295.	295.	294.	294.	294.	294.	294.	294.	294.	294.	294.
02.0000	99.	277.	48.	296.	296.	295.	295.	295.	295.	295.	295.	295.	295.	295.
03.0000	99.	277.	48.	297.	297.	296.	296.	296.	296.	296.	296.	296.	296.	296.
04.0000	99.	277.	48.	298.	298.	297.	297.	297.	297.	297.	297.	297.	297.	297.
05.0000	200.	278.	48.	299.	299.	298.	298.	298.	298.	298.	298.	298.	298.	298.
06.0000	200.	278.	48.	300.	300.	299.	299.	299.	299.	299.	299.	299.	299.	299.
07.0000	200.	279.	48.	301.	301.	300.	300.	300.	300.	300.	300.	300.	300.	300.
08.0000	200.	279.	48.	302.	302.	301.	301.	301.	301.	301.	301.	301.	301.	301.
09.0000	200.	279.	48.	303.	303.	302.	302.	302.	302.	302.	302.	302.	302.	302.
10.0000	200.	279.	48.	304.	304.	303.	303.	303.	303.	303.	303.	303.	303.	303.
11.0000	215.	280.	48.	305.	305.	304.	304.	304.	304.	304.	304.	304.	304.	304.
12.0000	224.	280.	48.	306.	306.	305.	305.	305.	305.	305.	305.	305.	305.	305.
13.0000	224.	280.	48.	307.	307.	306.	306.	306.	306.	306.	306.	306.	306.	306.
14.0000	231.	281.	48.	308.	308.	307.	307.	307.	307.	307.	307.	307.	307.	307.
15.0000	233.	281.	48.	309.	309.	308.	308.	308.	308.	308.	308.	308.	308.	308.
16.0000	233.	281.	48.	310.	310.	309.	309.	309.	309.	309.	309.	309.	309.	309.
17.0000	234.	282.	48.	311.	311.	310.	310.	310.	310.	310.	310.	310.	310.	310.
18.0000	234.	282.	48.	312.	312.	311.	311.	311.	311.	311.	311.	311.	311.	311.
19.0000	235.	282.	48.	313.	313.	312.	312.	312.	312.	312.	312.	312.	312.	312.
20.0000	235.	282.	48.	314.	314.	313.	313.	313.	313.	313.	313.	313.	313.	313.
21.0000	235.	282.	48.	315.	315.	314.	314.	314.	314.	314.	314.	314.	314.	314.
22.0000	235.	282.	48.	316.	316.	315.	315.	315.	315.	315.	315.	315.	315.	315.
23.0000	235.	282.	48.	317.	317.	316.	316.	316.	316.	316.	316.	316.	316.	316.
24.0000	235.	282.	48.	318.	318.	317.	317.	317.	317.	317.	317.	317.	317.	317.
25.0000	235.	282.	48.	319.	319.	318.	318.	318.	318.	318.	318.	318.	318.	318.
26.0000	235.	282.	48.	320.	320.	319.	319.	319.	319.	319.	319.	319.	319.	319.
27.0000	235.	282.	48.	321.	321.	320.	320.	320.	320.	320.	320.	320.	320.	320.
28.0000	235.	282.	48.	322.	322.	321.	321.	321.	321.	321.	321.	321.	321.	321.
29.0000	235.	282.	48.	323.	323.	322.	322.	322.	322.	322.	322.	322.	322.	322.
30.0000	235.	282.	48.	324.	324.	323.	323.	323.	323.	323.	323.	323.	323.	323.
31.0000	235.	282.	48.	325.	325.	324.	324.	324.	324.	324.	324.	324.	324.	324.
32.0000	235.	282.	48.	326.	326.	325.	325.	325.	325.	325.	325.	325.	325.	325.
33.0000	235.	282.	48.	327.	327.	326.	326.	326.	326.	326.	326.	326.	326.	326.
34.0000	235.	282.	48.	328.	328.	327.	327.	327.	327.	327.	327.	327.	327.	327.
35.0000	235.	282.	48.	329.	329.	328.	328.	328.	328.	328.	328.	328.	328.	328.
36.0000	235.	282.	48.	330.	330.	329.	329.	329.	329.	329.	329.	329.	329.	329.
37.0000	235.	282.	48.	331.	331.	330.	330.	330.	330.	330.	330.	330.	330.	330.
38.0000	235.	282.	48.	332.	332.	331.	331.	331.	331.	331.	331.	331.	331.	331.
39.0000	235.	282.	48.	333.	333.	332.	332.	332.	332.	332.	332.	332.	332.	332.

SMUD RAPID COOLDOWN

D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFV FULL CERTIFICATION 91232 REV 4 13-15-74 94/25/78 03-22-82 PAGE 15

DATE 04/25/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION NOZZLE CFV

TIME	EQUIV LIN.	THERMAL STRESS		NOZZLE CFV										
		INSIDE	OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
140.0000	4AD	-237.	-330.	339.4	339.0	338.7	338.4	338.2	338.0	337.9	337.8	337.8	337.8	337.8

SMUD RAPID COOLDOWN

J. D. MORTON

A-85

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE
FULL CERTIFICATION

91232 REV 4 12-15-74 04/27/78 14:02:50 PAGE 2
FULL CERTIFICATION

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

DATE 04/27/78

DIMENSIONS

INSIDE RADIUS = 18.3125 INCHES OUTSIDE RADIUS = 30.0000 INCHES
NO. OF NODES = 9 RADIAL INCREMENT = 1.6609 INCHES
MATERIAL CODE = 5 POISSON'S RATIO = .3000
L = 0.0000

INITIAL CONDITIONS		
NODE	RADIUS	TEMPERATURE
1	18.3125	565.0
2	19.9734	565.0
3	21.6343	565.0
4	23.2952	565.0
5	24.9561	565.0
6	26.6170	565.0
7	28.2779	565.0
8	29.9388	565.0
9	30.0000	565.0

SMUD RAPID COOLDOWN

T. D. McKim

A-86

DATE 04/27/78

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE TIME APPROXIMATION (MINUTES)	TEMPERATURE INSIDE FLUID	FILM COEFF. CURVE TIME APPROXIMATION (MINUTES)	COEFFICIENT INSIDE FILM	PRESSURE CURVE TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	565.0	0.0000	1000.0	0.0000	0.
5.0000	565.0	140.0000	1000.0	0.0000	0.
10.0000	590.0	0.0000	0.0	0.0000	0.
15.0000	590.0	0.0000	0.0	0.0000	0.
20.0000	525.0	0.0000	0.0	0.0000	0.
40.0000	380.0	0.0000	0.0	0.0000	0.
60.0000	300.0	0.0000	0.0	0.0000	0.
80.0000	240.0	0.0000	0.0	0.0000	0.
95.0000	290.0	0.0000	0.0	0.0000	0.
110.0000	305.0	0.0000	0.0	0.0000	0.
140.0000	340.0	0.0000	0.0	0.0000	0.

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE TIME INCREMENT (MINUTES)	TIME LIMIT (MINUTES)	NUMBER OF PRINTOUTS
.5000	20.000	20.
.5000	80.000	160.
1.0000	160.000	160.

SMUD RAPID COOLDOWN

A. D. McKIM

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

DATE 04/27/78

TIME	EQUIV LIN. RAD	THRMAL STRESS INSIDE	THRMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
50.0000	29971.	56748.	3926.	347.3	427.1	482.4	518.2	526.6	526.6	526.6	526.6	526.6	526.6	526.6
50.5000	30314.	57129.	4143.	345.3	425.3	480.9	517.2	525.0	525.0	525.0	525.0	525.0	525.0	525.0
51.0000	30654.	57509.	4359.	343.3	423.6	479.4	516.5	523.8	523.8	523.8	523.8	523.8	523.8	523.8
51.5000	30991.	57887.	4572.	341.3	421.8	478.0	515.8	522.7	522.7	522.7	522.7	522.7	522.7	522.7
52.0000	31324.	58264.	4784.	339.3	420.0	476.5	515.0	521.6	521.6	521.6	521.6	521.6	521.6	521.6
52.5000	31655.	58641.	4995.	337.3	418.3	475.0	514.3	520.5	520.5	520.5	520.5	520.5	520.5	520.5
53.0000	31983.	59017.	5204.	335.3	416.6	473.6	513.6	519.4	519.4	519.4	519.4	519.4	519.4	519.4
53.5000	32308.	59394.	5412.	333.3	414.8	472.1	512.9	518.3	518.3	518.3	518.3	518.3	518.3	518.3
54.0000	32630.	59767.	5622.	331.3	413.1	470.7	512.2	517.2	517.2	517.2	517.2	517.2	517.2	517.2
54.5000	32950.	60141.	5822.	329.3	411.4	469.2	511.5	516.1	516.1	516.1	516.1	516.1	516.1	516.1
55.0000	33264.	60514.	6022.	327.3	409.7	467.8	510.8	515.0	515.0	515.0	515.0	515.0	515.0	515.0
55.5000	33583.	60886.	6222.	325.3	407.9	466.4	510.1	513.9	513.9	513.9	513.9	513.9	513.9	513.9
56.0000	33906.	61257.	6422.	323.3	406.2	464.9	509.4	512.8	512.8	512.8	512.8	512.8	512.8	512.8
56.5000	34205.	61627.	6622.	321.3	404.5	463.5	508.7	511.7	511.7	511.7	511.7	511.7	511.7	511.7
57.0000	34515.	61996.	6822.	319.3	402.8	462.1	508.0	510.6	510.6	510.6	510.6	510.6	510.6	510.6
57.5000	34821.	62365.	7022.	317.3	401.1	460.7	507.3	509.5	509.5	509.5	509.5	509.5	509.5	509.5
58.0000	35125.	62733.	7222.	315.3	399.4	459.3	506.6	508.4	508.4	508.4	508.4	508.4	508.4	508.4
58.5000	35427.	63100.	7422.	313.3	397.7	457.9	505.9	507.3	507.3	507.3	507.3	507.3	507.3	507.3
59.0000	35728.	63466.	7596.	311.3	396.0	456.5	505.2	506.2	506.2	506.2	506.2	506.2	506.2	506.2
59.5000	36025.	63831.	7746.	309.3	394.3	455.1	504.5	505.1	505.1	505.1	505.1	505.1	505.1	505.1
60.0000	36322.	64195.	7975.	307.3	392.7	453.7	503.8	504.0	504.0	504.0	504.0	504.0	504.0	504.0
60.5000	36617.	64557.	8131.	305.3	391.0	452.3	503.1	502.9	502.9	502.9	502.9	502.9	502.9	502.9
61.0000	36916.	64918.	8311.	303.3	389.4	450.9	502.4	501.8	501.8	501.8	501.8	501.8	501.8	501.8
61.5000	37203.	64277.	8478.	301.3	387.9	449.5	501.7	500.7	500.7	500.7	500.7	500.7	500.7	500.7
62.0000	37485.	64634.	8632.	299.3	386.6	448.1	501.0	499.6	499.6	499.6	499.6	499.6	499.6	499.6
62.5000	37779.	64982.	8782.	297.3	385.0	446.8	500.3	498.5	498.5	498.5	498.5	498.5	498.5	498.5
63.0000	38051.	65331.	8927.	295.3	384.0	445.5	499.6	497.4	497.4	497.4	497.4	497.4	497.4	497.4
63.5000	38314.	65681.	9077.	293.3	382.8	444.2	498.9	496.3	496.3	496.3	496.3	496.3	496.3	496.3
64.0000	38577.	66031.	9203.	291.3	381.5	442.9	498.2	495.2	495.2	495.2	495.2	495.2	495.2	495.2
64.5000	38830.	66372.	9336.	289.3	380.5	441.7	497.5	494.1	494.1	494.1	494.1	494.1	494.1	494.1
65.0000	39083.	66713.	9464.	287.3	379.4	440.5	496.8	493.0	493.0	493.0	493.0	493.0	493.0	493.0
65.5000	39336.	67054.	9589.	285.3	378.4	439.3	496.1	491.9	491.9	491.9	491.9	491.9	491.9	491.9
66.0000	39589.	67395.	9709.	283.3	377.4	437.9	495.4	490.8	490.8	490.8	490.8	490.8	490.8	490.8
66.5000	39842.	67736.	9827.	281.3	376.4	437.0	494.7	489.7	489.7	489.7	489.7	489.7	489.7	489.7
67.0000	40095.	68077.	9946.	279.3	375.4	435.9	494.0	488.6	488.6	488.6	488.6	488.6	488.6	488.6
67.5000	40348.	68418.	10061.	277.3	374.4	434.8	493.3	487.5	487.5	487.5	487.5	487.5	487.5	487.5
68.0000	40601.	68759.	10176.	275.3	373.5	433.7	492.6	486.4	486.4	486.4	486.4	486.4	486.4	486.4
68.5000	40854.	69100.	10287.	273.3	372.6	432.7	491.9	485.3	485.3	485.3	485.3	485.3	485.3	485.3
69.0000	41107.	69441.	10398.	271.3	371.7	431.6	491.2	484.2	484.2	484.2	484.2	484.2	484.2	484.2
69.5000	41360.	69782.	10503.	269.3	370.9	430.6	490.5	483.1	483.1	483.1	483.1	483.1	483.1	483.1

SMUD RAPID COLDOWN

J. D. McFARLANE

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

DATE 04/27/78

TIME	EQUIV LIN. RAD	TH. IN.	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE 10	NODE 11
70.0000	39232.	63017.	-20554.	296.1	370.0	429.6	474.7	506.9	528.8	542.0	549.2	548.7	548.3	548.0	548.0
70.5000	39314.	62959.	-20651.	295.5	369.2	428.6	473.8	506.6	528.5	541.6	548.2	548.0	548.0	548.0	548.0
71.0000	39393.	62901.	-20750.	295.0	368.4	427.7	472.8	505.3	528.2	540.9	548.0	548.0	548.0	548.0	548.0
71.5000	39468.	62845.	-20852.	294.5	367.5	426.5	471.9	504.4	527.5	540.0	548.0	548.0	548.0	548.0	548.0
72.0000	39540.	62788.	-20952.	294.0	366.7	425.8	471.0	503.6	526.8	539.9	548.0	548.0	548.0	548.0	548.0
72.5000	39609.	62733.	-21054.	293.6	365.9	425.0	470.0	502.8	526.0	539.0	548.0	548.0	548.0	548.0	548.0
73.0000	39673.	62678.	-21107.	292.9	365.2	423.9	469.0	502.0	525.2	538.1	548.0	548.0	548.0	548.0	548.0
73.5000	39735.	62624.	-21150.	292.6	364.4	423.0	468.2	501.2	524.4	537.2	548.0	548.0	548.0	548.0	548.0
74.0000	39794.	62570.	-21194.	291.9	363.6	422.1	467.2	500.4	523.6	536.3	548.0	548.0	548.0	548.0	548.0
74.5000	39851.	62517.	-21236.	291.6	362.9	421.1	466.5	499.6	522.8	535.4	548.0	548.0	548.0	548.0	548.0
75.0000	39904.	62464.	-21275.	290.8	362.1	420.3	465.6	498.8	522.0	534.5	548.0	548.0	548.0	548.0	548.0
75.5000	39956.	62412.	-21314.	290.3	361.4	419.5	464.7	498.0	521.2	533.6	548.0	548.0	548.0	548.0	548.0
76.0000	40004.	62361.	-21354.	289.8	360.7	418.7	463.9	497.2	520.4	532.7	548.0	548.0	548.0	548.0	548.0
76.5000	40050.	62310.	-21391.	289.3	359.9	417.8	463.0	496.4	519.6	531.8	548.0	548.0	548.0	548.0	548.0
77.0000	40094.	62259.	-21422.	288.8	359.2	417.0	462.2	495.7	518.8	530.9	548.0	548.0	548.0	548.0	548.0
77.5000	40136.	62209.	-21451.	288.2	358.5	416.2	461.3	494.9	518.0	530.0	548.0	548.0	548.0	548.0	548.0
78.0000	40176.	62159.	-21478.	287.7	357.8	415.4	460.5	494.1	517.2	529.1	548.0	548.0	548.0	548.0	548.0
78.5000	40213.	62110.	-21493.	287.2	357.1	414.6	459.7	493.4	516.4	528.2	548.0	548.0	548.0	548.0	548.0
79.0000	40249.	62061.	-21505.	286.7	356.4	413.8	458.9	492.6	515.6	527.3	548.0	548.0	548.0	548.0	548.0
79.5000	40283.	62013.	-21517.	286.2	355.7	413.0	458.1	491.8	514.8	526.4	548.0	548.0	548.0	548.0	548.0
80.0000	40314.	61965.	-21526.	285.7	355.1	412.2	457.3	491.1	514.0	525.5	548.0	548.0	548.0	548.0	548.0
81.0000	40309.	61917.	-21532.	285.0	354.4	411.4	456.5	490.3	513.2	524.6	548.0	548.0	548.0	548.0	548.0
82.0000	40261.	61870.	-21537.	284.5	353.8	410.6	455.7	489.6	512.4	523.7	548.0	548.0	548.0	548.0	548.0
83.0000	40185.	61820.	-21542.	284.0	353.1	409.8	454.9	488.8	511.6	522.8	548.0	548.0	548.0	548.0	548.0
84.0000	40086.	61756.	-21545.	283.5	352.5	409.0	454.1	488.0	510.8	521.9	548.0	548.0	548.0	548.0	548.0
85.0000	39968.	61698.	-21547.	283.0	351.9	408.2	453.3	487.2	510.0	521.0	548.0	548.0	548.0	548.0	548.0
86.0000	39834.	61645.	-21548.	282.5	351.3	407.4	452.5	486.4	509.2	520.1	548.0	548.0	548.0	548.0	548.0
87.0000	39684.	61597.	-21549.	282.0	350.7	406.6	451.7	485.6	508.4	519.2	548.0	548.0	548.0	548.0	548.0
88.0000	39521.	61555.	-21549.	281.5	350.0	405.8	450.9	484.8	507.6	518.3	548.0	548.0	548.0	548.0	548.0
89.0000	39345.	61517.	-21549.	281.0	349.4	405.0	450.1	484.0	506.8	517.4	548.0	548.0	548.0	548.0	548.0
90.0000	39161.	61484.	-21547.	280.5	348.8	404.2	449.3	483.2	506.0	516.5	548.0	548.0	548.0	548.0	548.0
91.0000	38966.	61456.	-21544.	280.0	348.0	403.4	448.5	482.4	505.2	515.6	548.0	548.0	548.0	548.0	548.0
92.0000	38763.	61432.	-21540.	279.5	347.3	402.6	447.7	481.6	504.4	514.7	548.0	548.0	548.0	548.0	548.0
93.0000	38551.	61412.	-21535.	279.0	347.6	401.8	446.9	480.8	503.6	513.8	548.0	548.0	548.0	548.0	548.0
94.0000	38333.	61397.	-21529.	278.5	347.8	401.0	446.1	480.0	502.8	512.9	548.0	548.0	548.0	548.0	548.0
95.0000	38108.	61386.	-21522.	278.0	347.2	400.2	445.3	479.2	502.0	512.0	548.0	548.0	548.0	548.0	548.0
96.0000	37864.	61379.	-21514.	277.5	347.1	399.4	444.5	478.4	501.2	511.1	548.0	548.0	548.0	548.0	548.0
97.0000	37609.	61375.	-21505.	277.0	347.0	398.6	443.7	477.6	500.4	510.2	548.0	548.0	548.0	548.0	548.0
98.0000	37343.	61373.	-21495.	276.5	347.0	397.8	442.9	476.8	500.0	509.3	548.0	548.0	548.0	548.0	548.0
99.0000	37069.	61372.	-21485.	276.0	347.1	397.0	442.1	476.0	499.6	508.4	548.0	548.0	548.0	548.0	548.0

SMUD RAPID COOLDOWN

L. D. McKIM

A-89

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

DATE 04/27/78

TIME	EQUIV LIN. RAD	THEMAL STRESS T-SIDE	THEMAL STRESS O-SIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9	NODE10	NODE11
00.0000	36789.	50927.	299.6	347.3	392.7	432.3	464.0	489.7	489.7	506.5	516.5	519.7	519.7	519.7
01.0000	36503.	50366.	299.6	347.3	392.7	432.3	464.0	489.7	489.7	506.5	516.5	519.7	519.7	519.7
02.0000	36212.	49769.	300.0	347.6	391.2	429.0	460.5	485.8	485.8	502.0	511.0	514.9	514.9	514.9
03.0000	35916.	49197.	302.4	347.9	390.5	429.0	458.5	483.7	483.7	500.0	509.0	512.9	512.9	512.9
04.0000	35615.	48629.	304.4	348.2	389.1	426.4	457.0	481.5	481.5	498.5	507.5	510.9	510.9	510.9
05.0000	35311.	48065.	305.3	348.4	389.0	426.4	456.6	480.0	480.0	497.0	506.0	509.4	509.4	509.4
06.0000	35004.	47505.	307.1	349.0	389.0	425.4	455.4	478.7	478.7	495.7	504.7	508.1	508.1	508.1
07.0000	34693.	46949.	309.5	349.2	389.0	423.4	453.2	476.0	476.0	493.0	502.0	505.5	505.5	505.5
08.0000	34380.	46396.	307.1	349.7	389.0	423.4	452.1	474.5	474.5	491.5	500.5	504.0	504.0	504.0
09.0000	34064.	45848.	308.8	349.9	388.5	422.7	450.9	473.0	473.0	489.9	498.9	502.4	502.4	502.4
10.0000	33747.	45304.	309.5	349.9	388.5	422.7	449.8	471.5	471.5	488.5	497.5	501.0	501.0	501.0
11.0000	33421.	44722.	310.5	350.0	388.5	422.7	448.8	469.8	469.8	486.5	495.5	499.0	499.0	499.0
12.0000	33090.	44136.	311.5	350.0	387.7	421.1	447.7	467.5	467.5	484.2	493.2	496.7	496.7	496.7
13.0000	32756.	43555.	313.4	351.0	387.7	421.1	446.6	465.1	465.1	482.0	491.0	494.5	494.5	494.5
14.0000	32419.	42978.	315.0	351.0	387.7	420.9	445.5	463.0	463.0	480.0	489.0	492.5	492.5	492.5
15.0000	32079.	42405.	317.0	352.0	387.5	420.9	444.4	460.8	460.8	478.0	487.0	490.5	490.5	490.5
16.0000	31734.	41835.	319.0	352.0	387.5	420.9	443.3	458.6	458.6	476.0	485.0	488.5	488.5	488.5
17.0000	31395.	41269.	320.0	352.0	387.5	420.9	442.2	456.5	456.5	474.0	483.0	486.5	486.5	486.5
18.0000	31050.	40707.	321.0	352.0	387.4	420.9	441.1	454.4	454.4	472.0	481.0	484.5	484.5	484.5
19.0000	30705.	40149.	322.0	353.0	387.4	420.9	440.0	452.3	452.3	470.0	479.0	482.5	482.5	482.5
20.0000	30354.	39595.	324.0	353.0	387.4	420.9	438.9	450.2	450.2	468.0	477.0	480.5	480.5	480.5
21.0000	30012.	39046.	325.0	354.0	387.4	420.9	437.8	448.1	448.1	466.0	475.0	478.5	478.5	478.5
22.0000	29664.	38496.	327.0	354.0	387.4	420.9	436.7	446.0	446.0	464.0	473.0	476.5	476.5	476.5
23.0000	29316.	37952.	328.0	355.0	387.4	420.9	435.6	444.0	444.0	462.0	471.0	474.5	474.5	474.5
24.0000	28964.	37412.	329.0	355.0	387.4	420.9	434.5	442.0	442.0	460.0	469.0	472.5	472.5	472.5
25.0000	28621.	36875.	329.0	356.0	387.5	420.9	433.4	440.0	440.0	458.0	467.0	470.5	470.5	470.5
26.0000	28273.	36341.	327.0	356.0	387.5	420.9	432.3	437.9	437.9	456.0	465.0	468.5	468.5	468.5
27.0000	27925.	35811.	328.0	357.0	387.5	420.9	431.2	435.8	435.8	454.0	463.0	466.5	466.5	466.5
28.0000	27574.	35284.	330.0	357.0	387.5	420.9	430.1	433.8	433.8	452.0	461.0	464.5	464.5	464.5
29.0000	27231.	34760.	331.0	359.0	387.7	420.9	429.0	431.8	431.8	450.0	459.0	462.5	462.5	462.5
30.0000	26885.	34240.	331.0	359.0	387.7	420.9	427.9	429.7	429.7	448.0	457.0	460.5	460.5	460.5
31.0000	26539.	33722.	333.0	359.0	387.7	420.9	426.8	428.6	428.6	446.0	455.0	458.5	458.5	458.5
32.0000	26194.	33204.	333.0	360.0	388.0	420.9	425.7	427.5	427.5	444.0	453.0	456.5	456.5	456.5
33.0000	25850.	32697.	336.0	360.0	388.0	420.9	424.6	426.4	426.4	442.0	451.0	454.5	454.5	454.5
34.0000	25507.	32190.	336.0	361.0	388.0	420.9	423.5	425.3	425.3	440.0	449.0	452.5	452.5	452.5
35.0000	25162.	31683.	337.0	362.0	388.0	420.9	422.4	424.2	424.2	438.0	447.0	450.5	450.5	450.5
36.0000	24823.	31183.	339.0	362.0	388.0	420.9	421.3	423.1	423.1	436.0	445.0	448.5	448.5	448.5
37.0000	24482.	30685.	340.0	363.0	388.0	420.9	420.2	422.0	422.0	434.0	443.0	446.5	446.5	446.5
38.0000	24143.	30189.	340.0	363.0	388.0	420.9	419.1	420.9	420.9	432.0	441.0	444.5	444.5	444.5
39.0000	23804.	29696.	340.0	363.0	388.0	420.9	418.0	420.0	420.0	430.0	439.0	442.5	442.5	442.5

SMUD RAPID COOLDO

L. D. McKim

A-90

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE FULL CERTIFICATION 91232 REV 4 12-15-74 04/27/78 14.02:50 PAGE 15
FULL CERTIFICATION

SMUD REACTOR TRIP TEMPERATURE DISTRIBUTION OUTLET NOZZLE

DATE 04/27/78

TIME 140.0000
EQUIV RAD 23467.
THERMAL STRESS INSIDE 29207.
THERMAL STRESS OUTSIDE 341.7

NODE 1 341.7 NODE 2 344.5 NODE 3 389.1 NODE 4 413.0 NODE 5 434.5 NODE 6 452.1 NODE 7 465.1 NODE 8 473.0 NODE 9 475.6 NODE 10 475.6

SMUD RAPID COOLDOWN

D. McKIM

A-91

CONTRACT NO. 595-7072 620-0011		DOCUMENT COMMENT FORM	RELEASED BY <i>J.M. Burnett</i> 11/8/78		
SUPPLIER B&W			TASK ENGINEER DATE		
PO. NO.		PREPARED BY: <i>J.M. Burnett</i>	11/8/78	REL. DATE PAGE 11-17-78 1 OF 1	
		NAME	DATE		

PART/TGS	B&W DOC. NO.	DOCUMENT TITLE	CUSTOMER/ SUPPLIER DOC. NO.	STATUS	RRL NUMBER
59-01-001		SMUD COOLDOWN INCIDENT, JUSTIFICATION OF PRESSURFER FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT (RANCHO SECO), B&W CONTRACT 620-0011-59	620-0011- 59	APPROVED	N/A
33 0276 00					

DISTRIBUTION:

- J.M. BURNETT (W/1 ATTACH)
- R.R. SCHAEFER (W/1 ATTACH) - MTV
- J.J. KELLY (W/6 ATTACH)
- J.T. JANIS (W/0 ATTACH)

SMUD COOLDOWN INCIDENT
JUSTIFICATION OF PRESSURIZER
FOR
SACRAMENTO MUNICIPAL UTILITY DISTRICT
RANCHO SECO

B&W CONTRACT NO: 620-0011-59

PREPARED BY: John R. Strohman / associate engr. / 6-5-78

CHECKED BY: David M. Duffin / associate Eng. / 6-6-78

APPROVED BY: R. R. Schaefer / Senior Eng. / 6-7-78

Mt. Vernon Engineering
The Babcock & Wilcox Company
Mt. Vernon, Indiana

B & W DOCUMENT NUMBER

33 0276 00

TABLE OF CONTENTS

	<u>PAGE NO.</u>
Introduction.....	1
Discussion.....	1
Results.....	2
Conclusion.....	3
References.....	4
Transient Description.....	A-1 Thru A-6
Pressurizer Spray Nozzle Justification	B-1 Thru B-5

APPENDIX

Spray Nozzle, 91213 Output.....	Y-1 Thru Y-13
---------------------------------	---------------

INTRODUCTION:

The purpose of this discussion is to provide an assessment of the affect that the accelerated cooldown, experienced at SMUD, had upon the Pressurizer and to determine what analytical work should be done, if any, to justify the structural integrity of the Pressurizer and to show that the Pressurizer is still in accordance with Section III of the ASME Boiler and Pressure Vessel Code.

This rapid cooldown transient is being analyzed since it was not defined in the Reactor Coolant System Functional Specification, CS(F)-3-92/NSS-11, and was therefore not analyzed in the Pressurizer Stress Report, 620-0011-59.

DISCUSSION:

In order to determine what thermal/pressure transient the Pressurizer was subjected to, it is necessary to look at the sequence of events and descriptive curves contained in reference D-1.

From reference D-1, it can be seen that the reactor coolant pressure transient consists of a ΔP of approximately 900 psi due to a pressure drop from 2400 psi to 1500 psi in approximately 15 minutes. The reactor coolant thermal transient describes an accelerated temperature drop from 590°F to 280°F in approximately 1 hour. However, this thermal transient is not applicable when considering the bulk fluid temperature of the Pressurizer. The bulk fluid temperature may be determined from standard steam tables using the pressure transient for the accelerated cooldown since the Pressurizer is considered to remain at saturation. Thus, at saturation a temperature of =660°F exists for a pressure of 2400 psi while a temperature of =600°F corresponds to a pressure of 1500 psi.

Therefore, it is concluded that the Pressurizer was not subjected to the accelerated thermal cooldown transient shown for the reactor coolant.

Comparison of the thermal/pressure transient experienced by the bulk fluid of the Pressurizer with the thermal/pressure transients described in the Functional Specification, reference B-5, reveals that a more severe condition is depicted by Transient 9, "Rapid Depressurization".

Transient 9 describes a thermal/pressure transient that consists of a pressure drop from 2200 psi to 800 psi and a temperature drop from 650°F to 520°F with both conditions occurring simultaneously over a 15 minute period.

DISCUSSION: (Continued)

Note that, with the exception of the Pressurizer Spray Nozzle, none of the cumulative usage factors of the components of the pressurizer are increased by analyzing an additional cycle of "Rapid Depressurization". However, for the Pressurizer Spray Nozzle a new cumulative usage factor has been calculated for the SMUD accelerated cooldown transient.

RESULTS:

The following is a tabulation of the original and new cumulative usage factors for the affected pressurizer components:

<u>LOCATION</u>	<u>ORIGINAL C.U.F.</u>	<u>NEW C.U.F.</u>
Pressurizer Spray Nozzle	.330	.345

CONCLUSION:

It has been concluded that the Pressurizer still meets all of the requirements of the ASME Boiler and Pressure Vessel Code, Section III; and that the accelerated cooldown of the system does not reduce any of the number of cycles originally designed for and defined in the Functional Specification, Ref. B-5.

REFERENCES:

A. Drawings

1. B&W Drawing #135483E7 - Pressurizer List of Material
2. B&W Drawing #135493E5 - 4" Spray Nozzle Details

B. Codes, Specifications, and Reports

1. USAS B31.7 - 1969.
2. ASME Boiler and Pressure Vessel Code, Section III, 1965 Edition thru Summer 1967 Addenda.
3. "Design Analysis of 4" SCH 120 Spray Nozzle, Report No. 9, prepared by R.C. Bodell, dated December 1971.
4. "Pressurizer Stress Report for SMUD, Rancho Seco #1, B&W contract #620-0011-59, SMUD Order #3075, dated August 1974.
5. B&W Reactor Coolant System Functional CS(F)3-92/NSS-11.

C. Computer Programs

1. B&W Program #91213 - Slab Temperature Distribution.

D. General

1. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-4-78.
2. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-7-78.
3. Letter from R.W. Moore to J.M. Burnett, subject - Pressurizer Spray Following Rapid SMUD Cooldown of 3-20-78, 620-0011-50/59, dated 5-23-78.
4. Letter from J. M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4/20/78.

- A -

TRANSIENT
DESCRIPTION

The following pages of this section contain a description of the sequence of events of the SMUD Cooldown Incident. Also contained herein is a time-temperature and time-pressure plot of the reactor coolant system which is used in the justification of the cooldown.

SEQUENCE OF EVENTS - 04:25(AM) to 05:34(AM)
(TAKEN FROM REF D-2)

<u>TIME</u>	<u>EVENT</u>
4:25:35	- Lost NNI power supply cabinets 5,6, & 7 (B&W Channel "Y")
	- This caused a loss of T _H signals to the ICS. BTU limits ran back feedwater, resulting in a loss of feedwater (actual Rx power was 72%).
4:25:46	- Reactor trip on high pressure, turbine trip on interlock.
	- Pressurizer code relief setting was known to be low (=2225 psig). The electromatic relief was isolated due to previous leakage problems. The data indicates primary pressure went =2400 psig =>code relief valve lifted.
4:26:17	- Operator starts HPI pump "B" to maintain pwr. level.
4:28:23	- Operator stops HPI pump "B".
4:30	- OTSG "B" goes dry. Data indicates that "A" OTSG probably also went dry.
4:34:25	- RC pressure =1900 PSI (low pressure trip set-point).
4:34	- Operator increases speed of a MFP and feeds "A" OTSG. This starts RCS on pressure and temperature decrease.
4:37:16	- SFAS actuation at 1600 psig This starts HPI, LPI and initiates aux. feed. Aux. FW valves are opened to full open position. The system makes no automatic attempt to control steam generator water level.
4:40	- RC pressure at 1475 psig. It starts to recover from this point due to HPI. T _{ave} = 528°F.
4:43:56	- "A" HPI pump secured.
4:46:09	- LPI secured.
4:49:54	- "A" HPI initiated. From this point on, the operator started and stopped HPI pumps as necessary to maintain pressurized level.

<u>TIME</u>	<u>EVENT</u>
4:51:25	- Secured RCP-D ($T_{ave} = 435^{\circ}\text{F}$) This reduced #RCP's to three
4:57:27	- OTSG "A" water level - 599.7" Speculate that =2 ft of tubes are not flooded (at top) due to steam line arrangement.
5:00:00	- Hourly computer log printout Steam temp 380°F (OTSG "B") Steam pressure 171 psig (OTSG "B") Assuming $T_{ave} = T_{sat} \Rightarrow T_{ave} = 380^{\circ}\text{F}$
5:13:47	- OTSG "B" level - 599.1"
5:34	- Power restored to NNI cabinets 5, 6 & 7 $T_{ave} = 285^{\circ}\text{F}$ RCS Pressure = 2000 psig Both OTSG full level ranges pegged high * Operator begins to reduce RC pressure using Pzr spray. Operator stops electric aux FW pump.

(TAKEN FROM REF D-2)

* SEE PG A-5 + A-6

(TAKEN FROM REF D-1)

COLD LEG RC TEMPERATURE, °F

RC PRESSURE, PSIG




FIG. 1

A-4

NO. 2 REEFER & ESTERCO MIM-811

46 1470

THE BASCOCK & WILCOX COMPANY
POWER GENERATION GROUP

TAKEN FROM
REF D-3

To
J.M. Burnett, RCS Components

From
R.W. Moore, Control Analysis (2648)

BDS 643.5

Cust.
SMUD

File No.
or Ref.

Subj. Pressurizer Spray Following Rapid SMUD Cooldown
of 3/20/78

Date
May 23, 1978

This letter is cover and contains the subject only.

Attached please find a description of spray line variables for the pressurizer spray down following the rapid cooldown at SMUD on 3/20/78. The RCS pressure may be taken to be saturation pressure for the stated pressurizer temperature. The source of spray water was taken from the cold leg (not auxiliary spray).

RWH/lp

PRESSURIZER SPRAY FLOW AND TEMP.
FOLLOWING SMUD RCS COOLDOWN TRANSIENT OF 3/20/78

<u>Time</u> <u>Hr:Min</u>	<u>Elapsed</u> <u>Time,</u> <u>Min.</u>	<u>Pressurizer</u> <u>Steam, Temp.,</u> <u>F</u>	<u>Spray Nozzle</u> <u>Fluid Temp.,</u> <u>F</u>	<u>Spray</u> <u>Rate</u> <u>GPM</u>
5:34	0.	637	280	1.0
5:56	22.0	633	280	1.0
5:56.1	22.1	633	280	150.
5:59.5	25.5	613	280	150.
5:59.6	25.6	613	280	1.0
6:05	31.0	613	280	1.0
6:05.1	31.1	613	280	25.
6:07	33.0	611.5	280	25.
6:07.1	33.1	611.5	280	1.0
6:15	41.0	610	280	1.0
6:15.1	41.1	610	280	20.
6:29	55.0	600	280	20.
6:29.1	55.1	600	280	1.0
7:05	91.0	591	280	1.0

TAKEN FROM REF D-3

FOLLOWING ARE THE CHANGES REQUESTED BY 3/2/57

Part No.	Description	Quantity	Unit Price	Total Price
610		100		20
611		100		20
612		100		20
613		100		20
614		100		20
615		100		20
616		100		20
617		100		20
618		100		20
619		100		20
620		100		20
621		100		20
622		100		20
623		100		20
624		100		20
625		100		20
626		100		20
627		100		20
628		100		20
629		100		20
630		100		20

- B -

PRESSURIZER
SPRAY NOZZLE

PRESSURIZER SPRAY NOZZLE

PRIMARY + SECONDARY STRESS

THE MAXIMUM PRI + SEC STRESS OCCURS AT THE INSIDE SURFACE OF THE SPRAY NOZZLE AT THE BEGINNING OF THE INTERNAL PIPING.

- $S_D = 55.4$ KSI - REF PG B-16-17 OF
 - - - - - THE SPRAY NOZZLE
 - - - - - STRESS REPORT (REF B-3)

TO THIS S_D VALUE WILL BE ADDED AN ADDITIONAL RADIAL GRADIENT AND DISCONTINUITY STRESS.

$$\sigma_{R.G.} = \frac{1}{2(1-\nu)} E \alpha \Delta T_1 = \frac{1}{2(1-\nu)} (29.67 \times 10^6) (6.12 \times 10^{-6}) (24.1)$$

$$\sigma_{R.G.} = 3.1 \text{ KSI}$$

SEE CALCULATION OF ΔT_1 ON PG B-5

REF PG V-13

$$\sigma_{DISCONT} = C_3 E \alpha |\alpha_2 T_2 - \alpha_1 T_1| = 1.8 (30.5 \times 10^6) [(7.13 \times 10^{-6}) (63) - (6.12 \times 10^{-6}) (65)]$$

$$= 28.6 \text{ KSI}$$

THE FOLLOWING ASSUMPTIONS HAVE BEEN MADE. $C_3 = 1.8$ FOR A BRANCH CONNECTION. THE ΔT BETWEEN THE PRESSURIZER SHELL

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET B-1 OF

AND THE INTERNAL EXTENSION IS 19° .
 THIS IS ASSUMING THE PRESSURIZED
 SHELL IN THE AREA OF THE NOZZLE
 REMAINS AT 650°F WHILE THE AVERAGE
 TEMP OF THE INTERNAL EXTENSION
 IS 631°F , REF PG Y-13.

$$S_n = 55.4 + 3.1 + 28.6 = 87.1 \text{ KSI} > 3S_m = 51.0 \text{ KSI}$$

$S_p = 58.2 \text{ KSI}$ REF PG C-13-1 OF THE
 SPRAY NOZZLE STRESS REPORT (REF B-3)

TO THIS S_p VALUE WILL BE ADDED AN
 ADDITIONAL RADIAL GRADIENT AND DISCONTINUITY
 STRESS.

$$\begin{aligned} \sigma_{\text{RIG}} &= \frac{1}{2(1-\nu)} K_3 E \alpha \Delta T_1 + \frac{1}{1-\nu} E \alpha \Delta T_2 = 1.7(3.1) + \frac{1}{1-\nu} (29.27 \times 10^6) 6.12 \times 10^{-6} (.6) \\ &= 5.3 + .2 = 5.5 \text{ KSI} \\ &(\Delta T_2 = .6 \text{ REF PG B-5}) \end{aligned}$$

$$\sigma_{\text{DISCONT}} = C_3 K_3 E \alpha |\Delta T_2 - \Delta T_1| = 1.7(28.6) = 48.6 \text{ KSI}$$

$$S_p = 58.2 + 5.5 + 48.6 = 112.3 \text{ KSI}$$

USING THE SIMPLIFIED ELASTIC PLASTIC

$$K_2 = 1.0 + \frac{1-\nu}{2(3-1)} \left(\frac{S_p}{S_m} - 1 \right) = 2.4$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET 5-2 OF

$$S_{ALT} = K_c \frac{S}{E} = 2.4 \left(\frac{112.3}{2} \right)$$

$$= 135.6 \text{ KSI}$$

$$n_1 = 3 \text{ (REF PS A-6)}$$

$$N_1 = 200$$

$$U_1 = \frac{S}{N_1} = \frac{S}{200} = .015$$

ADDING U_1 TO THE PREVIOUSLY
CALCULATED U , REF PS C-13-1

$$U_{TOT} = .330 + .015 = .345 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET

B-3

OF

PRESSURIZER SPRAY NOZZLE THERMAL GRADIENT CALCULATIONS

$$T_{AVER} = \frac{1}{L} \int_{-L/2}^{L/2} T(Y) dy$$

$$\Delta T_1 = \frac{12}{L^2} \int_{-L/2}^{L/2} Y T(Y) dy$$

$$\Delta T_2 = \text{MAX} \begin{cases} |T_0 - T| - \frac{1}{2} |\Delta T_1| \\ |T_i - T| - \frac{1}{2} |\Delta T_1| \end{cases}$$

SIMPSON'S RULE IS USED TO EVALUATE THE INTEGRALS LISTED ABOVE FOR TIME 0540, SEE PRESSURIZER SPRAY NOZZLE THERMAL DISTRIBUTION PROGRAM PG Y-13

SIMPSON'S RULE $\int_{x_0}^{x_2} f(x) dx = \frac{h}{3} [f_0 + 4f_1 + f_2]$

$$h = \frac{L}{4} = .1171$$

$$T = \frac{1}{4(.25)} (.1171) \frac{1}{3} [618.8 + 4(625.4) + 2(631.7) + 4(637.7) + 643.4]$$

REF PG Y-13

$$= 631.4 \text{ } ^\circ\text{F}$$

Y	T(Y) REF PG Y-13	YT(Y)
- 1/4 IN	618.8	- 309.4 t
- 1/4 IN	625.4	- 156.4 t
0	631.7	0
OUTLET	637.7	159.4 t
INLET	643.3	321.7 t

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET B-4 OF

$$\Delta T_1 = \frac{12}{(4685)^2} (1171) \frac{1}{3} (-145.0 - 4(73.3) + 2(0) + 4(74.7) + 150.2)$$

$$= 24.1$$

$$\Delta T_2 = \text{MAX} \begin{cases} |1643.3 - 631.4| - \frac{1}{2}(24.1) = -1.2 \\ |1618.8 - 631.4| - \frac{1}{2}(24.1) = .6 \end{cases}$$

$$\therefore \Delta T_2 = .6$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET 3-5 OF

APPENDIX

SLAB TEMPERATURE DISTRIBUTION PROGRAM 91213

PRESSURIZER SPRAY NOZZLE, SHUD COOLDOWN INCIDENT

TIME (12) FOR THIS RUN IS INPUT IN SECONDS

NOTE * * * FLUID FOR THIS RUN IS ON THE INSIDE AND OUTSIDE SURFACES * * *

INSIDE RADIUS (TO BASE METAL) OF SLAB RI = 1.8125 INCHES REF A-2
RADIAL THICKNESS OF SLAB (BASE METAL) SLHT = .4685 INCHES II II
CLADDING THICKNESS CLAD = 0.0000 INCHES
AXIAL THICKNESS OF SLAB YY = 6.0000 INCHES
NUMBER OF CYCLES Q = 1
STARTING TIME FOR THIS RUN TIME = 0.0000 HOURS
STARTING ITERATION FOR THIS RUN ITER = 0
STARTING TEMPERATURE OF SOLID BLOCKS STEMP = 650.0 DEGREES
AVERAGE TEMPERATURE OF SOLID BLOCKS BT = 650.0 DEGREES

Y-1

1 PHRESSURIZER SPRAY NOZZLE * SMUD COOLDOWN INCIDENT
2 **** FULL CERTIFICATION ****

3

91213 REV 2 12-15-74 05/23/78 14-00:24 PAGE 3
4 **** FULL CERTIFICATION **** 501CC53

5 SLAB TEMPERATURE DISTRIBUTION PROGRAM 91213

6 PHRESSURIZER SPRAY NOZZLE * SMUD COOLDOWN INCIDENT

7 REF PJ B-3-2 OF B-3
8 FILM COEFFICIENTS - INSIDE AND OUTSIDE - PER CYCLE

9 (0.0 INDICATES INSULATION)

10 INSIDE OUTSIDE

11 .2900000E+02 .2000000E+04

12 EQUATIONS WILL BE RECALCULATED AT TIMES

13 1.06111

14 OUTPUT PRINTOUT DATA

15 PRINTOUT LIMIT 1 WILL BE TO TIME 1.3333 IN INCREMENTS OF .02417

2-2

SLAB TEMPERATURE DISTRIBUTION PROGRAM 91213
 PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

REF PS A-4

POINT NO.	1	TYPE	1																	
TIME	0.00000	.80333	.16667	.25000	.33333	.66667	1.00000	1.33333	9.00000											
TEMP	570.00000	570.00000	590.00000	590.00000	525.00000	380.00000	300.00000	280.00000	0.00000											

POINT NO.	7	TYPE	1																	
TIME	0.00000	1.33333	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
TEMP	650.60000	650.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000

TEMPERATURE PER NODE AT START OF RUN

TIME	1(1)	1(3)	1(4)	1(5)	1(6)	1(7)
570.0	650.0	650.0	650.0	650.0	650.0	650.0

NOTE: P P P TEMPERATURES 1(1) AND 1(7) ARE FLUID TEMPERATURES

POINT NO.	K	COEFFICIENT INSIDE	MODE	COEFFICIENT OUTSIDE	MODE	COEFFICIENT OF POINT NO	MODE
1	0	0.000	3	0.000	3	1.000	3
2	0	0.180	3	0.000	3	0.000	3
3	0	0.480	3	0.000	3	0.000	3
4	0	0.800	3	0.000	3	0.000	3
5	0	0.800	3	0.000	3	0.000	3
6	0	0.000	3	0.000	3	0.000	3

DELTA THETA = .1772E-03 HOURS/ITERATION BASED ON BLOCK 3

SLAB TEMPERATURE DISTRIBUTION
 PHESSUMIZER SPRAY NOZZLE, SMUD COOLDOWN INCIDENT

TIME FIG 1 PG A-4
0420

ITERATION	1	2	3	4	5	6	7	8	TIME
29	10.00	55.11	64.53	647.52	649.74	648.88	650.00	0.00	00037
71	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00035
94	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00102
118	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00107
142	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00206
166	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00232
190	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00341
214	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00376
238	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00416
262	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00485
286	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00512
310	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00520
334	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00547
358	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00652
382	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00669
406	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00794
430	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00835
454	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00871
478	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00930
502	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00957
526	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	00993
550	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01042
574	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01091
598	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01140
622	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01189
646	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01238
670	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01287
694	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01336
718	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01385
742	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01434
766	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01483
790	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01532
814	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01581
838	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01630
862	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01679
886	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01728
910	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01777
934	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01826
958	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01875
982	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01924
1006	10.00	64.53	644.77	646.00	647.54	648.88	650.00	0.00	01973

SLAR TEMPERATURE DISTRIBUTION
 PRESSURIZER SPRAY NOZZLE + SMUD COOLDOWN INCIDENT

ITERATION	1	2	3	4	5	6	7	8	TIME
001	000	000	000	000	000	000	000	000	000
002	000	000	000	000	000	000	000	000	000
003	000	000	000	000	000	000	000	000	000
004	000	000	000	000	000	000	000	000	000
005	000	000	000	000	000	000	000	000	000
006	000	000	000	000	000	000	000	000	000
007	000	000	000	000	000	000	000	000	000
008	000	000	000	000	000	000	000	000	000
009	000	000	000	000	000	000	000	000	000
010	000	000	000	000	000	000	000	000	000
011	000	000	000	000	000	000	000	000	000
012	000	000	000	000	000	000	000	000	000
013	000	000	000	000	000	000	000	000	000
014	000	000	000	000	000	000	000	000	000
015	000	000	000	000	000	000	000	000	000
016	000	000	000	000	000	000	000	000	000
017	000	000	000	000	000	000	000	000	000
018	000	000	000	000	000	000	000	000	000
019	000	000	000	000	000	000	000	000	000
020	000	000	000	000	000	000	000	000	000
021	000	000	000	000	000	000	000	000	000
022	000	000	000	000	000	000	000	000	000
023	000	000	000	000	000	000	000	000	000
024	000	000	000	000	000	000	000	000	000
025	000	000	000	000	000	000	000	000	000
026	000	000	000	000	000	000	000	000	000
027	000	000	000	000	000	000	000	000	000
028	000	000	000	000	000	000	000	000	000
029	000	000	000	000	000	000	000	000	000
030	000	000	000	000	000	000	000	000	000
031	000	000	000	000	000	000	000	000	000
032	000	000	000	000	000	000	000	000	000
033	000	000	000	000	000	000	000	000	000
034	000	000	000	000	000	000	000	000	000
035	000	000	000	000	000	000	000	000	000
036	000	000	000	000	000	000	000	000	000
037	000	000	000	000	000	000	000	000	000
038	000	000	000	000	000	000	000	000	000
039	000	000	000	000	000	000	000	000	000
040	000	000	000	000	000	000	000	000	000
041	000	000	000	000	000	000	000	000	000
042	000	000	000	000	000	000	000	000	000
043	000	000	000	000	000	000	000	000	000
044	000	000	000	000	000	000	000	000	000
045	000	000	000	000	000	000	000	000	000
046	000	000	000	000	000	000	000	000	000
047	000	000	000	000	000	000	000	000	000
048	000	000	000	000	000	000	000	000	000
049	000	000	000	000	000	000	000	000	000
050	000	000	000	000	000	000	000	000	000

MESSURIZER SPRAY NOZZLE, SHUD COOLDOWN INCIDENT
 FULL CERTIFICATION
 PROGRAM 91213

MESSURIZER SPRAY NOZZLE, SHUD COOLDOWN INCIDENT

ITERATION	1	2	3	4	5	6	7	8	TIME
001	665	634	630	641	644	646	650	650	446260
002	665	634	637	640	643	646	650	650	446669
003	665	634	637	640	643	646	650	650	447078
004	665	634	637	640	643	646	650	650	447487
005	665	634	637	640	643	646	650	650	447896
006	665	634	637	640	643	646	650	650	448305
007	665	634	637	640	643	646	650	650	448714
008	665	634	637	640	643	646	650	650	449123
009	665	634	637	640	643	646	650	650	449532
010	665	634	637	640	643	646	650	650	449941
011	665	634	637	640	643	646	650	650	450350
012	665	634	637	640	643	646	650	650	450759
013	665	634	637	640	643	646	650	650	451168
014	665	634	637	640	643	646	650	650	451577
015	665	634	637	640	643	646	650	650	451986
016	665	634	637	640	643	646	650	650	452395
017	665	634	637	640	643	646	650	650	452804
018	665	634	637	640	643	646	650	650	453213
019	665	634	637	640	643	646	650	650	453622
020	665	634	637	640	643	646	650	650	454031
021	665	634	637	640	643	646	650	650	454440
022	665	634	637	640	643	646	650	650	454849
023	665	634	637	640	643	646	650	650	455258
024	665	634	637	640	643	646	650	650	455667
025	665	634	637	640	643	646	650	650	456076
026	665	634	637	640	643	646	650	650	456485
027	665	634	637	640	643	646	650	650	456894
028	665	634	637	640	643	646	650	650	457303
029	665	634	637	640	643	646	650	650	457712
030	665	634	637	640	643	646	650	650	458121
031	665	634	637	640	643	646	650	650	458530
032	665	634	637	640	643	646	650	650	458939
033	665	634	637	640	643	646	650	650	459348
034	665	634	637	640	643	646	650	650	459757
035	665	634	637	640	643	646	650	650	460166
036	665	634	637	640	643	646	650	650	460575
037	665	634	637	640	643	646	650	650	460984
038	665	634	637	640	643	646	650	650	461393
039	665	634	637	640	643	646	650	650	461802
040	665	634	637	640	643	646	650	650	462211
041	665	634	637	640	643	646	650	650	462620
042	665	634	637	640	643	646	650	650	463029
043	665	634	637	640	643	646	650	650	463438
044	665	634	637	640	643	646	650	650	463847
045	665	634	637	640	643	646	650	650	464256
046	665	634	637	640	643	646	650	650	464665
047	665	634	637	640	643	646	650	650	465074
048	665	634	637	640	643	646	650	650	465483
049	665	634	637	640	643	646	650	650	465892
050	665	634	637	640	643	646	650	650	466301

PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT FULL CERTIFICATION PROGRAM 91213 SLAR TEMPERATURE DISTRIBUTION

PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

ITERATION	1	2	3	4	5	6	7	8	TIME
1	55.00	210.00	00.00	03.25	640.00	644.00	650.00	00.00	87094
2	55.00	225.00	00.00	03.25	640.00	644.00	650.00	00.00	87150
3	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87192
4	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87173
5	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87200
6	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87208
7	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87244
8	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87252
9	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87279
10	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87319
11	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87323
12	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87350
13	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87358
14	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87404
15	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87409
16	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87502
17	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87509
18	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87538
19	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87599
20	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87607
21	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87713
22	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87735
23	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87812
24	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87873
25	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87913
26	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	87958
27	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	88043
28	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	88058
29	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	88126
30	55.00	224.00	00.00	03.25	640.00	644.00	650.00	00.00	88169

SLAB TEMPERATURE DISTRIBUTION SMUD COOLDOWN INCIDENT

ITERATION	INSIDE FLUID	3	4	5	6	7	8	TIME
6940	6020	63	63	63	64	65	66	23.333
6967	6020	63	63	63	64	65	66	23.333
7011	6020	63	63	63	64	65	66	23.333
7054	6020	63	63	63	64	65	66	23.333
7108	6020	63	63	63	64	65	66	23.333
7151	6020	63	63	63	64	65	66	23.333
7198	6020	63	63	63	64	65	66	23.333
7242	6020	63	63	63	64	65	66	23.333
7292	6020	63	63	63	64	65	66	23.333
7342	6020	63	63	63	64	65	66	23.333
7392	6020	63	63	63	64	65	66	23.333
7443	6020	63	63	63	64	65	66	23.333
7493	6020	63	63	63	64	65	66	23.333
7546	6020	63	63	63	64	65	66	23.333
7603	6020	63	63	63	64	65	66	23.333

TIME 0540, FIG 1 PG A-4

CONTRACT NO. 595-7072 620-0011		DOCUMENT COMMENT FORM		RELEASED BY <i>J.M. Burnett</i> 11/8/78 DATE	
SUPPLIER B&W		PREPARED BY: <i>J.M. Burnett</i> 11/8/78 NAME DATE		TASK ENGINEER	
PO. NO.				REL. DATE 11-17-78	PAGE 1 OF 1

PART/TGS	B&W DOC. NO.	DOCUMENT TITLE	CUSTOMER/ SUPPLIER DOC. NO.	STATUS	RRL NUMBER
59-01-001	33 0276 00	SMUD COOLDOWN INCIDENT, JUSTIFICATION OF PRESSURIZER FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT (RANCHO SECO), B&W CONTRACT 620-0011-59	620-0011- 59	APPROVED	N/A

DISTRIBUTION:

- J.M. BURNETT (W/1 ATTACH)
- R.R. SCHAEFER (W/1 ATTACH) - MTV
- J.J. KELLY (W/6 ATTACH)
- J.T. JANIS (W/0 ATTACH)

SMUD COOLDOWN INCIDENT
JUSTIFICATION OF PRESSURIZER
FOR
SACRAMENTO MUNICIPAL UTILITY DISTRICT
RANCHO SECO

B&W CONTRACT NO: 620-0011-59

PREPARED BY: John W. Studhouse / associate eng. / 6-5-78

CHECKED BY: David M. Duffair / associate Eng. / 6-6-78

APPROVED BY: R.P. Schaefer / Senior Eng. / 6-7-78

Mt. Vernon Engineering
The Babcock & Wilcox Company
Mt. Vernon, Indiana

B & W DOCUMENT NUMBER

33 0276 00

TABLE OF CONTENTS

	<u>PAGE NO.</u>
Introduction.....	1
Discussion.....	1
Results.....	2
Conclusion.....	3
References.....	4
Transient Description.....	A-1 Thru A-6
Pressurizer Spray Nozzle Justification.....	B-1 Thru B-5

APPENDIX

Spray Nozzle, 91213 Output.....	Y-1 Thru Y-13
---------------------------------	---------------

INTRODUCTION:

The purpose of this discussion is to provide an assessment of the affect that the accelerated cooldown, experienced at SMUD, had upon the Pressurizer and to determine what analytical work should be done, if any, to justify the structural integrity of the Pressurizer and to show that the Pressurizer is still in accordance with Section III of the ASME Boiler and Pressure Vessel Code.

This rapid cooldown transient is being analyzed since it was not defined in the Reactor Coolant System Functional Specification, CS(F)-3-92/NSS-11, and was therefore not analyzed in the Pressurizer Stress Report, 620-0011-59.

DISCUSSION:

In order to determine what thermal/pressure transient the Pressurizer was subjected to, it is necessary to look at the sequence of events and descriptive curves contained in reference D-1.

From reference D-1, it can be seen that the reactor coolant pressure transient consists of a ΔP of approximately 900 psi due to a pressure drop from 2400 psi to 1500 psi in approximately 15 minutes. The reactor coolant thermal transient describes an accelerated temperature drop from 590°F to 280°F in approximately 1 hour. However, this thermal transient is not applicable when considering the bulk fluid temperature of the Pressurizer. The bulk fluid temperature may be determined from standard steam tables using the pressure transient for the accelerated cooldown since the Pressurizer is considered to remain at saturation. Thus, at saturation a temperature of =660°F exists for a pressure of 2400 psi while a temperature of =600°F corresponds to a pressure of 1500 psi.

Therefore, it is concluded that the Pressurizer was not subjected to the accelerated thermal cooldown transient shown for the reactor coolant.

Comparison of the thermal/pressure transient experienced by the bulk fluid of the Pressurizer with the thermal/pressure transients described in the Functional Specification, reference B-5, reveals that a more severe condition is depicted by Transient 9, "Rapid Depressurization".

Transient 9 describes a thermal/pressure transient that consists of a pressure drop from 2200 psi to 800 psi and a temperature drop from 650°F to 520°F with both conditions occurring simultaneously over a 15 minute period.

DISCUSSION: (Continued)

Note that, with the exception of the Pressurizer Spray Nozzle, none of the cumulative usage factors of the components of the pressurizer are increased by analyzing an additional cycle of "Rapid Depressurization". However, for the Pressurizer Spray Nozzle a new cumulative usage factor has been calculated for the SMUD accelerated cooldown transient.

RESULTS:

The following is a tabulation of the original and new cumulative usage factors for the affected pressurizer components:

<u>LOCATION</u>	<u>ORIGINAL C.U.F.</u>	<u>NEW C.U.F.</u>
Pressurizer Spray Nozzle	.330	.345

CONCLUSION:

It has been concluded that the Pressurizer still meets all of the requirements of the ASME Boiler and Pressure Vessel Code, Section III; and that the accelerated cooldown of the system does not reduce any of the number of cycles originally designed for and defined in the Functional Specification, Ref. B-5.

REFERENCES:

A. Drawings

1. B&W Drawing #135483E7 - Pressurizer List of Material
2. B&W Drawing #135493E5 - 4" Spray Nozzle Details

B. Codes, Specifications, and Reports

1. USAS B31.7 - 1969.
2. ASME Boiler and Pressure Vessel Code, Section III, 1965 Edition thru Summer 1967 Addenda.
3. "Design Analysis of 4" SCH 120 Spray Nozzle, Report No. 9, prepared by R.C. Bodell, dated December 1971.
4. "Pressurizer Stress Report for SMUD, Rancho Seco #1, B&W contract #620-0011-59, SMUD Order #3075, dated August 1974.
5. B&W Reactor Coolant System Functional CS(F)3-92/NSS-11.

C. Computer Programs

1. B&W Program #91213 - Slab Temperature Distribution.

D. General

1. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-4-78.
2. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-7-78.
3. Letter from R.W. Moore to J.M. Burnett, subject - Pressurizer Spray Following Rapid SMUD Cooldown of 3-20-78, 620-0011-50/59, dated 5-23-78.
4. Letter from J. M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4/20/78.

- A -

TRANSIENT
DESCRIPTION

The following pages of this section contain a description of the sequence of events of the SMUD Cooldown Incident. Also contained herein is a time-temperature and time-pressure plot of the reactor coolant system which is used in the justification of the cooldown.

SEQUENCE OF EVENTS - 04:25(AM) to 05:34(AM)
(TAKEN FROM REF D-2)

<u>TIME</u>	<u>EVENT</u>
4:25:35	- Lost NNI power supply cabinets 5, 6, & 7 (B&W Channel "X")
	- This caused a loss of T _H signals to the JCS. BTU limits ran back feedwater, resulting in a loss of feedwater (actual R _x power was 72%).
4:25:46	- Reactor trip on high pressure, turbine trip on interlock.
	- Pressurizer code relief setting was known to be low (=2225 psig). The electromatic relief was isolated due to previous leakage problems. The data indicates primary pressure went =2400 psig =>code relief valve lifted.
4:26:17	- Operator starts HPI pump "B" to maintain p _{zr} . level.
4:28:23	- Operator stops HPI pump "B".
4:30	- OTSG "B" goes dry. Data indicates that "A" OTSG probably also went dry.
4:34:25	- RC pressure =1900 PSI (low pressure trip set-point).
4:34	- Operator increases speed of a MFP and feeds "A" OTSG. This starts RCS on pressure and temperature decrease.
4:37:16	- SFAS actuation at 1600 psig This starts HPI, LPI and initiates aux. feed. Aux. FW valves are opened to full open position. The system makes no automatic attempt to control steam generator water level.
4:40	- RC pressure at 1475 psig. It starts to recover from this point due to HPI. T _{ave} = 528°F.
4:43:56	- "A" HPI pump secured.
4:46:09	- LPI secured.
4:49:56	- "A" HPI initiated. From this point on, the operator started and stopped HPI pumps as necessary to maintain pressurized level.

<u>TIME</u>	<u>EVENT</u>
4:51:25	- Secured RCP-D ($T_{ave} = 435^{\circ}\text{F}$) - This reduced #RCP's to three
4:57:27	- OTSG "A" water level - 599.7" Speculate that =2 ft of tubes are not flooded (at top) due to steam line arrangement.
5:00:00	- Hourly computer log printout Steam temp 380°F (OTSG "B") Steam pressure 171 psig (OTSG "B") Assuming $T_{ave} = T_{sat} \Rightarrow T_{ave} = 380^{\circ}\text{F}$
5:13:47	- OTSG "B" level - 599.1"
5:34	- Power restored to NNI cabinets 5, 6 & 7 $T_{ave} = 285^{\circ}\text{F}$ RCS Pressure = 2000 psig Both OTSG full level ranges pegged high * Operator begins to reduce RC pressure using Pzr spray. Operator stops electric aux FW pump.

(TAKEN FROM REF D-2)

* SEE PG A-5 + A-6

A-4

(TAKEN FROM REF D-1)
COLD LES RC TEMPERATURE, °F
RC PRESSURE, PSIG




FIG. 1

(

THE BASCOCK & WILCOX COMPANY
POWER GENERATION GROUP

TAKEN FROM
REF D-3

To
J.M. Burnett, RCS Components

From
R.W. Moore, Control Analysis (2648)

BDS 643.5

Cust.
SMUD

File No.
or Ref.

Subj. Pressurizer Spray Following Rapid SMUD Cooldown
of 3/20/78

Date
May 23, 1978

This letter to cover one customer and one subject only.

Attached please find a description of spray line variables for the pressurizer spray down following the rapid cooldown at SMUD on 3/20/78. The RCS pressure may be taken to be saturation pressure for the stated pressurizer temperature. The source of spray water was taken from the cold leg (not auxiliary spray).

KWH/lp

PRESSURIZER SPRAY FLOW AND TEMP.

FOLLOWING SMUD RCS COOLDOWN TRANSIENT OF 3/20/78

<u>Time</u> <u>hr:min</u>	<u>Elapsed</u> <u>Time,</u> <u>Min.</u>	<u>Pressurizer</u> <u>Steam, Temp.,</u> <u>F</u>	<u>Spray Nozzle</u> <u>Fluid Temp.,</u> <u>F</u>	<u>Spray</u> <u>Rate</u> <u>GPM</u>
5:34	0.	637	280	1.0
5:56	22.0	633	280	1.0
5:56.1	22.1	633	280	150.
5:59.5	25.5	613	280	150.
5:59.6	25.6	613	280	1.0
6:05	31.0	613	280	1.0
6:05.1	31.1	613	280	25.
6:07	33.0	611.5	280	25.
6:07.1	33.1	611.5	280	1.0
6:15	41.0	610	280	1.0
6:15.1	41.1	610	280	20.
6:29	55.0	600	280	20.
6:29.1	55.1	600	280	1.0
7:05	91.0	591	280	1.0

TAKEN FROM REF D-3

INVENTORY LIST FOR THE YEAR 1957

FOR THE YEAR ENDING 12/31/57

Item No.	Description	Quantity	Unit Price	Total Price
1001
1002
1003
1004
1005
1006
1007
1008
1009
1010
1011
1012
1013
1014
1015
1016
1017
1018
1019
1020

B -

PRESSURIZER
SPRAY NOZZLE

PRESSURIZER SPRAY NOZZLE

PRIMARY + SECONDARY STRESS

THE MAXIMUM PRI+SEC STRESS OCCURS AT THE INSIDE SURFACE OF THE SPRAY NOZZLE AT THE BEGINNING OF THE INTERNAL PIPING.

- $S_D = 55.4$ KSI REF PG B-16-17 OF
 - - - - - THE SPRAY NOZZLE
 - - - - - STRESS REPORT (REF B-3)

TO THIS S_D VALUE WILL BE ADDED AN ADDITIONAL RADIAL GRADIENT AND DISCONTINUITY STRESS.

$$\sigma_{R.G.} = \frac{1}{2(1-\nu)} E \alpha \Delta T_1 = \frac{1}{2(1-\nu)} (29.67 \times 10^6) (6.12 \times 10^{-6}) (24.1)$$

$$\sigma_{R.G.} = 3.1 \text{ KSI}$$

SEE CALCULATION OF ΔT_1 ON PG B-5

REF PG Y-13

$$\begin{aligned} \sigma_{DISCONT} &= C_2 E \alpha |\alpha_2 T_2 - \alpha_1 T_1| = 1.8 (30.5 \times 10^6) [(7.13 \times 10^{-6}) 631 - (6.12 \times 10^{-6}) 650] \\ &= 28.6 \text{ KSI} \end{aligned}$$

THE FOLLOWING ASSUMPTIONS HAVE BEEN MADE. $C_2 = 1.8$ FOR A BRANCH CONNECTION. THE ΔT BETWEEN THE PRESSURIZER SHELL

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO

REVISION

SHEET 3-1 OF

AND THE INTERNAL EXTENSION IS 19°
 THIS IS ASSUMING THE PRESSURIZED
 SHELL IN THE AREA OF THE NOZZLE
 REMAINS AT 650°F WHILE THE AVERAGE
 TEMP OF THE INTERNAL EXTENSION
 IS 631°F, REF PG Y-13.

$$S_p = 55.4 + 3.1 + 28.6 = 87.1 \text{ KSI} > 3S_m = 51.0 \text{ KSI}$$

$$S_p = 58.2 \text{ KSI} \text{ REF PG C-13-1 OF THE} \\ \text{SPRAY NOZZLE STRESS REPORT (REF B-3)}$$

TO THIS S_p VALUE WILL BE ADDED AN
 ADDITIONAL RADIAL GRADIENT AND DISCONTINUITY
 STRESS.

$$\sigma_{\text{RIG}} = \frac{1}{2(1-\nu)} K_3 E \alpha \Delta T_1 + \frac{1}{1-\nu} E \alpha \Delta T_2 = 1.7(3.1) + \frac{1}{1-\nu} (29.67 \times 10^6) (6.12 \times 10^{-6}) (.6) \\ = 5.3 + .2 = 5.5 \text{ KSI} \\ (\Delta T_2 = .6 \text{ REF PG B-5})$$

$$\sigma_{\text{DISCONT}} = C_2 K_3 E \alpha |\Delta T_2 - \Delta T_1| = 1.7(28.6) = 48.6 \text{ KSI}$$

$$S_p = 58.2 + 5.5 + 48.6 = 112.3 \text{ KSI}$$

USING THE SIMPLIFIED ELASTIC PLASTIC

$$K_c = 1.0 + \frac{1-\nu}{2(1-\nu)} \left(\frac{S_p}{S_m} - 1 \right) = 2.4$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET B-2 OF

$$S_{ALT} = K_c \frac{S_P}{2} = 2.4 \left(\frac{12.3}{2} \right)$$

$$= 135.6 \text{ KSI}$$

$$n_1 = 3 \text{ (REF PS A-6)}$$

$$N_1 = 200$$

$$U_1 = \frac{n_1}{N_1} = \frac{3}{200} = .015$$

ADDING U_1 TO THE PREVIOUSLY
CALCULATED U , REF PS C-13-1

$$U_{TOT} = .330 + .015 = .345 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET **B-3** OF

PRESSURIZER SPRAY NOZZLE
THERMAL GRADIENT CALCULATIONS

$$T_{AVER} = \frac{1}{L} \int_{-L/2}^{L/2} T(Y) dy$$

$$\Delta T_1 = \frac{12}{L^2} \int_{-L/2}^{L/2} Y T(Y) dy$$

$$\Delta T_2 = \text{MAX} \begin{cases} |T_0 - T| - \frac{1}{2} |\Delta T_1| \\ |T_i - T| - \frac{1}{2} |\Delta T_1| \end{cases}$$

SIMPSON'S RULE IS USED TO EVALUATE
THE INTEGRALS LISTED ABOVE FOR
TIME 0540, SEE PRESSURIZER SPRAY
NOZZLE THERMAL DISTRIBUTION PROGRAM
PG Y-13

$$\text{SIMPSON'S RULE } \int_{x_0}^{x_2} f(x) dx = \frac{h}{3} [f_0 + 4f_1 + f_2]$$

$$h = \frac{L}{4} = .1171$$

$$T = \frac{1}{.4625} (.1171) \frac{1}{3} [618.8 + 4(625.4) + 2(631.7) + 4(637.7) + 643.4]$$

REF PG Y-13

$$= 631.4 \text{ } ^\circ\text{F}$$

Y	T(Y) REF PG Y-13	YT(Y)
11.71	618.8	- 309.4 t
4.6875	625.4	- 156.4 t
0	631.7	0
4.6875	637.7	159.4 t
11.71	643.3	321.7 t

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET B-4 OF

$$\Delta T_1 = \frac{12}{(4685)^2} (.1171) \frac{1}{3} (-145.0 - 4(73.3) + 2(0) + 4(74.7) + 150.2)$$

$$= 24.1$$

$$\Delta T_2 = \text{MAX} \begin{cases} |643.3 - 631.4| - \frac{1}{2}(24.1) = -.2 \\ |618.8 - 631.4| - \frac{1}{2}(24.1) = .6 \end{cases}$$

$$\therefore \Delta T_2 = .6$$

BABCOCK & WILCOX		REVISION	
DEPARTMENT	DATE	BY	
	CHECKED DATE	BY	
	JOB NO.		SHEET <u>6-5</u> OF

APPENDIX

PRESSURIZER SPRAY NOZZLE, SMUD COOLDOWN INCIDENT
 FULL CERTIFICATION
 SLAR TEMPERATURE DISTRIBUTION PROGRAM 91213
 FULL CERTIFICATION ***** 91213 REV 2 12-15-74 05/23/78 14-08024 PAGE 3010053

PRESSURIZER SPRAY NOZZLE, SMUD COOLDOWN INCIDENT

TIME (12) FOR THIS RUN IS INPUT IN SECONDS

NOTE ***** THE FLUID FOR THIS RUN IS ON THE INSIDE AND OUTSIDE SURFACES *****

INSIDE RADIUS (TO BASE METAL) OF SLAB NI = 1.8125 INCHES REF A-2
 RADIAL THICKNESS OF SLAB (BASE METAL) SLBT = .4885 INCHES II II
 CLADDING THICKNESS CLAD = 3.0000 INCHES
 AXIAL THICKNESS OF SLAB XY = 6.0000 INCHES
 NUMBER OF CYCLES Q = 1
 STARTING TIME FOR THIS RUN TIME = 0.0000 HOURS
 STARTING ITERATION FOR THIS RUN ITER = 0
 STARTING TEMPERATURE OF SOLID BLOCKS STEMP = 650.0 DEGREES
 AVERAGE TEMPERATURE OF SOLID BLOCKS BT = 650.0 DEGREES

Y-1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

91213 REV 2 22-15-74 05/23/78 14-00424 PAGE 3
91213 FULL CERTIFICATION 91213 FULL CERTIFICATION 501CC52

SLAB TEMPERATURE DISTRIBUTION PROGRAM 91213

PRESSURIZER SPRAY NOZZLE + SMUD COOLDOWN INCIDENT

REF PG B-3-2 OF B-3
FILM COEFFICIENTS - INSIDE AND OUTSIDE - PER CYCLE

(10.0 INDICATES INSULATION)

INSIDE OUTSIDE

.2900000E+02 .2000000E+04

EQUATIONS WILL BE RECALCULATED AT TIMES

1.86111

OUTPUT PRINTOUT DATA

PRINTOUT LIMIT 1 WILL BE TO TIME 1.35333 IN INCREMENTS OF .00417

Y-2

SLAB TEMPERATURE DISTRIBUTION PROGRAM 99213

PRESSURIZER SPRAY NOZZLE, SMUD COOLDOWN INCIDENT

REF PS A-4

POINT NO.	1	TYPE 1							
TIME	0.00000	.08333	.16667	.25000	.33333	.41667	1.00000	1.33333	0.00000
TEMP	570.00000	570.00000	590.00000	590.00000	525.00000	380.00000	300.00000	280.00000	0.00000

POINT NO.	7	TYPE 1							
TIME	0.00000	1.93333	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
TEMP	650.00000	650.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000

TEMPERATURE PER NODE AT START OF RUN

T(1)	T(2)	T(3)	T(4)	T(5)	T(6)	T(7)
570.0	650.0	650.0	650.0	650.0	650.0	650.0

NOTE: TEMPERATURES T(1) AND T(7) ARE FLUID TEMPERATURES

SLAB TEMPERATURE DISTRIBUTION PROGRAM 91213
 PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

POINT NO.	X	Y	COEFFICIENT INSIDE	MODE	COEFFICIENT OUTSIDE	MODE	COEFFICIENT OF POINT NO	MODE
1	0	0	0.100	1	0.0000	3	1.0000	1
2	0	0	0.000	1	0.0000	3	0.0000	3
3	0	0	0.000	3	0.0000	1	0.0000	1
4	0	0	0.000	3	0.0000	1	0.0000	1
5	0	0	0.000	3	0.0000	1	0.0000	1
6	0	0	0.000	3	0.0000	1	0.0000	1

DELTA THETA = .1772E-03 HOURS/ITERATION BASED ON BLOCK 3

91218 REV 2 12-15-74 07/23/78 14-88434 PAGE 501CC52

***** FULL CERTIFICATION PROGRAM 91213 *****

PHESURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT
FULL CERTIFICATION *****

SLAR TEMPERATURE DISTRIBUTION

PHESURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

TIME 0500, FIG 1 P9 A-4

ITERATION	1	2	3	4	5	6	7	8	TIME
0470	00100	00000	00000	00000	00000	00000	00000	00000	061000
0471	00000	00000	00000	00000	00000	00000	00000	00000	061000
0472	00000	00000	00000	00000	00000	00000	00000	00000	062000
0473	00000	00000	00000	00000	00000	00000	00000	00000	062000
0474	00000	00000	00000	00000	00000	00000	00000	00000	063000
0475	00000	00000	00000	00000	00000	00000	00000	00000	063000
0476	00000	00000	00000	00000	00000	00000	00000	00000	064000
0477	00000	00000	00000	00000	00000	00000	00000	00000	064000
0478	00000	00000	00000	00000	00000	00000	00000	00000	065000
0479	00000	00000	00000	00000	00000	00000	00000	00000	065000
0480	00000	00000	00000	00000	00000	00000	00000	00000	066000
0481	00000	00000	00000	00000	00000	00000	00000	00000	066000
0482	00000	00000	00000	00000	00000	00000	00000	00000	067000
0483	00000	00000	00000	00000	00000	00000	00000	00000	067000
0484	00000	00000	00000	00000	00000	00000	00000	00000	068000
0485	00000	00000	00000	00000	00000	00000	00000	00000	068000
0486	00000	00000	00000	00000	00000	00000	00000	00000	069000
0487	00000	00000	00000	00000	00000	00000	00000	00000	069000
0488	00000	00000	00000	00000	00000	00000	00000	00000	070000
0489	00000	00000	00000	00000	00000	00000	00000	00000	070000
0490	00000	00000	00000	00000	00000	00000	00000	00000	071000
0491	00000	00000	00000	00000	00000	00000	00000	00000	071000
0492	00000	00000	00000	00000	00000	00000	00000	00000	072000
0493	00000	00000	00000	00000	00000	00000	00000	00000	072000
0494	00000	00000	00000	00000	00000	00000	00000	00000	073000
0495	00000	00000	00000	00000	00000	00000	00000	00000	073000
0496	00000	00000	00000	00000	00000	00000	00000	00000	074000
0497	00000	00000	00000	00000	00000	00000	00000	00000	074000
0498	00000	00000	00000	00000	00000	00000	00000	00000	075000
0499	00000	00000	00000	00000	00000	00000	00000	00000	075000
0500	00000	00000	00000	00000	00000	00000	00000	00000	076000

PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT FULL CERTIFICATION PROGRAM 91213

SLAR TEMPERATURE DISTRIBUTION PRESSURIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

ITERATION	1	2	3	4	5	6	7	8	TIME
430	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	17094
431	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	17503
432	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	17929
433	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	18338
434	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	18764
435	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	19173
436	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	19500
437	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	19808
438	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20044
439	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20252
440	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20444
441	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20619
442	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20774
443	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	20914
444	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21050
445	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21158
446	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21267
447	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21367
448	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21467
449	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21567
450	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21667
451	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21767
452	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21867
453	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	21967
454	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22067
455	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22167
456	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22267
457	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22367
458	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22467
459	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22567
460	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22667
461	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22767
462	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22867
463	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	22967
464	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23067
465	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23167
466	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23267
467	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23367
468	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23467
469	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23567
470	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23667
471	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23767
472	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23867
473	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	23967
474	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24067
475	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24167
476	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24267
477	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24367
478	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24467
479	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24567
480	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24667
481	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24767
482	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24867
483	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	24967
484	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25067
485	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25167
486	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25267
487	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25367
488	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25467
489	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25567
490	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25667
491	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25767
492	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25867
493	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	25967
494	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26067
495	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26167
496	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26267
497	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26367
498	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26467
499	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26567
500	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	26667

91213 REV 2 FULL CERTIFICATION PROGRAM 91213
 PHESSUMIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT FULL CERTIFICATION
 SLAR TEMREATURE DISTRIBUTION

PHESSUMIZER SPRAY NOZZLE SHUD COOLDOWN INCIDENT

ITERATION	1	2	3	4	5	6	7	8	TIME
6073	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6074	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6075	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6076	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6077	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6078	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6079	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6080	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6081	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6082	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6083	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6084	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6085	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6086	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6087	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6088	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6089	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6090	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6091	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6092	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6093	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6094	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6095	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6096	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6097	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6098	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6099	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000
6100	295.26	295.00	295.00	295.00	295.00	295.00	295.00	295.00	00000

CONTRACT NO. <u>595-7072</u> <u>620-0011</u>		DOCUMENT COMMENT FORM		RELEASED BY <u>J.M. Burnett</u> <u>11/8/78</u>	
SUPPLIER <u>B&W</u>		PREPARED BY: <u>J.M. Burnett</u>		TASK ENGINEER <u>J.M. Burnett</u> <u>11/8/78</u>	
PO. NO.		NAME <u>J.M. Burnett</u>		REL. DATE <u>11-17-78</u>	
		DATE <u>11/8/78</u>		PAGE OF	

<u>PART/TGS</u>	<u>B&W DOC. NO.</u>	<u>DOCUMENT TITLE</u>	<u>CUSTOMER/ SUPPLIER DOC. NO.</u>	<u>STATUS</u>	<u>RRL NUMBER</u>
<u>50-01-001</u>		<u>SMUD COOLDOWN INCIDENT JUSTIFICATION OF PRIMARY PIPING FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT (RANCHO SECO)</u>	<u>620-0011- 50 CONTRACT #3075</u>	<u>APPROVED</u>	<u>N/A</u>
<u>33 0279 00</u>					

DISTRIBUTION:

- J.M. BURNETT (w/ 1 ATTACH)
- R.R. SCHAEFER (w/ 1 ATTACH) - MTV
- J.J. KELLY (w/ 6 ATTACH)
- J.T. Janis (w/o ATTACH)

SMUD COOLDOWN INCIDENT
JUSTIFICATION OF PRIMARY PIPING

FOR

SACRAMENTO MUNICIPAL UTILITY DISTRICT
RANCHO SECO

B&W CONTRACT NO: 620-0011-50

PREPARED BY: John W. Stockhous / Associate Engr. / 6-5-78

CHECKED BY: Paul M. Duffai / Associate Engr. / 6-7-78

APPROVED BY: R. R. Schaefer / Senior Engr. / 6-9-78

Mt. Vernon Engineering
The Babcock & Wilcox Company
Mt. Vernon, Indiana

TABLE OF CONTENTS

	<u>PAGE NO.</u>
Introduction.....	1
Discussion.....	2
Results.....	3
Conclusion.....	4
References.....	5
Transient Description.....	A-1 thru A-7
Surge Line Justification.....	B-1 thru B-1
Surge Nozzle Justification.....	C-1 thru C-3
36" & 28" Primary Pipe Justification.....	D-1 thru D-4
Make-Up & HPI Nozzle Justification.....	E-1 thru E-13
Spray Nozzle Justification.....	F-1 thru F-5
Decay Heat Nozzle Justification.....	G-1 thru G-3

APPENDIX

Film Coefficient Calculations.....	Y-1 thru Y-7
28" Carbon Steel 91232 Output.....	Y-8 thru Y-13
28" Stainless Steel 91232 Output.....	Y-14 thru Y-25
36" Carbon Steel 91232 Output.....	Y-26 thru Y-37
Spray Nozzle 91232 Output.....	Y-38 thru Y-47
Decay Heat Nozzle 91232 Output.....	Y-48 thru Y-53

TABLE OF CONTENTS

INTRODUCTION:

The following calculation package has been assembled so as to show that the Primary Piping, RCS Piping and Surge Line, is still in accordance with Section III of the ASME Boiler and Pressure Vessel Code, following the accelerated cooldown of SMUD. (Ref. D-1)

This rapid cooldown transient is being analyzed since it was not defined in the Reactor Coolant System Functional Specification, CS(F)-3-92/NSS-11, or the Reactor Coolant Piping Functional Specification CS(F)-3-37/NSS-11, and was therefore not analyzed in the Primary Piping Stress Reports, 620-0011-50.

.....
.....
.....
.....
.....

APPENDIX

.....
.....
.....
.....
.....
.....

DISCUSSION:

The Primary Piping, which includes the surge line, the 36" hot leg, and the 28" upper and lower cold legs, as well as the various nozzles (HPI, Make-Up, Decay Heat, Spray, and Surge Nozzles), have been analyzed to show that the cumulative usage factor of the pipe, of the nozzle, and of the pipe in the area of the nozzle does not exceed the allowable of 1.0.

Generally speaking, this was done by one of the following two methods:

1. Recalculating the primary plus secondary stresses, primary plus secondary plus peak stresses, and then a new cumulative usage factor.
2. By going into the applicable design analysis and where a more severe or equally severe transient has been analyzed, recalculate a new cumulative usage factor by increasing, by the appropriate number of cycles associated with the accelerated cooldown, the number of design cycles previously analyzed.

RESULTS:

The following is a tabulation of the original and new cumulative usage factors for the various piping locations analyzed:

<u>LOCATION</u>	<u>ORIGINAL C.U.F.</u>	<u>NEW C.U.F.</u>
28" Primary Pipe	.049	.049
Make-Up & HPI Nozzle Branch Connection	.079	.083
HPI Nozzle	.954	.677*
Spray Nozzle Branch Connection	.210	.212
Spray Nozzle	.444	.463
Decay Heat Nozzle Branch Connection	.679	.686
Surge Nozzle Branch Connection	.620	.697
Surge Line	.760	.762

*Note that this new cumulative usage factor was reduced from the original C.U.F., because some of the conservatism was deleted and the entire C.U.F. recalculated.

CONCLUSION:

It has been concluded that the Primary Piping still meets all of the requirements of the ASME Boiler and Pressure Vessel Code, Section III; and that the accelerated cooldown of the system does not reduce any of the number of cycles originally designed for and defined in the Functional Specification, Ref. B-5.

REFERENCES:

A. Drawings

1. B&W Drawing #143491E7 - Piping Coolant List of Material
2. B&W Drawing #143498E10 - Details for 28" Coolant Inlet Pipe
3. B&W Drawing #143499E2 - 28" ID Elbow Forming Drawing
4. B&W Drawing #143495E7 - Details for 36" Coolant Outlet Pipe
5. B&W Drawing #143496E2 - 36" ID Elbow Forming Drawing
6. B&W Drawing #143510E6 - 2-1/2" & 12" Decay Heat Nozzles Ass'y. & Details

B. Codes, Specifications, and Reports

1. USAS B31.7 - 1969.
2. ASME Boiler and Pressure Vessel Code, Section III, 1965 Edition thru Summer 1967 Addenda.
3. B&W Standards Manual 2A3521 and 2A3522, Heat Transfer Calculation.
4. B&W Reactor Coolant Piping Functional Specification, CS(F)3-37/NSS-11.
5. B&W Reactor Coolant System Functional Specification, CS(F)3-92/NSS-11.
6. "Primary Piping Analysis Report No. 2", prepared by Al McKim, dated October 1971.
7. "Decay Heat Nozzle Report No. 3", prepared by Randal R. Schaefer, dated January 1973.
8. "Thermal/Mechanical Analysis of Surge Line Nozzle Report No. 4", prepared by Randal R. Schaefer, dated October 1971.
9. "Thermal/Mechanical Analysis of 2-1/2" SCH 16⁰ Make-Up and High Pressure Injection Nozzle Report No. 5", prepared by H.W. Behnke, dated May 1972.
10. "Stress Evaluation of Reactor Coolant Spray Line Nozzle Report No. 7", prepared by Ralph Skinner, dated November 1971.
11. "Stress Analysis of Surge Line, Report No. 6", prepared by Randal R. Schaefer, dated January 1972, Rev. 1 dated January 5, 1973.

C. Computer Program

1. Program No. 91232 - One-Dimensional Implicit Transient Temperature Distribution.

D. General

1. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-4-78.
2. Letter from J.M. Burnett to Distribution, subject - SMUD Cooldown Incident, 620-0011-50/59, dated 4-7-78.
3. Letter from R.W. Moore to J.M. Burnett, subject - Pressurizer Spray Following Rapid SMUD Cooldown of 3-20-78, 620-0011-50/59, dated 5-23-78.
4. Telecopy of "Sequence of Events - SMUD Transient" from J.M. Burnett to Mt. Vernon.
5. Letter from J. M. Burnett to Distribution, Subject: SMUD Cooldown Incident", 620-0011-50/59, dated 4/20/78.

- A -

TRANSIENT
DESCRIPTION

The following pages of this section contain a description of the sequence of events of the SMUD Cooldown Incident. Also contained herein is a time-temperature and time-pressure plot of the reactor coolant system which is used in the justification of the cooldown.

SEQUENCE OF EVENTS - 04:25(AM) to 05:34(AM)

TAKEN FROM REF D-2

<u>TIME</u>	<u>EVENT</u>
4:25:35	- Lost NNI power supply cabinets 5, 6, & 7 (B&W Channel "Y")
	- This caused a loss of T _H signals to the ICS. BTU limits ran back feedwater, resulting in a loss of feedwater (actual Rx power was 72%).
4:25:46	- Reactor trip on high pressure, turbine trip on interlock.
	- Pressurizer code relief setting was known to be low (=2225 psig). The automatic relief was isolated due to previous leakage problems. The data indicates primary pressure went =2400 psig =>code relief valve lifted.
4:26:17	- Operator starts HPI pump "B" to maintain pzz. level.
4:28:23	- Operator stops HPI pump "B".
4:30	- OTSG "B" goes dry. Data indicates that "A" OTSG probably also went dry.
4:31:25	- RC pressure =1900 PSI (low pressure trip set-point).
4:34	- Operator increases speed of a MFP and feeds "A" OTSG. This starts RCS on pressure and temperature decrease.
4:37:16	- SFAS actuation at 1600 psig This starts HPI, LPI and initiates aux. feed. Aux. FW valves are opened to full open position. The system makes no automatic attempt to control steam generator water level.
4:40	- RC pressure at 1475 psig. It starts to recover from this point due to HPI. T _{ave} = 528°F.
4:43:56	- "A" HPI pump secured.
4:46:09	- LPI secured.
4:48:34	- "A" HPI initiated. From this point on, the operator started and stopped HPI pumps as necessary to maintain pressurized level.

<u>TIME</u>	<u>EVENT</u>
4:51:25	- Secured RCP-D ($T_{ave} = 435^{\circ}F$) This reduced #RCP's to three
4:57:27	- OTSG "A" water level - 599.7" Speculate that =2 ft of tubes are not flooded (at top) due to steam line arrangement.
5:00:00	- Hourly computer log printout Steam temp $380^{\circ}F$ (OTSG "B") Steam pressure 171 psig (OTSG "B") Assuming $T_{ave} = T_{sat} \Rightarrow T_{ave} = 380^{\circ}F$
5:13:47	- OTSG "B" level - 599.1"
5:34	- Power restored to NNI cabinets 5, 6 & 7 $T_{ave} = 285^{\circ}F$ RCS Pressure = 2000 psig Both OTSG full level ranges pegged high * Operator begins to reduce RC pressure using Pzr spray. Operator stops electric aux FW pump.

* SEE PAGES A-6 AND A-7.

TAKEN FROM REF D-2

SEQUENCE OF EVENTS - SMUD TRANSIENT

(REF D-4)

TIME	EVENT
04:25:35	LOST NNE PWR SUPPLY
04:25:45	TURB TRIP RX TRIP (HP)
04:26:17	HPI "B" (MANUAL)
04:26:23	" " NORMAL (OIF)
04:34:25	RX LOW PRESS TRIP
04:37:56	TRIP "B" SFAS ANALOG
04:37:57	" " "A" " " "
04:37:58	HPI INIT ON C SFAS
04:43:56	HPI SECURED
04:46:09	B LPI SECURED
04:46:39	A " " "
04:49:54	HPI INITIATED (MANUAL)
04:51:25	"D" RCP SECURED
04:51:52	A HPI SECURED
04:55:23	A HPI INITIATED
05:05:30	" " SP HPI SECURED
05:09:42	B HPI INITIATED
05:23:04	B HPI SECURED
05:33:14	B HPI INITIATED
05:34:04	B HPI SECURED

WR PRESS
1543 1091
1576

AT 04:44:16 - CALCULATED HT UP/O/D RATE 84°/HR
 AT 04:45:16 " " " " 291.1°/HR

XMITTER SWITCH DURING CALL

05:34. RESTORED NNE X & Y PWR SUPPLIES

APP FW WITH SFAS

NOTE THAT THE MAX # OF CYCLES WAS 4, EXPERIENCED BY HPI "B". THIS WILL BE USED IN THE FATIGUE ANALYSIS OF THE HPIS. REF P5 E-6.

A-5

TIME OF EVENT

0620

0600

0550

0520

0500

0440

0420

RC TEMPERATURE

RS PRESSURE

2-MIN POWER RESUMED

OTSG "B" FULL

OTSG "A" FULL

MFP SPEED INCREASED


SFAS ACTUATION

MFI POWER-SUPPLY LOST

COLD LES RC TEMPERATURE, °F

RC PRESSURE, PSIG

200 040 300 004 005 009 1000 2000 2500



THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

To |
J.M. Burnett, RCS Components

From |
R.W. Moore, Control Analysis (2648)

BDS 253.5

Cust.
SMUD

File No.
or Ref.

Subj. Pressurizer Spray Following Rapid SMUD Cooldown
of 3/20/78

Date
May 23, 1978

This letter is cover and customer and the subject only.

Attached please find a description of spray line variables for the pressurizer spray down following the rapid cooldown at SMUD on 3/20/78. The RCS pressure may be taken to be saturation pressure for the stated pressurizer temperature. The source of spray water was taken from the cold leg (not auxiliary spray).

RWH/lp

TAKEN FROM REF D-3

PRESSURIZER SPRAY FLOW AND TEMP.
 FOLLOWING SMD RCS COOLDOWN TRANSIENT OF 3/20/78

<u>Time</u> <u>Hr:Min</u>	<u>Elapsed</u> <u>Time,</u> <u>Min.</u>	<u>Pressurizer</u> <u>Steam, Temp.,</u> <u>F</u>	<u>Spray Nozzle</u> <u>Fluid Temp.,</u> <u>F</u>	<u>Spray</u> <u>Rate</u> <u>GPM</u>
5:34	0.	637	280	1.0
5:56	22.0	633	280	1.0
5:56.2	22.1	633	280	150.
5:59.5	25.5	613	280	150.
5:59.6	25.6	613	280	1.0
6:05	31.0	613	280	1.0
6:05.1	31.1	613	280	25.
6:07	33.0	611.5	280	25.
6:07.1	33.1	611.5	280	1.0
6:15	41.0	610	280	1.0
6:15.1	41.1	610	280	20.
6:29	55.0	600	280	20.
6:29.1	55.1	600	280	1.0
7:05	91.0	591	280	1.0

TAKEN FROM REF D-3

<u>Tract No.</u>	<u>Acres</u>	<u>Original Grantee</u>	<u>Acres</u>	<u>Original Grantee</u>
100	100	100	100	100
101	100	100	100	100
102	100	100	100	100
103	100	100	100	100
104	100	100	100	100
105	100	100	100	100
106	100	100	100	100
107	100	100	100	100
108	100	100	100	100
109	100	100	100	100
110	100	100	100	100
111	100	100	100	100
112	100	100	100	100
113	100	100	100	100
114	100	100	100	100
115	100	100	100	100
116	100	100	100	100
117	100	100	100	100
118	100	100	100	100
119	100	100	100	100
120	100	100	100	100

- B -

SURGE LINE

SURGE LINE

REFERENCE B-11, "STRESS ANALYSIS OF SURGE LINE", WAS SCANNED AND IT WAS DETERMINED THAT THE BIMETAL WELD, AT THE RCS SURGE NOZZLE TO SURGE LINE JUNC., HAD THE HIGHEST CUMULATIVE USAGE FACTOR IN THE SURGE LINE. PAGES C-17 + D-3 SHOW THAT THE FIRST FATIGUE CASE ANALYZED ASSUMED A ΔP OF 2500 PSI AND A ΔT OF 580°F. SINCE THIS CASE IS WORSE THAN THE ACCELERATED COOL DOWN BEING ANALYZED A NEW USAGE FACTOR WILL BE CALCULATED ASSUMING ONE ADDITIONAL CYCLE WHICH WILL ACCOUNT FOR THE ACCELERATED COOLDOWN. SINCE ORIGINALLY 240 CYCLES WERE ANALYZED, THE NEW USAGE FACTOR WILL BE BASED ON 241 CYCLES.

$$\text{HENCE: } U_1 = \frac{241}{550} = .438 \quad \left(\begin{array}{l} \text{REF PG D-3} \\ \text{OF REF B-11} \end{array} \right)$$

$$U_{\text{TOT}} = .438 + .016 + .008 + .300 + 0.000 + 0.000$$

$$U_{\text{TOT}} = .762 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET B-1 OF

- C -

SURGE NOZZLE

PRIMARY PIPE AT THE
BASE OF THE SURGE NOZZLE

PRI + SEC, EQ 10

$$S_D = C_1 \frac{PD_0}{2t} + C_{2b} \frac{M_b}{Z_b} + C_{2r} \frac{M_r}{Z_r} + \frac{1}{2(1-\nu)} E \alpha |\Delta T| + C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b| \leq 3S$$

WHERE: $C_1 \frac{PD_0}{2t} = 1.0 \frac{250(42.25)}{2(2.8125)} = 18.8 \text{ KSI}$

$$C_{2b} \frac{M_b}{Z_b} = 7.5 \text{ KSI} \quad (\text{REF PG B-15-7 OF REF B-8})$$

$$C_{2r} \frac{M_r}{Z_r} = 2.5 \text{ KSI} \quad (\text{REF PG B-15-2 OF REF B-8})$$

$$\frac{1}{2(1-\nu)} E \alpha \Delta T = 6.8 \text{ KSI} \quad (\text{REF PG Y-36 OF REPORT})$$

$C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b|$ WILL BE CONSERVATIVELY
CALCULATED ASSUMING A MAX AT BETWEEN
THE AVERAGE TEMP OF THE SURGE NOZZLE
AND THE AVERAGE TEMP OF THE RUN PIPE
OF 310°F. (310°F COMES FROM THE MAX
ΔT OF FLUID TEMP, 590°F @ TIME 0435 MINUS
280°F @ TIME 0540.)

$$C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b| = 1.8(29.67 \times 10^6) / 6.12 \times 10^{-6} (590) - 6.12 \times 10^{-6} (280) / = 101.3 \text{ KSI}$$

$$S_D = 18.8 + 7.5 + 2.5 + (6.8 + 2.0) + 101.3 = 138.9 \text{ KSI}$$

PREVIOUS R.G. STRESS FROM PRIMARY PIPE REPORT
REF P. 275

BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE	BY
	CHECKED DATE	BY
	JOB NO.	
		SHEET <u>C-1</u> OF

$$S_n = 138.9 \text{ KSI} > 3S_m = 52.2 \text{ KSI}$$

PEAK STRESSES, EQ 11

$$S_p = K_1 C_1 \frac{P_0 D}{2t} + C_{2a} K_{2a} \frac{M_b}{Z_b} + C_{2r} K_{2r} \frac{M_r}{Z_r} + \frac{1}{2(1-\nu)} K_3 E \alpha T_1 + K_3 C_3 E_{ab} (\alpha_c T_c - \alpha_h T_h) + \frac{1}{1-\nu} E \alpha T_2$$

WHERE: $K_1 C_1 \frac{P_0 D}{2t} = 1.7(1.0) \frac{2500(42.25)}{2(2.8125)} = 31.9 \text{ KSI}$

$C_{2a} K_{2a} \frac{M_b}{Z_b} = 14.7 \text{ KSI}$ (REF PG B-15-7 OF REF B-9)

$C_{2r} K_{2r} \frac{M_r}{Z_r} = 4.9 \text{ KSI}$ (REF PG B-15-2 OF REF B-9)

$\frac{1}{2(1-\nu)} K_3 E \alpha T_1 = 1.7(6.8) = 11.6 \text{ KSI}$ (REF PG Y-36 OF REPORT)

$\frac{1}{(1-\nu)} E \alpha T_2 = 9.5 - 6.8 = 2.7 \text{ KSI}$ (REF PG Y-36 OF REPORT)

$K_3 C_3 E_{ab} (\alpha_c T_c - \alpha_h T_h)$ WILL BE CONSERVATIVELY CALCULATED ASSUMING A MAX AT BETWEEN THE AVERAGE TEMP OF THE SURGE NOBLE AND THE AVERAGE TEMP OF THE RUN PIPE OF 310°F. (310°F COMES FROM THE MAX AT OF THE FLUID TEMP, 590°F @ TIME 0455 MINUS 280°F @ TIME 0540.)

$$C_3 K_3 E_{ab} (\alpha_c T_c - \alpha_h T_h) = 1.9(1.7) 29.67 \times 10^6 / 6.12 \times 10^{-6} (590) - 6.12 \times 10^{-6} (280) = 172.2 \text{ KSI}$$

BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE	BY
	CHECKED DATE	BY
	JOB NO.	
		SHEET C-2 OF

PREVIOUS R.G. STRESS FROM PRIMARY
PIPE REPORT REF P9 275



$$S_p = 31.9 + 14.7 + 4.9 + (11.6 + 2.0) + 2.7 + 172.2 = 240.0 \text{ KSI}$$

USING SIMPLIFIED ELASTIC PLASTIC
USAS B31.7 NUCLEAR POWER PIPING

$$\frac{S_n}{3S_m} = \frac{138.9}{52.2} = 2.66 ; \therefore A = 1.45 \text{ (FIG D-201)}$$

$$S_{ALT} = \frac{1}{2} [S_p + A(S_p - S_n)] \frac{S_n}{3S_m}$$

$$= \frac{1}{2} [240 + 1.45(240 - 138.9)] \frac{138.9}{52.2}$$

$$= 514.4 \text{ KSI}$$

$$N_1 = 13$$

$$U_1 = \frac{1}{13} = .077$$

ADDING U_1 TO THE PREVIOUS USAGE FACTOR
OF THE REPORT (REF P9 B-16-30 OF REF B-11)

$$U_{TOT} = .077 + .620 = .697$$

$$U_{TOT} = .697 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET C-3 OF

-D-

-36" & 28"

PRIMARY-PIPE

PRIMARY PIPE
CARBON STEEL

THE PRIMARY + SECONDARY AND PRIMARY + SECONDARY + PEAK STRESSES HAVE BEEN RECALCULATED USING THE SMUD COOLDOWN INCIDENT TRANSIENT. IN ADDITION A NEW FATIGUE USAGE FACTOR HAS BEEN CALCULATED.

THE RADIAL GRADIENT STRESS HAS BEEN RECALCULATED FOR A 28" STAINLESS STEEL SECTION. THIS INCREASED RADIAL GRADIENT STRESS HAS BEEN ADDED TO THE WORST STRESSED JOINT IN THE HOT OR COLD LEG. THE 28" STAINLESS STEEL RADIAL GRADIENT STRESS WAS CHOSEN TO BE ADDED TO THE HIGHEST STRESSED JOINT IN THE RCS PRIMARY PIPING SINCE THE 28" S.S. SECTION HAD THE HIGHEST RADIAL GRADIENT STRESS OF THE 28" AND 36" PIPING. (SEE THERMAL OUTPUT OF 28" + 36" C.S. SECTIONS AND 28" S.S. SECTIONS, PG Y-8 THRU Y-37.)

THE MAXIMUM PRI + SEC STRESS (AS WELL AS MAX USAGE FACTOR) OCCURS AT JOINT # 47 WHICH IS THE 28" COLD LEG DISCHARGE CARBON STEEL - STAINLESS STEEL PUMP JOINT.

FROM "PRIMARY PIPING ANALYSIS, REPORT # 2, 620-0011-50" THE PRI + SEC STRESS IS

BABCOCK & WILCOX		REVISION	
DEPARTMENT	DATE	BY	
	CHECKED DATE	BY	
	JOB NO.		SHEET <u>D-1</u> OF

$$S_{PRI+SEC} = 71,738 \quad (\text{REF PG 160})$$

$$\sigma_{R.G. (\text{INCIDENT})} = 6848 \text{ PSI} \quad (\text{CALCULATED USING 1-DIMENSIONAL THERMAL COMPUTER PROGRAM})$$

ADDING THE ADDITIONAL RADIAL GRADIENT STRESS TO THE PRI + SEC STRESS OF THE REPORT

$$S_{PRI+SEC} = 71,738 + 6848 = 78,586 \text{ PSI}$$

$$S = 78,586 \text{ PSI} > 3S_m = 57,000 \text{ PSI}$$

PAGE 181 CONTAINS THE COMPUTER OUTPUT OF THE DETAILED ANALYSIS OF JT# 47 WHICH WAS PERFORMED SINCE ORIGINALLY THE $3S_m$ LIMIT WAS EXCEEDED ALSO. THE σ_{RG} WILL BE CONSERVATIVELY ADDED TO THE STRESS INTENSITY TO SHOW COMPLIANCE WITH THE $3S_m$ LIMIT.

$$S_{22} = 42,590 \text{ PSI} \quad (\text{REF PAGE 181})$$

$$S_{22} + A\sigma_{R.G.} = 42,590 + 6848 = 49,438 \text{ PSI}$$

$$S_{22} = 49,438 \text{ PSI} < 3S_m = 57,000 \text{ PSI}$$

NOTE THAT THERE IS NO CHANGE IN THE DISCONTINUITY STRESS PREVIOUSLY CALCULATED. FROM PREVIOUS THERMAL DISCONTINUITY ANALYSES IT HAS BEEN DETERMINED THAT THE MAX DISCONT STRESS OCCURS AT THE MAX SYSTEM TEMPERATURE RATHER THAN

BABCOCK & WILCOX		REVISION	
DEPARTMENT	DATE	BY	
	CHECKED DATE	BY	
	JOB NO.		SHEET <u>D-2</u> OF

AT A HEATUP OR COOLDOWN OR OTHER THERMAL TRANSIENT CONDITION. THIS IS DUE TO THE FACT THAT THERE ARE VERY SMALL ΔT 'S PRESENT BETWEEN THE AVERAGE STAINLESS STEEL SECTION TEMPERATURES AND THE AVERAGE CARBON STEEL TEMPERATURES DURING A TRANSIENT CONDITION.

CALCULATION OF USAGE FACTOR

FROM THE OUTPUT OF THE 1-DIMENSIONAL COMPUTER PROGRAM THE MAX PEAK RADIAL GRADIENT STRESS IS 9468 PSI. (THIS WAS RUN FOR THE THERMAL PARAMETER DEFINED IN THE SMUD COOLDOWN INCIDENT.)

$$\begin{aligned}\sigma_{R.G. \text{ COOLDOWN INCIDENT}} &= (K_s \times \text{LINEAR PORTION}) + \text{PEAK PORTION} \\ &= 1.7 (6848) + (9468 - 6848) \\ &= 14262 \text{ PSI}\end{aligned}$$

REF PS 162 OF STRESS REPORT

$$\begin{aligned}\rightarrow S_{\text{PEAK REPORT}} + \sigma_{R.G.} &= 70,737 + 14,262 \\ &= 84,999 \text{ PSI}\end{aligned}$$

$$S_{\text{ALT}} = \frac{84,999}{2} = 42,499 \text{ PSI}$$

$$N_{\text{ALLOW}} = 6,500 \text{ CYCLES}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET D-3 OF

$$U_{\text{cycle}} = .000$$

$$U_{\text{TOTAL}} = .000 + .002 + .047 = .049 < 1.0$$

HENCE IT HAS BEEN SHOWN THAT THE SMUD COOLDOWN INCIDENT DOES NOT SIGNIFICANTLY EFFECT THE PRI + SEC STRESSES OR THE CUMDLATIVE USAGE FACTOR. HENCE THE PRIMARY PIPING IS IN ACCORDANCE WITH SECTION III FOR THE PREVIOUS DESIGN LIFE.

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET D-4 OF

-E-

MAKE-UP & HPI
NOZZLE

MAKE-UP + HPI NOZZLE

SINCE THE MAKE-UP + HPI NOZZLES ARE ANALYZED COLLECTIVELY IN ONE STRESS REPORT ("THERMAL MECHANICAL ANALYSIS OF 2 1/2" SCH 160 MAKE-UP AND HPI NOZZLE", DESIGN REPORT #S, 620-0011-50) THEY AGAIN WILL BE ANALYZED TOGETHER FOR THIS COOLDOWN INCIDENT.

BRANCH CONNECTION

OF THE TWO NOZZLES, THE MAKE-UP NOZZLE HAD THE HIGHER STRESS + USAGE FACTOR AT THE BRANCH CONNECTION AND WILL HEREFOR BE USED IN THE JUSTIFICATION CALCULATIONS.

THE MAX STRESS INTENSITY FROM P₉ i_i OF ABOVE REFERENCED POINT IS:

$$S = 52.2 \text{ KSI} < 3S_m = 53.4 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET E-1 OF

THE INCREASED RADIAL GRADIENT STRESS IN THE BRANCH CONNECTION WILL BE ADDED TO THE PRI + SEC STRESS OF THE REPORT OF 52.2 KSI.

$$\sigma_{r.g.} = 5.2 \text{ KSI (REF 28" COMPUTER OUTPUT, ATTACHED)}$$

$$\therefore S = 52.2 + 5.2 = 57.4 \text{ KSI} \quad 3S_m = 53.4 \text{ KSI}$$

USING A SIMPLIFIED ELASTIC PLASTIC OF USAS B31.7 - 1969

$$S_{ULT} = \frac{1}{2} [S_p + A(S_p - S_n)] \frac{S_n}{3S_m}$$

$$\text{WHERE } S_n = 57.4 \text{ KSI}$$

$$3S_m = 53.4 \text{ KSI}$$

$$A = .75 \text{ (FIG D-201 (a))}$$

$$S_{PEAK} = S_{P \text{ OF REPORT}}^{(F_3 \text{ 3-65})} + \sigma_{r.g.}$$

$$\sigma_{r.g.} = \frac{1}{2(1-\nu)} K_3 E \alpha \Delta T_1 + \frac{1}{1-\nu} E \alpha \Delta T_2 \text{ (REF 28" COMPUTER OUTPUT, ATTACHED)}$$

$$\sigma_{r.g.} = [1.7(5.2) + (7.3 - 5.2)] = 10.9 \text{ KSI}$$

$$S_{PEAK} = 107.7 + 10.9 = 118.6 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET E-2 OF

$$S_{eq} = \frac{1}{2} [118.6 + .75(718.6 - 57.4)] \frac{57.4}{53.4}$$

$$= 88.4 \text{ KSI}$$

$$N_1 = 900$$

ASSUMING THE HPI PUMPS WERE STARTED AND STOPPED 4 TIMES

$$U_1 = \frac{4}{900} = .004$$

ADDING U_1 TO THE PREVIOUS U OF THE STRESS REPORT (REF PG 3-66 OF STRESS REPORT)

$$U_{TOT} = .004 + .079 = .083$$

$$U_{TOT} = .083 < 1.0$$

BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE	BY
	CHECKED DATE	BY
	JOB NO.	

SHEET <u>E-3</u> OF

HPI NOZZLE SAFE END

NO ADDITIONAL THERMAL TRANSIENT ANALYSIS IS REQUIRED ON THE HPI + MAKE-UP NOZZLES SINCE A MORE SEVERE TRANSIENT WAS ANALYZED IN REF B-9 FOR A "RAPID DEPRESSURIZATION" CONDITION, TRANSIENT # 9 OF REF B-4. THEREFORE IN ORDER TO JUSTIFY 4 CYCLES OF THE HPI ACTUATION, THESE 4 CYCLES WILL BE ADDED TO THE 40 CYCLES OF "RAPID DEPRESSURIZATION" ALREADY ANALYZED.

THE HPI NOZZLE HAD THE HIGHER OVER-ALL STRESS + USAGE FACTOR AT THE END OF THE NOZZLE. IN ORDER TO JUSTIFY THIS LOCATION, SOME OF THE CONSERVATISM OF THE CALCULATION OF THE CUMULATIVE USAGE FACTOR WAS DELETED AND HENCE THE CALCULATIONS OF P9 5-28 THRU 5-30, REF B-9, WERE REVISED.

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED-DATE

BY

JOB NO.

SHEET E-4 OF

(TAKEN FROM REF B-9)

HPI STRESS CASES

<u>ITERATION</u>	<u>TIME</u>	<u>EXPLANATION</u>
27967	4.95 Hrs.	End of Heat-Up - No flow condition See Page 4-5
41491	7.5 Hrs.	Steady State Temperature at 575 Hottest temperature in vicinity of Bi-metal weld.
42021	7.6 Hrs.	Reversal in Axial gradient from 27967. See Page 4-5
3, 6, 8	0 - 10 Secs.	Maximum radial gradient stress during test transient. See Page 8-6
15	10.7 Sec. from start of test	Maximum axial gradient in upper part of nozzle
30	21.4 Sec. after test	Reversal of radial gradient
1211	14.8 min. after test	Reversal of axial gradient in upper part of nozzle
5060, 5063, 5072	0-10 Secs. after start of rapid depress- urization	Maximum radial gradient stress in rapid depressurization. See Page 4-7
5124	1.015 Hrs. .9 min. after start of rapid depressurization	One location of possible maximum axial gradient stress. See Page 4-7.
5237	1.0384 Hrs.	Possible maximum axial gradient stress
6059	1.2 hrs.	Possible maximum axial gradient stress.
6307	1.248 hrs.	End of 40°F water injection
6338	1.254 hrs.	Reversal of radial gradient and reversal of axial gradient. See Page 4-3
6850	1.35 hrs.	Reversal of axial gradient.
1	-	Pressure Only, 1000 PSI.

JUNCTION NO. 8

ITER.

PRIMARY + SECONDARY STRESS INTENSITIES

PEAK STRESS INTENSITIES

ITER.	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - R		R - H		H - I		L - R		R - H		H - I	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
3	63.7	-58.2	-54.7	50.2	-9.0	7.9	109.0	-50.7	-92.9	22.5	-16.0	28
6	77.5	-70.8	-63.6	59.5	-14.0	11.3	115.0	-67.3	-92.1	31.3	-22.9	36
8	78.8	-71.9	-62.9	59.2	-16.0	12.6	113.3	-70.6	-88.0	32.7	-25.3	37
15	69.3	-63.0	-47.3	48.2	-22.0	14.9	95.0	-75.0	-64.2	38.0	-30.4	37
30	7.7	-6.9	-1.2	1.1	-6.5	5.8	8.7	-9.4	-1.0	1.2	-1.7	8
1211	-.4	.3	.1	-.1	.3	-.2	-.4	.4	.1	-.1	.4	-
1491	.0	-.0	.0	.0	-.0	-.0	.0	-.0	.0	.0	-.0	-
1	2.2	.6	-3.5	-1.6	1.3	1.0	2.5	.9	-3.5	-1.6	1.0	-
42021	.0	.0	.0	.0	.0	.0	.0	.0	.0	.0	.0	-
2996	-.7	-.6	1.1	-.3	-.5	-.3	-.8	.5	1.2	.0	-.4	-

STRESS OUTPUT ANALYSIS

5072	86.0	-78.3	-62.4	60.0	-23.6	10.3	117.3	-80.5	-83.1	34.7	-34.2	45
5060	73.1	-66.8	-61.9	58.3	-11.2	8.4	147.4	-53.3	-128.6	21.9	-18.7	31
5063	97.9	-89.3	-81.4	74.5	-16.4	14.8	143.3	-85.3	-115.7	39.3	-27.6	46
5124	33.0	-29.7	-13.1	15.1	-19.5	14.7	39.9	-36.7	-15.8	11.4	-24.1	25
5237	11.5	-10.4	-3.8	5.5	-7.7	4.9	14.2	-13.4	-5.1	4.8	-9.2	8
6059	.4	-.4	.3	.4	-.7	-.0	.5	-.5	.3	.3	-.8	-

6307	.4	-.4	.2	.3	-.6	.0	.5	-.5	.2	.3	-.7	-.2
6338	-7.7	7.0	5.6	-5.1	2.1	-1.9	-9.6	8.7	6.6	-4.3	3.1	-4.4
6850	-3.5	3.1	-1.0	-.5	4.5	-2.6	-1.3	4.1	-3.4	-.4	4.7	-3.7
1	2.2	.6	-3.5	-1.6	1.3	1.0	2.5	.9	-3.5	-1.6	1.0	-.7

STRESS OUTPUT ANALYSIS

TAKEN FROM REF B-9

III-6

STRESS INTENSITY ON BRANCH DUE TO BRANCH PIPE LOADS

SECTION	CATEGORY	R _i	R _o	M _i FT-KIPS	INTENSITY (KSI)	
					INSIDE	OUTSIDE
1 $\frac{1}{I} = .425$	PRIMARY	R _m = 1.25		2.68	17.1	
	SECONDARY 2.0BE	1.0625, 1.4375		4.54	24.6, 33.3	
	SECONDARY 0.2ETHER	↓	↓	3.45	18.7, 25.3	
	SECONDARY THERM	↓	↓	1.18	6.4, 8.7	
2 $\frac{1}{I} = .336$	PRI	R _m = 1.28125		2.76	14.3	
	SEC.(2.0BE)	1.0625, 1.5		4.64	19.9, 28.1	
	SEC.(0.2ETHER)	↓	↓	3.52	15.1, 21.3	
	SEC.(THER)	↓	↓	1.20	5.1, 7.3	
3 $\frac{1}{I} = .0126$	PRI	R _m = 2.1875		3.84	1.3	
	SEC(2.0BE)	1.1875, 3.1875		5.91	1.1, 2.8	
	SEC(0.2ETHER)	↓	↓	4.45	.8, 2.1	
	SEC(THER)	↓	↓	1.50	.3, .7	
4 $Z = 30.06 \text{ IN}^3$		STRESS INDEX				
	PRI	1.863		3.84	2.86	
	SEC(2.0BE)	2.484		5.91	5.86	
	SEC(0.2ETHER)	2.484		4.45	4.91	
	SEC(THER)	2.484		1.50	1.49	

(TAKEN FROM REF B-9)

BABCOCK & WILCOX	BY _____	DATE _____
DEPARTMENT _____		JOB NO. _____
		SHEET <u>E-7</u> OF _____

PRT + SEC STRESSES

CASE 1

40 CYCLES "RAPID DEPRESS"
 4 "ACCELERATED COOLDOWN (REF PG A-4)
 44 CYCLES

$$S_n = [\sigma_{\text{ITER 50.0}}^{\text{L-R}} + \sigma_{\text{PRES}} + \sigma_{\text{THERM EXP}}] - [\sigma_{\text{ITER 40.0}}^{\text{L-R}} + \sigma_{\text{PRES}}]$$

$$= [73.1 + 2.2(2.2) + 5.1] - [-7.7 + 1.5(2.2)]$$

$$= 83.04 + 4.40 = 87.44 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

SINCE $S = 87.44 > 1.7(3S_m) = 87.21 \therefore K_e = 3.52$

CASE 2

40 CYCLES "TEST TRANSIENT"

$$S_n = [\sigma_{\text{ITER 6}}^{\text{L-R}}] - [\sigma_{\text{ITER 30}}^{\text{L-R}}]$$

$$= 77.5 - 7.7 = 69.8 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

$$K_e = 1.0 + \frac{1.3}{3(1.7-1)} \left(\frac{69.8}{51.3} - 1 \right) = 2.20$$

CASE 3

30 CYCLES "OBE SEISMIC" @ STEADY STATE

$$S_n = [\sigma_{\text{PRES}} + \sigma_{\text{THERM EXP}} + \sigma_{\text{OBE}}] - [\text{COLD CONDITION}]$$

$$S_n = 2.2(2.2) + 15.1 = 19.9 \text{ KSI} < 3S_m = 51.3 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET E-8 OF

PRI + SEC STRESSES

CASE 4

240 CYCLES "HEAT-UP + COOLDOWN"

$$S_n = \left[\sigma_{THER}^{L-R} + \sigma_{PRES} + \sigma_{THERM EXP} \right] - \text{COLD CONDITION}$$

$$= \left[-0.7 + 2.2(2.2) + 5.1 \right] - 0$$

$$= 9.24 \text{ KSI} < 3S_m = 51.3 \text{ KSI}$$

CASE 5

620 CYCLES "2 OBE"

$$S_n = 19.9 \text{ KSI} \quad \text{REF P5 E-8}$$

$$S = 19.9 \text{ KSI} < 3S_m = 51.3 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET E-9 OF

PEAK STRESSES

CASE 1

$$S_p = \left[\sigma_{ITER}^{L-R} + \sigma_{PRESS} + S.C.F. \sigma_{THERM EXP} \right] - \left[\sigma_{ITER}^{L-R} + S.C.F. \times \sigma_{PRESS} \right]$$

$$= [147.4 + (2.2)2.2 + 1.39(5.1)] - [-9.6 + (1.5)2.2]$$

$$= 159.3 + 6.3 = 165.6 \text{ KSI}$$

CASE 2

$$S_p = \left[\sigma_{ITER}^{L-R} \right] - \left[\sigma_{ITER}^{L-R} \right] = 115.0 - 8.7 = 106.3 \text{ KSI}$$

CASE 3

$$S_p = \left[\sigma_{PRESS} + S.C.F. (\sigma_{THERM EXP} + \sigma_{CASE}) \right] - \left[\text{COLD CONDITION} \right]$$

$$= [2.2(2.2) + 1.39(15.1)] = 25.83 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET E-10 OF

PEAK STRESSES

CASE 4

$$S_p = \left[\sigma_{\text{ITER 27926}}^{\text{CRK}} + \sigma_{\text{PRES}} + \text{S.C.F.} (\sigma_{\text{THERM EXP}}) \right] - \text{COLD CONDITION}$$

$$= \left[-0.9 + 2.2(2.2) + 1.39(5.1) \right]$$

$$= 11.13 \text{ KSI}$$

CASE 5

$$S_p = \left[2 \times \text{OBE} \times \text{S.C.F.} \right]$$

$$= \left[19.9 (1.39) \right]$$

$$= 27.66 \text{ KSI}$$

USAGE FACTOR

$$\text{CASE 1 } S_{\text{ALT}} = K_e \frac{S_p}{2} = 3.33 \left(\frac{165.6}{2} \right)$$

$$= 276.0 \text{ KSI}$$

$$M_1 = 44$$

$$N_1 = 70$$

$$U_1 = \frac{M_1}{N_1} = \frac{44}{70} = .629$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET E-11 OF

USAGE FACTOR

CASE 2

$$S_{ALT} = K_c \left(\frac{S_D}{2} \right) = 2.2 \left(\frac{106.3}{2} \right) = 116.9 \text{ KSI}$$

$$N_2 = 40$$

$$N_2 = 830$$

$$U_2 = \frac{40}{830} = .048$$

CASE 3

$$S_{ALT} = \frac{S_D}{2} = \frac{25.83}{2} = 12.92 \text{ KSI}$$

$$N_3 = 30$$

$$N_3 = \infty$$

$$U_3 = 0.000$$

CASE 4

$$S_{ALT} = \frac{S_D}{2} = \frac{11.13}{2} = 5.57 \text{ KSI}$$

$$N_4 = 240$$

$$N_4 = \infty$$

$$U_4 = 0.000$$

CASE 5

$$S_{ALT} = \frac{S_D}{2} = \frac{27.66}{2} = 13.83 \text{ KSI}$$

$$N_5 = 620$$

$$N_5 = \infty$$

$$U_5 = 0.000$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY

JOB NO.

SHEET E-12 OF

USAGE FACTOR

$$U_{TOT} = U_1 + U_2 + U_3 + U_4 + U_5$$

$$= .629 + .048 + 0.000 + 0.000 + 0.000$$

$$= .677 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION

CHECKED DATE

BY


JOB NO.

SHEET E-13 OF

- F -

SPRAY NOZZLE

SPRAY NOZZLE VS 28" S.S. PIPE
TIME - TEMPERATURE PLOTS



REF.

— SPRAY NOZZLE AVERAGE TEMP (P95 Y-38 - Y-47)

- - - 28" S.S. PIPE AVERAGE TEMP (P95 Y-14 - Y-25)

MAX ΔT

11

SPRAY NOZZLE - PRIMARY PIPE BRANCH CONNECTION

PRI + SEC, EQ 10

$$S = C_1 \frac{PD_0}{2t} + C_2 \frac{M_D}{Z_b} + C_3 \frac{M_F}{Z_p} + \frac{1}{2(1-\nu)} E \Delta T + C_3 E_{cb} |\alpha_a T_a - \alpha_b T_b|$$

FROM THE SPRAY NOZZLE STRESS REPORT,
THE PRESSURE AND MOMENT TERMS ARE
STILL APPLICABLE.

$$\frac{1}{2(1-\nu)} E \Delta T = 12.3 \text{ KSI (REF 28" S.S. COMPUTER OUTPUT, ATTACHED)}$$

$$C_3 E_{cb} |\alpha_a T_a - \alpha_b T_b| = 1.8(28.4 \times 10^6) |8.70 \times 10^{-6}(427) - 8.70 \times 10^{-6}(398)| = 12.9 \text{ KSI}$$

NOTE THAT THE 427°F + 398°F WERE SELECTED FROM
THE ATTACHED COMPUTER OUTPUT OF THE 28" S.S. PIPE
AND THE SPRAY NOZZLE @ APPROX 40.0 MINUTES
WHICH IS WHERE THE MAX ΔT OCCURRED FOR THIS COOLDOWN.
R.G. STRESS FROM REPORT

(REF B.11 OF STRESS REPORT)

$$S = 30.5 + 5.5 + 8.6 + (5.0 + 12.3) + 12.9 = 74.8 \text{ KSI}$$
$$S = 74.8 \text{ KSI} > 3S_m = 51.3 \text{ KSI}$$

USING SIMPLIFIED ELASTIC PLASTIC
OF USAS B.31.7 - 1969

$$S_{net} = \frac{1}{2} [S_p + A(S_p - S_n)] \frac{S_n}{3S_m}$$

WHERE $\frac{S_n}{3S_m} = 1.48 \rightarrow A = .7$ (REF FIG D-201)

BABCOCK & WILCOX
DEPARTMENT

DATE BY

CHECKED DATE BY

JOB NO.

REVISION

SHEET F-2 OF

RADIAL GRADIENT STRESS FROM REPORT

Ref Pg
11a of
STRESS
REPORT

$$S_{PEAK} = 51.8 + 5.5 + 25.9 + 8.5 + K_2 C_2 E_1 \left[\frac{K_1 T_1 - K_1 T_2}{K_1 (2 - \nu)} \right] E_{MAT_1} + \frac{1}{1 - \nu} E_{MAT_2}$$

$$= 51.8 + 5.5 + 25.9 + 8.5 + 1.7(12.9) + [1.7(12.3) + (17.0 - 12.3)]$$

$$= 139.2 \text{ KSI}$$

$$S_{ALT} = \frac{1}{2} [139.2 + .7(139.2 - 74.8)] \frac{74.8}{51.3} = 134.4$$

$$S_{ALT} = 134.4 \text{ KSI}$$

$$N_1 = 520 \text{ CYCLES}$$

$$U_1 = \frac{3}{520} = .006$$

ADDING U_1 TO THE U OF THE STRESS REPORT, REFP 13a.

$$U_{TOT} = .006 + .210 = .216$$

$$U_{TOT} = .212 < 1.0$$

BABCOCK & WILCOX
DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET F-3 OF

SPRAY NOZZLE AT START OF TAPER

PRI + SEC, EQ 10

$$S_n = C_1 \frac{PD_0}{2t} + C_2 \frac{D_0 M_1}{2I} + \frac{1}{2(1-\nu)} E \alpha \Delta T + C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b|$$

FROM THE SPRAY NOZZLE STRESS REPORT, REF B-10, THE PRESSURE AND MOMENT TERMS ARE STILL APPLICABLE.

$$C_1 \frac{PD_0}{2t} = 13.4 \text{ KSI}$$

$$C_2 \frac{D_0 M_1}{2I} = 29.2 \text{ KSI}$$

} REF PG 9 OF B-10

$$\frac{1}{2(1-\nu)} E \alpha \Delta T = 5.8 \text{ KSI (REF SPRAY NOZZLE COMPUTER OUTPUT)}$$

$$C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b| = 1.0 (29.42 \times 10^6) |8.7 \times 10^{-6} (590) - 8.7 \times 10^{-6} (280)| = 76.6 \text{ KSI}$$

$C_3 E_{ab} |\alpha_a T_a - \alpha_b T_b|$ WAS CONSERVATIVELY CALCULATED ASSUMING A MAX ΔT OF 310°F . (310° COMES FROM THE MAX ΔT OF THE FLUID TEMP, 590°F @ TIME 0435 MINUS 280°F @ TIME 0540.)

$$S_n = 13.4 + 29.2 + 5.8 + 76.6 = 125.0 \text{ KSI}$$

$$S_n = 125.0 > 3 S_m = 51.3 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET F-4 OF

PEAK STRESSES, EQ 11

$$S_p = K_1 C_1 \frac{P D_0}{2t} + K_2 C_2 \frac{D_0 M_i}{2I} + \frac{1}{2(1-\nu)} K_3 E \Delta T_1 + \frac{1}{1-\nu} E \Delta T_2 + K_3 C_3 E \alpha_b |\alpha_a T_a - \alpha_b T_b|$$

FROM THE SPRAY NOZZLE STRESS REPORT, REF B-10,
THE PRESSURE AND MOMENT TERMS ARE STILL APPLICABLE

$$\left. \begin{aligned} K_1 C_1 \frac{P D_0}{2t} &= 20.1 \text{ KSI} \\ K_2 C_2 \frac{D_0 M_i}{2I} &= 52.5 \text{ KSI} \end{aligned} \right\} \text{pg 14 OF B-10}$$

$$\left. \begin{aligned} K_3 \frac{1}{2(1-\nu)} E \Delta T_1 &= 1.5 (5.8) = 8.7 \text{ KSI} \\ \frac{1}{1-\nu} E \Delta T_2 &= 9.3 - 5.8 = 3.5 \text{ KSI} \end{aligned} \right\} \text{REF SPRAY NOZZLE COMPUTER OUTPUT}$$

$$K_3 C_3 E \alpha_b |\alpha_a T_a - \alpha_b T_b| = 1.5 (76.6) = 114.9 \text{ KSI}$$

$$S_p = 20.1 + 52.5 + 8.7 + 3.5 + 114.9 = 199.7 \text{ KSI}$$

$$S_{ALT} = \frac{1}{2} [S_p + A (S_p - S_m)] \frac{S_m}{3S_m}$$

$$A = .7 \text{ REF FIG D-201 OF B-1}$$

$$S_{ALT} = \frac{1}{2} [199.7 + .7(199.7 - 125.0)] \frac{125.0}{51.3} = 307.0 \text{ KSI}$$

$$N_1 = 52 \text{ CYCLES}$$

$$U_1 = \frac{1}{52} = .019$$

ADDING U_1 TO U OF REPORT, PG 15,

$$U_{TOT} = .444 + .019 = .463 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.


REVISION

SHEET F-5 OF

- G -

DECAY HEAT
NOZZLE

DECAY HEAT NOZZLE VS 36° PRIMARY PIPE
TIME - TEMPERATURE PLOTS



DECAY HEAT NOZZLE
BRANCH CONNECTION

PRI + SEC; EQ 10

$$S = C_1 \frac{PD_0}{2t} + C_{2A} \frac{M_B}{Z_B} + C_{2B} \frac{M_B}{Z_B} + \frac{1}{2(1-\nu)} E \Delta T$$

$$+ C_3 E \alpha_b |\alpha_a T_a - \alpha_b T_b|$$

FROM DELAY HEAT NOZZLE STRESS REPORT, THE PRESSURE AND MOMENT TERMS ARE STILL APPLICABLE.

$$\frac{1}{2(1-\nu)} E \Delta T = 6.8 \text{ KSI (REF 36° ELBOW COMPUTER OUTPUT, ATTACHED)}$$

$$C_3 E \alpha_b |\alpha_a T_a - \alpha_b T_b| = 1.8 (29.67 \times 10^6) |6.12 \times 10^{-6} (433^\circ) - 6.12 \times 10^{-6} (381^\circ)| = 17.0 \text{ KSI}$$

THE 433° + 381° IS THE MAX AT BETWEEN NOZZLE + BRANCH AND OCCURS @ 47.5 MINUTES. (SEE COMPUTER OUTPUT)

$$S = 31.2 + 10.2 + 19.7 + (3.9 + 6.8) + 17.0 = 88.8 \text{ KSI (REF Pg D-4 STRESS REPORT)}$$

$$S = 88.8 \text{ KSI} > 3S_m = 52.2 \text{ KSI FOR SA-105 Gr 2}$$

- USING SIMPLIFIED ELASTIC PLASTIC

$$\frac{S}{3S_m} = \frac{88.8}{52.2} = 1.70 ; \therefore A = 1.1 \text{ (REF FIG D-201)}$$

$$\frac{1}{1-\nu} E \Delta T$$

$$S_{\text{SPEC}} = 53.1 + 20.4 + 19.7 + 6.6 + K_3 C_3 E_b |\alpha_a T_a - \alpha_b T_b| + K_2 \frac{1}{2(1-\nu)} E \Delta T$$

$$\text{(REF B.D-10 STRESS REPORT)} = 53.1 + 20.4 + 19.7 + 6.6 + 1.7 (17.0) + [1.7 (6.8) + (9.5 - 6.8)]$$

$$= 143.0 \text{ KSI}$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET G-2 OF

$$S_{ALT} = \frac{1}{2} [S_p + A(S_p - S_n)] \frac{S_n}{S_{SM}}$$

$$S_{ALT} = \frac{1}{2} [1430 + 1.1(1430 - 88.8)] \frac{88.8}{52.2} = 172.3 \text{ KSI}$$

$$N_1 = 190 \text{ CYCLES}$$

$$U_1 = \frac{1}{150} = .007$$

ADDING U_1 TO THE PREVIOUS U OF THE STRESS REPORT,
 REF. P. D-14.

$$U_{TOT} = .007 + .679$$

$$U_{TOT} = .686 < 1.0$$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET 6-3 OF

APPENDIX

36" HOT LEG

$$Re = \frac{\rho V D}{\mu}$$

$$\rho = 42.3 \text{ lb/ft}^3 @ 600^\circ\text{F}$$

$$D = 3.0 \text{ ft}$$

$$\mu = 58 \times 10^{-6} \text{ lbm/ft-sec @ 600}^\circ\text{F}$$

$$\dot{M} = 92,400 \text{ GPM/PUMP}$$

$$\dot{M} = \frac{2(92,400) \text{ gal} \cdot 231 \text{ in}^3 \cdot \text{ft}^3}{\text{min} \cdot \text{gal} \cdot 1728 \text{ in}^3 \cdot 60 \text{ sec}} = 412 \text{ ft}^3/\text{sec}$$

$$V = \frac{\dot{M}}{A} = \frac{412 \text{ ft}^3/\text{sec}}{\pi (1.5)^2} = 58.3 \text{ ft/sec}$$

$$Re = \frac{42.3 (58.3)^3}{58 \times 10^{-6}} = 1.3 \times 10^8$$

$$[Gr_o Pr]_m = K_{cs} D^3 \Delta T$$

$$D = 3.0 \text{ ft}$$

$\Delta T =$ assume this is 10°F

$$K_{cs} = 4.4 \times 10^{10} \text{ from fig NC-23}$$

$$[Gr_o Pr]_m = 4.4 \times 10^{10} (3.0)^3 10 = 1.2 \times 10^{13}$$

SINCE $[Gr_o Pr]_m > 10^9$ AND FROM FIG FC-7, $Re_c = 1.3 \times 10^8 > Re_c = 2.5 \times 10^6$ THIS IS TURBULENT FLOW.

BABCOCK & WILCOX		REVISION
DEPARTMENT	DATE	BY
	CHECKED DATE	BY
	JOB NO.	SHEET <u>Y-1</u> OF

36" HOT LEG FILM COEFFICIENTS

THE HEAT TRANSFER FROM THE FLUID
TO THE HOT LEG FALLS IN THE TURBULENT
REGION II REGIME.

THE EQUATION FOR THE FILM COEFFICIENT
THEREFORE IS:

$$h = K_{104} \left(\frac{\dot{m}}{D} \right)^{0.75}$$

WHERE $D = 3.0 \text{ ft}$

$$\dot{m} = 2(92,400) \text{ GPM} = 412 \text{ ft}^3/\text{sec}$$

$$\begin{aligned} \dot{m} \left(\frac{\text{lb}}{\text{hr}} \right) &= \frac{412 \text{ ft}^3 \times 3600 \text{ sec} \times \rho \text{ lb}}{\text{sec} \times \text{hr} \times \text{ft}^3} \\ &= 1,483,200 \text{ P @ TEMP} \end{aligned}$$

IN ORDER TO TAKE INTO ACCOUNT THE AFFECT OF THE
CLADDING, AN EFFECTIVE FILM COEFFICIENT WILL BE
CALCULATED USING THE FOLLOWING FORMULA:

$$h_{\text{eff}} = \frac{1}{\frac{1}{h} + \frac{\Delta X}{K}}$$

WHERE $\Delta X = \text{MINIMUM THICKNESS OF S.S. CLADDING}$
 $K = \text{THERMAL CONDUCTIVITY OF S.S. @ TEMP.}$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET Y-2 OF

SAMPLE EFFECTIVE FILM COEFFICIENT
CALCULATION AT 600 °F

$$h = K_{100} \left(\frac{m \cdot g}{D \cdot F} \right) = .0295 \left[\frac{(41,200 (42.3))^{.8}}{(3.0)^{1.5}} \right] = 6788$$

$$h_{eff} = \frac{1}{\frac{1}{h} + \frac{\Delta X}{K}} = \frac{1}{\frac{1}{6788} + \frac{.125}{134.2}} = 927$$

36" HOT LEG FILM
COEFFICIENTS

TEMP °F	ρ_{H_2O} lb/ft ³	K_{ss} BTU/ft ² -HR-°F/IN	K_{100}	h BTU/HR FT ² °F	h_{eff} BTU/HR FT ² °F
600	42.3	134.2	.0295	6788	927
550	46.0	131.3	.0295	7298	918
500	49.0	128.5	.0275	7407	903
450	51.4	125.6	.0264	7388	885
400	53.7	122.7	.0252	7303	865
350	55.6	119.9	.0239	7122	845
300	57.3	117.0	.0222	6777	822
250	58.8	114.2	.0202	6295	798

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET Y-3 OF

28" COLD LEG
CARBON STEEL

$$Re = \frac{\rho V D}{\mu}$$

$$\rho = 42.3 \text{ lb/ft}^3 @ 600^\circ$$

$$D = \frac{28}{12} = 2.33 \text{ ft}$$

$$\mu = 58 \times 10^{-6} \text{ lbm/ft-sec @ } 600^\circ \text{ F}$$

$$\dot{M} = 92,400 \text{ GPM/PUMP}$$

$$\dot{M} = \frac{92,400 \text{ gal} \times 2.31 \text{ ft}^3/\text{gal}}{1728 \text{ in}^3/\text{ft}^3 \times 60 \text{ sec}} = 206 \text{ ft}^3/\text{sec}$$

$$= 206 \text{ ft}^3/\text{sec}$$

$$V = \frac{\dot{M}}{A} = \frac{206}{\pi (1.17)^2} = 47.9 \text{ ft/sec}$$

$$Re = \frac{42.3 (47.9) 2.33}{58 \times 10^{-6}} = 8.2 \times 10^7$$

$$[Gr_D Pr]_m = K_{sa} D^3 \Delta T$$

$$D = 2.33 \text{ ft}$$

$$\Delta T = \text{assume } 10^\circ \text{ F}$$

$$K_{sa} = 4.4 \times 10^{10} \text{ from fig NC-23}$$

$$[Gr_D Pr]_m = 4.4 \times 10^{10} (2.33)^3 10 = 5.6 \times 10^{12}$$

SINCE $[Gr_D Pr] > 10^9$ AND FROM FIG EC-7, $Re_0 = 8.2 \times 10^7 > Re_c = 1.8 \times 10^6$ THIS IS TURBULENT II FLOW.

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET Y-4 OF

28" CARBON STEEL FILMS
COEFFICIENTS

THE HEAT TRANSFER FROM THE FLUID
TO THE HOT LEG FALLS IN THE TURBULENT
REGION II REGIME.

THE EQUATION FOR THE FILM
COEFFICIENT THEREFORE IS:

$$h = K_{104} \left(\frac{\dot{m}^{.8}}{D^{1.5}} \right)$$

WHERE $D = 2.33 \text{ ft}$
 $\dot{m} = 92,400 = 206 \text{ ft}^3/\text{sec}$

$$\dot{m} \left(\frac{\text{lb}}{\text{hr}} \right) = \frac{206 \text{ ft}^3 \times 3600 \text{ sec/hr} \times \rho_{16}}{\text{ft}^3} \\ = 741,600 \times \rho @ \text{TEMP}$$

IN ORDER TO TAKE INTO ACCOUNT THE AFFECT
OF THE CLADDING, AN EFFECTIVE FILM
COEFFICIENT WILL BE CALCULATED USING:

$$h_{\text{eff}} = \frac{1}{\frac{1}{h} + \frac{AX}{K}}$$

WHERE $AX = \text{MIN. THICKNESS OF S.S. CLADDING}$
 $K = \text{THERMAL CONDUCTIVITY OF S.S. @ TEMP}$

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

CHECKED DATE

BY

JOB NO.

REVISION

SHEET Y-5 OF

SAMPLE EFFECTIVE FILM COEF
CALCULATION AT 600°F

$$h = K_{104} \left(\frac{m}{D^{1.8}} \right) = .0295 \left(\frac{((741,600)(42.3))^{1.8}}{(2.33)^{1.8}} \right) = 6394$$

$$h_{eff} = \frac{1}{\frac{1}{h} + \frac{A_1}{K}} = \frac{1}{\frac{1}{6394} + \frac{.125}{134.2}} = 919$$

28" CARBON STEEL COLD LEG

TEMP °F	P_{H_2O} lb/ft ³	$K_{s.s.}$ BTU/ft ² -hr-°F/in	K_{104}	h BTU/hr-ft ² -°F	h_{eff} BTU/hr-ft ² -°F
600	42.3	134.2	.0295	6394	919
550	46.0	131.3	.0285	6606	906
500	49.0	128.5	.0275	6705	891
450	51.4	125.6	.0264	6688	874
400	53.7	122.7	.0252	6611	855
350	55.6	119.9	.0239	6447	835
300	57.3	117.0	.0222	6134	812
250	58.8	114.2	.0202	5698	787

BABCOCK & WILCOX

DEPARTMENT

DATE

BY

REVISION


CHECKED DATE

BY

JOB NO.

SHEET Y-6 OF

28" STAINLESS STEEL STRAIGHT
SECTION FILM COEFFICIENTS
REF P9 Y-6



Y-7

2A INCH C.S. ELBOW, SMUD COOLDOWN INCIDENT TRANSIENT
FULL CERTIFICATION

91232 REV 4 12-15-74 05/08/78 10-18-04 PAGE 2
FULL CERTIFICATION 502CCGR

2B INCH C.S. ELBOW, SMUD COOLDOWN INCIDENT TRANSIENT

DATE 05/08/78

DIMENSIONS

INSIDE RADIUS = 14.2500 INCHES OUTSIDE RADIUS = 17.3750 INCHES REF A-3
NO. OF NODES = 9 RADIAL INCREMENT = .3906 INCHES
MATERIAL CODE = 1 POISSON'S RATIO = .3000
L = 0.0000

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	14.2500	570.0
2	14.6406	570.0
3	15.0313	570.0
4	15.4219	570.0
5	15.8125	570.0
6	16.2031	570.0
7	16.5938	570.0
8	16.9844	570.0
9	17.3750	570.0

8-1

28 INCH C.S. ELBOW, SMUD COOLDOWN INCIDENT TRANSIENT DATE 05/08/78

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATION (MINUTES)	TEMPERATURE (MINUTES)	TIME APPROXIMATION (MINUTES)	COEFFICIENT	TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0-0.000	570.0	0-0.000	911.0	0-0.000	0.
5-0.000	570.0	5-0.000	911.0	0-0.000	0.
10-0.000	590.0	10-0.000	916.0	0-0.000	0.
15-0.000	525.0	15-0.000	999.0	0-0.000	0.
20-0.000	340.0	20-0.000	947.0	0-0.000	0.
40-0.000	300.0	40-0.000	912.0	0-0.000	0.
60-0.000	280.0	60-0.000	902.0	0-0.000	0.
95-0.000	285.0	95-0.000	905.0	0-0.000	0.
110-0.000	305.0	110-0.000	914.0	0-0.000	0.

REF
PG
Y-6

REF
PG
A-5

TEMPERATURE CALCULATION TIMES AND PRINTOUTS
 TIME INCREMENT (MINUTES) .2500
 TIME LIMIT (MINUTES) 110.000
 NUMBER OF PRINTOUTS 440.

DATE 05/08/78

24 INCH C.S. ELBOW, SMUD COOLDOWN INCIDENT TRANSIENT THERMAL STRESS

TIME	F3UV LIN. RAD	DELTA	DELTA2	STRESS INSIDE	STRESS OUTSIDE	TEMPERATURE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
1.2500	-0.000	-0.000	-0.000	-0.000	-0.000	16.51	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
1.5000	-0.000	-0.000	-0.000	-0.000	-0.000	100.156	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
1.7500	-0.000	-0.000	-0.000	-0.000	-0.000	217.363	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.0000	-0.000	-0.000	-0.000	-0.000	-0.000	290.404	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.2500	-0.000	-0.000	-0.000	-0.000	-0.000	363.445	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.5000	-0.000	-0.000	-0.000	-0.000	-0.000	436.486	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.7500	-0.000	-0.000	-0.000	-0.000	-0.000	509.527	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.0000	-0.000	-0.000	-0.000	-0.000	-0.000	582.568	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.2500	-0.000	-0.000	-0.000	-0.000	-0.000	655.609	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.5000	-0.000	-0.000	-0.000	-0.000	-0.000	728.650	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.7500	-0.000	-0.000	-0.000	-0.000	-0.000	801.691	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.0000	-0.000	-0.000	-0.000	-0.000	-0.000	874.732	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.2500	-0.000	-0.000	-0.000	-0.000	-0.000	947.773	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.5000	-0.000	-0.000	-0.000	-0.000	-0.000	1020.814	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.7500	-0.000	-0.000	-0.000	-0.000	-0.000	1093.855	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.0000	-0.000	-0.000	-0.000	-0.000	-0.000	1166.896	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.2500	-0.000	-0.000	-0.000	-0.000	-0.000	1239.937	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.5000	-0.000	-0.000	-0.000	-0.000	-0.000	1312.978	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.7500	-0.000	-0.000	-0.000	-0.000	-0.000	1386.019	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.0000	-0.000	-0.000	-0.000	-0.000	-0.000	1459.060	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.2500	-0.000	-0.000	-0.000	-0.000	-0.000	1532.101	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.5000	-0.000	-0.000	-0.000	-0.000	-0.000	1605.142	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.7500	-0.000	-0.000	-0.000	-0.000	-0.000	1678.183	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.0000	-0.000	-0.000	-0.000	-0.000	-0.000	1751.224	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.2500	-0.000	-0.000	-0.000	-0.000	-0.000	1824.265	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.5000	-0.000	-0.000	-0.000	-0.000	-0.000	1897.306	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.7500	-0.000	-0.000	-0.000	-0.000	-0.000	1970.347	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.0000	-0.000	-0.000	-0.000	-0.000	-0.000	2043.388	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.2500	-0.000	-0.000	-0.000	-0.000	-0.000	2116.429	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.5000	-0.000	-0.000	-0.000	-0.000	-0.000	2189.470	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.7500	-0.000	-0.000	-0.000	-0.000	-0.000	2262.511	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
9.0000	-0.000	-0.000	-0.000	-0.000	-0.000	2335.552	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00

24 INCH C.S. ELBOW, SMUD COOLDOWN INCIDENT TRANSIENT

DATE 05/08/78

TIME	EQJIV RAD	LIN. STM.	THERMAL STRESS		NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9		
			DELTA1	DELTA2										INSIDE	OUTSIDE
20.0000		4946.	36.419	7.506	7205.	-3014.	534.86	544.74	552.85	559.30	564.29	567.99	570.53	572.01	572.44
20.2500		5074.	37.386	7.320	7243.	-3115.	532.68	542.34	550.52	557.14	562.32	566.17	568.83	570.38	570.88
20.5000		5144.	37.904	7.086	7272.	-3182.	530.72	540.27	548.38	555.05	560.33	564.31	567.06	568.67	569.20
20.7500		5188.	38.193	6.830	7277.	-3224.	528.82	538.29	546.36	553.04	558.38	562.43	565.25	566.91	567.45
21.0000		5216.	38.367	6.527	7265.	-3240.	525.96	535.34	544.40	551.08	556.55	560.54	563.01	564.65	565.19
21.2500		5219.	38.417	6.157	7256.	-3246.	525.11	534.67	542.48	549.27	554.55	558.66	561.56	563.27	563.83
21.5000		5222.	38.435	6.709	7246.	-3271.	521.28	532.60	540.54	547.27	552.55	556.78	559.69	561.41	561.98
21.7500		5221.	38.420	6.674	7235.	-3274.	521.65	530.75	538.72	545.38	550.77	554.90	557.82	559.55	560.12
22.0000		5216.	38.386	6.548	7223.	-3273.	519.63	528.60	535.86	543.51	548.89	553.03	555.95	557.68	558.25
22.2500		5216.	38.339	6.628	7211.	-3270.	517.81	527.36	535.00	541.64	547.02	551.15	554.07	555.80	556.37
22.5000		5203.	38.244	6.611	7209.	-3267.	515.99	525.21	533.15	539.78	545.15	549.24	552.19	553.92	554.49
22.7500		5194.	38.226	6.526	7189.	-3262.	514.17	523.33	531.30	537.92	543.28	547.40	550.32	552.05	552.61
23.0000		5188.	38.164	6.541	7176.	-3259.	512.36	521.54	529.45	535.06	541.51	545.53	548.64	550.17	550.74
23.2500		5174.	38.102	6.571	7165.	-3257.	510.54	519.74	527.61	534.21	539.55	543.66	546.56	548.29	548.86
23.5000		5171.	38.033	6.560	7153.	-3249.	508.73	517.91	525.76	532.35	537.68	541.74	544.69	546.61	547.18
23.7500		5163.	37.976	6.549	7142.	-3242.	506.91	516.07	523.92	530.50	535.82	539.92	542.82	544.53	545.10
24.0000		5155.	37.913	6.539	7130.	-3237.	505.10	514.24	522.08	528.54	533.96	538.05	540.95	542.66	543.22
24.2500		5146.	37.851	6.529	7119.	-3232.	503.29	512.41	520.24	526.79	532.10	536.18	539.07	540.78	541.35
24.5000		5138.	37.789	6.519	7108.	-3227.	501.47	510.58	518.40	524.94	530.24	534.32	537.20	538.91	539.47
24.7500		5130.	37.727	6.509	7097.	-3222.	499.65	508.75	515.56	523.09	528.38	532.45	535.33	537.03	537.60
25.0000		5122.	37.665	6.499	7086.	-3217.	497.84	505.91	512.72	521.24	526.52	530.58	533.45	535.16	535.72
25.2500		5114.	37.603	6.489	7075.	-3212.	496.03	505.13	510.88	519.49	524.66	528.72	531.59	533.29	533.85
25.5000		5107.	37.541	6.480	7065.	-3207.	494.21	503.27	511.04	517.54	522.80	526.86	529.72	531.42	531.98
25.7500		5099.	37.491	6.470	7054.	-3202.	492.40	501.44	509.20	515.69	520.95	524.99	527.85	529.55	530.11
26.0000		5091.	37.433	6.461	7044.	-3197.	490.59	499.62	507.36	513.84	519.09	523.13	525.98	527.68	528.23
26.2500		5084.	37.376	6.452	7033.	-3192.	488.77	497.79	505.52	512.00	517.23	521.27	524.12	525.81	526.36
26.5000		5076.	37.319	6.442	7023.	-3187.	486.96	495.95	503.68	510.15	515.38	519.41	522.25	523.94	524.49
26.7500		5068.	37.263	6.433	7013.	-3183.	485.15	494.14	501.85	508.30	513.52	517.54	520.38	522.07	522.62
27.0000		5061.	37.207	6.424	7003.	-3178.	483.33	492.31	500.01	506.45	511.57	515.54	518.32	520.00	520.55
27.2500		5054.	37.152	6.415	6993.	-3173.	481.52	490.44	498.17	504.61	509.82	513.82	516.55	518.24	518.79
27.5000		5046.	37.095	6.406	6983.	-3169.	479.71	488.64	496.34	502.75	507.95	511.96	514.79	516.47	517.02
27.7500		5039.	37.044	6.398	6973.	-3164.	477.90	486.84	494.50	500.92	506.11	510.10	512.93	514.60	515.16
28.0000		5032.	36.990	6.390	6963.	-3160.	476.08	485.01	492.57	499.07	504.26	508.25	511.07	512.74	513.29
28.2500		5025.	36.937	6.380	6953.	-3155.	474.27	483.19	490.83	497.23	502.40	506.39	509.20	510.87	511.42
28.5000		5018.	36.884	6.372	6944.	-3151.	472.46	481.37	488.99	495.38	500.55	504.53	507.34	509.01	509.56
28.7500		5011.	36.832	6.353	6934.	-3146.	470.65	479.54	487.16	493.54	499.70	503.67	506.48	508.15	508.70
29.0000		5004.	36.780	6.355	6925.	-3142.	468.83	477.71	485.32	491.69	496.85	500.82	503.62	505.28	505.83
29.2500		4997.	36.724	6.346	6915.	-3137.	467.02	475.84	483.49	489.85	495.00	498.96	501.76	503.42	503.97
29.5000		4990.	36.674	6.338	6906.	-3133.	465.21	474.07	481.66	488.01	493.15	497.10	500.90	501.56	502.11
29.7500		4983.	36.627	6.329	6896.	-3129.	463.40	472.24	479.82	486.17	491.30	495.25	498.04	499.70	500.24

Y-12

2# INCH C.S. ELHOW, SHUD COOLDOWN INCIDENT TRANSIENT THERMAL STRESS INSIDE THERMAL STRESS OUTSIDE DATE 05/08/78

TIME	EQUIV LIN. RAD	DELTA	DELTA	INSIDE THERMAL STRESS	OUTSIDE THERMAL STRESS	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
30.0000	6976	36.527	6.312	6884	-3120	451.57	470.42	477.99	449.32	485.45	433.54	496.12	497.83	493.38
30.2500	6969	36.527	6.312	6874	-3120	459.77	466.77	476.15	440.64	487.60	441.54	492.32	497.83	495.52
30.5000	6963	36.428	6.305	6868	-3115	456.15	465.95	474.32	440.64	485.75	449.83	492.32	497.83	495.52
30.7500	6956	36.428	6.297	6859	-3112	456.15	465.95	472.49	478.90	483.90	449.83	492.32	497.83	495.52
31.0000	6950	36.390	6.290	6850	-3107	456.30	463.12	470.65	476.96	482.05	445.04	491.75	497.83	495.52
31.2500	6943	36.332	6.280	6841	-3103	452.31	461.39	468.82	475.11	480.21	444.17	491.75	497.83	495.52
31.5000	6936	36.283	6.272	6832	-3099	450.72	461.39	465.99	473.21	478.36	444.17	491.75	497.83	495.52
31.7500	6930	36.236	6.265	6823	-3095	448.09	457.64	463.16	471.43	476.51	440.52	491.75	497.83	495.52
32.0000	6923	36.188	6.257	6814	-3091	447.09	455.81	463.32	469.59	474.66	478.96	491.75	497.83	495.52
32.2500	6917	36.141	6.249	6805	-3087	445.24	455.01	461.49	467.75	472.82	476.71	491.75	497.83	495.52
32.5000	6910	36.094	6.241	6796	-3083	443.67	452.19	459.66	465.91	470.97	474.86	491.75	497.83	495.52
32.7500	6904	36.047	6.233	6787	-3079	441.66	450.37	457.83	463.07	469.12	473.01	491.75	497.83	495.52
33.0000	6897	36.001	6.225	6778	-3074	439.85	448.53	456.00	462.23	467.28	471.16	491.75	497.83	495.52
33.2500	6890	35.954	6.214	6770	-3070	438.04	446.72	454.16	460.39	465.43	469.31	491.75	497.83	495.52
33.5000	6883	35.908	6.202	6761	-3065	436.23	444.91	452.33	458.55	463.58	467.40	491.75	497.83	495.52
33.7500	6876	35.861	6.202	6752	-3062	434.41	443.08	450.50	456.73	461.74	465.59	491.75	497.83	495.52
34.0000	6872	35.817	6.195	6744	-3058	432.60	441.25	448.67	454.87	459.89	463.76	491.75	497.83	495.52
34.2500	6865	35.772	6.187	6735	-3054	430.79	439.43	446.84	453.03	458.05	461.91	491.75	497.83	495.52
34.5000	6859	35.727	6.180	6726	-3050	428.94	437.61	445.01	451.20	456.20	460.06	491.75	497.83	495.52
34.7500	6853	35.682	6.172	6718	-3045	427.17	435.79	443.18	449.36	454.35	458.21	491.75	497.83	495.52
35.0000	6847	35.637	6.165	6709	-3043	425.36	433.97	441.35	447.52	452.51	456.36	491.75	497.83	495.52
35.2500	6840	35.593	6.157	6701	-3038	423.55	432.15	439.52	445.68	450.67	454.51	491.75	497.83	495.52
35.5000	6836	35.549	6.150	6692	-3035	421.74	430.33	437.69	443.84	448.83	452.65	491.75	497.83	495.52
35.7500	6829	35.505	6.142	6684	-3031	419.93	428.51	435.85	442.00	447.04	450.81	491.75	497.83	495.52
36.0000	6822	35.461	6.135	6675	-3027	418.12	426.69	434.02	440.17	445.14	449.00	491.75	497.83	495.52
36.2500	6816	35.417	6.127	6667	-3023	416.30	424.88	432.19	438.33	443.29	447.11	491.75	497.83	495.52
36.5000	6810	35.374	6.120	6658	-3019	414.49	423.07	430.36	436.53	441.49	445.26	491.75	497.83	495.52
36.7500	6803	35.330	6.113	6650	-3015	412.68	421.25	428.53	434.65	439.61	443.41	491.75	497.83	495.52
37.0000	6797	35.287	6.106	6641	-3011	410.87	419.44	426.70	432.82	437.76	441.57	491.75	497.83	495.52
37.2500	6791	35.244	6.098	6633	-3008	409.05	417.64	424.87	431.08	435.92	439.72	491.75	497.83	495.52
37.5000	6785	35.201	6.091	6624	-3004	407.25	415.84	423.04	429.28	434.08	437.87	491.75	497.83	495.52
37.7500	6779	35.159	6.084	6616	-3000	405.44	414.04	421.21	427.51	432.23	436.02	491.75	497.83	495.52
38.0000	6773	35.116	6.077	6608	-2996	403.63	412.23	419.39	425.73	430.39	434.14	491.75	497.83	495.52
38.2500	6767	35.074	6.069	6600	-2992	401.82	410.43	417.56	423.95	428.55	432.23	491.75	497.83	495.52
38.5000	6761	35.032	6.062	6591	-2988	400.01	408.64	415.73	422.17	426.70	430.43	491.75	497.83	495.52
38.7500	6755	34.990	6.055	6583	-2984	398.20	406.84	413.90	420.39	424.86	428.55	491.75	497.83	495.52
39.0000	6749	34.947	6.048	6574	-2981	396.39	405.04	412.07	418.62	423.00	426.70	491.75	497.83	495.52
39.2500	6743	34.906	6.041	6565	-2977	394.58	403.23	410.24	416.79	421.18	424.86	491.75	497.83	495.52
39.5000	6737	34.864	6.034	6556	-2973	392.77	401.43	408.41	414.95	419.34	423.00	491.75	497.83	495.52
39.7500	6731	34.822	6.027	6550	-2970	390.96	399.63	406.58	413.11	417.49	421.18	491.75	497.83	495.52

2A INCH S.S. PIPE, SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION, 91232 REV A 12-15-76, 05/08/78, 10-18-09, PAGE 2
 FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION, FULL CERTIFICATION

DATE: 05/08/78

2A INCH S.S. PIPE, SNUD COOLDOWN INCIDENT TRANSIENT DIMENSIONS

INSIDE RADIUS = 14.0000 INCHES
 NO. OF NOTES = 0
 MATERIAL CODE = 3
 L = 0.0000
 OUTSIDE RADIUS = 16.7500 INCHES
 RADIAL INCREMENT = .3639 INCHES
 POISSON'S RATIO = .3000

NODE	INITIAL RADIUS	INITIAL TEMPERATURE
1	14.0000	570.0
2	14.3639	570.0
3	14.7278	570.0
4	15.0917	570.0
5	15.4556	570.0
6	15.8195	570.0
7	16.1834	570.0
8	16.5473	570.0
9	16.9112	570.0

DATE 05/08/78

24 INCH S.S. PIPE, SMUD COOLDOWN INCIDENT TRANSIENT

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATION (MINUTES)	INSIDE FLUID TEMPERATURE	TIME APPROXIMATION (MINUTES)	INSIDE FILM COEFFICIENT	TIME APPROXIMATION (MINUTES)	PRESSURE (PSI)
0.0000	570.0	0.0000	6520.0	0.0000	0.
5.0000	570.0	5.0000	6520.0	0.0000	0.
10.0000	590.0	10.0000	6635.0	0.0000	0.
15.0000	590.0	15.0000	6635.0	0.0000	0.
20.0000	525.0	20.0000	6525.0	0.0000	0.
40.0000	380.0	40.0000	6525.0	0.0000	0.
60.0000	300.0	60.0000	4134.0	0.0000	0.
80.0000	240.0	80.0000	4035.0	0.0000	0.
95.0000	245.0	95.0000	4035.0	0.0000	0.
110.0000	205.0	110.0000	4170.0	0.0000	0.

REF
 PG
 Y-6

TEMPERATURE CALCULATION TIMES AND PRINTOUTS
 TIME INCREMENT (MINUTES) .2500
 TIME LIMIT (MINUTES) 110.000
 NUMBER OF PRINTOUTS 660.

28 INCH S.S. PIPE FULL CERTIFICATION INCIDENT TRANSIENT FULL CERTIFICATION 10-18-89 PAGE 583CC62

28 INCH S.S. PIPE S-MUD COOLDOWN INCIDENT TRANSIENT THERMAL PROPERTIES DATE 05/08/78

TIME	INSIDE FLUID TEMP	INSIDE FILM COEFF	Avg. TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANS	DENSITY
30.000	433	6515	494.9492	28.2402	276	6.6E+07	0.05E-05	488.5719
30.250	431	6514	493.2049	28.1920	275	6.6E+07	0.05E-05	488.5769
30.500	429	6512	491.5056	28.1446	274	6.6E+07	0.05E-05	488.6222
30.750	427	6511	489.8404	27.9971	274	6.6E+07	0.05E-05	488.6775
31.000	425	6509	488.2104	27.8505	273	6.6E+07	0.05E-05	488.7328
31.250	423	6508	486.6155	27.7045	273	6.6E+07	0.05E-05	488.7881
31.500	421	6506	485.0554	27.5584	272	6.6E+07	0.05E-05	488.8434
31.750	419	6503	483.5293	27.4121	272	6.6E+07	0.05E-05	488.8987
32.000	416	6502	482.0371	27.2654	271	6.6E+07	0.05E-05	488.9540
32.250	414	6500	480.5789	27.1182	270	6.6E+07	0.05E-05	489.0093
32.500	411	6497	479.1521	27.0004	269	6.6E+07	0.05E-05	489.0646
32.750	409	6496	477.7565	27.1177	269	6.6E+07	0.05E-05	489.1199
33.000	407	6494	476.3912	27.0139	269	6.6E+07	0.05E-05	489.1752
33.250	405	6493	475.0560	26.9157	269	6.6E+07	0.05E-05	489.2305
33.500	403	6491	473.7507	26.8176	268	6.6E+07	0.05E-05	489.2858
33.750	401	6488	472.4744	26.7196	268	6.6E+07	0.05E-05	489.3411
34.000	399	6487	471.2371	26.6214	268	6.6E+07	0.05E-05	489.3964
34.250	397	6485	470.0392	26.5231	268	6.6E+07	0.05E-05	489.4517
34.500	395	6484	468.8707	26.4249	268	6.6E+07	0.05E-05	489.5070
34.750	393	6482	467.7312	26.3267	268	6.6E+07	0.05E-05	489.5623
35.000	391	6481	466.6207	26.2285	267	6.6E+07	0.05E-05	489.6176
35.250	389	6479	465.5382	26.1303	267	6.6E+07	0.05E-05	489.6729
35.500	387	6478	464.4837	26.0321	267	6.6E+07	0.05E-05	489.7282
35.750	385	6476	463.4572	25.9339	267	6.6E+07	0.05E-05	489.7835
36.000	383	6475	462.4587	25.8357	266	6.6E+07	0.05E-05	489.8388
36.250	381	6474	461.4872	25.7375	266	6.6E+07	0.05E-05	489.8941
36.500	379	6473	460.5427	25.6393	266	6.6E+07	0.05E-05	489.9494
36.750	377	6472	459.6252	25.5411	266	6.6E+07	0.05E-05	489.9747
37.000	375	6471	458.7347	25.4429	266	6.6E+07	0.05E-05	489.9747
37.250	373	6470	457.8692	25.3447	266	6.6E+07	0.05E-05	489.9747
37.500	371	6469	457.0287	25.2465	266	6.6E+07	0.05E-05	489.9747
37.750	369	6468	456.2122	25.1483	266	6.6E+07	0.05E-05	489.9747
38.000	367	6467	455.4197	25.0501	266	6.6E+07	0.05E-05	489.9747
38.250	365	6466	454.6512	24.9519	266	6.6E+07	0.05E-05	489.9747
38.500	363	6465	453.9067	24.8537	266	6.6E+07	0.05E-05	489.9747
38.750	361	6464	453.1862	24.7555	266	6.6E+07	0.05E-05	489.9747
39.000	359	6463	452.4897	24.6573	266	6.6E+07	0.05E-05	489.9747
39.250	357	6462	451.8172	24.5591	266	6.6E+07	0.05E-05	489.9747
39.500	355	6461	451.1687	24.4609	266	6.6E+07	0.05E-05	489.9747
39.750	353	6460	450.5442	24.3627	266	6.6E+07	0.05E-05	489.9747
40.000	351	6459	450.0000	24.2645	266	6.6E+07	0.05E-05	489.9747
40.250	349	6458	449.5265	24.1663	266	6.6E+07	0.05E-05	489.9747
40.500	347	6457	449.1230	24.0681	266	6.6E+07	0.05E-05	489.9747
40.750	345	6456	448.7895	23.9700	266	6.6E+07	0.05E-05	489.9747
41.000	343	6455	448.5260	23.8718	266	6.6E+07	0.05E-05	489.9747
41.250	341	6454	448.3225	23.7737	266	6.6E+07	0.05E-05	489.9747
41.500	339	6453	448.1790	23.6755	266	6.6E+07	0.05E-05	489.9747
41.750	337	6452	448.0955	23.5774	266	6.6E+07	0.05E-05	489.9747
42.000	335	6451	448.0720	23.4792	266	6.6E+07	0.05E-05	489.9747
42.250	333	6450	448.1085	23.3811	266	6.6E+07	0.05E-05	489.9747
42.500	331	6449	448.2050	23.2830	266	6.6E+07	0.05E-05	489.9747
42.750	329	6448	448.3615	23.1849	266	6.6E+07	0.05E-05	489.9747
43.000	327	6447	448.5780	23.0868	266	6.6E+07	0.05E-05	489.9747
43.250	325	6446	448.8545	22.9887	266	6.6E+07	0.05E-05	489.9747
43.500	323	6445	449.1910	22.8906	266	6.6E+07	0.05E-05	489.9747
43.750	321	6444	449.5875	22.7925	266	6.6E+07	0.05E-05	489.9747
44.000	319	6443	450.0440	22.6944	266	6.6E+07	0.05E-05	489.9747
44.250	317	6442	450.5605	22.5963	266	6.6E+07	0.05E-05	489.9747
44.500	315	6441	451.1370	22.4982	266	6.6E+07	0.05E-05	489.9747
44.750	313	6440	451.7735	22.4001	266	6.6E+07	0.05E-05	489.9747
45.000	311	6439	452.4700	22.3020	266	6.6E+07	0.05E-05	489.9747
45.250	309	6438	453.2265	22.2039	266	6.6E+07	0.05E-05	489.9747
45.500	307	6437	454.0430	22.1058	266	6.6E+07	0.05E-05	489.9747
45.750	305	6436	454.9195	22.0077	266	6.6E+07	0.05E-05	489.9747
46.000	303	6435	455.8560	21.9096	266	6.6E+07	0.05E-05	489.9747
46.250	301	6434	456.8525	21.8115	266	6.6E+07	0.05E-05	489.9747
46.500	299	6433	457.9090	21.7134	266	6.6E+07	0.05E-05	489.9747
46.750	297	6432	459.0255	21.6153	266	6.6E+07	0.05E-05	489.9747
47.000	295	6431	460.2020	21.5172	266	6.6E+07	0.05E-05	489.9747
47.250	293	6430	461.4385	21.4191	266	6.6E+07	0.05E-05	489.9747
47.500	291	6429	462.7350	21.3210	266	6.6E+07	0.05E-05	489.9747
47.750	289	6428	464.0915	21.2229	266	6.6E+07	0.05E-05	489.9747
48.000	287	6427	465.5080	21.1248	266	6.6E+07	0.05E-05	489.9747
48.250	285	6426	466.9845	21.0267	266	6.6E+07	0.05E-05	489.9747
48.500	283	6425	468.5210	20.9286	266	6.6E+07	0.05E-05	489.9747
48.750	281	6424	470.1175	20.8305	266	6.6E+07	0.05E-05	489.9747
49.000	279	6423	471.7740	20.7324	266	6.6E+07	0.05E-05	489.9747
49.250	277	6422	473.4905	20.6343	266	6.6E+07	0.05E-05	489.9747
49.500	275	6421	475.2670	20.5362	266	6.6E+07	0.05E-05	489.9747
49.750	273	6420	477.1035	20.4381	266	6.6E+07	0.05E-05	489.9747
50.000	271	6419	479.0000	20.3400	266	6.6E+07	0.05E-05	489.9747

28 INCH S.S. PIPE, 54UD COOLDOAN INCIDENT TRANSIENT FULL CERTIFICATION 10-18-89 PAGE 563CCGL

WIPER REV 4 12-15-78 RE-CERTIFICATION FULL CERTIFICATION ****

DATE 05/08/78

28 INCH S.S. PIPE, 54UD COOLDOAN INCIDENT TRANSIENT THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP.	INSIDE COEFF.	AVERAGE TEMP.	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF. OF EXPANSION	DENSITY
40.000	349.	6555.	224.700	24.309	250	2.35	0.000000	489.000
40.250	374.	6544.	225.061	24.159	250	2.35	0.000000	489.000
40.500	377.	6539.	225.457	24.072	249	2.35	0.000000	489.000
41.000	375.	6534.	225.480	23.931	249	2.35	0.000000	489.000
41.250	373.	6529.	225.760	23.763	246	2.35	0.000000	489.000
41.500	372.	6524.	226.250	23.549	245	2.35	0.000000	489.000
42.000	371.	6518.	226.777	23.285	244	2.35	0.000000	489.000
42.250	370.	6513.	227.311	23.085	243	2.35	0.000000	489.000
42.500	369.	6507.	227.850	22.851	242	2.35	0.000000	489.000
43.000	367.	6492.	228.406	22.585	242	2.35	0.000000	489.000
43.250	366.	6481.	228.979	22.287	240	2.35	0.000000	489.000
43.500	365.	6471.	229.567	22.065	239	2.35	0.000000	489.000
44.000	364.	6466.	230.169	21.817	239	2.35	0.000000	489.000
44.250	363.	6459.	230.793	21.541	239	2.35	0.000000	489.000
44.500	362.	6455.	231.430	21.237	239	2.35	0.000000	489.000
44.750	361.	6450.	232.084	20.907	237	2.35	0.000000	489.000
45.000	360.	6444.	232.754	20.554	237	2.35	0.000000	489.000
45.250	359.	6439.	233.439	20.177	237	2.35	0.000000	489.000
45.500	358.	6436.	234.137	19.777	235	2.35	0.000000	489.000
45.750	357.	6429.	234.847	19.354	235	2.35	0.000000	489.000
46.000	356.	6423.	235.566	18.908	234	2.35	0.000000	489.000
46.250	355.	6418.	236.294	18.440	234	2.35	0.000000	489.000
46.500	354.	6413.	237.030	17.951	233	2.35	0.000000	489.000
46.750	353.	6407.	237.774	17.441	233	2.35	0.000000	489.000
47.000	352.	6402.	238.525	16.909	233	2.35	0.000000	489.000
47.250	351.	6397.	239.284	16.356	232	2.35	0.000000	489.000
47.500	350.	6392.	240.050	15.782	232	2.35	0.000000	489.000
47.750	349.	6387.	240.823	15.187	231	2.35	0.000000	489.000
48.000	348.	6381.	241.604	14.571	231	2.35	0.000000	489.000
48.250	347.	6376.	242.392	13.934	230	2.35	0.000000	489.000
48.500	346.	6370.	243.187	13.276	230	2.35	0.000000	489.000
48.750	345.	6366.	243.989	12.600	229	2.35	0.000000	489.000
49.000	344.	6360.	244.797	11.906	229	2.35	0.000000	489.000
49.250	343.	6355.	245.611	11.195	229	2.35	0.000000	489.000
49.500	342.	6350.	246.431	10.467	228	2.35	0.000000	489.000
49.750	341.	6345.	247.256	9.723	228	2.35	0.000000	489.000
50.000	340.	6340.	248.086	8.964	228	2.35	0.000000	489.000

24 INCH S.S. PIPE, SMUD COOLDOWN INCIDENT TRANSIENT THERMAL PROPERTIES DATE 05/08/78

TIME	INSIDE FLUID TEMPERATURE	INSIDE COEFF. OF EXPANSION	AVE. TEMPERATURE	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF. OF EXPANSION	DENSITY
50.000	300.	6.345	373.0668	25.4031	222	2.64E+07	9.1E-05	490.420
50.250	300.	6.345	371.0497	25.4031	222	2.64E+07	9.1E-05	490.420
50.500	300.	6.345	370.1190	25.4031	222	2.64E+07	9.1E-05	490.420
50.750	300.	6.345	369.2829	25.4031	222	2.64E+07	9.1E-05	490.420
51.000	300.	6.345	368.5404	25.4031	222	2.64E+07	9.1E-05	490.420
51.250	300.	6.345	367.8925	25.4031	222	2.64E+07	9.1E-05	490.420
51.500	300.	6.345	367.3392	25.4031	222	2.64E+07	9.1E-05	490.420
51.750	300.	6.345	366.8815	25.4031	222	2.64E+07	9.1E-05	490.420
52.000	300.	6.345	366.5194	25.4031	222	2.64E+07	9.1E-05	490.420
52.250	300.	6.345	366.2528	25.4031	222	2.64E+07	9.1E-05	490.420
52.500	300.	6.345	366.0816	25.4031	222	2.64E+07	9.1E-05	490.420
52.750	300.	6.345	365.9957	25.4031	222	2.64E+07	9.1E-05	490.420
53.000	300.	6.345	365.9957	25.4031	222	2.64E+07	9.1E-05	490.420
53.250	300.	6.345	366.0816	25.4031	222	2.64E+07	9.1E-05	490.420
53.500	300.	6.345	366.2528	25.4031	222	2.64E+07	9.1E-05	490.420
53.750	300.	6.345	366.5194	25.4031	222	2.64E+07	9.1E-05	490.420
54.000	300.	6.345	366.8815	25.4031	222	2.64E+07	9.1E-05	490.420
54.250	300.	6.345	367.3392	25.4031	222	2.64E+07	9.1E-05	490.420
54.500	300.	6.345	367.8925	25.4031	222	2.64E+07	9.1E-05	490.420
54.750	300.	6.345	368.5404	25.4031	222	2.64E+07	9.1E-05	490.420
55.000	300.	6.345	369.2829	25.4031	222	2.64E+07	9.1E-05	490.420
55.250	300.	6.345	370.1190	25.4031	222	2.64E+07	9.1E-05	490.420
55.500	300.	6.345	371.0497	25.4031	222	2.64E+07	9.1E-05	490.420
55.750	300.	6.345	372.0829	25.4031	222	2.64E+07	9.1E-05	490.420
56.000	300.	6.345	373.2188	25.4031	222	2.64E+07	9.1E-05	490.420
56.250	300.	6.345	374.4573	25.4031	222	2.64E+07	9.1E-05	490.420
56.500	300.	6.345	375.7982	25.4031	222	2.64E+07	9.1E-05	490.420
56.750	300.	6.345	377.2414	25.4031	222	2.64E+07	9.1E-05	490.420
57.000	300.	6.345	378.7877	25.4031	222	2.64E+07	9.1E-05	490.420
57.250	300.	6.345	380.4370	25.4031	222	2.64E+07	9.1E-05	490.420
57.500	300.	6.345	382.1892	25.4031	222	2.64E+07	9.1E-05	490.420
57.750	300.	6.345	384.0452	25.4031	222	2.64E+07	9.1E-05	490.420
58.000	300.	6.345	386.0059	25.4031	222	2.64E+07	9.1E-05	490.420
58.250	300.	6.345	388.0712	25.4031	222	2.64E+07	9.1E-05	490.420
58.500	300.	6.345	390.3420	25.4031	222	2.64E+07	9.1E-05	490.420
58.750	300.	6.345	392.8192	25.4031	222	2.64E+07	9.1E-05	490.420
59.000	300.	6.345	395.5038	25.4031	222	2.64E+07	9.1E-05	490.420
59.250	300.	6.345	398.3958	25.4031	222	2.64E+07	9.1E-05	490.420
59.500	300.	6.345	401.4951	25.4031	222	2.64E+07	9.1E-05	490.420
59.750	300.	6.345	404.8026	25.4031	222	2.64E+07	9.1E-05	490.420
60.000	300.	6.345	408.3191	25.4031	222	2.64E+07	9.1E-05	490.420

24 INCH S.S. PIPE, 5000 COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 10-18-80 PAGE 10
 24 INCH S.S. PIPE, 5000 COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 10-18-80 PAGE 10

DATE 05/08/79

MECHANICAL PROPERTIES

TIME	INSIDE FLOW	INSIDE FLOW COEFF.	INSIDE FILM	AVE. TEMP.	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF. OF EXPANS.	DENSITY
60.000	300.	6134.	6134.	324.3784	19.5425	1202.	2.70E+07	0.0E+00	49.0000
60.250	300.	5132.	5132.	324.0000	19.6267	1202.	2.70E+07	0.0E+00	49.0000
60.500	300.	4131.	4131.	327.0752	19.5715	1202.	2.70E+07	0.0E+00	49.0000
60.750	299.	3129.	3129.	326.1128	19.5225	1202.	2.70E+07	0.0E+00	49.0000
61.000	299.	2125.	2125.	325.1128	19.4727	1202.	2.70E+07	0.0E+00	49.0000
61.250	298.	1124.	1124.	324.6690	19.4299	1202.	2.70E+07	0.0E+00	49.0000
61.500	298.	622.	622.	323.6690	19.3899	1202.	2.70E+07	0.0E+00	49.0000
61.750	298.	120.	120.	322.0650	19.3499	1202.	2.70E+07	0.0E+00	49.0000
62.000	298.	0.	0.	321.0650	19.3099	1202.	2.70E+07	0.0E+00	49.0000
62.250	298.	0.	0.	321.0650	19.2699	1202.	2.70E+07	0.0E+00	49.0000
62.500	297.	0.	0.	321.5511	19.2299	1202.	2.70E+07	0.0E+00	49.0000
62.750	297.	0.	0.	321.4002	19.1899	1202.	2.70E+07	0.0E+00	49.0000
63.000	297.	0.	0.	321.4002	19.1499	1202.	2.70E+07	0.0E+00	49.0000
63.250	297.	0.	0.	321.7110	19.1099	1202.	2.70E+07	0.0E+00	49.0000
63.500	297.	0.	0.	321.7110	19.0699	1202.	2.70E+07	0.0E+00	49.0000
63.750	296.	0.	0.	322.3221	19.0299	1202.	2.70E+07	0.0E+00	49.0000
64.000	296.	0.	0.	322.3221	18.9899	1202.	2.70E+07	0.0E+00	49.0000
64.250	296.	0.	0.	322.0426	18.9499	1202.	2.70E+07	0.0E+00	49.0000
64.500	296.	0.	0.	321.5555	18.9099	1202.	2.70E+07	0.0E+00	49.0000
64.750	295.	0.	0.	321.5555	18.8699	1202.	2.70E+07	0.0E+00	49.0000
65.000	295.	0.	0.	321.3304	18.8299	1202.	2.70E+07	0.0E+00	49.0000
65.250	295.	0.	0.	321.3304	18.7899	1202.	2.70E+07	0.0E+00	49.0000
65.500	295.	0.	0.	321.5401	18.7499	1202.	2.70E+07	0.0E+00	49.0000
65.750	294.	0.	0.	322.0554	18.7099	1202.	2.70E+07	0.0E+00	49.0000
66.000	294.	0.	0.	321.4914	18.6699	1202.	2.70E+07	0.0E+00	49.0000
66.250	294.	0.	0.	321.4914	18.6299	1202.	2.70E+07	0.0E+00	49.0000
66.500	294.	0.	0.	321.1612	18.5899	1202.	2.70E+07	0.0E+00	49.0000
66.750	293.	0.	0.	321.4144	18.5499	1202.	2.70E+07	0.0E+00	49.0000
67.000	293.	0.	0.	321.4144	18.5099	1202.	2.70E+07	0.0E+00	49.0000
67.250	293.	0.	0.	321.2771	18.4699	1202.	2.70E+07	0.0E+00	49.0000
67.500	292.	0.	0.	321.2771	18.4299	1202.	2.70E+07	0.0E+00	49.0000
67.750	292.	0.	0.	321.1144	18.3899	1202.	2.70E+07	0.0E+00	49.0000
68.000	292.	0.	0.	321.1144	18.3499	1202.	2.70E+07	0.0E+00	49.0000
68.250	291.	0.	0.	321.2110	18.3099	1202.	2.70E+07	0.0E+00	49.0000
68.500	291.	0.	0.	321.2110	18.2699	1202.	2.70E+07	0.0E+00	49.0000
68.750	291.	0.	0.	321.2616	18.2299	1202.	2.70E+07	0.0E+00	49.0000
69.000	290.	0.	0.	321.2616	18.1899	1202.	2.70E+07	0.0E+00	49.0000
69.250	290.	0.	0.	321.3249	18.1499	1202.	2.70E+07	0.0E+00	49.0000
69.500	290.	0.	0.	321.3249	18.1099	1202.	2.70E+07	0.0E+00	49.0000
69.750	289.	0.	0.	321.0720	18.0699	1202.	2.70E+07	0.0E+00	49.0000
70.000	289.	0.	0.	321.0720	18.0299	1202.	2.70E+07	0.0E+00	49.0000

TIME	EQUIV LIM.	DELTA	DELTA 2	INCIDENT THERMAL STRESS INSIDE	TRANSIENT THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
0.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
0.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
1.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
1.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
2.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
3.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
4.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
5.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
6.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
7.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
8.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
9.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
9.500	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00
10.000	0.000	0.000	0.000	0.000	0.000	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00	570.00

2R INCH S.S. PIPE, SMUD COOLDOWN INCIDENT TRANSIENT

DATE 05/08/78

TIME	EQUIV LIN. RAD	THERMAL STRESS		THERMAL STRESS		NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
		DELTA 1	DELTA 2	INSIDE	OUTSIDE									
0.0000	-2453.	-6.224	-3.941	-4363.	699.	589.72	584.83	581.00	578.07	575.90	574.34	573.31	572.72	572.53
0.2500	-2449.	-6.436	-3.394	-4181.	765.	589.74	585.42	581.68	578.68	576.42	574.79	573.70	573.08	572.88
0.5000	-2440.	-6.389	-3.903	-4037.	769.	589.76	582.77	582.21	579.24	576.94	575.25	574.11	573.45	573.24
0.7500	-2448.	-6.207	-2.777	-3902.	773.	589.77	586.03	582.63	579.74	577.43	575.71	574.53	573.85	573.63
1.0000	-2402.	-5.942	-2.674	-3774.	765.	589.78	585.24	582.39	579.18	577.90	576.16	574.95	574.25	574.02
1.2500	-2745.	-5.622	-2.573	-3652.	766.	589.79	585.41	583.30	580.57	578.33	576.50	575.34	574.67	574.43
1.5000	-2583.	-5.287	-2.479	-3535.	720.	589.80	585.57	583.57	580.93	578.73	577.02	575.81	575.09	574.85
1.7500	-2617.	-4.891	-2.390	-3423.	647.	589.81	585.71	583.42	581.26	579.11	577.43	576.22	575.51	575.27
2.0000	-2564.	-4.592	-2.307	-3312.	650.	589.82	585.87	584.05	581.57	579.48	577.82	576.63	575.92	575.69
2.2500	-2474.	-4.107	-2.229	-3211.	611.	589.83	585.94	584.26	581.86	579.82	578.20	577.04	576.33	576.10
2.5000	-2409.	-3.711	-2.154	-3111.	570.	589.83	587.05	584.65	582.13	580.15	578.57	577.43	576.74	576.51
2.7500	-2340.	-3.317	-2.084	-3014.	528.	589.84	587.15	584.64	582.39	580.46	578.93	577.41	576.13	575.91
3.0000	-2271.	-2.928	-2.016	-2920.	485.	589.84	587.25	584.42	582.63	580.77	579.27	578.18	577.52	577.30
3.2500	-2204.	-2.545	-1.952	-2830.	443.	589.85	587.34	584.49	582.87	581.06	579.60	578.54	577.90	577.69
3.5000	-2138.	-2.171	-1.899	-2742.	401.	589.85	587.42	584.51	583.04	581.35	579.92	578.84	578.27	578.05
3.7500	-2074.	-1.804	-1.830	-2657.	360.	589.86	587.51	584.53	583.31	581.61	580.23	579.23	578.63	578.42
4.0000	-2011.	-1.447	-1.773	-2575.	319.	589.86	587.54	584.55	583.52	581.47	580.54	579.54	578.97	578.78
4.2500	-1950.	-1.099	-1.714	-2495.	278.	589.87	587.65	584.54	583.72	581.12	580.83	579.84	579.31	579.12
4.5000	-1899.	-0.760	-1.654	-2418.	241.	589.87	587.71	584.57	583.92	582.37	581.11	580.20	579.64	579.45
4.7500	-1832.	-0.431	-1.592	-2343.	203.	589.87	587.80	584.56	584.11	582.60	581.39	580.50	579.95	579.78
5.0000	-1774.	-0.111	-1.532	-2271.	167.	589.88	587.87	584.99	584.29	582.83	581.65	580.79	580.27	580.09
5.2500	-1658.	-0.302	-1.470	-2186.	104.	589.88	587.87	584.99	584.43	583.05	581.91	581.07	580.57	580.40
5.5000	-1008.	-5.738	2.416	-177.	871.	589.89	587.87	584.99	584.57	583.20	582.14	581.35	580.86	580.69
5.7500	-494.	-2.811	3.637	786.	580.	589.89	587.87	584.99	584.61	584.05	583.21	582.32	581.83	581.66
6.0000	55.	3.316	4.866	1711.	292.	577.20	581.45	583.22	583.51	583.07	582.40	581.74	581.38	581.24
6.2500	624.	3.549	5.302	2601.	-22.	574.01	579.25	581.85	582.77	582.78	582.39	581.93	581.59	581.47
6.5000	1209.	6.829	6.244	3454.	-154.	570.81	575.94	580.33	581.89	582.36	582.27	581.99	581.75	581.63
6.7500	1777.	10.114	6.899	4247.	-634.	567.61	574.57	578.70	580.88	581.81	582.05	581.79	581.55	581.44
7.0000	2351.	13.376	7.446	5087.	-1049.	564.41	572.15	576.94	579.75	581.15	581.73	581.84	581.84	581.86
7.2500	2917.	16.596	8.021	5861.	-1399.	561.20	569.64	575.14	578.53	580.39	581.31	581.70	581.83	581.85
7.5000	3474.	19.759	8.512	6611.	-1750.	557.94	567.17	573.32	577.22	579.54	580.80	581.63	581.69	581.77
7.7500	4019.	22.858	8.973	7336.	-2035.	554.78	564.61	571.40	575.84	578.60	580.21	581.07	581.48	581.60
8.0000	4552.	25.884	9.402	8039.	-2318.	551.56	562.06	569.42	574.38	577.58	579.52	580.64	581.19	581.35
8.2500	5071.	28.835	9.804	8720.	-2773.	548.35	559.45	567.34	572.86	576.48	578.77	580.11	580.81	581.02
8.5000	5574.	31.704	10.195	9380.	-3100.	545.13	556.81	565.32	571.24	575.32	577.93	579.51	580.35	580.60
8.7500	6071.	34.504	10.554	10020.	-3420.	541.91	554.13	563.21	569.65	574.00	577.02	578.83	579.80	580.11
9.0000	6550.	37.221	10.814	10661.	-3732.	538.69	551.53	561.06	567.46	572.79	576.03	578.07	579.14	579.53
9.2500	7015.	39.861	11.257	11243.	-4035.	535.47	548.84	558.88	565.22	571.63	574.98	577.24	578.48	579.07
9.5000	7464.	42.423	11.544	11826.	-4331.	532.24	546.14	556.66	562.43	570.01	573.46	575.33	577.70	578.36
9.7500	7907.	44.910	11.800	12392.	-4619.	529.02	543.41	554.40	562.60	568.54	572.67	575.35	578.85	579.33

12-1

24 INCH S.S. PIPE, SMUD COOLDOWN INCIDENT TRANSIENT

DATE '05/08/78

TIME	EQUIV RAD	LIN. STN.	THERMAL STRESS		NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
			DELTA 1	DELTA 2									
20.0000	9333.	47.324	2.204	2942.	525.80	540.67	552.12	560.72	567.01	571.82	574.91	575.93	575.45
20.2500	8630.	44.001	1.572	3021.	523.98	538.30	549.89	554.82	565.43	570.11	573.19	574.93	575.49
20.5000	8856.	50.272	1.190	3119.	522.15	536.27	547.84	556.96	563.52	568.74	572.01	573.47	574.47
20.7500	9049.	51.311	0.934	3220.	520.33	535.35	545.94	555.17	562.22	567.34	570.78	572.74	573.38
21.0000	9197.	52.190	0.770	3325.	518.52	532.51	543.11	553.64	560.64	565.43	568.50	571.56	572.23
21.2500	9331.	52.953	0.661	3425.	515.71	530.70	542.34	551.75	559.07	564.47	568.14	570.33	571.03
21.5000	9451.	53.630	0.595	3525.	514.89	528.91	540.61	550.09	557.32	563.03	566.85	569.06	570.78
21.7500	9562.	54.239	0.559	3627.	513.08	527.15	538.89	548.46	555.98	561.60	565.49	567.75	569.49
22.0000	9652.	54.796	0.546	3726.	511.27	525.34	537.20	546.83	554.44	560.15	564.10	566.41	568.17
22.2500	9755.	55.311	0.548	3822.	509.46	523.64	535.51	545.22	552.90	558.68	562.70	565.05	567.82
22.5000	9841.	55.792	0.563	3917.	507.65	521.91	533.83	543.61	551.36	557.21	561.28	563.67	566.43
22.7500	9922.	56.244	0.585	4010.	505.85	520.15	532.16	542.00	549.82	555.73	559.85	562.27	565.06
23.0000	10000.	56.673	0.613	4108.	504.04	518.41	530.48	540.39	548.27	554.24	558.40	560.85	563.69
23.2500	10071.	57.041	0.646	4198.	502.23	516.67	528.81	538.74	546.72	552.74	556.94	559.42	562.23
23.5000	10144.	57.472	0.681	4274.	500.42	514.94	527.14	537.17	545.16	551.23	555.47	557.97	560.79
23.7500	10212.	57.848	0.717	4348.	498.61	513.14	525.46	535.55	543.60	549.72	553.99	556.51	559.34
24.0000	10277.	58.209	0.755	4420.	496.80	511.45	523.78	533.94	542.04	548.19	552.50	555.04	558.88
24.2500	10341.	58.558	0.793	4491.	495.04	509.71	522.10	532.31	540.46	546.66	551.00	553.56	557.48
24.5000	10402.	58.895	0.831	4567.	493.18	507.95	520.42	530.68	538.88	545.12	549.49	552.07	556.02
24.7500	10461.	59.221	0.869	4642.	491.37	506.22	518.73	529.05	537.30	543.57	547.97	550.57	554.43
25.0000	10518.	59.537	0.907	4715.	489.56	504.47	517.04	527.42	535.71	542.02	546.45	549.06	552.92
25.2500	10574.	59.843	0.944	4787.	487.75	502.72	515.35	525.77	534.11	540.46	544.91	547.54	551.41
25.5000	10628.	60.140	0.981	4858.	485.94	500.97	513.65	524.13	532.51	538.89	543.37	546.02	549.59
25.7500	10681.	60.428	1.016	4926.	484.13	499.22	511.96	522.48	530.90	537.32	541.82	544.48	548.36
26.0000	10732.	60.708	1.051	4990.	482.32	497.45	510.26	520.82	529.28	535.74	540.26	542.94	546.82
26.2500	10782.	60.981	1.085	5054.	480.51	495.71	508.55	519.17	527.67	534.15	538.70	541.39	545.27
26.5000	10830.	61.245	1.119	5116.	478.70	493.95	506.84	517.50	526.04	532.55	537.13	540.83	544.72
26.7500	10877.	61.502	1.151	5177.	476.89	492.19	505.13	515.84	524.41	530.95	535.55	539.26	543.16
27.0000	10923.	61.752	1.183	5236.	475.08	490.41	503.42	514.17	522.70	529.35	533.96	537.69	541.54
27.2500	10968.	61.995	1.214	5294.	473.27	488.67	501.71	512.49	521.14	527.74	532.37	536.11	539.82
27.5000	11011.	62.231	1.244	5350.	471.46	486.91	499.99	510.81	519.49	526.12	530.78	534.53	538.24
27.7500	11054.	62.461	1.273	5405.	469.65	485.15	498.27	509.13	517.84	524.50	529.17	532.94	536.85
28.0000	11095.	62.685	1.302	5460.	467.84	483.38	496.54	507.45	516.19	522.87	527.57	531.34	535.26
28.2500	11135.	62.903	1.330	5514.	466.03	481.62	494.82	505.76	514.53	521.24	525.95	529.74	533.66
28.5000	11174.	63.115	1.357	5569.	464.22	479.85	493.09	504.07	512.87	519.60	524.33	528.13	532.05
28.7500	11213.	63.321	1.384	5621.	462.41	478.08	491.36	502.37	511.21	517.95	522.71	526.52	530.44
29.0000	11250.	63.522	1.409	5674.	460.60	476.31	489.63	500.67	509.54	516.31	521.08	524.90	528.83
29.2500	11284.	63.717	1.435	5726.	458.79	474.54	487.90	498.97	507.87	514.66	519.55	523.47	527.31
29.5000	11321.	63.907	1.459	5778.	456.98	472.77	486.16	497.27	506.19	513.01	517.81	521.65	525.54
29.7500	11356.	64.093	1.483	5827.	455.17	470.99	484.42	495.56	504.51	511.35	516.16	520.01	524.45

Y-82

2# 1/4" S.S. PIPE, SWUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION DATE 05/08/78

TIME	F2UV RAD	DELTA	DELTA	INSIDE THERMAL STRESS	OUTSIDE THERMAL STRESS	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
30.0000	1390.	64.273	64.273	5470.	-7152.	453.36	469.22	482.68	493.85	502.83	509.69	519.52	517.37	514.32
30.2500	1222.	64.449	64.449	5470.	-7173.	451.54	467.44	480.94	492.14	501.14	508.35	517.21	515.73	512.68
30.5000	1486.	64.621	64.621	5982.	-7194.	449.73	463.89	477.65	488.71	497.76	504.64	512.43	510.98	507.93
31.0000	1546.	64.793	64.793	5982.	-7215.	447.92	462.11	475.70	486.27	495.06	501.00	507.84	506.43	503.38
31.2500	1546.	64.965	64.965	6036.	-7236.	446.11	460.33	473.96	483.54	492.36	500.12	506.25	504.95	501.91
31.5000	1546.	65.137	65.137	6071.	-7257.	444.30	458.55	472.21	481.82	490.65	497.95	504.79	503.59	500.54
31.7500	1546.	65.309	65.309	6117.	-7278.	442.49	456.76	470.45	480.09	489.25	496.26	502.41	501.21	498.16
32.0000	1631.	65.481	65.481	6143.	-7309.	440.68	454.99	468.70	478.36	487.54	494.55	500.79	499.59	496.54
32.2500	1684.	65.653	65.653	6214.	-7330.	438.87	453.21	466.94	476.62	485.82	492.87	499.14	497.94	494.89
32.5000	1710.	65.825	65.825	6253.	-7351.	437.06	451.43	465.19	474.89	484.19	491.17	497.45	496.25	493.20
33.0000	1745.	66.000	66.000	6285.	-7372.	435.25	449.66	463.47	473.15	482.39	489.46	495.71	494.51	491.46
33.2500	1745.	66.172	66.172	6317.	-7393.	433.44	447.88	461.67	471.61	480.95	487.75	494.00	492.80	489.75
33.5000	1745.	66.344	66.344	6342.	-7414.	431.63	446.10	459.91	469.61	479.03	486.05	492.30	491.10	488.05
33.7500	1745.	66.516	66.516	6367.	-7435.	429.82	444.32	458.15	467.84	477.22	484.34	490.63	489.43	486.38
34.0000	1830.	66.688	66.688	6413.	-7456.	428.01	442.54	456.37	466.04	475.30	482.63	488.95	487.75	484.70
34.2500	1852.	66.860	66.860	6442.	-7477.	426.20	440.76	454.59	464.24	473.57	480.91	487.24	486.04	483.00
34.5000	1874.	67.032	67.032	6471.	-7498.	424.39	438.98	452.82	462.47	471.80	479.20	485.53	484.33	481.28
34.7500	1895.	67.204	67.204	6500.	-7519.	422.58	437.20	451.05	460.70	470.03	477.49	483.82	482.62	479.57
35.0000	1916.	67.376	67.376	6528.	-7540.	420.77	435.42	449.29	458.95	468.28	475.79	482.12	480.92	477.87
35.2500	1937.	67.548	67.548	6557.	-7561.	418.96	433.64	447.52	457.20	466.53	473.93	480.26	479.06	476.01
35.5000	1958.	67.720	67.720	6586.	-7582.	417.15	431.86	445.75	455.43	464.74	472.31	478.64	477.44	474.39
35.7500	1979.	67.892	67.892	6615.	-7603.	415.34	430.08	443.98	453.66	462.96	470.53	476.86	475.66	472.61
36.0000	2014.	68.064	68.064	6644.	-7624.	413.53	428.30	442.21	451.89	460.18	467.75	474.08	472.88	469.83
36.2500	2032.	68.236	68.236	6673.	-7645.	411.72	426.52	440.44	450.18	458.47	466.04	472.37	471.17	468.12
36.5000	2050.	68.408	68.408	6702.	-7666.	410.00	424.74	438.67	448.47	456.76	464.33	470.66	469.46	466.41
36.7500	2067.	68.580	68.580	6730.	-7687.	408.19	422.96	436.90	446.70	455.00	462.87	469.20	467.99	464.94
37.0000	2085.	68.752	68.752	6759.	-7708.	406.38	421.18	435.13	444.93	453.22	460.19	466.52	465.31	462.26
37.2500	2101.	68.924	68.924	6787.	-7729.	404.57	419.40	433.36	443.16	451.45	458.72	465.05	463.84	460.79
37.5000	2118.	69.096	69.096	6819.	-7750.	402.76	417.62	431.59	441.39	449.68	456.95	463.28	462.07	459.02
37.7500	2136.	69.268	69.268	6840.	-7771.	400.95	415.84	429.82	439.62	447.91	455.22	461.51	460.30	457.25
38.0000	2150.	69.440	69.440	6880.	-7792.	399.14	414.06	428.04	437.86	446.14	453.41	460.04	458.83	455.78
38.2500	2165.	69.612	69.612	6900.	-7813.	397.33	412.28	426.26	436.09	444.33	451.68	458.11	456.90	453.85
38.5000	2190.	69.784	69.784	6920.	-7834.	395.52	410.50	424.48	434.32	442.56	449.95	456.38	455.17	452.12
38.7500	2210.	69.956	69.956	6940.	-7855.	393.71	408.72	422.70	432.56	440.79	448.14	454.56	453.35	450.30
39.0000	2209.	70.128	70.128	6960.	-7876.	391.90	406.94	420.92	430.80	439.02	446.33	452.71	451.50	448.45
39.2500	2224.	70.300	70.300	6980.	-7897.	390.09	405.16	419.15	429.04	437.25	444.44	450.83	449.62	446.57
39.5000	2238.	70.472	70.472	6995.	-7918.	388.28	403.38	417.37	427.27	435.47	442.66	449.05	447.84	444.79
39.7500	2238.	70.644	70.644	6975.	-7939.	386.47	401.60	415.59	425.50	433.70	440.85	447.24	446.03	442.98
40.0000	2238.	70.816	70.816	6975.	-7960.	384.66	399.82	413.81	423.73	431.92	439.04	445.43	444.22	441.17

TIME	FLOW LIM.	DELTA	DELTA 2	INCIDENT THERMAL STRESS	TRANSIENT THERMAL STRESS	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
40.0000	12514	68.801	12.101	1699.4	1699.4	390.89	391.64	412.00	423.94	433.56	440.95	446.15	449.24	450.26
40.2500	12144	68.496	11.803	1671.4	1671.4	379.87	396.10	410.26	422.17	431.05	439.19	446.65	447.80	449.26
40.5000	12111	68.002	11.500	1652.4	1652.4	374.85	394.71	408.65	420.45	428.05	435.44	442.65	445.74	446.57
40.7500	12007	67.413	11.198	1631.5	1631.5	377.83	392.60	407.12	418.79	426.33	433.67	440.90	445.70	446.57
41.0000	11996	66.770	10.997	1611.1	1611.1	376.82	392.64	405.65	417.19	424.66	431.97	439.16	446.05	446.57
41.2500	11774	66.095	10.799	1591.5	1591.5	375.81	390.59	404.23	415.63	422.99	430.26	437.43	444.31	445.74
41.5000	11552	65.403	10.575	1572.7	1572.7	374.80	389.69	402.86	414.10	421.78	428.54	435.72	442.66	443.77
41.7500	11523	64.705	10.375	1556.7	1556.7	373.79	388.84	401.44	412.61	420.21	426.92	434.02	440.96	441.50
42.0000	11405	64.004	10.197	1542.0	1542.0	372.74	387.94	400.12	411.14	418.67	425.07	432.36	439.35	440.02
42.2500	11283	63.317	10.043	1528.0	1528.0	371.77	386.94	398.84	409.69	417.14	423.67	430.67	437.66	438.16
42.5000	11162	62.636	9.908	1514.5	1514.5	370.76	385.94	397.52	408.27	415.64	422.04	429.02	435.96	436.46
42.7500	11046	61.967	9.794	1502.4	1502.4	369.75	384.94	396.23	406.85	414.15	420.49	427.40	434.33	434.96
43.0000	10928	61.312	9.696	1491.7	1491.7	368.75	383.94	394.95	405.47	412.64	418.93	425.78	432.69	433.50
43.2500	10815	60.672	9.614	1482.4	1482.4	367.74	382.94	393.68	404.09	410.15	416.44	423.19	430.96	431.81
43.5000	10702	60.047	9.546	1474.3	1474.3	366.73	381.94	392.42	402.72	408.62	414.87	421.62	429.26	429.86
43.7500	10589	59.440	9.493	1467.3	1467.3	365.73	380.94	391.17	401.37	407.78	413.35	420.06	427.87	428.40
44.0000	10482	58.848	9.454	1461.4	1461.4	364.72	379.94	389.93	400.03	406.36	411.85	418.51	426.30	426.92
44.2500	10390	58.273	9.429	1456.5	1456.5	363.71	378.94	388.70	398.70	405.15	410.33	417.19	424.74	425.38
44.5000	10291	57.714	9.416	1452.6	1452.6	362.71	377.94	387.48	397.48	404.07	409.81	416.48	423.20	423.84
44.7500	10194	57.171	9.412	1449.7	1449.7	361.70	376.94	386.26	396.26	403.04	408.47	415.68	421.68	422.32
45.0000	10101	56.645	9.417	1447.8	1447.8	360.70	375.94	385.05	395.07	402.16	407.04	414.98	420.20	420.84
45.2500	10010	56.133	9.430	1446.9	1446.9	359.69	374.94	383.85	393.89	401.42	406.61	413.54	418.68	419.32
45.5000	9923	55.637	9.453	1447.0	1447.0	358.69	373.94	382.65	392.71	400.67	405.20	412.04	417.24	417.88
45.7500	9837	55.155	9.489	1448.1	1448.1	357.68	372.94	381.46	391.57	400.04	404.81	410.55	415.80	416.44
46.0000	9754	54.688	9.546	1450.2	1450.2	356.68	371.94	380.28	390.47	399.60	404.42	409.12	414.20	414.84
46.2500	9674	54.235	9.624	1454.3	1454.3	355.67	370.94	379.10	389.42	398.60	404.02	408.72	412.70	413.34
46.5000	9596	53.796	9.720	1460.4	1460.4	354.66	369.94	377.92	388.62	397.60	403.65	408.31	411.20	411.84
46.7500	9521	53.370	9.833	1468.5	1468.5	353.65	368.94	376.76	387.87	396.60	403.33	408.01	410.70	411.34
47.0000	9447	52.959	9.964	1479.6	1479.6	352.65	367.94	375.59	387.17	395.60	403.04	407.72	410.20	410.84
47.2500	9376	52.555	10.114	1493.7	1493.7	351.65	366.94	374.43	386.42	394.60	402.77	407.45	409.85	410.48
47.5000	9307	52.157	10.284	1510.8	1510.8	350.65	365.94	373.28	385.62	393.60	402.52	407.18	409.35	410.02
47.7500	9241	51.784	10.474	1530.9	1530.9	349.65	364.94	372.13	384.87	392.60	402.29	406.91	409.02	409.66
48.0000	9176	51.424	10.684	1554.0	1554.0	348.65	363.94	370.99	384.17	391.60	402.04	406.64	409.02	409.66
48.2500	9113	51.064	10.914	1580.1	1580.1	347.64	362.94	369.85	383.47	390.60	401.79	406.39	409.02	409.66
48.5000	9052	50.725	11.164	1609.2	1609.2	346.63	361.94	369.71	382.75	389.60	401.54	406.14	409.02	409.66
48.7500	8993	50.392	11.434	1642.3	1642.3	345.63	360.94	369.58	382.04	388.60	401.29	405.89	409.02	409.66
49.0000	8935	50.069	11.724	1680.4	1680.4	344.63	359.94	369.45	381.33	387.60	401.04	405.64	409.02	409.66
49.2500	8880	49.755	12.034	1724.5	1724.5	343.63	358.94	369.32	380.63	386.60	400.79	405.39	409.02	409.66
49.5000	8826	49.451	12.364	1774.6	1774.6	342.63	357.94	369.19	379.90	385.60	400.54	405.14	409.02	409.66
49.7500	8774	49.156	12.714	1830.7	1830.7	341.62	356.94	369.06	379.23	384.60	400.29	404.89	409.02	409.66

TIME	EQUIV LIN. RAD	DELTA1	DELTA2	INCIDENT THERMAL STRESS INSIDE	INCIDENT THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
50.0000	48.870	7.423	4.005	11849	-5245	340.62	352.09	361.94	370.24	376.09	382.60	386.43	389.70	393.15
50.2500	48.870	7.423	4.005	11849	-5245	339.61	350.93	359.77	368.09	373.94	380.45	383.24	386.48	389.92
50.5000	48.870	7.423	4.005	11849	-5245	337.61	348.83	357.67	365.95	371.80	378.31	381.10	384.34	387.78
50.7500	48.870	7.423	4.005	11849	-5245	335.60	347.83	356.67	364.95	370.80	377.31	380.10	383.34	386.78
51.0000	48.870	7.423	4.005	11849	-5245	334.60	346.83	355.67	363.95	369.80	376.31	379.10	382.34	385.78
51.2500	48.870	7.423	4.005	11849	-5245	333.60	345.83	354.67	362.95	368.80	375.31	378.10	381.34	384.78
51.5000	48.870	7.423	4.005	11849	-5245	332.60	344.83	353.67	361.95	367.80	374.31	377.10	380.34	383.78
51.7500	48.870	7.423	4.005	11849	-5245	331.60	343.83	352.67	360.95	366.80	373.31	376.10	379.34	382.78
52.0000	48.870	7.423	4.005	11849	-5245	330.60	342.83	351.67	359.95	365.80	372.31	375.10	378.34	381.78
52.2500	48.870	7.423	4.005	11849	-5245	329.60	341.83	350.67	358.95	364.80	371.31	374.10	377.34	380.78
52.5000	48.870	7.423	4.005	11849	-5245	328.60	340.83	349.67	357.95	363.80	370.31	373.10	376.34	379.78
52.7500	48.870	7.423	4.005	11849	-5245	327.60	339.83	348.67	356.95	362.80	369.31	372.10	375.34	378.78
53.0000	48.870	7.423	4.005	11849	-5245	326.60	338.83	347.67	355.95	361.80	368.31	371.10	374.34	377.78
53.2500	48.870	7.423	4.005	11849	-5245	325.60	337.83	346.67	354.95	360.80	367.31	370.10	373.34	376.78
53.5000	48.870	7.423	4.005	11849	-5245	324.60	336.83	345.67	353.95	359.80	366.31	369.10	372.34	375.78
53.7500	48.870	7.423	4.005	11849	-5245	323.60	335.83	344.67	352.95	358.80	365.31	368.10	371.34	374.78
54.0000	48.870	7.423	4.005	11849	-5245	322.60	334.83	343.67	351.95	357.80	364.31	367.10	370.34	373.78
54.2500	48.870	7.423	4.005	11849	-5245	321.60	333.83	342.67	350.95	356.80	363.31	366.10	369.34	372.78
54.5000	48.870	7.423	4.005	11849	-5245	320.60	332.83	341.67	349.95	355.80	362.31	365.10	368.34	371.78
54.7500	48.870	7.423	4.005	11849	-5245	319.60	331.83	340.67	348.95	354.80	361.31	364.10	367.34	370.78
55.0000	48.870	7.423	4.005	11849	-5245	318.60	330.83	339.67	347.95	353.80	360.31	363.10	366.34	369.78
55.2500	48.870	7.423	4.005	11849	-5245	317.60	329.83	338.67	346.95	352.80	359.31	362.10	365.34	368.78
55.5000	48.870	7.423	4.005	11849	-5245	316.60	328.83	337.67	345.95	351.80	358.31	361.10	364.34	367.78
55.7500	48.870	7.423	4.005	11849	-5245	315.60	327.83	336.67	344.95	350.80	357.31	360.10	363.34	366.78
56.0000	48.870	7.423	4.005	11849	-5245	314.60	326.83	335.67	343.95	349.80	356.31	359.10	362.34	365.78
56.2500	48.870	7.423	4.005	11849	-5245	313.60	325.83	334.67	342.95	348.80	355.31	358.10	361.34	364.78
56.5000	48.870	7.423	4.005	11849	-5245	312.60	324.83	333.67	341.95	347.80	354.31	357.10	360.34	363.78
56.7500	48.870	7.423	4.005	11849	-5245	311.60	323.83	332.67	340.95	346.80	353.31	356.10	359.34	362.78
57.0000	48.870	7.423	4.005	11849	-5245	310.60	322.83	331.67	339.95	345.80	352.31	355.10	358.34	361.78
57.2500	48.870	7.423	4.005	11849	-5245	309.60	321.83	330.67	338.95	344.80	351.31	354.10	357.34	360.78
57.5000	48.870	7.423	4.005	11849	-5245	308.60	320.83	329.67	337.95	343.80	350.31	353.10	356.34	359.78
57.7500	48.870	7.423	4.005	11849	-5245	307.60	319.83	328.67	336.95	342.80	349.31	352.10	355.34	358.78
58.0000	48.870	7.423	4.005	11849	-5245	306.60	318.83	327.67	335.95	341.80	348.31	351.10	354.34	357.78
58.2500	48.870	7.423	4.005	11849	-5245	305.60	317.83	326.67	334.95	340.80	347.31	350.10	353.34	356.78
58.5000	48.870	7.423	4.005	11849	-5245	304.60	316.83	325.67	333.95	339.80	346.31	349.10	352.34	355.78
58.7500	48.870	7.423	4.005	11849	-5245	303.60	315.83	324.67	332.95	338.80	345.31	348.10	351.34	354.78
59.0000	48.870	7.423	4.005	11849	-5245	302.60	314.83	323.67	331.95	337.80	344.31	347.10	350.34	353.78
59.2500	48.870	7.423	4.005	11849	-5245	301.60	313.83	322.67	330.95	336.80	343.31	346.10	349.34	352.78
59.5000	48.870	7.423	4.005	11849	-5245	300.60	312.83	321.67	329.95	335.80	342.31	345.10	348.34	351.78
59.7500	48.870	7.423	4.005	11849	-5245	299.60	311.83	320.67	328.95	334.80	341.31	344.10	347.34	350.78
60.0000	48.870	7.423	4.005	11849	-5245	298.60	310.83	319.67	327.95	333.80	340.31	343.10	346.34	349.78

36 INCH ELBOW, SAUD COOLDOWN INCIDENT TRANSIENT
 DIMENSIONS
 INSIDE RADIUS = 14.2500 INCHES
 NO. OF VOTES = 9
 MATERIAL CODE = 1
 L = 0.0000
 DATE 05/02/78
 REF A-5
 OUTSIDE RADIUS = 22.0000 INCHES
 RADIAL INCHEMENT = .4648 INCHES
 POISSON S RATIO = .3000

MODE	INITIAL RADIUS	TEMPERATURE
1	14.2500	570.0
2	14.7184	570.0
3	15.1875	570.0
4	15.6563	570.0
5	16.1250	570.0
6	16.5938	570.0
7	17.0625	570.0
8	17.5313	570.0
9	18.0000	570.0

DATE 05/02/78

36 INCH ELBOW, SHUD COOLDOWN INCIDENT TRANSIENT

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP. CURVE		FILM COEFF. CURVE		PRESSURE CURVE	
TIME APPROXIMATION	INSIDE FLUID TEMPERATURE	TIME APPROXIMATION	INSIDE FILM COEFFICIENT	TIME APPROXIMATION	PRESSURE
(MINUTES)	(TEMPERATURE)	(MINUTES)	(COEFFICIENT)	(MINUTES)	(PSI)
0.0000	570.0	0.0000	925.0	0.0000	0.
5.0000	570.0	5.0000	925.0	0.0000	0.
10.0000	570.0	10.0000	930.0	0.0000	0.
15.0000	570.0	15.0000	930.0	0.0000	0.
20.0000	525.0	20.0000	911.0	0.0000	0.
40.0000	380.0	40.0000	855.0	0.0000	0.
60.0000	300.0	60.0000	822.0	0.0000	0.
80.0000	240.0	80.0000	810.0	0.0000	0.
95.0000	242.0	95.0000	815.0	0.0000	0.
110.0000	303.0	110.0000	822.0	0.0000	0.

TEMPERATURE CALCULATION TIMES AND PRINTOUTS

TEMPERATURE INCREMENT	TIME LIMIT (MINUTES)	NUMBER OF PRINTOUTS
25.00	145.000	540.

REF PG Y-3

36 INCH EL 304L SHUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 14-1887 PAGE 301055

91232 REV 4 FULL CERTIFICATION

DATE 05/02/78

36 INCH EL 304L SHUD COOLDOWN INCIDENT TRANSIENT THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE FILM COEFF	Avg. TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNGS MODULUS	COEFF OF EXPANS	DENSITY
30.000	437.0	M83	436.4371	126.44083	281	70E+07	70E-05	482.4125
30.250	437.0	M82	436.4750	126.41145	280	70E+07	70E-05	482.4370
30.500	437.0	M81	437.0099	126.41212	279	70E+07	70E-05	482.4570
30.750	437.0	M80	437.1714	127.02145	279	70E+07	70E-05	482.5011
31.000	437.0	M79	437.5965	127.4630	279	70E+07	70E-05	482.5200
31.250	437.0	M78	437.4224	127.0570	276	70E+07	70E-05	482.5716
31.500	437.0	M77	437.0667	127.0590	276	70E+07	70E-05	482.5716
31.750	437.0	M76	437.2643	127.0590	275	70E+07	70E-05	482.6170
32.000	437.0	M75	437.0434	127.0590	275	70E+07	70E-05	482.6170
32.250	437.0	M74	437.4094	127.0590	275	70E+07	70E-05	482.6635
32.500	437.0	M73	437.2704	127.0590	275	70E+07	70E-05	482.6635
32.750	437.0	M72	437.1204	127.0590	273	70E+07	70E-05	482.7090
33.000	437.0	M71	437.2704	127.0590	273	70E+07	70E-05	482.7090
33.250	437.0	M70	437.0667	127.0590	273	70E+07	70E-05	482.7527
33.500	437.0	M69	437.0667	127.0590	273	70E+07	70E-05	482.7527
33.750	437.0	M68	437.0667	127.0590	270	70E+07	70E-05	482.7527
34.000	437.0	M67	437.0667	127.0590	269	70E+07	70E-05	482.8022
34.250	437.0	M66	437.0667	127.0590	269	70E+07	70E-05	482.8022
34.500	437.0	M65	437.0667	127.0590	269	70E+07	70E-05	482.8449
34.750	437.0	M64	437.0667	127.0590	269	70E+07	70E-05	482.8449
35.000	437.0	M63	437.0667	127.0590	267	70E+07	70E-05	482.8716
35.250	437.0	M62	437.0667	127.0590	267	70E+07	70E-05	482.8716
35.500	437.0	M61	437.0667	127.0590	266	70E+07	70E-05	482.9191
35.750	437.0	M60	437.0667	127.0590	266	70E+07	70E-05	482.9191
36.000	437.0	M59	437.0667	127.0590	265	70E+07	70E-05	482.9640
36.250	437.0	M58	437.0667	127.0590	265	70E+07	70E-05	482.9640
36.500	437.0	M57	437.0667	127.0590	264	70E+07	70E-05	482.9640
36.750	437.0	M56	437.0667	127.0590	264	70E+07	70E-05	482.9640
37.000	437.0	M55	437.0667	127.0590	262	70E+07	70E-05	482.9640
37.250	437.0	M54	437.0667	127.0590	262	70E+07	70E-05	482.9640
37.500	437.0	M53	437.0667	127.0590	261	70E+07	70E-05	482.9640
37.750	437.0	M52	437.0667	127.0590	261	70E+07	70E-05	482.9640
38.000	437.0	M51	437.0667	127.0590	260	70E+07	70E-05	482.9640
38.250	437.0	M50	437.0667	127.0590	260	70E+07	70E-05	482.9640
38.500	437.0	M49	437.0667	127.0590	259	70E+07	70E-05	482.9640
38.750	437.0	M48	437.0667	127.0590	259	70E+07	70E-05	482.9640
39.000	437.0	M47	437.0667	127.0590	258	70E+07	70E-05	482.9640
39.250	437.0	M46	437.0667	127.0590	258	70E+07	70E-05	482.9640
39.500	437.0	M45	437.0667	127.0590	255	70E+07	70E-05	482.9640
39.750	437.0	M44	437.0667	127.0590	255	70E+07	70E-05	482.9640
40.000	437.0	M43	437.0667	127.0590	255	70E+07	70E-05	482.9640
40.250	437.0	M42	437.0667	127.0590	255	70E+07	70E-05	482.9640
40.500	437.0	M41	437.0667	127.0590	255	70E+07	70E-05	482.9640
40.750	437.0	M40	437.0667	127.0590	255	70E+07	70E-05	482.9640
41.000	437.0	M39	437.0667	127.0590	255	70E+07	70E-05	482.9640
41.250	437.0	M38	437.0667	127.0590	255	70E+07	70E-05	482.9640
41.500	437.0	M37	437.0667	127.0590	255	70E+07	70E-05	482.9640
41.750	437.0	M36	437.0667	127.0590	255	70E+07	70E-05	482.9640
42.000	437.0	M35	437.0667	127.0590	255	70E+07	70E-05	482.9640
42.250	437.0	M34	437.0667	127.0590	255	70E+07	70E-05	482.9640
42.500	437.0	M33	437.0667	127.0590	255	70E+07	70E-05	482.9640
42.750	437.0	M32	437.0667	127.0590	255	70E+07	70E-05	482.9640
43.000	437.0	M31	437.0667	127.0590	255	70E+07	70E-05	482.9640
43.250	437.0	M30	437.0667	127.0590	255	70E+07	70E-05	482.9640
43.500	437.0	M29	437.0667	127.0590	255	70E+07	70E-05	482.9640
43.750	437.0	M28	437.0667	127.0590	255	70E+07	70E-05	482.9640
44.000	437.0	M27	437.0667	127.0590	255	70E+07	70E-05	482.9640
44.250	437.0	M26	437.0667	127.0590	255	70E+07	70E-05	482.9640
44.500	437.0	M25	437.0667	127.0590	255	70E+07	70E-05	482.9640
44.750	437.0	M24	437.0667	127.0590	255	70E+07	70E-05	482.9640
45.000	437.0	M23	437.0667	127.0590	255	70E+07	70E-05	482.9640
45.250	437.0	M22	437.0667	127.0590	255	70E+07	70E-05	482.9640
45.500	437.0	M21	437.0667	127.0590	255	70E+07	70E-05	482.9640
45.750	437.0	M20	437.0667	127.0590	255	70E+07	70E-05	482.9640
46.000	437.0	M19	437.0667	127.0590	255	70E+07	70E-05	482.9640
46.250	437.0	M18	437.0667	127.0590	255	70E+07	70E-05	482.9640
46.500	437.0	M17	437.0667	127.0590	255	70E+07	70E-05	482.9640
46.750	437.0	M16	437.0667	127.0590	255	70E+07	70E-05	482.9640
47.000	437.0	M15	437.0667	127.0590	255	70E+07	70E-05	482.9640
47.250	437.0	M14	437.0667	127.0590	255	70E+07	70E-05	482.9640
47.500	437.0	M13	437.0667	127.0590	255	70E+07	70E-05	482.9640
47.750	437.0	M12	437.0667	127.0590	255	70E+07	70E-05	482.9640
48.000	437.0	M11	437.0667	127.0590	255	70E+07	70E-05	482.9640
48.250	437.0	M10	437.0667	127.0590	255	70E+07	70E-05	482.9640
48.500	437.0	M9	437.0667	127.0590	255	70E+07	70E-05	482.9640
48.750	437.0	M8	437.0667	127.0590	255	70E+07	70E-05	482.9640
49.000	437.0	M7	437.0667	127.0590	255	70E+07	70E-05	482.9640
49.250	437.0	M6	437.0667	127.0590	255	70E+07	70E-05	482.9640
49.500	437.0	M5	437.0667	127.0590	255	70E+07	70E-05	482.9640
49.750	437.0	M4	437.0667	127.0590	255	70E+07	70E-05	482.9640
50.000	437.0	M3	437.0667	127.0590	255	70E+07	70E-05	482.9640
50.250	437.0	M2	437.0667	127.0590	255	70E+07	70E-05	482.9640
50.500	437.0	M1	437.0667	127.0590	255	70E+07	70E-05	482.9640

36 INCH EL 304. SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 05/02/78 91232 MEV * 12-15-78 95/02/18 14-10-27 PAGE 501C-58

36 INCH EL 304. SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 05/02/78

MECHANICAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE WALL COEFF	AVE. TEMP.	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	DENSITY
40.000	310.	855.	424.4153	315.8194	254.	2.74E+07	69E-05	486.3391
40.250	310.	855.	422.4376	315.8194	254.	2.74E+07	69E-05	486.3620
40.500	310.	854.	421.4599	315.8194	254.	2.74E+07	69E-05	486.3847
40.750	310.	854.	420.4822	315.8194	254.	2.74E+07	69E-05	486.4074
41.000	310.	853.	419.5045	315.8194	254.	2.74E+07	69E-05	486.4301
41.250	310.	853.	418.5268	315.8194	254.	2.74E+07	69E-05	486.4528
41.500	310.	852.	417.5491	315.8194	254.	2.74E+07	69E-05	486.4755
41.750	310.	852.	416.5714	315.8194	254.	2.74E+07	69E-05	486.4982
42.000	310.	851.	415.5937	315.8194	254.	2.74E+07	69E-05	486.5209
42.250	310.	851.	414.6160	315.8194	254.	2.74E+07	69E-05	486.5436
42.500	310.	850.	413.6383	315.8194	254.	2.74E+07	69E-05	486.5663
42.750	310.	850.	412.6606	315.8194	254.	2.74E+07	69E-05	486.5890
43.000	310.	849.	411.6829	315.8194	254.	2.74E+07	69E-05	486.6117
43.250	310.	849.	410.7052	315.8194	254.	2.74E+07	69E-05	486.6344
43.500	310.	848.	409.7275	315.8194	254.	2.74E+07	69E-05	486.6571
43.750	310.	848.	408.7498	315.8194	254.	2.74E+07	69E-05	486.6798
44.000	310.	847.	407.7721	315.8194	254.	2.74E+07	69E-05	486.7025
44.250	310.	847.	406.7944	315.8194	254.	2.74E+07	69E-05	486.7252
44.500	310.	846.	405.8167	315.8194	254.	2.74E+07	69E-05	486.7479
44.750	310.	846.	404.8390	315.8194	254.	2.74E+07	69E-05	486.7706
45.000	310.	845.	403.8613	315.8194	254.	2.74E+07	69E-05	486.7933
45.250	310.	845.	402.8836	315.8194	254.	2.74E+07	69E-05	486.8160
45.500	310.	844.	401.9059	315.8194	254.	2.74E+07	69E-05	486.8387
45.750	310.	844.	400.9282	315.8194	254.	2.74E+07	69E-05	486.8614
46.000	310.	843.	400.9505	315.8194	254.	2.74E+07	69E-05	486.8841
46.250	310.	843.	400.9728	315.8194	254.	2.74E+07	69E-05	486.9068
46.500	310.	842.	400.9951	315.8194	254.	2.74E+07	69E-05	486.9295
46.750	310.	842.	401.0174	315.8194	254.	2.74E+07	69E-05	486.9522
47.000	310.	841.	401.0397	315.8194	254.	2.74E+07	69E-05	486.9749
47.250	310.	841.	401.0620	315.8194	254.	2.74E+07	69E-05	486.9976
47.500	310.	840.	401.0843	315.8194	254.	2.74E+07	69E-05	487.0203
47.750	310.	840.	401.1066	315.8194	254.	2.74E+07	69E-05	487.0430
48.000	310.	839.	401.1289	315.8194	254.	2.74E+07	69E-05	487.0657
48.250	310.	839.	401.1512	315.8194	254.	2.74E+07	69E-05	487.0884
48.500	310.	838.	401.1735	315.8194	254.	2.74E+07	69E-05	487.1111
48.750	310.	838.	401.1958	315.8194	254.	2.74E+07	69E-05	487.1338
49.000	310.	837.	401.2181	315.8194	254.	2.74E+07	69E-05	487.1565
49.250	310.	837.	401.2404	315.8194	254.	2.74E+07	69E-05	487.1792
49.500	310.	836.	401.2627	315.8194	254.	2.74E+07	69E-05	487.2019
49.750	310.	836.	401.2850	315.8194	254.	2.74E+07	69E-05	487.2246
50.000	310.	835.	401.3073	315.8194	254.	2.74E+07	69E-05	487.2473

36 INCH EL 304, SUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 91232 REV 4 12-15-79 95826170 11-10-87 PAGE 26 OF 30

DATE 05/02/78

36 INCH EL 304, SUD COOLDOWN INCIDENT TRANSIENT THERMAL PROPERTIES

TIME	INSIDE TEMP	INSIDE COEFF	AVE. TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANS	DENSITY
50.000	M19	M19	342.5652	161.3715	0.239	29.8E+07	0.0005	487.0719
50.050	M18	M18	357.2119	161.3715	0.239	29.8E+07	0.0005	487.0719
50.100	M17	M17	362.0630	161.3715	0.239	29.8E+07	0.0005	487.0719
50.150	M16	M16	363.9414	161.3715	0.239	29.8E+07	0.0005	487.0719
50.200	M15	M15	362.7224	161.3715	0.239	29.8E+07	0.0005	487.0719
50.250	M14	M14	361.5225	161.3715	0.239	29.8E+07	0.0005	487.0719
50.300	M13	M13	353.2434	161.3715	0.239	29.8E+07	0.0005	487.0719
50.350	M12	M12	354.1441	161.3715	0.239	29.8E+07	0.0005	487.0719
50.400	M11	M11	355.4745	161.3715	0.239	29.8E+07	0.0005	487.0719
50.450	M10	M10	354.7503	161.3715	0.239	29.8E+07	0.0005	487.0719
50.500	M09	M09	353.5400	161.3715	0.239	29.8E+07	0.0005	487.0719
50.550	M08	M08	352.5234	161.3715	0.239	29.8E+07	0.0005	487.0719
50.600	M07	M07	351.6110	161.3715	0.239	29.8E+07	0.0005	487.0719
50.650	M06	M06	350.1020	161.3715	0.239	29.8E+07	0.0005	487.0719
50.700	M05	M05	349.1944	161.3715	0.239	29.8E+07	0.0005	487.0719
50.750	M04	M04	348.9254	161.3715	0.239	29.8E+07	0.0005	487.0719
50.800	M03	M03	344.4071	161.3715	0.239	29.8E+07	0.0005	487.0719
50.850	M02	M02	343.7108	161.3715	0.239	29.8E+07	0.0005	487.0719
50.900	M01	M01	341.5447	161.3715	0.239	29.8E+07	0.0005	487.0719
50.950	M00	M00	340.1094	161.3715	0.239	29.8E+07	0.0005	487.0719
51.000	M00	M00	337.6652	161.3715	0.239	29.8E+07	0.0005	487.0719
51.050	M00	M00	336.1094	161.3715	0.239	29.8E+07	0.0005	487.0719
51.100	M00	M00	334.1634	161.3715	0.239	29.8E+07	0.0005	487.0719
51.150	M00	M00	332.0241	161.3715	0.239	29.8E+07	0.0005	487.0719
51.200	M00	M00	329.9511	161.3715	0.239	29.8E+07	0.0005	487.0719
51.250	M00	M00	327.9160	161.3715	0.239	29.8E+07	0.0005	487.0719
51.300	M00	M00	325.7181	161.3715	0.239	29.8E+07	0.0005	487.0719
51.350	M00	M00	324.0620	161.3715	0.239	29.8E+07	0.0005	487.0719
51.400	M00	M00	321.9620	161.3715	0.239	29.8E+07	0.0005	487.0719
51.450	M00	M00	320.6073	161.3715	0.239	29.8E+07	0.0005	487.0719
51.500	M00	M00	318.5543	161.3715	0.239	29.8E+07	0.0005	487.0719

36 INCH FL 304 • SWUD COOL DOWN INCIDENT TRANSIENT FULL CERTIFICATION 10-10-87 PAGE 58

36 INCH FL 304 • SWUD COOL DOWN INCIDENT TRANSIENT

TEMPERATURE PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE FILM COEFF	AVERAGE TEMP	CONDUCTIVITY
60.000	300.000	822	324.5024	166.5174
60.250	300.000	822	323.6947	166.5516
60.500	300.000	822	322.8870	166.5858
60.750	300.000	822	322.0793	166.6200
61.000	300.000	822	321.2716	166.6542
61.250	300.000	822	320.4639	166.6884
61.500	300.000	822	319.6562	166.7226
61.750	300.000	822	318.8485	166.7568
62.000	300.000	822	318.0408	166.7910
62.250	300.000	822	317.2331	166.8252
62.500	300.000	822	316.4254	166.8594
62.750	300.000	822	315.6177	166.8936
63.000	300.000	822	314.8100	166.9278
63.250	300.000	822	314.0023	166.9620
63.500	300.000	822	313.1946	166.9962
63.750	300.000	822	312.3869	167.0304
64.000	300.000	822	311.5792	167.0646
64.250	300.000	822	310.7715	167.0988
64.500	300.000	822	309.9638	167.1330
64.750	300.000	822	309.1561	167.1672
65.000	300.000	822	308.3484	167.2014
65.250	300.000	822	307.5407	167.2356
65.500	300.000	822	306.7330	167.2698
65.750	300.000	822	305.9253	167.3040
66.000	300.000	822	305.1176	167.3382
66.250	300.000	822	304.3100	167.3724
66.500	300.000	822	303.5023	167.4066
66.750	300.000	822	302.6946	167.4408
67.000	300.000	822	301.8869	167.4750
67.250	300.000	822	301.0792	167.5092
67.500	300.000	822	300.2715	167.5434
67.750	300.000	822	299.4638	167.5776
68.000	300.000	822	298.6561	167.6118
68.250	300.000	822	297.8484	167.6460
68.500	300.000	822	297.0407	167.6802
68.750	300.000	822	296.2330	167.7144
69.000	300.000	822	295.4253	167.7486
69.250	300.000	822	294.6176	167.7828
69.500	300.000	822	293.8100	167.8170
69.750	300.000	822	293.0023	167.8512
70.000	300.000	822	292.1946	167.8854
70.250	300.000	822	291.3869	167.9196
70.500	300.000	822	290.5792	167.9538
70.750	300.000	822	289.7715	167.9880
71.000	300.000	822	288.9638	168.0222
71.250	300.000	822	288.1561	168.0564
71.500	300.000	822	287.3484	168.0906
71.750	300.000	822	286.5407	168.1248
72.000	300.000	822	285.7330	168.1590
72.250	300.000	822	284.9253	168.1932
72.500	300.000	822	284.1176	168.2274
72.750	300.000	822	283.3100	168.2616
73.000	300.000	822	282.5023	168.2958
73.250	300.000	822	281.6946	168.3300
73.500	300.000	822	280.8869	168.3642
73.750	300.000	822	280.0792	168.3984
74.000	300.000	822	279.2715	168.4326
74.250	300.000	822	278.4638	168.4668
74.500	300.000	822	277.6561	168.5010
74.750	300.000	822	276.8484	168.5352
75.000	300.000	822	276.0407	168.5694
75.250	300.000	822	275.2330	168.6036
75.500	300.000	822	274.4253	168.6378
75.750	300.000	822	273.6176	168.6720
76.000	300.000	822	272.8100	168.7062
76.250	300.000	822	272.0023	168.7404
76.500	300.000	822	271.1946	168.7746
76.750	300.000	822	270.3869	168.8088
77.000	300.000	822	269.5792	168.8430
77.250	300.000	822	268.7715	168.8772
77.500	300.000	822	267.9638	168.9114
77.750	300.000	822	267.1561	168.9456
78.000	300.000	822	266.3484	168.9798
78.250	300.000	822	265.5407	169.0140
78.500	300.000	822	264.7330	169.0482
78.750	300.000	822	263.9253	169.0824
79.000	300.000	822	263.1176	169.1166
79.250	300.000	822	262.3100	169.1508
79.500	300.000	822	261.5023	169.1850
79.750	300.000	822	260.6946	169.2192
80.000	300.000	822	259.8869	169.2534

SPECIFIC HEAT

YOUNGS MODULUS

COEFF OF EXPANSION

DENSITY

36 INCH EL304 SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION 10-19627-PA35.DCS

01238 REV 9 FULL CERTIFICATION

05/02/78

36 INCH EL304 SNUD COOLDOWN INCIDENT TRANSIENT THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE SURF COEFF	AVERAGE	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	ENERGY
70.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
70.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
70.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
70.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
71.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
71.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
71.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
71.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
72.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
72.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
72.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
72.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
73.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
73.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
73.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
73.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
74.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
74.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
74.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
74.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
75.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
75.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
75.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
75.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
76.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
76.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
76.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
76.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
77.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
77.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
77.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
77.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
78.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
78.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
78.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
78.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
79.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
79.250	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
79.500	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
79.750	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000
80.000	209.444	MM	209.444	160.4910	202	209.444	66E-05	488.0000

91232 REV 4 1P-15-74 05/02/78 1A-13487 PAGE 5010055

36 INCH ELROW SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION

DATE 05/02/78

36 INCH ELROW SNUD COOLDOWN INCIDENT TRANSIENT FULL CERTIFICATION

TERMAL STRESS OUTSIDE

TRANSIENT THERMAL STRESS INSIDE

DELTA

DELTA

EQUIV LIM

TIME

TIME	EQUIV LIM	DELTA	DELTA	TRANSIENT THERMAL STRESS INSIDE	TERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
0.0000	1097	3.3210	3.3210	-2704	997	580.66	583.91	580.66	577.62	575.82	574.51	573.64	573.51	573.9
0.2500	1097	3.4973	3.4973	-2666	122	581.21	583.18	581.21	578.74	576.84	575.45	574.64	573.51	573.74
0.5000	1097	3.6736	3.6736	-2597	142	582.40	582.70	582.40	574.24	572.34	570.95	570.14	570.01	571.16
0.7500	1097	3.8499	3.8499	-2498	162	583.59	582.41	583.59	570.78	568.88	567.49	566.68	566.55	570.4
1.0000	1097	4.0262	4.0262	-2369	190	584.78	581.24	584.78	567.32	565.42	564.03	563.22	563.09	571.59
1.2500	1097	4.2025	4.2025	-2211	175	585.97	579.70	585.97	563.86	561.96	560.57	559.76	559.63	572.69
1.5000	1097	4.3788	4.3788	-2004	142	587.16	578.20	587.16	560.40	558.50	557.11	556.30	556.17	573.79
1.7500	1097	4.5551	4.5551	-1797	122	588.35	576.70	588.35	556.94	555.04	553.65	552.84	552.71	574.89
2.0000	1097	4.7314	4.7314	-1590	99	589.54	575.20	589.54	553.48	551.58	550.19	549.38	549.25	575.99
2.2500	1097	4.9077	4.9077	-1383	77	590.73	573.70	590.73	549.02	547.12	545.73	544.92	544.79	577.09
2.5000	1097	5.0840	5.0840	-1176	55	591.92	572.20	591.92	544.56	542.66	541.27	540.46	540.33	578.19
2.7500	1097	5.2603	5.2603	-969	33	593.11	570.70	593.11	540.10	538.20	536.81	536.00	535.87	579.29
3.0000	1097	5.4366	5.4366	-762	11	594.30	569.20	594.30	535.64	533.74	532.35	531.54	531.41	580.39
3.2500	1097	5.6129	5.6129	-555	-9	595.49	567.70	595.49	531.18	529.28	527.89	527.08	526.95	581.49
3.5000	1097	5.7892	5.7892	-348	-27	596.68	566.20	596.68	526.72	524.82	523.43	522.62	522.49	582.59
3.7500	1097	5.9655	5.9655	-141	-45	597.87	564.70	597.87	522.26	520.36	518.97	518.16	518.03	583.69
4.0000	1097	6.1418	6.1418	76	-63	599.06	563.20	599.06	517.80	515.90	514.51	513.70	513.57	584.79
4.2500	1097	6.3181	6.3181	269	-81	600.25	561.70	600.25	513.34	511.44	510.05	509.24	509.11	585.89
4.5000	1097	6.4944	6.4944	466	-99	601.44	560.20	601.44	508.78	506.88	505.49	504.68	504.55	586.99
4.7500	1097	6.6707	6.6707	663	-117	602.63	558.70	602.63	504.22	502.32	500.93	500.12	500.00	588.09
5.0000	1097	6.8470	6.8470	860	-135	603.82	557.20	603.82	500.00	498.10	496.71	495.90	495.77	589.19
5.2500	1097	7.0233	7.0233	1057	-153	605.01	555.70	605.01	495.44	493.54	492.15	491.34	491.21	590.29
5.5000	1097	7.2000	7.2000	1254	-171	606.20	554.20	606.20	490.88	488.98	487.59	486.78	486.65	591.39
5.7500	1097	7.3763	7.3763	1451	-189	607.39	552.70	607.39	486.32	484.42	483.03	482.22	482.09	592.49
6.0000	1097	7.5526	7.5526	1648	-207	608.58	551.20	608.58	481.76	479.86	478.47	477.66	477.53	593.59
6.2500	1097	7.7289	7.7289	1845	-225	609.77	549.70	609.77	477.20	475.30	473.91	473.10	472.97	594.69
6.5000	1097	7.9052	7.9052	2042	-243	610.96	548.20	610.96	472.64	470.74	469.35	468.54	468.41	595.79
6.7500	1097	8.0815	8.0815	2239	-261	612.15	546.70	612.15	468.08	466.18	464.79	463.98	463.85	596.89
7.0000	1097	8.2578	8.2578	2436	-279	613.34	545.20	613.34	463.52	461.62	460.23	459.42	459.29	597.99
7.2500	1097	8.4341	8.4341	2633	-297	614.53	543.70	614.53	458.96	457.06	455.67	454.86	454.73	599.09
7.5000	1097	8.6104	8.6104	2830	-315	615.72	542.20	615.72	454.40	452.50	451.11	450.30	450.17	600.19
7.7500	1097	8.7867	8.7867	3027	-333	616.91	540.70	616.91	449.84	447.94	446.55	445.74	445.61	601.29
8.0000	1097	8.9630	8.9630	3224	-351	618.10	539.20	618.10	445.28	443.38	441.99	441.18	441.05	602.39
8.2500	1097	9.1393	9.1393	3421	-369	619.29	537.70	619.29	440.72	438.82	437.43	436.62	436.49	603.49
8.5000	1097	9.3156	9.3156	3618	-387	620.48	536.20	620.48	436.16	434.26	432.87	432.06	431.93	604.59
8.7500	1097	9.4919	9.4919	3815	-405	621.67	534.70	621.67	431.60	429.70	428.31	427.50	427.37	605.69
9.0000	1097	9.6682	9.6682	4012	-423	622.86	533.20	622.86	427.04	425.14	423.75	422.94	422.81	606.79
9.2500	1097	9.8445	9.8445	4209	-441	624.05	531.70	624.05	422.48	420.58	419.19	418.38	418.25	607.89
9.5000	1097	10.0208	10.0208	4406	-459	625.24	530.20	625.24	417.92	416.02	414.63	413.82	413.69	608.99
9.7500	1097	10.1971	10.1971	4603	-477	626.43	528.70	626.43	413.36	411.46	410.07	409.26	409.13	610.09
10.0000	1097	10.3734	10.3734	4800	-495	627.62	527.20	627.62	408.80	406.90	405.51	404.70	404.57	611.19

TIME	EQUIV LIN. RAD	DELTA	DELTA	MELT2	TRANSIENT THERMAL STRIPS		INCIDENT THERMAL STRIPS		MODE 1	MODE 2	MODE 3	MODE 4	MODE 5	MODE 6	MODE 7	MODE 8	MODE 9
					INSIDE	OUTSIDE	INSIDE	OUTSIDE									
20.0000	5306	39.075	9.247	M.524	-4261	9394	4261	9394	534.62	545.13	553.70	567.59	571.00	573.68	575.90	577.33	578.41
20.2500	5514	40.002	M.764	M.999	-4317	9314	4317	9314	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
20.5000	5553	41.701	M.764	M.999	-4317	9314	4317	9314	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
20.7500	5570	43.557	M.559	M.832	-4315	9324	4315	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
21.0000	5573	43.244	M.377	M.644	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
21.2500	5593	44.309	M.331	M.557	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
21.5000	5617	44.731	M.297	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
22.0000	5124	45.104	M.297	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
22.2500	5154	45.438	M.297	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
22.5000	5215	45.763	M.306	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
23.0000	5224	46.023	M.313	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
23.2500	5325	46.285	M.335	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
23.5000	5386	46.753	M.372	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
24.0000	5439	46.969	M.412	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
24.2500	5466	47.173	M.431	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
24.5000	5489	47.550	M.450	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
25.0000	5511	47.725	M.487	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
25.2500	5533	48.050	M.520	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
25.5000	5552	48.201	M.536	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
25.7500	5593	48.345	M.551	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
26.0000	5611	48.442	M.559	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
26.2500	5624	48.612	M.574	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
26.5000	5654	48.854	M.603	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
26.7500	5659	48.965	M.603	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
27.0000	5674	49.071	M.614	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
27.2500	5691	49.177	M.634	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
27.5000	5701	49.267	M.634	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
27.7500	5714	49.357	M.633	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
28.0000	5725	49.442	M.650	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
28.2500	5735	49.522	M.650	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
28.5000	5751	49.574	M.657	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
28.7500	5766	49.664	M.649	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
29.0000	5774	49.707	M.645	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20
29.2500	5782	49.856	M.630	M.524	-4360	9324	4360	9324	532.66	543.84	551.10	566.90	570.00	572.90	575.00	576.50	577.20

TIME	EQUIV RAD	DELTA	MELIP	TRANSIENT THERMAL STRESS INSIDE	INCIDENT	TRANSIENT THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
30.0000	6790.	49.910	M.635	9403.		-6279.	474.91	480.50	485.25	493.91	500.90	506.21	510.04	518.35	521.30
30.2500	6797.	49.951	M.703	9412.		-6276.	473.33	458.80	483.64	492.14	497.14	502.70	506.56	516.35	519.25
30.5000	6803.	50.007	M.709	9417.		-6270.	471.52	446.54	479.70	487.37	492.57	497.21	500.80	508.81	509.80
30.7500	6809.	50.051	M.714	9426.		-6244.	469.26	443.85	474.14	481.60	485.61	489.23	492.41	500.50	505.04
31.0000	6815.	50.099	M.719	9433.		-6244.	467.76	443.05	474.54	481.84	485.27	488.47	491.24	499.54	503.24
31.2500	6820.	50.127	M.714	9437.		-6231.	465.42	442.14	474.54	481.27	484.30	487.47	490.51	498.77	502.52
31.5000	6824.	50.160	M.714	9444.		-6227.	462.24	441.69	472.79	479.69	482.52	485.70	488.74	496.91	500.75
32.0000	6812.	50.217	M.715	9453.		-6100.	464.64	440.50	471.71	478.52	481.35	484.52	487.57	495.74	499.24
32.2500	6835.	50.282	M.716	9455.		-6302.	446.54	457.01	469.22	477.02	484.76	492.37	499.19	498.24	498.24
32.5000	6834.	50.263	M.716	9459.		-6304.	443.85	455.22	467.42	475.18	482.94	490.52	497.41	496.64	497.21
33.0000	6841.	50.294	M.716	9464.		-6304.	443.05	453.62	465.63	473.34	481.10	488.81	495.63	494.90	495.62
33.2500	6846.	50.311	M.715	9465.		-6309.	442.24	451.62	462.04	470.75	478.50	486.23	493.06	492.12	493.04
33.5000	6845.	50.322	M.714	9467.		-6310.	441.69	449.43	460.25	469.26	477.01	484.74	491.57	490.57	491.04
33.7500	6847.	50.334	M.712	9467.		-6311.	440.86	447.40	458.45	467.17	475.92	483.65	490.54	489.57	490.57
34.0000	6844.	50.334	M.710	9464.		-6312.	440.06	446.21	456.65	465.37	474.12	481.85	488.75	487.75	488.75
34.2500	6844.	50.342	M.709	9464.		-6312.	439.27	444.91	454.85	463.57	472.32	480.05	486.95	485.91	486.95
34.5000	6844.	50.344	M.709	9467.		-6312.	438.47	443.61	453.85	462.57	471.32	479.05	485.95	484.91	485.95
34.7500	6844.	50.344	M.703	9465.		-6312.	437.67	442.41	453.05	461.77	470.52	478.25	485.15	484.11	485.15
35.0000	6844.	50.342	M.703	9465.		-6312.	436.87	441.21	452.25	460.97	469.72	477.45	484.35	483.31	484.35
35.2500	6846.	50.332	M.697	9461.		-6312.	436.07	440.02	451.44	460.16	468.91	476.64	483.54	482.50	483.54
35.5000	6846.	50.322	M.697	9461.		-6312.	435.27	438.82	450.64	459.36	468.11	475.84	482.74	481.70	482.74
35.7500	6845.	50.325	M.697	9459.		-6311.	434.47	437.62	449.55	458.27	467.02	474.75	481.65	480.61	481.65
36.0000	6843.	50.316	M.690	9454.		-6310.	433.67	436.41	448.44	457.16	465.91	473.64	480.54	479.50	480.54
36.2500	6842.	50.302	M.682	9454.		-6309.	432.87	435.20	447.22	455.94	464.69	472.42	479.32	478.28	479.32
36.5000	6840.	50.292	M.674	9447.		-6308.	432.07	434.00	446.03	454.75	463.50	471.23	478.13	477.09	478.13
36.7500	6839.	50.274	M.674	9447.		-6307.	431.27	432.83	445.00	453.72	462.47	470.20	477.10	476.06	477.10
37.0000	6837.	50.253	M.676	9441.		-6306.	430.47	431.63	444.24	452.96	461.71	469.44	476.34	475.30	476.34
37.2500	6833.	50.226	M.659	9439.		-6304.	429.67	430.83	443.47	452.19	460.94	468.67	475.57	474.53	475.57
37.5000	6830.	50.207	M.659	9437.		-6302.	428.87	429.97	442.71	451.44	460.17	467.90	474.80	473.76	474.80
38.0000	6824.	50.187	M.654	9426.		-6301.	428.07	429.17	441.94	450.67	459.40	467.13	474.03	472.99	474.03
38.2500	6820.	50.164	M.649	9421.		-6297.	427.27	428.37	441.17	450.00	458.73	466.46	473.36	472.32	473.36
38.5000	6817.	50.154	M.644	9421.		-6295.	426.47	427.57	440.40	449.13	457.86	465.59	472.49	471.45	472.49
38.7500	6813.	50.116	M.634	9415.		-6295.	425.67	426.77	439.63	448.36	457.09	465.22	472.35	471.31	472.35
39.0000	6809.	50.090	M.632	9406.		-6292.	424.87	425.97	438.86	447.59	456.32	464.05	471.20	470.16	471.20
39.2500	6805.	50.064	M.627	9398.		-6287.	424.07	425.17	438.09	446.72	455.45	463.18	470.09	469.05	470.09
39.5000	6801.	50.034	M.621	9392.		-6285.	423.27	424.37	437.32	445.96	454.69	462.31	469.20	468.16	469.20
39.7500	6797.	50.007	M.615	9386.		-6282.	422.47	423.57	436.55	445.19	453.92	461.44	468.33	467.29	468.33
40.0000	6797.	50.007	M.615	9386.		-6282.	421.67	422.77	435.74	444.42	453.15	460.67	467.56	466.52	467.56

TIME	ERJIV LIN. #AD	DELTA	DELTA	DELTA12	THERMAL STRESS TRANSIENT	THERMAL STRESS INCIDENT	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
40.0070	6792.	49.977	49.977	H.00A	OUTSIDE	390.44	402.46	413.19	421.45	428.85	434.25	439.41	440.32	441.07	441.07
40.2500	6792.	49.977	49.977	H.33A	INSIDE	389.44	401.17	413.19	421.45	428.85	434.25	439.41	439.41	439.41	439.41
40.5000	6697.	49.977	49.977	M.137	INSIDE	388.20	395.67	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
40.7500	6622.	48.737	48.737	M.039	INSIDE	387.00	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
41.0000	6540.	48.131	48.131	M.039	INSIDE	385.81	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
41.2500	5364.	47.494	47.494	M.039	INSIDE	384.67	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
41.5000	5364.	46.863	46.863	M.039	INSIDE	383.53	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
41.7500	4275.	46.231	46.231	M.039	INSIDE	382.39	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
42.0000	6186.	45.594	45.594	M.039	INSIDE	381.25	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
42.2500	5099.	44.962	44.962	M.039	INSIDE	380.11	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
42.5000	6013.	44.330	44.330	M.039	INSIDE	378.97	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
42.7500	5930.	43.698	43.698	M.039	INSIDE	377.83	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
43.0000	5847.	43.066	43.066	M.039	INSIDE	376.69	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
43.2500	5770.	42.434	42.434	M.039	INSIDE	375.55	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
43.5000	2693.	41.802	41.802	M.039	INSIDE	374.41	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
43.7500	5519.	41.170	41.170	M.039	INSIDE	373.27	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
44.0000	5548.	40.538	40.538	M.039	INSIDE	372.13	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
44.2500	5478.	39.906	39.906	M.039	INSIDE	370.99	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
44.5000	5411.	39.274	39.274	M.039	INSIDE	369.85	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
44.7500	3326.	38.642	38.642	M.039	INSIDE	368.71	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
45.0000	5243.	38.010	38.010	M.039	INSIDE	367.57	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
45.2500	5222.	37.378	37.378	M.039	INSIDE	366.43	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
45.5000	5166.	36.746	36.746	M.039	INSIDE	365.29	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
45.7500	5107.	36.114	36.114	M.039	INSIDE	364.15	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
46.0000	5052.	35.482	35.482	M.039	INSIDE	363.01	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
46.2500	4964.	34.850	34.850	M.039	INSIDE	361.87	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
46.5000	4850.	34.218	34.218	M.039	INSIDE	360.73	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
46.7500	4759.	33.586	33.586	M.039	INSIDE	359.59	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
47.0000	4676.	32.954	32.954	M.039	INSIDE	358.45	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
47.2500	4594.	32.322	32.322	M.039	INSIDE	357.31	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
47.5000	4512.	31.690	31.690	M.039	INSIDE	356.17	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
47.7500	4430.	31.058	31.058	M.039	INSIDE	355.03	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
48.0000	4348.	30.426	30.426	M.039	INSIDE	353.89	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
48.2500	4266.	29.794	29.794	M.039	INSIDE	352.75	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
48.5000	4184.	29.162	29.162	M.039	INSIDE	351.61	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
48.7500	4102.	28.530	28.530	M.039	INSIDE	350.47	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
49.0000	4020.	27.898	27.898	M.039	INSIDE	349.33	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
49.2500	3938.	27.266	27.266	M.039	INSIDE	348.19	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
49.5000	3856.	26.634	26.634	M.039	INSIDE	347.05	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
49.7500	3774.	26.002	26.002	M.039	INSIDE	345.91	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65
50.0000	3692.	25.370	25.370	M.039	INSIDE	344.77	395.87	408.13	415.26	423.21	428.59	432.30	435.65	435.65	435.65

SPRAY NOZZLE SHUD COOLDOWN INCIDENT ***** FULL CERTIFICATION ***** 91232 REV A 12-15-74 95/12/78 09-21431 PAGE 582CCAC

DATE 05/15/78

SPRAY NOZZLE SHUD COOLDOWN INCIDENT

DIMENSIONS

INSIDE RADIUS = 1.0652 INCHES
 NO. OF NODES = 9
 MATERIAL CODE = 3
 L = .1771
 OUTSIDE RADIUS = 2.5000 INCHES
 RADIAL INCREMENT = .1794 INCHES
 POISSON'S RATIO = .3000

NODE	INITIAL RADIUS	TEMPERATURE
1	1.0652	570.0
2	1.2446	570.0
3	1.4240	570.0
4	1.6034	570.0
5	1.7828	570.0
6	1.9622	570.0
7	2.1416	570.0
8	2.3210	570.0
9	2.5000	570.0

SPRAY NOZZLE FULL CERTIFICATION INCIDENT 91272 REV 4 FULL CERTIFICATION 09-21-81 PAGE 102CCAC

DATE 05/15/78

SPRAY NOZZLE SHUT COOLDOWN INCIDENT

TABULATION OF BOUNDARY CONDITIONS

FLUID TEMP CURVE APPROXIMATION TIME (MINUTES)	FLUID FLOW CURVE APPROXIMATION INSIDE FLOW GPM	PRESSURE CURVE APPROXIMATION TIME (MINUTES)	PRESSURE (PSI)
0.0000	180.0	0.0000	0.0
5.0000	180.0	0.0000	0.0
10.0000	0.0	0.0000	0.0
15.0000	0.0	0.0000	0.0
20.0000	0.0	0.0000	0.0
25.0000	0.0	0.0000	0.0
30.0000	0.0	0.0000	0.0
35.0000	0.0	0.0000	0.0
40.0000	0.0	0.0000	0.0
45.0000	0.0	0.0000	0.0
50.0000	0.0	0.0000	0.0
55.0000	0.0	0.0000	0.0
60.0000	0.0	0.0000	0.0
65.0000	0.0	0.0000	0.0
70.0000	0.0	0.0000	0.0
75.0000	0.0	0.0000	0.0
80.0000	0.0	0.0000	0.0
85.0000	0.0	0.0000	0.0
90.0000	0.0	0.0000	0.0
95.0000	0.0	0.0000	0.0
100.0000	0.0	0.0000	0.0
105.0000	0.0	0.0000	0.0
110.0000	0.0	0.0000	0.0

TEMPERATURE CALCULATION TIMES AND PRINTOUTS NUMBER OF PRINTOUTS
 TIME INCREMENT (MINUTES) 0.2500
 TIME LIMIT (MINUTES) 110.000
 NUMBER OF PRINTOUTS 440

* NOTE THAT A 180 GPM FLOW RATE WILL PRODUCE A CONSERVATIVE FILM COEFFICIENT SINCE THE LARGEST FLOW RATE LISTED ON PAGE A-7 IS 150 GPM.

SPRAY NOZZLE - SHUD COOLDOWN INCIDENT FULL CERTIFICATION 9125-003 9125-003 12-15-74 97/15/78 00-2781 042E 502CCAC

DATE 05/15/78

SPRAY NOZZLE - SHUD COOLDOWN INCIDENT

THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE SURF. TEMP	AVE. TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	DENSITY
30-000	425	464	470	26.77024	2267	662E+07	94E-05	488.9611
30-500	442	464	467	26.95806	2267	662E+07	94E-05	488.9611
30-750	442	464	465	26.43765	2265	662E+07	94E-05	489.0152
31-000	442	464	463	26.37541	2265	662E+07	94E-05	489.0152
31-250	442	464	463	26.15339	2263	662E+07	94E-05	489.0966
31-500	442	464	462	25.97359	2263	662E+07	94E-05	489.1239
31-750	442	464	462	25.74119	2263	662E+07	94E-05	489.1509
32-000	442	464	462	25.51744	2263	662E+07	94E-05	489.1779
32-250	442	464	462	25.29369	2263	662E+07	94E-05	489.2049
32-500	442	464	462	25.06994	2263	662E+07	94E-05	489.2319
32-750	442	464	462	24.84619	2263	662E+07	94E-05	489.2589
33-000	442	464	462	24.62244	2263	662E+07	94E-05	489.2859
33-250	442	464	462	24.39869	2263	662E+07	94E-05	489.3129
33-500	442	464	462	24.17494	2263	662E+07	94E-05	489.3399
33-750	442	464	462	23.95119	2263	662E+07	94E-05	489.3669
34-000	442	464	462	23.72744	2263	662E+07	94E-05	489.3939
34-250	442	464	462	23.50369	2263	662E+07	94E-05	489.4209
34-500	442	464	462	23.27994	2263	662E+07	94E-05	489.4479
34-750	442	464	462	23.05619	2263	662E+07	94E-05	489.4749
35-000	442	464	462	22.83244	2263	662E+07	94E-05	489.5019
35-250	442	464	462	22.60869	2263	662E+07	94E-05	489.5289
35-500	442	464	462	22.38494	2263	662E+07	94E-05	489.5559
35-750	442	464	462	22.16119	2263	662E+07	94E-05	489.5829
36-000	442	464	462	21.93744	2263	662E+07	94E-05	489.6099
36-250	442	464	462	21.71369	2263	662E+07	94E-05	489.6369
36-500	442	464	462	21.48994	2263	662E+07	94E-05	489.6639
36-750	442	464	462	21.26619	2263	662E+07	94E-05	489.6909
37-000	442	464	462	21.04244	2263	662E+07	94E-05	489.7179
37-250	442	464	462	20.81869	2263	662E+07	94E-05	489.7449
37-500	442	464	462	20.59494	2263	662E+07	94E-05	489.7719
37-750	442	464	462	20.37119	2263	662E+07	94E-05	489.7989
38-000	442	464	462	20.14744	2263	662E+07	94E-05	489.8259
38-250	442	464	462	19.92369	2263	662E+07	94E-05	489.8529
38-500	442	464	462	19.69994	2263	662E+07	94E-05	489.8799
38-750	442	464	462	19.47619	2263	662E+07	94E-05	489.9069
39-000	442	464	462	19.25244	2263	662E+07	94E-05	489.9339
39-250	442	464	462	19.02869	2263	662E+07	94E-05	489.9609
39-500	442	464	462	18.80494	2263	662E+07	94E-05	489.9879
39-750	442	464	462	18.58119	2263	662E+07	94E-05	489.9949
40-000	442	464	462	18.35744	2263	662E+07	94E-05	490.0019
40-250	442	464	462	18.13369	2263	662E+07	94E-05	490.0089
40-500	442	464	462	17.90994	2263	662E+07	94E-05	490.0159
40-750	442	464	462	17.68619	2263	662E+07	94E-05	490.0229

SHAW NOZZLE SHUD COOLDOWN INCIDENT FULL CERTIFICATION 91232 REV 4 12-15-74 05/15/78 05-2321 PAT 502CCAL

DATE 05/15/78

INTERNAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE COEFF	AVE TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	DENSITY
40.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
40.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
40.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
40.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
41.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
41.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
41.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
41.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
42.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
42.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
42.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
42.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
43.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
43.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
43.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
43.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
44.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
44.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
44.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
44.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
45.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
45.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
45.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
45.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
46.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
46.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
46.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
46.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
47.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
47.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
47.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
47.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
48.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
48.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
48.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
48.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
49.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
49.250	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
49.500	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
49.750	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000
50.000	330.0	4472	307.5231	11150	237	662.07	9.11	490.0000

THERMAL PROPERTIES
 SPRAY NOZZLE, SHJD COOLDOWN INCIDENT DATE 05/15/78

TIME	INSIDE FLUID TEMP	INSIDE FILM COEFF	AVE TEMP	CONDUCTIVITY	SPECIFIC HEAT	DENSITY	EXPANS COEFF
000	330	660	350	990	200	490	000
005	330	660	350	990	200	490	000
010	330	660	350	990	200	490	000
015	330	660	350	990	200	490	000
020	330	660	350	990	200	490	000
025	330	660	350	990	200	490	000
030	330	660	350	990	200	490	000
035	330	660	350	990	200	490	000
040	330	660	350	990	200	490	000
045	330	660	350	990	200	490	000
050	330	660	350	990	200	490	000
055	330	660	350	990	200	490	000
060	330	660	350	990	200	490	000
065	330	660	350	990	200	490	000
070	330	660	350	990	200	490	000
075	330	660	350	990	200	490	000
080	330	660	350	990	200	490	000
085	330	660	350	990	200	490	000
090	330	660	350	990	200	490	000
095	330	660	350	990	200	490	000
100	330	660	350	990	200	490	000
105	330	660	350	990	200	490	000
110	330	660	350	990	200	490	000
115	330	660	350	990	200	490	000
120	330	660	350	990	200	490	000
125	330	660	350	990	200	490	000
130	330	660	350	990	200	490	000
135	330	660	350	990	200	490	000
140	330	660	350	990	200	490	000
145	330	660	350	990	200	490	000
150	330	660	350	990	200	490	000
155	330	660	350	990	200	490	000
160	330	660	350	990	200	490	000
165	330	660	350	990	200	490	000
170	330	660	350	990	200	490	000
175	330	660	350	990	200	490	000
180	330	660	350	990	200	490	000
185	330	660	350	990	200	490	000
190	330	660	350	990	200	490	000
195	330	660	350	990	200	490	000
200	330	660	350	990	200	490	000

J 11144

SPRAY NOZZLE FULL COOLDOWN INCIDENT 91238 REV 4 12-15-78 FULL CERTIFICATION 05-37281 582CCAC

DATE 05/15/78

THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE WALL COEFF	AVERAGE TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	DENSITY
60.000	300	4285	300	7.681	90	0	0	2500
60.250	300	4282	300	7.681	90	0	0	2500
60.500	300	4282	300	7.681	90	0	0	2500
60.750	300	4281	300	7.681	90	0	0	2500
61.000	300	4279	300	7.681	90	0	0	2500
61.250	300	4277	300	7.681	90	0	0	2500
61.500	300	4275	300	7.681	90	0	0	2500
61.750	300	4273	300	7.681	90	0	0	2500
62.000	300	4271	300	7.681	90	0	0	2500
62.250	300	4270	300	7.681	90	0	0	2500
62.500	300	4269	300	7.681	90	0	0	2500
62.750	300	4267	300	7.681	90	0	0	2500
63.000	300	4265	300	7.681	90	0	0	2500
63.250	300	4265	300	7.681	90	0	0	2500
63.500	300	4264	300	7.681	90	0	0	2500
63.750	300	4263	300	7.681	90	0	0	2500
64.000	300	4260	300	7.681	90	0	0	2500
64.250	300	4259	300	7.681	90	0	0	2500
64.500	300	4257	300	7.681	90	0	0	2500
64.750	300	4255	300	7.681	90	0	0	2500
65.000	300	4254	300	7.681	90	0	0	2500
65.250	300	4253	300	7.681	90	0	0	2500
65.500	300	4251	300	7.681	90	0	0	2500
65.750	300	4250	300	7.681	90	0	0	2500
66.000	300	4248	300	7.681	90	0	0	2500
66.250	300	4247	300	7.681	90	0	0	2500
66.500	300	4245	300	7.681	90	0	0	2500
66.750	300	4244	300	7.681	90	0	0	2500
67.000	300	4243	300	7.681	90	0	0	2500
67.250	300	4241	300	7.681	90	0	0	2500
67.500	300	4240	300	7.681	90	0	0	2500
67.750	300	4239	300	7.681	90	0	0	2500
68.000	300	4237	300	7.681	90	0	0	2500
68.250	300	4235	300	7.681	90	0	0	2500
68.500	300	4233	300	7.681	90	0	0	2500
68.750	300	4231	300	7.681	90	0	0	2500
69.000	300	4229	300	7.681	90	0	0	2500









IMAGE EVALUATION
TEST TARGET (MT-3)



MICROCOPY RESOLUTION TEST CHART



SPRAY NOZZLE, SMUD COOLDOWN INCIDENT

DATE 05/15/78

TIME	EQJIV 3AO	LIN. STK.	DELTA1	DELTA2	THERMAL STRESS		NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
					INSIDE	OUTSIDE									
0.0000	-1779.	-10.124	-2.491	-2870.	883.	589.49	586.47	584.14	582.33	580.97	579.98	579.31	578.93	578.81	
0.2500	-1701.	-9.684	-1.964	-2670.	844.	589.54	586.97	584.83	583.11	581.77	580.78	580.11	579.72	579.60	
0.5000	-1584.	-9.018	-1.738	-2417.	815.	589.58	587.25	585.32	583.73	582.48	581.53	580.88	580.51	580.39	
0.7500	-1453.	-8.332	-1.574	-2221.	756.	589.62	587.44	585.72	584.26	583.10	582.22	581.61	581.26	581.14	
1.0000	-1348.	-7.675	-1.439	-2042.	698.	589.65	587.70	586.07	584.73	583.66	582.85	582.29	581.96	581.83	
1.2500	-1240.	-7.061	-1.320	-1877.	643.	589.68	587.89	586.39	585.16	584.17	583.43	582.91	582.60	582.51	
1.5000	-1140.	-6.494	-1.212	-1726.	591.	589.71	588.06	586.68	585.55	584.64	583.96	583.48	583.20	583.11	
1.7500	-1048.	-5.971	-1.114	-1587.	540.	589.73	588.22	586.95	585.91	585.08	584.44	584.00	583.75	583.66	
2.0000	-964.	-5.489	-1.024	-1459.	500.	589.75	588.36	587.20	586.24	585.47	584.89	584.49	584.25	584.18	
2.2500	-886.	-5.047	-0.942	-1341.	460.	589.77	588.49	587.42	586.54	585.84	585.30	584.93	584.71	584.64	
2.5000	-815.	-4.660	-0.856	-1233.	422.	589.79	588.61	587.63	586.82	586.17	585.69	585.34	585.14	585.08	
2.7500	-749.	-4.265	-0.776	-1133.	388.	589.81	588.73	587.82	587.08	586.48	586.03	585.72	585.53	585.48	
3.0000	-688.	-3.921	-0.703	-1042.	357.	589.82	588.83	588.00	587.31	586.77	586.35	586.06	585.89	585.84	
3.2500	-633.	-3.605	-0.633	-958.	328.	589.84	588.92	588.16	587.53	587.03	586.65	586.38	586.23	586.17	
3.5000	-582.	-3.316	-0.568	-880.	302.	589.85	589.01	588.31	587.73	587.27	586.92	586.67	586.53	586.48	
3.7500	-535.	-3.046	-0.508	-809.	277.	589.86	589.09	588.44	587.91	587.49	587.13	586.86	586.73	586.68	
4.0000	-492.	-2.801	-0.453	-744.	255.	589.87	589.15	588.57	588.08	587.69	587.33	587.01	586.89	586.84	
4.2500	-452.	-2.574	-0.402	-684.	236.	589.88	589.21	588.68	588.24	587.88	587.53	587.21	587.10	587.05	
4.5000	-415.	-2.367	-0.352	-629.	215.	589.89	589.25	588.79	588.38	588.05	587.70	587.41	587.30	587.25	
4.7500	-382.	-2.174	-0.306	-578.	199.	589.90	589.35	588.89	588.49	588.19	587.84	587.57	587.46	587.41	
5.0000	-351.	-2.000	-0.273	-531.	182.	589.91	589.40	588.98	588.61	588.33	588.00	587.73	587.62	587.57	
5.2500	41.	1.236	1.163	461.	46.	586.87	587.99	584.41	588.47	588.38	588.25	588.14	588.07	588.02	
5.5000	551.	3.139	2.035	1349.	-180.	583.79	585.90	7.10	587.73	588.02	588.13	588.16	588.15	588.15	
5.7500	1042.	6.049	2.936	2164.	-411.	580.64	583.62	585.50	586.66	587.35	587.74	587.95	588.05	588.08	
6.0000	1567.	8.810	3.253	2913.	-677.	577.56	581.23	583.71	585.71	586.44	587.11	587.32	587.42	587.44	
6.2500	1998.	11.377	3.769	3602.	-969.	574.43	578.76	581.79	583.46	584.33	585.27	585.46	585.55	585.58	
6.5000	2415.	13.749	4.198	4235.	-1124.	571.28	575.22	579.74	582.28	583.24	584.23	585.09	585.41	585.60	
6.7500	2800.	15.934	4.609	4818.	-1127.	568.13	571.62	577.61	580.53	581.59	582.74	583.94	584.44	584.64	
7.0000	3154.	17.945	4.986	5355.	-1157.	564.96	570.47	575.60	578.65	581.00	582.64	583.70	584.30	584.64	
7.2500	3480.	19.795	5.333	5849.	-1167.	561.79	563.27	573.10	576.67	579.27	581.10	582.01	582.78	583.20	
7.5000	3780.	21.498	5.653	6304.	-1181.	558.62	562.53	570.71	574.58	577.42	579.44	580.78	581.51	581.90	
7.7500	4056.	23.064	5.947	6723.	-1194.	555.44	562.74	568.26	572.60	575.66	577.64	579.08	579.90	580.30	
8.0000	4311.	24.506	6.218	7109.	-1206.	552.24	562.92	565.74	570.14	573.40	575.73	577.28	578.15	578.43	
8.2500	4546.	25.833	6.467	7455.	-1229.	549.05	563.06	563.17	567.80	571.24	573.71	575.36	576.24	576.54	
8.5000	4762.	27.055	6.697	7793.	-1240.	545.84	563.17	560.54	565.38	568.99	571.59	573.33	574.32	574.63	
8.7500	4961.	28.180	6.908	8095.	-1244.	542.64	563.25	557.86	562.46	566.67	569.39	571.28	572.24	572.57	
9.0000	5145.	29.217	7.103	8374.	-1253.	539.44	563.31	555.53	559.75	564.27	567.10	568.99	570.07	570.41	
9.2500	5313.	30.172	7.293	8632.	-1256.	535.22	563.34	553.37	557.73	561.80	564.73	566.70	567.82	568.17	
9.5000	5472.	31.053	7.449	8864.	-1257.	533.00	563.35	551.56	555.10	559.27	562.30	564.33	565.48	565.83	
9.7500	5616.	31.865	7.602	9089.	-1272.	529.78	563.33	549.92	552.41	556.69	560.80	562.89	564.08	564.46	

44-1

SPRAY NOZZLE FULL CERTIFICATION INCIDENT

91232 REV 4 12-15-74 05/15/78 09-37-01

91232 REV 4 12-15-74 05/15/78 09-37-01

PA 15 302cc

SPRAY NOZZLE SHUD COOLDOWN INCIDENT

TIME	EQUIV LIN. RAD	DELTA	DELTA 2	THERMAL INSIDE	THERMAL OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
30.0000	4208	23.700	5.358	6706	-2100	453.75	460.41	465.79	470.09	473.21	475.57	477.13	478.05	478.38
30.2500	4205	23.679	5.358	6707	-2100	458.75	459.57	463.97	466.34	471.33	473.74	475.13	476.25	476.59
30.5000	4200	23.644	5.352	6694	-2103	464.12	459.75	466.32	466.50	467.73	470.91	471.50	472.59	473.88
31.2500	4194	23.619	5.340	6691	-2102	469.49	453.11	456.69	460.88	465.90	468.43	469.85	470.76	471.05
31.5000	4185	23.606	5.346	6686	-2101	472.67	447.53	454.87	457.06	462.26	465.60	466.20	467.19	467.23
32.0000	4184	23.588	5.343	6684	-2100	479.05	445.87	451.23	453.24	458.42	462.78	464.37	465.27	465.40
32.2500	4192	23.575	5.342	6682	-2099	483.24	444.05	449.42	453.60	456.80	459.14	460.73	461.64	461.70
32.5000	4191	23.570	5.341	6681	-2098	487.61	442.27	445.79	451.97	453.16	455.51	457.10	458.01	458.10
33.0000	4191	23.563	5.340	6681	-2098	491.80	436.61	442.16	449.34	451.35	453.67	455.26	456.19	456.47
33.2500	4191	23.559	5.340	6681	-2098	496.36	433.17	438.53	444.71	447.72	451.06	453.83	454.37	454.84
34.0000	4193	23.554	5.340	6682	-2099	502.55	431.14	436.72	442.90	445.90	448.93	451.82	452.75	453.09
34.2500	4192	23.552	5.340	6683	-2099	509.92	429.55	434.90	439.09	442.28	444.62	446.21	447.12	447.31
34.5000	4193	23.559	5.341	6685	-2099	517.30	427.74	433.09	437.27	440.47	442.81	444.40	445.17	445.69
35.0000	4194	23.562	5.342	6687	-2099	525.67	426.11	431.47	435.65	438.84	441.09	442.59	443.79	444.17
35.2500	4195	23.564	5.342	6689	-2100	534.67	424.49	429.85	434.03	437.22	439.50	441.06	441.87	442.17
35.5000	4196	23.567	5.343	6690	-2101	544.05	422.98	428.34	432.52	435.71	437.95	439.34	439.86	440.17
36.0000	4198	23.570	5.345	6692	-2101	554.05	421.46	426.82	431.00	434.19	436.45	437.84	438.06	438.37
36.2500	4198	23.573	5.345	6693	-2102	564.42	420.04	425.40	429.58	432.77	435.03	436.42	436.65	436.96
36.5000	4199	23.574	5.345	6695	-2102	574.61	418.24	423.61	427.79	430.98	433.24	434.63	434.86	435.17
37.0000	4200	23.580	5.347	6697	-2103	584.61	416.41	421.78	425.96	429.15	431.41	432.80	433.03	433.34
37.2500	4201	23.584	5.347	6698	-2103	594.99	414.68	420.05	424.23	427.42	429.68	431.07	431.30	431.61
37.5000	4203	23.588	5.349	6702	-2104	604.99	413.05	418.42	422.60	425.79	428.05	429.44	429.67	429.98
37.7500	4205	23.597	5.352	6706	-2105	614.99	411.24	416.61	420.79	423.98	426.24	427.63	427.86	428.17
38.0000	4206	23.601	5.353	6706	-2105	624.99	409.41	414.78	418.96	422.15	424.41	425.80	426.03	426.34
38.2500	4207	23.611	5.353	6708	-2106	634.99	407.61	412.98	417.16	420.35	422.61	424.00	424.23	424.54
38.5000	4209	23.616	5.354	6710	-2107	644.99	406.09	410.46	414.64	417.83	420.09	421.48	421.71	422.02
39.0000	4211	23.623	5.357	6712	-2108	654.99	404.35	408.84	413.02	416.21	418.47	419.86	420.09	420.40
39.2500	4213	23.629	5.358	6717	-2109	664.99	402.55	407.04	411.22	414.41	416.67	418.06	418.29	418.60
39.5000	4214	23.635	5.359	6719	-2110	674.99	400.75	405.24	409.42	412.61	414.87	416.26	416.49	416.80

SPRAY NOZZLE SMUD COOLDOWN INCIDENT

DATE 05/15/78

TIME	EQUIV RAD	LIN. SW.	DEL T1	DEL T2	THERMAL STRESS INSIDE	THERMAL STRESS OUTSIDE	NODE 1	NODE 2	NODE 3	NODE 4	NODE 5	NODE 6	NODE 7	NODE 8	NODE 9
40.0000	4216.	2.641	3.660	6721.	-2110.	381.05	387.89	393.26	397.46	400.66	403.01	404.61	405.52	405.81	
40.2500	4125.	3.128	4.777	6479.	-2041.	380.01	386.44	391.61	395.72	398.88	401.21	402.80	403.72	404.01	
40.5000	4003.	2.444	4.752	6264.	-2024.	378.97	385.16	390.15	394.11	397.19	399.47	401.03	401.93	402.21	
40.7500	3879.	1.750	4.600	6045.	-1969.	377.94	383.91	388.75	392.59	395.57	397.78	399.30	400.18	400.46	
41.0000	3762.	1.089	4.455	5883.	-1908.	375.91	382.72	387.40	391.12	394.01	396.16	397.63	398.48	398.75	
41.2500	3652.	0.471	4.345	5715.	-1852.	375.88	381.54	386.08	389.69	392.50	394.54	396.00	396.83	397.04	
41.5000	3550.	0.898	4.237	5560.	-1793.	374.86	380.37	384.79	388.30	391.02	393.05	394.43	395.23	395.44	
41.7500	3455.	0.369	4.138	5417.	-1750.	373.84	379.21	383.52	386.94	389.59	391.56	392.90	393.68	393.93	
42.0000	3368.	0.881	4.047	5286.	-1705.	372.82	378.07	382.27	385.61	388.19	390.10	391.41	392.17	392.41	
42.2500	3288.	0.431	3.963	5165.	-1663.	371.80	376.94	381.05	384.30	386.82	388.69	389.96	390.70	390.94	
42.5000	3214.	0.016	3.845	5053.	-1625.	370.78	375.82	379.84	383.02	385.48	387.30	388.55	389.27	389.50	
42.7500	3146.	0.633	3.814	4950.	-1590.	369.77	374.71	378.64	381.76	384.17	385.93	387.17	387.87	388.04	
43.0000	3084.	0.241	3.758	4855.	-1557.	368.75	373.60	377.46	380.52	382.88	384.62	385.81	386.50	386.72	
43.2500	3026.	0.950	3.688	4768.	-1527.	367.74	372.50	376.30	379.30	381.61	383.32	384.49	385.15	385.38	
43.5000	2973.	0.657	3.632	4687.	-1500.	366.73	371.42	375.15	378.09	380.37	382.04	383.19	383.85	384.06	
43.7500	2923.	0.381	3.581	4613.	-1476.	365.72	370.34	374.01	376.91	379.14	380.79	381.91	382.56	382.77	
44.0000	2878.	0.127	3.533	4544.	-1451.	364.71	369.26	372.88	375.73	377.93	379.55	380.66	381.30	381.50	
44.2500	2835.	0.892	3.490	4481.	-1429.	363.70	368.19	371.76	374.57	376.74	378.34	379.43	380.05	380.25	
44.5000	2793.	0.676	3.448	4423.	-1409.	362.69	367.13	370.65	373.43	375.56	377.14	378.21	378.83	379.03	
44.7500	2763.	0.477	3.412	4369.	-1391.	361.68	366.07	369.55	372.29	374.40	375.95	377.01	377.62	377.82	
45.0000	2730.	0.294	3.374	4320.	-1374.	360.67	365.02	368.46	371.17	373.25	374.78	375.83	376.43	376.62	
45.2500	2700.	0.125	3.347	4275.	-1359.	359.67	363.97	367.37	370.05	372.11	373.63	374.66	375.25	375.44	
45.5000	2672.	0.959	3.318	4233.	-1344.	358.65	362.92	366.30	368.95	370.98	372.49	373.50	374.09	374.28	
45.7500	2647.	0.825	3.291	4194.	-1331.	357.65	361.88	365.22	367.85	369.87	371.35	372.36	372.94	373.13	
46.0000	2623.	0.693	3.266	4158.	-1318.	356.65	360.84	364.16	366.76	368.76	370.23	371.23	371.80	371.99	
46.2500	2601.	0.571	3.244	4126.	-1307.	355.64	359.81	363.10	365.68	367.66	369.12	370.11	370.68	370.86	
46.5000	2581.	0.459	3.223	4096.	-1297.	354.64	358.77	362.04	364.60	366.57	368.01	369.00	369.56	369.74	
46.7500	2563.	0.355	3.203	4068.	-1287.	353.64	357.74	360.99	363.53	365.49	366.92	367.89	368.45	368.63	
47.0000	2546.	0.260	3.186	4042.	-1278.	352.63	356.71	359.94	362.47	364.40	365.83	366.80	367.35	367.53	
47.2500	2530.	0.172	3.164	4018.	-1270.	351.63	355.69	358.84	361.41	363.33	364.75	365.71	366.26	366.44	
47.5000	2516.	0.091	3.154	3997.	-1263.	350.63	354.66	357.85	360.35	362.26	363.67	364.63	365.18	365.35	
47.7500	2503.	0.016	3.140	3977.	-1256.	349.62	353.64	356.87	359.30	361.20	362.60	363.56	364.10	364.27	
48.0000	2491.	0.948	3.128	3958.	-1250.	348.62	352.62	355.78	358.25	360.15	361.54	362.50	363.03	363.20	
48.2500	2479.	0.884	3.116	3941.	-1244.	347.62	351.60	354.75	357.21	359.10	360.48	361.44	361.96	362.14	
48.5000	2469.	0.826	3.105	3925.	-1238.	346.61	350.59	353.72	356.17	358.05	359.43	360.39	360.90	361.07	
48.7500	2459.	0.772	3.095	3911.	-1233.	345.61	349.57	352.80	355.13	357.00	358.38	359.34	359.85	359.92	
49.0000	2451.	0.723	3.086	3898.	-1229.	344.61	348.56	351.87	354.10	355.96	357.33	358.29	358.79	358.97	
49.2500	2443.	0.677	3.077	3886.	-1225.	343.61	347.55	350.85	353.07	354.93	356.29	357.25	357.75	357.92	
49.5000	2435.	0.636	3.070	3875.	-1221.	342.61	346.53	349.82	352.04	353.89	355.25	356.21	356.70	356.87	
49.7500	2428.	0.597	3.062	3864.	-1217.	341.61	345.52	348.80	351.02	352.86	354.22	355.18	355.66	355.83	

DECAY HEAT NOZZLE, SHUD COOLDOWN INCIDENT
FULL CERTIFICATION

FULL CERTIFICATION

91232 REV 4 12-15-74 05/15/78 09-22828 PAGE 2
FULL CERTIFICATION

DECAY HEAT NOZZLE, SHUD COOLDOWN INCIDENT

DATE 05/15/78

DIMENSIONS

INSIDE RADIUS = 5.2500 INCHES

OUTSIDE RADIUS = 9.6250 INCHES

REF A-6

NO. OF NODES = 9

RADIAL INCREMENT = .5469 INCHES

MATERIAL CODE = 1

POISSON'S RATIO = .3000

L = .8750

CLADDING THICK. = .1875

CLADDING MATL. = 3

INITIAL CONDITIONS

NODE	RADIUS	TEMPERATURE
1	5.2500	70.0
2	5.7969	70.0
3	6.3439	70.0
4	6.8906	70.0
5	7.4375	70.0
6	7.9844	70.0
7	8.5313	70.0
8	9.0781	70.0
9	9.6250	70.0

84-4

DECAY HEAT NOZZLE, SNUD COOLDOWN INCIDENT" FULL CERTIFICATION 01238 MEV A FULL CERTIFICATION 01238 MEV A FULL CERTIFICATION

DATE 05/15/78

DECAY HEAT NOZZLE, SNUD COOLDOWN INCIDENT

TABULATION OF BOUNDARY CONDITIONS			
FLUID TEMP. CURVE APPROXIMATION TIME (MINUTES)	INSIDE FLUID TEMPERATURE	FLUID FLOW CURVE APPROXIMATION TIME (MINUTES)	INSIDE FLOW GPM
0.0000	570.0	0.0000	0.0
5.0000	570.0	110.0000	0.0
10.0000	570.0	0.0000	0.0
15.0000	525.0	0.0000	0.0
20.0000	525.0	0.0000	0.0
25.0000	340.0	0.0000	0.0
30.0000	340.0	0.0000	0.0
35.0000	340.0	0.0000	0.0
40.0000	340.0	0.0000	0.0
45.0000	340.0	0.0000	0.0
50.0000	305.0	0.0000	0.0
55.0000	305.0	0.0000	0.0

TEMPERATURE CALCULATION TIMES AND PRINTOUTS
 TIME (MINUTES) 10.000
 NUMBER OF PRINTOUTS 440.

* THIS IS BASED ESSENTIALLY ON A ZERO FLOW RATE.

DECAY HEAT NOZZLE, SHUD COOLDOWN INCIDENT FULL CERTIFICATION 01232 REV 4 FULL CERTIFICATION 09-29-88 P25501CCAB

DATE 05/15/78

DECAY HEAT NOZZLE, SHUD COOLDOWN INCIDENT

THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP.	INSIDE FILM COEFF.	EFF. FILM COEFF.	AVG. TEMP.	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF. OF EXPANSION	EMISSIVITY
40.000	310.	367.	236.	471.846	329.454	1717.0	1.12E+07	0.000000	0.800000
40.500	319.	366.	236.	470.389	329.454	1717.0	1.12E+07	0.000000	0.800000
41.000	328.	363.	234.	469.349	329.454	1717.0	1.12E+07	0.000000	0.800000
41.500	337.	362.	233.	467.923	329.454	1717.0	1.12E+07	0.000000	0.800000
42.000	346.	360.	232.	466.376	329.454	1717.0	1.12E+07	0.000000	0.800000
42.500	355.	359.	232.	464.900	329.454	1717.0	1.12E+07	0.000000	0.800000
43.000	364.	358.	232.	463.495	329.454	1717.0	1.12E+07	0.000000	0.800000
43.500	373.	357.	230.	462.073	329.454	1717.0	1.12E+07	0.000000	0.800000
44.000	382.	356.	230.	460.743	329.454	1717.0	1.12E+07	0.000000	0.800000
44.500	391.	355.	229.	459.497	329.454	1717.0	1.12E+07	0.000000	0.800000
45.000	400.	354.	229.	458.328	329.454	1717.0	1.12E+07	0.000000	0.800000
45.500	409.	353.	228.	457.238	329.454	1717.0	1.12E+07	0.000000	0.800000
46.000	418.	352.	228.	456.220	329.454	1717.0	1.12E+07	0.000000	0.800000
46.500	427.	351.	227.	455.277	329.454	1717.0	1.12E+07	0.000000	0.800000
47.000	436.	350.	227.	454.403	329.454	1717.0	1.12E+07	0.000000	0.800000
47.500	445.	349.	226.	453.599	329.454	1717.0	1.12E+07	0.000000	0.800000
48.000	454.	348.	225.	452.868	329.454	1717.0	1.12E+07	0.000000	0.800000
48.500	463.	347.	225.	452.202	329.454	1717.0	1.12E+07	0.000000	0.800000
49.000	472.	346.	224.	451.603	329.454	1717.0	1.12E+07	0.000000	0.800000
49.500	481.	345.	224.	451.073	329.454	1717.0	1.12E+07	0.000000	0.800000
50.000	490.	344.	223.	450.604	329.454	1717.0	1.12E+07	0.000000	0.800000
50.500	499.	343.	223.	450.198	329.454	1717.0	1.12E+07	0.000000	0.800000
51.000	508.	342.	222.	449.857	329.454	1717.0	1.12E+07	0.000000	0.800000
51.500	517.	341.	222.	449.573	329.454	1717.0	1.12E+07	0.000000	0.800000
52.000	526.	340.	221.	449.348	329.454	1717.0	1.12E+07	0.000000	0.800000
52.500	535.	339.	221.	449.175	329.454	1717.0	1.12E+07	0.000000	0.800000
53.000	544.	338.	220.	449.057	329.454	1717.0	1.12E+07	0.000000	0.800000
53.500	553.	337.	220.	448.997	329.454	1717.0	1.12E+07	0.000000	0.800000
54.000	562.	336.	219.	448.997	329.454	1717.0	1.12E+07	0.000000	0.800000
54.500	571.	335.	219.	449.057	329.454	1717.0	1.12E+07	0.000000	0.800000
55.000	580.	334.	218.	449.175	329.454	1717.0	1.12E+07	0.000000	0.800000
55.500	589.	333.	218.	449.348	329.454	1717.0	1.12E+07	0.000000	0.800000
56.000	598.	332.	217.	449.573	329.454	1717.0	1.12E+07	0.000000	0.800000
56.500	607.	331.	217.	449.857	329.454	1717.0	1.12E+07	0.000000	0.800000
57.000	616.	330.	217.	450.198	329.454	1717.0	1.12E+07	0.000000	0.800000
57.500	625.	329.	216.	450.599	329.454	1717.0	1.12E+07	0.000000	0.800000
58.000	634.	328.	216.	451.073	329.454	1717.0	1.12E+07	0.000000	0.800000
58.500	643.	327.	215.	451.603	329.454	1717.0	1.12E+07	0.000000	0.800000
59.000	652.	326.	215.	452.198	329.454	1717.0	1.12E+07	0.000000	0.800000
59.500	661.	325.	214.	452.868	329.454	1717.0	1.12E+07	0.000000	0.800000
60.000	670.	324.	214.	453.603	329.454	1717.0	1.12E+07	0.000000	0.800000
60.500	679.	323.	213.	454.403	329.454	1717.0	1.12E+07	0.000000	0.800000
61.000	688.	322.	213.	455.277	329.454	1717.0	1.12E+07	0.000000	0.800000
61.500	697.	321.	212.	456.220	329.454	1717.0	1.12E+07	0.000000	0.800000
62.000	706.	320.	212.	457.238	329.454	1717.0	1.12E+07	0.000000	0.800000
62.500	715.	319.	211.	458.328	329.454	1717.0	1.12E+07	0.000000	0.800000
63.000	724.	318.	211.	459.497	329.454	1717.0	1.12E+07	0.000000	0.800000
63.500	733.	317.	210.	460.743	329.454	1717.0	1.12E+07	0.000000	0.800000
64.000	742.	316.	210.	462.073	329.454	1717.0	1.12E+07	0.000000	0.800000
64.500	751.	315.	209.	463.495	329.454	1717.0	1.12E+07	0.000000	0.800000
65.000	760.	314.	209.	465.017	329.454	1717.0	1.12E+07	0.000000	0.800000
65.500	769.	313.	208.	466.638	329.454	1717.0	1.12E+07	0.000000	0.800000
66.000	778.	312.	208.	468.360	329.454	1717.0	1.12E+07	0.000000	0.800000
66.500	787.	311.	207.	470.182	329.454	1717.0	1.12E+07	0.000000	0.800000
67.000	796.	310.	207.	472.104	329.454	1717.0	1.12E+07	0.000000	0.800000
67.500	805.	309.	206.	474.126	329.454	1717.0	1.12E+07	0.000000	0.800000
68.000	814.	308.	206.	476.248	329.454	1717.0	1.12E+07	0.000000	0.800000
68.500	823.	307.	205.	478.470	329.454	1717.0	1.12E+07	0.000000	0.800000
69.000	832.	306.	205.	480.792	329.454	1717.0	1.12E+07	0.000000	0.800000
69.500	841.	305.	204.	483.214	329.454	1717.0	1.12E+07	0.000000	0.800000
70.000	850.	304.	204.	485.736	329.454	1717.0	1.12E+07	0.000000	0.800000
70.500	859.	303.	203.	488.358	329.454	1717.0	1.12E+07	0.000000	0.800000
71.000	868.	302.	203.	491.080	329.454	1717.0	1.12E+07	0.000000	0.800000
71.500	877.	301.	202.	493.902	329.454	1717.0	1.12E+07	0.000000	0.800000
72.000	886.	300.	202.	496.824	329.454	1717.0	1.12E+07	0.000000	0.800000
72.500	895.	299.	201.	499.846	329.454	1717.0	1.12E+07	0.000000	0.800000
73.000	904.	298.	201.	502.968	329.454	1717.0	1.12E+07	0.000000	0.800000
73.500	913.	297.	200.	506.190	329.454	1717.0	1.12E+07	0.000000	0.800000
74.000	922.	296.	200.	509.512	329.454	1717.0	1.12E+07	0.000000	0.800000
74.500	931.	295.	199.	512.934	329.454	1717.0	1.12E+07	0.000000	0.800000
75.000	940.	294.	199.	516.456	329.454	1717.0	1.12E+07	0.000000	0.800000
75.500	949.	293.	198.	520.078	329.454	1717.0	1.12E+07	0.000000	0.800000
76.000	958.	292.	198.	523.800	329.454	1717.0	1.12E+07	0.000000	0.800000
76.500	967.	291.	197.	527.622	329.454	1717.0	1.12E+07	0.000000	0.800000
77.000	976.	290.	197.	531.544	329.454	1717.0	1.12E+07	0.000000	0.800000
77.500	985.	289.	196.	535.566	329.454	1717.0	1.12E+07	0.000000	0.800000
78.000	994.	288.	196.	539.688	329.454	1717.0	1.12E+07	0.000000	0.800000
78.500	1003.	287.	195.	543.910	329.454	1717.0	1.12E+07	0.000000	0.800000
79.000	1012.	286.	195.	548.232	329.454	1717.0	1.12E+07	0.000000	0.800000
79.500	1021.	285.	194.	552.654	329.454	1717.0	1.12E+07	0.000000	0.800000
80.000	1030.	284.	194.	557.176	329.454	1717.0	1.12E+07	0.000000	0.800000

DECAY HEAT NOZZLE S-MUD COOLDOWN INCIDENT FULL CERTIFICATION 01232 NEV 4 12-15-74 05/13/78 09.34.58 PAGE 301CAD

DECAY HEAT NOZZLE S-MUD COOLDOWN INCIDENT DATE 05/15/78

THERMAL PROPERTIES

TIME	INSIDE FLUID TEMP	INSIDE SHELL COEFF	EFFM COEFF	AVG TEMP	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANSION	DENSITY
00.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
00.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
00.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
00.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
01.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
01.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
01.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
01.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
02.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
02.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
02.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
02.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
03.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
03.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
03.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
03.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
04.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
04.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
04.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
04.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
05.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
05.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
05.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
05.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
06.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
06.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
06.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
06.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
07.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
07.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
07.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
07.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
08.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
08.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
08.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
08.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
09.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
09.250	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
09.500	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
09.750	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800
10.000	300.0	300.0	300.0	420.0	35.0	1.000	75000	0.00000	4800

DECAY HEAT NOZZLE SHUT DOWN INCIDENT **** FUEL CERTIFICATION **** 91232 REV 4 13-75-2A 971218 09-23150 PA361CCL8

DECAY HEAT NOZZLE SHUT DOWN INCIDENT

DATE 05/15/76

THERMAL PROPERTIES

TIME	INSIDE TEMP	INSIDE COEFF	FILM COEFF	Avg TEMP	CONDUCT	SPECIFIC HEAT	YOUNG'S MODULUS	COEFF OF EXPANS	SENSITV
60.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
60.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
60.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
60.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
61.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
61.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
61.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
61.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
62.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
62.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
62.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
62.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
63.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
63.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
63.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
63.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
64.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
64.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
64.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
64.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
65.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
65.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
65.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
65.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
66.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
66.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
66.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
66.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
67.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
67.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
67.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
67.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
68.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
68.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
68.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
68.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
69.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
69.250	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
69.500	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
69.750	300	504	504	372	34.4	25.5	800000	0.00000	0.00000
70.000	300	504	504	372	34.4	25.5	800000	0.00000	0.00000

DECAY HEAT NOZZLE SHUD COOLDOWN INCIDENT FULL CERTIFICATION ***** 91232 REV 4 12-15-74 07/13/78 09-20-78 PAGE 181CC118

DATE 05/15/78

DECAY HEAT NOZZLE SHUD COOLDOWN INCIDENT

THERMAL PROPERTIES

TIME	INSIDE FLUID T	INSIDE COEFF	EFF. FILM COEFF	AVG. T	CONDUCTIVITY	SPECIFIC HEAT	YOUNG'S MODULUS	EXP. OF	TEMP.
0000	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0050	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0100	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0150	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0200	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0250	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0300	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0350	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0400	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0450	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0500	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0550	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0600	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0650	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0700	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0750	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0800	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0850	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0900	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
0950	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1000	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1050	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1100	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1150	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1200	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1250	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1300	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1350	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1400	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1450	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1500	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1550	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1600	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1650	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1700	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1750	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1800	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1850	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1900	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
1950	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2000	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2050	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2100	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2150	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2200	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2250	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2300	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2350	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2400	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2450	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2500	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2550	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2600	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2650	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2700	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2750	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2800	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2850	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2900	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
2950	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700
3000	2990	5255	7700	4737	11760	0.44	192000	0.0000	2700

CONTRACT NO. 575-7072 620-0011	DOCUMENT COMMENT FORM	RELEASED BY <i>J.M. Burnett</i>	11/8/78
SUPPLIER B&W		TASK ENGINEER	DATE
PO. NO.	PREPARED BY: <i>J.M. Burnett</i>	11/8/78	REL. DATE 11-17-78
	NAME	DATE	PAGE 1 OF 1

<u>PART/TGS</u>	<u>B&W DOC. NO.</u>	<u>DOCUMENT TITLE</u>	<u>CUSTOMER/ SUPPLIER DOC. NO.</u>	<u>STATUS</u>	<u>RRL NUMBER</u>
55-01-001		OTSG SUPPORT SKIRT STRESS EVALUATION OF	620-0011-55 ORDER # 3075	APPROVED	N/A
33 0273 00		"RAPID COOLDOWN" EVENT OF MARCH 20, 1978 FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT, B&W CONTRACT NO. 620-0011-55, CUSTOMER ORDER #3075.			
55-01-001		OTSG LOWER TUBESHEET AREA AND TUBE STRESS EVALUATION DUE TO	620-0011-55 ORDER # 3075	APPROVED	N/A
33 0274 00		THE "RAPID COOLDOWN" EVENT OF MARCH 20, 1978 FOR SACRAMENTO MUNICIPAL UTILITY DISTRICT, B&W CONTRACT #620-0011-55, CUSTOMER ORDER NO. 3075,			

DISTRIBUTION:

- J.M. BURNETT (w/1 ATTACH)
- J.D. BREW (w/1 ATTACH) - MTV
- J.J. KELLY (w/6 ATTACH)
- J.T. JANIS (w/0 ATTACH)

OTSG SUPPORT SKIRT STRESS EVALUATION
OF "RAPID COOLDOWN" EVENT OF
MARCH 20, 1978
FOR
SACRAMENTO MUNICIPAL UTILITY DISTRICT
B&W CONTRACT NO. 620-0011-55
CUSTOMER ORDER #3075

BY: J. L. Harkins / Engineer / 08/28/78

APPROVED BY: John D. Brien / Supervisor / 8-29-78

B & W DOCUMENT NUMBER

33 0273 00

COMPONENT ENGINEERING
MT. VERNON WORKS
MT. VERNON, INDIANA

INTRODUCTION:

The Thermal Model was taken from the 'Stress Analysis of Support Skirt' for Sacramento Municipal Utility District, Report No. 3, B&W Contract No. 620-0011-55 and the cooldown transient experienced on March 20, 1978, was analyzed for cumulative damage. The cumulative fatigue from this occurrence was then combined with the usage factor anticipated for the service life of the plant.

The original analysis of the support skirt yielded primary plus secondary stress intensity ranges in excess of the $3 S_m$ allowable limit. Therefore, a simplified elastic analysis was performed to calculate the cumulative usage factor. The one cycle cooldown incident has been analyzed by the simplified elastic plastic method also.

DISCUSSION:

The thermal model from the stress report was subjected to the "cool-down" transient with the use of B&W computer program 91167, Transient Temperature Distribution. Heat balance equations were calculated by the program and the time-temperature history determined.

By comparing the thermal gradients between selected nodes in the 91167 output summary to those plotted in the stress report, it was found the cooldown transient produced more severe thermal gradients at the support skirt to head juncture; therefore, a stress evaluation was necessary.

The thermal and pressure motions of the juncture of the head and tubesheet were calculated in the evaluation of stresses produced by the cool-down incident on the tubesheet. These motions were imposed on the top edge of the head as boundary conditions. The dead weight at the head and support skirt interface produces a moment on the head due to the diameter of the support skirt being greater than the head diameter. The deadweight force and moment were imposed on the head at the juncture with the support skirt. These boundary conditions at the top of the head and at the interface between the head and support skirt along with the pressure and temperature distributions that produced the most severe gradients were applied to the stress model for the lower head by using B&W Program 91206, Save 55-2. The motions that resulted at the support skirt to head juncture were then imposed on the stress model for the support skirt and primary plus secondary and peak stress intensities were calculated.

JFH
05/75
620-0011-55

RESULTS:

The maximum primary plus secondary stress intensity range = 169.8 KSI > 80.1 KSI = 3 S_m ; therefore, a simplified elastic plastic analysis was performed.

The usage factor for the 1 cycle of "Rapid Cooldown" is 0.02.

The usage factor for 240 cycles of heatup and cooldown from the stress report is 0.89.

The cumulative usage factor is $0.89 + 0.02 = 0.91 < 1.0$.

JLH
08/78
620-0011-55
3

CONCLUSION:

The analysis of the "Cooldown" transient on the support skirt shows that the cumulative usage factor of the support skirt is less than the allowable; therefore, the structural integrity of the skirt is adequate for its anticipated service life.

JFH
08/78
620-001-55
4

THERMAL/MECHANICAL
ANALYSIS

REFERENCES:


1. Report No. 3, Stress Analysis of Support Skirt for Sacramento Municipal Utility District, B&W Contract No. 620-0011-55.
2. B&W letter from J.M. Burnett-RCS Components to Distribution, subject SMUD Cooldown Incident dated 4/4/78.
3. "OTSG Lower Tubesheet Area and Tube Stress Evaluation Due to the 'Rapid Cooldown' Event of March 20, 1978 for Sacramento Municipal Utility District", B&W Contract 620-0011-55.
4. ASME Code, Section III, 1965 Edition, with Addenda through Summer 1967.
5. USAS B31.7 Nuclear Power Piping Code, Draft USA Standard (Feb. 1968).
6. B&W Computer Program 91167, 'Explicit and Implicit Transient Temperature Distribution'.
7. B&W Computer Program 91032, 'Temperature Interpolation and Free-body Thermal Motions and Stresses'.
8. B&W Computer Program 91206, 'SAVE SS-2'.
9. B&W letter from J. M. Burnett - RCS Components to Distribution, Subject: SMUD Cooldown Incident, dated 4/7/78.
10. B&W letter from J. M. Burnett - RCS Components to Distribution, Subject: SMUD Cooldown Incident, dated 4/20/78.

JLH
08/78
620-0011-55

The thermal model of the support skirt and lower head as shown in Reference 1 was used in this analysis. The thermal parameters of the thermal grid in Reference 1 were also used.

The analyzed transient from Reference 2, is shown on the following page.

JFH
05/12
620-0011-50
6



REACTOR COOLANT TEMPERATURE VS TIME

J.L.H.
07/73
620-0011-55

The thermal model, thermal parameters and thermal transient were input into Program 91167, Transient Temperature Distribution, and the time-temperature history was determined.

A summary of certain nodes selected to show axial and radial gradients through the head and support skirt was obtained in the 91167 output.

Two times during the transient that produced the most severe gradients were selected by reviewing the summary.

The following pages contain sample output through Iteration 1 along with the selected iterations (40 and 45) and the nodal summary.

JLH
07/78
620-0011-55

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 911A7

DETERMINATION OF BLOCKS WITH FLUID BOUNDARIES

SERIES NO	BLOCK NO. FIRST	BLOCK NO. LAST	SIDE NO	FLUID FIRST	FLUID LAST	SERIES NO	BLOCK NO. FIRST	BLOCK NO. LAST	SIDE NO
1	240	241	1	173	1	1	196	215	3
2	241	161	1	173	1	2	196	215	3

AXIAL DIMENSION PER EDGE

EDGE NO	DIMENSION	EDGE NO	DIMENSION	EDGE NO	DIMENSION	EDGE NO	DIMENSION
1	4.00000	5	2.00000	9	2.00000	13	1.50000
2	1.00000	6	2.00000	10	1.00000	14	1.50000
3	1.00000	7	1.00000	11	1.00000	15	1.50000
4	1.00000	8	1.00000	12	1.00000	16	1.50000
5	1.00000	15	2.00000	17	2.00000	19	2.00000
6	1.00000	16	2.00000	18	2.00000	20	2.00000
7	1.00000	17	2.00000	19	2.00000	21	2.00000
8	1.00000	18	2.00000	20	2.00000	22	2.00000
9	1.00000	19	2.00000	21	2.00000	23	2.00000
10	1.00000	20	2.00000	22	2.00000	24	2.00000
11	1.00000	21	2.00000	23	2.00000	25	2.00000
12	1.00000	22	2.00000	24	2.00000	26	2.00000
13	1.00000	23	2.00000	25	2.00000	27	2.00000
14	1.00000	24	2.00000	26	2.00000	28	2.00000
15	1.00000	25	2.00000	27	2.00000	29	2.00000
16	1.00000	26	2.00000	28	2.00000	30	2.00000
17	1.00000	27	2.00000	29	2.00000	31	2.00000
18	1.00000	28	2.00000	30	2.00000	32	2.00000
19	1.00000	29	2.00000	31	2.00000	33	2.00000
20	1.00000	30	2.00000	32	2.00000	34	2.00000
21	1.00000	31	2.00000	33	2.00000	35	2.00000
22	1.00000	32	2.00000	34	2.00000	36	2.00000
23	1.00000	33	2.00000	35	2.00000	37	2.00000
24	1.00000	34	2.00000	36	2.00000	38	2.00000
25	1.00000	35	2.00000	37	2.00000	39	2.00000
26	1.00000	36	2.00000	38	2.00000	40	2.00000
27	1.00000	37	2.00000	39	2.00000	41	2.00000
28	1.00000	38	2.00000	40	2.00000	42	2.00000
29	1.00000	39	2.00000	41	2.00000	43	2.00000
30	1.00000	40	2.00000	42	2.00000	44	2.00000
31	1.00000	41	2.00000	43	2.00000	45	2.00000
32	1.00000	42	2.00000	44	2.00000	46	2.00000
33	1.00000	43	2.00000	45	2.00000	47	2.00000
34	1.00000	44	2.00000	46	2.00000	48	2.00000
35	1.00000	45	2.00000	47	2.00000	49	2.00000
36	1.00000	46	2.00000	48	2.00000	50	2.00000
37	1.00000	47	2.00000	49	2.00000	51	2.00000
38	1.00000	48	2.00000	50	2.00000	52	2.00000
39	1.00000	49	2.00000	51	2.00000	53	2.00000
40	1.00000	50	2.00000	52	2.00000	54	2.00000
41	1.00000	51	2.00000	53	2.00000	55	2.00000
42	1.00000	52	2.00000	54	2.00000	56	2.00000
43	1.00000	53	2.00000	55	2.00000	57	2.00000
44	1.00000	54	2.00000	56	2.00000	58	2.00000
45	1.00000	55	2.00000	57	2.00000	59	2.00000
46	1.00000	56	2.00000	58	2.00000	60	2.00000
47	1.00000	57	2.00000	59	2.00000	61	2.00000
48	1.00000	58	2.00000	60	2.00000	62	2.00000
49	1.00000	59	2.00000	61	2.00000	63	2.00000
50	1.00000	60	2.00000	62	2.00000	64	2.00000
51	1.00000	61	2.00000	63	2.00000	65	2.00000
52	1.00000	62	2.00000	64	2.00000	66	2.00000
53	1.00000	63	2.00000	65	2.00000	67	2.00000
54	1.00000	64	2.00000	66	2.00000	68	2.00000
55	1.00000	65	2.00000	67	2.00000	69	2.00000
56	1.00000	66	2.00000	68	2.00000	70	2.00000
57	1.00000	67	2.00000	69	2.00000	71	2.00000
58	1.00000	68	2.00000	70	2.00000	72	2.00000
59	1.00000	69	2.00000	71	2.00000	73	2.00000
60	1.00000	70	2.00000	72	2.00000	74	2.00000
61	1.00000	71	2.00000	73	2.00000	75	2.00000
62	1.00000	72	2.00000	74	2.00000	76	2.00000
63	1.00000	73	2.00000	75	2.00000	77	2.00000
64	1.00000	74	2.00000	76	2.00000	78	2.00000
65	1.00000	75	2.00000	77	2.00000	79	2.00000
66	1.00000	76	2.00000	78	2.00000	80	2.00000
67	1.00000	77	2.00000	79	2.00000	81	2.00000
68	1.00000	78	2.00000	80	2.00000	82	2.00000
69	1.00000	79	2.00000	81	2.00000	83	2.00000
70	1.00000	80	2.00000	82	2.00000	84	2.00000
71	1.00000	81	2.00000	83	2.00000	85	2.00000
72	1.00000	82	2.00000	84	2.00000	86	2.00000
73	1.00000	83	2.00000	85	2.00000	87	2.00000
74	1.00000	84	2.00000	86	2.00000	88	2.00000
75	1.00000	85	2.00000	87	2.00000	89	2.00000
76	1.00000	86	2.00000	88	2.00000	90	2.00000
77	1.00000	87	2.00000	89	2.00000	91	2.00000
78	1.00000	88	2.00000	90	2.00000	92	2.00000
79	1.00000	89	2.00000	91	2.00000	93	2.00000
80	1.00000	90	2.00000	92	2.00000	94	2.00000
81	1.00000	91	2.00000	93	2.00000	95	2.00000
82	1.00000	92	2.00000	94	2.00000	96	2.00000
83	1.00000	93	2.00000	95	2.00000	97	2.00000
84	1.00000	94	2.00000	96	2.00000	98	2.00000
85	1.00000	95	2.00000	97	2.00000	99	2.00000
86	1.00000	96	2.00000	98	2.00000	100	2.00000

J.L.H.
 07/79
 620-0011-55

TITLE (SMUD COOLDOWN SUPPORT SKIRT)
***** FULL CERTIFICATION *****

***** FULL CERTIFICATION *****

91167 REV A 12-15-76 07/17/78 16-32-37 PAGE 5
***** FULL CERTIFICATION ***** HRICMA

TRANSIENT TEMPERATURE DISTRIBUTION

PROGRAM 91167

MATERIAL SERIES

MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK
2	111	13	125	2	131	13	141	10	145	2	239

FLUID BLOCK

FILM COEF.

240	875.00	875.00	875.00	875.00	875.00
241	1.30	1.30	.65	.65	1.30
242	2.34	2.34	1.17	1.17	2.34

J.L.H.
07/28
620-0011-55

11

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

CYCLE NO. 1 IS IMPLICIT
 CYCLE NO. 2 IS IMPLICIT
 CYCLE NO. 3 IS IMPLICIT
 CYCLE NO. 4 IS IMPLICIT
 CYCLE NO. 5 IS IMPLICIT

IMPLICIT CYCLE INFORMATION													
LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP
6	.020												
6	.020												
6	.020												
6	.020												
12	.020	18	.056	23	.100	31	.300						

J.L.H.
 07/78
 620-0011-55
 12

TITLE (SMUD COOLDOWN SUPPORT SKIRT)
**** FULL CERTIFICATION ****

**** FULL CERTIFICATION ****

91167 REV A 12-15-76 07/17/78 16-2227 PAGE 7
**** FULL CERTIFICATION H01CCM6

TRANSIENT TEMPERATURE DISTRIBUTION

PROGRAM 91167

TIMES AT WHICH EQUATIONS WILL VARY

.16680 .33360 .50040 .66720 4.23380

TIMES FOR PRINTOUT

TIME LIMIT	TIME MULTIPLE
.00000	.02700
.33360	.05550
.66720	.10000
4.23380	.10000

J.L.H.
07/78
620-011-55
13

91167 REV 4 12-18-74 07/11/78 16-32-37 PABF
 FULL CERTIFICATION 16-32-37 PABF
 FULL CERTIFICATION

TITLE: SHUT DOWN SUPPORT SKIRT
 FULL CERTIFICATION

FULL CERTIFICATION

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

POINT NO. 240	TYPE 1	TIME	TEMP	25020	33360	440.00000	50040	56720	63400	70080	76760	83440	90120	96800	103480	110160	116840
570.00000	592.00000	1.63360	277.00000	592.00000	575.00000	540.00000	500.00000	460.00000	420.00000	380.00000	340.00000	300.00000	260.00000	220.00000	180.00000	140.00000	100.00000
277.00000	290.00000	1.63360	277.00000	302.00000	315.00000	328.00000	341.00000	354.00000	367.00000	380.00000	393.00000	406.00000	419.00000	432.00000	445.00000	458.00000	471.00000
300.00000	300.00000	4.23360	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000	300.00000

J.L.H.
 07/78
 620-11-55
 14

91167 REV * 12-15-74 91167/18 16-2227 PAGE 9
MOICOMA
***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION *****

TITLE: SHUD COOLDOWN SUPPORT SKIRT
***** FULL CERTIFICATION *****

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

POINT NO. 242 TYPE 1
TIME 0.00000 4.23340 999.99000 0.00000 0.00000 0.00000 0.00000 0.00000
TEMP 120.00000 120.00000 120.00000 0.00000 0.00000 0.00000 0.00000 0.00000

J.A.H.
07/78
620-0011-55
15

***** FULL CERTIFICATION *****

TRANSIENT TEMPERATURE DISTRIBUTION

1	45	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	
4	00	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02	02
8	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
12	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
16	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
20	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
24	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
28	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
32	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
36	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
40	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
44	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
48	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
52	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
56	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
60	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
64	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
68	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
72	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
76	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00
80	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00	00

824
0770
620-0011-55

ITER	PT	TEMPERATURE DISTRIBUTION										TIME
		TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	
1	1	573	573	573	573	572	572	572	572	572	572	.02780
2	1	572	572	573	573	573	573	573	573	573	573	.02780
3	1	576	576	574	574	574	574	574	574	574	574	.02780
4	1	571	571	570	570	570	570	570	570	570	570	.02780
5	1	574	574	574	574	574	574	574	574	574	574	.02780
6	1	567	567	569	569	570	570	570	570	570	570	.02780
7	1	574	574	574	574	574	574	574	574	574	574	.02780
8	1	572	572	569	569	564	564	563	563	563	563	.02780
9	1	567	567	571	571	574	574	574	574	574	574	.02780
10	1	574	574	574	574	561	561	568	568	568	568	.02780
11	1	557	557	554	554	540	540	535	528	520	520	.02780
12	1	574	574	498	498	557	557	556	555	555	555	.02780
13	1	571	571	526	526	502	502	487	471	430	430	.02780
14	1	574	574	338	338	327	327	327	327	327	327	.02780
15	1	574	574	502	502	486	486	465	420	393	393	.02780
16	1	574	574	238	238	222	218	201	193	188	182	.02780
17	1	574	574	53	53	44	44	36	36	32	32	.02780
18	1	574	574	540	540	446	446	426	415	402	406	.02780
19	1	574	574	393	393	359	317	280	255	237	222	.02780
20	1	574	574	187	187	177	177	171	163	151	145	.02780
21	1	574	574	37	37	32	32	25	25	24	24	.02780
22	1	574	574	504	504	472	472	448	440	445	440	.02780
23	1	574	574	507	507	545	544	539	536	530	574	.02780

JCH
 07/1/83
 620-0011-55

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM Q11A7

TIME	TEMPERATURE	DEPTH	LOCATION
0.00	240	0	1
0.05	240	0	1
0.10	240	0	1
0.15	240	0	1
0.20	240	0	1
0.25	240	0	1
0.30	240	0	1
0.35	240	0	1
0.40	240	0	1
0.45	240	0	1
0.50	240	0	1
0.55	240	0	1
0.60	240	0	1
0.65	240	0	1
0.70	240	0	1
0.75	240	0	1
0.80	240	0	1
0.85	240	0	1
0.90	240	0	1
0.95	240	0	1
1.00	240	0	1
1.05	240	0	1
1.10	240	0	1
1.15	240	0	1
1.20	240	0	1
1.25	240	0	1
1.30	240	0	1
1.35	240	0	1
1.40	240	0	1
1.45	240	0	1
1.50	240	0	1
1.55	240	0	1
1.60	240	0	1
1.65	240	0	1
1.70	240	0	1
1.75	240	0	1
1.80	240	0	1
1.85	240	0	1
1.90	240	0	1
1.95	240	0	1
2.00	240	0	1
2.05	240	0	1
2.10	240	0	1
2.15	240	0	1
2.20	240	0	1
2.25	240	0	1
2.30	240	0	1
2.35	240	0	1
2.40	240	0	1
2.45	240	0	1
2.50	240	0	1
2.55	240	0	1
2.60	240	0	1
2.65	240	0	1
2.70	240	0	1
2.75	240	0	1
2.80	240	0	1
2.85	240	0	1
2.90	240	0	1
2.95	240	0	1
3.00	240	0	1
3.05	240	0	1
3.10	240	0	1
3.15	240	0	1
3.20	240	0	1
3.25	240	0	1
3.30	240	0	1
3.35	240	0	1
3.40	240	0	1
3.45	240	0	1
3.50	240	0	1
3.55	240	0	1
3.60	240	0	1
3.65	240	0	1
3.70	240	0	1
3.75	240	0	1
3.80	240	0	1
3.85	240	0	1
3.90	240	0	1
3.95	240	0	1
4.00	240	0	1
4.05	240	0	1
4.10	240	0	1
4.15	240	0	1
4.20	240	0	1
4.25	240	0	1
4.30	240	0	1
4.35	240	0	1
4.40	240	0	1
4.45	240	0	1
4.50	240	0	1
4.55	240	0	1
4.60	240	0	1
4.65	240	0	1
4.70	240	0	1
4.75	240	0	1
4.80	240	0	1
4.85	240	0	1
4.90	240	0	1
4.95	240	0	1
5.00	240	0	1
5.05	240	0	1
5.10	240	0	1
5.15	240	0	1
5.20	240	0	1
5.25	240	0	1
5.30	240	0	1
5.35	240	0	1
5.40	240	0	1
5.45	240	0	1
5.50	240	0	1
5.55	240	0	1
5.60	240	0	1
5.65	240	0	1
5.70	240	0	1
5.75	240	0	1
5.80	240	0	1
5.85	240	0	1
5.90	240	0	1
5.95	240	0	1
6.00	240	0	1
6.05	240	0	1
6.10	240	0	1
6.15	240	0	1
6.20	240	0	1
6.25	240	0	1
6.30	240	0	1
6.35	240	0	1
6.40	240	0	1
6.45	240	0	1
6.50	240	0	1
6.55	240	0	1
6.60	240	0	1
6.65	240	0	1
6.70	240	0	1
6.75	240	0	1
6.80	240	0	1
6.85	240	0	1
6.90	240	0	1
6.95	240	0	1
7.00	240	0	1
7.05	240	0	1
7.10	240	0	1
7.15	240	0	1
7.20	240	0	1
7.25	240	0	1
7.30	240	0	1
7.35	240	0	1
7.40	240	0	1
7.45	240	0	1
7.50	240	0	1
7.55	240	0	1
7.60	240	0	1
7.65	240	0	1
7.70	240	0	1
7.75	240	0	1
7.80	240	0	1
7.85	240	0	1
7.90	240	0	1
7.95	240	0	1
8.00	240	0	1
8.05	240	0	1
8.10	240	0	1
8.15	240	0	1
8.20	240	0	1
8.25	240	0	1
8.30	240	0	1
8.35	240	0	1
8.40	240	0	1
8.45	240	0	1
8.50	240	0	1
8.55	240	0	1
8.60	240	0	1
8.65	240	0	1
8.70	240	0	1
8.75	240	0	1
8.80	240	0	1
8.85	240	0	1
8.90	240	0	1
8.95	240	0	1
9.00	240	0	1
9.05	240	0	1
9.10	240	0	1
9.15	240	0	1
9.20	240	0	1
9.25	240	0	1
9.30	240	0	1
9.35	240	0	1
9.40	240	0	1
9.45	240	0	1
9.50	240	0	1
9.55	240	0	1
9.60	240	0	1
9.65	240	0	1
9.70	240	0	1
9.75	240	0	1
9.80	240	0	1
9.85	240	0	1
9.90	240	0	1
9.95	240	0	1
10.00	240	0	1

8:54
07/79
620-6011-55
23

TITLE: SHUD COOLDOWN SUPPORT SKIRT 1
 FULL CERTIFICATION

91147 REV 4 12-15-74 07/11/78 16-23-57 PAGE 42
 FULL CERTIFICATION MOICCH4

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91147

TIME	TA	TR	TC	D	TD	TS	TF	TK	TT
00	224	667	100	.000	74	77	100	0.000	000
01	224	667	202	.000	74	77	202	.000	000
02	224	667	203	.000	74	77	203	.000	000
03	224	667	205	.000	74	77	205	.000	000
04	224	667	207	.000	74	77	207	.000	000
05	224	667	208	.000	74	77	208	.000	000
06	224	667	209	.000	74	77	209	.000	000
07	224	667	210	.000	74	77	210	.000	000
08	224	667	211	.000	74	77	211	.000	000
09	224	667	212	.000	74	77	212	.000	000
10	224	667	213	.000	74	77	213	.000	000
11	224	667	214	.000	74	77	214	.000	000
12	224	667	215	.000	74	77	215	.000	000
13	224	667	216	.000	74	77	216	.000	000
14	224	667	217	.000	74	77	217	.000	000
15	224	667	218	.000	74	77	218	.000	000
16	224	667	219	.000	74	77	219	.000	000
17	224	667	220	.000	74	77	220	.000	000
18	224	667	221	.000	74	77	221	.000	000
19	224	667	222	.000	74	77	222	.000	000
20	224	667	223	.000	74	77	223	.000	000
21	224	667	224	.000	74	77	224	.000	000
22	224	667	225	.000	74	77	225	.000	000
23	224	667	226	.000	74	77	226	.000	000
24	224	667	227	.000	74	77	227	.000	000
25	224	667	228	.000	74	77	228	.000	000
26	224	667	229	.000	74	77	229	.000	000
27	224	667	230	.000	74	77	230	.000	000
28	224	667	231	.000	74	77	231	.000	000
29	224	667	232	.000	74	77	232	.000	000
30	224	667	233	.000	74	77	233	.000	000
31	224	667	234	.000	74	77	234	.000	000
32	224	667	235	.000	74	77	235	.000	000
33	224	667	236	.000	74	77	236	.000	000
34	224	667	237	.000	74	77	237	.000	000
35	224	667	238	.000	74	77	238	.000	000
36	224	667	239	.000	74	77	239	.000	000
37	224	667	240	.000	74	77	240	.000	000
38	224	667	241	.000	74	77	241	.000	000
39	224	667	242	.000	74	77	242	.000	000
40	224	667	243	.000	74	77	243	.000	000
41	224	667	244	.000	74	77	244	.000	000
42	224	667	245	.000	74	77	245	.000	000
43	224	667	246	.000	74	77	246	.000	000
44	224	667	247	.000	74	77	247	.000	000
45	224	667	248	.000	74	77	248	.000	000
46	224	667	249	.000	74	77	249	.000	000
47	224	667	250	.000	74	77	250	.000	000
48	224	667	251	.000	74	77	251	.000	000
49	224	667	252	.000	74	77	252	.000	000
50	224	667	253	.000	74	77	253	.000	000
51	224	667	254	.000	74	77	254	.000	000
52	224	667	255	.000	74	77	255	.000	000
53	224	667	256	.000	74	77	256	.000	000
54	224	667	257	.000	74	77	257	.000	000
55	224	667	258	.000	74	77	258	.000	000
56	224	667	259	.000	74	77	259	.000	000
57	224	667	260	.000	74	77	260	.000	000
58	224	667	261	.000	74	77	261	.000	000
59	224	667	262	.000	74	77	262	.000	000
60	224	667	263	.000	74	77	263	.000	000
61	224	667	264	.000	74	77	264	.000	000
62	224	667	265	.000	74	77	265	.000	000
63	224	667	266	.000	74	77	266	.000	000
64	224	667	267	.000	74	77	267	.000	000
65	224	667	268	.000	74	77	268	.000	000
66	224	667	269	.000	74	77	269	.000	000
67	224	667	270	.000	74	77	270	.000	000
68	224	667	271	.000	74	77	271	.000	000
69	224	667	272	.000	74	77	272	.000	000
70	224	667	273	.000	74	77	273	.000	000
71	224	667	274	.000	74	77	274	.000	000
72	224	667	275	.000	74	77	275	.000	000
73	224	667	276	.000	74	77	276	.000	000
74	224	667	277	.000	74	77	277	.000	000
75	224	667	278	.000	74	77	278	.000	000
76	224	667	279	.000	74	77	279	.000	000
77	224	667	280	.000	74	77	280	.000	000
78	224	667	281	.000	74	77	281	.000	000
79	224	667	282	.000	74	77	282	.000	000
80	224	667	283	.000	74	77	283	.000	000
81	224	667	284	.000	74	77	284	.000	000
82	224	667	285	.000	74	77	285	.000	000
83	224	667	286	.000	74	77	286	.000	000
84	224	667	287	.000	74	77	287	.000	000
85	224	667	288	.000	74	77	288	.000	000
86	224	667	289	.000	74	77	289	.000	000
87	224	667	290	.000	74	77	290	.000	000
88	224	667	291	.000	74	77	291	.000	000
89	224	667	292	.000	74	77	292	.000	000
90	224	667	293	.000	74	77	293	.000	000
91	224	667	294	.000	74	77	294	.000	000
92	224	667	295	.000	74	77	295	.000	000
93	224	667	296	.000	74	77	296	.000	000
94	224	667	297	.000	74	77	297	.000	000
95	224	667	298	.000	74	77	298	.000	000
96	224	667	299	.000	74	77	299	.000	000
97	224	667	300	.000	74	77	300	.000	000
98	224	667	301	.000	74	77	301	.000	000
99	224	667	302	.000	74	77	302	.000	000
100	224	667	303	.000	74	77	303	.000	000

620-0011-55
 27

ITEM	TEMPERATURE DISTRIBUTION	TEMPERATURE	TIME
1	304	307	310
2	301	305	305
3	301	307	302
4	301	307	302
5	301	307	302
6	301	307	302
7	301	307	302
8	301	307	302
9	301	307	302
10	301	307	302
11	301	307	302
12	301	307	302
13	301	307	302
14	301	307	302
15	301	307	302
16	301	307	302
17	301	307	302
18	301	307	302
19	301	307	302
20	301	307	302
21	301	307	302
22	301	307	302
23	301	307	302
24	301	307	302
25	301	307	302
26	301	307	302
27	301	307	302
28	301	307	302
29	301	307	302
30	301	307	302
31	301	307	302
32	301	307	302
33	301	307	302
34	301	307	302
35	301	307	302
36	301	307	302
37	301	307	302
38	301	307	302
39	301	307	302
40	301	307	302
41	301	307	302
42	301	307	302
43	301	307	302
44	301	307	302
45	301	307	302
46	301	307	302
47	301	307	302
48	301	307	302
49	301	307	302
50	301	307	302
51	301	307	302
52	301	307	302
53	301	307	302
54	301	307	302
55	301	307	302
56	301	307	302
57	301	307	302
58	301	307	302
59	301	307	302
60	301	307	302
61	301	307	302
62	301	307	302
63	301	307	302
64	301	307	302
65	301	307	302
66	301	307	302
67	301	307	302
68	301	307	302
69	301	307	302
70	301	307	302
71	301	307	302
72	301	307	302
73	301	307	302
74	301	307	302
75	301	307	302
76	301	307	302
77	301	307	302
78	301	307	302
79	301	307	302
80	301	307	302
81	301	307	302
82	301	307	302
83	301	307	302
84	301	307	302
85	301	307	302
86	301	307	302
87	301	307	302
88	301	307	302
89	301	307	302
90	301	307	302
91	301	307	302
92	301	307	302
93	301	307	302
94	301	307	302
95	301	307	302
96	301	307	302
97	301	307	302
98	301	307	302
99	301	307	302
100	301	307	302

127
 07/8
 620-001-55

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 911A7

ITERATION	12	90	100	131	153	158	160	189	199	200	TIME
1	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	0.2500
2	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	0.5000
3	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	0.7500
4	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	1.0000
5	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	1.2500
6	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	1.5000
7	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	1.7500
8	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	2.0000
9	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	2.2500
10	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	2.5000
11	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	2.7500
12	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	3.0000
13	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	3.2500
14	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	3.5000
15	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	3.7500
16	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	4.0000
17	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	4.2500
18	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	4.5000
19	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	4.7500
20	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	5.0000
21	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	5.2500
22	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	5.5000
23	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	5.7500
24	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	6.0000
25	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	6.2500
26	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	6.5000
27	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	6.7500
28	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	7.0000
29	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	7.2500
30	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	7.5000
31	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	7.7500
32	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	8.0000
33	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	8.2500
34	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	8.5000
35	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	8.7500
36	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	9.0000
37	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	9.2500
38	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	9.5000
39	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	9.7500
40	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	10.0000
41	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	10.2500
42	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	10.5000
43	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	10.7500
44	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	11.0000
45	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	11.2500
46	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	11.5000
47	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	11.7500
48	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	12.0000
49	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	12.2500
50	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	12.5000
51	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	12.7500
52	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	13.0000
53	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	13.2500
54	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	13.5000
55	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	13.7500
56	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	14.0000
57	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	14.2500
58	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	14.5000
59	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	14.7500
60	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	55.00	15.0000

12-14
 07/78
 620-0011-55

TITLE: SMUD COOLDOWN SUPPORT SKIRT 1
FULL CERTIFICATION

**** FULL CERTIFICATION

91167 REV 4 12-15-79 07/17/78 16-22-87 PAGE 04
FULL CERTIFICATION

ITERATION	12	90	100	131	153	158	160	189	190	209	TIME
408.	389.	367.	401.	425.	387.	342.	475.	235.	51.	3.01100	
435.	403.	302.	401.	415.	378.	316.	414.	214.	51.	3.11100	
462.	419.	419.	400.	408.	370.	329.	406.	211.	51.	3.61100	
490.	431.	448.	418.	404.	362.	326.	401.	211.	51.	3.91100	
518.	457.	476.	429.	403.	357.	310.	398.	230.	51.	4.21100	

32
07/78
620001-55

TITLE: SHUG BOOL DOWN SUPPORT SKIRT | FULL CERTIFICATION | 16-2257 PAGE 07
 M01CCMA

***** FULL CERTIFICATION *****

ITERATION	TIME
228	0.02780
	0.05540
	0.08740
	0.11260
	0.14000
	0.16660
	0.19240
	0.21800
	0.24400
	0.27000
	0.29600
	0.32200
	0.34800
	0.37400
	0.40000
	0.42600
	0.45200
	0.47800
	0.50400
	0.53000
	0.55600
	0.58200
	0.60800
	0.63400
	0.66000
	0.68600
	0.71200
	0.73800
	0.76400
	0.79000
	0.81600
	0.84200
	0.86800
	0.89400
	0.92000
	0.94600
	0.97200
	0.99800
	1.02400
	1.05000
	1.07600
	1.10200
	1.12800
	1.15400
	1.18000
	1.20600
	1.23200
	1.25800
	1.28400
	1.31000
	1.33600
	1.36200
	1.38800
	1.41400
	1.44000
	1.46600
	1.49200
	1.51800
	1.54400
	1.57000
	1.59600
	1.62200
	1.64800
	1.67400
	1.70000
	1.72600
	1.75200
	1.77800
	1.80400
	1.83000
	1.85600
	1.88200
	1.90800
	1.93400
	1.96000
	1.98600
	2.01200
	2.03800
	2.06400
	2.09000
	2.11600
	2.14200
	2.16800
	2.19400
	2.22000
	2.24600
	2.27200
	2.29800
	2.32400
	2.35000
	2.37600
	2.40200
	2.42800
	2.45400
	2.48000
	2.50600
	2.53200
	2.55800
	2.58400
	2.61000
	2.63600
	2.66200
	2.68800
	2.71400
	2.74000
	2.76600
	2.79200
	2.81800
	2.84400
	2.87000
	2.89600
	2.92200
	2.94800
	2.97400
	2.99999

8276
 07/98
 620-011-55
 33

ITERATION	220	226	233	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	TIME
1	409.	415.	425.	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	2.03340
5	406.	405.	415.	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	2.23300
9	406.	398.	408.	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	2.43340
13	410.	389.	404.	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	2.93340
17	416.	384.	403.	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	0:	4.23340

127
 05/25
 620-001-55

TITLESMUD COOLDOWN SUPPORT SKIRT 91147 REV 4 12-15-74 FULL CERTIFICATION 16-22-57 PAGE 100
 FULL CERTIFICATION 91147 REV 4 12-15-74 FULL CERTIFICATION 16-22-57 PAGE 100
 FULL CERTIFICATION 91147 REV 4 12-15-74 FULL CERTIFICATION 16-22-57 PAGE 100

ITERATION	12-220	90-131	90-100	153-140	153-224	146-109	109-209	0-0	0-0	0-0	TIME
53	29	-10	27	42	9	167	42	0	0	0	3:07:00
54	56	10	16	70	10	162	47	0	0	0	3:23:00
55	60	19	-10	79	12	97	79	0	0	0	3:21:00
55	102	24	-10	84	14	89	77	0	0	0	4:21:00

JPH
 07/98
 620-0011-55

B&W Program 91206 (SAVE SS-2) was used to calculate primary plus secondary and peak stresses. The output for the 91167 thermal model is incompatible with the 91206 stress model input requirements. Program 91032 (Temperature Interpolation and Free-Body Thermal Motions and Stresses) was used to interpolate the temperature distribution onto 2 stress models compatible with Program 91206 input requirements. The support skirt and lower head were modeled separately for stress calculations. Refer to Ref. 1 for the stress model of the lower head and skirt for input into Program 91206 (SAVE SS-2).

The following pages contain the 91032 temperature interpolations for the two iterations selected for analysis onto each of the stress models.

JLH
07/78
620-0011-55

HEAD ONLY SHUD ***** FULL CERTIFICATION *****
 91032 REV 3 4-15-76 07/27/78 16.23.04 PAGE 6
 ***** FULL CERTIFICATION *****
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78
 HEAD ONLY SHUD ***** FULL CERTIFICATION *****
 ***** FULL CERTIFICATION *****
 ELEMENT -0.

DIMENSION PER COLUMN OF THE INITIAL GRID

COLUMN NO.	INSIDE RADIUS	BLOCK WIDTH	91167 TEMPERATURE GRID MODAL RADIUS	OUTSIDE RADIUS	LOW BLOCK NO.	HIGH BLOCK NO.
1	56.0000	3.0000	57.0000	58.0000	1	24
2	60.0000	3.0000	61.0000	62.0000	25	73
3	62.0000	3.0000	63.0000	64.0000	74	04
4	64.0000	3.0000	65.0000	66.0000	05	11
5	67.0000	3.0000	68.0000	69.0000	12	50
6	67.5000	3.0000	68.5000	69.5000	44	50
7	68.3400	3.0000	69.3400	70.3400	41	20
8	69.0000	3.0000	70.0000	71.0000	21	20
9	70.1200	3.0000	71.1200	72.1200	22	20
10	71.5000	3.0000	72.5000	73.5000	23	23

53-110-029
 05/78
 H-21

HEAD ONLY SMUD
 FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM
 HEAD ONLY SMUD
 FULL CERTIFICATION
 FULL CERTIFICATION
 FULL CERTIFICATION
 91032 REV 3
 07/27/78
 10-22-84
 PAGE 7
 07/27/78
 ELEMENT -0-

INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS
57.0000	50.0000	50.0000	50.0000
61.0000	63.0000	63.0000	63.0000
67.5000	66.7500	66.7500	66.7500
72.5000	70.6250	70.6250	70.6250

287
 07/78
 620-0011-55

HEAD ONLY SMUD ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION *****
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78
 HEAD ONLY SMUD ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION *****
 91032 REV 3 6-15-76 07/27/78 16.33.84 PAGE 8
 ***** FULL CERTIFICATION *****
 FLWENT -0.

FINAL GRID		INITIAL GRID			FINAL GRID			
EDGE NUMBER	DISTANCE FROM ZERO LINE	INSIDE RADIUS	OUTSIDE RADIUS	INSIDE RADIUS	RR(2)	RR(3)	RR(4)	OUTSIDE RADIUS
1	7.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
2	9.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
3	11.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
4	13.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
5	15.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
6	17.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
7	19.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
8	21.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
9	23.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
10	25.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
11	27.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
12	29.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
13	31.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
14	33.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
15	35.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
16	37.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
17	39.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
18	41.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
19	43.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
20	45.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
21	47.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
22	49.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
23	51.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
24	53.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000
25	55.0000	56.0000	64.0000	56.0000	58.0000	60.0000	62.0000	64.0000

***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 7 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 11 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 13 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 15 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 17 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 19 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 21 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 23 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 25 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 27 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 29 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 31 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 33 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 35 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 37 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 39 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 41 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 43 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 45 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 47 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 49 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 51 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 53 LAYER NO 40
 ***** CAUTION- YOUR FINAL GRID EXTENDS BEYOND THE OUTSIDE SURFACE OF YOUR INITIAL GRID AT EDGE 55 LAYER NO 40

JSH
 01/18
 620-001-55

HEAD ONLY SHUD FULL CERTIFICATION 91032 REV 3 4-15-76 07/27/78 16-227.4 PAGE
 FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78
 ELEMENT -0.

HEAD ONLY SHUD TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 40
 *IDENTIFIES PHANTOM SELEMENTS

SEGN NO.	OUTSIDE	INSIDE	CARD NO.
1	347	332	308 269 219 401.
2	358	335	310 270 219 402.
3	358	341	314 271 219 403.
4	375	350	318 274 220 404.
5	404	369	336 286 220 405.*
6	409	379	341 288 220 406.
7	427	393	354 297 220 407.*
8	426	399	358 299 220 408.
9	440	418	378 313 220 409.*
10	443	421	388 314 220 410.
11	449	430	391 323 220 411.*
12	458	432	392 323 220 412.
13	452	439	402 331 220 413.*
14	452	440	403 332 220 414.
15	453	441	403 330 220 415.
16	450	444	396 324 220 416.

***** NOTE THESE TEMPERATURES ARE (ACTUAL) MINUS (BASE) *****

24
 07/18
 620-0011-55

HEAD ONLY SMUD
**** FULL CERTIFICATION ****

**** FULL CERTIFICATION ****

91032 REV 3 4-15-76 07/27/78 16.33.04 PAGE 10
**** FULL CERTIFICATION ****

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78

HEAD ONLY SMUD

ELEMENT -0.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 40

SEGM NO.	CARD NO.	*IDENTIFIES PHANTOM SEGMENTS
17	390 353 319 274 220 417.*	
18	364 345 315 273 220 418.	
19	354 338 312 271 219 419.	
20	349 334 308 270 219 420.	
21	348 331 307 269 219 421.	
22	344 329 305 268 219 422.	
23	343 329 305 267 219 423.	
24	343 329 305 267 219 424.	
25	343 329 305 267 219 425.	
26	343 329 305 267 219 426.	

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

43
620-0011-55
07/78

HEAD ONLY SMUD
 FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3
 HEAD ONLY SMUD

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 45

IDENTIFIES PHANTOM SEGMENTS

SEGN
 NO. CARD
 NO.

OUTSIDE INSIDE

1	282	274	262	254	223	401.
2	268	279	266	245	224	402.
3	298	287	270	248	224	403.
4	317	299	277	251	225	404.
5	346	313	289	258	225	405.*
6	356	325	295	260	225	406.
7	374	339	304	266	225	407.*
8	379	348	310	268	225	408.
9	398	368	327	278	225	409.*
10	403	373	330	279	225	410.
11	413	385	340	285	225	411.*
12	415	388	343	286	225	412.
13	423	398	352	291	225	413.*
14	421	400	354	291	225	414.
15	422	405	355	290	225	415.
16	429	412	369	283	225	416.

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

07/18
 620-0011-55

HEAD ONLY SHUD
 FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3
 HEAD ONLY SHUD
 TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 45
 ELEMENT -7.

IDENTIFIES PHANTOM SEGMENT

SEGN NO.	CARD NO.
17	327 304 280 252 225 417.
18	308 293 274 250 224 416.
19	295 285 269 247 224 419.
20	286 278 264 245 224 420.
21	282 274 261 243 223 421.
22	278 269 257 241 223 422.
23	275 268 256 241 223 423.
24	274 267 256 240 223 424.
25	272 266 255 239 223 425.
26	273 266 255 239 223 426.

***** NOTE THESE TEMPERATURES ARE TACTUAL MINUS TIBASE *****

J.L.H.
 07/79
 620-0911-55
 45

SKIRT ONLY SMUD
CALCULATION CODE 7
PRINTED OUTPUT ONLY
BASE TEMPERATURE 70.00
NUMBER OF INPUT TEMPERATURES 91167 GRID - 242

EDGE NO.	TEMP. BLOCK HEIGHT	DIST FROM ZERO LINE TO EDGE	ZERO LINE TO BLOCK BOUNDARY	RADIUS	INSIDE SURFACE ADJ. BLOCK FILM COEFF.	RADIUS	OUTSIDE SURFACE ADJ. BLOCK FILM COEFF.	MATERIAL TYPE
1	0.000	1.2000	2.4000	67.5400	0.0000	13.0400	0.0000	MAG-MOLY
2	0.000	3.1500	2.4000	67.5400	0.0000	13.0400	0.0000	MAG-MOLY
3	0.000	7.0000	5.0000	67.5400	0.0000	73.0400	0.0000	MAG-MOLY
4	0.000	9.1700	10.1000	67.5400	0.0000	73.5800	0.0000	MAG-MOLY
5	0.000	11.3100	12.2000	67.5400	0.0000	70.1000	0.0000	MAG-MOLY
6	0.000	12.8300	14.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
7	0.000	14.6800	17.4000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
8	0.000	16.8000	20.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
9	0.000	19.1000	25.0000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
10	0.000	21.6000	30.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
11	0.000	24.3000	37.3000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
12	0.000	27.2000	45.2000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
13	0.000	30.3000	54.3000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
14	0.000	33.6000	64.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
15	0.000	37.1000	76.1000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
16	0.000	40.8000	88.8000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
17	0.000	44.7000	102.7000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
18	0.000	48.8000	117.8000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
19	0.000	53.1000	134.1000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
20	0.000	57.6000	151.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
21	0.000	62.3000	170.3000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
22	0.000	67.2000	190.2000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
23	0.000	72.3000	211.3000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY
24	0.000	77.6000	233.6000	67.5400	0.0000	69.0400	0.0000	MAG-MOLY

J.L.H.
07/78
620-0011-EE
46

SHIRT ONLY SHUD INPUT PER EDGE FOR INITIAL GRID (CONT.) ELEMENT -0.

EDGE NO.	TEMP. BLOCK HEIGHT	DIST FROM ZERO LINE TO EDGE	ZERO LINE TO BLOCK BOUNDARY	RADIUS	INSIDE SURFACE ADJ. BLOCK FILM COEFF.	RADIUS	OUTSIDE SURFACE ADJ. BLOCK FILM COEFF.	MATERIAL TYPE
27	1.0900	81.7400	84.8000	67.5400	0.0000	69.0400	242	MAG-HOLY
29	1.0900	89.7400	92.8000	67.5400	0.0000	69.0400	242	MAG-HOLY
30	1.9200	93.7400	96.7200	67.5400	0.0000	69.0400	242	MAG-HOLY
31	3.6600	96.5500	98.7800	67.5400	0.0000	69.0400	242	MAG-HOLY

J.L.H.
07/78
620-0011-55

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

07/27/78

SKIRT ONLY SMUD

ELEMENT -0.

DIMENSION PER COLUMN OF THE INITIAL GRID

COLUMN NO.	INSIDE RADIUS	BLOCK WIDTH	91167 TEMPERATURE GRID		LOW BLOCK NO.	HIGH BLOCK NO.
			NODAL RADIUS	OUTSIDE RADIUS		
1	67.5400	.7400	67.9200	68.3000	150	180
2	68.3000	.7400	68.6800	69.0600	185	215
3	69.0600	.7400	69.5800	70.1000	220	226
4	70.1000	.7400	70.8200	71.5400	230	234
5	71.5400	1.5200	72.3000	73.0600	237	230

620-0611-55

07/79

J.M.H.

48

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78

SKIRT ONLY SHUD

ELEMENT -0.

INITIAL INTERNAL RADIUS	INITIAL GRID DISTANCE FROM ZERO LINE TO CLOSEST SURFACE	INITIAL GRID DISTANCE FROM ZERO LINE TO FURTHEST SURFACE	INITIAL INTERNAL RADIUS	INITIAL GRID DISTANCE FROM ZERO LINE TO CLOSEST SURFACE	INITIAL GRID DISTANCE FROM ZERO LINE TO FURTHEST SURFACE
67.9200 69.5800 72.3000	0.0000 0.0000 0.0000	98.3801 14.1000 5.0000	68.6800 70.8200	0.0000 0.0000	98.3801 10.2400

T.L.H.
07/78
620-0011-55
49

SUPPORT SKIRT SHUD 91032 REV 3 4-15-76 07/27/78 16-33.04 PAGE 1A
 FULL CERTIFICATION ***** FULL CERTIFICATION ***** FULL CERTIFICATION *****
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78
 SKIRT ONLY SHUD ELEMENT -0.

F I N A L G R I D

EDGE NUMBER	INITIAL GRID	FINAL GRID	INSIDE RADIUS	OUTSIDE RADIUS	RR(1)	RR(3)	RR(4)	OUTSIDE RADIUS
1	5.5400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
2	4.2400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
3	3.9400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
4	3.7400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
5	3.5400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
6	3.3400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
7	3.1400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
8	2.9400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
9	2.7400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
10	2.5400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
11	2.3400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
12	2.1400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
13	1.9400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
14	1.7400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
15	1.5400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
16	1.3400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
17	1.1400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
18	0.9400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
19	0.7400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
20	0.5400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
21	0.3400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
22	0.1400	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
23	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
24	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
25	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
26	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
27	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
28	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
29	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
30	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
31	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
32	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
33	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
34	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
35	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
36	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
37	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
38	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
39	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
40	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
41	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
42	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
43	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
44	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
45	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
46	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
47	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
48	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
49	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400
50	0.0000	73.0400	67.5400	73.0400	67.5400	70.2900	73.0400	73.0400

J.H.
07/78
620-0011-55

SUPPORT SKIRT SMUD 91032 REV 3 4-15-75 07/27/7A 16-2324 PAGE 19
 FULL CERTIFICATION FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/7A
 SKIRT ONLY SMUD ELEMENT -0.

EDGE NUMBER	INITIAL GRID		FINAL GRID			
	INSIDE RADIUS	OUTSIDE RADIUS	IR(1)	OR(1)	IR(2)	OR(2)
35	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
36	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
37	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
38	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
39	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
40	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700
41	67.5600	70.1000	67.0050	70.2700	67.0050	70.2700

J.L.H.
 07/73
 620-0011-55

**** FULL CERTIFICATION ****

**** FULL CERTIFICATION ****

07/27/78

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

ELEMENT -0.

SKIRT ONLY SHUD

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 40

*IDENTIFIES PHANTOM SEGMENTS

CARD NO.

INSIDE

OUTSIDE

SEGN NO.	OUTSIDE	INSIDE
1	452 450 448 446 444 401.	
2	452 450 448 446 445 402.	
3	458 448 447 445 445 403.	
4	448 446 444 443 443 404.	
5	445 444 444 443 443 405.*	
6	442 441 440 440 440 406.	
7	439 438 436 435 435 407.	
8	436 434 432 431 429 408.	
9	434 428 424 423 422 409.	
10	424 424 423 423 422 410.*	
11	416 416 416 416 416 411.	
12	408 407 407 406 406 412.	
13	404 402 400 399 398 413.	
14	402 396 390 389 388 414.	
15	398 389 389 389 388 415.*	
16	383 383 382 382 382 416.	

***** NOTE THESE TEMPERATURES ARE (ACTUAL) MINUS (BIASE) *****

820-0011-25
 8/14
 07/78

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78

ELEMENT -0.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 40

*IDENTIFIES PHANTOM SEGMENTS

SEGN NO. CARD NO.

17	376	376	376	376	417.
18	369	369	369	370	418.
19	363	363	363	363	419.
20	357	357	357	357	420.
21	330	330	330	330	421.
22	303	303	303	303	422.
23	250	251	251	252	423.
24	211	211	212	212	424.
25	183	183	183	183	425.
26	162	162	162	162	426.
27	146	146	147	147	427.
28	135	135	135	136	428.
29	126	126	127	127	429.
30	120	120	120	120	430.
31	114	114	114	114	431.
32	108	108	108	109	432.
33	103	103	103	103	433.
34	96	96	96	96	434.
35	86	86	86	86	435.
36	78	78	78	78	436.

***** NOTE THESE TEMPERATURES ARE (ACTUAL MINUS T(BASE)) *****

2171
07/78
620-0011-55

SUPPORT SKIRT SMUD
**** FULL CERTIFICATION ****

**** FULL CERTIFICATION ****

91032 REV 3 4-15-76 07/27/78 16.33.04 PAGE 22
**** FULL CERTIFICATION ****

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78

SKIRT ONLY SMUD

ELEMENT -0.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 40

SEGN NO.	CARD NO.	*IDENTIFIES PHANTOM SEGMENTS				
37	72	72	72	72	72	437.
38	68	68	68	68	68	438.
39	65	65	65	65	65	439.
40	64	64	64	64	64	440.
41	63	63	63	63	63	441.

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

54
620-0011-55
07/78
JSH

SUPPORT SKIRT SHUD
 FULL CERTIFICATION
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM_91032 - REVISION 3
 SHIRT ONLY SHUD

91032 REV 3 4-15-76 07/27/74 16-33.84 PAGE 23
 FULL CERTIFICATION
 07/27/74
 ELEMENT -0.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 65

*IDENTIFIES PHANTOM SEGMENTS

SEGM NO.	CARD NO.	INSIDE
1	427 425 423 420 418 401.	
2	428 426 424 422 421 402.	
3	428 428 426 425 423 403.	
4	430 428 426 426 425 404.	
5	428 427 426 426 425 405.*	
6	427 426 425 424 424 406.	
7	425 424 423 422 422 407.	
8	423 422 421 419 418 408.	
9	421 418 415 414 412 409.	
10	415 415 414 413 412 410.*	
11	409 409 409 408 407 411.	
12	402 401 401 400 399 412.	
13	399 396 394 394 393 413.	
14	395 390 385 385 384 414.	
15	385 385 385 384 384 415.*	
16	378 378 378 378 378 416.	

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

620-0911-55
 05/78
 124

**** FULL CERTIFICATION **** FULL CERTIFICATION ****
 TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

07/27/78

ELEMENT -0.

SKIRT ONLY SMUD

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 45

*IDENTIFIES PHANTOM SEGMENTS

SEGN CARD
 NO. NO.

17	372	372	372	372	372	417.
18	368	366	366	366	366	418.
19	359	360	360	360	360	419.
20	353	353	353	353	354	420.
21	328	328	328	328	328	421.
22	302	302	302	302	302	422.
23	249	249	250	250	251	423.
24	209	209	210	210	210	424.
25	182	182	182	182	182	425.
26	161	161	161	161	161	426.
27	145	145	146	146	146	427.
28	135	135	135	135	136	428.
29	126	126	127	127	128	429.
30	119	120	120	121	121	430.
31	114	115	115	115	115	431.
32	108	108	108	108	108	432.
33	102	103	102	103	103	433.
34	96	96	96	96	97	434.
35	86	86	87	87	87	435.
36	78	78	78	78	78	436.

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

SUPPORT SKIRT SMUD
FULL CERTIFICATION

FULL CERTIFICATION

91032 REV 3 4-15-76 07/27/78 16-22:04 PAGE 7/9

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 07/27/78

SKIRT ONLY SMUD

ELEMENT -0.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 45

SEGN
NO.

CARD
NO.

*IDENTIFIES PHANTOM SEGMENTS

37	78	72	72	72	73	437.
38	68	68	68	68	68	438.
39	65	65	65	65	66	439.
40	63	63	63	64	64	440.
41	63	63	63	63	63	441.

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

57
620-011-55
D7710
JH

The stress model of the lower head was input to Program 91206 with the interpolated temperatures from Program 91032.

In the B&W Analysis, "OTSG Lower Tubesheet Area and Tube Stress Evaluation due to the 'Rapid Cooldown' event of March 20, 1978 for Sacramento Municipal Utility District", the thermal and pressure motions at the junction of the tubesheet and lower head were calculated. These motions were input as boundary conditions at the top of the head.

The mechanical loads as calculated in Reference 1 were input as intermediate forces at the junction of the support skirt and lower head.

The lower head stress model was analyzed for motions at the interface of the support skirt to lower head. The following pages contain the 91206 output for the selected iterations for the lower head.

JLH
08/78
620-0011-55

ITEMIZATION AN PAGE 1 DATE 04/04/78

INPUT DATA DATE 04/04/78

TOTAL NO. OF SEGMENTS = 70

BOUNDARY CONDITIONS AT THE TOP (0) END

1. A RADIAL DEFLECTION OF .11540 INCHES FROM REF. 3

2. A ROTATION OF -.00124 RADIAN

BOUNDARY CONDITIONS AT THE BOTTOM (N) END

1. AN AXIAL FORCE OF 0.00000 POUNDS

2. A RADIAL DEFLECTION OF 0.00000 INCHES

3. A ROTATION OF 0.00000 RADIAN

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.

SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.

ALL LOADS ABOVE ARE ON A TOTAL LOAD BASIS.

620-0011-55
 1/80
 1/10

ITERATION 40 PAGE 2 DATE 08/08/78

MID-SURFACE GEOMETRY
 AT TOP BOUNDARY, MEAN RADIUS = 63.2530, Z COORDINATE = 66.6000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	MEAN RADIUS	Z COORD.	CENT. OF CURVATURE DATA IDENTIFIER
1.0	63.154	65.100	0.000 70.000 1.0
2.0	63.010	63.500	0.000 70.000 1.0
3.0	63.742	61.500	0.000 70.000 1.0
4.0	63.016	61.500	0.000 70.000 1.0
5.0	63.702	60.000	0.000 70.000 1.0
6.0	63.107	60.000	0.000 70.000 1.0
7.0	63.883	58.600	0.000 70.000 1.0
8.0	63.000	58.600	0.000 70.000 1.0
9.0	63.604	57.000	0.000 70.000 1.0
10.0	63.214	57.000	0.000 70.000 1.0
11.0	64.825	55.000	0.000 70.000 1.0
12.0	65.706	55.000	0.000 70.000 1.0
13.0	65.513	54.000	0.000 70.000 1.0
14.0	65.044	52.700	0.000 70.000 1.0
15.0	64.410	51.700	0.000 70.000 1.0
16.0	60.643	51.700	0.000 70.000 1.0
17.0	60.104	50.000	0.000 70.000 1.0
18.0	59.725	48.000	0.000 70.000 1.0
19.0	59.287	46.200	0.000 70.000 1.0
20.0	52.461	36.500	0.000 70.000 1.0
21.0	63.000	66.600	0.000 70.000 1.0

60
 5-11-78
 H.P.

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD ***** 01204 REV 3 0-8-74 08/04/74 09.50.30 PAGE 4
***** M11C19

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD ***** ITERATION NO PAGE 3 DATE 08/04/74

NOTE - CURVATURE IDENTIFIER * 1 = POSITIVE CURVATURE
0 = NO CURVATURE
- 1 = NEGATIVE CURVATURE

55-100-027
08/75
H.J.F.

SMUD COOLDOWN INC. SUPPORT SKIRT HEAD ITERATION 40 PAGE 4 DATE 08/04/78

SEGMENTAL GEOMETRY BY SEGMENTS (K = SEGMENT NO.)

MEAN RADIUS										
K	R(K-1)	R(K)	R(K+1)	R(K+2)	R(K+3)	R(K+4)	R(K+5)	R(K+6)	R(K+7)	R(K+8)
1	63.25	63.15	63.01	62.78	62.94	62.70	63.16	62.88	63.81	63.70
2	65.31	64.84	65.79	65.58	65.98	64.81	68.64	68.10	69.73	69.86
3	58.29	56.58	54.63	52.66	47.82	40.64	33.52	25.13	17.43	8.88
4	.00									

Z COORDINATE										
K	Z(K-1)	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)
1	66.60	65.10	63.50	61.60	61.60	60.00	60.00	58.40	58.60	57.80
2	57.80	55.60	55.60	54.70	52.70	51.70	51.70	50.00	48.00	47.04
3	45.20	41.51	37.94	34.50	27.54	21.43	16.24	12.12	9.11	7.27
4	6.66									

620-011-55
 8/1/75
 J.P.H.
 62

SMUD COOLDOWN II. SUPPORT SKIRT HEAD ITERATION 40 PAGE 4 DATE 08/04/78

SEGMENT THICKNESS DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TOP THICK. OF TOP SEG.	BOTTOM THICK. OF BOTTOM SEG.
1	2	0.00	0.00
2	3	0.00	0.00
3	4	0.00	0.00
4	5	0.00	0.00
5	6	0.00	0.00
6	7	0.00	0.00
7	8	0.00	0.00
8	9	0.00	0.00
9	10	0.00	0.00
10	11	0.00	0.00
11	12	0.00	0.00
12	13	0.00	0.00
13	14	0.00	0.00
14	15	0.00	0.00
15	16	0.00	0.00
16	17	0.00	0.00
17	18	0.00	0.00
18	19	0.00	0.00
19	20	0.00	0.00
20	21	0.00	0.00
21	22	0.00	0.00
22	23	0.00	0.00
23	24	0.00	0.00
24	25	0.00	0.00
25	26	0.00	0.00
26	27	0.00	0.00
27	28	0.00	0.00
28	29	0.00	0.00
29	30	0.00	0.00
30	31	0.00	0.00
31	32	0.00	0.00
32	33	0.00	0.00
33	34	0.00	0.00
34	35	0.00	0.00
35	36	0.00	0.00
36	37	0.00	0.00
37	38	0.00	0.00
38	39	0.00	0.00
39	40	0.00	0.00
40	41	0.00	0.00
41	42	0.00	0.00
42	43	0.00	0.00
43	44	0.00	0.00
44	45	0.00	0.00
45	46	0.00	0.00
46	47	0.00	0.00
47	48	0.00	0.00
48	49	0.00	0.00
49	50	0.00	0.00
50	51	0.00	0.00
51	52	0.00	0.00
52	53	0.00	0.00
53	54	0.00	0.00
54	55	0.00	0.00
55	56	0.00	0.00
56	57	0.00	0.00
57	58	0.00	0.00
58	59	0.00	0.00
59	60	0.00	0.00
60	61	0.00	0.00
61	62	0.00	0.00
62	63	0.00	0.00
63	64	0.00	0.00
64	65	0.00	0.00
65	66	0.00	0.00
66	67	0.00	0.00
67	68	0.00	0.00
68	69	0.00	0.00
69	70	0.00	0.00
70	71	0.00	0.00
71	72	0.00	0.00
72	73	0.00	0.00
73	74	0.00	0.00
74	75	0.00	0.00
75	76	0.00	0.00
76	77	0.00	0.00
77	78	0.00	0.00
78	79	0.00	0.00
79	80	0.00	0.00
80	81	0.00	0.00
81	82	0.00	0.00
82	83	0.00	0.00
83	84	0.00	0.00
84	85	0.00	0.00
85	86	0.00	0.00
86	87	0.00	0.00
87	88	0.00	0.00
88	89	0.00	0.00
89	90	0.00	0.00
90	91	0.00	0.00
91	92	0.00	0.00
92	93	0.00	0.00
93	94	0.00	0.00
94	95	0.00	0.00
95	96	0.00	0.00
96	97	0.00	0.00
97	98	0.00	0.00
98	99	0.00	0.00
99	100	0.00	0.00

SEGMENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (MM)	THICKNESS AT BOTTOM OF SEGMENT (MM)	MARK-1	MARK-2	MARK-3	MARK-4	MARK-5	MARK-6	MARK-7	MARK-8	MARK-9
1	14.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	8.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1	14.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	8.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

620-029
 8/180
 H/S
 63

0870
 220-0011-55
 64

SHUD COLDOWN INC. SUPPORT SKIRI HEAD		ITERATION		AN PAGE 4 DATE 08/04/78	
SEG. NO.	ALPHA	MONI US OF	FUNCTION	CHRN	UNIT
6755	00	2872	00	00	00
6756	00	2873	00	00	00
6757	00	2874	00	00	00
6758	00	2875	00	00	00
6759	00	2876	00	00	00
6760	00	2877	00	00	00
6761	00	2878	00	00	00
6762	00	2879	00	00	00
6763	00	2880	00	00	00
6764	00	2881	00	00	00
6765	00	2882	00	00	00
6766	00	2883	00	00	00
6767	00	2884	00	00	00
6768	00	2885	00	00	00
6769	00	2886	00	00	00
6770	00	2887	00	00	00
6771	00	2888	00	00	00
6772	00	2889	00	00	00
6773	00	2890	00	00	00
6774	00	2891	00	00	00
6775	00	2892	00	00	00
6776	00	2893	00	00	00
6777	00	2894	00	00	00
6778	00	2895	00	00	00
6779	00	2896	00	00	00
6780	00	2897	00	00	00
6781	00	2898	00	00	00
6782	00	2899	00	00	00
6783	00	2900	00	00	00
6784	00	2901	00	00	00
6785	00	2902	00	00	00
6786	00	2903	00	00	00
6787	00	2904	00	00	00
6788	00	2905	00	00	00
6789	00	2906	00	00	00
6790	00	2907	00	00	00
6791	00	2908	00	00	00
6792	00	2909	00	00	00
6793	00	2910	00	00	00
6794	00	2911	00	00	00
6795	00	2912	00	00	00
6796	00	2913	00	00	00
6797	00	2914	00	00	00
6798	00	2915	00	00	00
6799	00	2916	00	00	00
6800	00	2917	00	00	00
6801	00	2918	00	00	00
6802	00	2919	00	00	00
6803	00	2920	00	00	00
6804	00	2921	00	00	00
6805	00	2922	00	00	00
6806	00	2923	00	00	00
6807	00	2924	00	00	00
6808	00	2925	00	00	00
6809	00	2926	00	00	00
6810	00	2927	00	00	00
6811	00	2928	00	00	00
6812	00	2929	00	00	00
6813	00	2930	00	00	00
6814	00	2931	00	00	00
6815	00	2932	00	00	00
6816	00	2933	00	00	00
6817	00	2934	00	00	00
6818	00	2935	00	00	00
6819	00	2936	00	00	00
6820	00	2937	00	00	00
6821	00	2938	00	00	00
6822	00	2939	00	00	00
6823	00	2940	00	00	00
6824	00	2941	00	00	00
6825	00	2942	00	00	00
6826	00	2943	00	00	00
6827	00	2944	00	00	00
6828	00	2945	00	00	00
6829	00	2946	00	00	00
6830	00	2947	00	00	00
6831	00	2948	00	00	00
6832	00	2949	00	00	00
6833	00	2950	00	00	00
6834	00	2951	00	00	00
6835	00	2952	00	00	00
6836	00	2953	00	00	00
6837	00	2954	00	00	00
6838	00	2955	00	00	00
6839	00	2956	00	00	00
6840	00	2957	00	00	00
6841	00	2958	00	00	00
6842	00	2959	00	00	00
6843	00	2960	00	00	00
6844	00	2961	00	00	00
6845	00	2962	00	00	00
6846	00	2963	00	00	00
6847	00	2964	00	00	00
6848	00	2965	00	00	00
6849	00	2966	00	00	00
6850	00	2967	00	00	00
6851	00	2968	00	00	00
6852	00	2969	00	00	00
6853	00	2970	00	00	00
6854	00	2971	00	00	00
6855	00	2972	00	00	00
6856	00	2973	00	00	00
6857	00	2974	00	00	00
6858	00	2975	00	00	00
6859	00	2976	00	00	00
6860	00	2977	00	00	00
6861	00	2978	00	00	00
6862	00	2979	00	00	00
6863	00	2980	00	00	00
6864	00	2981	00	00	00
6865	00	2982	00	00	00
6866	00	2983	00	00	00
6867	00	2984	00	00	00
6868	00	2985	00	00	00
6869	00	2986	00	00	00
6870	00	2987	00	00	00
6871	00	2988	00	00	00
6872	00	2989	00	00	00
6873	00	2990	00	00	00
6874	00	2991	00	00	00
6875	00	2992	00	00	00
6876	00	2993	00	00	00
6877	00	2994	00	00	00
6878	00	2995	00	00	00
6879	00	2996	00	00	00
6880	00	2997	00	00	00
6881	00	2998	00	00	00
6882	00	2999	00	00	00
6883	00	3000	00	00	00

SHUD COLDOWN INC. SUPPORT SKIRI HEAD *****
 0120A REV 3 5-A-75 04/04/78 09.58 39 PAGE 9

 SHUD COLDOWN INC. SUPPORT SKIRI HEAD *****

SHUD COLDOWN INC. SUPPORT SKIRI HEAD *****

ITERATION 40 PAGE 7 DATE 0A/0A/7A

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD

PRESSURE INPUT DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INTERNAL PRESSURE	EXTERNAL PRESSURE
1.0	3.0	2000.0	0.0
2.0	4.0	2000.0	0.0
3.0	5.0	2000.0	0.0
4.0	6.0	2000.0	0.0
5.0	7.0	2000.0	0.0
6.0	8.0	2000.0	0.0
7.0	9.0	2000.0	0.0
8.0	10.0	2000.0	0.0
9.0	11.0	2000.0	0.0
10.0	12.0	2000.0	0.0
11.0	13.0	2000.0	0.0
12.0	14.0	2000.0	0.0
13.0	15.0	2000.0	0.0
14.0	16.0	2000.0	0.0
15.0	17.0	2000.0	0.0

MECHANICAL LOADING ON SEGMENTAL GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	1.0	0.	0.	0.
15.0	15.0	0.	0.	0.
16.0	16.0	0.	0.	0.

FROM REFERENCE 1, PAGE B-12-1

5-11
 89/77
 620-0-11-55
 65

ITERATION 40 PAGE 8 DATE 08/04/78

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD
STRESS CONCENTRATION FACTORS BY GROUPS

TOP BOTTOM INSIDE OUTSIDE
SEG. NO. SEG. NO. TENSION REMAINING TENSION REMAINING
1 30 1.00 1.00

JPH
09/78
620-0011-55
66

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD ITERATION 40 PAGE 9 DATE 08/04/78

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

SEGMENT	OUTSIDE	T1	T2	T3	T4	INSIDE	T5	T6	T7	T8	T9	T10	T11	T12	T13	T14	T15
1	300.	300.	300.	300.	300.	300.	312.	312.	312.	312.	312.	312.	312.	312.	312.	312.	312.
2	304.	304.	304.	304.	304.	304.	307.	307.	307.	307.	307.	307.	307.	307.	307.	307.	307.
3	310.	310.	310.	310.	310.	310.	302.	302.	302.	302.	302.	302.	302.	302.	302.	302.	302.
4	326.	326.	326.	326.	326.	326.	209.	209.	209.	209.	209.	209.	209.	209.	209.	209.	209.
5	331.	331.	331.	331.	331.	331.	207.	207.	207.	207.	207.	207.	207.	207.	207.	207.	207.
6	342.	342.	342.	342.	342.	342.	204.	204.	204.	204.	204.	204.	204.	204.	204.	204.	204.
7	345.	345.	345.	345.	345.	345.	204.	204.	204.	204.	204.	204.	204.	204.	204.	204.	204.
8	340.	340.	340.	340.	340.	340.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
9	342.	342.	342.	342.	342.	342.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
10	370.	370.	370.	370.	370.	370.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
11	371.	371.	371.	371.	371.	371.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
12	371.	371.	371.	371.	371.	371.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
13	378.	378.	378.	378.	378.	378.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
14	378.	378.	378.	378.	378.	378.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.
15	375.	375.	375.	375.	375.	375.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.	206.

69
 55-112-070
 2-120
 H-8

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD ***** ITERATION 40 PAGE 10 DATE 08/04/78

***** PRIMARY + SECONDARY BOUNDARY AND FLEXIBILITY MATRICES *****

----- BOUNDARY FORCES DUE TO THE END CONDITIONS -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	ROTATION (N)	RADIAL DEFL. (N)	ROTATION (N)	SUM
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
ROTATION (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

----- FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS) -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	ROTATION (N)	RADIAL DEFL. (N)	ROTATION (N)	SUM
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
ROTATION (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

----- BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS -----

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	ROTATION (N)	RADIAL DEFL. (N)	ROTATION (N)	SUM
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
ROTATION (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

620-201-55
8
68

ITERATION 40 PAGE 11 DATE 08/04/78

FLEXIBILITY MATRIX OF ASSEMBLY 45 IN PROGRAM Q10A8
 (THIS MATRIX ONLY IS ON A PER NASTAV PASTIC)

	M101	Q101	M101	Q101
ROTATION(01)	.164134E-09	.140545E-09	.110856E-15	-.203927E-13
DEFLECTION(01)	.40544E-08	.545970E-07	.558806E-14	-.126570E-13
ROTATION(M)	.110545E-15	.224840E-14	.105007E-11	.746941E-13
DEFLECTION(M)	-.203927E-13	-.126570E-12	.764041E-11	.275444E-10

NOTE- THE + SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE - SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED IN ALL OF THE OFF-DIAGONAL ELEMENTS.

J-24
 09/17
 69

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD
PRIMARY SECONDARY FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	1103E+00	877E+00	199E+00	TOP	1154E+00	-124E-02	5180E-02
2	ROT	181E+00	724E+00	99E+00	ROT	1044E+00	763E-02	181E+00
3	ROT	119E+00	584E+00	97E+00	ROT	727E+00	580E-02	107E+00
4	ROT	819E+00	401E+00	64E+00	ROT	730E+00	-730E-02	184E+00
5	ROT	730E+00	270E+00	64E+00	ROT	607E+00	-817E-02	226E+00
6	ROT	620E+00	282E+00	64E+00	ROT	523E+00	-820E-02	226E+00
7	ROT	520E+00	162E+00	92E+00	ROT	420E+00	-846E-02	226E+00
8	ROT	543E+00	187E+00	92E+00	ROT	407E+00	-809E-02	250E+00
9	ROT	582E+00	170E+00	89E+00	ROT	493E+00	-893E-02	223E+00
10	ROT	612E+00	140E+00	89E+00	ROT	414E+00	-814E-02	205E+00
11	ROT	716E+00	621E+00	87E+00	ROT	327E+00	-827E-02	210E+00
12	ROT	779E+00	470E+00	82E+00	ROT	256E+00	-825E-02	210E+00
13	ROT	827E+00	310E+00	70E+00	ROT	186E+00	-820E-02	210E+00
14	ROT	877E+00	149E+00	50E+00	ROT	110E+00	-820E-02	210E+00
15	ROT	907E+00	0E+00	30E+00	ROT	39E+00	-820E-02	210E+00
16	ROT	927E+00	-149E+00	9E+00	ROT	-39E+00	-820E-02	210E+00
17	ROT	947E+00	-308E+00	-59E+00	ROT	-109E+00	-820E-02	210E+00
18	ROT	967E+00	-457E+00	-119E+00	ROT	-179E+00	-820E-02	210E+00
19	ROT	987E+00	-606E+00	-179E+00	ROT	-249E+00	-820E-02	210E+00
20	ROT	1007E+00	-755E+00	-239E+00	ROT	-319E+00	-820E-02	210E+00
21	ROT	1027E+00	-904E+00	-299E+00	ROT	-389E+00	-820E-02	210E+00
22	ROT	1047E+00	-1053E+00	-359E+00	ROT	-459E+00	-820E-02	210E+00
23	ROT	1067E+00	-1202E+00	-419E+00	ROT	-529E+00	-820E-02	210E+00
24	ROT	1087E+00	-1351E+00	-479E+00	ROT	-599E+00	-820E-02	210E+00
25	ROT	1107E+00	-1500E+00	-539E+00	ROT	-669E+00	-820E-02	210E+00
26	ROT	1127E+00	-1649E+00	-599E+00	ROT	-739E+00	-820E-02	210E+00
27	ROT	1147E+00	-1798E+00	-659E+00	ROT	-809E+00	-820E-02	210E+00
28	ROT	1167E+00	-1947E+00	-719E+00	ROT	-879E+00	-820E-02	210E+00
29	ROT	1187E+00	-2096E+00	-779E+00	ROT	-949E+00	-820E-02	210E+00
30	ROT	1207E+00	-2245E+00	-839E+00	ROT	-1019E+00	-820E-02	210E+00

FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS B AND 71

JPH
02/78
620-111-55

***** PRIMARY & SECONDARY STIFFNESSES *****

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	159208.2	146750.8	0.0	7292.7	101357.0	14378.3	10789.1	58667.4	-21.4
2	126831.0	20904.4	0.0	4105.4	101663.7	11904.5	160793.1	64725.6	-575.0
3	57644.0	12511.7	0.0	4030.6	02500.0	2094.5	102084.0	74110.2	-1076.0
4	27543.0	80021.3	0.0	3834.6	00110.5	4937.2	10020.4	126184.6	-1549.5
5	16714.0	84566.5	0.0	2803.2	85825.2	2776.4	14486.1	88908.4	-201.6
6	10114.0	78533.0	0.0	2034.8	85544.5	562.4	21810.4	04353.2	-2747.7
7	2240.8	63280.4	0.0	2001.0	77176.0	-1053.2	8627.4	06005.3	-2995.4
8	1609.5	49511.6	0.0	509.3	74114.5	-214.0	8071.4	01541.0	-3015.0
9	4004.3	46925.8	0.0	727.4	64776.1	-2751.7	2838.0	84002.7	-2818.0
10	4001.3	76376.1	0.0	5003.9	64205.7	-6400.4	36531.0	60685.3	-283.4
11	4701.3	15770.9	0.0	517.1	38908.7	-6854.7	37521.0	53660.0	-285.2
12	5712.3	15770.9	0.0	5495.1	31240.0	-6053.4	33700.2	44610.0	-2808.2
13	51063.0	7292.7	0.0	5292.7	12787.3	-5102.2	32260.4	33010.8	-2715.8
14	47996.5	7801.5	0.0	4855.1	8192.0	-4855.2	27691.8	22485.4	-2507.8
15	29785.5	7654.0	0.0	4855.1	0330.4	-4855.1	16581.0	126184.6	-2507.8
16	18046.4	4711.0	0.0	4611.8	0330.4	-187.0	10640.5	10640.5	-2132.2
17	10427.3	4711.0	0.0	4000.3	1000.9	-1267.0	4541.4	1613.5	-2022.0
18	3087.0	4528.7	0.0	7604.4	8522.5	-728.0	1424.0	3094.5	-1806.7
19	918.0	332.7	0.0	3849.6	7844.4	-356.3	11900.2	1222.0	-1806.7
20		-4504.4	0.0	3849.6	-4040.1	-330.8	4851.2	-3853.3	-1807.0

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

620-001-57
 08/78
 1/51

ITERATION 40 PAGE 14 DATE 08/06/78

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T4	SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T4
1	351	375	310	279	319	1	160	153	10	274	220
2	375	361	314	271	319	2	144	145	10	273	220
3	404	360	316	274	220	3	160	118	10	270	220
4	409	379	361	285	220	4	164	111	10	249	220
5	427	390	364	297	220	5	164	100	10	268	220
6	456	390	379	299	220	6	163	100	10	267	220
7	460	418	379	313	220	7	163	100	10	267	220
8	463	421	380	314	220	8	163	100	10	267	220
9	460	430	393	323	220	9	163	100	10	267	220
10	450	432	402	331	220	10	163	100	10	267	220
11	452	439	402	332	220	11	163	100	10	267	220
12	453	440	403	332	220	12	163	100	10	267	220
13	453	441	403	332	220	13	163	100	10	267	220
14	450	444	406	326	220	14	163	100	10	267	220

JJH
8/3
620-511-55
72

PEAK BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE FND CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	ROTATION (N)	RADIAL DEFL. (N)	ROTATION (N)	SUM
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	MOMENT (N)	RADIAL DEFL. (N)	MOMENT (N)
AXIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.

BOUNDARY DEFLECTIONS DUE TO THE FND CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (N)	ROTATION (N)	RADIAL DEFL. (N)	ROTATION (N)	SUM
AXIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL DEFL. (N)	0.	0.	0.	0.	0.	0.	0.	0.
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.

824
09/78
620-0011-55
93

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM Q1RAD
 (THIS MATRIX ONLY IS ON A PER NADIAN BASIS)

	M(0)	O(0)	MINI	O(M)
ROTATION(0)	.144174E-09	.14055E-08	.11845E-15	-.20302E-13
DEFLECTION(0)	.14055E-08	.24697E-07	.25054E-14	-.12857E-13
ROTATION(1)	.11845E-15	.24697E-07	.10600E-14	.14694E-13
DEFLECTION(1)	-.20302E-13	-.12857E-13	.14694E-14	.27594E-10

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

620-211-55
 08/78
 74

ITERATION 40 PAGE 17 DATE 08/06/78

SHUD COOLDOWN INC. SUPPORT SKIRT HEAD

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (-) ARE AS FOLLOWS
 TOP OF SEGMENT NO.1 ROTATION OF REMAINING SEGMENTS

RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL--- CLOCKWISE ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	PACIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	1108F.00	1003F.10	1095F.00	TOP	1156F.00	1242F.02	0.00
1	ROT	1519F.00	8407E.00	039F.00	ROT	1105E.00	1435E.02	1422F.00
1	ROT	8197E.00	5188F.00	075F.00	ROT	7275E.00	5602E.02	1902F.00
1	ROT	7107E.00	1446F.00	062E.00	ROT	7662E.00	7114E.02	265F.00
1	ROT	7107E.00	1446F.00	062E.00	ROT	7662E.00	7114E.02	265F.00
1	ROT	6166F.00	2781F.00	044F.00	ROT	5172E.00	8101E.02	2287E.00
1	ROT	5942E.00	2954F.00	027E.00	ROT	1840E.00	0120E.02	305E.00
1	ROT	5942E.00	2954F.00	027E.00	ROT	1840E.00	0120E.02	305E.00
1	ROT	4213E.00	1832E.00	040F.00	ROT	7522E.00	016E.02	104E.00
1	ROT	4213E.00	1832E.00	040F.00	ROT	7522E.00	016E.02	104E.00
1	ROT	1904F.00	461F.00	077F.00	ROT	206E.00	080F.02	190F.00
1	ROT	1111F.00	4708F.00	080F.00	ROT	2020F.00	802F.02	114F.00
1	ROT	1111F.00	4708F.00	080F.00	ROT	2020F.00	802F.02	114F.00
1	ROT	6603F.00	1673F.00	1092F.00	ROT	1528E.00	0230F.02	742F.00
1	ROT	6603F.00	1673F.00	1092F.00	ROT	1528E.00	0230F.02	742F.00
1	ROT	1204E.00	9160F.00	067E.00	ROT	411E.00	011E.02	010E.00
1	ROT	1204E.00	9160F.00	067E.00	ROT	411E.00	011E.02	010E.00
1	ROT	1100F.00	1007F.00	1076F.00	ROT	5421E.00	7541E.02	100F.00
1	ROT	1100F.00	1007F.00	1076F.00	ROT	5421E.00	7541E.02	100F.00
1	ROT	711E.00	4504F.00	1544F.00	ROT	9704F.00	6241E.02	48F.00
1	ROT	711E.00	4504F.00	1544F.00	ROT	9704F.00	6241E.02	48F.00
1	ROT	401F.00	1611F.00	010F.00	ROT	1651E.00	030E.02	461F.00
1	ROT	401F.00	1611F.00	010F.00	ROT	1651E.00	030E.02	461F.00
1	ROT	072E.00	115E.00	1650E.00	ROT	0447E.00	1212E.02	205E.00
1	ROT	072E.00	115E.00	1650E.00	ROT	0447E.00	1212E.02	205E.00
1	ROT	642E.00	2160F.00	1674E.00	ROT	540E.00	0470E.02	214F.00
1	ROT	642E.00	2160F.00	1674E.00	ROT	540E.00	0470E.02	214F.00
1	ROT	3195E.00	1510F.00	6274E.00	ROT	1921E.00	0377E.02	220F.00
1	ROT	3195E.00	1510F.00	6274E.00	ROT	1921E.00	0377E.02	220F.00
1	ROT	1664F.00	1510F.00	0.00	ROT	4120E.00	1094E.02	1004F.00

FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS - R AND Z

J-27
 08/78
 620-201-25

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MID-PLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	18096.6	66282.0	0	102877.2	7377.7	23277.6	31846.0	579.8	
2	42247.7	42247.7	0	100724.0	42247.7	13237.5	30180.5	42247.7	
3	09209.7	30446.6	0	91178.3	18066.4	13064.5	5500.7	5500.7	
4	75257.5	18740.0	0	84264.7	5426.7	100370.0	5995.7	5995.7	
5	40241.1	182266.5	0	84264.7	3719.8	46711.5	54751.2	54751.2	
6	22071.6	93679.6	0	80464.6	2201.0	26512.0	55306.7	682.8	
7	1414.0	48971.2	0	78376.7	1282.7	24205.2	52473.2	707.8	
8	4500.4	40618.8	0	71027.6	866.3	23305.2	48547.0	765.2	
9	23216.0	30910.4	0	65669.2	726.3	19208.1	43165.0	792.2	
10	26265.4	32959.4	0	60464.6	1440.5	16307.7	38553.7	2206.7	
11	31564.2	27683.7	0	45387.6	1664.1	10259.7	36691.9	2706.7	
12	3592.4	26483.7	0	37831.0	2251.8	7667.0	32743.8	2316.6	
13	29880.8	1927.1	0	26500.7	2665.6	5607.2	27743.8	2303.3	
14	3382.1	15166.7	0	15166.7	2505.6	4473.6	11026.2	2303.3	
15	1717.6	878.0	0	787.6	186.4	1273.6	0.6	0.6	
16	5082.0	1600.7	0	787.6	1236.1	875.7	0.6	0.6	
17	141.0	4677.0	0	10111.6	50.0	2078.4	2028.7	720.6	
18	1623.0	4677.0	0	839.1	839.1	2866.4	3157.7	508.0	
19	8028.0	4250.4	0	1370.0	1370.0	3265.7	3540.4	608.8	
20	8028.0	5012.6	0	1462.5	1462.5	3101.7	3084.8	653.7	
21	8028.0	5618.8	0	1750.7	1750.7	36185.0	36276.6	652.7	
22	10277.2	5618.8	0	1781.6	1781.6	20303.2	10310.6	651.6	

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

620-71-11
09/78
76

SMUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ITERATION AS PAGE 1 DATE 08/04/78

INPUT DATA DATE 08/04/78

TOTAL NO. OF SEGMENTS = 30

BOUNDARY CONDITIONS AT THE TOP (0) END

1. A RADIAL DEFLECTION OF .11848 INCHES FROM REF. 3
2. A ROTATION OF -.00124 RADIANS

BOUNDARY CONDITIONS AT THE BOTTOM (N) END

1. AN AXIAL FORCE OF 0.00000 POUNDS
2. A RADIAL DEFLECTION OF 0.00000 INCHES
3. A ROTATION OF 0.00000 RADIANS

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GROUP.
ALL LOADS ABOVE ARE ON A TOTAL LOAD BASIS.

JEN
08/25
620-0011-55
77

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ***** ITERATION 45 PAGE 2 DATE 08/04/78 *****

MID-SURFACE GEOMETRY
 AT TOP BOUNDARY, MEAN RADIUS = 63.2530 7 COORDINATE = 66.6000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	MEAN RADIUS	7	COORDINATE	IDENTIFIER
1.0	63.154	65.100	0.000	70.000
2.0	63.210	65.500	0.000	70.000
3.0	63.276	65.600	4.000	70.000
4.0	63.316	65.600	0.000	70.000
5.0	63.370	65.600	0.000	70.000
6.0	63.457	65.600	0.000	70.000
7.0	63.583	65.600	0.000	70.000
8.0	63.708	65.600	0.000	70.000
9.0	63.834	65.600	0.000	70.000
10.0	63.965	65.600	0.000	70.000
11.0	64.101	65.600	0.000	70.000
12.0	64.242	65.600	0.000	70.000
13.0	64.388	65.600	0.000	70.000
14.0	64.539	65.600	0.000	70.000
15.0	64.695	65.600	0.000	70.000
16.0	64.856	65.600	0.000	70.000
17.0	65.022	65.600	0.000	70.000
18.0	65.193	65.600	0.000	70.000
19.0	65.369	65.600	0.000	70.000
20.0	65.550	65.600	0.000	70.000
21.0	65.736	65.600	0.000	70.000
22.0	65.927	65.600	0.000	70.000
23.0	66.123	65.600	0.000	70.000
24.0	66.324	65.600	0.000	70.000
25.0	66.530	65.600	0.000	70.000
26.0	66.741	65.600	0.000	70.000
27.0	66.957	65.600	0.000	70.000
28.0	67.178	65.600	0.000	70.000
29.0	67.404	65.600	0.000	70.000
30.0	67.635	65.600	0.000	70.000

620-01150
 78

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ****

ITERATION AS PAGE 3 DATE 08/08/78

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD

NOTE- CURVATURE IDENTIFIER 0 = POSITIVE CURVATURE
0 = NO CURVATURE
-1 = NEGATIVE CURVATURE

12/1
08/79
620-0011-CC
79

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ***** ITERATION 45 PAGE 4 DATE 08/04/78

SEGMENTAL GEOMETRY BY SEGMENTS (K = SEGMENT NO.)

MEAN RADIUS		R(K-1)		R(K-2)		R(K-3)		R(K-4)		R(K-5)		R(K-6)		R(K-7)		R(K-8)	
K	1	62.14	62.78	62.78	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94	62.94
	2	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	3	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	4	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	5	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	6	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	7	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	8	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	9	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	10	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	11	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	12	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	13	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	14	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	15	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	16	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	17	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	18	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	19	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	20	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	21	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	22	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	23	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	24	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	25	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	26	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	27	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	28	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	29	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	30	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88
	31	58.26	58.58	58.58	58.79	58.79	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88	58.88

620-011-CC
 80

ITERATION 45 PAGE 5 DATE 08/04/78

SEGMENT THICKNESS DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TOP THICK- OF TOP SEG.	BOTTOM THICK- OF BOTTOM SEG.
1.00	3.00	8.00	8.00
4.00	5.00	8.00	8.00
5.00	6.00	8.00	8.00
6.00	7.00	8.00	8.00
7.00	8.00	8.00	8.00
8.00	9.00	8.00	8.00
9.00	10.00	8.00	8.00
10.00	11.00	8.00	8.00
11.00	12.00	8.00	8.00
12.00	13.00	8.00	8.00
13.00	14.00	8.00	8.00
14.00	15.00	8.00	8.00
15.00	16.00	8.00	8.00
16.00	17.00	8.00	8.00
17.00	18.00	8.00	8.00

SEGMENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (H8)		THICKNESS AT BOTTOM OF SEGMENT (H9)	
MARK-1	MARK-2	MARK-3	MARK-4
1	8.00	8.00	8.00
2	14.20	0.00	14.00
3	8.00	8.00	8.00
4	8.00	8.00	8.00
5	8.00	8.00	8.00
6	8.00	8.00	8.00
7	8.00	8.00	8.00
8	8.00	8.00	8.00
9	8.00	8.00	8.00
10	8.00	8.00	8.00
11	8.00	8.00	8.00
12	8.00	8.00	8.00
13	8.00	8.00	8.00
14	8.00	8.00	8.00
15	8.00	8.00	8.00
16	8.00	8.00	8.00
17	8.00	8.00	8.00
18	8.00	8.00	8.00

620-0011-05
 31

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD *****

ITERATION 45 PAGE 6 DATE 08/04/78

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO.	ALPHA	MODULUS OF FUNCTION	MODULUS OF SHEAR	POISSON'S RATIO
1	AA57E-05	2805F+00	11F+00	3000F+00
2	AA57E-05	2803F+00	11F+00	3000F+00
3	AA57E-05	2805F+00	11F+00	3000F+00
4	AA57E-05	2805F+00	11F+00	3000F+00
5	AA57E-05	2805F+00	11F+00	3000F+00
6	AA57E-05	2805F+00	11F+00	3000F+00
7	AA57E-05	2805F+00	11F+00	3000F+00
8	AA57E-05	2805F+00	11F+00	3000F+00
9	AA57E-05	2805F+00	11F+00	3000F+00
10	AA57E-05	2805F+00	11F+00	3000F+00
11	AA57E-05	2805F+00	11F+00	3000F+00
12	AA57E-05	2805F+00	11F+00	3000F+00
13	AA57E-05	2805F+00	11F+00	3000F+00
14	AA57E-05	2805F+00	11F+00	3000F+00
15	AA57E-05	2805F+00	11F+00	3000F+00
16	AA57E-05	2805F+00	11F+00	3000F+00
17	AA57E-05	2805F+00	11F+00	3000F+00
18	AA57E-05	2805F+00	11F+00	3000F+00
19	AA57E-05	2805F+00	11F+00	3000F+00
20	AA57E-05	2805F+00	11F+00	3000F+00
21	AA57E-05	2805F+00	11F+00	3000F+00
22	AA57E-05	2805F+00	11F+00	3000F+00
23	AA57E-05	2805F+00	11F+00	3000F+00
24	AA57E-05	2805F+00	11F+00	3000F+00
25	AA57E-05	2805F+00	11F+00	3000F+00
26	AA57E-05	2805F+00	11F+00	3000F+00
27	AA57E-05	2805F+00	11F+00	3000F+00
28	AA57E-05	2805F+00	11F+00	3000F+00
29	AA57E-05	2805F+00	11F+00	3000F+00
30	AA57E-05	2805F+00	11F+00	3000F+00
31	AA57E-05	2805F+00	11F+00	3000F+00
32	AA57E-05	2805F+00	11F+00	3000F+00
33	AA57E-05	2805F+00	11F+00	3000F+00
34	AA57E-05	2805F+00	11F+00	3000F+00
35	AA57E-05	2805F+00	11F+00	3000F+00
36	AA57E-05	2805F+00	11F+00	3000F+00
37	AA57E-05	2805F+00	11F+00	3000F+00
38	AA57E-05	2805F+00	11F+00	3000F+00
39	AA57E-05	2805F+00	11F+00	3000F+00
40	AA57E-05	2805F+00	11F+00	3000F+00
41	AA57E-05	2805F+00	11F+00	3000F+00
42	AA57E-05	2805F+00	11F+00	3000F+00
43	AA57E-05	2805F+00	11F+00	3000F+00
44	AA57E-05	2805F+00	11F+00	3000F+00
45	AA57E-05	2805F+00	11F+00	3000F+00
46	AA57E-05	2805F+00	11F+00	3000F+00
47	AA57E-05	2805F+00	11F+00	3000F+00
48	AA57E-05	2805F+00	11F+00	3000F+00
49	AA57E-05	2805F+00	11F+00	3000F+00
50	AA57E-05	2805F+00	11F+00	3000F+00
51	AA57E-05	2805F+00	11F+00	3000F+00
52	AA57E-05	2805F+00	11F+00	3000F+00
53	AA57E-05	2805F+00	11F+00	3000F+00
54	AA57E-05	2805F+00	11F+00	3000F+00
55	AA57E-05	2805F+00	11F+00	3000F+00
56	AA57E-05	2805F+00	11F+00	3000F+00
57	AA57E-05	2805F+00	11F+00	3000F+00
58	AA57E-05	2805F+00	11F+00	3000F+00
59	AA57E-05	2805F+00	11F+00	3000F+00
60	AA57E-05	2805F+00	11F+00	3000F+00
61	AA57E-05	2805F+00	11F+00	3000F+00
62	AA57E-05	2805F+00	11F+00	3000F+00
63	AA57E-05	2805F+00	11F+00	3000F+00
64	AA57E-05	2805F+00	11F+00	3000F+00
65	AA57E-05	2805F+00	11F+00	3000F+00
66	AA57E-05	2805F+00	11F+00	3000F+00
67	AA57E-05	2805F+00	11F+00	3000F+00
68	AA57E-05	2805F+00	11F+00	3000F+00
69	AA57E-05	2805F+00	11F+00	3000F+00
70	AA57E-05	2805F+00	11F+00	3000F+00
71	AA57E-05	2805F+00	11F+00	3000F+00
72	AA57E-05	2805F+00	11F+00	3000F+00
73	AA57E-05	2805F+00	11F+00	3000F+00
74	AA57E-05	2805F+00	11F+00	3000F+00
75	AA57E-05	2805F+00	11F+00	3000F+00
76	AA57E-05	2805F+00	11F+00	3000F+00
77	AA57E-05	2805F+00	11F+00	3000F+00
78	AA57E-05	2805F+00	11F+00	3000F+00
79	AA57E-05	2805F+00	11F+00	3000F+00
80	AA57E-05	2805F+00	11F+00	3000F+00
81	AA57E-05	2805F+00	11F+00	3000F+00
82	AA57E-05	2805F+00	11F+00	3000F+00
83	AA57E-05	2805F+00	11F+00	3000F+00
84	AA57E-05	2805F+00	11F+00	3000F+00
85	AA57E-05	2805F+00	11F+00	3000F+00
86	AA57E-05	2805F+00	11F+00	3000F+00
87	AA57E-05	2805F+00	11F+00	3000F+00
88	AA57E-05	2805F+00	11F+00	3000F+00
89	AA57E-05	2805F+00	11F+00	3000F+00
90	AA57E-05	2805F+00	11F+00	3000F+00
91	AA57E-05	2805F+00	11F+00	3000F+00
92	AA57E-05	2805F+00	11F+00	3000F+00
93	AA57E-05	2805F+00	11F+00	3000F+00
94	AA57E-05	2805F+00	11F+00	3000F+00
95	AA57E-05	2805F+00	11F+00	3000F+00
96	AA57E-05	2805F+00	11F+00	3000F+00
97	AA57E-05	2805F+00	11F+00	3000F+00
98	AA57E-05	2805F+00	11F+00	3000F+00
99	AA57E-05	2805F+00	11F+00	3000F+00
100	AA57E-05	2805F+00	11F+00	3000F+00

8071
 08/78
 620-0011-55
 82

ITERATION AS PAGE 7 DATE 08/04/78

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD *****

PRESSURE INPUT DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INTERNAL PRESSURE	EXTERNAL PRESSURE
1.0	3.0	2000.0	0.0
2.0	4.0	2000.0	0.0
3.0	5.0	2000.0	0.0
4.0	6.0	2000.0	0.0
5.0	7.0	2000.0	0.0
6.0	8.0	2000.0	0.0
7.0	9.0	2000.0	0.0
8.0	10.0	2000.0	0.0
9.0	11.0	2000.0	0.0
10.0	12.0	2000.0	0.0
11.0	13.0	2000.0	0.0
12.0	14.0	2000.0	0.0

MECHANICAL LOADING ON SEGMENTAL GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	3.0	0.0	0.0	0.0
2.0	4.0	0.0	0.0	0.0

0.000E+00 0.000E+00 0.000E+00
 0.000E+00 0.000E+00 0.000E+00

8/80
 08/78
 5-110-225
 88

ITERATION 45 PAGE 4 DATE 08/04/74

SMUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD
STRESS CONCENTRATION FACTORS BY GROUPS

TOP	POSITION	INSIDE	OUTSIDE
SEG. NO.	SEG. NO.	TENSION BENDING TENSION BENDING	
1	30	1.00	1.00

824
05/88
620-001-55
84

SHMD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ***** 01206 REV 1 5-8-75 08/04/78 09.50.39 PAGE 31
 ***** M11CC14

SHMD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ITERATION 45 PAGE 0 DATE 08/04/78

TEMPERATURES PER SEGMENT

 (M PRIMARY + SECONDARY ANALYSIS

SEGMENT	OUTSIDE	T2	T3	T4	INSIDE	SEGMENT	OUTSIDE	T2	T3	T4	INSIDE
1	262	262	262	262	262	17	278	278	278	278	278
2	275	275	275	275	275	18	278	278	278	278	278
3	285	285	285	285	285	19	241	241	241	241	241
4	293	293	293	293	293	20	249	249	249	249	249
5	302	302	302	302	302	21	254	254	254	254	254
6	307	307	307	307	307	22	254	254	254	254	254
7	321	321	321	321	321	23	253	253	253	253	253
8	324	324	324	324	324	24	253	253	253	253	253
9	332	332	332	332	332	25	252	252	252	252	252
10	336	336	336	336	336	26	252	252	252	252	252
11	341	341	341	341	341	27	252	252	252	252	252
12	343	343	343	343	343	28	252	252	252	252	252
13	343	343	343	343	343	29	252	252	252	252	252
14	343	343	343	343	343	30	252	252	252	252	252

7-1
 0.718
 670-0000
 85

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ITERATION 45 PAGE 18 DATE 08/04/78

PRIMARY + SECONDARY BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE FND CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	ROTATION (N)	RADIAL DEF. (N)	ROTATION (N)	SUM
AXIAL FORCE (N)	0.	0.	0.	0.	0.	0.	0.	0.	0.
RADIAL SHEAR (N)	.555E+09	.274E+07	.345E+05	0.	.482E+08	0.	0.	0.	.103E+09
MOMENT (N)	.451E+09	.290E+08	.250E+07	0.	.475E+08	0.	0.	0.	.176E+09
RADIAL SHEAR (N)	-.352E+06	-.291E+05	-.722E+04	0.	.471E+05	0.	0.	0.	-.340E+06
MOMENT (N)	.830E+05	.872E+04	.915E+03	0.	.545E+05	0.	0.	0.	.151E+06

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (INITIAL LOAD BASIS)

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	MOMENT (N)	RADIAL DEF. (N)	MOMENT (N)
AXIAL DEF. (N)	-.121E+00	-.117E-01	.250E-02	.141E-01	.211E-08	-.208E-09	.224E-06	-.522E-12
RADIAL DEF. (N)	-.152E+00	-.147E-01	.502E-02	.510E-01	.510E-09	-.219E-09	.190E-03	-.370E-13
ROTATION (N)	-.506E-01	-.473E-02	.104E-01	.210E-01	.210E-09	-.201E-09	.210E-04	-.44E-14
RADIAL DEF. (N)	-.100E+00	-.121E-01	.250E-02	.211E-01	.211E-09	-.208E-09	.210E-04	-.370E-13
ROTATION (N)	.272E-01	-.651E-01	-.682E-01	-.522E-12	.349E-15	.174E-16	.117E-13	.167E-12

BOUNDARY DEFLECTIONS DUE TO THE FND CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	ROTATION (N)	RADIAL DEF. (N)	ROTATION (N)	SUM
AXIAL DEF. (N)	.590E-01	-.552E-02	-.245E-02	0.	.103E-01	0.	0.	0.	.162E+00
RADIAL DEF. (N)	-.175E-14	-.102E-15	.207E-16	0.	.154E+00	0.	0.	0.	.154E+00
ROTATION (N)	-.650E-14	-.455E-19	.125E-17	0.	.140E-14	0.	0.	0.	-.125E-19
RADIAL DEF. (N)	-.630E-20	-.207E-21	.400E-21	0.	-.180E-20	0.	0.	0.	-.309E-20
ROTATION (N)	.150E-21	.661E-21	-.872E-21	0.	.180E-21	0.	0.	0.	.317E-21

82H
 05/78
 86

SHUD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ITERATION 45 DATE 08/04/78

FLEXIBILITY MATRIX OF ASSEMBLY 45 IN PROGRAM 91060
 (THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(0)	Q(0)	M(1)	Q(1)
ROTATION(0)	1.62827E-09	1.30604E-09	1.00418E-15	-2.52240E-13
DEFLECTION(0)	1.30604E-09	5.67761E-07	5.26051E-14	-1.25509E-11
ROTATION(1)	1.00418E-15	2.24831E-14	1.02113E-11	1.31654E-13
DEFLECTION(1)	-2.20224E-13	-1.25509E-11	1.31654E-13	2.73510E-10

NOTE - THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

8/11
 08/12
 620-0011-00
 87

PRIMARY + SECONDARY STRESSES

SEG. NO.	LONG	HOOP	OUTSIDE	RAD.	LONG	HOOP	MIDDLE	RAD.	LONG	HOOP	INSIDE	RAD.
1	17662.0	24780.9	13780.9	0.0	7195.4	9452.1	1323.6	0.0	176936.6	54776.7	-140.1	0.0
2	17328.5	24110.7	13210.7	0.0	4985.0	8215.1	7210.3	0.0	176915.7	-62651.4	-144.8	0.0
3	16449.6	22202.0	12102.0	0.0	1042.7	4625.4	6480.0	0.0	176913.2	-129007.4	-150.5	0.0
4	15552.0	20313.7	11013.7	0.0	2107.1	4020.8	1988.0	0.0	176879.8	-176879.8	-155.2	0.0
5	14640.0	18444.0	9944.0	0.0	3174.0	3288.8	412.5	0.0	176822.3	-208522.3	-160.0	0.0
6	13725.0	16575.0	8075.0	0.0	4240.0	2708.7	1010.5	0.0	176764.8	-240918.0	-164.8	0.0
7	12810.0	14706.0	6206.0	0.0	5306.0	2128.4	2233.1	0.0	176707.3	-273314.3	-169.3	0.0
8	11895.0	12837.0	4337.0	0.0	6372.0	1548.1	4355.7	0.0	176649.8	-305710.8	-173.8	0.0
9	10980.0	10968.0	2468.0	0.0	7438.0	967.8	4376.4	0.0	176592.3	-338107.3	-178.3	0.0
10	10065.0	9100.0	680.0	0.0	8504.0	387.5	4397.2	0.0	176534.8	-370504.8	-182.8	0.0
11	9150.0	7231.0	-1109.0	0.0	9570.0	-199.0	4418.0	0.0	176477.3	-402901.3	-187.3	0.0
12	8235.0	5362.0	-3240.0	0.0	10636.0	-608.5	4438.7	0.0	176419.8	-435298.8	-191.8	0.0
13	7320.0	3493.0	-5371.0	0.0	11702.0	-1218.0	4459.3	0.0	176362.3	-467695.3	-196.3	0.0
14	6405.0	1624.0	-7502.0	0.0	12768.0	-1827.5	4479.9	0.0	176304.8	-500092.8	-200.8	0.0
15	5490.0	-1245.0	-9633.0	0.0	13834.0	-2437.0	4499.5	0.0	176247.3	-532489.3	-205.3	0.0
16	4575.0	-3376.0	-11764.0	0.0	14900.0	-3046.5	4519.1	0.0	176189.8	-564886.8	-209.8	0.0
17	3660.0	-5507.0	-13895.0	0.0	15966.0	-3656.0	4538.7	0.0	176132.3	-597283.3	-214.3	0.0
18	2745.0	-7638.0	-16026.0	0.0	17032.0	-4265.5	4558.3	0.0	176074.8	-629680.8	-218.8	0.0
19	1830.0	-9769.0	-18157.0	0.0	18098.0	-4875.0	4577.9	0.0	176017.3	-662077.3	-223.3	0.0
20	915.0	-11900.0	-20288.0	0.0	19164.0	-5484.5	4597.5	0.0	175959.8	-694474.8	-227.8	0.0
21	0.0	-14031.0	-22419.0	0.0	20230.0	-6094.0	4617.1	0.0	175902.3	-726871.3	-232.3	0.0
22	0.0	-16162.0	-24550.0	0.0	21296.0	-6703.5	4636.7	0.0	175844.8	-759268.8	-236.8	0.0
23	0.0	-18293.0	-26681.0	0.0	22362.0	-7313.0	4656.3	0.0	175787.3	-791665.3	-241.3	0.0
24	0.0	-20424.0	-28812.0	0.0	23428.0	-7922.5	4675.9	0.0	175729.8	-824062.8	-245.8	0.0
25	0.0	-22555.0	-30943.0	0.0	24494.0	-8532.0	4695.5	0.0	175672.3	-856459.3	-250.3	0.0
26	0.0	-24686.0	-33074.0	0.0	25560.0	-9141.5	4715.1	0.0	175614.8	-888856.8	-254.8	0.0
27	0.0	-26817.0	-35205.0	0.0	26626.0	-9751.0	4734.7	0.0	175557.3	-921253.3	-259.3	0.0
28	0.0	-28948.0	-37336.0	0.0	27692.0	-10360.5	4754.3	0.0	175500.8	-953650.8	-263.8	0.0
29	0.0	-31079.0	-39467.0	0.0	28758.0	-10970.0	4773.9	0.0	175443.3	-986047.3	-268.3	0.0
30	0.0	-33210.0	-41598.0	0.0	29824.0	-11579.5	4793.5	0.0	175385.8	-1018444.8	-272.8	0.0

(LONGITUDINAL DIRECTION IS ALONG SHFL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHFL MIDSURFACE.)

1.27
 08/95
 620-0011-55
 59

SHLD COOLDOWN INCIDENT SUPPORT SKIRT HEAD ***** ITERATION 15 PAGE 14 DATE 08/04/78 *****

TEMPERATURES PER SEGMENT USED IN BEAN PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE	T2	T3	T4	INSIDE	T5	SEGMENT	OUTSIDE	T1	T2	T3	T4	INSIDE
1	288	279	266	245	224	224	14	327	304	280	252	228	228
2	308	297	277	248	224	224	17	308	293	278	250	228	228
3	317	299	289	251	225	225	18	295	285	274	245	228	228
4	342	313	295	248	225	225	20	284	278	268	245	228	228
5	354	325	306	245	225	225	21	282	276	267	241	228	228
6	370	339	310	249	225	225	22	274	269	257	241	228	228
7	390	364	327	249	225	225	23	275	264	256	240	228	228
8	403	381	337	279	225	225	24	274	267	255	240	228	228
9	417	395	340	279	225	225	25	273	264	255	240	228	228
10	427	408	343	284	225	225	26	273	266	255	240	228	228
11	431	408	345	284	225	225	27	273	266	255	240	228	228
12	433	405	354	291	225	225	28	273	266	255	240	228	228
13	435	413	360	298	225	225	29	273	266	255	240	228	228
14	450	413	367	297	225	225	30	273	266	255	240	228	228

2.27
 0.7/0
 620-001-55
 90

SHUD CROLDOWN INCIDENT SUPPORT SKIRT HEAD
 PEAK BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	ROTATION (N)	RADIAL DEF. (N)	ROTATION (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
5605E+08	2741E+07	3650E+04	1415E+01	5021E+04	6427E+07	0.	0.	1045E+08
5317E+00	2072E+04	2254E+07	2117E+04	2206E+00	8727E+07	0.	0.	1045E+08
3211E+04	2819E+05	7124E+04	2001E+09	4194E+04	4329E+05	0.	0.	3180E+06
7439E+05	8720E+04	0815E+07	2214E+04	5450E+05	2701E+04	0.	0.	1428E+06

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	ROTATION (N)	RADIAL DEF. (N)	ROTATION (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
117E+00	1179E+01	2507E+02	1415E+01	2117E+04	2007E+00	2714E+04	522E+02	0.
173E+00	2072E+04	2034E+02	2117E+04	4194E+04	2210E+00	1000E+04	1270E+04	0.
321E+02	2819E+05	1302E+02	2001E+09	2100E+03	2501E+00	210E+04	745E+04	0.
814E+05	8720E+04	4652E+02	2214E+04	1000E+03	3210E+00	4194E+04	745E+04	0.
210E+04	0815E+07	2402E+00	2214E+04	1070E+03	1765E+04	1174E+04	671E+02	0.

BOUNDARY DEFLECTIONS DUE TO THE FND CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (N)	ROTATION (N)	RADIAL DEF. (N)	ROTATION (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
5605E+08	5522E+02	2655E+07	0.	3011E+00	1855E+02	0.	0.	9915E+08
2414E+04	1020E+00	1207E+04	0.	1400E+00	2341E+02	0.	0.	1245E+08
707E+04	4559E+00	1207E+04	0.	1400E+00	1263E+02	0.	0.	1245E+08
411E+04	2074E+02	848E+03	0.	1400E+00	3070E+02	0.	0.	1245E+08
1420E+02	8617E+03	8772E+04	0.	1400E+00	0.	0.	0.	1858E+02

16
 272
 270

SHUD CROLDOWN INCIDENT SUPPORT SKIRT HEAD ***** ITERATION 45 PAGE 16 DATE 04/04/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
(TIME MATRIX ONLY IS ON A PER RENTAN BASIS)

	M(1)	O(1)	M(1)	O(1)
ROTATION(1)	.16282E-09	.13900E-08	.10014E-15	-.70226E-13
DEFLECTION(1)	.10610E-08	.24714E-07	.25804E-14	-.12550E-13
ROTATION(1)	.10610E-15	.27451E-14	.10501E-11	.73850E-13
DEFLECTION(1)	-.20226E-13	-.12550E-13	.14850E-11	.27351E-10

NOTE: THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 ROTION OF REMAINING SEGMENTS
 RADIAL----- TO THE LEFT
 ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- UPWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	PARTIAL MOTION	POTATION	AXIAL MOTION
1	TOP	1040F+00	905.3F+00	1905F+00	TOP	-1154F+00	-1742F-02	4.80AF-02
1	PO1	9554F+00	7512F+00	098F+00	PO1	-1040F+00	1500F-02	1041F-00
1	PO2	8431F+00	6040F+00	078F+00	PO2	-7504F-01	5471F-02	1745F-00
1	PO3	7684F+00	6434F+00	042F+00	PO3	-7700F-01	7735F-02	1475F-00
1	PO4	6941F+00	4644F+00	042F+00	PO4	-6214F-01	8131F-02	2700F-00
1	PO5	6841F+00	3700F+00	064F+00	PO5	-4134F-01	8131F-02	2700F-00
1	PO6	5084F+00	2700F+00	077F+00	PO6	-5554F-01	8131F-02	2700F-00
1	PO7	5084F+00	2831F+00	077F+00	PO7	-4704F-01	8131F-02	2700F-00
1	PO8	5084F+00	2831F+00	077F+00	PO8	-4704F-01	8131F-02	2700F-00
1	PO9	5084F+00	2831F+00	077F+00	PO9	-4704F-01	8131F-02	2700F-00
1	PO10	5084F+00	2831F+00	077F+00	PO10	-4704F-01	8131F-02	2700F-00
1	PO11	5084F+00	2831F+00	077F+00	PO11	-4704F-01	8131F-02	2700F-00
1	PO12	5084F+00	2831F+00	077F+00	PO12	-4704F-01	8131F-02	2700F-00
1	PO13	5084F+00	2831F+00	077F+00	PO13	-4704F-01	8131F-02	2700F-00
1	PO14	5084F+00	2831F+00	077F+00	PO14	-4704F-01	8131F-02	2700F-00
1	PO15	5084F+00	2831F+00	077F+00	PO15	-4704F-01	8131F-02	2700F-00
1	PO16	5084F+00	2831F+00	077F+00	PO16	-4704F-01	8131F-02	2700F-00
1	PO17	5084F+00	2831F+00	077F+00	PO17	-4704F-01	8131F-02	2700F-00
1	PO18	5084F+00	2831F+00	077F+00	PO18	-4704F-01	8131F-02	2700F-00
1	PO19	5084F+00	2831F+00	077F+00	PO19	-4704F-01	8131F-02	2700F-00
1	PO20	5084F+00	2831F+00	077F+00	PO20	-4704F-01	8131F-02	2700F-00
1	PO21	5084F+00	2831F+00	077F+00	PO21	-4704F-01	8131F-02	2700F-00
1	PO22	5084F+00	2831F+00	077F+00	PO22	-4704F-01	8131F-02	2700F-00
1	PO23	5084F+00	2831F+00	077F+00	PO23	-4704F-01	8131F-02	2700F-00
1	PO24	5084F+00	2831F+00	077F+00	PO24	-4704F-01	8131F-02	2700F-00
1	PO25	5084F+00	2831F+00	077F+00	PO25	-4704F-01	8131F-02	2700F-00
1	PO26	5084F+00	2831F+00	077F+00	PO26	-4704F-01	8131F-02	2700F-00
1	PO27	5084F+00	2831F+00	077F+00	PO27	-4704F-01	8131F-02	2700F-00
1	PO28	5084F+00	2831F+00	077F+00	PO28	-4704F-01	8131F-02	2700F-00
1	PO29	5084F+00	2831F+00	077F+00	PO29	-4704F-01	8131F-02	2700F-00
1	PO30	5084F+00	2831F+00	077F+00	PO30	-4704F-01	8131F-02	2700F-00

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS. 0 AND 7)

224
 05/75
 620-001-55
 93

SEG. NO. LONG HOOP R&D. LONG HOOP R&D. MIDPLANE HOOP R&D. LONG HOOP R&D. INSIDE HOOP R&D.

SEG. NO.	LONG	HOOP	R&D.	LONG	HOOP	R&D.	LONG	HOOP	R&D.	LONG	HOOP	R&D.
1	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
2	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
3	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
4	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
5	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
6	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
7	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
8	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
9	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
10	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
11	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
12	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
13	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
14	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
15	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
16	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
17	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
18	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
19	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
20	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
21	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
22	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
23	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
24	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
25	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
26	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
27	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
28	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
29	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1
30	13097.3	4670.4	0.0	4470.4	04016.5	15272.2	10782.8	40442.5	185.1	17026.7	47447.4	308.1

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

620-111-55
94

The motions at the interface of the support skirt and lower head were imposed on the support skirt stress model along with the interpolated temperature distribution and mechanical loads using the 91206 program.

The motions are the peak motions that were calculated previously by the 91206 program for the stress model of the lower head. The motions at the bottom of segment 15 of the lower head model are the boundary conditions for the upper (0) end of the support skirt stress model. The peak motions for iterations 40 and 45 are found on pages 75 and 93 respectively.

The 91206 program calculates primary plus secondary and peak stresses. The following pages contain the stress output for the iterations selected.

JLH
08/78
620-0011-55

SMUD COOLDOWN INC. SUPPORT SKIRT

ITERATION 10 PAGE 1 DATE 08/04/78

INPUT DATA DATE 08/04/78

TOTAL NO. OF SEGMENTS = 37

BOUNDARY CONDITIONS AT THE TOP (O) END

1. A RADIAL DEFLECTION OF -0.02879 INCHES
2. A ROTATION OF -0.00884 RADIAN

REF. PAGE 75

BOUNDARY CONDITIONS AT THE BOTTOM (IN) END

1. AN AXIAL FORCE OF -2800000.00000 POUNDS
2. A RADIAL DEFLECTION OF 0.00000 INCHES
3. A ROTATION OF 0.00000 RADIAN

FROM REF. 1, PAGE B-12-1

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.
ALL LOADS ABOVE ARE ON A TOTAL LOAD BASIS.

96
620-01145
36150
11/8

SHUD COOLDOWN INC. SUPPORT SKIRT

ITERATION 10. PAGE 2 DATE 08/04/78

MID-SURFACE GEOMETRY
 AT TOP BOUNDARY, MEAN RADIUS = 70.3200 Z COORDINATE = 94.4000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEGMENT NO.	MEAN RADIUS	Z COORD.	CURVATURE	IDENTIFIER
1	70.270	93.860	0.000	0.0
2	70.270	93.860	0.000	0.0
3	68.700	94.260	0.000	0.0
4	68.700	94.260	0.000	0.0
5	68.700	94.260	0.000	0.0
6	68.700	94.260	0.000	0.0
7	68.700	94.260	0.000	0.0
8	68.700	94.260	0.000	0.0
9	68.700	94.260	0.000	0.0
10	68.700	94.260	0.000	0.0
11	68.700	94.260	0.000	0.0
12	68.700	94.260	0.000	0.0
13	68.700	94.260	0.000	0.0
14	68.700	94.260	0.000	0.0
15	68.700	94.260	0.000	0.0
16	68.700	94.260	0.000	0.0
17	68.700	94.260	0.000	0.0
18	68.700	94.260	0.000	0.0
19	68.700	94.260	0.000	0.0
20	68.700	94.260	0.000	0.0
21	68.700	94.260	0.000	0.0
22	68.700	94.260	0.000	0.0
23	68.700	94.260	0.000	0.0
24	68.700	94.260	0.000	0.0
25	68.700	94.260	0.000	0.0
26	68.700	94.260	0.000	0.0
27	68.700	94.260	0.000	0.0
28	68.700	94.260	0.000	0.0
29	68.700	94.260	0.000	0.0
30	68.700	94.260	0.000	0.0
31	68.700	94.260	0.000	0.0
32	68.700	94.260	0.000	0.0
33	68.700	94.260	0.000	0.0
34	68.700	94.260	0.000	0.0
35	68.700	94.260	0.000	0.0
36	68.700	94.260	0.000	0.0
37	68.700	94.260	0.000	0.0
38	68.700	94.260	0.000	0.0
39	68.700	94.260	0.000	0.0
40	68.700	94.260	0.000	0.0
41	68.700	94.260	0.000	0.0
42	68.700	94.260	0.000	0.0
43	68.700	94.260	0.000	0.0
44	68.700	94.260	0.000	0.0
45	68.700	94.260	0.000	0.0
46	68.700	94.260	0.000	0.0
47	68.700	94.260	0.000	0.0
48	68.700	94.260	0.000	0.0
49	68.700	94.260	0.000	0.0
50	68.700	94.260	0.000	0.0
51	68.700	94.260	0.000	0.0
52	68.700	94.260	0.000	0.0
53	68.700	94.260	0.000	0.0
54	68.700	94.260	0.000	0.0
55	68.700	94.260	0.000	0.0
56	68.700	94.260	0.000	0.0
57	68.700	94.260	0.000	0.0
58	68.700	94.260	0.000	0.0
59	68.700	94.260	0.000	0.0
60	68.700	94.260	0.000	0.0
61	68.700	94.260	0.000	0.0
62	68.700	94.260	0.000	0.0
63	68.700	94.260	0.000	0.0
64	68.700	94.260	0.000	0.0
65	68.700	94.260	0.000	0.0
66	68.700	94.260	0.000	0.0
67	68.700	94.260	0.000	0.0
68	68.700	94.260	0.000	0.0
69	68.700	94.260	0.000	0.0
70	68.700	94.260	0.000	0.0
71	68.700	94.260	0.000	0.0
72	68.700	94.260	0.000	0.0
73	68.700	94.260	0.000	0.0
74	68.700	94.260	0.000	0.0
75	68.700	94.260	0.000	0.0
76	68.700	94.260	0.000	0.0
77	68.700	94.260	0.000	0.0
78	68.700	94.260	0.000	0.0
79	68.700	94.260	0.000	0.0
80	68.700	94.260	0.000	0.0
81	68.700	94.260	0.000	0.0
82	68.700	94.260	0.000	0.0
83	68.700	94.260	0.000	0.0
84	68.700	94.260	0.000	0.0
85	68.700	94.260	0.000	0.0
86	68.700	94.260	0.000	0.0
87	68.700	94.260	0.000	0.0
88	68.700	94.260	0.000	0.0
89	68.700	94.260	0.000	0.0
90	68.700	94.260	0.000	0.0
91	68.700	94.260	0.000	0.0
92	68.700	94.260	0.000	0.0
93	68.700	94.260	0.000	0.0
94	68.700	94.260	0.000	0.0
95	68.700	94.260	0.000	0.0
96	68.700	94.260	0.000	0.0
97	68.700	94.260	0.000	0.0
98	68.700	94.260	0.000	0.0
99	68.700	94.260	0.000	0.0
100	68.700	94.260	0.000	0.0

NOTE - CURVATURE IDENTIFIER
 0 = POSITIVE CURVATURE
 -1 = NO CURVATURE
 -2 = NEGATIVE CURVATURE

8211
 08/78
 620-0011-55
 97

ITERATION 40. PAGE 3 DATE 08/04/78

SHUD COOLDOWN INC. SUPPORT SKIRT

SHUD COOLDOWN INC. SUPPORT SKIRT

SEGMENTAL GEOMETRY BY SEGMENTS (K= SEGMENT NO.)

MEAN RADIUS		R(K-1)		R(K-2)		R(K-3)		R(K-4)		R(K-5)		R(K-6)		R(K-7)		R(K-8)	
K	1	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22	70.22
1	1	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26
Z	COORDINATE	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1	81.1
K	1	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48	92.48
1	1	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00	81.00
3	3	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00

20K
04/78
60-011-55

SEGMENT THICKNESS DATA BY GROUPS

TOP BOTTOM TOP THICK. BOTTOM THICK.
 SEG. NO. SEG. NO. OF TOP SEG. OF BOTTOM SEG.
 15.00 17.00 1.50 1.50

SEGMENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (HAK)
 HAK(1) HAK(2) HAK(3) HAK(4) HAK(5) HAK(6) HAK(7) HAK(8) HAK(9)
 1 2.00 2.00 2.00 2.00 2.00 2.00 2.00 2.00
 3 1.50 1.50 1.50 1.50 1.50 1.50 1.50 1.50

THICKNESS AT BOTTOM OF SEGMENT (HBI)

HBI(1) HBI(2) HBI(3) HBI(4) HBI(5) HBI(6) HBI(7) HBI(8) HBI(9)
 1 2.00 2.00 2.00 2.00 2.00 2.00 2.00 2.00
 3 1.50 1.50 1.50 1.50 1.50 1.50 1.50 1.50

620-0711-029
 08/84
 99

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO#	ALPHA	MODULUS OF TENSION	MODULUS OF SHEAR	POISSON'S RATIO
1	0.000000	2.702E+08	0.000000	0.000000
2	0.000000	2.702E+08	0.000000	0.000000
3	0.000000	2.702E+08	0.000000	0.000000
4	0.000000	2.702E+08	0.000000	0.000000
5	0.000000	2.702E+08	0.000000	0.000000
6	0.000000	2.702E+08	0.000000	0.000000
7	0.000000	2.702E+08	0.000000	0.000000
8	0.000000	2.702E+08	0.000000	0.000000
9	0.000000	2.702E+08	0.000000	0.000000
10	0.000000	2.702E+08	0.000000	0.000000
11	0.000000	2.702E+08	0.000000	0.000000
12	0.000000	2.702E+08	0.000000	0.000000
13	0.000000	2.702E+08	0.000000	0.000000
14	0.000000	2.702E+08	0.000000	0.000000
15	0.000000	2.702E+08	0.000000	0.000000
16	0.000000	2.702E+08	0.000000	0.000000
17	0.000000	2.702E+08	0.000000	0.000000
18	0.000000	2.702E+08	0.000000	0.000000
19	0.000000	2.702E+08	0.000000	0.000000
20	0.000000	2.702E+08	0.000000	0.000000
21	0.000000	2.702E+08	0.000000	0.000000
22	0.000000	2.702E+08	0.000000	0.000000
23	0.000000	2.702E+08	0.000000	0.000000
24	0.000000	2.702E+08	0.000000	0.000000
25	0.000000	2.702E+08	0.000000	0.000000
26	0.000000	2.702E+08	0.000000	0.000000
27	0.000000	2.702E+08	0.000000	0.000000
28	0.000000	2.702E+08	0.000000	0.000000
29	0.000000	2.702E+08	0.000000	0.000000
30	0.000000	2.702E+08	0.000000	0.000000
31	0.000000	2.702E+08	0.000000	0.000000
32	0.000000	2.702E+08	0.000000	0.000000
33	0.000000	2.702E+08	0.000000	0.000000
34	0.000000	2.702E+08	0.000000	0.000000
35	0.000000	2.702E+08	0.000000	0.000000
36	0.000000	2.702E+08	0.000000	0.000000
37	0.000000	2.702E+08	0.000000	0.000000
38	0.000000	2.702E+08	0.000000	0.000000
39	0.000000	2.702E+08	0.000000	0.000000
40	0.000000	2.702E+08	0.000000	0.000000
41	0.000000	2.702E+08	0.000000	0.000000
42	0.000000	2.702E+08	0.000000	0.000000
43	0.000000	2.702E+08	0.000000	0.000000
44	0.000000	2.702E+08	0.000000	0.000000
45	0.000000	2.702E+08	0.000000	0.000000
46	0.000000	2.702E+08	0.000000	0.000000
47	0.000000	2.702E+08	0.000000	0.000000
48	0.000000	2.702E+08	0.000000	0.000000
49	0.000000	2.702E+08	0.000000	0.000000
50	0.000000	2.702E+08	0.000000	0.000000

SH
00/00
620-0011-00
100

SHUD COOLDOWN INC. SUPPORT SKIRT

PRESSURE INPUT DATA BY GROUPS

TOP. NO.	SPG. NO.	INTERNAL PRESSURE
1.0	37.0	0.0

MECHANICAL LOADS ON SEGMENTAL GROUPS

TOP. NO.	BOTTOM. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	37.0	0.	0.	0.

STRESS CONCENTRATION FACTORS BY GROUPS

TOP. NO.	BOTTOM. NO.	INSIDE		OUTSIDE	
		TENSION	REINFORCING TENSION	TENSION	BENDING
1	37	1.00	1.72	1.20	0.07
2	37	1.00	1.58	1.13	0.07
3	37	1.00	1.44	1.06	0.07
4	37	1.00	1.00	1.00	0.07
5	37	1.00	1.00	1.00	0.07

FROM REF. 1, SECTION B-13

ITERATION NO. PAGE 8 DATE 08/04/78

PRIMARY SECONDARY BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (IN)	ROTATION (D)	RADIAL DEFL. (IN)	ROTATION (D)	SUM
AXIAL FORCE (N)	0.	0.	0.	-2509E-07	0.	0.	0.	0.	-2509E-07
RADIAL SHEAR (N)	0.	0.	0.	-2714E-06	0.	0.	0.	0.	-2714E-06
MOMENT (N)	0.	0.	0.	0.	0.	0.	0.	0.	0.

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (N)	MOMENT (N)	RADIAL SHEAR (N)	MOMENT (N)
AXIAL DEFL. (N)	0.919E-01	0.	0.	5189E-08	0.	0.	0.	0.
RADIAL DEFL. (N)	-2314E-08	0.	0.	3802E-08	0.	0.	0.	0.
ROTATION (N)	-2844E-08	0.	0.	-411E-09	0.	0.	0.	0.
RADIAL DEFL. (N)	-2844E-08	0.	0.	-160E-08	0.	0.	0.	0.
ROTATION (N)	-2804E-08	0.	0.	555E-11	0.	0.	0.	0.

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (IN)	ROTATION (D)	RADIAL DEFL. (IN)	ROTATION (D)	SUM
AXIAL DEFL. (N)	0.919E-01	0.	0.	5189E-08	0.	0.	0.	0.	0.919E-01
RADIAL DEFL. (N)	-2314E-08	0.	0.	3802E-08	0.	0.	0.	0.	-2314E-08
ROTATION (N)	-2844E-08	0.	0.	-411E-09	0.	0.	0.	0.	-2844E-08
RADIAL DEFL. (N)	-2844E-08	0.	0.	-160E-08	0.	0.	0.	0.	-2844E-08
ROTATION (N)	-2804E-08	0.	0.	555E-11	0.	0.	0.	0.	-2804E-08

320-100-055
928
104

SMUD COOLDOWN INC. SUPPORT SKIRT ***** ITERATION 40. PAGE 9 DATE 08/04/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
(THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(0)	Q(0)	M(1)	Q(1)
ROTATION(0)	.18559E-09	.118170E-07	.57802E-13	.110020E-11
DEFLECTION(0)	.18174E-09	.12141E-09	.61500E-13	.42700E-11
ROTATION(1)	.51802E-11	.81444E-12	.15895E-07	.49214E-07
DEFLECTION(1)	.119020E-11	.814566E-11	.492164E-07	.39015E-06

NOTE- THE .1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

620-811-55
104

SHVD CROLDOWN INC. SUPPORT SKIRT ***** ITERATION 40 ***** PAGE 10 ***** DATE 08/04/78 *****

PRIMARY SECONDARY FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 ROTION OF REMAINING SEGMENTS
 RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL--- CLOCKWISE ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	157.00	4684.00	2000.00	TOP	2870.00	0.00	704.00
1	R01	0.00	0.00	0.00	R01	0.00	0.00	0.00
1	R02	0.00	0.00	0.00	R02	0.00	0.00	0.00
1	R03	0.00	0.00	0.00	R03	0.00	0.00	0.00
1	R04	0.00	0.00	0.00	R04	0.00	0.00	0.00
1	R05	0.00	0.00	0.00	R05	0.00	0.00	0.00
1	R06	0.00	0.00	0.00	R06	0.00	0.00	0.00
1	R07	0.00	0.00	0.00	R07	0.00	0.00	0.00
1	R08	0.00	0.00	0.00	R08	0.00	0.00	0.00
1	R09	0.00	0.00	0.00	R09	0.00	0.00	0.00
1	R10	0.00	0.00	0.00	R10	0.00	0.00	0.00
1	R11	0.00	0.00	0.00	R11	0.00	0.00	0.00
1	R12	0.00	0.00	0.00	R12	0.00	0.00	0.00
1	R13	0.00	0.00	0.00	R13	0.00	0.00	0.00
1	R14	0.00	0.00	0.00	R14	0.00	0.00	0.00
1	R15	0.00	0.00	0.00	R15	0.00	0.00	0.00
1	R16	0.00	0.00	0.00	R16	0.00	0.00	0.00
1	R17	0.00	0.00	0.00	R17	0.00	0.00	0.00
1	R18	0.00	0.00	0.00	R18	0.00	0.00	0.00
1	R19	0.00	0.00	0.00	R19	0.00	0.00	0.00
1	R20	0.00	0.00	0.00	R20	0.00	0.00	0.00
1	R21	0.00	0.00	0.00	R21	0.00	0.00	0.00
1	R22	0.00	0.00	0.00	R22	0.00	0.00	0.00
1	R23	0.00	0.00	0.00	R23	0.00	0.00	0.00
1	R24	0.00	0.00	0.00	R24	0.00	0.00	0.00
1	R25	0.00	0.00	0.00	R25	0.00	0.00	0.00
1	R26	0.00	0.00	0.00	R26	0.00	0.00	0.00
1	R27	0.00	0.00	0.00	R27	0.00	0.00	0.00
1	R28	0.00	0.00	0.00	R28	0.00	0.00	0.00
1	R29	0.00	0.00	0.00	R29	0.00	0.00	0.00
1	R30	0.00	0.00	0.00	R30	0.00	0.00	0.00
1	R31	0.00	0.00	0.00	R31	0.00	0.00	0.00
1	R32	0.00	0.00	0.00	R32	0.00	0.00	0.00
1	R33	0.00	0.00	0.00	R33	0.00	0.00	0.00
1	R34	0.00	0.00	0.00	R34	0.00	0.00	0.00
1	R35	0.00	0.00	0.00	R35	0.00	0.00	0.00
1	R36	0.00	0.00	0.00	R36	0.00	0.00	0.00
1	R37	0.00	0.00	0.00	R37	0.00	0.00	0.00
1	R38	0.00	0.00	0.00	R38	0.00	0.00	0.00
1	R39	0.00	0.00	0.00	R39	0.00	0.00	0.00
1	R40	0.00	0.00	0.00	R40	0.00	0.00	0.00
1	R41	0.00	0.00	0.00	R41	0.00	0.00	0.00
1	R42	0.00	0.00	0.00	R42	0.00	0.00	0.00
1	R43	0.00	0.00	0.00	R43	0.00	0.00	0.00
1	R44	0.00	0.00	0.00	R44	0.00	0.00	0.00
1	R45	0.00	0.00	0.00	R45	0.00	0.00	0.00
1	R46	0.00	0.00	0.00	R46	0.00	0.00	0.00
1	R47	0.00	0.00	0.00	R47	0.00	0.00	0.00
1	R48	0.00	0.00	0.00	R48	0.00	0.00	0.00
1	R49	0.00	0.00	0.00	R49	0.00	0.00	0.00
1	R50	0.00	0.00	0.00	R50	0.00	0.00	0.00

620-110-020
 55-110-55
 105

ITERATION	40.	PAGE 11	DATE 08/04/78
32	ROT: 000E+06	2194E+01	01E+00
33	ROT: 442E+06	250E+01	01E+00
34	ROT: 526E+06	200E+01	01E+00
35	ROT: 572E+06	200E+01	01E+00
36	ROT: 950E+06	222E+01	01E+00
37	ROT: 3730E+07	222E+01	01E+00

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

1/4
25/2
320-011-55

STATION 40.

PRIMARY + SECONDARY STRESSES

S/G. NO.	OUTSIDE		MIDPLANE		INSIDE	
	LONG	HOOP	LONG	HOOP	LONG	HOOP
1	10000	10000	10000	10000	10000	10000
2	10000	10000	10000	10000	10000	10000
3	10000	10000	10000	10000	10000	10000
4	10000	10000	10000	10000	10000	10000
5	10000	10000	10000	10000	10000	10000
6	10000	10000	10000	10000	10000	10000
7	10000	10000	10000	10000	10000	10000
8	10000	10000	10000	10000	10000	10000
9	10000	10000	10000	10000	10000	10000
10	10000	10000	10000	10000	10000	10000
11	10000	10000	10000	10000	10000	10000
12	10000	10000	10000	10000	10000	10000
13	10000	10000	10000	10000	10000	10000
14	10000	10000	10000	10000	10000	10000
15	10000	10000	10000	10000	10000	10000
16	10000	10000	10000	10000	10000	10000
17	10000	10000	10000	10000	10000	10000
18	10000	10000	10000	10000	10000	10000
19	10000	10000	10000	10000	10000	10000
20	10000	10000	10000	10000	10000	10000
21	10000	10000	10000	10000	10000	10000
22	10000	10000	10000	10000	10000	10000
23	10000	10000	10000	10000	10000	10000
24	10000	10000	10000	10000	10000	10000
25	10000	10000	10000	10000	10000	10000
26	10000	10000	10000	10000	10000	10000
27	10000	10000	10000	10000	10000	10000
28	10000	10000	10000	10000	10000	10000
29	10000	10000	10000	10000	10000	10000
30	10000	10000	10000	10000	10000	10000
31	10000	10000	10000	10000	10000	10000
32	10000	10000	10000	10000	10000	10000
33	10000	10000	10000	10000	10000	10000
34	10000	10000	10000	10000	10000	10000
35	10000	10000	10000	10000	10000	10000
36	10000	10000	10000	10000	10000	10000
37	10000	10000	10000	10000	10000	10000
38	10000	10000	10000	10000	10000	10000
39	10000	10000	10000	10000	10000	10000
40	10000	10000	10000	10000	10000	10000

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

100-001-105

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T5	SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T5
1	452	448	444	440	445	1	452	448	444	440	445
2	448	444	440	436	441	2	448	444	440	436	441
3	444	440	436	432	437	3	444	440	436	432	437
4	440	436	432	428	433	4	440	436	432	428	433
5	436	432	428	424	429	5	436	432	428	424	429
6	432	428	424	420	425	6	432	428	424	420	425
7	428	424	420	416	421	7	428	424	420	416	421
8	424	420	416	412	417	8	424	420	416	412	417
9	420	416	412	408	413	9	420	416	412	408	413
10	416	412	408	404	409	10	416	412	408	404	409
11	412	408	404	400	405	11	412	408	404	400	405
12	408	404	400	396	401	12	408	404	400	396	401
13	404	400	396	392	397	13	404	400	396	392	397
14	400	396	392	388	393	14	400	396	392	388	393
15	396	392	388	384	389	15	396	392	388	384	389

114
05/78
620-0011-55
108

SMUD CROLDOWN INC. SUPPORT SKIRT ITERATION 40. PAGE 14 DATE 08/04/78

PEAK BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (O)	ROTATION (O)	RADIAL DEFL. (N)	ROTATION (N)	SUM
0.	0.	0.	-200E+07	0.	0.	0.	0.	-200E+07
.252E+08	0.	0.	370E+06	-370E+07	0.	0.	0.	370E+06
1.38E+08	0.	0.	1.60E+07	-1.60E+08	0.	0.	0.	1.60E+07
-1.51E+06	0.	0.	1.80E+05	-1.72E+02	0.	0.	0.	1.80E+05
-3.66E+07	0.	0.	2714E+06	-2704E+03	-1192E+03	0.	0.	2714E+06

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)
0.	0.	0.	538E+08	2402E+08	-471E+09	105E+08	555E+11
-2.77E+08	0.	0.	340E+08	1057E+07	1.07E+09	1.97E+08	9.20E+08
2.80E+01	0.	0.	-471E+09	1.68E+08	1.11E+10	1.97E+08	7.91E+08
-2.60E+03	0.	0.	-555E+11	-941E+13	620E+14	783E+08	200E+08

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (O)	ROTATION (O)	RADIAL DEFL. (N)	ROTATION (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
1.13E+08	0.	0.	-905E+07	-305E+07	715E+03	0.	0.	-905E+07
1.30E+08	0.	0.	-896E+07	-370E+07	2.67E+03	0.	0.	-896E+07
1.34E+08	0.	0.	693E+07	-6.12E-04	-1.60E+03	0.	0.	693E+07
5.55E+16	0.	0.	1041E+16	-5082E+20	-1.35E+19	0.	0.	1041E+16

620-111.05
109

SHUD CBOLDOWN INC. SUPPORT SKIRT ITERATION 49. PAGE 15 DATE 08/04/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
(THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(0)	Q(0)	M(1)	Q(1)
ROTATION(0)	.195593E-09	.119179E-07	.578875E-12	.119820E-11
OFFLECTION(0)	.16170E-07	.12749E-06	.618884E-12	.615888E-11
ROTATION(1)	.578875E-12	.119179E-07	.12749E-06	.492144E-07
OFFLECTION(1)	.119020E-11	.618884E-12	.492144E-07	.390335E-06

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

824
08/78
820-0011-55

SHUD COOLDOWN INC. SUPPORT SKIRT

SHUD COOLDOWN INC. SUPPORT SKIRT

ITERATION 46.

PAGE 14 DATE 08/04/78

PEAK FORCES AND MOMENTS

POSITIVE DIRECTIONS (-) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
ROTATIONAL--- COUNTERCLOCKWISE ROTATIONAL--- COUNTERCLOCKWISE
AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
TOP	TOP	15498	4742E	2000E	TOP	2879E	8870E	2234E
RO1	RO1	15498	4742E	2000E	RO1	2879E	8870E	2234E
RO2	RO2	15498	4742E	2000E	RO2	2879E	8870E	2234E
RO3	RO3	15498	4742E	2000E	RO3	2879E	8870E	2234E
RO4	RO4	15498	4742E	2000E	RO4	2879E	8870E	2234E
RO5	RO5	15498	4742E	2000E	RO5	2879E	8870E	2234E
RO6	RO6	15498	4742E	2000E	RO6	2879E	8870E	2234E
RO7	RO7	15498	4742E	2000E	RO7	2879E	8870E	2234E
RO8	RO8	15498	4742E	2000E	RO8	2879E	8870E	2234E
RO9	RO9	15498	4742E	2000E	RO9	2879E	8870E	2234E
RO10	RO10	15498	4742E	2000E	RO10	2879E	8870E	2234E
RO11	RO11	15498	4742E	2000E	RO11	2879E	8870E	2234E
RO12	RO12	15498	4742E	2000E	RO12	2879E	8870E	2234E
RO13	RO13	15498	4742E	2000E	RO13	2879E	8870E	2234E
RO14	RO14	15498	4742E	2000E	RO14	2879E	8870E	2234E
RO15	RO15	15498	4742E	2000E	RO15	2879E	8870E	2234E
RO16	RO16	15498	4742E	2000E	RO16	2879E	8870E	2234E
RO17	RO17	15498	4742E	2000E	RO17	2879E	8870E	2234E
RO18	RO18	15498	4742E	2000E	RO18	2879E	8870E	2234E
RO19	RO19	15498	4742E	2000E	RO19	2879E	8870E	2234E
RO20	RO20	15498	4742E	2000E	RO20	2879E	8870E	2234E
RO21	RO21	15498	4742E	2000E	RO21	2879E	8870E	2234E
RO22	RO22	15498	4742E	2000E	RO22	2879E	8870E	2234E
RO23	RO23	15498	4742E	2000E	RO23	2879E	8870E	2234E
RO24	RO24	15498	4742E	2000E	RO24	2879E	8870E	2234E
RO25	RO25	15498	4742E	2000E	RO25	2879E	8870E	2234E
RO26	RO26	15498	4742E	2000E	RO26	2879E	8870E	2234E
RO27	RO27	15498	4742E	2000E	RO27	2879E	8870E	2234E
RO28	RO28	15498	4742E	2000E	RO28	2879E	8870E	2234E
RO29	RO29	15498	4742E	2000E	RO29	2879E	8870E	2234E
RO30	RO30	15498	4742E	2000E	RO30	2879E	8870E	2234E
RO31	RO31	15498	4742E	2000E	RO31	2879E	8870E	2234E
RO32	RO32	15498	4742E	2000E	RO32	2879E	8870E	2234E
RO33	RO33	15498	4742E	2000E	RO33	2879E	8870E	2234E
RO34	RO34	15498	4742E	2000E	RO34	2879E	8870E	2234E
RO35	RO35	15498	4742E	2000E	RO35	2879E	8870E	2234E
RO36	RO36	15498	4742E	2000E	RO36	2879E	8870E	2234E
RO37	RO37	15498	4742E	2000E	RO37	2879E	8870E	2234E
RO38	RO38	15498	4742E	2000E	RO38	2879E	8870E	2234E
RO39	RO39	15498	4742E	2000E	RO39	2879E	8870E	2234E
RO40	RO40	15498	4742E	2000E	RO40	2879E	8870E	2234E
RO41	RO41	15498	4742E	2000E	RO41	2879E	8870E	2234E
RO42	RO42	15498	4742E	2000E	RO42	2879E	8870E	2234E
RO43	RO43	15498	4742E	2000E	RO43	2879E	8870E	2234E
RO44	RO44	15498	4742E	2000E	RO44	2879E	8870E	2234E
RO45	RO45	15498	4742E	2000E	RO45	2879E	8870E	2234E
RO46	RO46	15498	4742E	2000E	RO46	2879E	8870E	2234E
RO47	RO47	15498	4742E	2000E	RO47	2879E	8870E	2234E
RO48	RO48	15498	4742E	2000E	RO48	2879E	8870E	2234E
RO49	RO49	15498	4742E	2000E	RO49	2879E	8870E	2234E
RO50	RO50	15498	4742E	2000E	RO50	2879E	8870E	2234E
RO51	RO51	15498	4742E	2000E	RO51	2879E	8870E	2234E
RO52	RO52	15498	4742E	2000E	RO52	2879E	8870E	2234E
RO53	RO53	15498	4742E	2000E	RO53	2879E	8870E	2234E
RO54	RO54	15498	4742E	2000E	RO54	2879E	8870E	2234E
RO55	RO55	15498	4742E	2000E	RO55	2879E	8870E	2234E
RO56	RO56	15498	4742E	2000E	RO56	2879E	8870E	2234E
RO57	RO57	15498	4742E	2000E	RO57	2879E	8870E	2234E
RO58	RO58	15498	4742E	2000E	RO58	2879E	8870E	2234E
RO59	RO59	15498	4742E	2000E	RO59	2879E	8870E	2234E
RO60	RO60	15498	4742E	2000E	RO60	2879E	8870E	2234E
RO61	RO61	15498	4742E	2000E	RO61	2879E	8870E	2234E
RO62	RO62	15498	4742E	2000E	RO62	2879E	8870E	2234E
RO63	RO63	15498	4742E	2000E	RO63	2879E	8870E	2234E
RO64	RO64	15498	4742E	2000E	RO64	2879E	8870E	2234E
RO65	RO65	15498	4742E	2000E	RO65	2879E	8870E	2234E
RO66	RO66	15498	4742E	2000E	RO66	2879E	8870E	2234E
RO67	RO67	15498	4742E	2000E	RO67	2879E	8870E	2234E
RO68	RO68	15498	4742E	2000E	RO68	2879E	8870E	2234E
RO69	RO69	15498	4742E	2000E	RO69	2879E	8870E	2234E
RO70	RO70	15498	4742E	2000E	RO70	2879E	8870E	2234E
RO71	RO71	15498	4742E	2000E	RO71	2879E	8870E	2234E
RO72	RO72	15498	4742E	2000E	RO72	2879E	8870E	2234E
RO73	RO73	15498	4742E	2000E	RO73	2879E	8870E	2234E
RO74	RO74	15498	4742E	2000E	RO74	2879E	8870E	2234E
RO75	RO75	15498	4742E	2000E	RO75	2879E	8870E	2234E
RO76	RO76	15498	4742E	2000E	RO76	2879E	8870E	2234E
RO77	RO77	15498	4742E	2000E	RO77	2879E	8870E	2234E
RO78	RO78	15498	4742E	2000E	RO78	2879E	8870E	2234E
RO79	RO79	15498	4742E	2000E	RO79	2879E	8870E	2234E
RO80	RO80	15498	4742E	2000E	RO80	2879E	8870E	2234E

620-6011-55
111

SHUD COOLDOWN INC. SUPPORT SKIRT

ITERATION	NO.	PAGE	IT	DATE	08/04/78
32	ROT:	470E+05	208E+07	140E+02	130E+00
33	ROT:	470E+05	208E+07	140E+02	130E+00
34	ROT:	470E+05	208E+07	140E+02	130E+00
35	ROT:	470E+05	208E+07	140E+02	130E+00
36	ROT:	470E+05	208E+07	140E+02	130E+00
37	ROT:	470E+05	208E+07	140E+02	130E+00

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS X AND Z)

82/1
05/98
620-001-55

SHUD COOLDOWN INC. SUPPORT SKIRT

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE		MIDPLANE		INSIDE	
	LONG	HOOP	LONG	HOOP	LONG	HOOP
1	12525	12525	12525	12525	12525	12525
2	12525	12525	12525	12525	12525	12525
3	12525	12525	12525	12525	12525	12525
4	12525	12525	12525	12525	12525	12525
5	12525	12525	12525	12525	12525	12525
6	12525	12525	12525	12525	12525	12525
7	12525	12525	12525	12525	12525	12525
8	12525	12525	12525	12525	12525	12525
9	12525	12525	12525	12525	12525	12525
10	12525	12525	12525	12525	12525	12525
11	12525	12525	12525	12525	12525	12525
12	12525	12525	12525	12525	12525	12525
13	12525	12525	12525	12525	12525	12525
14	12525	12525	12525	12525	12525	12525
15	12525	12525	12525	12525	12525	12525
16	12525	12525	12525	12525	12525	12525
17	12525	12525	12525	12525	12525	12525
18	12525	12525	12525	12525	12525	12525
19	12525	12525	12525	12525	12525	12525
20	12525	12525	12525	12525	12525	12525
21	12525	12525	12525	12525	12525	12525
22	12525	12525	12525	12525	12525	12525
23	12525	12525	12525	12525	12525	12525
24	12525	12525	12525	12525	12525	12525
25	12525	12525	12525	12525	12525	12525
26	12525	12525	12525	12525	12525	12525
27	12525	12525	12525	12525	12525	12525
28	12525	12525	12525	12525	12525	12525
29	12525	12525	12525	12525	12525	12525
30	12525	12525	12525	12525	12525	12525
31	12525	12525	12525	12525	12525	12525
32	12525	12525	12525	12525	12525	12525
33	12525	12525	12525	12525	12525	12525
34	12525	12525	12525	12525	12525	12525
35	12525	12525	12525	12525	12525	12525
36	12525	12525	12525	12525	12525	12525
37	12525	12525	12525	12525	12525	12525
38	12525	12525	12525	12525	12525	12525
39	12525	12525	12525	12525	12525	12525
40	12525	12525	12525	12525	12525	12525

LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.

620-011-00

SMUD COOLDOWN INC. SUPPORT SKIRT

ITERATION 45 PAGE 1 DATE 08/04/78

INPUT DATA

DATE 08/04/78

TOTAL NO. OF SEGMENTS = 37

BOUNDARY CONDITIONS AT THE TOP (O) END

- 1. A RADIAL DEFLECTION OF $-.01879$ INCHES } REF. PAGE 93
- 2. A ROTATION OF $-.00820$ RADIANS }

BOUNDARY CONDITIONS AT THE BOTTOM (I) END

- 1. AN AXIAL FORCE OF -2000000.00000 POUNDS FROM REF. 1, PAGE B-12-1
- 2. A RADIAL DEFLECTION OF 0.00000 INCHES
- 3. A ROTATION OF 0.00000 RADIANS

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
 SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.
 ALL LOADS ABOVE, ARE ON A TOTAL LOAD BASIS.

111
 620-111-02
 05/11/78
 HFB

PLATE 1018 PROVIDED BY THE STRUCTURAL ANALYSIS GROUP

ITERATION 45 PAGE 2 DATE 08/04/78

SHUD COOLDOWN INC. SUPPORT SKIRT

MID-SURFACE GEOMETRY
 AT TOP BOUNDARY, MEAN RADIUS = 76.3200 Z COORDINATE = 94.4000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	BOTTOM MEAN RADIUS	MEAN RADIUS	TOP MEAN RADIUS	CENTER OF CURVATURE DATA	IDENTIFIER
				RADIUS TO CENTER	CURVATURE
1	70.220	93.840	0.000	0.000	0.0
2	76.570	92.800	0.000	0.000	0.0
3	69.890	91.840	0.000	0.000	0.0
4	69.500	90.640	0.000	0.000	0.0
5	69.500	89.600	0.000	0.000	0.0
6	69.500	88.530	0.000	0.000	0.0
7	68.700	87.500	0.000	0.000	0.0
8	68.700	86.200	0.000	0.000	0.0
9	68.700	84.640	0.000	0.000	0.0
10	68.700	83.620	0.000	0.000	0.0
11	68.330	82.520	0.000	0.000	0.0
12	68.330	81.020	0.000	0.000	0.0
13	68.200	81.020	0.000	0.000	0.0
14	68.200	79.000	0.000	0.000	0.0
15	68.200	77.000	0.000	0.000	0.0

NOTE - CURVATURE IDENTIFIER
 *1= POSITIVE CURVATURE
 0= NO CURVATURE
 -1= NEGATIVE CURVATURE

115
 0000
 620-0011-50

SEGMENTAL GEOMETRY BY SEGMENTS I K= SEGMENT NO. 1

MEAN RADIUS		R(K-1)		R(K-2)		R(K-3)		R(K-4)		R(K-5)		R(K-6)		R(K-7)		R(K-8)	
1	70.22	70.07	69.89	69.70	69.50	69.30	69.10	68.90	68.70	68.50	68.30	68.10	67.90	67.70	67.50	67.30	67.10
3	68.26	68.18	68.10	68.02	67.94	67.86	67.78	67.70	67.62	67.54	67.46	67.38	67.30	67.22	67.14	67.06	66.98
5	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26	68.26

Z COORDINATE		Z(K-1)		Z(K-2)		Z(K-3)		Z(K-4)		Z(K-5)		Z(K-6)		Z(K-7)		Z(K-8)	
1	94.49	92.40	91.40	90.40	89.40	88.40	87.40	86.40	85.40	84.40	83.40	82.40	81.40	80.40	79.40	78.40	77.40
3	84.00	83.00	82.00	81.00	80.00	79.00	78.00	77.00	76.00	75.00	74.00	73.00	72.00	71.00	70.00	69.00	68.00
5	89.00	88.00	87.00	86.00	85.00	84.00	83.00	82.00	81.00	80.00	79.00	78.00	77.00	76.00	75.00	74.00	73.00

55-110-020
 31/50

ITERATION 45 PAGE 8 DATE 08/04/78

SHUD COOLDOWN INC. SUPPORT SKIRT

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO.	ALPHA	MODULUS OF TENSION	MODULUS OF SHEAR	POISSON'S RATIO
1	16947	2800E+09	1080E+08	3000E-00
2	16948	2800E+09	1070E+08	3000E-00
3	16949	2800E+09	1070E+08	3000E-00
4	16950	2800E+09	1080E+08	3000E-00
5	16951	2800E+09	1080E+08	3000E-00
6	16952	2800E+09	1080E+08	3000E-00
7	16953	2800E+09	1080E+08	3000E-00
8	16954	2800E+09	1080E+08	3000E-00
9	16955	2800E+09	1080E+08	3000E-00
10	16956	2800E+09	1080E+08	3000E-00
11	16957	2800E+09	1080E+08	3000E-00
12	16958	2800E+09	1080E+08	3000E-00
13	16959	2800E+09	1080E+08	3000E-00
14	16960	2800E+09	1080E+08	3000E-00
15	16961	2800E+09	1080E+08	3000E-00
16	16962	2800E+09	1080E+08	3000E-00
17	16963	2800E+09	1080E+08	3000E-00
18	16964	2800E+09	1080E+08	3000E-00
19	16965	2800E+09	1080E+08	3000E-00
20	16966	2800E+09	1080E+08	3000E-00
21	16967	2800E+09	1080E+08	3000E-00
22	16968	2800E+09	1080E+08	3000E-00
23	16969	2800E+09	1080E+08	3000E-00
24	16970	2800E+09	1080E+08	3000E-00
25	16971	2800E+09	1080E+08	3000E-00
26	16972	2800E+09	1080E+08	3000E-00
27	16973	2800E+09	1080E+08	3000E-00
28	16974	2800E+09	1080E+08	3000E-00
29	16975	2800E+09	1080E+08	3000E-00
30	16976	2800E+09	1080E+08	3000E-00
31	16977	2800E+09	1080E+08	3000E-00
32	16978	2800E+09	1080E+08	3000E-00
33	16979	2800E+09	1080E+08	3000E-00
34	16980	2800E+09	1080E+08	3000E-00
35	16981	2800E+09	1080E+08	3000E-00
36	16982	2800E+09	1080E+08	3000E-00
37	16983	2800E+09	1080E+08	3000E-00
38	16984	2800E+09	1080E+08	3000E-00
39	16985	2800E+09	1080E+08	3000E-00
40	16986	2800E+09	1080E+08	3000E-00
41	16987	2800E+09	1080E+08	3000E-00
42	16988	2800E+09	1080E+08	3000E-00
43	16989	2800E+09	1080E+08	3000E-00
44	16990	2800E+09	1080E+08	3000E-00
45	16991	2800E+09	1080E+08	3000E-00
46	16992	2800E+09	1080E+08	3000E-00
47	16993	2800E+09	1080E+08	3000E-00
48	16994	2800E+09	1080E+08	3000E-00
49	16995	2800E+09	1080E+08	3000E-00
50	16996	2800E+09	1080E+08	3000E-00
51	16997	2800E+09	1080E+08	3000E-00
52	16998	2800E+09	1080E+08	3000E-00
53	16999	2800E+09	1080E+08	3000E-00
54	17000	2800E+09	1080E+08	3000E-00

Jan 12

SHUD CROLDOWN INC. SUPPORT SKIRT *****

ITERATION 45 PAGE 6 DATE 08/04/78

SHUD CROLDOWN INC. SUPPORT SKIRT

PRESSURE INPUT DATA BY GROUPS

TOP BOTTOM INTERNAL EXTERNAL
 SEG. NO. SPO. NO. PRESSURE PRESSURE
 1.0 37.0 0.0 0.0

MECHANICAL LOADING ON SEGMENTAL GROUPS

TOP BOTTOM RADIAL MOMENT AXIAL
 SEG. NO. SEG. NO. FORCE FORCE
 1.0 37.0 0. 0.

STRESS CONCENTRATION FACTORS BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TENSION INSIDE	TENSION OUTSIDE
1	37	.72	.79
1	37	.44	.06
1	37	.00	.06
1	37	.00	.00

FROM REF. SECTION B-13

100-001-55

TEMPERATURES PER SEGMENT USED IN PRIMARY + SECONDARY ANALYSIS

SEGMENT	OUTSIDE				INSIDE			
	T1	T2	T3	T4	T1	T2	T3	T4
1	424.4	424.4	424.4	424.4	424.4	424.4	424.4	424.4
2	426.7	426.7	426.7	426.7	426.7	426.7	426.7	426.7
3	425.5	425.5	425.5	425.5	425.5	425.5	425.5	425.5
4	423.3	423.3	423.3	423.3	423.3	423.3	423.3	423.3
5	421.1	421.1	421.1	421.1	421.1	421.1	421.1	421.1
6	409.7	409.7	409.7	409.7	409.7	409.7	409.7	409.7
7	401.1	401.1	401.1	401.1	401.1	401.1	401.1	401.1
8	395.5	395.5	395.5	395.5	395.5	395.5	395.5	395.5
9	387.7	387.7	387.7	387.7	387.7	387.7	387.7	387.7
10	378.8	378.8	378.8	378.8	378.8	378.8	378.8	378.8
11	372.2	372.2	372.2	372.2	372.2	372.2	372.2	372.2
12	366.6	366.6	366.6	366.6	366.6	366.6	366.6	366.6
13	360.0	360.0	360.0	360.0	360.0	360.0	360.0	360.0
14	353.3	353.3	353.3	353.3	353.3	353.3	353.3	353.3
15	328.8	328.8	328.8	328.8	328.8	328.8	328.8	328.8
16	302.2	302.2	302.2	302.2	302.2	302.2	302.2	302.2

620-00-155
120

SMUD COOLDOWN INC. SUPPORT SKIRT ITERATION 45 PAGE 8 DATE 08/04/78

PRIMARY SECONDARY BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (O)	ROTATION (O)	RADIAL DEF. (N)	ROTATION (N)	SUM
0.	0.	0.	-200E+07	0.	0.	0.	0.	-200E+07
0.	0.	0.	-237E+04	-230AF+07	0.	0.	0.	-237E+04
0.	0.	0.	-161E+05	-139E+08	-6075E+07	0.	0.	-161E+05
0.	0.	0.	-680E+05	-263E+02	-1024E+03	0.	0.	-680E+05
0.	0.	0.	-2714E+06	-1440E+03	-1666E+03	0.	0.	-2714E+06

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (O)	MOMENT (O)	RADIAL DEF. (N)	MOMENT (N)
0.	0.	0.	5364E+08	780E+09	-409E+09	-104E+09	-5554E+14
0.	0.	0.	378E+08	194E+07	-17E+08	-76E+08	-27E+08
0.	0.	0.	400E+09	475E+09	-37E+08	109E+08	17E+08
0.	0.	0.	100E+09	-276E+13	-62E+14	-92E+08	2004E+08
0.	0.	0.	5556E+11	-276E+13	-184E+14	-783E+08	-2004E+08

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEF. (O)	ROTATION (O)	RADIAL DEF. (N)	ROTATION (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	-975E+02	-2194E+07	645E+05	0.	0.	-975E+02
0.	0.	0.	-57E+06	-494E+08	-247E+05	0.	0.	-57E+06
0.	0.	0.	41E+16	-1764E+20	-247E+20	0.	0.	41E+16
0.	0.	0.	0.	0.	0.	0.	0.	0.

Handwritten initials or marks.

ITERATION 45 PAGE 6 DATE 08/04/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 01060
(THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(0)	Q(0)	X(0)	Q(0)
ROTATION(0)	.10122E-09	.11781E-07	.57205E-13	.11805E-11
DEFLECTION(0)	.11781E-09	.11781E-06	.57205E-13	.11805E-11
ROTATION(1)	.11781E-09	.11781E-06	.57205E-13	.11805E-11
DEFLECTION(1)	.11805E-11	.11781E-06	.57205E-13	.11805E-11

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

620-2111-55
122

PRIMARY - SECONDARY FORCES AND MOTIONS

POSITIVE DIRECTIONS (-) ARE AS FOLLOWS
 TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS

RADIAL----- TO THE LEFT
 ROTATIONAL--- CLOCKWISE
 AXIAL----- UPWARD

RADIAL----- TO THE RIGHT
 ROTATIONAL--- COUNTERCLOCKWISE
 AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	1625.00	5631.00	2000.00	TOP	0.00	0.00	0.00
	R01	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R02	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R03	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R04	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R05	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R06	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R07	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R08	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R09	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R10	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R11	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R12	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R13	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R14	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R15	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R16	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R17	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R18	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R19	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R20	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R21	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R22	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R23	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R24	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R25	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R26	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R27	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R28	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R29	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R30	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R31	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R32	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R33	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R34	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R35	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R36	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R37	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R38	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R39	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R40	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R41	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R42	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R43	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R44	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R45	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R46	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R47	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R48	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R49	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00
	R50	1470.00	4407.00	2000.00	ROT	0.00	0.00	0.00

620-0011-55
 123

 SHUD COOLDOWN INC. SUPPORT SKIRT ***

ITERATION AS PAGE 11 DATE 08/04/78

ITERATION	AS	PAGE 11	DATE 08/04/78
33	ROT:	2109E-01	1199E-00
34	ROT:	2512E-01	1202E-00
35	ROT:	1508E-01	1217E-00
36	ROT:	5866E-02	1221E-00
37	ROT:	4418E-15	1249E-00

IFORCF AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z1

11/1
 05/78
 620-0011-55
 124

SHUD COOLDOWN INC. SUPPORT SKIRT

ITERATION 45 DATE 08/04/78

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE	INSIDE	SEGMENT	OUTSIDE	INSIDE
1	4200	4200	1	4200	4200
2	4200	4200	2	4200	4200
3	4200	4200	3	4200	4200
4	4200	4200	4	4200	4200
5	4200	4200	5	4200	4200
6	4200	4200	6	4200	4200
7	4200	4200	7	4200	4200
8	4200	4200	8	4200	4200
9	4200	4200	9	4200	4200
10	4200	4200	10	4200	4200
11	4200	4200	11	4200	4200
12	4200	4200	12	4200	4200
13	4200	4200	13	4200	4200
14	4200	4200	14	4200	4200
15	4200	4200	15	4200	4200
16	4200	4200	16	4200	4200
17	4200	4200	17	4200	4200
18	4200	4200	18	4200	4200
19	4200	4200	19	4200	4200
20	4200	4200	20	4200	4200
21	4200	4200	21	4200	4200
22	4200	4200	22	4200	4200
23	4200	4200	23	4200	4200
24	4200	4200	24	4200	4200
25	4200	4200	25	4200	4200
26	4200	4200	26	4200	4200
27	4200	4200	27	4200	4200
28	4200	4200	28	4200	4200
29	4200	4200	29	4200	4200
30	4200	4200	30	4200	4200
31	4200	4200	31	4200	4200
32	4200	4200	32	4200	4200
33	4200	4200	33	4200	4200
34	4200	4200	34	4200	4200
35	4200	4200	35	4200	4200
36	4200	4200	36	4200	4200
37	4200	4200	37	4200	4200
38	4200	4200	38	4200	4200
39	4200	4200	39	4200	4200
40	4200	4200	40	4200	4200
41	4200	4200	41	4200	4200
42	4200	4200	42	4200	4200
43	4200	4200	43	4200	4200
44	4200	4200	44	4200	4200
45	4200	4200	45	4200	4200
46	4200	4200	46	4200	4200
47	4200	4200	47	4200	4200
48	4200	4200	48	4200	4200
49	4200	4200	49	4200	4200
50	4200	4200	50	4200	4200
51	4200	4200	51	4200	4200
52	4200	4200	52	4200	4200
53	4200	4200	53	4200	4200
54	4200	4200	54	4200	4200
55	4200	4200	55	4200	4200
56	4200	4200	56	4200	4200
57	4200	4200	57	4200	4200
58	4200	4200	58	4200	4200
59	4200	4200	59	4200	4200
60	4200	4200	60	4200	4200
61	4200	4200	61	4200	4200
62	4200	4200	62	4200	4200
63	4200	4200	63	4200	4200
64	4200	4200	64	4200	4200
65	4200	4200	65	4200	4200
66	4200	4200	66	4200	4200
67	4200	4200	67	4200	4200
68	4200	4200	68	4200	4200
69	4200	4200	69	4200	4200
70	4200	4200	70	4200	4200
71	4200	4200	71	4200	4200
72	4200	4200	72	4200	4200
73	4200	4200	73	4200	4200
74	4200	4200	74	4200	4200
75	4200	4200	75	4200	4200
76	4200	4200	76	4200	4200
77	4200	4200	77	4200	4200
78	4200	4200	78	4200	4200
79	4200	4200	79	4200	4200
80	4200	4200	80	4200	4200
81	4200	4200	81	4200	4200
82	4200	4200	82	4200	4200
83	4200	4200	83	4200	4200
84	4200	4200	84	4200	4200
85	4200	4200	85	4200	4200
86	4200	4200	86	4200	4200
87	4200	4200	87	4200	4200
88	4200	4200	88	4200	4200
89	4200	4200	89	4200	4200
90	4200	4200	90	4200	4200
91	4200	4200	91	4200	4200
92	4200	4200	92	4200	4200
93	4200	4200	93	4200	4200
94	4200	4200	94	4200	4200
95	4200	4200	95	4200	4200
96	4200	4200	96	4200	4200
97	4200	4200	97	4200	4200
98	4200	4200	98	4200	4200
99	4200	4200	99	4200	4200
100	4200	4200	100	4200	4200

8-24
 6020-0011-05
 126

SHUD COOLDOWN INC. SUPPORT SKIRT ITERATION 45 PAGE 14 DATE 08/04/78

PEAK BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (O)	ROTATION (O)	RADIAL DEFL. (N)	ROTATION (N)	SUM
0	0	0	-200E+07	0	0	0	0	-200E+07
-244E+08	0	0	-233E+06	-210E+07	-607E+07	0	0	-200E+07
-175E+09	0	0	-140E+05	-192E+06	-100E+03	0	0	-200E+07
-343E+07	0	0	-271E+06	-140E+03	-160E+03	0	0	-200E+07

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (O)	MOMENT (O)	RADIAL DEFL. (N)	MOMENT (N)
0	0	0	0	0	0	0	0
-997E+01	0	0	-578E+08	-789E+08	-469E+08	-104E+08	-556E+08
-237E+02	0	0	-789E+08	-197E+08	-145E+08	-976E+08	-574E+08
-257E+01	0	0	-469E+08	-145E+08	-145E+08	-104E+08	-556E+08
-240E+01	0	0	-556E+08	-104E+08	-104E+08	-976E+08	-574E+08

BOUNDARY DEFLECTIONS DUE TO THE FND CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL DEFL. (O)	ROTATION (O)	RADIAL DEFL. (N)	ROTATION (N)	SUM
0	0	0	0	0	0	0	0	0
-120E+08	0	0	-905E+02	-219E+02	-662E+02	0	0	-120E+08
-107E+12	0	0	-577E+10	-179E+08	-249E+08	0	0	-120E+08
-274E+12	0	0	-616E+10	-694E+08	-194E+08	0	0	-120E+08
-331E+12	0	0	0	-140E+02	-271E+02	0	0	-120E+08

824
 07/18
 1020-111-55
 127

SMUD COOLDOWN INC. SUPPORT SKIRT ***** ITERATION 45 PAGE 15 DATE 08/04/78 *****

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
 (THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(0)	G(0)	M(1)	G(1)
ROTATION(0)	:19122E-09	:11787E-07	:37450E-12	:11895E-11
DEFLECTION(0)	:17787E-07	:12291E-06	:62505E-09	:61227E-08
ROTATION(1)	:17705E-13	:1505E-12	:12490E-07	:12317E-07
DEFLECTION(1)	:11895E-11	:13224E-11	:402143E-07	:370318E-07

NOTE- THE *1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF *1 IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

2011
 05/78
 620-011-55
 128

SHUD COOLDOWN INC. SUPPORT SKIRT ITERATION 45 PAGE 17 DATE 08/04/78

	ROT:		ROT:	ITERATION	DATE	TIME
33	000E+00	428E+06	000E+07	3199E+01	08/04/78	11:02:00
34	000E+00	506E+06	200E+07	2515E+01	08/04/78	11:02:00
35	000E+00	587E+06	200E+07	1507E+01	08/04/78	11:02:00
36	000E+00	957E+06	200E+07	5857E+01	08/04/78	11:02:00
37	000E+00	376E+07	200E+07	4441E+15	08/04/78	11:02:00

IF FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

620-0011-55
130

The primary plus secondary stress intensity was calculated at the most highly stressed point and combined with the worst case stress intensity during heatup from the Stress Report (Ref. 1) to calculate the range of stress intensity. The range of primary plus secondary stress intensity was found to be greater than the allowable, therefore it was necessary to perform a Simplified Elastic-Plastic Fatigue Analysis.

The usage factor for the one (1) cycle of "Rapid Cooldown" was calculated by the same method as the primary plus secondary stress intensity and combined with the usage factor from the Stress Report (Ref. 1) for a total cumulative usage factor.

The following pages contain the fatigue analysis.

JLH
08/78
620-0011-55

THE MAXIMUM (OR MINIMUM) STRESS INTENSITY RESULTING FROM HEAT UP AS CALCULATED IN THE SUPPORT SKIRT STRESS REPORT WILL BE COMBINED WITH THE COOLDOWN INCIDENT STRESS INTENSITY TO FIND THE RANGE OF STRESS INTENSITIES.

FROM THE STRESS REPORT THE MAXIMUM STRESS INTENSITY OCCURRING DURING HEAT UP WAS $\delta_H - \delta_L = 74.4$ KSI (PRIMARY PLUS SECONDARY) JUNCTURE 1 INSIDE. PAGE B-16-2 & B-17-2.

FROM THE COOLDOWN INCIDENT STRESS EVALUATION THE MINIMUM STRESS INTENSITY WAS $\delta_H - \delta_L = -72.7 - 21.7 = -94.4$ KSI (PRIMARY PLUS SECONDARY, JUNCTURE 1, INSIDE).

THE RANGE OF PRIMARY PLUS SECONDARY STRESS INTENSITY IS
 $74.4 + 94.4 = 168.8$ KSI

THE MAXIMUM PEAK STRESS INTENSITY OCCURRING DURING HEAT UP FROM THE STRESS REPORT WAS $\delta_H - \delta_L = 86.7$ AT JUNCT 1, IN, PAGE B-16-2 FROM THE COOLDOWN INCIDENT STRESS EVALUATION, THE MINIMUM PEAK STRESS INTENSITY WAS $\delta_H - \delta_L = -67.0 - 36.7 = -103.7$ KSI Jct 1, IN.

THE RANGE OF PEAK STRESS INTENSITY IS
 $86.7 + 103.7 = 190.4$ KSI

REF. USAS B31.7 NUCLEAR POWER PIPING CODE, DRAFT USA STANDARD FEB, 1968 PARAGRAPH F-105.2.7

$$SALT = \frac{1}{2} K_f K_e S_{rij}^{(n)}$$

WHERE $K_f = K_t + A (K_t - 1)$
 AND $K_t = S_{rij}^{(P)} / S_{rij}^{(n)}$

$$S_{rij}^{(P)} = \text{PEAK STRESS INTENSITY RANGE} = 190.4 \text{ KSI}$$

$$S_{rij}^{(n)} = \text{PRIMARY PLUS SECONDARY STRESS INTENSITY RANGE} = 168.8 \text{ KSI}$$

THE "A" FACTOR IS A FUNCTION OF $S_{rij}^{(n)} / 3 S_m$

REF. FIG. 201(b) APPENDIX D OF B 31.7

$$S_{rij}^{(n)} / 3 S_m = 168.8 / 80.1 = 2.11$$

BABCOCK & WILCOX
 DEPARTMENT

DATE 08/07/78 BY J.L.H.

CHECKED DATE BY

JOB NO. 1620-0011-55

REVISION

SHEET 133 OF

FROM FIG. 241 (C)* IN APPENDIX D OF B31.7 THE "A" FACTOR IS FOUND BY EXTRAPOLATING THE "A" CURVE FOR 2 1/4 Cr-Mo TO BE 3.5

* A CURVE IS NOT AVAILABLE FOR A-508 CL2 MATERIAL SO THE APPROXIMATION IS MADE BY EXTRAPOLATING THE MOST CONSERVATIVE CURVE AVAILABLE (THE (b) CURVE).

$$K_t = S_{FL}^{(P)} / S_{FL}^{(N)} = 190.4 / 168.3 = 1.13$$

$$K_f = K_t + A(K_t - 1) = 1.13 + 3.5(1.13 - 1.0) = 1.585$$

K_E (ELASTIC-PLASTIC CORRECTION FACTOR) IS A FUNCTION OF A RATIO OF THE AVERAGE (THRU THICKNESS) PRIMARY PLUS SECONDARY MEMBRANE STRESS INTENSITY RANGE AND THE AVERAGE (THRU THICKNESS) PRIMARY PLUS SECONDARY BENDING STRESS INTENSITY RANGE.

PRIMARY PLUS SECONDARY MEMBRANE STRESSES (MIDPLANE)

	σ_L	σ_H	σ_R
ITER 45 "COOLDOWN"	-1.7	-74.4	0.
ITER 2025 STRESS REPORT	-0.5	-0.5	37.3

PRIMARY PLUS SECONDARY MEMBRANE STRESS INTENSITIES (MIDPLANE)

	$\sigma_L - \sigma_R$	$\sigma_R - \sigma_L$	$\sigma_H - \sigma_L$
ITER 45 "COOLDOWN"	-1.7	74.4	-72.7
ITER 2025 STRESS REPORT	0.	-37.3	37.3

PRIMARY PLUS SECONDARY MEMBRANE STRESS INTENSITY RANGE (G.M.)

1.7	112.2	110.5
-----	-------	-------

BABCOCK & WILCOX DEPARTMENT	DATE 12/10/52 BY J.L.H.	REVISION
	CHECKED DATE BY	
	JOB NO. 6700-100-55	SHEET 74 OF

PRIMARY PLUS SECONDARY PRINCIPLE BENDING STRESSES
INSIDE - MIDPLANE

	σ_L	σ_H	σ_R
ITER 45 "COOLDOWN"	23.4	1.7	0.
ITER 2028 STRESS REPORT	-50.4	.4	-13.8

PRIMARY PLUS SECONDARY BENDING STRESS INTENSITIES
INSIDE - MIDPLANE

	$\sigma_L - \sigma_R$	$\sigma_R - \sigma_H$	$\sigma_H - \sigma_L$
ITER 45 "COOLDOWN"	23.4	-1.7	-21.7
ITER 2028 STRESS REPORT	-50.8	14.2	36.6

Q_B PRIMARY PLUS SECONDARY
BENDING STRESS INTENSITY
RANGE

74.2 15.9 58.3

FOR THE $\sigma_H - \sigma_L$ STRESS INTENSITIES THE PARAMETER FOR
THE K_e CORRECTION FACTOR IS

$$\frac{Q_M}{Q_M + Q_B} = \frac{110.5}{110.5 + 58.3} = .65$$

FROM FIGURE F-105(a) APPENDIX F OF B 31.7 $K_e = 1.9$

$$S_{ALT} = \frac{1}{2} K_f K_e S_{rij}^{(n)}$$

$$S_{ALT} = \frac{1}{2} (1.58)(1.9)(168.8) = 253.4 \text{ KSI}$$

$$S'_{ALT} = (30 \times 10^6 / 28.8 \times 10^6)(253.4) = 264 \text{ KSI}$$

BABCOCK & WILCOX	DATE 09/28/70	BY J.L.H.	REVISION
DEPARTMENT	CHECKED DATE	BY	
	JOB NO. 620-0011-55		SHEET 135 OF

N ALLOWABLE CYCLES FROM SECTION III N-415(a) IS 52 CYCLES
N REQUIRED IS 1 CYCLE

USAGE FACTOR = $\frac{1}{52} = .02$ (COOLDOWN, 1 CYCLE)

USAGE FACTOR FROM STRESS REPORT IS 0.89 (240 CYCLES HEAT UP & COOLDOWN)

COMBINED TOTAL USAGE FACTOR = $0.89 + 0.02 = 0.91$

BABCOCK & WILCOX

DEPARTMENT

DATE 08/08/75 BY J.L.H.

CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 136 OF

OTSG LOWER TUBESHEET AREA AND TUBE
STRESS EVALUATION DUE TO THE
'RAPID COOLDOWN' EVENT OF MARCH 20, 1978

FOR

SACRAMENTO MUNICIPAL UTILITY DISTRICT

B&W CONTRACT: 620-0011-55
CUSTOMER ORDER NO: 3075

BY: *James C. White* - ENGR. Assoc. 10-6-78

APPROVED BY: *John D. Brew* - Sn. Engr. Supervisor 6-9-78

B & W DOCUMENT NUMBER

33 0274 00

Component Engineering
Mt. Vernon Works
Mt. Vernon, Indiana

DISCUSSION

The geometry and materials were established by Report No. 4 of the OTSG Stress Report for Sacramento Municipal Utility District.

The Transient Condition is given in the transmitted data shown in the Appendix. The analyzed 'Rapid Cooldown' was taken from this information.

To determine the thermal effects of the analyzed transient, a thermal model was developed, film coefficients were calculated, and B&W Program 91167 'Implicit and Explicit Temperature Distribution' was run. This program determined the temperature distribution versus time for the overall geometry. (The tubesheet was not included in this model; however, its temperature distribution was determined later in the report.)

From this 'Time vs. Temperature' information, the critical times for further analysis were selected based on: 1) maximum radial and axial gradients in the model and 2) maximum temperature difference between average tube temperature and average shell temperature (causes maximum tube loads).

The overall geometry was divided into classic analytical parts called interaction elements.

At the critical times for analysis, the temperatures for each interaction element were interpolated (by B&W Program 91032 'Temperature Interpolation Grid Change Program') to the format used by B&W Program 91206 'Save-SS-II'. This interpolation was required since the 91206 B&W Program is used to determine the free-body thermal motions and stresses resulting from the temperature effects of the transients analyzed.

The temperatures through the thickness of the tubesheet were determined using equations pertaining to a 'Not Very Long Rod Protruding From A Heat Source' from Ref. 6.

The preceding thermal motions were input, along with the appropriate pressures and other data, into B&W Program 91249 'Tubesheet Area Interaction Analysis' to determine interaction stresses, tube loads, ligament stresses, etc.

To evaluate the interaction junctures, the appropriate stress concentration factors were input, along with the sum of the free-body thermal and 91249 interaction stresses, into B&W Program 91076 'Stress Summary Program'. This program calculates stress intensities and ranges for both primary plus secondary and peak classifications. These values are then used in meeting the stress and fatigue requirements of the design code.


— The critical interaction junctures (head-to-tubesheet and shell-to-tubesheet) were also evaluated for increased fatigue usage factor due to the 'Rapid Cooldown'.

The stress requirements applicable to the tubes were satisfied based on stresses resulting from the tube loads output by Program 91249.


As an aid in visualizing the analytical steps just explained, a flow chart of the analysis has been included on the following two pages.

A final check was made to assure that non-ductile failure would not occur for a postulated base metal defect.

ANALYSIS FLOW CHART



FLOW CHART (CONT'D)



RESULTS:

A) Interaction Junctionures

1) Head-To-Tubesheet

a) Max. Pri. + Sec. Stress Intensity Range = 79 KSI < 3 S_m
= 80.1 KSI (Page 161)

b) Max. cumulative usage factor = 0.034 < 1.0 max.
allowable (Page 166)

2) Shell-To-Tubesheet

a) Max. Pri. + Sec. Stress Intensity Range = 33 KSI < 3 S_m
= 80.1 KSI (Page 160)

b) Max. cumulative usage factor = 0.0 < 1.0 max.
allowable (Page 164)

B) Tubes

Max. Tube Stress = 26.0 KSI < yield strength = 30.3 KSI
(Page 173)

C) Check for assurance that non-ductile failure, due to postulated defect, will not occur:

Temperature at which non-ductile failure could occur
≈ 220°F (Page 177)

Actual temperature of metal in area of postulated defect
= 308°F (Page 177)

CONCLUSIONS:

This analysis of lower tubesheet area and tubes shows that the stresses and usage factors, including the effects of the 'Rapid cool-down', are still well within the code allowables and the structural adequacy of these areas has not been impaired.

REFERENCES:

1. ASME Code, Section III, 1965 Edition, with Addenda through Summer 1967.
2. "Stress Report for Once-Thru Steam Generator", for Sacramento Municipal Utility District, B&W Contract No. 620-0011-55, Customer Order No. 3075, Report Section No. 4, entitled 'Stress Analysis of Upper and Lower Tubesheets'.
3. BAW-10046 Topical Report, May 1976, entitled 'Methods of Compliance with Fracture Toughness and Operational Requirements of 10CFR50, Appendix G.
4. ASME Code, Section III, 1977 Edition, Appendix G.
5. Babcock & Wilcox, NPGD, Engineering Calculations, Heat Transfer Manual 2A3-N, Sections 2A35221 and 2A35222.
6. 'Heat Transfer', Volume 1, by Max Jakob, copyright 1949, John Wiley & Sons, Inc., Publishers, New York.
7. B&W Computer Program 91167, 'Explicit and Implicit Transient Temperature Distribution', Revision 2, dated 7/73.
8. B&W Computer Program 91032, 'Temperature Interpolation and Free-body Thermal Motions and Stresses', Revision 3, 9/73.
9. B&W Computer Program 91206, 'Save SS-2', Rev. 0, 2/69.
10. B&W Computer Program 91249, 'Tubesheet Area Interaction Analysis for Once-Through Steam Generators, Rev. 2, 8/75.
11. B&W Computer Program 91076, 'Calculation and Tabulation of Stress Intensities, Maximum and Minimum Stresses, Stress Range, Mean and Alternating Stresses, Rev. 0, 8/66.
12. B&W Computer Program 91425, 'Materials Standard'.
13. B&W letter from J. M. Burnett, RCS Components to Distribution, Subject: SMUD Cooldown Incident, dated 4/4/78.
14. B&W letter from J. M. Burnett - RCS Components to Distribution, Subject: SMUD Cooldown Incident, dated 4/7/78.
15. B&W letter from J. M. Burnett - RCS Components to Distribution, Subject: SMUD Cooldown Incident, dated 4/20/78.
16. B&W letter from P. A. Sherburne to C. W. Bruny, Subject: SMUD Cooldown Incident, dated 5/11/78.

LEW
620-0011-55
6/78

GEOMETRY TO BE ANALYZED

The Geometry Analyzed here is the same as was used in the original analysis, and will not be presented here again. Refer to Reference 2 for complete description of Geometry Analyzed.


LEW
620-0011-55
6/78

LOADS TO BE ANALYZED

The subject for investigation is the 'Rapid Cooldown' present in the information contained in the appendix of this analysis.

The following pages contain sketches and a discussion of the transient that is analyzed.

SMUD RAPID COOLDOWN



LEW
620-0011-55
6/78
9A OFF

SMUD RAPID COOLDOWN

DISCUSSION OF ANALYZED TRANSIENT

A) Primary Parameters -

The reactor coolant cold leg temperature and pressure are shown on the figure on page 9. These conditions are applicable to fluid blocks 193 and 192*

B) Secondary Parameters -

Period #1 - The steam generator is operating at 100% steady state conditions.

Period #2 - The loss of Non Nuclear Instrumentation (NNI) causes a reactor trip and loss of main feedwater. Thus, fluid 191* conducts heat by natural convection and it is essentially saturated water. During this period, the water level in the OTSG is decreasing but this does not affect the lower tubesheet area until Period #3.

Period #3 - During this period the steam generator has boiled 'dry' and the pressure has decreased to essentially zero. Therefore, the heat conduction during this period will be by natural convection of steam.

Period #4 - At the beginning of this period. The auxiliary feedwater flow is started. The temperature of this feedwater is 80°F. However, it should be visualized that the water exiting the auxiliary feedwater header comes into contact with the tube bundle. Before reaching the lower tubesheet this water runs down the outside of the hot (>500°F) tubes. It is reasonably assumed that after running down the outside of the tubes for an approximate distance of 50 feet, the water is heated to the saturation temperature.

As the auxiliary feedwater flow continues, the water level in the generator increases until the OTSG is full.

Since the water is 'pooled' in the lower tubesheet area, the heat conduction for this period will be by natural convection of a saturated fluid.

*See Pages 14 and 15 for location of Fluid Blocks.

LEW
620-0011-55
6/78

MATERIALS OF CONSTRUCTION

Tubesheet - A-508 CL 2 (Mag Moly)
Head - SA 533 GR B CL 1 (Mag Moly)
Shell - SA 212 GR B (Carbon Steel)
Tubes - SB 163 (Inconel)

THERMAL LOADING

The Thermal Loads are represented by the fluid transients shown on page 9, and they will be analyzed in detail in the following Thermal Analysis.


TEMPERATURE DISTRIBUTION MODEL

The following pages show the temperature distribution model as extracted from Reference 2. This model is used by Program 91167 to determine the temperature distribution versus time for the lower tubesheet interaction area.

It should be noted that the perforated portion of the tubesheet is not included in the model since its temperature distribution will be determined later by a different method.

UPPER PORTION OF PROGRAM 91167 THERMAL MODEL

LINE NUMBERS




LINE #	WIDTH
1	1.7475"
2	2.0"
3	2.0"
4	2.0"
5	2.0"
6	1.40625"
7	2.0"
8	2.0"
9	2.625"

5510

5A-533 GR B CL 1
2 72 805-A

BABCOCK & WILCOX
 DEPARTMENT MT. V-COMP ENGRS DATE 6/78 BY LEW
PROGRAM 91167 MODEL CHECKED DATE _____ BY _____
 JOB NO. 620-0011-55

REVISION _____
 SHEET 14 OF _____



LOWER PORTION OF PROGRAM 91167
THERMAL MODEL

BABCOCK & WILCOX
 DEPARTMENT NIT. V-COMP. ENGRG. DATE 6/78 BY LEW
PROGRAM 91167-MODEL CHECKED DATE _____ BY _____
 JOB NO. 620-0011-55

REVISION _____
 SHEET 15 OF _____

THERMAL PARAMETERS

The Thermal Parameters, with the exception of Heat Transfer Film Boundary Coefficients, are determined internally in Program 91167.

The following pages show the calculation of the film coefficients using equation contained in B&W Engineering Standards. However, when conditions were similar to those analyzed in the original analysis (Reference 2), the coefficients of the original analysis were extracted and used here.

LEW
620-0011-55
6/78

FILM COEFFICIENTS

FLUID 191 - LWR SHELL AND LWR TUBESHEET

TIME PERIOD #1 - 0.0 - 305.0 MIN. (100% S.S.)

PARAMETERS:

FLOW = 6.12×10^6 #/HR

FLUID = MAIN FEED WATER

TEMPERATURE = 455°F @ EDW NOZZLE (SATURATION TEMP. BY THE TIME IT CONTACTS LWR TUBESHEET = 531°)

PRESSURE = 890 PSIA

FROM REF. 2, 'TUBESHEET ANALYSIS', PG. B-3-11,

$h_{191} = 285 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$

TIME PERIOD #2A - 305.0 - 309.0 MIN.

PARAMETERS:

FLOW = 0 #/HR (NO EDW FLOW)

FLUID = SATURATED WATER

TEMP. = 515°F (AVG. TEMP. FOR TIME PERIOD)

PRESSURE = 830 PSIG (AVG. FOR TIME PERIOD)

CALC. [GEL PER] _{film}

$G_{GEL} = K_{50} L^3 \Delta T$ (REF. 5, PG. 3)

BABCOCK & WILCOX

DEPARTMENT Plant - Cond. Engr. DATE 6/78 BY LEW

FILM COEFFICIENTS

CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 17 OF

$$K_{50} = 2(10)^{10}$$

$$L = 3.11 \text{ FT (EQ. CIRCLE DIA.)} \times 0.9 = 2.80 \text{ FT}$$

$$\Delta T = 25^\circ \text{ F}$$

$$G_{c2} = [2(10)^{10}] (2.80)^3 (25) = 1.1 (10^{13})$$

$$P_r = 0.77 \text{ (FIG. NC 22)}$$

$$\therefore \left[\frac{G_{c2} P_r}{\mu} \right] = (1.1 \times 10^{13}) (0.77) = 8.5 (10^{12})$$

CORRELATION - FLAT PLATE - HORIZ. - TURB. REGION

REF. 5, PG. 7

$$h = [\Delta T]^{1/3} K_{96} K_L = [25]^{1/3} (0.17)(915)$$

$$\underline{h = 455 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}}$$

TIME PERIOD # ZB - 308.0+ TO 310.0 MIN.

PARAMETERS:

FLOW = 0 #/HR

FLUID = SATURATED WATER

TEMP. = 450 °F (AVG. TEMP. FOR TIME PERIOD)

PRESSURE = 450 PSIG (AVG. FOR TIME PERIOD)

TEMP. OF THE T.S. ASSUMED AS 500 °F.

$$\Delta T = 500^\circ - 450^\circ = 50^\circ$$

BABCOCK & WILCOX		REVISION
DEPARTMENT <u>MT. V - COMP. ENGRS.</u>	DATE <u>6/78</u>	BY <u>LEW</u>
<u>FILM COEFFICIENTS</u>	CHECKED DATE	BY
	JOB NO. <u>620-0011-55</u>	SHEET <u>18</u> OF

SAME CORRELATION AS #2A APPLIES.

$$\bar{h} = [\Delta T]^{1/3} K_{40} K_6 = [50]^{1/3} (0.17)(860)$$

$$\bar{h} = \underline{\underline{538 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}}}$$

TIME PERIOD # 2C - 310.0+ TO 312.0 MIN.

PARAMETERS:

FLOW = 0 #/HR

FLUID = SATURATED WATER

TEMP. = 305° F (AVG. TEMP. FOR TIME PERIOD)

PRESSURE = 150 PSIG (AVG. FOR TIME PERIOD)

TEMP. OF THE T.S. ASSUMED AS 405° F.

$$\Delta T = 405^\circ - 305^\circ = 100^\circ \text{F}$$

SAME CORRELATION AS #2A APPLIES.

$$\bar{h} = [\Delta T]^{1/3} K_{40} K_6 = [100]^{1/3} (0.17)(710)$$

$$\bar{h} = \underline{\underline{560 \text{ BTU/H-FT}^2\text{-}^\circ\text{F}}}$$

BABCOCK & WILCOX

DEPARTMENT MT V-CONTR. ENGRG. DATE 6/78 BY LEW

FILM COEFFICIENTS

CHECKED DATE

BY

JOB NO. 620-0011-55

REVISION

SHEET 19 OF

TIME PERIOD # 3 - 312.0 + to 317.0 MIN.

PARAMETERS:

- FLOW = 0 #/HR
- FLUID = SATURATED STEAM
- TEMP. = 212 °F (AVG. TEMP. FOR TIME PERIOD)
- PRESSURE = 0 PSIG
- TEMP. OF T.S. ASSUMED AS 500 °

$$G_{RL} = \frac{\rho^2 g \beta}{\mu^2} \times L^3 \times \Delta T$$

$$\rho = 0.0373 \text{ #/FT}^3$$

$$g = [(32.2) \text{ FT/SEC}^2] [(3600)^2 \text{ SEC}^2/\text{HR}^2] = 4.17 (10^8) \text{ FT/HR}^2$$

$$\mu = 2.5 (10^{-7}) \text{ (LBF SEC/FT}^2) \times g = 0.029 \text{ LBF/FT-HR}^2$$

$$\beta = 0.00149 / ^\circ\text{F}$$

$$G_{RL} = \frac{[(0.0373)^2 \text{ #}^2/\text{FT}^6]}{[0.029^2 \text{ #}^2/\text{FT-HR}^2]} \times \frac{[4.17 (10^8) \text{ FT}]}{[\text{HR}^2]} \times \frac{[0.00149]}{[^\circ\text{F}]}$$

$$= [(2.18)^3 \text{ FT}^3] [282] \text{ #}$$

$$G_{RL} = 4500$$

BABCOCK & WILCOX

DEPARTMENT MT. V - COND. EXPL. DATE 6/78

FILM COEFFICIENTS

CHECKED DATE

JOB NO. 620-0011-55

BY LEW

BY

REVISION

SHEET 20 OF

$$Pr = \frac{\mu C_p}{k} = \frac{[0.029 \frac{\text{lb}}{\text{ft-sec}}]}{[0.451 \frac{\text{BTU}}{\text{hr-ft-F}}]} = 0.902$$

$$\frac{[0.0145 \frac{\text{BTU}}{\text{hr-ft-F}}]}{[0.451 \frac{\text{BTU}}{\text{hr-ft-F}}]}$$

$$Gr Pr = 4500(0.902) = 4,059$$

CORRELATION - HORIZ. PL. - LAMINAR REGION

REF. 5, PG. 6

$$h = \left[\frac{\Delta T}{L} \right]^{1/4} K_1 K_2$$

$$h = \left[\frac{282}{2.8} \right]^{1/4} (0.71)(109) = \underline{\underline{245 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}}}$$

TIME PERIOD #4A - 317.0 TO 318.75 MIN

PARAMETERS:

FLOW = 0 #/HR

FLUID = SATURATED WATER

TEMP. = 375 °F (AVG. FOR TIME PERIOD)

PRESSURE = 550 PSIG (AVG. FOR TIME PERIOD)

TUBESHEET TEMP. ASSUMED AS 450 °F

$$Gr Pr = K_{52} L^3 \Delta T = 1.38(10)^{10}$$

CORRELATION - HORIZ. PLATE - TURBULENT REGION

REF. 5, PG. 7

BABCOCK & WILCOX

DEPARTMENT M.T.V. - COMP. ENGR. DATE 6/78

BY LEW

FILM COEFFICIENTS

CHECKED DATE

BY

JOB NO. 620-0011-55

REVISION

SHEET 21 OF

$$\bar{h} = [\Delta T]^{1/3} K_{46} K_c = [75]^{1/3} (0.17)(910)$$

$$\bar{h} = 652 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$$

TIME PERIOD # 4B - 318.75+ TO 340.0 MIN.

PARAMETERS:

FLOW = 0 #/HR

FLUID = SATURATED WATER

TEMP. = 460 °F (AVG. FOR TIME PERIOD)

PRESSURE = 450 PSIG (AVG. FOR TIME PERIOD)

TUBESHEET TEMP. ASSUMED AS 452 °F.

SAME CORRELATION APPLIES AS FOR #4A.

$$\bar{h} = [\Delta T]^{1/3} K_{46} K_c = [2]^{1/3} (0.17)(850)$$

$$\bar{h} = 182 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$$

TIME PERIOD # 4C - 340.0+ TO 410.0 MIN.

PARAMETERS:

FLOW = 0 #/HR

FLUID = SATURATED WATER

TEMP. = 290 °F (AVG. FOR TIME PERIOD)

PRESSURE = 60 PSIG (AVG. FOR TIME PERIOD)

TUBESHEET TEMP. ASSUMED AS 292 °F

SAME CORRELATION APPLIES AS FOR #4A.

$$\bar{h} = [\Delta T]^{1/3} K_{46} K_c = [2]^{1/3} (0.17)(640.) = 137. \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$$

BABCOCK & WILCOX

DEPARTMENT MT. V - COMP. FIGG. DATE 6/78 BY LEW

FILM COEFFICIENTS

CHECKED DATE BY

JOB NO. 630-0011-55

REVISION

SHEET 22 OF

FLUID 193 - INSIDE OF LOWER HEAD

TIME PERIOD # 1, 2, + 3 - 0.0 TO 317.0 (100% S.S.)

PARAMETERS:

FLOW = 68.95 (10⁶) #/HR

FLUID = WATER

TEMPERATURE = 568 °F

PRESSURE = 2150 PSIG

FROM REF. 2, 'TUBESHEET ANALYSIS', PAGE B-3-5,

$$\bar{h} = 317 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F (INCL. EFFECT OF CLAD.)}$$

TIME PERIOD # 4 - 317.0 + TO 410.0 MIN.

PARAMETERS:

FLOW = 68.95 (10⁶) #/HR

FLUID = WATER

TEMPERATURE = 410 °F (AVG. FOR TIME PERIOD)

PRESSURE = 150 PSI

CORRELATION - CIRC. TUBE - VERT. INSIDE SURF. - TURB.

REF. 5, PG. 9

$$\bar{h} = K_{104} \left(\frac{m^{0.8}}{D^{1.8}} \right) = (0.0254) \left(\frac{(68.95 \cdot 10^6)^{0.8}}{9.921875^{1.8}} \right)$$

$$\bar{h} = 762 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$$

BABCOCK & WILCOX

DEPARTMENT MT. V - COMP. ENGRS. DATE 6-178 BY LEW

FILM COEFFICIENTS

CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 23 OF

TAKING THE CLADDING INTO ACCOUNT -

$$\bar{h}_{193} = \frac{1}{\frac{1}{h} + \frac{x}{K_{CLAD}}} = \frac{1}{\frac{1}{762} + \frac{0.1875}{123.3}}$$
$$= \underline{\underline{352 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}}}$$

HOWEVER, USE $\bar{h} = 317 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$ (SAME AS FOR PERIODS 1, 2 + 3)

FLUID 192 - INSIDE OF SOLID TUBESHEET RIM

TIME PERIOD #1, #2, #3, #4 - 0.0 TO 410.0 MIN. (100% S.S.)

PARAMETERS:

FLOW = 68.95 (10%) #/HR

FLUID = WATER

TEMP. = 568 °F

PRESSURE = 2150 PSIG

FLOW REF. 2, 'TUBESHEET ANALYSIS', PAGE 3-3-B,

$$\underline{\underline{\bar{h}_{192} = 992 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}}}$$

BABCOCK & WILCOX

DEPARTMENT M-V-COND. ENGRS. DATE 6/78 BY LEW

FILM COEFFICIENTS

CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 24 OF

SUMMARY OF FILM COEFFICIENTS

TIME PERIOD	BLOCK 191	BLOCK 192	BLOCK 193
1	285	992	317
2A	455	992	317
2B	538	992	317
2C	560	992	317
3	245	992	317
4A	652	992	317
4B	182	992	317
4C	137	992	317

BABCOCK & WILCOX

DEPARTMENT MT. V - COMP. ENGRS. DATE 6/78 BY LEW

FILM COEFFICIENTS

CHECKED DATE _____ BY _____

JOB NO. 620-0011-55

REVISION _____

SHEET 25 OF _____

TEMPERATURE DISTRIBUTION PROGRAM 91167

The Fluid Transients, Film Coefficients, Model Geometry, and Material Codes were input into Program 91167 which determines temperature versus transient time.

The following pages contain sample output from 91167 to show its format and application.

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

SMJD--RAPID COOLDOWN TRANS.--OTSG LWR TUBESHEET ANALYSIS BY LEW

GENERAL INPUT DATA

NO SOLID BLOCKS 190 NO FLUID BLOCKS 3 NO OF EDGES 38 NO OF LINES 9 NO OF CYCLES 8
 BASE TEMP 530.0 STARTING TEMP 530.0 STARTING TIME 0.00000 STARTING ITER 0 PUNCH CARD TIME 0.00000

TIME IS IN HOURS

GEOMETRY OF THE COLUMNS

ROW NO	BLOCK NO. LOW	HI	ADJ	RADIAL DIMS	MEAN RADIUS	LOW EDGE NO	ROW NO	BLOCK NO. LOW	HI	ADJ	RADIAL DIMS	MEAN RADIUS	LOW EDGE NO
1	1	12	6	1.74750	58.65750	15	2	13	38	32	2.00000	60.53130	1
3	39	64	58	2.00000	62.53130	1	4	65	90	84	2.00000	64.53130	1
5	91	116	110	2.00000	66.53130	1	6	117	127	121	1.40630	68.23440	16
7	128	150	132	2.00000	69.93750	16	8	151	171	153	2.00000	71.93750	18
9	172	190	172	2.62500	74.25000	20							

27
 6/78
 55-100-039
 LEW

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

DETERMINATI OF BLOCKS WITH FLUID BOUNDARIES

SERIES NO	FLUID NO	FLUID FIRST	FLUID LAST	SIDE NO	SERIES NO	FLUID NO	FLUID FIRST	FLUID LAST	SIDE NO	BLOCK NO. FIRST	BLOCK NO. LAST	SIDE NO
1	193	15	12	4	3	193	13	26	1	13	26	1
4	191	15	12	2	6	191	64	64	2	64	64	2
7	191	136	150	2	9	191	127	127	2	127	127	2
10	191	136	150	1								

AXIAL DIMENSION PER EDGE

EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION	EDGE	DIMENSION
1	2.00000	4	2.00000	5	2.00000	12	2.00000
13	1.00000	10	2.00000	17	1.00000	18	1.00000
14	2.00000	14	2.00000	23	2.00000	24	2.00000
15	1.00000	15	2.00000	29	1.00000	30	1.00000
16	2.00000	22	1.00000	35	2.00000	36	2.00000
17	2.00000	28	2.00000				
18	2.00000	34	2.00000				
19	2.00000						
20	2.00000						
21	2.00000						
22	2.00000						
23	2.00000						
24	2.00000						
25	2.00000						
26	2.00000						
27	2.00000						
28	2.00000						
29	2.00000						
30	2.00000						
31	2.00000						
32	2.00000						
33	2.00000						

LEW
620-0011-55
6/78
28

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

MATERIAL SERIES

MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK	MATL NO	LAST BLOCK
12	12	2	24	12	38	2	50	12	54	2	76	12	90
2	102	12	140	1	150	12	161	1	171	12	180	1	190

FLUID BLOCK	FILM COEF.								
191	285.00	455.00	538.00	560.00	245.00	652.00	182.00	137.00	
192	992.00	992.00	992.00	992.00	992.00	992.00	992.00	992.00	
193	317.00	317.00	317.00	317.00	317.00	317.00	317.00	317.00	

LEW
 620-0011-55
 6/78
 29

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

CYCLE NO. 1 IS IMPLICIT
 CYCLE NO. 2 IS IMPLICIT
 CYCLE NO. 3 IS IMPLICIT
 CYCLE NO. 4 IS IMPLICIT
 CYCLE NO. 5 IS IMPLICIT
 CYCLE NO. 6 IS IMPLICIT
 CYCLE NO. 7 IS IMPLICIT
 CYCLE NO. 8 IS IMPLICIT

IMPLICIT CYCLE INFORMATION											
LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP	LAST STEP NO.	TIME STEP
10	.010	14	.100	23	.500	25	.035	26	.013		
5	.010										
3	.011										
3	.011										
3	.020	5	.012								
2	.010	3	.009								
5	.020	9	.050	15	.009						
10	.100	15	.020	18	.022						

30
 8/19
 6/78
 LEW
 620-0011-53

SMUD--RAPID COOLDOWN TRANS--OTSG LWR TUBESHEET ANALYSIS BY LEW
 FULL CERTIFICATION
 91167 REV 4 12-15-74 94/21/78 13-53:45 PAGE 8
 FULL CERTIFICATION
 FULL CERTIFICATION

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

TIMES AT WHICH EQUATIONS WILL VARY

5.08330 5.13330 5.16660 5.19990 5.28330 5.31250 5.66650
 6.83310

TIMES FOR PRINTOUT TIME MULTIPLE

TIME LIMIT
 .01000
 .01000
 2.49000
 2.50000
 .04330
 .01000
 .01110
 .01110
 .02000
 .01170
 .01000
 .00920
 .02000
 .10000
 .01000
 .10000
 .20000
 .02000
 .06660

LEW
 620-0011-55
 6/78
 31

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

POINT NO. 191	TYPE 1	TIME	TEMP	5.08330	5.10000	5.13330	5.16660	5.20000	5.23330	5.26660	5.29990
531.00000	531.00000	540.00000	483.00000	400.00000	320.00000	240.00000	160.00000	80.00000	0.00000	0.00000	0.00000
540.00000	540.00000	540.00000	380.00000	312.00000	240.00000	160.00000	80.00000	0.00000	0.00000	0.00000	0.00000
540.00000	540.00000	540.00000	380.00000	312.00000	240.00000	160.00000	80.00000	0.00000	0.00000	0.00000	0.00000

POINT NO. 192	TYPE 1	TIME	TEMP	5.08330	5.10000	5.13330	5.16660	5.20000	5.23330	5.26660	5.29990
0.00000	568.00000	568.00000	592.00000	540.00000	480.00000	420.00000	360.00000	300.00000	240.00000	180.00000	120.00000
568.00000	568.00000	568.00000	592.00000	540.00000	480.00000	420.00000	360.00000	300.00000	240.00000	180.00000	120.00000
568.00000	568.00000	568.00000	592.00000	540.00000	480.00000	420.00000	360.00000	300.00000	240.00000	180.00000	120.00000

LEW
 620-0011-55
 6/78
 32

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

POINT NO. 193	TYPE 1	TRANSIENT TEMPERATURE DISTRIBUTION				PROGRAM 91167			
TIME	6.00000	5.08330	5.16660	5.25000	5.31250	5.41670	5.66670	5.93330	6.20000
TEMP	568.00000	568.00000	592.00000	592.00000	540.00000	480.00000	380.00000	312.00000	280.00000
TIME	6.45670	6.83330	999.99000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
TEMP	283.00000	304.00000	304.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000

LEW
 620-0011-55
 6/78
 33

PROGRAM 91167

TRANSIENT TEMPERATURE DISTRIBUTION

PT	A	TA	B	TS	C	TC	D	ID	E	TE
0000	169	192	.084	1	.105	27	.093	193	509	1
0000	169	192	.084	2	.105	28	.084	193	559	2
0000	169	192	.084	3	.105	30	.084	193	559	3
0000	169	192	.084	4	.105	31	.084	193	559	4
0000	169	192	.084	5	.105	32	.084	193	559	5
0000	169	192	.084	6	.105	33	.084	193	559	6
0000	169	192	.084	7	.105	34	.084	193	559	7
0000	169	192	.084	8	.105	35	.084	193	559	8
0000	169	192	.084	9	.105	36	.084	193	559	9
0000	169	192	.084	10	.105	37	.084	193	559	10
0000	169	192	.084	11	.105	38	.084	193	559	11
0000	169	192	.084	12	.105	39	.084	193	559	12
0000	169	192	.084	13	.105	40	.084	193	559	13
0000	169	192	.084	14	.105	41	.084	193	559	14
0000	169	192	.084	15	.105	42	.084	193	559	15
0000	169	192	.084	16	.105	43	.084	193	559	16
0000	169	192	.084	17	.105	44	.084	193	559	17
0000	169	192	.084	18	.105	45	.084	193	559	18
0000	169	192	.084	19	.105	46	.084	193	559	19
0000	169	192	.084	20	.105	47	.084	193	559	20
0000	169	192	.084	21	.105	48	.084	193	559	21
0000	169	192	.084	22	.105	49	.084	193	559	22
0000	169	192	.084	23	.105	50	.084	193	559	23
0000	169	192	.084	24	.105	51	.084	193	559	24
0000	169	192	.084	25	.105	52	.084	193	559	25
0000	169	192	.084	26	.105	53	.084	193	559	26
0000	169	192	.084	27	.105	54	.084	193	559	27
0000	169	192	.084	28	.105	55	.084	193	559	28
0000	169	192	.084	29	.105	56	.084	193	559	29
0000	169	192	.084	30	.105	57	.084	193	559	30
0000	169	192	.084	31	.105	58	.084	193	559	31
0000	169	192	.084	32	.105	59	.084	193	559	32
0000	169	192	.084	33	.105	60	.084	193	559	33
0000	169	192	.084	34	.105	61	.084	193	559	34
0000	169	192	.084	35	.105	62	.084	193	559	35
0000	169	192	.084	36	.105	63	.084	193	559	36
0000	169	192	.084	37	.105	64	.084	193	559	37
0000	169	192	.084	38	.105	65	.084	193	559	38
0000	169	192	.084	39	.105	66	.084	193	559	39
0000	169	192	.084	40	.105	66	.084	193	559	40

LEW
 620-0011-55
 6/78
 34

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

	A	TA	B	T3	C	TC	D	TD	E	TE
0	.093	15	.094	42	.096	67	.094	40	.624	41
0	.093	16	.094	43	.096	68	.094	41	.624	42
0	.093	17	.094	44	.096	69	.094	42	.624	43
0	.093	18	.094	45	.096	70	.094	43	.624	44
0	.093	19	.094	46	.096	71	.094	44	.624	45
0	.093	20	.094	47	.096	72	.094	45	.624	46
0	.093	21	.094	48	.096	73	.094	46	.624	47
0	.093	22	.125	49	.096	74	.094	47	.592	48
0	.093	23	.376	50	.096	75	.251	48	.185	49
0	.093	24	.356	51	.096	76	.376	49	.080	50
0	.083	25	.338	52	.086	77	.356	50	.138	51
0	.083	26	.225	53	.086	78	.338	51	.268	52
0	.083	27	.084	54	.086	79	.111	52	.634	53
0	.083	28	.084	55	.086	80	.084	53	.662	54
0	.083	29	.084	55	.086	81	.084	54	.662	55
0	.083	30	.084	57	.086	82	.084	55	.662	56
0	.083	31	.084	58	.086	83	.084	56	.662	57
0	.083	32	.084	59	.085	84	.084	57	.662	58
0	.083	33	.084	60	.085	85	.084	58	.662	59
0	.083	34	.084	61	.086	86	.094	59	.662	60
0	.083	35	.084	62	.086	87	.084	60	.662	61
0	.083	36	.084	63	.086	88	.084	61	.662	62
0	.083	37	.084	64	.086	89	.084	62	.662	63
0	.083	38	.089	191	.085	90	.084	63	.658	64
0	.093	39	.094	66	.095	91	0.000	194	.718	65
0	.093	40	.094	67	.095	92	.094	65	.624	66
0	.093	41	.094	68	.095	93	.094	66	.624	67
0	.093	42	.094	69	.095	94	.094	67	.624	68
0	.093	43	.094	70	.095	95	.094	68	.624	69
0	.093	44	.094	71	.095	96	.094	69	.624	70
0	.093	45	.094	72	.095	97	.094	70	.624	71
0	.093	46	.094	73	.095	98	.094	71	.624	72
0	.093	47	.094	74	.095	99	.094	72	.624	73
0	.093	48	.125	75	.095	100	.094	73	.592	74
0	.093	49	.376	76	.095	101	.251	74	.185	75
0	.093	50	.356	77	.095	102	.376	75	.080	76
0	.083	51	.338	78	.086	103	.356	76	.138	77
0	.083	52	.225	79	.086	104	.338	77	.268	78
0	.083	53	.084	80	.086	105	.111	78	.634	79
0	.083	54	.084	81	.086	106	.084	79	.662	80
0	.083	55	.084	82	.086	107	.084	80	.662	81

620-0011-55
 6/78
 LEW
 35

TRANSIENT TEMPERATURE DISTRIBUTION PROGRAM 91167

PT	A	TA	B	IB	C	TC	D	ID	E	TE
00	.083	57	.084	83	.085	08	.084	81	.662	82
00	.083	58	.084	84	.085	09	.084	82	.662	83
00	.083	59	.084	85	.085	10	.084	83	.662	84
00	.083	60	.084	86	.085	11	.084	84	.662	85
00	.083	61	.084	87	.085	12	.084	85	.662	86
00	.083	62	.084	88	.085	13	.084	86	.662	87
00	.083	63	.084	89	.085	14	.084	87	.662	88
00	.083	64	.084	90	.085	15	.084	88	.662	89
00	.083	65	.084	91	.085	16	.084	89	.662	90
00	.093	66	.094	92	.000	17	.000	90	.662	91
00	.093	67	.094	93	.000	18	.094	91	.719	92
00	.093	68	.094	94	.000	19	.094	92	.719	93
00	.093	69	.094	95	.000	20	.094	93	.719	94
00	.093	70	.094	96	.000	21	.094	94	.719	95
00	.093	71	.094	97	.000	22	.094	95	.719	96
00	.093	72	.094	98	.000	23	.094	96	.719	97
00	.093	73	.094	99	.000	24	.094	97	.719	98
00	.093	74	.125	00	.000	25	.094	98	.719	99
00	.093	75	.376	01	.000	26	.251	00	.280	00
00	.093	76	.338	02	.000	27	.376	01	.175	01
00	.093	77	.225	03	.000	28	.338	02	.354	02
00	.093	78	.084	04	.000	29	.225	03	.720	03
00	.083	80	.084	05	.000	30	.113	04	.647	04
00	.083	81	.084	06	.000	31	.084	05	.647	05
00	.083	82	.084	07	.000	32	.084	06	.647	06
00	.083	83	.084	08	.000	33	.084	07	.647	07
00	.083	84	.084	09	.000	34	.084	08	.647	08
00	.083	85	.084	10	.000	35	.084	09	.647	09
00	.083	86	.084	11	.000	36	.084	10	.647	10
00	.083	87	.084	12	.000	37	.084	11	.647	11
00	.083	88	.084	13	.000	38	.084	12	.647	12
00	.083	89	.084	14	.000	39	.084	13	.647	13
00	.083	90	.084	15	.000	40	.084	14	.647	14
00	.140	06	.089	16	.000	41	.084	15	.647	15
00	.140	07	.084	17	.42	42	.000	16	.633	16
00	.140	08	.084	18	.42	43	.000	17	.633	17
00	.140	09	.084	19	.42	44	.084	18	.549	18
00	.140	10	.084	20	.42	45	.084	19	.549	19
00	.140	11	.084	21	.42	46	.084	20	.549	20
00	.140	11	.084	22	.42	47	.084	21	.549	21
00	.140	11	.084	23	.42	48	.084	22	.549	22

LEW
 620-0011-55
 6/78
 36

PROGRAM 91167

TRANSIENT TEMPERATURE DISTRIBUTION

PT	K	A	TA	B	IB	C	IC	D	ID	E	TE
00	00	140	23	084	25	42	34	084	23	549	23
00	00	140	25	084	26	42	35	084	24	549	25
00	00	140	27	084	27	42	36	084	25	545	26
00	00	140	29	084	29	000	34	000	26	818	29
00	00	099	30	084	30	085	94	084	28	733	30
00	00	099	31	084	31	086	52	084	30	648	31
00	00	099	32	084	32	086	53	084	31	648	32
00	00	099	33	084	33	086	54	084	32	648	33
00	00	099	34	084	34	086	55	084	33	648	34
00	00	099	35	084	35	086	56	084	34	648	35
00	00	099	36	084	36	086	57	084	35	648	36
00	00	099	37	084	37	086	57	084	36	620	37
00	00	099	38	113	38	086	59	084	37	620	38
00	00	087	39	375	39	086	60	225	38	215	39
00	00	087	40	421	40	086	61	375	40	110	40
00	00	097	41	281	41	086	63	421	41	094	41
00	00	097	42	105	42	086	65	140	42	550	42
00	00	097	43	105	43	086	65	105	43	545	43
00	00	097	44	105	44	086	66	105	44	545	44
00	00	097	45	105	45	086	67	105	45	545	45
00	00	097	46	105	46	086	68	105	46	545	46
00	00	097	47	105	47	086	68	105	47	545	47
00	00	097	48	105	48	086	69	105	48	545	48
00	00	097	49	105	49	086	70	105	49	545	49
00	00	097	50	105	50	086	71	105	50	545	50
00	00	083	51	084	51	086	94	086	49	874	51
00	00	083	52	084	52	086	94	084	51	674	52
00	00	083	53	084	53	086	72	084	52	674	53
00	00	083	54	084	54	086	73	084	53	674	54
00	00	083	55	084	55	086	74	084	54	674	55
00	00	083	56	084	56	086	75	084	55	674	56
00	00	083	57	084	57	086	76	084	56	674	57
00	00	083	58	084	58	086	77	084	57	674	58
00	00	083	59	084	59	086	78	084	58	674	59
00	00	083	60	113	60	086	79	084	59	645	60
00	00	083	61	375	61	086	80	084	60	109	61
00	00	104	62	261	62	086	81	375	61	102	62
00	00	104	63	261	63	086	82	421	62	102	63

LEW
620-0011-5
6/78
37

PROGRAM 91167

TRANSIENT TEMPERATURE DISTRIBUTION

PT	A	TA	B	TS	C	TC	D	ID	E	TE
00	104	43	105	66	092	83	140	64	558	64
00	04	45	105	67	092	85	05	65	593	65
00	04	46	105	68	092	87	05	66	593	66
00	04	47	105	69	092	89	05	67	593	68
00	04	48	105	70	092	89	05	68	593	69
00	04	49	105	71	092	90	05	69	593	70
00	04	50	000	72	092	94	000	70	699	71
00	05	51	084	73	000	94	084	72	861	72
00	05	52	084	74	000	94	084	73	777	73
00	05	53	084	75	000	94	084	74	777	74
00	05	54	084	76	000	94	084	75	777	75
00	05	55	084	77	000	94	084	76	777	76
00	05	56	084	78	000	94	084	77	777	77
00	05	57	084	79	000	94	084	78	768	78
00	05	58	113	80	000	94	084	79	303	79
00	05	59	375	81	000	94	338	80	233	80
00	06	60	421	82	000	94	377	81	136	81
00	06	61	281	83	000	94	421	82	230	82
00	06	62	105	84	000	94	140	83	686	83
00	06	63	105	85	000	94	105	84	721	84
00	06	64	105	86	000	94	105	85	721	85
00	06	65	105	87	000	94	105	86	721	86
00	06	66	105	88	000	94	105	87	721	87
00	06	67	105	89	000	94	105	88	721	88
00	06	68	105	90	000	94	105	89	721	89
00	06	69	000	94	000	94	105	89	821	89
00	06	70	000	94	000	94	105	89	821	90
00	06	71	000	94	000	94	105	89	821	90

DELTA THETA = .683E-02HRS/ITER BLOCK 141

LEW
 620-0011-55
 6/78
 38

CRITICAL TIMES FOR ANALYSIS

Based on the temperature distributions output by Program 91167, the critical times for analysis were chosen.

The choice of times is a judgement based on experience. The factors considered are: 1) maximum radial gradients in the model, 2) maximum axial gradients, and 3) maximum tube-to-shell temperature difference (results in highest tube loads).

The following pages show 91167 temperature distribution which will be analyzed (those in brackets).

In reference to time scale on transient sketch (Page 9), the critical times are:

305.0 minutes (Iteration 26)
312.0 minutes (Iteration 39)
317.0 minutes (Iteration 45)
318.75 minutes (Iteration 49)
372.0 minutes (Iteration 72)

LEW
620-0011-55
6/78

ITER	TIME	TEMPERATURE DISTRIBUTION										
		TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	TEMPERATURE	
48	.30500	565	568	568	568	568	568	567	565	561	561	561
48	.30500	572	574	572	572	572	572	574	574	573	573	573
48	.30500	571	571	569	571	571	571	574	574	574	574	574
48	.30500	574	574	574	574	574	574	574	573	573	573	573
48	.30500	572	572	570	570	570	570	566	565	563	563	563
48	.30500	547	571	466	398	571	572	572	572	572	572	572
48	.30500	564	553	562	560	571	570	569	564	569	566	566
48	.30500	570	570	570	570	570	570	570	570	569	569	569
48	.30500	569	568	567	567	565	563	562	560	559	559	559
48	.30500	554	569	533	513	462	398	561	560	559	559	559
48	.30500	555	553	548	539	518	475	417	560	559	559	559
48	.30500	556	554	551	568	541	525	495	445	411	396	396
48	.30500	389	384	380	378	377	376	376	376	376	376	376
48	.30500	556	555	552	550	547	543	534	517	490	467	467
48	.30500	456	455	439	433	430	428	428	427	427	427	427
48	.30500	427	451	549	547	546	539	530	518	507	500	500
48	.30500	493	489	484	481	480	479	479	479	478	478	478
48	.30500	468	546	546	546	546	546	546	546	546	546	546

49	.31250	561	565	565	565	564	564	563	562	567	547	547
49	.31250	523	569	569	569	569	569	569	569	569	569	569
49	.31250	569	570	568	568	565	565	569	573	572	571	571
49	.31250	571	574	574	574	574	574	573	573	574	574	574
49	.31250	572	571	571	570	569	568	566	565	563	558	558
49	.31250	466	467	467	467	467	467	467	467	467	467	467
49	.31250	572	571	571	570	570	570	570	569	568	566	566
49	.31250	565	562	562	560	557	552	540	512	460	416	416
49	.31250	570	570	570	570	570	570	570	570	569	569	569
49	.31250	568	568	567	567	566	563	562	560	559	557	557
49	.31250	569	569	567	567	566	563	562	560	559	557	557
49	.31250	552	537	537	538	463	476	435	560	559	557	557
49	.31250	555	551	551	547	540	524	493	468	429	411	411
49	.31250	555	504	404	402	401	401	401	400	400	400	400
49	.31250	552	552	550	550	547	542	533	515	488	457	457
49	.31250	456	460	434	434	430	429	428	428	428	428	428
49	.31250	551	549	547	547	544	538	529	516	505	497	497
49	.31250	486	481	477	477	476	475	475	475	475	475	475
49	.31250	540	540	540	540	540	540	540	540	540	540	540

620-001-5
 43
 6/78
 LEW

ITER	DT	TEMPERATURE DISTRIBUTION										TIME
		TEMPERATURE										
72	1	307	315	318	319	319	318	317	315	312	308	6.20000
72	2	303	295	334	334	334	335	335	335	335	335	6.20000
72	3	336	338	339	341	343	348	358	367	371	373	6.20000
72	4	373	372	369	364	357	347	333	315	379	379	6.20000
72	5	379	379	379	380	380	381	382	385	388	390	6.20000
72	6	394	398	405	413	418	421	420	418	413	406	6.20000
72	7	395	380	359	331	410	410	410	410	410	411	6.20000
72	8	411	412	414	417	421	424	428	432	439	449	6.20000
72	9	455	457	457	454	448	439	425	406	380	355	6.20000
72	10	425	425	425	426	426	426	427	428	430	434	6.20000
72	11	438	441	445	450	459	475	482	484	484	480	6.20000
72	12	473	463	449	428	399	359	495	498	500	499	6.20000
72	13	495	489	479	464	444	415	376	506	508	511	6.20000
72	14	510	507	500	490	476	457	433	401	376	365	6.20000
72	15	358	353	348	344	341	339	338	337	337	336	6.20000
72	16	518	517	514	508	499	486	470	449	425	407	6.20000
72	17	397	389	383	376	370	366	363	362	361	360	6.20000
72	18	360	318	313	305	493	478	460	440	425	416	6.20000
72	19	408	402	394	387	383	380	377	376	375	375	6.20000
72	20	280	280	280								
74	1	301	307	309	316	310	310	308	307	304	300	5.40000
74	2	296	291	318	318	318	318	318	319	319	320	6.40000
74	3	320	322	324	325	328	331	339	347	351	353	6.40000
74	4	354	352	349	345	338	329	318	304	350	350	6.40000
74	5	350	351	351	351	352	353	355	358	361	364	6.40000
74	6	367	371	378	387	392	395	395	393	389	382	6.40000
74	7	371	357	339	318	374	374	375	375	375	376	6.40000
74	8	377	378	380	384	388	392	396	401	409	420	6.40000
74	9	427	430	431	428	422	413	400	382	359	331	6.40000
74	10	387	387	387	387	388	388	389	391	394	398	6.40000
74	11	403	406	411	417	427	446	454	454	458	455	6.40000
74	12	448	438	424	404	378	344	467	471	475	475	6.40000
74	13	472	465	455	440	420	394	359	479	482	487	6.40000
74	14	488	485	479	468	454	435	410	381	358	348	6.40000
74	15	341	337	332	327	324	322	320	319	319	319	6.40000
74	16	496	496	494	489	479	465	448	426	403	385	6.40000
74	17	375	367	361	354	347	343	340	338	336	336	6.40000
74	18	335	499	495	486	473	457	437	417	401	392	6.40000
74	19	383	377	369	361	356	352	350	348	348	347	6.40000
74	20	282	282	282								

44
 6/78
 620-0011-55
 LEW


TEMPERATURE INTERPOLATION

In order to determine the Free-body Thermal Stresses and motions of the interaction elements (Reference 2, Page B-2-2), B&W Computer Program 91206 will be used. However, in order to change the 91167 output format to the input format of 91206, this intermediate step of temperature interpolation must be performed by B&W Program 91032.

Contained on the following pages are the 91167 Grid (Initial Grid) and the 91206 Grid (Final Grid) for each interaction element. Also, there is a sample 91032 output for Element 5, since it is the most geometrically complex, to show its format and application.

LEW
620-0011-55
6/78


ELEMENT #1 - INITIAL GRID



BABCOCK & WILCOX
 DEPARTMENT N-V-COMP ENGG. DATE 6/79 BY LEW
ELEMENT #1 CHECKED DATE BY
INITIAL GRID JOB NO. 630-0011-55

REVISION
 SHEET 4 OF

ELEMENT #1 - FINAL GRID




BABCOCK & WILCOX
 DEPARTMENT *MT. V - COMP. ENGRG.* DATE *6/78* BY *LEW*
ELEMENT #1
FINAL GRID

CHECKED DATE _____ BY _____
 JOB NO. *620-0011-55*


REVISION _____
 SHEET *47* OF _____

ELEMENT # 2 - INITIAL GRID



BABCOCK & WILCOX		REVISION	
DEPARTMENT <u>Mt. V - COMP. ENGRG.</u>	DATE <u>6/78</u>	BY <u>LEW</u>	
<u>ELEMENT # 2</u>	CHECKED DATE	BY	
<u>INITIAL GRID</u>	JOB NO. <u>620-0011-55</u>	SHEET <u>49</u>	OF

ELEMENT #2 - FINAL GRID



BABCOCK & WILCOX

DEPARTMENT *M-V-Comp. ENGRG.* DATE *6/78* BY *LEW*

ELEMENT #2

CHECKED DATE BY


FINAL GRID

JOB NO. *620-0011-55*

REVISION


SHEET *49* OF

ELEMENT #3 - INITIAL GRID



BABCOCK & WILCOX DEPARTMENT <i>NIT-V-Comp. ENGRG.</i> DATE <i>6/78</i> BY <i>LEW</i>	REVISION <hr/>
ELEMENT #3 INITIAL GRID	CHECKED DATE _____ BY _____ JOB NO. <i>620-0011-55</i>
SHEET <i>50</i> OF _____	


ELEMENT #3 - FINAL GRID



BABCOCK & WILCOX	REVISION
DEPARTMENT <i>MT. V - COMP. ENGRG.</i> DATE <i>6/78</i> BY <i>LEW</i>	_____
<i>ELEMENT #3</i>	CHECKED DATE _____ BY _____
<i>FINAL GRID</i>	JOB NO. <i>620-0011-55</i>

SHEET <i>51</i> OF _____

ELEMENT # 4 - INITIAL GRID



BABCOCK & WILCOX

DEPARTMENT NAV - COMP ENGRS DATE 6/78 BY LEW

ELEMENT # 4

CHECKED DATE BY


INITIAL GRID

JOB NO. 630-0011-55

REVISION

SHEET 52 OF

ELEMENT # 4 - FINAL GRID



BABCOCK & WILCOX

DEPARTMENT HT-V-COMP ENRG. DATE 6/78 BY LEW

ELEMENT # 4

CHECKED DATE BY


FINAL GRID

JOB NO. 620-0011-55

REVISION


SHEET 53 OF

ELEMENT #5 - INITIAL GRID



BABCOCK & WILCOX		REVISION	
DEPARTMENT <i>M/V - CIVIL ENG'G</i>	DATE <i>6/78</i>	BY <i>LEW</i>	
ELEMENT #1		CHECKED DATE	BY
INITIAL GRID		JOB NO. <i>620-0011-55</i>	SHEET <i>54</i> OF

ELEMENT #5 - FINAL GRID



BABCOCK & WILCOX

DEPARTMENT *MT. V - COND. ENGRG.*

DATE *6/78*

BY *LEW*

ELEMENT #5

CHECKED DATE

BY

FINAL GRID

JOB NO. *620-0011-55*

REVISION

SHEET *55* OF

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEM 91012 REV 3 4-15-76 04/24/78 10-43-45 PAGE 06
 FULL CERTIFICATION FULL CERTIFICATION

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 04/24/78

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEM ELEMENT 5.

CALCULATION CODE 7

PRINTED OUTPUT PLUS PUNCHED TEMPERATURE CARDS

BASE TEMPERATURE 70.00

NUMBER OF INPUT TEMPERATURES 91167 GRID - 193

INPUT PER EDGE FOR INITIAL GRID

EDGE NO.	TEMP. BLOCK HEIGHT	DIST FROM ZERO LINE TO EDGE	ZERO LINE TO BLOCK BOUNDARY	RADIUS	INSIDE SURFACE ADJ. BLOCK FILM COEFF.	RADIUS	OUTSIDE SURFACE ADJ. BLOCK FILM COEFF.	MATERIAL TYPE
1	1.0000	5.0000	1.0000	59.5313	193	67.5313	0.0000	SA-508 STEEL
2	1.0000	1.5000	2.0000	59.5313	193	67.5313	0.0000	SA-508 STEEL
3	2.0000	3.0000	4.0000	57.7838	192	70.9375	0.0000	SA-508 STEEL
4	2.0000	5.0000	6.0000	57.7838	192	70.9375	0.0000	SA-508 STEEL
5	2.0000	7.0000	8.0000	57.7838	192	72.9375	0.0000	SA-508 STEEL
6	2.0000	9.0000	10.0000	57.7838	192	72.9375	0.0000	SA-508 STEEL
7	2.0000	11.0000	12.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
8	2.0000	13.0000	14.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
9	2.0000	15.0000	16.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
10	2.0000	17.0000	18.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
11	2.0000	19.0000	20.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
12	2.0000	21.0000	22.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
13	2.0000	23.0000	24.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
14	2.0000	25.0000	26.0000	57.7838	192	75.5625	0.0000	SA-508 STEEL
15	1.0000	26.5000	27.0000	68.9375	191	75.5625	0.0000	SA-508 STEEL
16	1.0000	27.5000	28.0000	68.9375	191	75.5625	0.0000	SA-508 STEEL

56
 6/78
 620-0011-55
 LEW

SMUD RAPID COOLDOWN---DTSG LOWER TUBESHEET ANALYSIS---BY LEW
 **** FULL CERTIFICATION **** FULL CERTIFICATION

91032 REV 3 6-15-76 04/24/78 10.43.45 PAGE 67
 **** FULL CERTIFICATION ****

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

04/24/78

SMUD RAPID COOLDOWN---DTSG LOWER TUBESHEET ANALYSIS---BY LEW

ELEMENT S.

DIMENSION PER COLUMN OF THE INITIAL GRID

COLUMN NO.	INSIDE RADIUS	BLOCK WIDTH	91167 TEMPERATURE GRID NODAL RADIUS	OUTSIDE RADIUS	LOW BLOCK NO.	HIGH BLOCK NO.
1	57.7838	1.7474	58.6575	59.5312	1	12
2	59.5312	2.0002	60.5313	61.5314	25	38
3	61.5314	1.9998	62.5313	63.5312	51	64
4	63.5312	2.0002	64.5313	65.5314	77	90
5	65.5314	1.9998	66.5313	67.5312	103	116
6	67.5312	1.4064	69.2344	68.9376	117	127
7	68.9376	1.9998	69.9375	70.9374	128	140
8	70.9374	2.0002	71.9375	72.9376	151	161
9	72.9376	2.6248	74.2700	75.5624	172	180

LEW
 620-0011-55
 6/78
 57

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEW 91032 REV 3 4-15-76 04/24/78 10-43-45 PAGE 68

*** FULL CERTIFICATION *** FULL CERTIFICATION ***

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 04/24/78

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEW ELEMENT 5.

INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS	INITIAL INTERNAL RADIUS
58.6575	60.5313	60.5313	60.5313
62.6313	64.5313	64.5313	64.5313
66.6375	68.2344	68.2344	68.2344
74.2500	71.9375	71.9375	71.9375

INITIAL INTERNAL RADIUS

INITIAL INTERNAL RADIUS

DISTANCE FROM ZERO LINE TO CLOSEST SURFACE

DISTANCE FROM ZERO LINE TO CLOSEST SURFACE

DISTANCE FROM ZERO LINE TO CLOSEST SURFACE

DISTANCE FROM ZERO LINE TO CLOSEST SURFACE

LEW
620-0011-55
6/78
58

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

04/24/78

SMUD RAPID COOLDOWN---OTS& LOWER TUBESHEET ANALYSIS---BY LEW

ELEMENT 5.

FINAL GRID		INITIAL GRID		FINAL GRID				
EDGE NUMBER	DISTANCE FROM ZERO LINE	INSIDE RADIUS	OUTSIDE RADIUS	INSIDE RADIUS	RB(2)	RB(3)	RB(4)	OUTSIDE RADIUS
1	2.0000	57.7838	67.5313	57.7838	60.2207	62.6576	65.0944	67.5313
2	3.0000	57.7838	67.5313	57.7838	60.2207	62.6576	65.0944	67.5313
3	4.0000	57.7838	67.5313	57.7838	60.2207	62.6576	65.0944	67.5313
4	5.0000	57.7838	67.5313	57.7838	60.2207	62.6576	65.0944	67.5313
5	6.0000	57.7838	70.9375	57.7838	61.0722	64.3607	67.6491	70.9375
6	7.0000	57.7838	70.9375	57.7838	61.0722	64.3607	67.6491	70.9375
7	8.0000	57.7838	70.9375	57.7838	61.0722	64.3607	67.6491	70.9375
8	9.0000	57.7838	72.9375	57.7838	61.5722	65.3607	69.1491	72.9375
9	10.0000	57.7838	72.9375	57.7838	61.5722	65.3607	69.1491	72.9375
10	11.0000	57.7838	72.9375	57.7838	61.5722	65.3607	69.1491	72.9375
11	12.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
12	13.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
13	14.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
14	15.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
15	16.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
16	17.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
17	18.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
18	19.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
19	20.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
20	21.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
21	22.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
22	23.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
23	24.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
24	25.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625
25	26.0000	57.7838	75.5625	57.7838	62.2285	66.6732	71.1178	75.5625

59
 6/78
 55-1100-02
 LEW

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEW
***** FULL CERTIFICATION *****

91032 REV 3 4-15-76 04/24/78 10.43.45 PAGE 78
***** FULL CERTIFICATION *****

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3

04/24/78

SMUD RAPID COOLDOWN---OTSG LOWER TUBESHEET ANALYSIS---BY LEW

ELEMENT 5.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 72

SEGN NO.	OUTSIDE	INSIDE	CARD NO.	*IDENTIFIES PHANTOM SEGMENTS
1	392 371 333	271 215	401.	
2	395 373 335	275 216	402.	
3	399 375 338	279 216	403.	
4	403 379 340	282 217	404.	
5	408 381 342	285 217	405.	
6	443 413 371	306 217	406.*	
7	442 418 376	310 218	407.	
8	443 421 390	313 219	408.	
9	444 423 382	315 219	409.	
10	445 425 384	316 219	410.	
11	452 435 399	328 219	411.*	
12	452 437 399	329 219	412.	
13	451 436 400	329 219	413.	
14	451 435 399	329 219	414.	
15	449 434 398	328 219	415.	
16	451 444 414	343 219	416.*	

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

620-0011-55
6/78
LEW
60

TEMPERATURE INTERPOLATION GRID CHANGE PROGRAM 91032 - REVISION 3 04/24/78

SMUD RAPID COOLDOWN---DTSG LOWER TUBESHEET ANALYSIS---BY LEW ELEMENT 5.

TEMPERATURE OF NODE PER EDGE OF THE FINAL GRID FOR ITERATION 72

SEGN NO.	CARD NO.	*IDENTIFIES PHANTOM SEGMENTS					
17	450	442	412	342	219	417.	
18	448	439	403	340	219	418.	
19	446	435	405	337	219	419.	
20	442	431	400	334	218	420.	
21	438	425	394	330	218	421.	
22	433	420	389	326	218	422.	
23	427	412	380	320	217	423.	
24	420	404	371	313	217	424.	
25	413	395	359	306	217	425.	
26	405	385	345	296	216	426.	
27	396	373	330	285	215	4	
28	388	360	312	273	215	428.	
29	383	353	301	266	214	429.	
30	379	345	290	259	214	430.	
31	374	339	279	251	213	431.	
32	370	332	265	243	212	432.	

***** NOTE THESE TEMPERATURES ARE T(ACTUAL) MINUS T(BASE) *****

19
 8/19
 55-1100-029
 LEW

FREEBODY THERMAL MOTIONS & STRESSES


The following pages contain a sample output from Program 91206 to show its format and application, a tabulation of Primary Plus Secondary Freebody Thermal Stresses, Peak Free-body Thermal Stresses, Free-body Thermal Motions, Motion Adjustments for Element #5 (Tubesheet Ring), and Program 91206 models.

ELEMENT # 1 - PROG. 91206 MODEL

Z

O' END (72.25, 16.0)

6.625" →



(72.25, 0.0)

N' END

BABCOCK & WILCOX

DEPARTMENT 11-V-CMP ENGRS DATE 6/78

BY LEW

REVISION

ELEMENT # 1

CHECKED DATE


BY

91206 MODEL

JOB NO. 620-0011-55

SHEET 63 OF


ELEMENT #2 - PROGRAM 91206 MODEL



BABCOCK & WILCOX
 DEPARTMENT M-V-Comp. Engrg. DATE 6/78 BY EW
ELEMENT #2 CHECKED DATE _____ BY _____
91206 MODEL JOB NO. 620-001-55

REVISION _____
 SHEET 64 OF _____

ELEMENT # 3 - 91206 MODEL



BABCOCK & WILCOX

DEPARTMENT MT. V - CONIP ENGRG. DATE 6/78 BY LEW

ELEMENT # 3

CHECKED DATE BY

91206 MODEL

JOB NO. 620-001-55


REVISION

SHEET 65 OF

ELEMENT # 4 - PROG. 91206 MODEL

Z

O' END (63.53125, 2.5)



N' END (63.53125, 0.0)

BABCOCK & WILCOX

DEPARTMENT MT. V. COND. ENGRS. DATE 6/78 BY LEW

ELEMENT # 4

CHECKED DATE BY

91206 MODEL


JOB NO. 620-0011-55

REVISION

SHEET 66 OF

ELEMENT #5 - PROC. 91206 MODEL

Z



BABCOCK & WILCOX

DEPARTMENT MEV-COMP. ENGRS. DATE 6/78

BY LEW

REVISION

ELEMENT #5

CHECKED DATE

BY

91206 MODEL

JOB NO. 620-0011-55

SHEET 67 OF

INPUT DATA -----
 DATE 04/26/78
 ELEMENT 5. ITERATION 72 PAGE 1 DATE 04/26/78

TOTAL NO. OF SEGMENTS = 31

BOUNDARY CONDITIONS AT THE TOP (U) END

- 1. A RADIAL SHEAR OF 0.00000 POUNDS
- 2. A MOMENT OF 0.00000 INCH-LBS.

BOUNDARY CONDITIONS AT THE BOTTOM (V) END

- 1. AN AXIAL FORCE OF 0.00000 POUNDS
- 2. A RADIAL SHEAR OF 0.00000 POUNDS
- 3. A MOMENT OF 0.00000 INCH-LBS.

* NOTE * A SEGMENTAL GROUP MAY CONSIST OF FROM ONE TO THE TOTAL NO. OF SEGMENTS.
 SEGMENT ONE IS CONSIDERED AT THE TOP OF THE GEOMETRY.
 ALL LOADS ABOVE, ARE ON A TOTAL LOAD BASIS.

LEW
 620-0011-55
 6/78
 68

ELEMENT 5. ITERATION 72 PAGE 2 DATE 04/26/78

MID-SURFACE GEOMETRY

AT TOP BOUNDARY, MEAN RADIUS = 62.6575 Z COORDINATE = 24.0000

SEGMENTAL GEOMETRY DATA BY GROUPS

SEG. NO.	MEAN RADIUS	Z COORD.	TO CENTER	RADIUS	Z COORD.	CURVATURE IDENTIFIER
4.0	52.658	22.000	0.000	0.000	0.000	0.0
5.0	54.361	22.000	0.000	0.000	0.000	0.0
9.0	54.361	18.000	0.000	0.000	0.000	0.0
10.0	55.361	18.000	0.000	0.000	0.000	0.0
14.0	55.361	14.000	0.000	0.000	0.000	0.0
15.0	56.673	14.000	0.000	0.000	0.000	0.0
31.0	56.673	0.000	0.000	0.000	0.000	0.0

NOTE - CURVATURE IDENTIFIER *1= POSITIVE CURVATURE
 0= NO CURVATURE
 -1= NEGATIVE CURVATURE

LEW
 620-0011-55
 6/78
 69

SEGMENTAL GEOMETRY BY SEGMENTS (K= SEGMENT NO.)

MEAN RADIUS										
K	H(K-1)	R(K)	R(K+1)	R(K+2)	R(K+3)	H(K+4)	H(K+5)	H(K+6)	H(K+7)	H(K+8)
1	62.56	62.66	62.66	62.66	62.66	64.36	64.36	64.36	64.36	64.36
2	65.36	65.36	65.36	65.36	65.36	66.67	66.67	66.67	66.67	66.67
3	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Z COORDINATE										
K	Z(K-1)	Z(K)	Z(K+1)	Z(K+2)	Z(K+3)	Z(K+4)	Z(K+5)	Z(K+6)	Z(K+7)	Z(K+8)
1	24.00	23.50	23.00	22.50	22.00	22.00	21.00	20.00	19.00	18.00
2	18.00	17.00	16.00	15.00	14.00	14.00	13.13	12.25	11.38	10.50
3	9.53	8.75	7.88	7.00	6.13	5.25	4.38	3.50	2.63	1.75

LEW
 6/78
 620-0011-55
 70

 SEGMENT THICKNESS DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	TOP THICK. OF TOP SEG.	BOTTOM THICK. OF BOTTOM SEG.
1.00	4.00	9.75	9.75
5.00	5.00	0.00	0.00
6.00	9.00	13.15	13.15
10.00	10.00	0.00	0.00
11.00	14.00	15.15	15.15
15.00	15.00	0.00	0.00
16.00	31.00	17.78	17.78

SEGMENTAL THICKNESS BY SEGMENTS

THICKNESS AT TOP OF SEGMENT (HA)										
K	HA(K)	HA(K+1)	HA(K+2)	HA(K+3)	HA(K+4)	HA(K+5)	HA(K+6)	HA(K+7)	HA(K+8)	HA(K+9)
1	9.75	9.75	9.75	9.75	0.00	13.15	13.15	13.15	13.15	0.00
11	15.15	15.15	15.15	15.15	0.00	17.78	17.78	17.78	17.78	17.78
31	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78

THICKNESS AT BOTTOM OF SEGMENT (HB)										
K	HB(K)	HB(K+1)	HB(K+2)	HB(K+3)	HB(K+4)	HB(K+5)	HB(K+6)	HB(K+7)	HB(K+8)	HB(K+9)
1	9.75	9.75	9.75	9.75	0.00	13.15	13.15	13.15	13.15	0.00
11	15.15	15.15	15.15	15.15	0.00	17.78	17.78	17.78	17.78	17.78
31	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78	17.78

620-0011-55
 6/78
 71
 LEW

ELEMENT 5. ITERATION 72 PAGE 5 DATE 04/26/78

MATERIAL PROPERTIES BY SEGMENTS

SEG. NO.	ALPHA II	MODULUS OF TENSION	MODULUS OF SHEAR	POISSON'S RATIO
1	7304E-05	2858E+08	1099E+08	3000E+00
2	7306E-05	2856E+08	0999E+08	3000E+00
3	7309E-05	2855E+08	0998E+08	3000E+00
4	7310E-05	2854E+08	0958E+08	3000E+00
5	7324E-05	2846E+08	091E+08	3000E+00
6	7339E-05	2837E+08	0870E+08	3000E+00
7	7342E-05	2834E+08	083E+08	3000E+00
8	7345E-05	2832E+08	089E+08	3000E+00
9	7347E-05	2827E+08	087E+08	3000E+00
10	7349E-05	2827E+08	085E+08	3000E+00
11	7351E-05	2822E+08	085E+08	3000E+00
12	7351E-05	2822E+08	085E+08	3000E+00
13	7351E-05	2823E+08	086E+08	3000E+00
14	7351E-05	2819E+08	084E+08	3000E+00
15	7371E-05	2815E+08	083E+08	3000E+00
16	7371E-05	2816E+08	083E+08	3000E+00
17	7371E-05	2816E+08	083E+08	3000E+00
18	7371E-05	2816E+08	083E+08	3000E+00
19	7371E-05	2816E+08	083E+08	3000E+00
20	7371E-05	2816E+08	083E+08	3000E+00
21	7371E-05	2816E+08	083E+08	3000E+00
22	7371E-05	2816E+08	083E+08	3000E+00
23	7371E-05	2816E+08	083E+08	3000E+00
24	7371E-05	2816E+08	083E+08	3000E+00
25	7371E-05	2816E+08	083E+08	3000E+00
26	7371E-05	2816E+08	083E+08	3000E+00
27	7371E-05	2816E+08	083E+08	3000E+00
28	7371E-05	2816E+08	083E+08	3000E+00
29	7371E-05	2816E+08	083E+08	3000E+00
30	7371E-05	2816E+08	083E+08	3000E+00
31	7371E-05	2816E+08	083E+08	3000E+00

LEW
 620-0011-55
 6/78
 72

 ELEMENT 5. ITERATION 72 PAGE 6 DATE 04/26/78

PRESSURE INPUT DATA BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INTERNAL PRESSURE	EXTERNAL PRESSURE
1.0	31.0	0.0	0.0

MECHANICAL LOADINGS ON SEGMENTAL GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	RADIAL FORCE	MOMENT	AXIAL FORCE
1.0	31.0	0.	0.	0.

STRESS CONCENTRATION FACTORS BY GROUPS

TOP SEG. NO.	BOTTOM SEG. NO.	INSIDE TENSION	INSIDE BENDING	OUTSIDE TENSION	OUTSIDE BENDING
1	31	1.00	1.00	1.00	1.00

LEW
 620-0011-55
 6/78
 73

ELEMENT 5. ITERATION 72 PAGE 7 DATE 04/26/78

TEMPERATURES PER SEGMENT USED IN PRIMARY & SECONDARY ANALYSIS

SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T5	SEGMENT	OUTSIDE T1	T2	T3	T4	INSIDE T5
1	417.	370.	323.	276.	229.	16	494.	440.	385.	332.	278.
2	420.	373.	326.	279.	232.	17	490.	437.	383.	330.	277.
3	424.	376.	329.	281.	234.	18	486.	433.	380.	327.	275.
4	427.	379.	331.	283.	235.	19	481.	429.	377.	324.	272.
5	467.	412.	357.	305.	247.	20	475.	424.	372.	321.	269.
6	470.	415.	360.	308.	250.	21	469.	418.	368.	312.	267.
7	473.	418.	363.	310.	253.	22	460.	410.	361.	306.	263.
8	477.	420.	365.	311.	255.	23	450.	402.	354.	299.	258.
9	489.	422.	366.	311.	255.	24	440.	395.	346.	291.	247.
10	490.	433.	377.	321.	265.	25	428.	382.	336.	281.	236.
11	490.	434.	378.	322.	266.	26	415.	370.	325.	270.	227.
12	489.	433.	377.	322.	265.	27	400.	357.	313.	263.	221.
13	488.	433.	377.	322.	265.	28	392.	349.	306.	257.	215.
14	487.	431.	376.	321.	268.	29	384.	342.	299.	250.	208.
15	496.	441.	387.	333.	279.	30	375.	327.	285.	243.	201.
						31	369.				

LEW
 620-0011-55
 6/78
 74

ELEMENT 5. ITERATION 72 PAGE 8 DATE 04/26/78
 PRIMARY * SECONDARY BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RAJIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RAJIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)
0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RAJIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)	SUM
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.	0.	0.	0.

620-0011-55 LEW

6/78

75

ELEMENT 5. ITERATION 72 PAGE 9 DATE 04/26/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 910A0
 (THIS MATRIX ONLY IS ON A PER RADIAY BASIS)

	M(I)	Q(I)	M(N)	Q(N)
ROTATION(I)	:16544E-09	:179330E-08	-.133994E-09	-.148085E-08
DEFLECTION(I)	:179330E-08	:291417E-07	-.172376E-08	-.131176E-07
ROTATION(N)	-.133994E-09	-.172376E-08	:47422E-09	:151941E-08
DEFLECTION(N)	-.148085E-08	-.131176E-07	:51941E-08	:229760E-07

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

LEW
 620-0011-55
 6/78
 76

ELEMENT S. ITERATION 72 PAGE 10 DATE 04/26/78

PRIMARY * SECONDARY FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
 RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	0.	0.	TOP	-.1701E+00	-.4359E-03	0.
1	HOT.	.3392E+06	-.8516E+05	0.	ROT.	.1703E+00	.3424E-03	.1113E-02
1	HOT.	.6593E+06	-.3353E+06	0.	ROT.	.1704E+00	.2492E-03	.2240E-02
1	HOT.	.9627E+06	-.7413E+06	0.	ROT.	.1705E+00	.1550E-03	.3381E-02
1	HOT.	.1250E+07	-.1293E+07	0.	ROT.	.1706E+00	.6001E-04	.4534E-02
1	HOT.	.1750E+07	-.1293E+07	0.	ROT.	.1749E+00	.6001E-04	.4432E-02
1	HOT.	.2517E+07	-.2663E+07	0.	ROT.	.1749E+00	-.1014E-03	.7020E-02
1	HOT.	.721E+07	-.4308E+07	0.	ROT.	.1749E+00	-.2632E-03	.9641E-02
1	HOT.	.873E+07	-.6102E+07	0.	ROT.	.1744E+00	-.4254E-03	.1229E-01
1	HOT.	.993E+07	-.8041E+07	0.	ROT.	.1740E+00	-.5898E-03	.1495E-01
1	HOT.	.993E+07	-.8041E+07	0.	ROT.	.1767E+00	-.5898E-03	.1554E-01
1	HOT.	.453E+07	-.993E+07	0.	ROT.	.1751E+00	-.7332E-03	.1812E-01
1	HOT.	.645E+07	-.1173E+08	0.	ROT.	.1753E+00	-.8759E-03	.2111E-01
1	HOT.	.449E+07	-.1332E+08	0.	ROT.	.1744E+00	-.1020E-02	.2340E-01
1	HOT.	.1257E+07	-.1470E+08	0.	ROT.	.1733E+00	-.1161E-02	.2668E-01
1	HOT.	.1267E+07	-.1470E+08	0.	ROT.	.1770E+00	-.1161E-02	.2821E-01
1	HOT.	.7961E+06	-.561E+08	0.	ROT.	.1760E+00	-.1264E-02	.3074E-01
1	HOT.	.3212E+06	-.610E+08	0.	ROT.	.1749E+00	-.1368E-02	.3325E-01
1	HOT.	-.1450E+06	-.617E+08	0.	ROT.	.1736E+00	-.1469E-02	.3575E-01
1	HOT.	-.5952E+06	-.1545E+08	0.	ROT.	.1722E+00	-.1564E-02	.3822E-01
1	HOT.	-.1019E+07	-.1513E+08	0.	ROT.	.1709E+00	-.1664E-02	.4066E-01
1	HOT.	-.1407E+07	-.1409E+08	0.	ROT.	.1691E+00	-.1765E-02	.4307E-01
1	HOT.	-.1741E+07	-.1269E+08	0.	ROT.	.1677E+00	-.1859E-02	.4543E-01
1	HOT.	-.1998E+07	-.1105E+08	0.	ROT.	.1660E+00	-.1952E-02	.4775E-01
1	HOT.	-.2168E+07	-.9224E+07	0.	ROT.	.1642E+00	-.2042E-02	.5000E-01
1	HOT.	-.2225E+07	-.7294E+07	0.	ROT.	.1624E+00	-.2130E-02	.5218E-01
1	HOT.	-.2139E+07	-.5373E+07	0.	ROT.	.1604E+00	-.2215E-02	.5428E-01
1	HOT.	-.1985E+07	-.3601E+07	0.	ROT.	.1584E+00	-.2299E-02	.5629E-01
1	HOT.	-.1510E+07	-.2112E+07	0.	ROT.	.1564E+00	-.2380E-02	.5822E-01
1	HOT.	-.1073E+07	-.4773E+06	0.	ROT.	.1542E+00	-.2461E-02	.6007E-01
1	HOT.	-.5711E+06	-.2540E+06	0.	ROT.	.1520E+00	-.2541E-02	.6192E-01
1	ROT.	0.	0.	0.	ROT.	.1498E+00	-.2621E-02	.6368E-01

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

LEW 620-0011-55 6/78 77

PRIMARY + SECONDARY STRESSES

SEG. NO.	OUTSIDE		MIDPLANE		LUNG		INSIDE		RAD.
	LONG	H HOOP	LONG	H HOOP	RAD.	LUNG	H HOOP	RAD.	
1	285.9	-91.49	346.8	10881.0	1630.1	-87.6	32060.0	231.9	
2	315.5	-97.96	343.0	10261.0	1623.1	-119.1	31473.2	231.6	
3	370.0	-104.23	341.6	9711.9	1626.5	-259.7	31608.7	232.4	
4	442.0	-109.94	340.5	9221.5	1631.1	-274.3	30597.5	340.7	
5	497.0	-119.97	491.5	2220.2	2355.0	-274.3	26952.5	338.7	
6	578.7	-130.66	482.5	1693.1	2334.1	-424.0	26101.6	335.7	
7	625.9	-140.24	475.5	1173.0	2334.1	-447.8	25014.5	378.9	
8	725.9	-154.74	536.6	1495.0	2605.6	-559.2	23780.5	376.8	
9	825.7	-173.52	531.0	1788.0	2580.3	-659.8	21292.5	373.3	
10	913.6	-183.85	522.1	2091.7	2559.7	-745.8	20964.3	370.4	
11	993.1	-197.80	514.0	2369.0	2785.7	-816.0	21544.1	402.4	
12	1093.6	-213.96	563.2	4707.0	2760.2	-842.4	21737.6	398.8	
13	1200.2	-234.50	557.4	4581.8	2735.7	-851.1	21318.3	395.1	
14	1323.5	-254.91	553.0	4391.2	2711.0	-843.7	21000.0	391.0	
15	1460.5	-278.88	544.5	4048.3	2683.7	-820.7	20736.0	385.3	
16	1600.0	-307.31	546.3	3668.6	2645.7	-803.2	20477.9	377.6	
17	1750.0	-340.77	531.3	3228.6	2604.2	-784.6	20225.9	367.7	
18	1900.0	-379.67	521.9	2756.0	2552.6	-761.2	19985.8	363.8	
19	2060.0	-424.24	521.9	2251.0	2500.5	-734.9	19744.9	357.9	
20	2220.0	-464.82	521.9	1723.7	2448.0	-700.5	19507.3	357.1	
21	2390.0	-501.70	522.2	1184.0	2390.3	-658.9	19270.8	355.0	
22	2570.0	-535.55	522.2	639.0	2332.6	-614.9	19038.2	352.9	
23	2770.0	-565.77	524.2	82.0	2274.9	-570.0	18810.2	351.3	
24	319.7	-1157.1	524.2	6233.4	2488.6	-6.3	25741.1	357.3	

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

LEW
 620-0011-55
 6/78
 78

ELEMENT 5. ITERATION 72 PAGE 12 DATE 04/26/78

TEMPERATURES PER SEGMENT USED IN PEAK PRINCIPLE ANALYSIS

SEGMENT	OUTSIDE	INSIDE	SEGMENT	OUTSIDE	INSIDE	T1	T2	T3	T4	INSIDE	T5
1	335.	373.	16	450.	216.	442.	442.	412.	342.	219.	219.
2	339.	376.	17	448.	217.	439.	435.	408.	340.	219.	219.
3	404.	379.	18	446.	217.	435.	431.	405.	337.	219.	219.
4	443.	381.	19	442.	217.	431.	426.	400.	336.	219.	219.
5	442.	418.	20	433.	218.	426.	420.	398.	330.	219.	219.
6	443.	421.	21	427.	219.	420.	412.	380.	326.	219.	219.
7	444.	421.	22	420.	219.	406.	406.	371.	313.	219.	219.
8	445.	425.	23	413.	219.	392.	392.	359.	306.	219.	219.
9	445.	425.	24	405.	219.	385.	385.	346.	306.	219.	219.
10	445.	437.	25	396.	219.	373.	373.	330.	285.	219.	219.
11	445.	437.	26	388.	219.	360.	353.	312.	273.	219.	219.
12	451.	436.	27	383.	219.	353.	346.	301.	266.	219.	219.
13	439.	434.	28	379.	219.	346.	339.	290.	259.	219.	219.
14	451.	444.	29	374.	219.	339.	332.	278.	251.	219.	219.
15	451.	444.	30	370.	219.	332.	332.	266.	243.	219.	219.
16	451.	444.	31	370.	219.	332.	332.	266.	243.	219.	219.

LEW
 620-0011-55
 6/78
 79

ELEMENT 5. ITERATION 72 PAGE 13 DATE 04/26/78
 PEAK BOUNDARY AND FLEXIBILITY MATRICES

BOUNDARY FORCES DUE TO THE END CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)	SUM
AXIAL FORCE (N)	0:	0:	0:	0:	0:	0:	0:	0:	0:
RADIAL SHEAR (O)	0:	0:	0:	0:	0:	0:	0:	0:	0:
MOMENT (O)	0:	0:	0:	0:	0:	0:	0:	0:	0:
RADIAL SHEAR (N)	0:	0:	0:	0:	0:	0:	0:	0:	0:
ROTATION (N)	0:	0:	0:	0:	0:	0:	0:	0:	0:

FLEXIBILITY MATRIX DUE TO A UNIT LOAD (TOTAL LOAD BASIS)

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)	SUM
AXIAL DEFL. (N)	.6386E-01	0:	0:	.4880E-09	-.990E-09	.9194E-10	-.025E-08	-.875E-10	0:
RADIAL DEFL. (O)	-.1701E+00	0:	0:	-.990E-09	.4644E-08	-.2854E-08	.2088E-08	-.2743E-09	0:
ROTATION (O)	-.3927E-03	0:	0:	.9194E-10	-.2854E-09	-.2633E-10	-.2357E-09	-.2118E-09	0:
RADIAL DEFL. (N)	.1500E+00	0:	0:	-.1032E-08	.2088E-08	-.2357E-09	.3657E-08	-.2418E-09	0:
ROTATION (N)	-.2616E-02	0:	0:	-.8375E-10	.2743E-09	-.2133E-10	.2418E-09	.2346E-10	0:

BOUNDARY DEFLECTIONS DUE TO THE END CONDITIONS

	TEMP.	PRESS.	EXTERNAL LOAD	AXIAL FORCE (N)	RADIAL SHEAR (O)	MOMENT (O)	RADIAL SHEAR (N)	MOMENT (N)	SUM
AXIAL DEFL. (N)	.6386E-01	0:	0:	0:	0:	0:	0:	0:	.6386E-01
RADIAL DEFL. (O)	-.1701E+00	0:	0:	0:	0:	0:	0:	0:	-.1701E+00
ROTATION (O)	-.3927E-03	0:	0:	0:	0:	0:	0:	0:	-.3927E-03
RADIAL DEFL. (N)	.1500E+00	0:	0:	0:	0:	0:	0:	0:	.1500E+00
ROTATION (N)	-.2616E-02	0:	0:	0:	0:	0:	0:	0:	-.2616E-02

LEW
 6/78
 620-001-55

ELEMENT 5. ITERATION 72 PAGE 14 DATE 04/26/78

FLEXIBILITY MATRIX OF ASSEMBLY AS IN PROGRAM 91060
 (THIS MATRIX ONLY IS ON A PER RADIAN BASIS)

	M(O)	Q(O)	MIN)	Q(N)
ROTATION(O)	.16544E-09	.179330E-09	-.133994E-09	-.148085E-09
DEFLECTION(O)	.179330E-09	.291917E-07	-.172376E-09	-.131176E-07
ROTATION(N)	-.133994E-09	-.172376E-09	.47422E-09	.51941E-09
DEFLECTION(N)	-.148085E-09	-.131176E-07	.51941E-09	.229760E-07

NOTE- THE +1 SIGN CONVENTION IS USED IN THE MATRIX PRINTED HERE.
 IF IT IS DESIRED TO USE THE -1 SIGN CONVENTION THEN THE
 SIGNS MUST BE CHANGED ON ALL OF THE OFF-DIAGONAL ELEMENTS.

LEW
 620-0011-55
 6/78
 81

ELEMENT 5. ITERATION 72 PAGE 15 DATE 04/26/78
 PEAK FORCES AND MOTIONS

POSITIVE DIRECTIONS (+) ARE AS FOLLOWS

TOP OF SEGMENT NO.1 BOTTOM OF REMAINING SEGMENTS
 RADIAL----- TO THE LEFT RADIAL----- TO THE RIGHT
 ROTATIONAL-- CLOCKWISE ROTATIONAL-- COUNTERCLOCKWISE
 AXIAL----- UPWARD AXIAL----- DOWNWARD

** SIGN CONVENTIONS ARE FOR A RIGHT HAND VIEW **

SEG. NO.	LOC.	RADIAL FORCE	MOMENT	AXIAL FORCE	LOC.	RADIAL MOTION	ROTATION	AXIAL MOTION
1	TOP	0.	0.	0.	TOP	-.1701E+00	-.3927E-03	0.
	H01.	.3401E+06	-.8565E+05	0.	ROT.	.1703E+00	.2995E-03	.1112E-02
	H01.	.6624E+06	-.3370E+06	0.	ROT.	.1704E+00	.2065E-03	.2238E-02
	H01.	.9662E+06	-.7443E+06	0.	ROT.	.1705E+00	.1124E-03	.3379E-02
	H01.	.1254E+07	-.1300E+07	0.	ROT.	.1705E+00	.1824E-04	.4532E-02
	H01.	.2507E+07	-.1300E+07	0.	ROT.	.1750E+00	.1824E-04	.4501E-02
	H01.	.5233E+07	-.2694E+07	0.	ROT.	.1750E+00	-.1411E-03	.7088E-02
	H01.	.725E+07	-.4323E+07	0.	ROT.	.1744E+00	-.3009E-03	.9710E-02
	H01.	.873E+07	-.6123E+07	0.	ROT.	.1744E+00	-.4614E-03	.1236E-01
	H01.	.995E+07	-.8064E+07	0.	ROT.	.1739E+00	-.6231E-03	.1502E-01
	H01.	.995E+07	-.8064E+07	0.	ROT.	.1764E+00	-.6231E-03	.1564E-01
	H01.	.1453E+07	-.9944E+07	0.	ROT.	.1761E+00	-.7637E-03	.1842E-01
	H01.	.634E+07	-.1174E+08	0.	ROT.	.1753E+00	-.9045E-03	.2121E-01
	H01.	.447E+07	-.335E+08	0.	ROT.	.1744E+00	-.1045E-02	.2400E-01
	H01.	.262E+07	-.473E+08	0.	ROT.	.1733E+00	-.1185E-02	.2679E-01
	H01.	.262E+07	-.1473E+08	0.	ROT.	.1772E+00	-.1185E-02	.2834E-01
	H01.	.792E+06	-.1563E+08	0.	ROT.	.1762E+00	-.1285E-02	.3087E-01
	H01.	.319E+06	-.1611E+08	0.	ROT.	.1750E+00	-.1384E-02	.3334E-01
	H01.	-.146E+06	-.1611E+08	0.	ROT.	.1738E+00	-.1492E-02	.3588E-01
	H01.	-.595E+06	-.1545E+08	0.	ROT.	.1724E+00	-.1579E-02	.3835E-01
	H01.	-.102E+07	-.1515E+08	0.	ROT.	.1710E+00	-.1675E-02	.4080E-01
	H01.	-.140E+07	-.1402E+08	0.	ROT.	.1695E+00	-.1769E-02	.4321E-01
	H01.	-.174E+07	-.1279E+08	0.	ROT.	.1674E+00	-.1861E-02	.4554E-01
	H01.	-.200E+07	-.1105E+08	0.	ROT.	.1661E+00	-.1952E-02	.4784E-01
	H01.	-.217E+07	-.9227E+07	0.	ROT.	.1644E+00	-.2040E-02	.5014E-01
	H01.	-.222E+07	-.7294E+07	0.	ROT.	.1625E+00	-.2126E-02	.5233E-01
	H01.	-.214E+07	-.5373E+07	0.	ROT.	.1606E+00	-.2210E-02	.5443E-01
	H01.	-.189E+07	-.3500E+07	0.	ROT.	.1584E+00	-.2293E-02	.5643E-01
	H01.	-.151E+07	-.2110E+07	0.	ROT.	.1565E+00	-.2375E-02	.5837E-01
	H01.	-.107E+07	-.9771E+06	0.	ROT.	.1544E+00	-.2455E-02	.6025E-01
	H01.	-.570E+06	-.2537E+06	0.	ROT.	.1522E+00	-.2536E-02	.6207E-01
	H01.	0.	0.	0.	ROT.	.1500E+00	-.2616E-02	.6384E-01

(FORCE AND MOTION OUTPUT IS IN GLOBAL DIRECTIONS R AND Z)

LEW 620-0011-55 6/78 82

ELEMENT 5. ITERATION 72 PAGE 16 DATE 04/26/78

PEAK PRINCIPAL STRESSES

SEG. NO.	OUTSIDE			MIDPLANE			INSIDE		
	LONG	HOOP	RAD.	LONG	HOOP	RAD.	LONG	HOOP	RAD.
1	6556.2	-2772.7	212.8	-3327.4	7241.9	1694.4	3830.4	35968.1	212.8
2	6459.0	-3540.5	217.9	-3278.3	6657.0	1664.9	4643.0	36172.9	217.9
3	6363.1	-4327.5	222.8	-3050.3	6320.0	1650.5	4409.0	35999.4	222.8
4	5869.6	-5467.3	228.5	-2927.3	5917.2	1636.5	5361.3	36077.8	224.5
5	8443.9	-1107.0	355.1	-4180.8	-1730.1	2294.0	9895.6	36709.7	355.1
6	9083.9	-1162.5	350.2	-4533.6	-2795.1	2243.4	0126.9	36386.4	350.2
7	9506.6	-1355.5	364.2	-4611.2	-3418.1	2266.3	0644.0	36212.9	349.2
8	9991.0	-1582.5	368.9	-4793.1	-4129.2	2261.5	0685.2	35911.6	348.9
9	1372.3	-2391.9	407.9	-5803.0	-7833.0	2464.8	4053.1	36328.6	407.9
10	1441.9	-2489.2	405.1	-6191.1	-8511.4	2451.2	4071.5	35921.1	405.1
11	1235.2	-2730.3	403.8	-6052.5	-8540.6	2416.3	3947.0	35417.6	403.8
12	1472.4	-2478.9	400.8	-6061.9	-8443.7	2395.6	3753.5	34835.7	400.8
13	1484.4	-2495.4	461.7	-7280.3	-12562.0	2499.8	4046.0	35371.7	461.7
14	12307.5	-2686.6	458.7	-6835.9	-12071.2	2473.8	7508.4	34760.2	458.7
15	1727.7	-2984.4	455.0	-6456.9	-11941.8	2451.7	6774.1	34087.6	455.0
16	1512.9	-2886.5	450.4	-6431.7	-11317.7	2432.4	6573.0	33669.5	450.4
17	1006.7	-2767.8	443.5	-5935.3	-10500.5	2419.4	5719.6	32907.3	443.5
18	0419.1	-2502.0	433.1	-5566.6	-9756.6	2395.8	4974.4	32140.2	433.1
19	9589.0	-2385.2	426.9	-5156.6	-8607.2	2365.2	3977.1	31547.6	426.9
20	8329.9	-1940.0	416.2	-4789.2	-7219.4	2356.0	2515.9	30604.4	416.2
21	7905.7	-1657.1	403.1	-3348.9	-5022.0	2354.6	18462.6	24638.6	403.1
22	6399.0	-1178.5	390.2	-2319.5	-2647.8	2376.7	8871.2	24746.4	390.2
23	5729.8	-8575.2	376.4	-842.7	400.8	2423.3	6504.4	27897.3	376.4
24	3954.7	-8568.7	362.6	984.2	4005.8	2467.3	3554.7	25637.9	362.6
25	3133.1	-0661.3	351.6	2214.2	5421.4	2508.8	2033.2	25764.5	351.6
26	2082.7	-1071.6	343.1	3498.1	7794.2	2542.6	231.9	24516.5	343.1
27	1315.5	-1217.0	333.7	4884.5	9887.6	2540.9	-1046.3	23465.4	333.7
28	369.4	-1641.4	325.0	6300.1	11971.3	2653.7	-3549.4	22359.8	325.0

(LONGITUDINAL DIRECTION IS ALONG SHELL MIDSURFACE. RADIAL DIRECTION IS NORMAL TO SHELL MIDSURFACE.)

LEAD 620-001-55 6/78 83

PRI. + SEC. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SNUD RAPID COOLDOWN

ITERATION = 26

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
#1	0.0	0.5	0.0	0.0	-0.4	0.0
#2	0.0	0.7	0.0	0.0	+1.9	0.0
#3	0.0	-0.4	0.0	0.0	0.4	0.0
#4	0.0	0.7	0.0	0.0	1.1	0.0
#5	0.0	-0.5	0.0	0.0	0.7	0.0

NOTE: STRESS VALUES FOR ADJACENT ELEMENTS AT EACH JUNCTURE WERE COMPARED AND THE LARGER OF THE VALUES WAS TABULATED.

BABCOCK & WILCOX

DEPARTMENT *MT.V - COMP. ENGRG.* DATE *6/78* BY *LEW**PRI. + SEC. FBTS*

CHECKED DATE BY

JOB NO. *620-0011-5.5*

REVISION

SHEET *94* OF

PRI. + SEC. FREE BODY THERMAL STRESSES

FOR

TRANSIENT - SMUD RAPID COOLDOWN

ITERATION = 39

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
#1	0.1	17.6	0.2	0.0	-17.7	0.2
#2	0.4	14.2	0.3	0.5	-14.3	0.3
#3	0.0	-1.8	0.0	+0.1	+3.0	0.0
#4	0.1	2.8	0.0	0.1	1.8	0.0
#5	-0.3	32.0	0.3	0.1	2.8	0.0

BABCOCK & WILCOX

DEPARTMENT *M.T.V.-COMP ENGRS.* DATE *6/78* BY *LEW**PRI. + SEC. FBTS*

CHECKED DATE _____ BY _____

JOB NO. *620-0011-55*

REVISION _____

SHEET *85* OF _____

PRI. + SEC. FREE BODY THERMAL STRESSES

FOR

TRANSIENT - SNUD RAPID COOLDOWN

ITERATION = 45

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
# 1	0.1	22.1	0.2	0.1	-22.4	0.2
# 2	0.5	18.5	0.4	0.6	-18.6	0.4
# 3	0.0	-1.6	0.0	0.0	+2.2	0.0
# 4	-0.2	8.1	0.0	0.2	9.0	0.0
# 5	-0.3	38.4	0.4	-0.2	8.1	0.0

BABCOCK & WILCOX

DEPARTMENT *N/V- COMP. ENGRG.* DATE *6/78* BY *L.E.W.**PRI. + SEC. FBTS*

CHECKED DATE BY

JOB NO. *620-0011-55*

REVISION

SHEET *86* OF

PRI. + SEC. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 49

JUNCTION	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
#1	0.0	10.0	0.1	0.0	-10.5	0.1
#2	0.2	10.0	0.1	0.3	-9.8	0.1
#3	0.0	0.0	0.0	0.0	-0.2	0.0
#4	0.1	8.5	0.0	0.1	5.6	0.0
#5	-0.2	15.7	0.1	-0.1	8.5	0.0

BABCOCK & WILCOX

DEPARTMENT *NT-V-Comp. Engr.* DATE *6/78* BY *LEW*

PRI. + SEC. FBTS

CHECKED DATE _____ BY _____

JOB NO. *620-0011-55*

REVISION _____

SHEET *87* OF _____

PRI. + SEC. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 72

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_c	σ_R	σ_L	σ_c	σ_R
#1	0.0	8.1	0.0	0.0	-8.4	0.0
#2	0.0	8.0	0.4	0.3	-11.5	0.3
#3	-0.2	+15.3	+0.1	-0.5	-23.2	+0.1
#4	-0.1	32.1	0.2	0.3	-16.2	0.2
#5	0.0	25.7	0.4	0.1	32.1	0.2

BABCOCK & WILCOX

DEPARTMENT *M.V. - COMP. ENGRG.* DATE *6/78* BY *LEW**PRI. + SEC. FBTS*

CHECKED DATE _____ BY _____

JOB NO. *620-001-55*

REVISION

SHEET *88* OF _____

PEAK INCREM. FREE BODY THERMAL STRESSES

1.0K

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 26

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
#1	-0.1	0.0	0.0	+0.1	+0.1	0.0
#2	+1.2	-1.3	+0.2	-1.6	-1.8	-0.1
#3	-0.1	-0.1	0.0	-0.1	-0.1	0.0
#4	-0.3	-0.3	0.0	0.0	0.0	0.0
#5	-6.1	-5.9	-0.1	-0.3	-0.3	0.0

BABCOCK & WILCOX

DEPARTMENT *N. V. COMP. ENGRS.* DATE *3/78* BY *LEW*

PEAK INCREMENT CHECKED DATE BY

CBTS

JOB NO. *620-001-55*

REVISION

SHEET *89* OF

PEAK INCREM. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID-COOLDOWN

ITERATION = 39

JUNCTION	INSIDE			OUTSIDE		
	$\bar{\sigma}_L$	σ_c	σ_R	σ_L	σ_c	σ_R
# 1	+39.2	+38.3	+0.1	+10.4	+11.3	+0.1
# 2	+46.5	+45.2	-0.5	+9.6	+10.5	-0.4
# 3	-2.1	-2.1	0.0	-1.0	-1.0	0.0
# 4	-2.4	-2.3	0.0	-1.5	-1.5	0.0
# 5	-57.0	-54.4	-0.5	-2.0	+2.1	0.0

BABCOCK & WILCOX	REVISION
DEPARTMENT <u>NAV. COMP. ENRG.</u> DATE <u>6/78</u> BY <u>LEW</u>	
<u>PEAK INCREMENT</u> CHECKED DATE _____ BY _____	
<u>FBTS</u> JOB NO. <u>620-0011-55</u>	SHEET <u>90</u> OF _____

PEAK INCREM. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 45

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
# 1	+14.6	+14.3	+0.1	+6.4	+7.1	+0.1
# 2	+27.0	+26.9	-0.5	-15.0	-17.6	-0.5
# 3	+2.4	+2.4	0.0	-0.1	0.0	0.0
# 4	+3.3	+3.0	0.0	-0.3	+0.4	0.0
# 5	-69.7	66.3	-0.5	+3.3	+3.0	0.0

BABCOCK & WILCOX

DEPARTMENT *NIT. V-COMP. ENGRG.* DATE *6/78* BY *LEW*

PEAK INCREMENT CHECKED DATE BY

FBTS JOB NO. *620-0011-55*

REVISION

SHEET *91* OF

PEAK INCREM. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 49

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
# 1	-31.4	-30.7	-0.1	-4.1	-4.9	-0.1
# 2	-26.5	-25.8	-0.1	-15.5	-17.3	-0.1
# 3	+5.2	+5.0	0.0	+1.0	+1.1	0.0
# 4	+6.0	+6.0	0.0	+1.6	+1.9	0.0
# 5	-35.4	-34.0	-0.1	+6.0	+6.0	0.0

BABCOCK & WILCOX

DEPARTMENT *NITV-COMP. ENGRG* DATE *6/78* BY *LEW*

PEAK INCREMENT

CHECKED DATE BY

FBTS

JOB NO. *620-0011-55*

REVISION

SHEET *92* OF

PEAK INCREM. FREE BODY THERMAL STRESSES

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 72

JUNCTURE	INSIDE			OUTSIDE		
	σ_L	σ_C	σ_R	σ_L	σ_C	σ_R
# 1	+5.1	+5.0	0.0	+2.1	+2.2	0.0
# 2	+7.6	+7.4	+0.1	+2.5	+2.6	+0.1
# 3	+6.7	+6.5	0.0	+5.6	+5.6	0.0
# 4	+7.3	+7.2	+0.1	+5.4	+5.4	0.0
# 5	-3.6	-3.4	0.0	+3.8	+3.9	0.0

BABCOCK & WILCOX

DEPARTMENT *MT.V-COND. ENGRG.* DATE *6/78* BY *LEW*

PEAK INCREMENT CHECKED DATE BY

FBTS JOB NO. *620-0011-55*

REVISION

SHEET *93* OF

ELEMENT # 5 FREE BODY THERMAL MOTIONS

(ADJUSTMENT OF MOTIONS TO INTERACTION JUNCTURES)

ITERATION NUMBER = 26

JUNCTURE 2

$R_2 = \text{JUNCTURE 2 MEAN RADIUS} = 72.250''$
 $R_{'N'} = \text{PROGRAM 91206 'O' END RADIUS} = 66.673''$

$$\theta_{\text{JCT. 2}} = \theta_{91206}^{\text{'N' END}} = -0.5275E-03$$

$$\delta_{\text{JCT. 2}} = \delta_{91206}^{\text{'N' END}} \left(\frac{72.250}{66.673} \right) = (1.084)(+0.2334)$$

$$= +0.2530E+00$$

JUNCTURE 4

$R_4 = \text{JUNCTURE 4 MEAN RADIUS} = 63.53125''$
 $R_{'O'} = \text{PROGRAM 91206 'O' END RADIUS} = 62.6575''$

$$\theta_{\text{JCT. 4}} = \theta_{91206}^{\text{'O' END}} = -0.7215E-03$$

$$\delta_{\text{JCT. 4}} = \delta_{91206}^{\text{'O' END}} \left(\frac{63.53125}{62.6575} \right) = (1.0139)(0.2339)$$

$$= +0.2372E+00$$

JUNCTURE 5

$R_5 = \text{JUNCTURE 5 MEAN RADIUS} = 57.47125''$
 $R_{\text{SEG. 17}} = \text{PROGRAM 91206 SEGMENT 17 RAD.} = 66.673''$

$$\theta_{\text{JCT. 5}} = \theta_{91206}^{\text{SEG. 17}} = -0.6409E-03$$

$$\delta_{\text{JCT. 5}} = \delta_{91206}^{\text{SEG. 17}} \left(\frac{57.47125}{66.673} \right) = (0.8620)(0.2405)$$

$$= +0.2073E+00$$

BABCOCK & WILCOX
 DEPARTMENT NIT V - COMP. ENGRG. DATE 6/78 BY LEW

JUNCTURE #5

CHECKED DATE BY

FBTM

JOB NO. 620-0011-55

REVISION

SHEET 44 OF

ELEMENT # 5 FREE BODY THERMAL MOTIONS

(ADJUSTMENT OF MOTIONS TO INTERACTION JUNCTURES)

ITERATION NUMBER = 39

JUNCTURE 2

$R_2 =$ JUNCTURE 2 MEAN RADIUS = 72.250"
 $R_{'N'}$ = PROGRAM 91206 'O' END RADIUS = 66.673"

$$\theta_{JCT. 2} = \theta_{91206}^{N' END} = -0.2141E-02$$

$$\delta_{JCT. 2} = \delta_{91206}^{N' END} \left(\frac{72.250}{66.673} \right) = (1.084)(0.2123)$$

$$= +0.2301E+00$$

JUNCTURE 4

$R_4 =$ JUNCTURE 4 MEAN RADIUS = 63.53125"
 $R_{'O'}$ = PROGRAM 91206 'O' END RADIUS = 62.6575"

$$\theta_{JCT. 4} = \theta_{91206}^{O' END} = -0.2234E-02$$

$$\delta_{JCT. 4} = \delta_{91206}^{O' END} \left(\frac{63.53125}{62.6575} \right) = (1.0139)(0.2470)$$

$$= +0.2504E+00$$

JUNCTURE 5

$R_5 =$ JUNCTURE 5 MEAN RADIUS = 57.47125"
 $R_{'SEG 17'}$ = PROGRAM 91206 SEGMENT 17 RAD. = 66.673"

$$\theta_{JCT. 5} = \theta_{91206}^{SEG. 17} = -0.2050E-02$$

$$\delta_{JCT. 5} = \delta_{91206}^{SEG. 17} \left(\frac{57.47125}{66.673} \right) = (0.8620)(0.2370)$$

$$= +0.2043E+00$$

BABCOCK & WILCOX		REVISION
DEPARTMENT	MT.V. COND. ENGRG. DATE 6/78 BY LEW	
JUNCTURE #5	CHECKED DATE BY	
FBTM	JOB NO. 620-0011-55	SHEET 95 OF

ELEMENT # 5 FREE BODY THERMAL MOTIONS

(ALIGNMENT OF MOTIONS TO INTERACTION JUNCTURES)

ITERATION NUMBER = 45

JUNCTURE 2

$R_2 = \text{JUNCTURE 2 MEAN RADIUS} = 72.250''$
 $R_{'N'} = \text{PROGRAM 91206 'O' END RADIUS} = 66.673''$

$$\theta_{\text{JCT. 2}} = \theta_{91206}^{\text{'N' END}} = -0.3543E-02$$

$$\delta_{\text{JCT. 2}} = \delta_{91206}^{\text{'N' END}} \left(\frac{72.250}{66.673} \right) = (1.084)(0.1911)$$

$$= +0.2072 E+00$$

JUNCTURE 4

$R_4 = \text{JUNCTURE 4 MEAN RADIUS} = 63.53125''$
 $R_{'O'} = \text{PROGRAM 91206 'O' END RADIUS} = 62.6575''$

$$\theta_{\text{JCT. 4}} = \theta_{91206}^{\text{'O' END}} = -0.3401E-02$$

$$\delta_{\text{JCT. 4}} = \delta_{91206}^{\text{'O' END}} \left(\frac{63.53125}{62.6575} \right) = (1.0139)(0.2558)$$

$$= +0.2594 E+00$$

JUNCTURE 5

$R_5 = \text{JUNCTURE 5 MEAN RADIUS} = 57.47125''$
 $R_{\text{SEG. 17}} = \text{PROGRAM 91206 SEGMENT 17 RAD.} = 66.673''$

$$\theta_{\text{JCT. 5}} = \theta_{91206}^{\text{SEG. 17}} = -0.3285E-02$$

$$\delta_{\text{JCT. 5}} = \delta_{91206}^{\text{SEG. 17}} \left(\frac{57.47125}{66.673} \right) = (0.8620)(0.2318)$$

$$= +0.1998 E+00$$

BABCOCK & WILCOX

DEPARTMENT UNIT V - COMP. ENRG. DATE 6/78 BY LEW

JUNCTURE #5

CHECKED DATE BY

FBTM

JOB NO. 620-0011-55

REVISION

SHEET 96 OF

ELEMENT # 5 FREE-BODY THERMAL MOTIONS

(ADJUSTMENT OF MOTIONS TO INTERACTION JUNCTURES)

ITERATION NUMBER = 49

JUNCTURE 2

$R_2 = \text{JUNCTURE 2 MEAN RADIUS} = 72.250''$
 $R_{N'} = \text{PROGRAM 91206 'O' END RADIUS} = 66.673''$

$\delta_{JCT. 2} = \delta_{91206}^{N' END} = -0.2946E-02$

$\delta_{JCT. 2} = \delta_{91206}^{N' END} \left(\frac{72.250}{66.673} \right) = (1.084)(0.1976)$
 $= +0.2142E+00$

JUNCTURE 4

$R_4 = \text{JUNCTURE 4 MEAN RADIUS} = 63.53125''$
 $R_{O'} = \text{PROGRAM 91206 'O' END RADIUS} = 62.6575''$

$\delta_{JCT. 4} = \delta_{91206}^{O' END} = -0.2769E-02$

$\delta_{JCT. 4} = \delta_{91206}^{O' END} \left(\frac{63.53125}{62.6575} \right) = (1.0139)(0.2497)$
 $= +0.2532E+00$

JUNCTURE 5

$R_5 = \text{JUNCTURE 5 MEAN RADIUS} = 57.47125''$
 $R_{SEG. 17} = \text{PROGRAM 91206 SEGMENT 17 RAD.} = 66.673''$

$\delta_{JCT. 5} = \delta_{91206}^{SEG. 17} = -0.2792E-02$

$\delta_{JCT. 5} = \delta_{91206}^{SEG. 17} \left(\frac{57.47125}{66.673} \right) = (0.8620)(0.2322)$
 $= +0.2002E+00$

BABCOCK & WILCOX

DEPARTMENT N.T.V.-COMP. ENGRG. DATE 6/72 BY LEW

JUNCTURE # 5

CHECKED DATE BY

FBTM

JOB NO. 620-0011-55

REVISION

SHEET 97 OF

ELEMENT # 5 FREE BODY THERMAL MOTIONS

(ADJUSTMENT OF MOTIONS TO INTERACTION JUNCTURES)

ITERATION NUMBER = 72 [REFER TO PG. 82 FOR 91206 MOTIONS]

JUNCTURE 2

$R_2 =$ JUNCTURE 2 MEAN RADIUS = 72.250"
 $R_{N'} =$ PROGRAM 91206 'O' END RADIUS = 66.673"

$\delta_{JCT. 2} = \delta_{91206}^{N' END} = -0.2616 E-02$

$\delta_{JCT. 2} = \delta_{91206}^{N' END} \left(\frac{72.250}{66.673} \right) = (1.084)(0.1500)$
 $= +0.1626 E+00$

JUNCTURE 4

$R_4 =$ JUNCTURE 4 MEAN RADIUS = 63.53125"
 $R_{O'} =$ PROGRAM 91206 'O' END RADIUS = 62.6575"

$\delta_{JCT. 4} = \delta_{91206}^{O' END} = +0.3927 E-03$

$\delta_{JCT. 4} = \delta_{91206}^{O' END} \left(\frac{63.53125}{62.6575} \right) = (1.0139)(0.1701)$
 $= +0.1725 E+00$

JUNCTURE 5

$R_5 =$ JUNCTURE 5 MEAN RADIUS = 57.47125"
 $R_{SEG. 17} =$ PROGRAM 91206 SEGMENT 17 RAD. = 66.673"

$\delta_{JCT. 5} = \delta_{91206}^{SEG. 17} = -0.1384 E-02$

$\delta_{JCT. 5} = \delta_{91206}^{SEG. 17} \left(\frac{57.47125}{66.673} \right) = (0.8620)(0.1750)$
 $= +0.1509 E+00$

BABCOCK & WILCOX

DEPARTMENT MT. V. COND. ENGRG. DATE 6/78 BY LEW

JUNCTURE # 5

CHECKED DATE BY

FBTMI

JOB NO. 620-0011-55

REVISION

SHEET 98 OF

FREE BODY THERMAL MOTIONS

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 26

ELEM. #	JUNC. #	ROTATION	DEFLECTION
1	1	-0.6092E-04	+0.2400E+00
2	1	-0.5881E-03	+0.2488E+00
	2	-0.5761E-03	+0.2502E+00
3	3	+0.1953E-04	+0.2256E+00
4	3	-0.2298E-03	+0.2351E+00
	4	-0.2199E-03	+0.2345E+00
5*	2	-0.5275E-03	+0.2530E+00
	4	-0.7215E-03	+0.2372E+00
	5	-0.6409E-03	+0.2073E+00

FOR EL. 5 JUNC. MOTIONS, SEE PAGE 94 (TYPICAL FOR ALL ITERS)

UNITS:

DEFLECTION - INCHES

ROTATION - RADIANS

BABCOCK & WILCOX

DEPARTMENT *MT. V - COMP. ENGRS.* DATE *6/78* BY *LEW*

FREE BODY THERM - CHECKED DATE BY

AL MOTIONS

JOB NO. *620-0011-55*

REVISION

SHEET *99* OF

FREE BODY THERMAL MOTIONS

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 39

ELEM. #	JUNC. #	ROTATION	DEFLECTION
1	1	+0.1729E-02	+0.2121E+00
2	1	-0.4156E-02	+0.2265E+00
	2	-0.3621E-02	+0.2362E+00
3	3	+0.3081E-03	+0.2299E+00
4	3	-0.5058E-03	+0.2373E+00
	4	-0.4526E-03	+0.2361E+00
5	2	-0.2141E-02	+0.2301E+00
	4	-0.2234E-02	+0.2504E+00
	5	-0.2050E-02	+0.2043E+00

UNITS:

DEFLECTION - INCHES

ROTATION - RADIANS

BABCOCK & WILCOX

DEPARTMENT *M.V. COMP. ENGRG.* DATE *6/78*

BY *LEW*

REVISION

FREE BODY THERM - CHECKED DATE

BY

AL MOTIONS

JOB NO. *620-0011-55*

SHEET *100* OF

FREE BODY THERMAL MOTIONS

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 45

ELEM. #	JUNC. #	ROTATION	DEFLECTION
1	1	+0.2164E-02	+0.1778E+00
2	1	-0.6998E-02	+0.1976E+00
	2	-0.6282E-02	+0.2141E+00
3	3	+0.2280E-03	+0.2304E+00
4	3	-0.4569E-03	+0.2381E+00
	4	-0.4134E-03	+0.2371E+00
5	2	-0.3543E-02	+0.2072E+00
	4	-0.3401E-02	+0.2594E+00
	5	-0.3285E-02	+0.1998E+00

UNITS:

DEFLECTION - INCHES

ROTATION - RADIANS

BABCOCK & WILCOX DEPARTMENT <u>M-V-COMP. ENGRG.</u> DATE <u>6/78</u> BY <u>LEW</u>	REVISION _____ _____
FREE BODY THERM - CHECKED DATE _____ BY _____	SHEET <u>101</u> OF _____
AL MOTIONS	JOB NO. <u>620-0011-55</u>

FREE BODY THERMAL MOTIONS

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 49

ELEM. #	JUNC. #	ROTATION	DEFLECTION
1	1	+0.9129E-03	+0.1825E+00
2	1	-0.5708E-02	+0.2000E+00
	2	-0.5324E-02	+0.2137E+00
3	3	-0.3484E-04	+0.2271E+00
4	3	-0.1771E-03	+0.2370E+00
	4	-0.1697E-03	+0.2365E+00
5*	2	-0.2946E-02	+0.2142E+00
	4	-0.2769E-02	+0.2532E+00
	5	-0.2792E-02	+0.2002E+00

FOR EL. 5 JUNC. MOTIONS, SEE PG. 98 (TYPICAL ALL ITERS)

UNITS:

DEFLECTION - INCHES

ROTATION - RADIAN

BABCOCK & WILCOX		REVISION
DEPARTMENT <i>MT. V - COMP. ENGRG.</i> DATE <i>6/78</i> BY <i>LEW</i>		
<i>FREE BODY THERM</i> - CHECKED DATE BY		
<i>AL MOTIONS</i> JOB NO. <i>620-0011-55</i>		SHEET <i>102</i> OF

FREE BODY THERMAL MOTIONS

FOR

TRANSIENT = SMUD RAPID COOLDOWN

ITERATION = 72

ELEM. #	JUNC. #	ROTATION	DEFLECTION
1	1	+0.1127E-03	+0.1473E+00
2	1	-0.5439E-02	+0.1661E+00
	2	-0.5161E-02	+0.1793E+00
3	3	-0.2418E-02	+0.1179E+00
4	3	+0.2917E-02	+0.1524E+00
	4	+0.2478E-02	+0.1591E+00
5	2	-0.2616E-02	+0.1626E+00
	4	+0.3927E-03	+0.1725E+00
	5	-0.1384E-02	+0.1509E+00

UNITS:

DEFLECTION - INCHES

ROTATION - RADIAN

BABCOCK & WILCOX

DEPARTMENT MT.V - COMP. ENGRG DATE 6/78 BY LEW

FREE BODY THERMAL - CHECKED DATE BY

AL MOTIONS

JOB NO. 620-0011-55

REVISION

SHEET 103 OF

Page 500

TEMPERATURES THROUGH THE THICKNESS


OF THE TUBESHEET

The temperature distribution through the thickness of the perforated portion of the tubesheet is determined based on a method contained in Reference 6. This method uses equations pertaining to a 'Not Very Long Rod Protruding From A Heat Source'. These equations have been programed into a computer terminal.

The following pages contain a model of the rod and temperature distribution for each iteration. The point spacing through the tubesheet is chosen to agree with the input requirements of Program 91249 (Tubesheet Area Interaction Analysis) in which the temperatures are used.

MODEL OF A 'NOT VERY LONG ROD PROTRUDING FROM A HEAT SOURCE'

SEC. SIDE FILM COEF. APPLIED TO THIS SURF.



REFLECTIVE BOUNDARY

SECONDARY SURFACE

PRI. FILM COEF. (ACTUALLY FILM COEF. ON INSIDE OF TUBE HOLE) APPLIED TO THESE SURFACES

REFLECTIVE BOUNDARY - (NO HEAT TRANSFERRED ACROSS)

TYPICAL LIGAMENT

BABCOCK & WILCOX

DEPARTMENT HT. V-Comp Engrg. DATE 6/79 BY LEW

TUBESHEET LIGAMENT CHECKED DATE BY

THERMAL MODEL JOB NO. 630-0011-55

REVISION SHEET 105 OF

TEMPS. THROUGH THE THICKNESS OF THE TUBESHEET--BY LARRY WHITE

ITERATION NUMBER ▪ 26

TUBE HOLE DIA. (IN)	▪ 0.641	TUBE HOLE PITCH (IN)	▪ 0.875
TUBESHEET THK. (IN)	▪ 24.00	TUBESHEET MATL CODE	▪ 12
PRIMARY CLAD. THK. (IN)	▪ 0.0	PRI. CLAD MATL CODE	▪ 0
SEC. CLAD. THK. (IN)	▪ 0.0	SEC. CLAD MATL CODE	▪ 0
PRIMARY FLUID TEMP (F)	▪ 568.0	PRI. FILM COEF. (BTU/H-FT*FT-F)	▪ 640.
SECONDARY FLUID TEMP (F)	▪ 531.0	SEC. FILM COEF. (BTU/H-FT*FT-F)	▪ 285.

SECONDARY SURFACE TEMPERATURE	▪ TS	▪ 559.71
AT X = 0.005 * THK,	T 1	▪ 562.77
AT X = 0.015 * THK,	T 2	▪ 565.92
AT X = 0.025 * THK,	T 3	▪ 567.17
AT X = 0.035 * THK,	T 4	▪ 567.67
AT X = 0.045 * THK,	T 5	▪ 567.87
AT X = 0.055 * THK,	T 6	▪ 567.95
AT X = 0.065 * THK,	T 7	▪ 567.98
AT X = 0.075 * THK,	T 8	▪ 567.99
AT X = 0.085 * THK,	T 9	▪ 568.00
AT X = 0.095 * THK,	T10	▪ 568.00
AT X = 0.150 * THK,	T11	▪ 568.00
AT X = 0.300 * THK,	T12	▪ 568.00
AT X = 0.500 * THK,	T13	▪ 568.00
AT X = 0.700 * THK,	T14	▪ 568.00
AT X = 0.900 * THK,	T15	▪ 568.00
PRIMARY SURFACE TEMPERATURE	▪ TP	▪ 568.00

WEIGHTED AVERAGE TEMPERATURE ▪ AT ▪ 567.91

106
 9/78
 55-110-029
 LEW

TEMPS. THROUGH THE THICKNESS OF THE TUBESHEET--BY LARRY WHITE

ITERATION NUMBER • 39

TUBE HOLE DIA. (IN)	• 0.641	TUBE HOLE PITCH (IN)	• 0.875
TUBESHEET THK. (IN)	• 24.00	TUBESHEET MATL CODE	• 12
PRIMARY CLAD. THK. (IN)	• 0.0	PRI. CLAD MATL CODE	• 0
SEC. CLAD. THK. (IN)	• 0.0	SEC. CLAD MATL CODE	• 0
PRIMARY FLUID TEMP (F)	• 592.0	PRI. FILM COEF. (BTU/H-FT*FT-F)	• 640.
SECONDARY FLUID TEMP (F)	• 212.0	SEC. FILM COEF. (BTU/H-FT*FT-F)	• 560.

SECONDARY SURFACE TEMPERATURE	• TS	• 454.25
AT X • 0.005 * THK,	T 1	• 505.17
AT X • 0.015 * THK,	T 2	• 557.49
AT X • 0.025 * THK,	T 3	• 578.29
AT X • 0.035 * THK,	T 4	• 586.55
AT X • 0.045 * THK,	T 5	• 589.83
AT X • 0.055 * THK,	T 6	• 591.14
AT X • 0.065 * THK,	T 7	• 591.66
AT X • 0.075 * THK,	T 8	• 591.86
AT X • 0.085 * THK,	T 9	• 591.95
AT X • 0.095 * THK,	T10	• 591.98
AT X • 0.150 * THK,	T11	• 592.00
AT X • 0.300 * THK,	T12	• 592.00
AT X • 0.500 * THK,	T13	• 592.00
AT X • 0.700 * THK,	T14	• 592.00
AT X • 0.900 * THK,	T15	• 592.00
PRIMARY SURFACE TEMPERATURE	• TP	• 592.00

WEIGHTED AVERAGE TEMPERATURE • AT • 590.56

107
 6/78
 620-0011-55
 LCU

TEMPS. THROUGH THE THICKNESS OF THE TUBESHEET--BY LARRY WHITE

ITERATION NUMBER ▪ 45

TUBE HOLE DIA. (IN)	▪ 0.641	TUBE HOLE PITCH (IN)	▪ 0.875
TUBESHEET THK. (IN)	▪ 24.00	TUBESHEET MATL CODE	▪ 12
PRIMARY CLAD. THK. (IN)	▪ 0.0	PRI. CLAD MATL CODE	▪ 0
SEC. CLAD. THK. (IN)	▪ 0.0	SEC. CLAD MATL CODE	▪ 0
PRIMARY FLUID TEMP (F)	▪ 564.0	PRI. FILM COEF. (BTU/H-FT*FT-F)	▪ 640.
SECONDARY FLUID TEMP (F)	▪ 212.0	SEC. FILM COEF. (BTU/H-FT*FT-F)	▪ 245.

SECONDARY SURFACE TEMPERATURE	▪ TS	▪ 494.02
AT X = 0.005 * THK,	T 1	▪ 519.83
AT X = 0.015 * THK,	T 2	▪ 546.41
AT X = 0.025 * THK,	T 3	▪ 556.99
AT X = 0.035 * THK,	T 4	▪ 561.21
AT X = 0.045 * THK,	T 5	▪ 562.89
AT X = 0.055 * THK,	T 6	▪ 563.56
AT X = 0.065 * THK,	T 7	▪ 563.82
AT X = 0.075 * THK,	T 8	▪ 563.93
AT X = 0.085 * THK,	T 9	▪ 563.97
AT X = 0.095 * THK,	T10	▪ 563.99
AT X = 0.150 * THK,	T11	▪ 564.00
AT X = 0.300 * THK,	T12	▪ 564.00
AT X = 0.500 * THK,	T13	▪ 564.00
AT X = 0.700 * THK,	T14	▪ 564.00
AT X = 0.900 * THK,	T15	▪ 564.00
PRIMARY SURFACE TEMPERATURE	▪ TP	▪ 564.00

WEIGHTED AVERAGE TEMPERATURE ▪ AT ▪ 563.27

108
 6/78
 620-0011-55
 LEW

TEMPS. THROUGH THE THICKNESS OF THE TUBESHEET--BY LARRY WHITE

ITERATION NUMBER ▪ 49

TUBE HOLE DIA. (IN)	▪ 0.641	TUBE HOLE PITCH (IN)	▪ 0.875
TUBESHEET THK. (IN)	▪ 24.00	TUBESHEET MATL CODE	▪ 12
PRIMARY CLAD. THK. (IN)	▪ 0.0	PRI. CLAD MATL CODE	▪ 0
SEC. CLAD. THK. (IN)	▪ 0.0	SEC. CLAD MATL CODE	▪ 0
PRIMARY FLUID TEMP (F)	▪ 538.0	PRI. FILM COEF. (BTU/H-FT*FT-F)	▪ 640.
SECONDARY FLUID TEMP (F)	▪ 540.0	SEC. FILM COEF. (BTU/H-FT*FT-F)	▪ 652.

SECONDARY SURFACE TEMPERATURE	▪ TS	▪ 538.79
AT X = 0.005 * THK,	T 1	▪ 538.50
AT X = 0.015 * THK,	T 2	▪ 538.20
AT X = 0.025 * THK,	T 3	▪ 538.08
AT X = 0.035 * THK,	T 4	▪ 538.03
AT X = 0.045 * THK,	T 5	▪ 538.01
AT X = 0.055 * THK,	T 6	▪ 538.00
AT X = 0.065 * THK,	T 7	▪ 538.00
AT X = 0.075 * THK,	T 8	▪ 538.00
AT X = 0.085 * THK,	T 9	▪ 538.00
AT X = 0.095 * THK,	T10	▪ 538.00
AT X = 0.150 * THK,	T11	▪ 538.00
AT X = 0.300 * THK,	T12	▪ 538.00
AT X = 0.500 * THK,	T13	▪ 538.00
AT X = 0.700 * THK,	T14	▪ 538.00
AT X = 0.900 * THK,	T15	▪ 538.00
PRIMARY SURFACE TEMPERATURE	▪ TP	▪ 538.00

WEIGHTED AVERAGE TEMPERATURE ▪ AT ▪ 538.01

601
 34/2
 55-1100-029
 0137

TEMPS. THROUGH THE THICKNESS OF THE TUBESHEET--BY LARRY WHITE

ITERATION NUMBER ▪ 72

TUBE HOLE DIA. (IN)	▪ 0.641	TUBE HOLE PITCH (IN)	▪ 0.875
TUBESHEET THK. (IN)	▪ 24.00	TUBESHEET MATL CODE	▪ 12
PRIMARY CLAD. THK. (IN)	▪ 0.0	PRI. CLAD MATL CODE	▪ 5
SEC. CLAD. THK. (IN)	▪ 0.0	SEC. CLAD MATL CODE	▪ 5
PRIMARY FLUID TEMP (F)	▪ 278.0	PRI. FILM COEF. (BTU/H-FT*FT-F)	▪ 640.
SECONDARY FLUID TEMP (F)	▪ 280.0	SEC. FILM COEF. (BTU/H-FT*FT-F)	▪ 137.

SECONDARY SURFACE TEMPERATURE	▪ TS	▪ 278.24
AT X ▪ 0.005 * THK,	T 1	▪ 278.15
AT X ▪ 0.015 * THK,	T 2	▪ 278.06
AT X ▪ 0.025 * THK,	T 3	▪ 278.02
AT X ▪ 0.035 * THK,	T 4	▪ 278.01
AT X ▪ 0.045 * THK,	T 5	▪ 278.00
AT X ▪ 0.055 * THK,	T 6	▪ 278.00
AT X ▪ 0.065 * THK,	T 7	▪ 278.00
AT X ▪ 0.075 * THK,	T 8	▪ 278.00
AT X ▪ 0.085 * THK,	T 9	▪ 278.00
AT X ▪ 0.095 * THK,	T10	▪ 278.00
AT X ▪ 0.150 * THK,	T11	▪ 278.00
AT X ▪ 0.300 * THK,	T12	▪ 278.00
AT X ▪ 0.500 * THK,	T13	▪ 278.00
AT X ▪ 0.700 * THK,	T14	▪ 278.00
AT X ▪ 0.900 * THK,	T15	▪ 278.00
PRIMARY SURFACE TEMPERATURE	▪ TP	▪ 278.00

WEIGHTED AVERAGE TEMPERATURE ▪ AT ▪ 278.00

011
 84/9
 55-1100-029
 6/75
 620-0011-55
 0727

MECHANICAL LOADING

The Mechanical Loading is represented by the primary pressure and secondary pressure. Below is a tabulation of pressure for each iteration which will be input into the 'Tubesheet Interaction Program' 91249.

<u>ITERATION</u>	<u>PRIMARY PRESS.</u>	<u>SECONDARY PRESS.</u>
26	2150 PSI	890 PSI
39	2030 PSI	0 PSI
45	1650 PSI	0 PSI
49	1450 PSI	1100 PSI
72	2050 PSI	140 PSI

INTERACTION ANALYSIS PROGRAM 91249

The following pages contain a brief description of Program 91249 Analysis and sample 91249 output to show its format and application.

It should be noted here that late arriving transient information (See Page A-11 of Appendix) redefined the maximum tube-to-shell ΔT . To calculate the effects of this larger ΔT , the 91249, Iter. 72 was revised and now includes these effects.

BRIEF DESCRIPTION OF PROGRAM 91249 ANALYSIS
(CONSULT PROGRAM 91249 'USER'S GUIDE' FOR MORE DETAIL (REF. 10))

This program analyzes the straight-tube steam generator vessel as a six-element, five-juncture interaction. The program calculates the element flexibility matrices and the redundant forces at each juncture.

Element 1 is a long cylinder extending from Juncture 1 to the secondary face of the opposite tubesheet. Each section may have a different E, α , and thickness. Elements 2 and 4 are transition elements. Element 5 is an irregular shaped ring. Element 6 is a perforated plate on an elastic foundation.

The free-body pressure motions and some of the free-body thermal motions at the junctures on each element are calculated by the program. The remaining free-body thermal motions must be input according to the following sign convention. Deflection outward from the centerline and rotation in a counter-clockwise direction on the view shown in Fig. 2.1-2 are positive. This sign convention is only used for input. Rotation and radial deflection are positive in the direction of the corresponding redundant for output.

The total matrix includes the effects of local flexibility at junctures 2 and 4, for the redundant moments, shears, and vertical loads at each juncture. The only redundant vertical load is the load at juncture 5. The vertical equilibrium equations for elements 2 and 5 yield $V_1 = V_2 = V_5$ plus the free-body pressure loads on element 5.

Principal stresses and stress intensities are calculated at the inner and outer surface of each element at preset intervals along the element, except for tapered cylinders. The use of tapered cylinders rather than short cylinders results in stress calculations only at the junctures.

The program calculates peak stress intensities in the tubesheet ligaments using the method described in the ASME Code, Section III. Peak stresses are not calculated at the junctures between elements. The program also does not include any free-body thermal stress due to the linear portion of a radial temperature gradient.

ITERATION PRI. PRESS. SEC. PRESS.

26	2150	890
39	2030	0
45	1650	0
49	1450	1100
72	2050*	140*

ITERATION AVERAGE SHELL TEMPERATURE

26	570°
39	570°
45	570°
49	570°
72	545.8°*

ITERATION AVERAGE TUBE TEMPERATURE

26	568°
39	592°
45	564°
49	540°
72	359.8°*

* REVISED PER INFORMATION CONTAINED ON PAGE A-11 OF THE APPENDIX

BABCOCK & WILCOX

DEPARTMENT NTV - COMP. ENGRS DATE 6/78 BY LEW

91249 - INPUT PARAMETERS CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 114 OF

<u>ITER</u>	<u>EL.2 TAVG.</u>	<u>EL.3 TAVG.</u>	<u>EL.4 TAVG.</u>	<u>EL.5 TAVG.</u>
26	535°	568°	566°	554°
39	513°	572°	569°	554°
45	563°	575°	572°	554°
49	454°	574°	571°	554°
72	397°	379°	398°	473°

BABCOCK & WILCOX

DEPARTMENT M.V. - COMP. ENGRS DATE 6/78 BY LEW

91249 INERT FURNACE CHECKED DATE _____ BY _____

JOB NO. 620-0011-55

REVISION

SHEET 115 OF _____

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

INPUT DATA

PIECE	ELEMENT	INSIDE RADIUS	THICKNESS (TOP)	THICKNESS (BOTTOM)	LENGTH	YOUNGS MODULUS	ALPHA	AVERAGE TEMP.	MATERIAL CODE
TRANSITION CYL.	2	68.9375	6.6250	6.6250	2.500	2.861E+07	.730E-05	397.000	12
TRANSITION CYL.	4	59.5313	8.0000	8.0000	2.500	2.861E+07	.730E-05	398.000	12
SPHERICAL SEG.	3	59.5313	8.0000	-----	-----	2.872E+07	.675E-05	379.000	2
RING	5	57.4713	18.0913	10.0501	24.000	2.820E+07	.736E-05	473.000	12
		OUTSIDE RADIUS	THICKNESS						
PLATE ON ELASTIC FOUNDATION	6	57.4713	24.0000			6.158E+06	.718E-05	278.002	12

PRIMARY PRESSURE 2050.0 PSI
 SECONDARY PRESSURE 140.0 PSI
 POISSONS RATIO .300
 HALF-ANGLE OPENING OF CAP (DEG) 90.000
 TYPE OF TAPER ON ELEMENT 2 IS 0
 TYPE OF TAPER ON ELEMENT 4 IS 0
 LOCAL FLEXIBILITY THICKNESS AT JUNCTURE 2 IS 7.375
 LOCAL FLEXIBILITY THICKNESS AT JUNCTURE 4 IS 8.750

9/11
 8/2/78
 620-0011-55
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

INPUT DATA

SUBDIVISIONS OF LONG CYLINDER - ELEMENT 1

SECTION NO.	MATERIAL CODE	INSIDE RADIUS	THICKNESS	LENGTH	YOUNGS MODULUS	AVERAGE TEMP.	ALPHA
1	1	68.9375	6.6250	51.5475	2.657E+07	545.8	.716E-05
2	1	68.9375	4.1875	304.5925	2.657E+07	545.8	.716E-05
3	1	68.9375	6.6250	120.5950	2.657E+07	545.8	.716E-05
4	1	68.9375	4.1875	91.4975	2.657E+07	545.8	.716E-05
5	1	68.9375	6.6250	54.9475	2.657E+07	545.8	.716E-05

TOTAL LENGTH (L) OF LONG CYLINDER 622.270
 EFFECTIVE LENGTH (L - LENGTH OF ELEMENT 2) 619.770
 EFFECTIVE HALF-LENGTH OF ELEMENT 1 309.985
 AVERAGE YOUNGS MODULUS 2.657E+07
 AVERAGE THERMAL EXPANSION COEFFICIENT .716E-05

LEW
 620-2011-55
 6/78
 117

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

INPUT DATA

SUBDIVISIONS OF RING - ELEMENT 5

SECTION NO.	DISTANCE TO TOP	DISTANCE TO BOTTOM	OUTSIDE RADIUS	INSIDE RADIUS	CODE NO.
1	10.7500	0.0000	67.5313	57.4713	1
2	24.0000	10.7500	75.5625	57.4713	1
3	10.7500	0.0000	75.5625	67.5313	2

TUBESHEET DATA

TUBE DATA

TUBE PATTERN DIMENSIONS (IN)				TUBE TEMPERATURE	359.80
PITCH		TUBE HOLE DIAM		THERMAL EXPANSION COEFFICIENT	.764E-05
NOM	MIN	NOM	MAX	YOUNGS MODULUS	2.989E+07
.8750	.8650	.6350	.6410	TUBE WALL THICKNESS	.0340
LIGAMENT EFFICIENCY OF TUBESHEET .274				NUMBER OF TUBES	15457.
EFFECTIVE POISSONS RATIO OF TUBESHEET .4010				LENGTH OF TUBES BETWEEN PRIMARY FACES	673.25
THERMAL EXPANSION COEFFICIENT .7182E-05				FREE LENGTH OF TUBES	669.25
EFFECTIVE YOUNGS MODULUS .616E+07				ELASTIC FOUNDATION MODULUS	8400.0
MATERIAL CODE FOR TUBESHEET 12				MATERIAL CODE FOR TUBES	5
				TUBE OUTSIDE DIAMETER	.625

118
 6/78
 620-001-55
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LOW T.S. ANALYSIS --- BY L. WHITE - ITER 72

TEMPERATURES THRU TURESHEET

	T1	T2	T3	T4	T5	T6	T7	T8
IS 278.24	278.15	278.06	278.02	278.01	278.00	278.00	278.00	278.00
T9 278.00	T10 278.00	T11 278.00	T12 278.00	T13 278.00	T14 278.00	T15 278.00	T16 278.00	T17 278.00
								T18 70.00

FREEBODY THERMAL MOTIONS

	LONG CYLINDER	TRANS. CYLINDER	RING	TRANS. CYLINDER	SPHERICAL SEGMENT	PLATE
JUNCTURE 1 RTI. DEF.	.1127E-03	-.5439E-02				
	.1473E+00	.1661E+00				
JUNCTURE 2 RTI. DEF.		-.5161E-02	-.2616E-02	.2917E-02	-.2618E-02	
		.1793E+00	.1626E+00	.1574E+00	.1179E+00	
JUNCTURE 3 RTI. DEF.			.3927E-03	.2478E-02		
			.1725E+00	.1591E+00		
JUNCTURE 4 RTI. DEF.						
JUNCTURE 5 RTI. DEF.						.2251E-06
						.8586E-01

SIGN CONVENTION-- DEFLECTION OUTWARD FROM THE CENTERLINE IS POSITIVE
 ROTATION COUNTERCLOCKWISE ON AN UPPER RIGHTHAND VIEW IS POSITIVE

THERMAL MOMENT DUE TO TEMPERATURE DISTRIBUTION (IN*LB/IN) .2872E+04
 (POSITIVE IN SAME DIRECTION AS M5)

620-0011-55
 6/78
 119
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCF-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

ELEMENT NO. 1 LONG CYLINDER

FLEXIBILITY MATRIX

	41	01	V
ROTATION	.33239876E-09	-.28338954E-08	0.
HORIZONTAL DEFLECTION	-.28338954E-08	.48234194E-07	.17044319E-08
VERTICAL DEFLECTION	0.	.17044319E-08	.33817592E-07

ELEMENT NO. 2 SHORT CYLINDER

FLEXIBILITY MATRIX

	41	01	M2	02	V
ROTATION	.29274323E-06	.36591390E-06	-.29272053E-06	-.36590444E-06	0.
HORIZONTAL DEFLECTION	.36591390E-06	.60984930E-06	-.36590444E-06	-.30492127E-06	-.15826469E-08
ROTATION	-.29272053E-06	-.36590444E-06	.29274323E-06	.36591390E-06	0.
HORIZONTAL DEFLECTION	-.36590444E-06	-.30492127E-06	.36591390E-06	.60984930E-06	-.15826469E-08
VERTICAL DEFLECTION	0.	-.15826469E-08	0.	-.15826469E-08	.18254289E-09

ELEMENT NO. 3 SPHERICAL SEGMENT

FLEXIBILITY MATRIX

	43	03	V
ROTATION	.20177732E-09	-.17694592E-08	0.
HORIZONTAL DEFLECTION	-.17694592E-08	.31034066E-07	0.
VERTICAL DEFLECTION	0.	0.	0.

120
 6/78
 5-1100-02
 LEW

SMUD STEAM GENERATOR---REACTOR TRIP TRANS. FULL CERTIFICATION ITER 28 FULL CERTIFICATION 91249 REV 4 3-15-75 05/16/78 09-27-79 PAGE 149
 FULL CERTIFICATION 91CC68

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LHM T.S. ANALYSIS --- BY L. WHITE - ITER 72

ELEMENT NO. 4 SHORT CYLINDER

	M3	M4	M5	V
ROTATION	.21321005E-06	-.21319539E-06	-.26644667E-06	0.
HORIZONTAL DEFLECTION	.26650278E-06	-.26649667E-06	-.22208144E-06	0.
ROTATION	-.21319539E-06	.21321005E-06	.26650278E-06	0.
HORIZONTAL DEFLECTION	-.26649667E-06	.26650278E-06	.22208144E-06	0.
VERTICAL DEFLECTION	0.	0.	0.	0.

ELEMENT NO. 5 RING

	M2	M3	M4	M5	V
ROTATION	.1860287E-09	-.1575914E-08	-.3718090E-09	-.1718055E-08	-.197530E-07
HORIZONTAL DEFLECTION	.1575914E-08	.2501659E-07	.1491562E-08	.1320671E-07	.471602E-08
ROTATION	.338090E-09	.1491562E-08	.1797974E-09	.1797973E-08	.121469E-07
HORIZONTAL DEFLECTION	.1718055E-08	.1320671E-07	.3051150E-07	.3051150E-07	.140155E-08
ROTATION	.338090E-09	.1491562E-08	.1797974E-09	.1797973E-08	.121469E-07
HORIZONTAL DEFLECTION	.1575914E-08	.2501659E-07	.1491562E-08	.1320671E-07	.471602E-08
VERTICAL DEFLECTION	0.	0.	0.	0.	0.

ELEMENT NO. 6 FLAT PLATE ON ELASTIC FOUNDATION

	M	V
ROTATION	.78398730E-10	-.10959607E-08
HORIZONTAL DEFLECTION	0.	.40528815E-08
VERTICAL DEFLECTION	-.10959607E-08	0.

121
 6/78
 620-0011-55
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LHM T.S. ANALYSIS --- BY L. WHITE - ITER 72

FREEBODY PRESSURE MOTIONS

		LONG CYLINDER	TRANS. CYLINDER	RING	TRANS. CYLINDER	SPHERICAL SEGMENT	PLATE
JUNCTURE 1	ROT. DEFL.	0. .1933E-02	0. -.1795E-02				
JUNCTURE 2	ROT. DEFL.		0. -.1795E-02	-.3906E-02 .4620E-01			
JUNCTURE 3	ROT. DEFL.				0. .2966E-01	.8528E-08 -.1146E-01	
JUNCTURE 4	ROT. DEFL.			.3906E-02 -.4755E-01	0. .2966E-01		
JUNCTURE 5	ROT. DEFL.			.3906E-02 -.6714E-03			0. .1237E-02

SIGN CONVENTION< SAME AS PROGRAM 91060

221
 8/19
 55-1100-029
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

*** VERTICAL FREE BODY MOTIONS ***

VERTICAL LOOP (SHELL LEG)		VERTICAL LOOP (TUBE LEG)	
MOTIONS OF THE SHELL AND RING ELEMENTS		MOTIONS OF THE TUBES AND TUBESHEET	
<u>PRESSURE ELONGATION</u>		<u>PRESSURE ELONGATION</u>	
LONG CYLINDER	.1111712	TUBE AND TUBESHEET AXIAL ELONGATION AT JUNCTURE 5	-.1919730
TRANS. CYLINDER	.0006001		
RING	.0593106		
SUBTOTAL	.1710919	SUBTOTAL	-.1919730
<u>TEMPERATURE ELONGATION</u>		<u>TEMPERATURE ELONGATION</u>	
LONG CYLINDER	1.0558195	TUBE AND TUBESHEET AXIAL ELONGATION AT JUNCTURE 5	.7261914
TRANS. CYLINDER	.0059661		
RING	.0356113		
SUBTOTAL	1.0973369	SUBTOTAL	.7261914
TOTAL ELONGATION (SHELL LEG)	1.2684788	TOTAL ELONGATION (TUBE LEG)	.5342185

VERTICAL MISMATCH ACROSS JUNCTURE 5
 (TUBE LEG - SHELL LEG)

-.734260

NOTE- POSITIVE NUMBERS INDICATE ELONGATIONS,
 NEGATIVE NUMBERS INDICATE CONTRACTIONS.
 ELONGATIONS OF THE TUBES AND LONG CYLINDER ARE

123
 6/78
 620-0011
 -55
 LEW

SMUD STEAM GENERATOR---REACTOR TRIP TRANS. ITER 26 91249 REV A 3-15-75 05/16/78 09-27-89 PAGE 142
FULL CERTIFICATION FULL CERTIFICATION FULL CERTIFICATION
ELEMENTS (NEAR THE MIDPOINT OF THE VESSEL).

LEW
620-0011-55
6/78
124

SOLUTION CHECK FOR TOTAL MATRIX

CALC. GIVEN PCI
 RHS RHS DEVIATION

.55517E-02	.55517E-02	.000
-.18938E-01	-.18938E-01	-.000
.13612E-02	.13612E-02	-.000
-.61108E-01	-.61108E-01	.000
.53350E-02	.53350E-02	.000
-.52702E-01	-.52702E-01	-.000
-.59915E-02	-.59915E-02	.000
.31282E-01	.31282E-01	-.000
-.52904E-02	-.52904E-02	-.000
.64478E-01	.64478E-01	0.000
-.73426E+00	-.73426E+00	-.000

LEW
 620-0011-55
 6/78
 126

SMUD STEAM GENERATOR -- REACTOR TRIP TRANS.
FULL CERTIFICATION

ITER 26
FULL CERTIFICATION

91249 REV 4 3-15-75 05/16/78 09-37-49 PAGE 146
FULL CERTIFICATION .91C 66

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCF-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

REDUNDANTS

SHEARS AND MOMENTS AT JUNCTURES 1, 2, 3, 4, AND 5

M1	Q1	M2	Q2	M3	Q3
-.208205E+07	-.341447E+08	-.283634E+07	.247424E+08	.376647E+08	.266252E+07

M4	Q4	M5	Q5
.451145E+08	-.330427E+07	-.566067E+08	.767623E+07

VERTICAL LOADS IMPOSED AT JUNCTURES 1, 2, AND 5

V1	V2	V5
-.204840E+07	-.204840E+07	-.553538E+07

VALUES ARE ON A LOAD PER RADIAN BASIS

121
5/19
55-1100-029
LEW

SMUD STEAM GENERA. OH---REACTOR TRIP TRANS.
FULL CERTIFICATION

ITER 76
FULL CERTIFICATION

91249 HEV A 3-15-75 05/16/78 09:37:40 PAGE 1/17
FULL CERTIFICATION .91CC66

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

FINAL MOTIONS

		LONG CYLINDER	TRANS. CYLINDER	RING	TRANS. CYLINDER	SPHERICAL SEGMENT	PLATE
JUNCTURE 1	ROT. DEFL.	.1616E-03 -.1654E+00	-.1616E-03 .1654E+00				
JUNCTURE 2	ROT. DEFL.		-.2290E-03 .1652E+00	.2290E-03 -.1652E+00			
JUNCTURE 3	ROT. DEFL.				-.4707E-03 .1134E+00	.4707E-03 -.1134E+00	
JUNCTURE 4	ROT. DEFL.			-.1242E-02 -.1154E+00	.1242E-02 .1154E+00		
JUNCTURE 5	ROT. DEFL.			-.1529E-02 -.1182E+00			.1629E-02 .1182E+00

SIGN CONVENTION< SAME AS PROGRAM 91060

128
6/78
LEW
55-11022
620-0011-55

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

LOCATION	ELEMENT 1 LONG CYLINDER					
	PRINCIPAL STRESSES (KSI)					
	CIRCUMFERENTIAL		LONGITUDINAL			
MEASURED ALONG ELEMENT FROM BOTTOM (INCHES)	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
0.00	6.5	6.5	-8.2	-2.5	0.0	0.0
3.83	4.4	4.3	-4.1	-4.0	0.0	0.0
7.66	4.0	3.7	-4.6	-5.0	0.0	0.0
11.49	3.6	3.2	-3.0	-5.5	0.0	0.0
15.31	3.2	2.7	-2.7	-5.8	0.0	0.0
19.14	2.8	2.4	-2.7	-5.7	0.0	0.0
22.97	2.4	2.1	-2.8	-5.7	0.0	0.0
26.80	2.1	1.7	-3.0	-5.6	0.0	0.0
30.63	1.7	1.4	-3.2	-5.3	0.0	0.0
34.46	1.4	1.1	-3.4	-5.1	0.0	0.0
38.29	1.1	0.8	-3.4	-5.1	0.0	0.0



STRESS INTENSITY (KSI)

	INSIDE			OUTSIDE		
	C-L	L-R	R-C	C-L	L-R	R-C
0.00	12.5	8.6	4.4	6.8	2.5	5.5
3.83	9.9	4.4	4.4	4.3	4.0	4.4
7.66	7.6	3.5	3.7	4.4	5.0	3.4
11.49	5.0	2.7	3.3	4.0	5.5	2.7
15.31	3.6	2.6	2.9	3.6	5.8	2.1
19.14	3.2	2.6	2.5	3.5	5.7	1.9
22.97	2.8	2.4	2.5	3.4	5.6	1.8
26.80	2.4	2.1	2.0	3.1	5.3	1.7
30.63	2.1	1.7	1.8	2.8	5.1	1.6
34.46	1.7	1.4	1.6	2.5	4.9	1.5
38.29	1.4	1.1	1.4	2.2	4.7	1.4

LEW
 620-0011-55
 6/78
 129

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

LOCATION MEASURED ALONG ELEMENT 2 FROM BOTTOM (INCHES)	ELEMENT 2 SHORT CYLINDER PRINCIPAL STRESSES (KSI)					
	CIRCUMFERENTIAL		LONGITUDINAL		RADIAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
0.00	-8.4	-5.2	-9.6	1.1	-.1	0.0
.25	-7.8	-4.7	-9.5	1.0	-.1	0.0
.50	-7.3	-4.2	-9.4	.8	-.1	0.0
.75	-6.7	-3.7	-9.3	.7	-.1	0.0
1.00	-6.1	-3.2	-9.1	.6	-.1	0.0
1.25	-5.6	-2.7	-9.0	.6	-.1	0.0
1.50	-5.0	-2.3	-8.8	.3	-.1	0.0
1.75	-4.4	-1.8	-8.7	.1	-.1	0.0
2.00	-3.8	-1.3	-8.5	-.0	-.1	0.0
2.25	-3.3	-.8	-8.4	-.2	-.1	0.0
2.50	-2.7	-.4	-8.2	-.3	-.1	0.0

LOCATION MEASURED ALONG ELEMENT 2 FROM BOTTOM (INCHES)	STRESS INTENSITY (KSI)					
	INSIDE			OUTSIDE		
	C-L	L-R	R-C	C-L	L-R	R-C
0.00	1.2	-9.5	8.3	-6.3	1.1	5.3
.25	1.1	-9.4	7.7	-5.7	1.0	4.7
.50	1.1	-9.3	7.1	-5.1	.8	4.1
.75	1.0	-9.1	6.5	-4.5	.7	3.5
1.00	1.0	-9.0	6.0	-4.0	.6	3.0
1.25	1.0	-8.8	5.4	-3.4	.6	2.4
1.50	1.0	-8.7	4.8	-2.8	.3	1.8
1.75	1.0	-8.5	4.3	-2.3	.1	1.3
2.00	1.0	-8.4	3.7	-1.7	-.0	.7
2.25	1.0	-8.2	3.2	-1.2	-.1	.2
2.50	1.0	-8.1	2.6	-.6	-.1	-.4

130
 4/78
 55-100-029
 LWR

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

LOCATION MEASURED ALONG ELEMENT & FROM TOP (INCHES)	ELEMENT 4		SHORT CYLINDER			
	PRINCIPAL STRESSES (KSI)					
	CIRCUMFERENTIAL		LONGITUDINAL		RADIAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
0.00	1.0	-36.8	73.7	-59.4	-2.1	0.0
0.25	.8	-36.3	72.5	-58.2	-2.1	0.0
0.50	.6	-35.8	71.3	-57.0	-2.1	0.0
0.75	.5	-35.3	70.2	-55.9	-2.1	0.0
1.00	.3	-34.8	69.0	-54.7	-2.1	0.0
1.25	.2	-34.2	67.9	-53.6	-2.1	0.0
1.50	.1	-33.7	66.8	-52.5	-2.1	0.0
1.75	.0	-33.2	65.8	-51.5	-2.1	0.0
2.00	.0	-32.6	64.7	-50.4	-2.1	0.0
2.25	.0	-32.1	63.7	-49.4	-2.1	0.0
2.50	-.1	-31.5	62.7	-48.4	-2.1	0.0

STRESS INTENSITY (KSI)

	INSIDE			OUTSIDE		
	C-L	L-R	R-C	C-L	L-R	R-C
0.00	-72.7	75.4	-3.1	22.6	-59.4	36.8
0.25	-71.7	74.6	-3.0	21.9	-58.2	36.3
0.50	-70.7	73.4	-2.5	20.2	-57.0	35.8
0.75	-69.7	72.2	-2.7	19.0	-55.9	35.3
1.00	-68.7	71.1	-2.6	17.9	-54.7	34.8
1.25	-67.7	70.0	-2.3	16.8	-53.6	34.2
1.50	-66.7	64.9	-2.2	15.8	-52.5	33.7
1.75	-65.7	67.8	-2.1	14.8	-51.5	33.2
2.00	-64.7	66.8	-2.0	13.7	-50.4	32.6
2.25	-63.8	65.8	-2.0	12.6	-49.4	32.1
2.50	-62.8	64.8	-2.0	11.5	-48.4	31.5

620-0011-55
 6/78
 131
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

ELEMENT 3 SPHERICAL HEAD SEGMENT

LOCATION MEASURED ALONG ELEMENT FROM TOP (DEGREES)	PRINCIPAL STRESSES (KSI)				RADIAL	
	CIRCUMFERENTIAL		LONGITUDINAL		INSIDE	OUTSIDE
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
0.00	17.0	-17.3	63.3	-48.9	-2.1	0.0
4.50	1.6	-16.9	44.7	-31.0	-2.1	0.0
9.00	1.8	-18.6	29.6	-16.3	-2.1	0.0
13.50	-1.1	-4.3	18.4	-5.2	-2.1	0.0
18.00	1.1	-4.5	10.8	7.5	-2.1	0.0
22.50	1.3	2.5	6.1	10.2	-2.1	0.0
27.00	3.3	4.2	3.9	1.4	-2.1	0.0
31.50	3.4	4.2	3.0	1.5	-2.1	0.0
36.00	3.6	7.1	3.7	1.0	-2.1	0.0
40.50	5.6	7.6	4.6	10.2	-2.1	0.0
45.00						

STRESS INTENSITY (KSI)

INSIDE			OUTSIDE		
C-L	L-R	R-C	C-L	L-R	R-C
-45.3	65.3	-19.1	31.6	-48.9	17.3
-29.0	46.7	-9.7	14.7	-31.0	16.9
-19.3	31.4	-1.3	3.4	-16.3	12.6
-11.3	20.8	-1.9	-0.9	-5.2	4.3
-5.0	18.2	-3.3	-4.0	7.5	2.3
-2.0	5.9	-6.9	-7.7	10.2	-4.7
1.3	5.1	-6.7	-6.3	11.4	-6.2
1.0	6.7	-8.7	-3.7	11.0	-7.6

LEW
 620-0011-55
 6/78
 132

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

STRESSES IN TUBESHEET (KSI)

EQUIVALENT SOLID PLATE STRESSES

TUBESHEET RADIUS	RADIAL		CIRCUMFERENTIAL		LONGITUDINAL	
	SECONDARY SIDE	PRIMARY SIDE	SECONDARY SIDE	PRIMARY SIDE	SECONDARY SIDE	PRIMARY SIDE
0.00	19.3	-6.9	18.3	-6.9	-	-2.1
5.75	19.0	-6.7	18.1	-6.8	-	-2.1
11.49	17.4	-6.1	17.7	-6.4	-	-2.1
17.24	15.4	-5.1	17.0	-5.7	-	-2.1
22.99	13.9	-3.6	16.1	-4.8	-	-2.1
28.74	13.0	-1.6	14.8	-3.5	-	-2.1
34.49	10.5	.8	13.3	-1.9	-	-2.1
40.23	7.6	3.8	11.4	-1.1	-	-2.1
45.98	5.1	7.1	9.2	-2.2	-	-2.1
51.72	3.0	11.1	6.6	4.7	-	-2.1
57.47	-4.6	15.9	3.6	7.7	-	-2.1

AVE. LIGAMENT STRESS INTENSITY **

	SECONDARY SIDE			PRIMARY SIDE		
	S12	S23	S31	S12	S23	S31
0.00	66.7	66.7	0.0	-23.2	-23.2	0.0
5.75	65.0	66.3	0.0	-22.5	-22.7	0.0
11.49	63.8	64.9	0.0	-20.2	-21.3	0.0
17.24	60.1	62.5	0.0	-16.5	-18.9	0.0
22.99	54.7	50.1	0.0	-11.0	-15.4	0.0
28.74	47.7	54.6	0.0	-4.0	-11.0	0.0
34.49	38.8	48.9	0.0	6.3	-8.3	0.0
40.23	28.0	42.0	0.0	18.0	1.8	0.0
45.98	15.4	34.3	0.0	29.6	10.3	0.0
51.72	3.3	27.9	0.0	44.2	19.7	0.0
57.47	-30.1	24.2	0.0	61.1	30.5	0.0

TUBESHEET FREEBODY
 THERMAL STRESS

AVE. LIGAMENT PRIMARY
 MEMBRANE STRESS INTENSITY

PEAK RIM
 STRESS INTENSITY

SECONDARY SIDE PRIMARY SIDE

R = 57.47

SECONDARY SIDE PRIMARY SIDE

LWR
 620-0011-55
 6/78
 133

0.0 0.0

20.8

5.0 -95.8

SMUD STEAM GENERATOR---REACTOR TRIP TRANS.
FULL CERTIFICATION

ITER 26
FULL CERTIFICATION

91249 REV A 3-15-75 05/16/78 09:37:49 PAGE 153
FULL CERTIFICATION 010066

•• SEE USERS GUIDE FOR DERIVATION OF STRESS INTENSITIES

LEAD
620-0011-55
6/78
134

SMUD STEAM GENERATOR---REACTOR TRIP TRANS. ***** ITER 26 ***** FULL CERTIFICATION ***** 91249 REV 4 3-15-75 05/16/78 09:37:49 PAGE 154
 FULL CERTIFICATION ***** 91249 REV 4 3-15-75 05/16/78 09:37:49 PAGE 154
 FULL CERTIFICATION ***** 91249 REV 4 3-15-75 05/16/78 09:37:49 PAGE 154

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

TUBE LOADS				
TUBESHEET RADIUS	TUBESHEET DEFLECTION	TUBE AXIAL DEFLECTION	LONGITUDINAL TUBE STRESS	TUBE LOAD LB.
0.00	.8685	.1910	17.06	1077.0
5.75	.8703	.1927	17.21	1086.4
11.49	.8752	.1975	17.65	114.5
17.24	.8833	.2057	18.37	159.9
22.99	.8941	.2165	19.34	220.8
28.74	.9071	.2295	20.50	296.3
34.48	.9219	.2442	21.81	376.9
40.23	.9372	.2596	23.19	463.9
45.98	.9525	.2749	24.55	549.9
51.72	.9654	.2888	25.79	628.3
57.47	.9776	.3000	26.80	691.5

TUBESHEET DEFLECTION TO PRIMARY SIDE IS POSITIVE

VERTICAL FORCE BALANCE FOR TUBESHEET (KIP/RAD BASIS)

VERTICAL REDUNDANT (V5)	CALCULATED VERTICAL LOAD	PERCENT DEVIATION
-5535.4	-5533.3	.0

NOTE: THE CALCULATED VERTICAL LOAD CONSISTS OF THE AREA-CORRECTED PRESSURE LOADS ON THE TUBESHEET FACES PLUS A RADIUS-WEIGHTED SUMMATION OF THE TUBE STRAINS AT THE TABULATED RADII.

LEW
 620-0011-55
 6/78
 135

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 0.00

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
00	20.7	20.7	20.7	20.7	60.0	60.0	60.0	60.0
05	20.7	20.7	20.7	20.7	60.0	60.0	60.0	60.0
10	20.7	20.7	20.7	20.7	63.3	63.3	63.3	63.3
15	20.7	20.7	20.7	20.7	66.6	66.6	73.3	73.3
20	20.7	20.7	20.7	20.7	76.6	76.6	73.3	73.3
25	20.7	20.7	20.7	20.7	79.9	79.9	76.6	76.6
30	20.7	20.7	20.7	20.7	79.9	79.9	79.9	79.9
35	20.7	20.7	20.7	20.7	70.0	70.0	79.9	79.9
40	20.7	20.7	20.7	20.7	70.0	70.0	73.3	73.3
45	20.7	20.7	20.7	20.7	66.6	66.6	66.6	66.6
50	20.7	20.7	20.7	20.7	66.6	66.6	63.3	63.3
55	20.7	20.7	20.7	20.7	60.0	60.0	56.7	56.7
60	20.7	20.7	20.7	20.7	60.0	60.0	53.3	53.3
65	20.7	20.7	20.7	20.7	60.0	60.0	56.7	56.7
70	20.7	20.7	20.7	20.7	63.3	63.3	63.3	63.3
75	20.7	20.7	20.7	20.7	66.6	66.6	66.6	66.6
80	20.7	20.7	20.7	20.7	73.3	73.3	73.3	73.3
85	20.7	20.7	20.7	20.7	76.6	76.6	74.9	74.9
90	20.7	20.7	20.7	20.7	76.6	76.6	74.9	74.9
95	20.7	20.7	20.7	20.7	76.6	76.6	76.6	76.6
00	20.7	20.7	20.7	20.7	73.3	73.3	73.3	73.3
05	20.7	20.7	20.7	20.7	66.6	66.6	73.3	73.3
10	20.7	20.7	20.7	20.7	63.3	63.3	63.3	63.3
15	20.7	20.7	20.7	20.7	60.0	60.0	60.0	60.0
20	20.7	20.7	20.7	20.7	60.0	60.0	60.0	60.0
25	20.7	20.7	20.7	20.7	60.0	60.0	60.6	60.6
30	20.7	20.7	20.7	20.7	66.6	65.6	63.3	61.3
35	20.7	20.7	20.7	20.7	66.6	66.6	63.3	63.3
40	20.7	20.7	20.7	20.7	70.0	70.0	73.3	73.3
45	20.7	20.7	20.7	20.7	70.0	70.0	79.9	79.9
50	20.7	20.7	20.7	20.7	74.9	74.9	86.6	86.6
55	20.7	20.7	20.7	20.7	74.9	74.9	74.9	74.9
60	20.7	20.7	20.7	20.7	76.6	76.6	73.3	73.3
65	20.7	20.7	20.7	20.7	66.6	66.6	63.3	63.3
70	20.7	20.7	20.7	20.7	63.3	63.3	63.3	63.3
75	20.7	20.7	20.7	20.7	60.0	60.0	66.6	66.6
80	20.7	20.7	20.7	20.7	60.0	60.0	60.0	60.0

136
 620-0011-55
 6/78
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 5.75

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
0	59.0	59.0	59.0	59.0	59.0	59.9	59.0	59.8
1	62.3	63.2	62.4	63.1	62.3	63.2	62.4	63.1
2	65.6	66.4	66.4	66.4	65.6	66.4	66.4	66.4
3	75.6	76.2	76.2	76.2	75.6	76.2	76.2	76.2
4	74.0	74.4	74.4	74.4	74.0	74.4	74.4	74.4
5	74.1	74.3	74.0	74.3	74.1	74.3	74.0	74.3
6	69.4	69.3	69.1	69.3	69.4	69.3	69.1	69.3
7	69.4	69.2	69.6	69.2	69.4	69.2	69.6	69.2
8	66.2	65.8	66.0	66.0	66.2	65.8	66.0	66.0
9	64.3	65.8	62.7	62.7	64.3	65.8	62.7	62.7
10	54.7	59.2	56.2	56.1	54.7	59.2	56.2	56.1
11	54.7	59.2	56.8	56.2	54.7	59.2	56.8	56.2
12	54.7	59.2	56.1	56.2	54.7	59.2	56.1	56.2
13	62.9	62.5	62.7	62.7	62.9	62.5	62.7	62.7
14	66.2	65.8	66.0	66.0	66.2	65.8	66.0	66.0
15	72.8	72.4	72.6	72.6	72.8	72.4	72.6	72.6
16	75.1	75.7	74.3	74.1	75.1	75.7	74.3	74.1
17	76.1	75.7	74.3	74.0	76.1	75.7	74.3	74.0
18	76.1	75.7	76.1	75.7	76.1	75.7	76.1	75.7
19	72.8	72.4	72.9	72.3	72.8	72.4	72.9	72.3
20	66.2	65.8	62.9	62.4	66.2	65.8	62.9	62.4
21	62.9	62.5	63.1	62.4	62.9	62.5	63.1	62.4
22	54.7	59.2	59.8	59.0	54.7	59.2	59.8	59.0
23	54.7	59.2	65.4	65.6	54.7	59.2	65.4	65.6
24	60.3	65.8	63.1	62.3	60.3	65.8	63.1	62.3
25	60.2	65.8	63.1	62.4	60.2	65.8	63.1	62.4
26	64.4	69.3	72.9	72.4	64.4	69.3	72.9	72.4
27	64.4	69.3	74.3	74.1	64.4	69.3	74.3	74.1
28	74.1	74.3	85.8	85.8	74.1	74.3	85.8	85.8
29	74.0	74.4	74.1	74.3	74.0	74.4	74.1	74.3
30	75.6	76.2	72.4	72.9	75.6	76.2	72.4	72.9
31	65.6	66.4	62.4	63.1	65.6	66.4	62.4	63.1
32	62.3	63.2	62.3	63.1	62.3	63.2	62.3	63.1
33	54.0	59.9	65.6	66.4	54.0	59.9	65.6	66.4
34	54.0	59.9	54.0	59.8	54.0	59.9	54.0	59.8

137
 620-0011-55
 6/78
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 17.24

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
50.6	50.6	50.6	50.6	50.6	59.3	51.2	58.7
50.7	50.7	50.7	50.7	50.7	59.1	51.4	58.4
54.1	54.1	54.1	54.1	54.1	61.9	54.7	61.3
57.5	57.5	57.5	57.5	57.5	64.5	64.2	70.0
67.3	67.3	67.3	67.3	67.3	73.0	64.7	69.5
71.3	71.3	71.3	71.3	71.3	75.1	68.3	72.0
72.5	72.5	72.5	72.5	72.5	73.9	71.9	74.5
65.3	65.3	65.3	65.3	65.3	63.6	72.5	73.9
62.8	62.8	62.8	62.8	62.8	62.8	60.9	67.3
61.2	61.2	61.2	61.2	61.2	54.2	61.1	60.9
57.2	57.2	57.2	57.2	57.2	58.9	58.2	57.8
57.1	57.1	57.1	57.1	57.1	52.6	52.1	51.7
57.0	57.0	57.0	57.0	57.0	52.8	48.8	48.8
59.8	59.8	59.8	59.8	59.8	52.9	51.7	52.1
62.7	62.7	62.7	62.7	62.7	56.1	57.8	58.2
68.7	68.7	68.7	68.7	68.7	59.3	60.9	61.1
71.7	71.7	71.7	71.7	71.7	65.5	67.3	66.6
71.7	71.7	71.7	71.7	71.7	68.6	71.9	72.5
71.7	71.7	71.7	71.7	71.7	68.6	74.5	71.9
68.7	68.7	68.7	68.7	68.7	68.6	68.0	68.3
62.7	62.7	62.7	62.7	62.7	63.5	64.7	64.7
59.8	59.8	59.8	59.8	59.8	59.3	70.0	64.2
57.0	57.0	57.0	57.0	57.0	56.1	61.3	54.4
57.1	57.1	57.1	57.1	57.1	52.9	58.4	51.4
57.2	57.2	57.2	57.2	57.2	52.8	58.7	51.2
63.2	63.2	63.2	63.2	63.2	52.6	64.6	57.4
62.8	62.8	62.8	62.8	62.8	58.9	61.6	54.5
65.3	65.3	65.3	65.3	65.3	54.2	61.0	54.0
64.5	64.5	64.5	64.5	64.5	62.8	64.4	64.8
72.5	72.5	72.5	72.5	72.5	63.6	74.4	72.0
71.3	71.3	71.3	71.3	71.3	73.4	74.3	74.3
67.3	67.3	67.3	67.3	67.3	75.1	72.0	74.4
57.5	57.5	57.5	57.5	57.5	73.0	64.8	64.4
54.1	54.1	54.1	54.1	54.1	64.5	54.9	61.0
50.6	50.6	50.6	50.6	50.6	61.9	54.5	61.4
50.7	50.7	50.7	50.7	50.7	59.1	57.4	64.6
50.6	50.6	50.6	50.6	50.6	59.3	51.2	58.7

139
 8/19
 SS-1100-02
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SHUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 22.99
 PEAK STRESS INTENSITIES (KSI)

	PRIMARY SIDE				SECONDARY SIDE			
	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
0	43.1	58.7	44.2	57.6	43.1	58.7	44.2	57.6
10	43.3	58.5	44.6	57.2	43.3	58.5	44.6	57.2
20	45.7	60.8	47.8	59.7	45.7	60.8	47.8	59.7
30	50.3	62.8	57.0	67.4	50.3	62.8	57.0	67.4
40	54.9	70.1	57.9	66.5	54.9	70.1	57.9	66.5
50	64.4	71.3	61.7	68.4	64.4	71.3	61.7	68.4
60	66.6	69.2	65.5	70.2	66.6	69.2	65.5	70.2
70	69.1	58.6	66.6	64.2	69.1	58.6	66.6	64.2
80	61.7	57.1	61.8	62.6	61.7	57.1	61.8	62.6
90	54.8	53.3	56.8	56.4	54.8	53.3	56.8	56.4
100	50.5	52.7	54.1	53.4	50.5	52.7	54.1	53.4
110	55.0	60.8	48.4	47.8	55.0	60.8	48.4	47.8
120	54.8	47.0	43.3	45.3	54.8	47.0	43.3	45.3
130	54.6	47.2	47.8	48.4	54.6	47.2	47.8	48.4
140	55.1	50.4	53.4	54.1	55.1	50.4	53.4	54.1
150	55.6	53.5	50.4	56.8	55.6	53.5	50.4	56.8
160	65.0	59.4	62.6	61.8	65.0	59.4	62.6	61.8
170	67.7	62.3	64.2	66.6	67.7	62.3	64.2	66.6
180	67.7	62.3	70.2	65.5	67.7	62.3	70.2	65.5
190	67.7	62.3	68.4	61.7	67.7	62.3	68.4	61.7
200	63.0	59.4	66.5	57.9	63.0	59.4	66.5	57.9
210	59.6	53.5	67.4	57.0	59.6	53.5	67.4	57.0
220	57.1	50.4	54.7	47.8	57.1	50.4	54.7	47.8
230	55.6	47.2	51.2	44.6	55.6	47.2	51.2	44.6
240	54.8	47.0	57.6	44.2	54.8	47.0	57.6	44.2
250	53.0	46.8	63.1	50.1	53.0	46.8	63.1	50.1
260	54.9	52.7	54.9	47.6	54.9	52.7	54.9	47.6
270	54.8	53.3	54.3	44.2	54.8	53.3	54.3	44.2
280	61.7	57.1	66.3	58.1	61.7	57.1	66.3	58.1
290	60.1	58.6	70.0	65.7	60.1	58.6	70.0	65.7
300	60.6	64.2	73.5	73.5	60.6	64.2	73.5	73.5
310	64.4	71.3	65.7	70.0	64.4	71.3	65.7	70.0
320	54.9	70.1	58.1	66.3	54.9	70.1	58.1	66.3
330	50.3	62.8	48.2	54.3	50.3	62.8	48.2	54.3
340	46.7	60.8	47.0	50.1	46.7	60.8	47.0	50.1
350	43.3	58.5	44.6	47.8	43.3	58.5	44.6	47.8
360	43.1	58.7	44.2	44.6	43.1	58.7	44.2	44.6

140
 6/78
 620-0011-55
 LFW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 28.74

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
0	5.0	18.7	6.3	17.0	33.3	58.0	35.0	56.3
5	5.0	18.7	6.3	17.0	33.3	57.7	35.7	55.6
10	5.0	18.7	6.3	17.0	33.3	57.4	36.8	57.6
15	5.0	18.7	6.3	17.0	33.3	60.7	47.6	64.0
20	5.0	18.7	6.3	17.0	33.3	66.4	48.9	62.7
25	5.0	18.7	6.3	17.0	33.3	66.3	53.0	63.6
30	5.0	18.7	6.3	17.0	33.3	62.9	57.1	64.6
35	5.0	18.7	6.3	17.0	33.3	52.1	58.8	62.9
40	5.0	18.7	6.3	17.0	33.3	49.7	55.1	56.5
45	5.0	18.7	6.3	17.0	33.3	45.6	51.1	50.4
50	5.0	18.7	6.3	17.0	33.3	44.6	48.7	47.7
55	5.0	18.7	6.3	17.0	33.3	39.2	43.7	42.6
60	5.0	18.7	6.3	17.0	33.3	39.9	40.6	40.6
65	5.0	18.7	6.3	17.0	33.3	42.9	42.6	43.7
70	5.0	18.7	6.3	17.0	33.3	45.4	47.7	48.7
75	5.0	18.7	6.3	17.0	33.3	51.3	50.4	51.1
80	5.0	18.7	6.3	17.0	33.3	54.0	50.5	55.1
85	5.0	18.7	6.3	17.0	33.3	54.0	62.9	54.8
90	5.0	18.7	6.3	17.0	33.3	54.0	64.6	57.1
95	5.0	18.7	6.3	17.0	33.3	54.0	63.6	53.0
100	5.0	18.7	6.3	17.0	33.3	51.3	62.7	48.9
105	5.0	18.7	6.3	17.0	33.3	49.9	64.0	47.6
110	5.0	18.7	6.3	17.0	33.3	42.9	57.6	38.8
115	5.0	18.7	6.3	17.0	33.3	34.9	55.6	33.7
120	5.0	18.7	6.3	17.0	33.3	34.5	50.3	33.0
125	5.0	18.7	6.3	17.0	33.3	37.2	58.0	38.4
130	5.0	18.7	6.3	17.0	33.3	44.6	57.0	39.5
135	5.0	18.7	6.3	17.0	33.3	44.7	62.3	44.3
140	5.0	18.7	6.3	17.0	33.3	52.1	64.3	57.4
145	5.0	18.7	6.3	17.0	33.3	62.9	65.9	65.9
150	5.0	18.7	6.3	17.0	33.3	66.3	57.4	64.3
155	5.0	18.7	6.3	17.0	33.3	66.4	44.3	62.3
160	5.0	18.7	6.3	17.0	33.3	60.7	39.5	57.0
165	5.0	18.7	6.3	17.0	33.3	54.4	34.4	58.0
170	5.0	18.7	6.3	17.0	33.3	57.7	40.5	61.0
175	5.0	18.7	6.3	17.0	33.3	54.0	35.0	56.3

141
 26/9
 20-001-55
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 34.48
 PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
18.3	17.9	15.7	15.4	21.1	57.2	23.6	54.7
17.7	17.4	15.3	15.4	21.6	56.7	24.6	53.7
15.5	16.2	15.3	16.7	25.0	57.6	27.5	55.1
16.6	15.5	15.3	15.3	28.9	58.0	33.8	54.8
17.0	15.5	15.3	15.3	38.2	61.8	37.8	57.8
17.6	15.5	15.3	15.3	44.1	60.2	42.2	57.7
18.1	15.5	15.3	15.3	44.1	55.1	46.6	57.7
18.4	15.5	15.3	15.3	47.4	43.9	44.1	55.1
18.5	15.5	15.3	15.3	50.9	40.4	46.8	48.8
18.5	15.5	15.3	15.3	51.0	35.4	44.0	43.0
18.5	15.5	15.3	15.3	52.5	34.4	42.1	40.5
18.5	15.5	15.3	15.3	48.7	29.6	37.7	36.2
18.5	15.5	15.3	15.3	48.2	30.1	36.4	34.8
18.5	15.5	15.3	15.3	47.7	30.6	36.2	37.7
18.5	15.5	15.3	15.3	44.1	33.5	40.5	42.1
18.5	15.5	15.3	15.3	50.5	36.4	43.0	44.0
18.5	15.5	15.3	15.3	56.3	41.3	48.8	46.8
18.5	15.5	15.3	15.3	57.7	43.7	53.1	44.1
18.5	15.5	15.3	15.3	57.7	43.7	57.7	47.6
18.5	15.5	15.3	15.3	59.3	43.7	57.7	42.2
18.5	15.5	15.3	15.3	59.3	41.3	57.8	37.8
18.5	15.5	15.3	15.3	50.5	36.4	54.8	33.8
18.5	15.5	15.3	15.3	44.1	33.5	51.1	27.5
18.5	15.5	15.3	15.3	44.1	30.6	53.7	24.6
18.5	15.5	15.3	15.3	44.1	30.1	56.7	23.6
18.5	15.5	15.3	15.3	48.2	24.6	58.5	24.6
18.5	15.5	15.3	15.3	52.5	34.4	55.6	27.5
18.5	15.5	15.3	15.3	50.9	35.9	54.1	28.9
18.5	15.5	15.3	15.3	44.1	40.4	57.3	38.2
18.5	15.5	15.3	15.3	44.1	43.4	57.2	47.6
18.5	15.5	15.3	15.3	44.1	55.1	50.5	50.5
18.5	15.5	15.3	15.3	44.1	60.2	47.1	55.1
18.5	15.5	15.3	15.3	44.1	61.8	38.2	57.7
18.5	15.5	15.3	15.3	44.1	58.0	28.9	54.8
18.5	15.5	15.3	15.3	44.1	57.6	27.0	55.1
18.5	15.5	15.3	15.3	44.1	56.7	20.4	54.7
18.5	15.5	15.3	15.3	44.1	57.2	23.6	54.7

20
 142
 620-001-55
 6/78
 LEW

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 40.23

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

PRIMARY SIDE				SECONDARY SIDE			
CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
33.1	16.9	24.5	11.4	6.2	56.2	4.7	52.8
33.1	16.9	24.5	11.4	0.9	55.3	11.8	51.4
33.1	16.9	24.5	11.4	10.4	55.5	13.8	52.1
33.1	16.9	24.5	11.4	14.5	54.8	21.4	52.8
33.1	16.9	24.5	11.4	13.5	56.2	24.2	52.0
33.1	16.9	24.5	11.4	30.5	52.7	29.1	50.6
33.1	16.9	24.5	11.4	37.4	45.7	33.9	44.2
33.1	16.9	24.5	11.4	38.8	36.0	37.4	45.7
33.1	16.9	24.5	11.4	43.7	29.1	36.7	39.5
33.1	16.9	24.5	11.4	45.1	22.2	35.4	34.0
33.1	16.9	24.5	11.4	47.2	22.2	34.0	31.9
33.1	16.9	24.5	11.4	44.6	18.7	30.5	24.4
33.1	16.9	24.5	11.4	43.7	18.7	27.8	21.8
33.1	16.9	24.5	11.4	43.0	14.4	28.4	30.5
33.1	16.9	24.5	11.4	43.7	22.2	31.9	35.0
33.1	16.9	24.5	11.4	44.4	22.2	34.0	35.4
33.1	16.9	24.5	11.4	47.2	22.2	34.5	36.7
33.1	16.9	24.5	11.4	48.5	31.2	35.7	37.6
33.1	16.9	24.5	11.4	48.5	31.2	44.2	41.9
33.1	16.9	24.5	11.4	47.2	31.2	50.6	42.1
33.1	16.9	24.5	11.4	44.4	24.9	44.8	34.6
33.1	16.9	24.5	11.4	43.7	22.2	52.1	33.8
33.1	16.9	24.5	11.4	43.0	19.4	51.4	31.1
33.1	16.9	24.5	11.4	43.7	18.7	52.8	29.7
33.1	16.9	24.5	11.4	44.4	18.0	55.5	13.8
33.1	16.9	24.5	11.4	47.2	22.2	52.8	13.1
33.1	16.9	24.5	11.4	45.1	24.2	50.7	15.9
33.1	16.9	24.5	11.4	43.0	34.0	48.5	34.6
33.1	16.9	24.5	11.4	39.8	45.0	45.0	45.0
33.1	16.9	24.5	11.4	30.5	52.7	35.6	48.4
33.1	16.9	24.5	11.4	23.3	56.2	24.4	51.3
33.1	16.9	24.5	11.4	20.4	54.8	19.4	50.7
33.1	16.9	24.5	11.4	17.1	52.7	13.1	51.4
33.1	16.9	24.5	11.4	10.4	50.3	11.8	52.8
33.1	16.9	24.5	11.4	3.2	55.5	11.3	55.5
33.1	16.9	24.5	11.4	0.9	52.7	11.3	55.5
33.1	16.9	24.5	11.4	6.2	56.2	4.7	52.8

143
 620-0011-53
 6/78
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 45.98

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
0	50.8	15.8	46.1	-11.2	-11.4	55.2	-6.8	50.5
1	49.8	15.8	44.4	-9.6	-10.5	55.2	-5.0	48.7
2	49.4	15.8	43.1	-7.1	-7.0	51.1	-2.4	48.5
3	45.9	17.7	43.1	-1.3	-2.6	49.6	4.5	48.2
4	43.5	17.7	39.1	2.4	5.2	43.9	8.2	45.2
5	37.4	17.7	36.1	7.4	16.3	34.6	13.6	42.2
6	32.2	17.7	32.1	7.4	19.0	32.6	18.9	34.3
7	29.2	17.7	32.1	7.7	20.2	29.5	23.5	34.4
8	25.8	17.7	22.1	17.1	20.2	24.8	24.8	33.3
9	10.3	17.7	18.3	20.1	10.4	20.2	20.2	23.3
10	2.5	17.7	15.5	20.7	7.6	24.5	24.5	21.7
11	0.0	17.7	15.5	18.0	4.9	22.0	22.0	19.3
12	0.0	17.7	15.5	18.0	3.5	22.0	22.0	19.3
13	0.0	17.7	15.5	18.0	2.8	22.0	22.0	19.3
14	0.0	17.7	15.5	18.0	2.2	22.0	22.0	19.3
15	0.0	17.7	15.5	18.0	1.6	22.0	22.0	19.3
16	0.0	17.7	15.5	18.0	1.0	22.0	22.0	19.3
17	0.0	17.7	15.5	18.0	0.4	22.0	22.0	19.3
18	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
19	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
20	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
21	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
22	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
23	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
24	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
25	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
26	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
27	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
28	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
29	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
30	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
31	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
32	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
33	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
34	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
35	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
36	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
37	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
38	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
39	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
40	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
41	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
42	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
43	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
44	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
45	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
46	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
47	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
48	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
49	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
50	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
51	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
52	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
53	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
54	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
55	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
56	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
57	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
58	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
59	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
60	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
61	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
62	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
63	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
64	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
65	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
66	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
67	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
68	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
69	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
70	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
71	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
72	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
73	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
74	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
75	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
76	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
77	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
78	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
79	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
80	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
81	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
82	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
83	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
84	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
85	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
86	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
87	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
88	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
89	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
90	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
91	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
92	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
93	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
94	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
95	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
96	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
97	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
98	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
99	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3
100	0.0	17.7	15.5	18.0	0.0	22.0	22.0	19.3

144
 6/78
 L.W.
 620-0011-55

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 51.72

PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

	CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
0000	71.3	-16.6	65.3	-9.7	-32.0	53.9	-26.0	48.0
0005	70.0	-13.4	62.2	-6.3	-30.8	52.8	-23.6	45.6
0010	69.6	-9.0	62.2	-3.9	-27.2	50.4	-21.2	44.4
0015	69.9	-3.3	62.2	3.5	-22.4	46.8	-15.2	42.0
0020	63.7	7.6	58.1	10.3	-14.1	42.0	-10.5	37.3
0025	55.2	19.9	56.1	17.1	-6.5	33.7	-4.5	32.5
0030	46.3	32.3	46.3	24.0	7.4	21.8	1.5	27.7
0035	30.5	45.9	30.5	31.8	17.0	8.6	7.4	21.8
0040	20.2	49.2	36.4	31.8	25.3	3.3	11.0	17.8
0045	13.4	49.2	30.8	32.5	30.1	-5.7	13.4	11.0
0050	9.9	51.7	25.5	33.7	33.7	-9.3	13.4	9.8
0055	5.7	52.0	25.5	35.7	32.5	-11.7	12.2	8.6
0060	5.9	48.8	25.5	35.4	32.5	-10.5	4.8	4.8
0065	1.3	48.8	31.6	30.0	31.3	-9.3	8.6	2.2
0070	1.3	48.8	31.6	25.0	30.1	-6.9	4.8	3.4
0075	1.3	48.8	31.6	35.6	28.9	-4.5	11.0	1.0
0080	1.3	48.8	31.6	50.3	24.9	-2.1	15.8	1.4
0085	0.7	50.0	24.9	56.3	24.9	-.9	21.8	1.5
0090	0.7	50.0	17.0	58.1	28.9	-.9	32.5	4.5
0095	0.7	48.8	10.0	62.2	28.9	-2.1	37.3	10.5
0100	0.6	48.8	3.3	62.2	30.1	-3.4	42.0	46.4
0105	0.6	48.8	0.0	62.2	31.3	-5.7	46.4	45.6
0110	0.6	48.8	0.0	62.2	31.3	-9.3	45.6	42.0
0115	0.6	48.8	0.0	62.2	32.5	-10.5	48.0	48.0
0120	0.6	48.8	0.0	62.2	33.7	-11.7	48.0	48.0
0125	0.6	48.8	0.0	62.2	33.7	-9.3	45.6	46.4
0130	0.6	48.8	0.0	62.2	33.7	-5.7	42.0	42.0
0135	0.6	48.8	0.0	62.2	33.7	-.9	30.1	30.1
0140	0.6	48.8	0.0	62.2	33.7	8.6	20.5	20.5
0145	0.6	48.8	0.0	62.2	33.7	21.8	13.8	13.8
0150	0.6	48.8	0.0	62.2	33.7	33.7	2.7	2.7
0155	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0160	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0165	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0170	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0175	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0180	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0185	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0190	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0195	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0200	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0205	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0210	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0215	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0220	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0225	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0230	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0235	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0240	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0245	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0250	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0255	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0260	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0265	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0270	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0275	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0280	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0285	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0290	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0295	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7
0300	0.6	48.8	0.0	62.2	33.7	42.0	2.7	2.7

145
 6/78
 020-0011-55
 LEW

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN -- LWR T.S. ANALYSIS --- BY L. WHITE - ITER 72

CALCULATION RADIUS 57.47
 PEAK STRESS INTENSITIES (KSI)

PRIMARY SIDE

SECONDARY SIDE

CASE 1	CASE 2	CASE 3	CASE 4	CASE 1	CASE 2	CASE 3	CASE 4
94.9	-13.3	87.4	-3.8	-55.5	52.6	-48.0	45.1
93.6	-11.8	84.4	-2.8	-54.0	51.1	-45.0	42.1
91.8	-5.9	84.3	1.5	-50.4	47.3	-42.4	39.8
88.7	1.5	85.4	13.3	-45.2	41.9	-37.4	34.2
85.9	16.3	79.4	19.6	-37.2	33.4	-31.4	28.2
77.7	29.7	74.9	28.3	-26.0	22.0	-23.2	21.4
73.7	44.7	70.2	37.2	-11.0	7.0	-18.5	14.5
68.0	52.5	62.7	46.7	3.5	-7.0	-11.0	7.0
63.0	63.0	52.4	46.4	14.0	-17.5	-4.8	1.2
67.6	72.6	43.5	45.6	20.9	-24.2	-.1	-3.1
72.1	77.1	40.7	43.2	25.4	-28.7	.7	-3.8
69.3	69.3	36.6	40.9	27.1	-30.0	.4	-3.6
67.8	66.3	35.5	35.5	25.6	-28.5	-1.3	-1.3
66.3	66.3	40.9	35.4	24.1	-27.0	-3.6	.4
65.2	65.2	45.2	40.7	21.7	-24.8	-3.8	.7
65.6	68.9	46.5	43.6	19.4	-22.7	-3.1	.1
68.9	70.3	44.7	52.4	17.7	-21.4	1.2	-4.8
70.3	70.3	37.2	60.7	16.9	-20.7	7.0	-11.0
70.3	68.9	28.3	74.8	15.7	-20.7	14.5	-18.5
68.9	65.5	19.6	79.4	17.7	-21.4	28.2	-25.2
65.5	65.5	13.3	85.4	19.4	-22.7	34.2	-31.4
66.3	67.8	1.5	84.3	21.7	-24.8	34.2	-37.4
66.3	69.3	-2.8	84.4	24.1	-27.0	42.1	-42.4
67.8	72.1	-5.8	87.4	25.6	-28.5	45.1	-45.0
69.3	77.1	.0	90.2	27.1	-30.0	43.4	-48.0
72.1	85.9	.1	93.6	25.4	-28.7	41.3	-44.4
67.6	91.8	9.3	87.7	20.9	-24.2	36.7	-34.9
63.0	93.6	20.9	81.2	14.0	-17.5	26.7	-30.4
52.5	94.9	69.7	68.0	3.5	-7.0	13.0	-17.0
29.7	93.6	58.7	58.7	-11.0	7.0	-2.2	-2.2
16.3	91.8	58.7	58.7	-26.0	22.0	-17.0	13.0
1.5	88.7	77.7	77.7	-37.2	33.4	-30.4	26.7
-.1	85.9	85.4	85.4	-45.2	41.9	-34.9	36.7
-.1	84.4	84.4	84.4	-50.4	47.3	-44.4	41.3
-.1	84.3	85.4	85.4	-54.0	51.1	-48.0	43.4
-.1	87.4	87.4	87.4	-55.5	52.6	-48.0	45.1

146
 6/78
 620-0011-55
 LEW

STRESS CONCENTRATION

The Stress Concentration factors are taken from Page B-13-1 of Reference 2. These are, of course, still appropriate since the geometry analyzed is the same.

<u>JUNCTURE</u>	<u>K_T</u>		<u>K_B</u>	
	<u>INSIDE</u>	<u>OUTSIDE</u>	<u>INSIDE</u>	<u>OUTSIDE</u>
1	1.0	1.0	1.0	1.0
2	2.75	1.0	2.31	1.0
3	1.0	1.0	1.0	1.0
4	3.39	1.0	2.94	1.0

INTERACTION JUNCTURE STRESS SUMMARY

To evaluate the interaction junctures, the appropriate stress concentration factors were input, along with the sum of the free-body thermal and 91249 interaction stresses, into B&W Program 91076 'Stress Summary Program'. This program calculates stress intensities and ranges for both primary plus secondary and peak classifications. These values will be used in meeting the stress and fatigue requirements of the Design Code.

It should be noted that there is a slight difference in the classification of stresses between the original analysis (ASME Code, Section III, 1965 Edition - Ref. 1) and this analysis (ASME Code, Section III, 1977 Edition).

More specifically, the 1965 code classified the thermal stress due to the equivalent linear portion of the radial gradient as 'Peak Stress'. However, the 1977 code designates this thermal stress as 'Secondary'.

Therefore, the primary + secondary stresses input into Program 91076 are actually the sum of the 91249 stresses (Example Page 132) and the 91206 stresses (Pri. + Sec. Free-Body Thermal Stresses - Page 88 that include the effect of the linear portion of the thermal radial gradient).

Consequently, the 'Peak Increment Free-Body Thermal Stresses' (Page 93 Example) includes the thermal stress resulting from the total radial gradient minus equivalent linear portion mentioned above. These were input into 91076 Program as peak free-body thermal stresses.

In essence, the above discussion means that the classifications of the 'Primary + Secondary' 91076 stresses are conservative compared to the original analysis and the classification of the total pri. + sec. + peak stresses have not changed.

The following pages are the total computer output from Program 91076.

LEW
620-0011-55
6/78

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** -BICCC6D

SHJD RAPID COOLDOWN---STRESS SUMMARY FOR LOWER TUBESHEET ANALYSIS---BY L. WHITE 05/16/78

INPUT DATA

JUNCTURE NO. 1
 STRESS CONCENTRATION FACTORS
 INSIDE OUTSIDE
 BENDING TENSION BENDING TENSION
 1.000 1.000 1.000 1.000

INPUT STRESSES (IN KSI)

ITER	LONGITUDINAL		CIRCUMFERENTIAL		RADIAL		LONGITUDINAL FACE THERMAL		CIRCUMFERENTIAL FACE THERMAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	7:	6:	9:	-1:	0:	0:	0:	0:	0:	0:
39	9:	-1:	-4:	0:	39:	10:	38:	11:	11:	11:
43	14:	-5:	45:	0:	-35:	6:	14:	17:	17:	17:
49	14:	-6:	7:	-1:	-31:	-4:	-31:	-5:	-5:	-5:
72	-8:	0:	-2:	0:	5:	2:	5:	2:	2:	2:

LEW
 620-0011-55
 6/78
 149

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** L01CC60

STRESS INTENSITY PROGRAM OUTPUT (IN KSI)

JUNCTURE NO. 1

ITER	PRIMARY + SECONDARY STRESS INTENSITIES				PEAK STRESS INTENSITIES			
	L - H	H - R	H - I	I - L	L - K	K - R	R - L	L - L
26	-4:	12:	-8:	-6:	-3:	12:	9:	-8:
39	-3:	35:	-9:	-25:	-2:	73:	7:	-48:
45	-34:	65:	-11:	-33:	-26:	59:	3:	-26:
49	-11:	34:	-16:	-18:	-19:	3:	2:	15:
72	-20:	17:	-2:	-20:	2:	17:	0:	3:

STRESS OUTPUT ANALYSIS

STRESS	INSIDE		OUTSIDE		INSIDE		OUTSIDE	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	0.0	3.0	9.0	8.0	2.0	73.0	9.0	15.0
MINIMUM	-34.0	-11.0	-4.0	-16.0	-10.0	0.0	0.0	-48.0
RANGE	34.0	14.0	13.0	24.0	12.0	73.0	9.0	63.0
MEAN	-17.0	-4.0	22.5	-4.0	-4.0	36.5	4.5	-16.5
ALTERNAT	-17.0	7.0	6.5	12.0	6.0	36.5	4.5	31.5

LEW
620-001-55
6/78
150

***** FJLL CERTIFICATION *****

***** FULL CERTIFICATION *****

***** FULL CERTIFICATION *****

L91CC6D

SMJD RAPID COOLDOWN---STRESS SUMMARY FOR LOWER TUBESHEET ANALYSIS---BY L. WHITE 05/16/78

INPUT DATA

JUNCTURE NO. 2

STRESS CONCENTRATION FACTORS

INSIDE OUTSIDE

BENDING TENSION BENDING TENSION
2.710 2.750 1.000 1.000

INPUT STRESSES (IN KSI)

ITER	LONGITUDINAL		CIRCUMFERENTIAL		RADIAL		LONGITUDINAL FREE THERMAL		CIRCUMFERENTIAL FREE THERMAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	7.	6.	8.	6.	-1.	0.	1.	-2.	-1.	-2.
30	5.	4.	22.	-7.	0.	0.	47.	10.	45.	11.
45	8.	1.	24.	-10.	0.	0.	27.	-15.	27.	-18.
40	10.	-3.	23.	-3.	-1.	0.	-27.	-16.	-26.	-17.
72	-10.	1.	0.	-17.	0.	0.	8.	3.	7.	3.

151
8/78
SS-1100-02
LEW

**** FULL CERTIFICATION **** **** FULL CERTIFICATION **** **** FULL CERTIFICATION **** L9IC60

STRESS INTENSITY PROGRAM OUTPUT (IN KSI)

JUNCTURE NO. 2

ITER	PRIMARY + SECONDARY STRESS INTENSITIES						PEAK STRESS INTENSITIES					
	L - H		H - R		R - L		L - H		H - R		R - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
26	-1.	0.	9.	6.	-8.	-6.	13.	0.	8.	4.	-21.	-4.
30	-15.	11.	22.	-7.	-6.	-4.	-4.	10.	67.	4.	-63.	-14.
45	-23.	11.	29.	-19.	-6.	-1.	-15.	14.	57.	-28.	-62.	14.
49	-4.	0.	24.	-3.	-16.	3.	10.	1.	2.	-20.	-11.	19.
72	-10.	18.	0.	-17.	10.	-1.	-22.	18.	5.	-14.	17.	-4.

STRESS OUTPUT ANALYSIS

STRESS	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	0.0	18.0	29.0	6.0	10.0	3.0	12.4	14.0	67.4	4.0	17.1	19.0
MINIMUM	-23.0	0.0	0.0	-17.0	-16.0	-6.0	-21.9	0.0	0.0	-28.0	-63.1	-14.0
RAVGE	-23.0	18.0	29.0	-23.0	26.0	9.0	34.8	18.0	67.4	32.0	80.1	33.0
MEAN	-11.5	9.0	14.5	-5.5	-1.0	-1.5	-4.5	9.0	33.7	-12.0	-23.0	2.5
ALTERNAT	11.5	9.0	14.5	11.5	13.0	4.5	17.4	9.0	33.7	16.0	40.1	16.5

LEW
620-0011-55
6/78
152

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** .P1CC60

SMJD RAPID COOLDOWN---STRESS SUMMARY FOR LOWER PURESHEET ANALYSIS---BY L. WHITE 05/16/78

INPUT DATA

JUNCTURE NO. 3

STRESS CONCENTRATION FACTORS

	INSIDE	OUTSIDE
BENDING TENSION	1.000	1.000
WELDING TENSION	1.000	1.000

INPUT STRESSES (IN KSI)

ITER	LONGITUDINAL		CIRCUMFERENTIAL		RADIAL		LONGITUDINAL FREE THERMAL		CIRCUMFERENTIAL FREE THERMAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	4.	11.	7.	9.	0.	0.	0.	0.	0.	0.
30	-1.	16.	3.	12.	-2.	-2.	-2.	-1.	-2.	-1.
45	-2.	14.	0.	8.	-1.	0.	0.	0.	2.	0.
46	-3.	14.	3.	7.	-2.	0.	5.	1.	5.	1.
72	63.	-49.	32.	-40.	-2.	0.	7.	6.	7.	6.

LEW
620-0011-55
6/78
153

STRESS INTENSITY PROGRAM OUTPUT (IN KSI)

JUNCTURE NO. 3

ITER	PRIMARY + SECONDARY STRESS INTENSITIES				PEAK STRESS INTENSITIES					
	L - H		H - R		L - H		H - R		R - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
26	-3.	2.	9.	4.	-6.	-11.	-3.	2.	9.	-6.
39	-4.	4.	12.	1.	-1.	-16.	-4.	4.	3.	11.
45	-2.	6.	1.	4.	1.	-14.	9.	9.	3.	-1.
49	-6.	7.	5.	7.	-6.	-16.	7.	10.	10.	-4.
72	31.	-9.	34.	-41.	-65.	49.	1.	-9.	41.	-72.

STRESS OUTPUT ANALYSIS

STRESS	INSIDE		OUTSIDE		INSIDE		OUTSIDE		INSIDE		OUTSIDE	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	31.0	7.0	36.0	12.0	1.0	69.0	31.0	7.0	41.0	11.0	1.0	43.0
MINIMUM	-5.0	-9.0	0.0	-40.0	-65.0	-16.0	-6.0	-9.0	0.0	-34.0	-72.0	-15.0
AVERAGE	37.0	16.0	34.0	52.0	66.0	16.0	37.0	12.0	41.0	45.0	73.0	58.0
MEAN	12.5	-1.0	17.0	-14.0	-32.0	16.5	12.5	-1.0	20.5	-11.5	-35.5	14.0
ALTERNAT	19.5	8.0	17.0	26.0	33.0	12.5	18.5	8.0	20.5	22.5	36.5	29.0

LEW
620-0011-55
6/78
154

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** .01CC60

SMJD RAPID COOLDOWN---STRESS SUMMARY FOR LOWER TUBESHEET ANALYSIS---BY L. WHITE 05/16/78

INPUT DATA

JUNCTURE NO. 4

STRESS CONCENTRATION FACTORS

INSIDE		OUTSIDE	
BENDING TENSION		BENDING TENSION	
2.940	3.390	1.000	1.000

INPUT STRESSES (IN KSI)

ITER	LONGITUDINAL		CIRCUMFERENTIAL		RADIAL		LONGITUDINAL FREE THERMAL		CIRCUMFERENTIAL FREE THERMAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	4.	12.	4.	6.	-2.	0.	0.	0.	0.	0.
30	-3.	17.	1.	6.	-2.	0.	-2.	-2.	-2.	-2.
45	-3.	15.	6.	12.	-2.	0.	3.	0.	3.	0.
60	-5.	15.	6.	4.	-2.	0.	6.	2.	6.	0.
72	74.	-60.	33.	-53.	-2.	0.	7.	5.	7.	5.

155
8/18
620-0011-55
LEW

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** LRICC6D

STRESS INTENSITY PROGRAM OUTPUT (IN KSI)

JUNCTURE NO. 4

ITER	PRIMARY + SECONDARY STRESS INTENSITIES		L - H		H - H		H - L		L - H		H - H		H - L	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	0.	6.	6.	-12.	14.	6.	4.	-17.	6.	-17.	6.	6.	-17.	6.
39	-4.	3.	1.	-17.	-1.	11.	-5.	4.	11.	11.	6.	4.	6.	6.
45	-9.	8.	12.	-15.	-1.	3.	6.	12.	6.	12.	12.	12.	12.	12.
49	-11.	5.	3.	-15.	-13.	6.	81.	6.	6.	6.	4.	4.	4.	4.
72	41.	-7.	35.	60.	149.	-7.	81.	-48.	-7.	-48.	-230.	-230.	-230.	-230.

STRESS OUTPUT ANALYSIS

STRESS	INSIDE		OUTSIDE		INSIDE		OUTSIDE		INSIDE		OUTSIDE	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	41.0	11.0	35.0	12.0	40.0	148.7	11.0	81.0	12.0	5.7	55.0	55.0
MINIMUM	-11.0	-17.0	0.0	-53.0	-17.0	-12.6	-17.0	-4.8	-48.0	-229.7	-17.0	-17.0
RANGE	52.0	18.0	35.0	65.0	57.0	161.3	18.0	85.8	60.0	235.4	72.0	72.0
MEAN	15.0	6.0	17.5	30.5	21.5	64.0	2.0	38.1	-18.0	-112.0	19.0	19.0
ALTERNAT	25.0	9.0	17.5	32.5	34.5	80.7	9.0	42.0	30.0	119.0	36.0	36.0

LEW
620-0011-55
6/78
156

**** FULL CERTIFICATION **** **** FULL CERTIFICATION **** **** FULL CERTIFICATION **** L91CC60

SMJD RAPID COOLDOWN---STRESS SUMMARY FOR LOWER TUBESHEET ANALYSIS---BY L. WHITE 05/16/78

INPUT DATA

JUNCTURE NO. 5

STRESS CONCENTRATION FACTORS

INSIDE OUTSIDE

BENDING TENSION BENDING TENSION
1.000 1.000 1.000 1.000

INPUT STRESSES (IN KSI)

ITER	LONGITUDINAL		CIRCUMFERENTIAL		RADIAL		LONGITUDINAL FREE THERMAL		CIRCUMFERENTIAL FREE THERMAL	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
24	-1.	-2.	-3.	2.	-4.	3.	-6.	0.	-6.	0.
39	0.	-2.	28.	3.	-6.	2.	-47.	-2.	-55.	0.
45	0.	-2.	34.	10.	-7.	3.	-70.	3.	66.	3.
49	-1.	-2.	13.	12.	-6.	4.	-35.	6.	-34.	6.
72	0.	-2.	24.	40.	-4.	16.	-4.	4.	-3.	4.

LEW
620-0011-55
6/78
157

**** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** FULL CERTIFICATION **** -91CC60

STRESS INTENSITY PROGRAM OUTPUT (IN KSI)

JUNCTURE NO. 5

ITER	PRIMARY + SECONDARY STRESS INTENSITIES				PEAK STRESS INTENSITIES							
	L - H	M - H	H - L	R - L	L - H	H - R	R - L	R - L				
26	2:	-4:	1:	-1:	-3:	5:	2:	-4:	-5:	-3:	3:	5:
39	-28:	5:	34:	7:	-5:	4:	-30:	-9:	-21:	10:	51:	6:
45	-34:	-12:	41:	7:	-7:	5:	-170:	-17:	107:	16:	32:	2:
49	-14:	-14:	17:	8:	-3:	6:	-15:	-14:	-17:	28:	0:	14:
72	-29:	-42:	33:	24:	-4:	18:	-30:	-42:	30:	28:	0:	14:

STRESS OUTPUT ANALYSIS

STRESS	INSIDE		OUTSIDE		INSIDE		OUTSIDE		INSIDE		OUTSIDE	
	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE	INSIDE	OUTSIDE
MAXIMUM	2.0	0.0	41.0	24.0	0.0	18.0	2.0	0.0	107.0	28.0	63.0	14.0
MINIMUM	-35.0	-42.0	0.0	-3.0	-7.0	0.0	-170.0	-42.0	-21.0	-1.0	0.0	0.0
GAVGE	35.0	41.0	25.0	25.0	7.0	18.0	172.0	42.0	128.0	29.0	63.0	14.0
MEAN	-15.0	-21.0	20.3	13.5	-3.5	9.0	-86.0	-21.0	43.0	13.5	31.5	7.0
ALTERNAT	19.0	21.0	20.3	13.5	3.5	9.0	86.0	21.0	64.0	14.5	31.5	7.0

LEW
620-0011-55
6/78
158

INTERACTION JUNCTURE STRESS EVALUATION

By examination of the Program 91076 'Stress Summary' (preceding pages), it can be seen that the most highly stressed junctures are Junctures 2 and 4.

Therefore, to simplify the analysis, only these junctures will be evaluated.

JUNCTURE # 2 EVALUATION

THE MAX. PRIMARY PLUS SECONDARY STRESS INTENSITY RANGE RESULTING FROM THE 'RAPID COOLDOWN' AND PREVIOUSLY ANALYZED TRANSIENTS IS DETERMINED IN THE TABLE BELOW.

	STRESS INTENSITY					
	L-H		H-R		R-L	
	INS.	OUT.	INS.	OUT.	INS.	OUT.
MAXIMUM	4.0 ^Δ	18.0*	29.0*	16.0 ^Δ	10.0*	3.0*
MINIMUM	-23.0*	-9.0 ^Δ	0.0 ^Δ	-17.0*	-16.0*	-7.0 ^Δ
RANGE	27.0	27.0	29.0	33.0	26.0	10.0

∴ MAX. RANGE = H-R (OUT) = 33.0 KSI < 35_{mm} = 80.1 KSI

Δ REF. 2, PAGE C-16-5

□ REF. 2, PAGE C-16-13

* REF. PAGE 152 OF THIS ANALYSIS

BABCOCK & WILCOX

DEPARTMENT MT. V - COMP. ENGR. DATE 6/78 BY LEW

JUNCTURE # 2

CHECKED DATE BY

EVALUATION

JOB NO. 620-0011-55

REVISION

SHEET 160 OF

JUNCTION #4 EVALUATION

THE MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY RANGE RESULTING FROM THE 'RAPID COOLDOWN' AND PREVIOUSLY ANALYZED TRANSIENTS IS DETERMINED IN THE TABLE BELOW.

	STRESS INTENSITY					
	L-H		H-R		R-L	
	INS	OUT	INS	OUT	INS	OUT
MAXIMUM	41*	11*	35*	12*	3*	60*
MINIMUM	-11*	-3*	0*	-53*	-76*	-17*
RANGE	52	14	35	65	79	77

∴ MAX. RANGE = R-L (INS) = 79 kSI < $3S_m = 80.1 \text{ kSI}$

Δ REF. 2, PAGE C-16-7

▽ REF. 2, PAGE C-16-17

* REF. PAGE 156 OF THIS ANALYSIS

BABCOCK & WILCOX

DEPARTMENT MT. V. COND. ENGRG. DATE 6/78 BY LEW

JUNCTION #4

CHECKED DATE BY

EVALUATION

JOB NO. 620-0011-55

REVISION

SHEET 161 OF

INTERACTION JUNCTURE FATIGUE EVALUATION

Prior experience on the OTSG has shown that the crucial areas for fatigue evaluation are Junctures 2 and 4. Therefore, to simplify the analysis those areas will be justified.

The following pages demonstrate the affect of the 'Rapid Cooldown' transient on the total cumulative fatigue usage factor.

EFFECT OF 'RAPID COOLDOWN' ON JUNCTION #2 USAGE FACTOR:

FROM REF. 2, PAGES C-17-2 AND C-17-3, THE JUNC. 2 CUMULATIVE USAGE FACTOR HAS BEEN CALCULATED TO BE 0.0.

THE ADDITIONAL CYCLE RESULTING FROM THE RAPID COOLDOWN WILL BE COMPLETED BY A NORMAL HEATUP TO FULL POWER. THE MAXIMUM PEAK STRESS INTENSITY RANGE FROM THE ADDITIONAL CYCLE IS DETERMINED FROM THE TABLE BELOW.

	PEAK STRESS INTENSITY					
	L-H		H-R		R-L	
	INS	OUT	INS	OUT	INS	OUT
MAXIMUM	13.0*	18.0*	67.0*	22.0 ^Δ	17.0*	19.0*
MINIMUM	-22.0*	-9.0 ^Δ	0.0*	-28.0*	-63.0*	-14.0*
RANGE	35.0	27.0	67.0	50.0	80.0	33.0

^Δ REF. 2, PAGE C-16-5

[□] REF. 2, PAGE C-16-13

* REF. PAGE 152 OF THIS ANALYSIS

BABCOCK & WILCOX

DEPARTMENT HEAVY-COMP ENGRG. DATE 6/78 BY LEW

JUNCTION #2

CHECKED DATE BY

EVALUATION

JOB NO. 620-0011-55

REVISION

SHEET 16.3 OF

MAX. PEAK STRESS INTENSITY RANGE @ JUNC. #2 =

$$(R-L)_{INS} = 80 \text{ KSI}$$

$$S_{ALT} = (80/2) \frac{E_s}{E_A} = 45.9 \text{ KSI}$$

FROM ASME CODE, SECT. III, FATIGUE CURVE

$N = 5,500$ ALLOWABLE CYCLES

$$\therefore U_2 = 0.0 + \frac{1}{5,500} \approx 0.0$$

THEREFORE, IT IS SHOWN THAT THE USAGE FACTOR FOR JUNCTURE #2 IS ESSENTIALLY UNCHANGED AND IS STILL ACCEPTABLE.

BABCOCK & WILCOX

DEPARTMENT M-V-COND. ENGRS. DATE 6/78 BY LEW

JUNCTURE #2

CHECKED DATE BY

EVALUATION

JOB NO. 620-0011-55

REVISION

SHEET 164 OF

EFFECT OF 'RAPID COOLDOWN' ON JUNCTURE #4
USAGE FACTOR:

FROM REF. 2, PAGES C-17-2 AND C-17-3,
THE JUNG. #4 CUMULATIVE USAGE FACTOR
HAS BEEN CALCULATED TO BE 0.03.

THE ADDITIONAL CYCLE RESULTING FROM THE
RAPID COOLDOWN WILL BE COMPLETED BY
A NORMAL HEATUP TO FULL POWER. THE
MAXIMUM PEAK STRESS INTENSITY RANGE
FROM THE ADDITIONAL CYCLE IS DETERMINED
FROM THE TABLE BELOW.

	PEAK STRESS INTENSITY					
	L-H		H-R		R-L	
	INS	OUT	INS	OUT	INS	OUT
MAXIMUM	149*	11*	81*	12*	6*	55*
MINIMUM	-13*	-7*	-5*	-48	-230*	-17*
RANGE	162	18	86	60	236	72

△ REF. 2, PAGE C-16-9

□ REF. 2, PAGE C-16-17

* REF. PAGE 156 OF THIS ANALYSIS

BABCOCK & WILCOX

DEPARTMENT INT. 11 - COMP. ENGRG. DATE 6/78 BY LEW

JUNCTURE #4

CHECKED DATE

BY

EVALUATION

JOB NO. 600-0011-55

REVISION

SHEET 165 OF

MAX. PEAK STRESS INTENSITY RANGE @ JUNC. #4 =

$$(R-L)_{INS} = 236 \text{ KSI}$$

$$S_{ALT} = (236/2) \frac{E_C}{E_A} = 135.7 \text{ KSI}$$

FROM ASME CODE, SECT. III, FATIGUE CURVE

$N = 250$ ALLOWABLE CYCLES

$$\therefore U_4 = 0.03 + \frac{1}{250} = 0.034$$

THEREFORE, IT IS SHOWN THAT THE USAGE FACTOR FOR JUNC. #4 IS ESSENTIALLY UNCHANGED AND IS STILL ACCEPTABLE.

BABCOCK & WILCOX

DEPARTMENT INT. V-COMP. ENGRS. DATE 6/78 BY LEW

JUNCTION #4

CHECKED DATE BY

EVALUATION

JOB NO. 620-0011-55

REVISION

SHEET 166 OF

TUBE STRESS EVALUATION

The critical requirement for the tubes is to assure that the tubes have not been stressed beyond the yield stress.

The following pages show the 91249 tube load output for each iteration, a tabulation of maximum tube load, and calculation of maximum tube stress.

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78

SMUD STEAM GENERATOR---REACTOR TRIP TRANS. ITEM 26

TUBE LOADS

TUBESHEET RADIUS	TUBESHEET DEFLECTION	TUBE AXIAL DEFLECTION	LONGITUDINAL TUBE STRESS	TUBE LOAD LB.
0.00	1.2214	-.0259	-2.23	-41.6
5.75	1.2216	-.0256	-2.18	-40.7
11.49	1.2222	-.0250	-2.10	-37.5
17.24	1.2231	-.0241	-2.00	-32.5
22.99	1.2243	-.0229	-1.88	-26.1
28.74	1.2255	-.0214	-1.78	-19.0
34.48	1.2258	-.0204	-1.68	-12.1
40.23	1.2278	-.0191	-1.54	-6.5
45.98	1.2284	-.0187	-1.53	-6.3
51.72	1.2293	-.0184	-1.54	-9.3
57.47	1.2272	-.0200	-1.74	-10.0

TUBESHEET DEFLECTION TO PRIMARY SIDE IS POSITIVE

VERTICAL FORCE BALANCE FOR TUBESHEET (KIP/RAD BASIS)

VERTICAL REDUNDANT (VS)	CALCULATED VERTICAL LOAD	PERCENT DEVIATION
-1156.4	-1161.0	-.4

NOTE: THE CALCULATED VERTICAL LOAD CONSISTS OF THE AREA-CORRECTED PRESSURE LOADS ON THE TUBESHEET FACES PLUS A RADIUS-WEIGHTED SUMMATION OF THE TUBE STRAINS AT THE TABULATED RADII.

LEW
 620-0011-55
 4/78
 168

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD RAPID COOLDOWN---LOWER TUBESHEET ANALYSIS---BY L. WHITE ITBE 59

TUBE LOADS

TUBESHEET RADIUS	TUBESHEET DEFLECTION	TUBE AXIAL DEFLECTION	LONGITUDINAL TUBE STRESS	TUBE LOAD LB.
0.00	1.2229	-.0630	-5.48	-346.1
5.75	.2230	-.0629	-5.47	-345.3
11.49	.2234	-.0626	-5.43	-342.9
17.24	.2241	-.0618	-5.38	-339.3
22.99	.2249	-.0610	-5.31	-335.1
28.74	.2256	-.0602	-5.26	-330.9
34.48	.2262	-.0597	-5.19	-327.9
40.23	.2264	-.0595	-5.18	-326.8
45.98	.2259	-.0600	-5.22	-329.6
51.72	.2244	-.0615	-5.35	-337.6
57.47	1.2217	-.0642	-5.59	-352.7

TUBESHEET DEFLECTION TO PRIMARY SIDE IS POSITIVE

VERTICAL FORCE BALANCE FOR TUBESHEET (KIP/RAD BASIS)

VERTICAL REJUVANT (VS)	CALCULATED VERTICAL LOAD	PERCENT DEVIATION
-1268.9	-1268.2	.1

NOTE* THE CALCULATED VERTICAL LOAD CONSISTS OF THE AREA-CORRECTED PRESSURE LOADS ON THE TUBESHEET FACES PLUS A RADIUS-WEIGHTED SUMMATION OF THE TUBE STRAINS AT THE TABULATED RADII.

691
 8/1/78
 55-1100-029
 LEW

SMUD STEAM GENERATOR---REACTOR TRIP TRANS. ITER 26 91249 REV 4 3-15-75 05/16/78 09-37:49 PAGE 90
 FULL CERTIFICATION FULL CERTIFICATION FULL CERTIFICATION

PROGRAM NO. 91249 INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS DATE 05/16/78
 SMUD RAPID COOLDOWN---LOWER TUBESHEET ANALYSIS---BY L. WHITE ITER 45

TUBE LOADS

TUBESHEET RADIUS	TUBESHEET DEFLECTION	TUBE AXIAL DEFLECTION	LONGITUDINAL TUBE STRESS	TUBE LOAD LB.
0.00	1.925	-0.274	-2.39	-51.1
0.75	1.925	-0.276	-2.39	-50.1
1.49	1.927	-0.272	-2.37	-49.6
2.24	1.930	-0.269	-2.35	-48.2
2.99	1.932	-0.267	-2.33	-46.9
3.74	1.932	-0.265	-2.32	-46.7
4.48	1.930	-0.270	-2.35	-48.5
5.23	1.920	-0.279	-2.43	-53.6
5.98	1.902	-0.297	-2.59	-63.6
6.72	1.872	-0.327	-3.05	-79.9
7.47	1.827	-0.371	-3.24	-204.6

TUBESHEET DEFLECTION TO PRIMARY SIDE IS POSITIVE

VERTICAL FORCE BALANCE FOR TUBESHEET (KIP/RAD BAS.S)

VERTICAL REDUNDANT (V5)	CALCULATED VERTICAL LOAD	PERCENT DEVIATION
-1301.3	-1300.6	.1

NOTE* THE CALCULATED VERTICAL LOAD CONSISTS OF THE AREA-CORRECTED PRESSURE LOADS ON THE TUBESHEET FACES PLUS A RADIUS-WEIGHTED SUMMATION OF THE TUBE STRAINS AT THE TABULATED RADII.

LEW
 620-0011-55
 6/78
 170

PROGRAM NO. 91249

INTERACTION ANALYSIS OF ONCE-THROUGH STEAM GENERATORS

DATE 05/16/78

SMUD STEAM GENERATOR---REACTOR TRIP TRANS.---

ITER 49

FOR ITER 72 OUTPUT
 SEE PG. 135

TUBE LOADS

TUBESHEET RADIUS	TUBESHEET DEFLECTION	TUBE AXIAL DEFLECTION	LONGITUDINAL TUBE STRESS	TUBE LOAD LB.
0.00	1.2079	.0108	.94	59.6
5.75	1.2078	.0105	.93	58.7
11.49	1.2072	.0101	.98	55.8
17.24	1.2053	.0092	.80	50.7
22.99	1.2050	.0078	.69	43.3
29.74	1.2031	.0060	.52	33.0
34.48	1.2007	.0035	.31	19.5
40.23	1.1975	.0004	.03	2.0
45.98	1.1935	-.0075	-.32	-20.0
51.72	1.1886	-.0096	-.75	-47.2
57.47	1.1825	-.0146	-1.28	-80.6

TUBESHEET DEFLECTION TO PRIMARY SIDE IS POSITIVE

VERTICAL FORCE BALANCE FOR TUBESHEET (KIP/RAD BASIS)

VERTICAL REDUNDANT (VS)	CALCULATED VERTICAL LOAD	PERCENT DEVIATION
-520.3	-526.4	-1.2

NOTE* THE CALCULATED VERTICAL LOAD CONSISTS OF THE AREA-CORRECTED PRESSURE LOADS ON THE TUBESHEET FACES PLUS A RADIUS-WEIGHTED SUMMATION OF THE TUBE STRAINS AT THE TABULATED RADII.

171
 6/78
 620-0011-55
 LEW

SUMMARY OF TUBE LOADS

ITERATION	TUBE LOAD CR=0.0"	TUBE LOAD CR=R*
26	-141.8	-110.0
39	-346.1	-352.7
45	-151.1	-204.6
49	59.6	-80.6
72	1077	1691.5

LOAD IN POUNDS

MAXIMUM TUBE STRESS

THE MAXIMUM TUBE LOAD FOR THE RAPID COOLDOWN IS:

$$P_{MAX} = +1691.5 \text{ POUNDS TENSILE LOAD}$$

THE TUBE CROSS-SECTIONAL AREA IS:

$$A_T = \pi (0.625 - 0.0340)(0.0340) = 0.0631 \text{ IN}^2$$

BABCOCK & WILCOX

DEPARTMENT MTN-COMP ENRG. DATE 6/78 BY LEW

MAX. TUBE STRESS

CHECKED DATE BY

JOB NO. 620-0011-55

REVISION

SHEET 172 OF

$$\therefore \text{MAX. TUBE STRESS} = \frac{1691.5}{0.0631} \cdot \sigma_{\text{MAX}} \\ = 26,807 \text{ PSI}$$

THE ALLOWABLE STRESS FOR THE TUBES IS THE YIELD STRESS AT THE TUBE TEMPERATURE

FOR SB-163 @ $\approx 360^\circ\text{F}$, $S_y = 30,280 \text{ PSI}$

SINCE $\sigma_{\text{MAX}} (26,807 \text{ PSI}) < S_y (30,280 \text{ PSI})$

TUBE STRESS IS ACCEPTABLE.

BABCOCK & WILCOX

DEPARTMENT *UT.V-COND. ENGRG.* DATE *6/78* BY *LEW*

MAX. TUBE STRESS

CHECKED DATE BY

JOB NO. *6-20-0011-55*

REVISION

SHEET *173* OF

NON-DUCTILE FAILURE ANALYSIS

The following pages show that the temperature at which non-ductile failure would occur for a defect in the base metal is far below the actual metal temperature. Hence, no failure would occur for the postulated defect.

The analysis is based on the procedure given in Reference 4.

LEW
620-0011-55
6/78
174

NON-DUCTILE FAILURE ANALYSIS

THE CRITICAL JUNCTURE FOR THIS CONSIDERATION IS JUNCTURE #3 (HEAD-TO-TUBESHEET WELD METAL).

SEE REFERENCE 4:

$$\text{MAX. POSTULATED DEFECT} = \frac{1}{4}T \times 1\frac{1}{2}T$$

WHERE $T = 8''$

MAX. JUNC. 3 STRESS CONDITION = LONG. STRESS

$$L_{\text{INS.}} = 63.3 \text{ KSI} \quad L_{\text{OUT}} = -48.9 \text{ KSI}$$

(REF. 91249 OUT. - ITER 72 - PG. 132)

$$L_{\text{MEMBRANE}} = (63.3 + (-48.9)) / 2 = +7.2 \text{ KSI}$$

$$L_{\text{BENDING}} = 63.3 - (+7.2) = +56.1 \text{ KSI}$$

THESE ARE PRI. + SEC. STRESSES

FROM FIG. G-2214-1, FOR $\sqrt{A} = 2.83$, $\frac{D}{Y} = 1.0$;

$$M_{\text{M}} = 2.92 ; M_{\text{L}} = \frac{2}{3}(2.92) = 1.95$$

DETERMINE STRESS COMPONENTS FOR PARA. G-2222:

$$\text{PRI. MEMBRANE} = \frac{PR}{2A} = \frac{(2.05)(59.5313)}{2(8)} = 7.63 \text{ KSI}$$

PRI. BENDING = ZERO FOR THIS GEOMETRY

BABCOCK & WILCOX

DEPARTMENT MT. V - COMP. ENGRG. DATE 6/78 BY LEW

NON-DUCTILE FAILURE CHECKED DATE BY

ANALYSIS JOB NO. 620-0011-55

REVISION

SHEET 175 OF

$$\begin{aligned} \text{SEC. MEMBRANE} &= (\text{PRI.} + \text{SEC. MEM.}) - (\text{PRI. MEM.}) \\ &= +7.2 (\text{PREV. PG.}) - 7.63 \\ &= -0.43 \text{ KSI} \end{aligned}$$

$$\begin{aligned} \text{SEC. BENDING} &= (\text{PRI.} + \text{SEC. BEND.}) - (\text{PRI. BEND.}) \\ &= +56.1 (\text{PREV. PG.}) - 0 \\ &= +56.1 \text{ KSI} \end{aligned}$$

PER PARA. G-2222:

$$\begin{aligned} &2 K_{Im} (\text{PRI. MEM.}) + 2 K_{Ib} (\text{PRI. BEND.}) + K_{Im} (\text{SEC. MEM.}) + \dots \\ &\dots K_{Ib} (\text{SEC. BEND.}) < K_{IR} \end{aligned}$$

$$\begin{aligned} &2 [(2.92)(7.63)] + 2 [(1.95)(0)] + [(2.92)(-0.43)] + \dots \\ &\dots [(1.95)(56.1)] = 152.7 \end{aligned}$$

IF WE ASSUME THIS VALUE AS K_{IR} IN FIG. G-2210-1, THEN THE QUANTITY $(T - RT_{NDT})$ EQUALS 160

FROM REFERENCE 3, PAGE 3-12, THE HIGHEST AND, THUS THE MOST CONSERVATIVE, VALUE OF RT_{NDT} THAT WAS MEASURED FOR THE MATERIALS INVOLVED IS 60°.

THEREFORE, $T - RT_{NDT} = 160$

$$T = 160 + 60 = 220^\circ \text{ F}$$

BABCOCK & WILCOX		REVISION	
DEPARTMENT	WIT-V-COMP. ENGR'G.	DATE	6/78
NEXT-DUCTILE FAILURE ANALYSIS		CHECKED DATE	BY LEW
JOB NO. 620-0011-55		SHEET 176 OF	

THEREFORE, THIS SHOWS THAT THE ACTUAL METAL TEMPERATURE NEEDS TO BE GREATER THAN 220°F TO PREVENT NON-DUCTILE FAILURE.

PER PAGE _____, THE ACTUAL METAL TEMPERATURE AT THE WELD LOCATION, INSIDE SURFACE, IS 308°F (NODAL TEMPS @ 24, 50, 76, 102 INTERPOLATED TO INSIDE SURFACE FOR ITER 72 - SEE PAGE 44).

SINCE $308^{\circ}\text{F} > 220^{\circ}\text{F}$, NON-DUCTILE FAILURE DUE TO A $\frac{1}{4}\text{T} \times 1\frac{1}{2}\text{T}$ DEFECT WILL NOT OCCUR.

BABCOCK & WILCOX

DEPARTMENT NV-COMP. ENGRS. DATE 6/78 BY LEWNON-DUCTILE FAILURE CHECKED DATE _____ BY _____ANALYSISJOB NO: 620-0011-55

REVISION _____

SHEET 177 OF _____

APPENDIX

Information supplied to Mt. Vernon Component Engineering
describing the 'Rapid Cooldown' parameters.

LEW
620-0011-55
6/78
A-1

cc: BA Karrasch
 RN Tornow
 LH Bohn
 JR Burris
 PA Sherburne
 CE Harris
 HS Palme
 JT Janis
 RM Douglass-MT. Ver
 RN Bottorf-MT. Ver

THE BABCOCK & WILCOX COMPANY
 POWER GENERATION GROUP

To DISTRIBUTION
 From J. M. BURNETT - RCS COMPONENTS

BOS 653.5

Cust. SMUD

File No.
 or Ref.

Subj. SMUD COOLDOWN INCIDENT

Date 4/4/78

This letter is cover one customer and one subject only.

DISTRIBUTION

B&W, "Bruny" - MT. Vernon
 H. W. Behnke - MT. Vernon
 A. D. McKim - MT. Vernon
 R. P. Schaefer - MT. Vernon

Reference: (1) Memo, B. A. Karrasch to G. M. Olds, "SMUD Cooldown Incident", dated 3/29/78.

Attached for your information and use is a copy of reference memo (1), including attachments. The transient sequence of events and curves contained in the referenced package comprise the official information regarding the subject transient. Based on the preliminary assessments performed on the RV, SG's, RC Piping, and Pressurizer SMUD has been allowed to go back to power operation (restricted to 75% full power). B&W has subsequently committed to a follow-up program of analysis and documentation to support the issuance of a letter from B&W to SMUD authorizing return to 100% full power. To support this Company commitment, those on distribution are requested to formalize and finalize all necessary analytical efforts for the affected components by May 15, 1978 (calculation packages and documentation should be in Lynchburg on this date). Steam generator analytical efforts should be coordinated with P. A. Sherburne. All other component activities should be coordinated with J. M. Burnett (C. E. Harris and H. S. Palme will be assisting J. M. Burnett in evaluation of the RV from a fracture mechanics standpoint).

-05

Manhour charges should continue per the previously authorized charge number (Contract 595-7072, Task 68, WBS Charge AM680572) and appropriate Time and Materials reporting forms should be transmitted weekly to J. T. Janis, Lynchburg,

Any problems or questions that arise should be addressed to J. M. Burnett or P. A. Sherburne as noted previously. Your cooperation in these activities are very much appreciated.

J. M. Burnett
 J. M. BURNETT

LEW
 620-0011-55
 6/78
 A-2

ef

man hours to 595-7072-68-05

J. M. Burnette

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

To |
G. M. Olds, Manager, Nuclear Service

From
B. A. Karrasch, Manager, Plant Integration

BDS 663.5

Cust.
177 - A21

File No.
or Ref.

Subj.
SMUD Cooldown Incident

Date
March 29, 1978

This letter to cover one customer and one subject only.

On March 20, 1978, SMUD experienced a loss of power to a substantial portion of the non-nuclear instrumentation (see details - Attachment 3). Although the Reactor Protection System (RPS) and Safety Features Actuation System (SFAS) functioned properly, SMUD still experienced the most severe thermal transient on any B&W plant to date. The subsequent investigation pointed out that additional guidance to our operating customers in the area of limiting potential events of this nature is warranted. Accordingly, the Engineering Department recommends that our operating plant customers be informed of this incident, and suggestions be made on how to minimize the plant thermal transient for loss of NNI and other similar events. Attachment 1, a sequence of events, and Attachment 2, a series of descriptive curves, are provided to assist you in preparation of a customer letter.

In addition, the following recommendations should be made to assure proper operator action for events of this nature:

1. Operators should be trained to recognize a loss of power to all or a majority of their NNI (indicators fail to mid-range, automatic or manual transfer to alternate instrument strings brings no response, etc.). The loss of power is emphasized here rather than the failure of any one instrument or control signal. These minor events are adequately covered in our present simulator course.
2. Given that the operator can determine that he has lost power to all or most of the NNI, he should know the location of the power supplies and power supply breakers and have a procedure available to regain power.
3. If the fault cannot be cleared (e.g., the breakers to the power supplies reopen), he should have a list of alternate instrumentation available to him. Some possibilities are:
 - a) ESFAS panels
 - b) RPS panels
 - c) EC1
 - d) SRCI

LEW
620-0011-55
6/78
A-3

- e) Remote shutdown panels
- f) Local gages
- g) Plant Computer

Note that each plant will be different in detail, but the list should be developed in advance and the operators thoroughly trained in its usage.

4. The above instrumentation sources should also be keyed to certain critical variables to help the operator select his priorities during the emergency condition. It is recognized that no procedure can cover all the possible combinations of non-nuclear instrumentation failures, however, if the operator knows he has an instrument problem (as opposed to a LOCA or steam line break, for example), he can limit the transient by controlling only a few variables. These are:

- a) Pressurizer level (via HPI or normal makeup pumps)
- b) RCS pressure (via pressurizer heaters, spray, E/M relief valve)
- c) Steam generator level (via feed flow, feedwater valves)
- d) Steam generator pressure (via turbine bypass system)

The pressurizer level and RCS pressure assure that the Reactor Coolant System is filled and the steam generator level and pressure assure adequate decay heat removal.

In our opinion, the preferred solution is to install safety grade steam generator level instrumentation, start auxiliary feedwater on a low level steam generator signal, and control steam generator level automatically, as is required on our IEOTSC plants. This may not be a practical backfit solution for the operating plants, however, this solution should be suggested as a possible way to assure minimal lost capacity days due to equipment failure. Plant Integration will be happy to assist you in the preparation of the customer letter.

B. Karrasch

BAK:jl

cc: J. C. Deddens	J. A. Castanes
D. E. Roy	P. A. Sherburne
R. M. Bell	J. R. Burris
T. M. Schuler	R. W. Moore
C. W. Pryor	R. W. Winks
L. J. Stanek	J. T. Janis
K. E. Sunrke	A. W. Brown
J. S. Tulenko	B. J. Shepherd
J. H. Taylor	L. R. Cartin
E. W. Swanson	C. E. Harris
J. J. Kelly	H. S. Palme
J. D. Phinney	J. M. Burnette
D. F. Hallman	G. A. Meyer

LEW
620-0011-55
6/78
A-4

ATTACHMENT 1

SEQUENCE OF EVENTS - 04:25(AM) to 05:34(AM)

<u>TIME</u>	<u>EVENT</u>
4:25:35	- Lost NNI power supply cabinets 5, 6, & 7 (B&W Channel "Y")
	- This caused a loss of T _H signals to the ICS. BTU limits ran back feedwater, resulting in a loss of feedwater (actual Rx power was 72%).
4:25:46	- Reactor trip on high pressure, turbine trip on interlock.
	- Pressurizer code relief setting was known to be low (=2225 psig). The electromatic relief was isolated due to previous leakage problems. The data indicates primary pressure went =2400 psig =>code relief valve lifted.
4:26:17	- Operator starts HPI pump "B" to maintain pzt. level.
4:28:23	- Operator stops HPI pump "B".
4:30	- OTSG "B" goes dry. Data indicates that "A" OTSG probably also went dry.
4:34:25	- RC pressure =1900 PSI (low pressure trip set-point).
4:34	- Operator increases speed of a MFP and feeds "A" OTSG. This starts RCS on pressure and temperature decrease.
4:37:16	- SFAS actuation at 1600 psig This starts HPI, LPI and initiates aux. feed. Aux. FW valves are opened to full open position. The system makes no automatic attempt to control steam generator water level.
4:40	- RC pressure at 1475 psig. It starts to recover from this point due to HPI. T _{ave} = 528°F.
4:43:56	- "A" HPI pump secured.
4:46:09	- LPI secured.
4:49:54	- "A" HPI initiated. From this point on, the operator started and stopped HPI pumps as necessary to maintain pressurized level.

LEW
620-0011-55
6/78
A-5

TIMEEVENT

- 4:51:25 - Secured RCP-D ($T_{ave} = 435^{\circ}F$)
This reduced #RCP's to three
- 4:47:27 - OTSG "A" water level - 599.7"

Speculate that =2 ft of tubes are not flooded
(at top) due to steam line arrangement.
- 5:00:00 - Hourly computer log printout
Steam temp $380^{\circ}F$ (OTSG "B")
Steam pressure 171 psig (OTSG "B")

Assuming $T_{ave} = T_{sat} \Rightarrow T_{ave} = 380^{\circ}F$
- 5:13:47 - Power restored to NNI cabinets 5, 6, & 7

 $T_{ave} = 285^{\circ}F$

RCS Pressure = 2000 psig

Both OTSG full level ranges pegged high


Operator begins to reduce RC pressure using
pzz. spray.

Operator stops aux. FW pump.

LEW
620-0011-55
6/78
A-6

COLD LES RC TEMPERATURE, °E

RC PRESSURE, PSZG



TIME OF EVENT

LEIN
E20-DON-55
6/72
A-7

SECONDARY PRESSURE, PSIG

0 200 400 600 800 1000

0430 ← ECS STOPS FEEDING OTSG'S
 0440 ← AFW INITIATED
 0450 ← OTSG DRY

0500
 0510
 0520
 0530
 0540
 0550
 0600
 0610
 0620

TIME OF EVENT

EXACT SHIPROE DURING NOT SAID
 IT FOLLOWS SATURATED PRESSURE
 FOR EXISTING PRIMARY TEMPERATURE

STEAM PRESSURE (collected) showing secondary pressure

LEW
 620-0011-55
 6/78
 A-8

WATER LEVEL, % FULL RANGE

0 20 40 60 80 100

0100

← AFW INITIATED

DTSG "A"

0130

DTSG "B"

0135

0140

0145

0150

0152 → TIME OF EVENT.

100%
50%

DTSG WATER LEVEL

LEU
620-00N-55
6/78
A-9

ATTACHMENT III

The operator was in the process of changing a light bulb in a turbine header pressure transfer switch when he dropped the bulb into the switch and shorted the switch to ground. A protective fuse in the circuit had no chance to blow before the power supply monitor circuit sensed the short on the bus and opened the breakers to the "Y" and "Z" power supplies. This resulted in the loss of approximately half the NNI signals ("X" power supply remained energized) and the ability to transfer from "bad" to "good" signals. It should be pointed out that the utility changed the original B&W design in the area of the power supplies. If the original B&W design were installed, the incident would have resulted in the loss of the ability to transfer (select) signals only. No active signal would have lost power.

LEW
620-0011-55
6/78
A-10

TO: J.D. BREW

THE BABCOCK & WILCOX COMPANY
POWER GENERATION GROUP

C. W. BRUNY, OTSG ENGINEERING, MT. VERNON

From P. A. SHERBURNE, STEAM GENERATOR UNIT, EPGD

DSG 433-3

Cust. File No. or Ref. T3.55/12.5

Subj. SMUD COOLDOWN INCIDENT Date 5-11-78


This letter is cover and contains only the subject only.

Reference: B&W Document #32-8053-00, SG Shell Temperature --
SMUD Rapid Cooldown Incident, May 1, 1978

Previous OTSG data transmittals to you regarding the subject transient indicated that maximum tube-to-shell ΔT was $170^{\circ}F$ for the "A" steam generator. Recent calculations (Reference) show that OTSG "B" developed $186^{\circ}F$ ΔT . The time history of average shell temperature for the "B" steam generator is as follows:

<u>Time</u>	<u>Avg. Shell Temperature</u>	<u>Tube-to-Shell ΔT</u>
hrs	$^{\circ}F$	$^{\circ}F$
0445	570.0	95
0450	567.8	128
0455	564.2	159
0500	557.3	177
0505	545.8	186
0515	496.8	182
0525	460.8	174
0535	435.2	160
0545	422.3	142

Please define the impact that the latest data will have on your analysis, conclusions, and schedule for completion.


P. A. SHERBURNE

of
cc: JM Burnett

LEW
620-0011-55
6/78
A-11 of 11