

FindingsBroad

Systems Engineering approach to design and operations has not been applied.

- Recognized as appropriate to complex man-machine situation.
- DOD reqs. require its use, NASA uses.

Specific

Design:

- 90% of display, w/ controls in CR fail HE criteria

- Information display - location of info in relation to controls, ability to see, avail of info, scaling, confusing

- Workstation design - inconsistency of display in relation to control; excessive reach envelopes ~42"; controls out of sequence for task; poor junctional ^{grouping}

- Display design - changing light bulbs exposed of short, no color coding for ranges.

- Control design - inconsistent, in functions (left and/or right), some critical controls unguarded

lighting - glare, no lamp test
 illumination unsat.

8001 220-755

- o Labeling - very poor in general; inconsistent placement, not consistent with control positions;

Critical Points

- o Onset of Accident - annunciators ~~to~~ saturate & become unusable to operators.

- o EMOV failure to close - operator relied on light. RCDT outside operating area.

- o 2nd Boil dry on SG-A ⁹⁴⁰⁰⁰ - Proximity of controls, inadequate labeling. -

- o HPI shutoff - Misinterpretation of ~~low~~ level indication - training

Model CR HF design

Should be involved in entire process - conception to decommissioning
Systems Engineering - HF, TA
~~TA~~

HF Criteria in Industry

1. Casting at time of TMI-2

Noting - $\$E^3$ 279, 308 ESF display
Manual must have gas indicator *irrigue*

GDC - general.

2. Current - more now in HE, but nothing

on rep. engg, rep integration.

no HE from HE standpoint.

Today's criteria would probably not
improve performance.

HF Eval. of TMI-2 development Process

None - ~~to~~ ^{minimal} attention to operator.

Did not take any standard HE

approaches to design of CR - Test and

mockup - no coordination among

parties.

HF Review of Some Vantage Plants

O'connor - Mgmt considerably better.
Mockup, SR procedures
minimal reach & usability problems
good displays & alarms.
control & display consistent

Calvert Cliffs - looked at HE
research work done at Detroit & clear
& lighters work. Mockup
~~good~~ systems integration approach -
all parties involved. Component selection
excellent. Good alarm display.
SG & EE management were Navy
nuclear training officers.

* TMI problem seems to be a fossil
background

Trainers -

NRC Training Adequacy

Procedures -

Precedents - Ornstein (Several)

1. Swain Report
2. EPRI Report
3. Michelan
4. BSAR
- 5.

Actions/Inactions before Accident Snel