

Boh!

OK
Fut

NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

THREE MILE ISLAND
SPECIAL INTERVIEWS

WITNESSES:

CRAIG FAUST
ED FREDERICK
FRED SCHEIMANN
WILLIAM ZEWE

POOR ORIGINAL

Place - Middletwon, Pennsylvania

Date - Tuesday, September 11, 1979

Pages 1 - 272

Telephone:
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D.C. 20001

NATIONWIDE COVERAGE - DAILY

8001240562 T

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

----- X
:
In the Matter of: :
:
THREE MILE ISLAND :
SPECIAL INTERVIEWS :
:
----- X

WITNESSES:

CRAIG FAUST
ED FREDERICK
FRED SCHEIMANN
WILLIAM ZEWE

Trailer No. 138
Three Mile Island
Middletown, Penna.

Tuesday, September 11, 1979

BEFORE:

For the Nuclear Regulatory Commission:

GEORGE T. FRAMPTON, JR., ESQ.
RON HAYNES
RON BELLAMY
MARK CUNNINGHAM
MICHAEL WORAM
RUSSELL SACKETT
PETER SICILIA

For Metropolitan Edison Company:

DELISSA A. RIDGWAY

C O N T E N T SINTERVIEW OF:EXAMINATION

Craig Faust	4
Ed Frederick	4
Fred Scheimann	4
William Zewe	4

E X H I B I T SEXHIBIT NUMBER:IDENTIFIED

7	40
8	175

bwLRW

P R O C E E D I N G S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. FRAMPTON: On the record.

This is a deposition being conducted by the NRC Special Inquiry Group on September 11 at Three Mile Island of Mr. Bill Zewe, Mr. Fred Scheimann, Mr. Ed Frederick and Mr. Craig Faust.

Gentlemen, we have given you to read a one-page witness notification which states the purpose and authority of our group and certain matters about the confidentiality of this deposition and the Privacy Act.

Have you read that one-page statement?

MR. FAUST: Yes.

MR. FREDERICK: Yes.

MR. SCHEIMANN: Yes.

MR. ZEWE: Yes.

MR. FRAMPTON: Do you understand it?

MR. FAUST: Yes.

MR. FREDERICK: Yes.

MR. SCHEIMANN: Yes.

MR. ZEWE: Yes.

MR. FRAMPTON: Ron, could you swear each of the witnesses individually?

by LRW

1 Whereupon,

2 CRAIG FAUST

3 ED FREDERICK

4 FRED SCHEIMANN

5 WILLIAM ZEWE

6 were called as witnesses and, having been first duly sworn,
7 were examined and testified as follows:

8 MR. FRAMPTON: Mr. Zewe, can you tell us as best
9 you recall what hours you were on and off, beginning with
10 March 28 and going through until Sunday after the accident,
11 so we can get those times down?

12 WITNESS ZEWE: On the 28th, I was there from
13 midnight until about 6:00 p.m. that evening. I had arrived
14 at about 10:30 on the previous evening, on the 27th. I came
15 back on site about a quarter after 3:00 in the morning on
16 the 29th, and I left about 2:00 p.m. in the afternoon.

17 On the 30th -- well, I came back about 10:30 that night
18 again and worked until around noon or 1:00 o'clock in the
19 afternoon on the 30th.

20 The next couple of days, Saturday, I just worked a normal
21 11:00 p.m. until 7:00 a.m. the next morning. Sunday, I was
22 off, but I was on the site for most of the day, either at
23 the observation center or the plant itself on Sunday.
24 Anywhere from about 9:00 in the morning until about 5:00 in
25 the afternoon, but I didn't have the duty responsibility.

bwlRW

1 MR. FRAMPTON: Mr. Scheimann, as best you can
2 recall, can you go through the same?

3 WITNESS SCHEIMANN: Okay. March 28, actually it
4 was the 27th, I started 11:00 p.m. Actually, I got here
5 about 10:30. I was here until about 5:00 o'clock, 5:30, the
6 next afternoon. The 29th, due to an unfortunate
7 misunderstanding as to the time of scheduling, I wasn't even
8 out. The 30th, I am having a hard time remembering when I
9 was here, but I was probably here from 11:00 p.m., to 11:00
10 a.m. And that is all I can really remember as far as
11 timewise.

12 MR. FRAMPTON: That would have be from 11:00
13 p.m. on Friday through until Saturday morning?

14 WITNESS SCHEIMANN: Yes. Other than that, I
15 couldn't really remember an exact time, being six months
16 from the time now.

17 MR. FRAMPTON: Thank you. Mr. Frederick?

18 WITNESS FREDERICK: I arrived at 2245 on the 27th
19 of March. I left at 1607 on the 28th. I arrived again at
20 about 2230 and left about 1000 on the 29th. I believe the
21 next day I worked the same thing. I am not sure. Was it
22 Sunday we were here together? So I worked probably noon to
23 5:00 or something on Sunday.

24 MR. FRAMPTON: Let me go back and make sure about
25 that again. You came back on at 10:30 p.m. on the 29th, on

RW

1 Thursday?

2 WITNESS FREDERICK: 28th.

3 MR. FRAMPTON: I am sorry. On the 28th. That is
4 Wednesday. You were on again beginning at 10:30 p.m.5 WITNESS FREDERICK: I was not on the panel. I was
6 not on the control room as operator. I was controlling the
7 auxiliary operators that night.

8 MR. FRAMPTON: That was until Thursday morning?

9 WITNESS FREDERICK: Yes, until about 7:00
10 or 8:00. I was tied up with something else until about
11 10:00 in the morning. I don't remember what.12 MR. FRAMPTON: Okay. Then were you on again at
13 all during Thursday or Friday?14 WITNESS FREDERICK: Thursday night I should have
15 been back out on the 11:00 to 7:00.16 MR. FRAMPTON: 11:00 to 7:00 Thursday night over
17 into Friday morning?18 WITNESS FREDERICK: 2300 at night until 7:00 in
19 the morning on Friday. I believe I stayed over a little bit
20 Friday morning too. Saturday, I don't know, I know I was on
21 site sometime during the day, but I don't know what time. I
22 was back again. Both off-scheduled days, but I was here.
23 Like I say, Sunday, I think, it was something like noon to
24 5:00 or 6:00, something like that.

25 MR. FRAMPTON: On Thursday night-Friday morning,

bwl:RW 1 were you in the control room or were you controlling
2 auxiliary operators at that time too?

3 WITNESS FREDERICK: I don't remember.

4 MR. FRAMPTON: Mr. Faust, do you recall your
5 hours?

6 MR. FAUST: Well, Ed and I go hand in hand on the
7 28th, 29th and 30th, about. The weekend, I think I was off.

8 MR. FRAMPTON: All right. Let me begin asking you
9 some questions about the venting of the makeup tank on
10 Thursday and Friday.

11 Mr. Zewe, do you recall when that began to occur during
12 the morning or early afternoon of Thursday the 29th? Was
13 the pressure beginning to build up in the makeup tank before
14 you left around 2:00 p.m. on Thursday?

15 WITNESS ZEWE: I really don't recall when it was,
16 but I am sure that we had the higher pressure build up in
17 the makeup tank that had started to occur before I left.
18 Exactly what time -- I believe it was earlier on Thursday
19 tht we began to vent the makeup tank more than what we owuld
20 normally do.

21 MR. FRAMPTON: When you say "more than what you
22 would normally do," would any venting normally be required
23 at full power operation, let's say?

24 WITNESS ZEWE: Really, the only time we would vent
25 the makeup tank is if we filled up the makeup tank a

b7LRW

1 abnormally and it just got a higher than normal pressure in
2 the makeup tank or if we had a low hydrogen atmosphere in
3 the makeup tank to where we would vent it off and reapply
4 the nitrogen overpressure. Normally, there was very little
5 venting done in the makeup tank normally.

6 MR. FRAMPTON: During normal operation, had there
7 been any indication at all of any leaks in the system going
8 from the vent header onto the compressor and waste gas decay
9 tanks?

10 WITNESS ZEWE: I really don't recall, because
11 prior to the accident, all right, the waste gas header
12 really wasn't very hot radioactively and really the only way
13 we could detect leakage from any part of the system header
14 is basically through our RMS system, or if we run the waste
15 gas compressors and if they don't build up pressure in the
16 waste gas decay tanks themselves.

17 We did have some problem with the waste gas compressors
18 and the cross-connect leakage that we had between two waste
19 gas tanks, and we had had previous leakage from some of the
20 instruments on the waste gas tanks that had been repaired.

21 So at this point, on the 28th, I am not certain of
22 exactly that we knew that there existed a leak that existed
23 after the accident.

24 MR. FRAMPTON: I understand if you don't have a
25 lot of activity in the normal waste gas, you would not find

bwLRW 1 it as easy to detect any small leaks that might exist, but
2 you said there had been some problems in the past in the
3 cross-connect between the waste gas decay tanks, but you
4 think that had been fixed?

5 WITNESS ZEWE: Well, I am going back to where we
6 did the start-up testing on it all right. Like all systems,
7 there were some leaks that existed and that were repaired,
8 and other ones appeared after this period. All right?

9 So after the 28th, I had no reason to believe that our
10 waste gas vent header system had any leaker.

11 MR. FRAMPTON: Do you recall whether prior to the
12 time you left on the afternoon of Thursday the 29th, there
13 was any awareness that the build-up of gas in the makeup
14 tank might become an increasingly serious problem? That it
15 might tend to substantially impair makeup and let-down flow?
16 In other words, was this perceived as a problem that was
17 going to potentially get greater as time went along?

18 WITNESS ZEWE: We were still trying to evaluate
19 the full accident and the controllability of the plant at
20 this point. Yes, we knew if you have a higher pressure in
21 the makeup tank that you would reduce your let-down
22 capability. Certainly, we were having a lot more gas come
23 back in the let-down system than what we were normally
24 accustomed to. We knew at this time we had a leak in the
25 vent header, because each time we did try to vent off the

bWLRW

1 makeup tank pressure, we did have a release that was
2 noticeable in the auxiliary building. We knew we would be
3 venting more and more, because the gas build-up seemed to
4 increase, so that the frequency between venting was
5 increasing all the day of the 29th, as I remember, but we
6 were trying to minimize the venting, so we would minimize
7 the release of the radioactive gases to the building.

8 MR. FRAMPTON: Do you recall then that during the
9 day on Thursday people had made a connection between the
10 venting of the tank and the activity levels in the aux
11 building or in the fuel handing building?

12 WITNESS ZEWE: As I recall, yes. I might have,
13 you know, the 29th early morning versus late at night, you
14 know, a little out of context there, but, yes, I believe we
15 did know it on the 29th, yes.

16 MR. FRAMPTON: Do you know whether anybody was
17 drawing a direct correlation between venting the makeup tank
18 and any off-sites levels of activity?

19 WITNESS ZEWE: Every activity that you vent from
20 the makeup tank went into the auxiliary building, and it
21 would ultimately go to the atmosphere, yes.

22 MR. FRAMPTON: I understand, but the question I am
23 asking is whether anybody was drawing a connection between
24 venting the makeup tank and actual readings taken by
25 monitoring teams someplace off-site or was the correlation

bwl.PW

1 that was observed the correlation between the activity in
2 the building --

3 WITNESS ZEWE: We could see it off-site. Every
4 time we would vent, there would be about 30 minutes to 40
5 minutes of a delay between the opening of the vent to where
6 we could actually monitor external to the plant.

7 MR. FRAMPTON: Okay. Do you recall whether
8 anybody was saying on Thursday, "Gee, the gas will continue
9 to build up. This will be an increasing problem we will
10 have to deal with down the road in 12 or 24 hours." Do you
11 remember any consciousness of the fact it would be a bigger
12 problem the next day?

13 WITNESS ZEWE: We were discussing the present
14 problems that we had. I don't believe that we discussed how
15 much greater it may become at some point in the future.

16 MR. FRAMPTON: Do you recall what your awareness
17 was on Thursday of how much hydrogen gas was probably in the
18 primary system? Can you recall anything about what you knew
19 or were told about that on Thursday?

20 WITNESS ZEWE: On Thursday was the first time that
21 I had received the information that the pressure spike that
22 we had the previous day was due to hydrogen burn in the
23 reactor building. Knowing that that would have to be a
24 considerable amount of hydrogen in order to have the
25 burn in the reactor building, we were certain that we had a

byLRW

1 considerable amount of hydrogen in the reactor coolant
2 system itself. But I really didn't have a feel for what
3 that concentration actually was other than we had a lot of
4 hydrogen.

5 MR. FRAMPTON: Well, did you think that most of
6 the gas that was coming off into the let-down lines was
7 hydrogen, or did you think -- did you reach any view about
8 that? What did you think the gas was as of Thursday that
9 was building up in the makeup tank?

10 WITNESS ZEWE: I really didn't know, other than
11 fission-produced gases. Xenon, krypton, and so forth, along
12 with some hydrogen and all the other fission-produced gases
13 we might have. I really didn't try to encompass it with a
14 quantitative type, you know, half of the gas is hydrogen, or
15 so many ccs per kg or something of this nature. We were
16 still concerned with trying to control the plant in the
17 situation we were in, more so than trying to do analytical
18 evaluations of it.

19 MR. FRAMPTON: Do you recall while you were there
20 during the morning and early afternoon of Thursday the 29th
21 what the command and control line was with respect to the
22 Unit 2 control room?

23 WITNESS ZEWE: Most definitely, yes.

24 MR. FRAMPTON: Who were you reporting to and who
25 was your immediate superior reporting to. Can you recall

bwlRW

1 that for us?

2 WITNESS ZEWE: Yes. My immediate superior was
3 James Floyd on the 29th. He was the supervisor of
4 operations. And then above him was a unit superintendent,
5 Joe Logan or Gary Miller or Jim Seelinger, depending on who
6 was there at that point in time.

7 MR. FRAMPTON: Do you recall who was there on
8 Thursday?

9 WITNESS ZEWE: Thursday morning?

10 MR. FRAMPTON: Yes.

11 WITNESS ZEWE: Jim Floyd was my immediate
12 supervisor, and I can't remember who the unit
13 superintendent was, though I believe it was Joe Logan, but
14 I don't call exactly, because they were not changing at the
15 same time as we were, and we had several of them there at
16 any one time, and I don't recall at that point exactly,
17 because in the late morning hours of the 11:00 to 7:00, when
18 we entered the makeup tank, it was right around where you
19 have a normal shift change.

20 MR. FRAMPTON: Friday morning?

21 WITNESS ZEWE: We are still talking about Thursday
22 morning.

23

24

25

re LRW

1 MR. FRAMPTON: Let's go to Thursday night when you
2 came back on. What was your understanding then of the
3 supervisory chain of command in the control room? Do you
4 recall from 10:30 p.m. to noon on Friday who was your
5 immediate supervisor and what other management people were
6 in the control room in charge?

7 WITNESS ZEWE: It was the same. Jim Floyd.

8 MR. FRAMPTON: Did he come back on around 10:30 or
9 11:00 Thursday night?

10 WITNESS ZEWE: I am not sure of Jim's exact time,
11 but he was working opposite Mike Ross, the Unit 1 supervisor
12 of operations and Jim and Mike were on and they relieved
13 each other.

14 I am not sure of what hour they relieved each other that
15 particular day, but in the morning hours of the 30th, Jim
16 Floyd was the supervisor of operations and my immediate
17 supervisor.

18 MR. FRAMPTON: Sometime early morning of the 30th,
19 Mike Ross went off and Jim Floyd came on?

20 WITNESS ZEWE: I think around midnight, but I am
21 not sure on that.

22 MR. FRAMPTON: Was it your understanding that
23 Floyd and Ross were trading off on the 12 on-12 off basis?

24 WITNESS ZEWE: As I remember, they were, yes.

25 MR. FRAMPTON: Above them, Gary Miller and

rc LRW 1 Joe Logan.

2 WITNESS ZEWE: And Jim Seelinger. Well, they
3 weren't strictly on 12 to 12, I don't believe. They
4 overlapped a considerable amount of time. For certain
5 periods of time, we would have two superintendents there at
6 one time.

7 MR. FRAMPTON: But the three of them -- Miller,
8 Seelinger and Logan -- were trading off at one level -- in
9 effect, superintendent -- and below them, Floyd and Ross
10 were trading off. Is that your perception?

11 WITNESS ZEWE: Yes.

12 MR. FRAMPTON: All right. On Friday morning, the
13 30th, Jim Floyd was your immediate supervisor?

14 WITNESS ZEWE: Yes.

15 MR. FRAMPTON: Do you recall whether Joe Logan was
16 there at, say, 6:00 or 7:00 a.m. on Friday morning?

17 WITNESS ZEWE: I couldn't say with much assurance
18 because at that time I really didn't keep track of what time
19 one came and what time one left. Some of them changed
20 shifts at like 4:00 in the morning and I get the days for
21 the ensuing two weeks pretty much confused on who was there
22 at any one point.

23 At the particular time, there was no question what the
24 chain of command was at any particular period.

25 MR. FRAMPTON: Now, I think in previous

re LRW

1 testimony, you have said that during the early morning
2 hours, the makeup tank was being burped in the sense that
3 the valve was just being cycled until it hit open and then
4 it would be cycled back closed; is that correct?

5 WITNESS ZEWE: That is true.

6 MR. FRAMPTON: I think some of the reactimeter
7 data or strip charts we have show a couple of venting
8 periods that are a little longer than that at about 2:00
9 o'clock and 3:00 o'clock a.m. on Friday morning. 20 or
10 25-minute time periods when the valve was left open and then
11 closed again.

12 Does that ring a bell with you?

13 WITNESS ZEWE: No.

14 MR. FRAMPTON: Does that seem right?

15 WITNESS ZEWE: No. All that morning on our shift,
16 I recall no instances at all that it was open longer than
17 cycle only.

18 WITNESS FAUST: That would have been me.

19 MR. FRAMPTON: Do you recall whether that sounds
20 accurate?

21 WITNESS FAUST: It doesn't to me, because we
22 were -- when we made the major release, so to speak, we ere
23 under the guidelines just to cycle it short durations and
24 shut off the valve and wait.

25 We were sending a guy in the building. Be right back to

re LRW

1 start the waste gas compressors at the time of venting, so
2 we could hopefully hold the pressure down to put it right
3 into the waste gas tanks.

4 MR. FRAMPTON: The individual who was being sent
5 to start up the waste gas compressor had to be suited up?

6 WITNESS FAUST: Yes. It took him a good deal of
7 time to get in there and get back out. They weren't
8 spending much time in the building at that period.

9 WITNESS FREDERICK: Can I asked a question? What
10 piece of reactimeter is giving you the valve position?

11 MR. FRAMPTON: Apparently there is a gentleman
12 name Jerry who was at some point assigned to keep a log to
13 make notes in the control room and his notes, I am told, are
14 what indicate the longer periods of opening the valve.

15 WITNESS FREDERICK: That is not reactimeter data.

16 MR. FRAMPTON: That is correct.

17 WITNESS FREDERICK: We are going by what a man
18 wrote in a log.

19 WITNESS FAUST: Whether he knew -- he might have
20 missed -- gotten the information wrong on what we were doing
21 at the time.

22 MR. FRAMPTON: That is correct. That is why I am
23 asking you what your understanding of it was.

24 WITNESS FAUST: I don't remember going through
25 anything longer than just cycling the valve.

re LRW

1 MR. FRAMPTON: Fine.

2 Mr. Zewe, let me ask you to describe what it was that
3 happened that caused you to go into a mode of venting the
4 tank over a continuous period. What was the first thing
5 that happened that made you change your tack?

6 WITNESS ZEWE: Well, Mr. Faust and myself were
7 mainly involved in this along with Greg Hitz, another shift
8 supervisor. When that happened, we had lost the makeup tank
9 level because of the increasing pressure that was built up
10 into the makeup tank.

11 We had to increase our frequency of venting the makeup
12 tank to keep it less than 80 pounds which is the relief
13 set-point on the makeup pump suction line from the makeup
14 tank itself. We didn't want that relief to lift.

15 Plus the increased pressure was putting more back
16 pressure on the let-down system flow and the let-down system
17 flow was diminishing rapidly also.

18 So, at some point -- it was around 6:30 or 7:00, I guess
19 it was -- the makeup tank, we lost the level from the makeup
20 tank and we had reached the relief valve set-point of 80
21 pounds on this line. So, it had -- we had thought that it
22 had lifted and discharged water from the makeup tank on its
23 relief valve to the RC bleed tank header.

24 MR. FRAMPTON: Let me ask you a question about
25 that. Would the fact that you lost the level in the makeup

re LRW

1 tank, would that be caused by the pressure forcing all of
2 the water over into the reactor coolant bleed tank or would
3 that -- could the loss of level occur simply because the
4 flow stopped and whatever coolant was in there went on back
5 into the primary system?

6 WITNESS ZEWE: I believe that as the relief valve
7 discharged the water, it caused a rapid reduction in level.
8 We weren't feeding at a very high feed right to the reactor
9 coolant system.

10 Throughout the night we had allowed the makeup tank
11 pressure to get substantially higher than what we had been
12 controlling it at earlier and we had been bringing down
13 the makeup tank level from where we had it before so we
14 could minimize the required time that we would have to
15 vent.

16 We got into that situation where we had the makeup tank
17 somewhere around 25 inches or so and the pressure greater
18 than 75 pounds to where we had an operator that was being
19 dressed out in protective clothing to go in and start the
20 waste gas compressors and follow the same procedures we
21 followed all that night and the previous day, of him
22 starting the air compressors by hand and us cycling the
23 valve.

24 So before he was able to go in there and start this
25 procedure of starting the waste gas compressors is when we

re LRW

1 reached the 80 pounds or above. It actually went up to
2 about 82 or 83 pounds. The relief valve blew over to the
3 reactor coolant drain tanks.

4 I had just came back from an interview with the GPU. I
5 had left the control room for just about an hour. When I
6 came back, we had the zero level in the makeup tank and it
7 was reported to me that we had lost two or three feet from
8 the BWST and the bleed tanks were pressurized and appeared
9 to be overflowing with a high level.

10 MR. FRAMPTON: Let me stop you a minute and ask
11 you some more questions. When you say the relief opened
12 from the makeup tank and dumped the coolant there, are you
13 talking about a liquid relief valve that would dump that
14 into the bleed tanks?

15 WITNESS ZEWE: Yes. The relief valve is between
16 the makeup tank and the suction of the makeup pumps when
17 always should be liquid. It was that night, too.

18 MR. FRAMPTON: Had the gas relief valve on the
19 makeup tank, the automatic valve, opened prior to that time?

20 WITNESS ZEWE: Which automatic gas relief valve?
21 There isn't one.

22 MR. FRAMPTON: There is no automatic gas relief?

23 WITNESS ZEWE: There is a manual control vent.

24 MR. FRAMPTON: That is the valve you were cycling.

25 WITNESS ZEWE: Right. There are other makeup

rc LRW 1 let-down relief valves, all right? But there is none that
2 will relieve the pressure in the makeup tank automatically.
3 There is not.

4 MR. FRAMPTON: If you had not been controlling the
5 manually operated gas relief valve on the makeup tank, how
6 would gas have been released automatically upon
7 overpressurization? Would the gas go into the reactor
8 coolant bleed tank and up into the relief vent header?

9 WITNESS ZEWE: Through the relief valve, it lifted
10 at 80 pounds. That is the only automatic valve that
11 relieves the overpressure in that system in the makeup tank.

12 MR. FRAMPTON: That valve goes where?

13 WITNESS ZEWE: To the header to the RC bleed
14 tanks.

15 MR. FRAMPTON: Gas would go with the water flow
16 into the reactor coolant bleed tanks?

17 WITNESS ZEWE: Yes. Whatever carried over with
18 the water would be the gas and it would go there also.

19 WITNESS FAUST: You understand what the valve is?
20 It is on the bottom of the tank. Outlet piping. After you
21 blow all the liquid out of it, then you get the gas.

22 MR. FRAMPTON: Would the gas blow through there or
23 would the valve close?

24 WITNESS FAUST: If the pressure is high enough, it
25 will blow through that relief valve if it gets down to that

re LRW

1 point. If it did, it would probably wipe out our makeup
2 pumps, too, though.

3 WITNESS ZEWE: Whenever we lost the makeup tank
4 level, we then switched our suction for the makeup pumps to
5 a part of BWST so the makeup pumps were still operational
6 from the BWST.

7 MR. FRAMPTON: When you came back, and I think you
8 have previously testified, observed that the reactor coolant
9 and the bleed tank level went up and the BWST level had gone
10 down, the cause for that would have been the makeup pumps
11 switched and took makeup flow from the BWST after the makeup
12 tank itself drained over into the bleed tanks; is that
13 correct? Or am I wrong?

14 WITNESS ZEWE: Whenever you open up the valve
15 between the makeup tank and BWST, you would assume the
16 makeup tank would take the suction from the BWST, but what
17 we didn't perceive right on was that why was the BWST going
18 down and the bleed tanks going up? How we were transferring
19 the water from the BWST into the makeup tank system and into
20 the reactor coolant bleed tank.

21 MR. FRAMPTON: So there is a route by which once
22 you lose makeup level, you can be drawing water from the
23 BWST right through into the bleed tanks.

24 WITNESS ZEWE: That is the design of the system,
25 yes. Oh, no, no, no. Just to provide suction for the

rc LRW

1 makeup pumps.

2 It is not designed or intended to function going from the
3 BWST to the makeup to the bleed tanks. All right? That was
4 a path we had never explored before.

5 But we had it and we then determined that because the
6 relief valve was open, the makeup pumps were mainly on full
7 recirc, all right? They were keeping that along with the
8 high pressure from the let-down that was keeping the relief
9 open.

10 The recircs for the running makeup pump was going into
11 the makeup tank and going to the bleed tank. We developed
12 a path from the BWST to the makeup pump through the recirc
13 into the makeup tank, again blowing out the relief. We had
14 a large transfer of water in that path.

15 That was not a design or intended path by any means.

16 WITNESS FREDERICK: One of the difficulties of
17 determining that path was actually that flow of water that
18 should take place at the bleed tank level indication was not
19 really designed to indicate that small a level change. We
20 were already high on the level indicators when we started
21 this.

22 A one-foot change is something like 30,000 gallons. So
23 you would have to wait a long period of time before you
24 would know this was going on. That is why it was slow in
25 discovering the path.

PC LRW

1 WITNESS FAUST: If you lost makeup tank level,
2 what they were working with, you were looking at the
3 pressure change in the tank from that point on. Plus, you
4 couldn't shut the suction path from the BWST because you
5 didn't know what the level in the makeup tank was.

6 MR. CUNNINGHAM: I have a question. Do you have a
7 feel for how much water you can put through one of those
8 recirc lines? How much water can be transferred?

9 WITNESS FREDERICK: One line?

10 MR. CUNNINGHAM: However many would be used at
11 that time.

12 WITNESS ZEWE: Flow required for the makeup pump
13 is 90. The recirc flow is right around 100 GPM. It is a
14 flow orifice. So in the neighborhood of 100.

15 MR. FRAMPTON: So one of the reasons for having to
16 vent the makeup tank with the manually operated vent valve
17 was to prevent the direct transfer of BWST inventory through
18 the makeup tank over to the bleed tanks; is that right?

19 WITNESS ZEWE: At this point, right. We wanted to
20 prevent that uncontrollable path through the relief valve.
21 We had no positive or manual control of controlling of that
22 path. The only way we could regain control of the system
23 was to force that relief valve to shut on its blowdown
24 setting.

25 So that, in fact, is what we did. We opened up the vent,

rc LRW

1 which was still shut at this time, so try to reduce the
2 pressure so we could force water into the makeup tank and
3 then regain suction of the makeup pumps on to the makeup
4 tank. That is what we did.

5 We vented the makeup tank to reduce the pressure and shut
6 the relief valve. We put on some de-min water transfer
7 pumps to try to force water into the makeup tank.

8 As soon as we recovered some visible indication in the
9 makeup tank, we switched the suction from the BWST back to
10 the makeup tank. Then we continued to vent the makeup tank
11 down knowing that it was still controllable, that at any
12 point, we could shut that vent and stop the present release
13 path that we had.

14 But we felt we were monitoring it and that we had more of
15 a controllable situation other than the fate of the relief
16 valve, which was not controllable.

17

18

19

20

21

22

23

24

25

CR 6978

LRW #3

jc 1

1 MR. FRAMPTON: Let me go back to the time when that
2 decision was made. Who basically made the decision to vent
3 the makeup tank for a limited period of time? Was that you
4 and Mr. Hitz?

5 WITNESS ZEWE: We made the ultimate decision to
6 go ahead but it was recommended by Mr. Faust. We were
7 exploring alternatives to the situation and then Mr. Faust
8 said that we just got to get the pressure down. Let's just
9 open up the vent.

10 I elected to do that. It was my ultimate decision to do
11 that based on his input. Our first plans were to open it
12 up just to reseal the relief valve and I picked 65 pounds to
13 shut the vent again.

14 MR. FRAMPTON: Your initial intention was just to get
15 the pressure down far enough that the liquid relief valve would
16 reseal.

17 WITNESS ZEWE: Right. Once we got to that point
18 under strong urging from Mr. Faust, and then Mr. Hitz and my
19 own reasoning was since we have it controlled, let's go ahead
20 and vent it off and leave open the vent is what we finally
21 determined to do. To leave the vent open and monitor the
22 release and then just take the gas buildup in small puffs from
23 thereon instead of a great big release every so often. So
24 that is what we elected to do and made that decision to do
25 that.

1 MR. FRAMPTON: Mr. Floyd said, in some of his interviews,
2 he made that decision. Was he consulted about that before
3 you started to do it as far as you can recall?

4 WITNESS ZEWE: He was aware of the decision, but I
5 don't recall that he made the decision. It was a decision
6 that was made, you know, in the course of events, opening
7 up to get enough water to stop the release. We did what I
8 felt was the best course of action at the time and really I
9 believe Jim's interface was more that he was aware of what
10 we were doing and agreed with what we were doing rather than
11 saying this is what I would like you to do.

12 The events there were somewhat rapid in succession and we
13 just reacted to what we had more so than waited for a whole
14 series of commands to be made.

15 WITNESS FAUST: You are aware of what it gained us by
16 doing that. What we were looking for if we kept going with
17 that relief valve popping open on us.

18 MR. FRAMPTON: Let me ask you a couple of questions
19 about that.

20 MS. RIDGEWAY: Could you direct these questions to
21 a specific individual?

22 MR. FRAMPTON: Yes.

23 Mr. Faust. I will direct these questions to you, Mr.
24 Faust. Let me see if I understand correctly the reasons
25 why the decision was made. Had you not opened the vent

jc 3

1 valve, I take it you were afraid that you would continue to
 2 have that unplanned path by which water from the BWST would
 3 come into the makeup tank but then would go out through the
 4 automatic relief valve and transfer straight over to the
 5 bleed tanks; is that right?

6 That is one of the things that would have happened.

7 WITNESS FAUST: The other thing is that sooner or later
 8 if we left it like that, we would end up taking the suction
 9 off the reactor building at which time we knew we didn't
 10 want to go in there if we could help it.

11 We were already having problems with radioactivity we
 12 didn't care for.

13 MR. FRAMPTON: When you say that, what do you mean?

14 WITNESS FAUST: End up actually going on decay heat,
 15 going into a piggyback operation to supply water from the
 16 building through the makeup pump via the decay heat pump and
 17 go back into our seal injection.

18 MR. FRAMPTON: Is the reason for that that the
 19 makeup flow provides seal water for the reactor coolant
 20 pump?

21 WITNESS FAUST: At the time we were running the
 22 reactor coolant pumps. A reactor coolant pump. It stands
 23 a chance of not providing seal water within the building, is
 24 possibly wiping out the seal on the makeup pump. You have
 25 another flow of water, you will end up in the same place.

jc 4

1 You have to supply water into the system just to keep the
2 pressure up now. The fluid inventory in the system.

3 MR. FRAMPTON: What you are saying is without getting
4 that relief valve closed, you weren't going to have any makeup
5 flow at all.

6 WITNESS FAUST: The BWWT level would drop from a
7 short period of time from an already low level of around 18
8 feet, we ended up somewhere 19 feet, we ended up with 15
9 feet.

10 No plants initially had been made to get that BWST
11 replenished with water and we didn't know what we were faced
12 with in the future. We were losing our last source of water
13 there.

14 MR. FRAMPTON: With the makeup tank automatic relief
15 valve open, is there any way of providing makeup flow from
16 the BWST into the primary coolant system?

17 WITNESS FAUST: With the --

18 MR. FRAMPTON: With the relief valve open.

19 WITNESS FAUST: You can provide it in but you have to
20 provide flow path for your makeup pump. If your minimum
21 flow, we were supplying mainly just seals which would be less
22 than the recirc capability needed for the pump to operate.

23 If we isolated the makeup tank, it would end up burning up
24 the makeup pump. Possibly. We don't know that for a fact
25 because we don't know the flow going into the RC pumps. Just

jc 5

1 seals isn't enough for the design of the makeup pump to keep
2 it cool.

3 MR. FRAMPTON: All right. Mr. Zewe, let me go back
4 and ask you what phone calls or notifications you can remember
5 making before you made the decision to open the vent valve and
6 leave it open. You, I believe, have said that you called the
7 Unit 1 control room before you did this or as you began to do
8 it in order to tell them to be alert for monitoring of
9 releases; is that right?

10 WITNESS ZEWE: I didn't make any phone calls person-
11 ally. Greg Hitz, the other supervisor, did, as I recall, call
12 the Unit 1 control room to the ECS to inform them we expected
13 to have a release because of the venting, more that we are
14 doing it and to expect the release and make sure the helicopter
15 is up to monitor the release. Which was done.

16 Any other calls made other than that one, I am unaware of.
17 It was at that point where the station manager came into the
18 control room.

19 MR. FRAMPTON: Who was that?

20 WITNESS ZEWE: Gary Miller. He assigned Craig for
21 the notification and assigned me plant responsibility only.

22 MR. FRAMPTON: Mr. Miller knew you would do this just
23 before you did it or as you were getting into it?

24 WITNESS ZEWE: It was already in the works. Mr. Hitz
25 was there to relieve me as the normal course of events as we

jc 6

1 did there. When Gary came in, he announced he was taking
2 charge and that he instructed me to operate the plant or have
3 plant responsibility and Mr. Hitz to make some of the necessary
4 notifications, which he was already in the process of doing.

5 MR. FRAMPTON: Did Mr. Miller come in for any reason
6 connected with this venting you were doing or did he just
7 happen to come in at that time?

8 WITNESS ZEWE: I believe he was called in. He was
9 already on site but I believe, just from what I heard, he
10 was asked to come to the control room. I am not sure if
11 he was in his normal rotation through the control room as
12 superintendent or not. I don't believe so.

13 I think he came up knowing we had another problem and he was
14 coming up to take charge of the situation.

15 MR. FRAMPTON: Had you asked Mr. Hitz before you
16 started the venting to call the ECS and let them know this
17 was coming?

18 WITNESS ZEWE: All together, we reacted to what we
19 had and were taking care of it. That was just to inform them
20 it was already in progress.

21 MR. FRAMPTON: And you are not aware of the call M
22 Floyd said he made to the Pennsylvania Civil Defense people
23 a little bit later on.

24 WITNESS ZEWE: My only knowledge there is what Mr.
25 Floyd has said I have heard and what I have read some days

jc 7

1 later.

2 MR. FRAMPTON: After the fact.

3 WITNESS ZEWE: Yes.

4 MR. FRAMPTON: Do you recall whether the helicopter
5 got up pretty quickly after Mr. Hitz notified the ECS?

6 WITNESS ZEWE: Yes. I do. I am not certain where
7 the helicopter was at the time we had requested it. I believe
8 it was already flying and he positioned himself over the stack.
9 And I recall hearing the first reading that he gave was 1200
10 MR directly over the stack. That was the first reading that
11 I remember.

12 Then he flew around and gave his readings at certain
13 marked intervals from the site. So I knew at that time that
14 we had the teams out in the field plus we had at least one
15 helicopter in the air with radiation instruments to monitor
16 the plume we had.

17 MR. FRAMPTON: Do you know when that vent valve was
18 closed?

19 WITNESS FAUST: It wasn't.

20 MR. FRAMPTON: Do you have any knowledge of that?

21 WITNESS FAUST: The vent valve wasn't shut. At
22 least I was in the process of getting relieved after we
23 initially got the makeup tank level reestablished and it was
24 shortly after we performed this vent. I turn it over to Denny
25 Olson with the understanding it was to stay open. Get makeup

1 tank pressure down, in other words, to zero pressure and leave
2 it there.

3 MR. FRAMPTON: It was not at zero pressure when you
4 went off.

5 WITNESS FAUST: Not quite. Somewhere around 30 pounds
6 yet on the tank.

7 MR. FRAMPTON: About what time was that? Do you
8 recall? On Friday.

9 WITNESS FAUST: Right around 7:00. Probably after
10 the hour now.

11 WITNESS ZEWE: It was like 9:00 or 9:30 maybe at
12 that time.

13 WITNESS FAUST: We didn't get out of there for a
14 while.

15 MR. FRAMPTON: As far as your turning the status
16 over to your replacement, you told him that it ought to stay
17 open until you got -- until he got the pressure down to zero.

18 WITNESS FAUST: I told him to keep it open. The
19 idea was once you get the pressure down, my reasoning was
20 anyway, you no longer have any kind of release. If anything,
21 it will be low. It will be a minimal release over a period
22 of time. Just decay.

23 However long it takes. You won't have bursts we were giving
24 every time you cycle it open and get a cloud going.

25 MR. FRAMPTON: It was your thought if the vent valve

1 was left open, you would get a very low level continuous
2 release.

3 WITNESS FAUST: That is the way I looked at it
4 anyway.

5 MR. FRAMPTON: Maybe I should ask Mr. Zewe, do
6 you know when the vent valve was eventually closed or was it
7 just left open indefinitely throughout the day and the next
8 day?

9 WITNESS ZEWE: Essentially it may have been shut
10 for a very short period of time. Being wasn't there, I
11 wouldn't know. Essentially it was left open for that entire
12 day and I believe for the great portion of the next several
13 days, it was left open.

14 MR. FRAMPTON: When Mr. Miller came into the control
15 room, did you brief him on the status of the plant, what
16 was happening with the vent valve and so forth?

17 WITNESS ZEWE: I certainly did.

18 MR. FRAMPTON: What was his reaction? Do you recall?

19 WITNESS ZEWE: He concurred. I didn't brief him in
20 great detail other than that we had transferred the water and
21 what actions I had taken. Before I took any of these actions,
22 I had announced to the control room what we were doing. If
23 anyone had objections to it at this point, we had in the
24 neighborhood of I would say 25 people in the control room, NRC
25 staff, superintendents, so forth from the company. So I

1 announced I was going to open up the vent, that I was going
2 to put on two de-min water transfer pumps and we were going
3 to switch the suction back, to see if anyone had objections.

4 I felt it was necessary action. I told everyone together
5 so if they had concerns, they would bring them forth then.
6 Say no, that is wrong, do this. But I had no response that
7 was negative at all from anyone. I did it in that light.

8 I consulted everyone there if they had objections. I didn't
9 have very many inputs on suggestions on what to do so once
10 I elected to do that, thinking that that was the best course
11 of action, I just told everyone what I was going to do and
12 what we had planned to do and there was certainly no objection
13 at the time.

14 MR. FRAMPTON: Mr. Miller concurred when he came in,
15 when you briefed him on what was happening.

16 WITNESS ZEWE: As I remember, he did. If not, he
17 would have directed me otherwise.

18 MR. FRAMPTON: Do you recall whether he was aware
19 at that time that you had decided to go ahead and keep it open
20 and go on down to zero and try to solve the problem?

21 WITNESS ZEWE: I kept him informed as decisions were
22 made at my level.

23 WITNESS FAUST: It did solve the problem.

24 MR. FRAMPTON: Did Mr. Miller continue to be in the
25 control room for a while after this period?

1 WITNESS ZEWE: Yes, he was in the control room for,
2 up until the time I left.

3 MR. FRAMPTON: How about Mr. Logan? Do you recall
4 whether he was there?

5 WITNESS ZEWE: I really couldn't say with certainty
6 that he was or not. There were several people there. He
7 could have come and gone and one or the other ones could
8 have been there at that time. At that time I dealt with Mr.
9 Floyd and Mr. Miller directly.



10 WITNESS FAUST: Everybody was aware of what that really
11 did for us, though, I just wanted to keep you up with this.

12 MR. FRAMPTON: I want to ask you one other question,
13 Mr. Faust, on the subject of what it did for you.



14 I have read in previous testimony some discussion of the
15 fact that if the manual vent valve on the makeup tank had not
16 been opened, that gas ultimately would have escaped on over
17 pressure through a route that would take it into a relief
18 vent header that bypasses some of the filtration.

19 Can you explain to me what that alternative path would
20 have been? Where the gas would have gone?




21 WITNESS FAUST: For one thing it would have went to
22 the bleed tank via another relief valve. In other words, your
23 pressure in the system, the tank would build up to the point
24 where not only would you go out possibly that bottom relief
25 path, if for some reason that didn't relieve all the pressure



**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



jc 12

1 to the bleed tank, it would end up in a relief valve further
2 up the makeup tank let down line which also vents here to
3 the bleed tank, too, and that is to the waste gas header.
4 Overpressurize the waste gas header and bypass the tank as
5 well as the filter.

6 You go a straight path to 219 or vent path or our monitor
7 at the stack.

8 MR. FRAMPTON: Further up the let down line there is
9 a gas relief safety relief valve?

10 WITNESS FAUST: I don't know if it is looked at as a
11 gas relief. This is a fluid system normally. It is a relief
12 valve.

13 MR. FRAMPTON: That goes to the reactor coolant bleed
14 tanks.

15 WITNESS FAUST: Yes.

16 MR. FRAMPTON: What happens with gas overpressure
17 in the reactor coolant bleed tanks?

18 WITNESS FAUST: For one thing it goes to the vent
19 header. The gas system.

20 MR. FRAMPTON: The relief vent header.

21 WITNESS FAUST: Yes. The tanks are designed for 20
22 pounds. The bleed tanks are designed, I believe, for 20
23 pounds pressure. I don't know what the rupture point is, but
24 I am sure the vent header was already overloaded as far as
25 being able to keep up with the gas pressure being jumped into it.

1 to the bleed tank, it would end up in a relief valve further
2 up the makeup tank let down line which also vents here to
3 the bleed tank, too, and that is to the waste gas header.
4 Overpressurize the waste gas header and bypass the tank as
5 well as the filter.

6 You go a straight path to 219 or vent path or our monitor
7 at the stack.

8 MR. FRAMPTON: Further up the let down line there is
9 a gas relief safety relief valve?

10 WITNESS FAUST: I don't know if it is looked at as a
11 gas relief. This is a fluid system normally. It is a relief
12 valve.

13 MR. FRAMPTON: That goes to the reactor coolant bleed
14 tanks.

15 WITNESS FAUST: Yes.

16 MR. FRAMPTON: What happens with gas overpressure
17 in the reactor coolant bleed tanks?

18 WITNESS FAUST: For one thing it goes to the vent
19 header. The gas system.

20 MR. FRAMPTON: The relief vent header.

21 WITNESS FAUST: Yes. The tanks are designed for 20
22 pounds. The bleed tanks are designed, I believe, for 20
23 pounds pressure. I don't know what the rupture point is, but
24 I am sure the vent header was already overloaded as far as
25 being able to keep up with the gas pressure being jumped into it.

jc 13

1 I am just saying you got possibilities you can talk about
 2 here. It would have probably fully handled the capability
 3 of what we were venting off and just put it to the atmosphere,
 4 but you also stand a chance of maybe a rupture of the tank.

5 MR. FRAMPTON: Mr. Frederick, you were nodding your
 6 head. Did you want to add something to that?

7 WITNESS FREDERICK: Speculation about the relief
 8 through the let down line would have to be focused on whether
 9 or not the de-mineralizer bypass valve was open at that time.
 10 I think you would have to go back through the testimony and
 11 find out when the de-mineralizer bypass valve was open.

12 Otherwise the relief path wouldn't have existed back through
 13 that line. Those are stop-check valves. The only path you
 14 would have would be through the makeup tank relief discharging
 15 the tank which is a much larger line.

16 WITNESS FAUST: You are talking about isolating
 17 the makeup tank.

end 3

18
 19
 20
 21
 22
 23
 24

LRWros

1 MR. FRAMPTON: What I am asking you is if you had
2 not vented the makeup tank manually to let the gas off into
3 the vent header and the makeup tank had simply
4 overpressurized and the relief valve opened, which it did,
5 the relief valve to the reactor coolant bleed tank; how
6 would the gas from the makup tank then have escaped? What
7 passageway would it follow?

8 WITNESS FAUST: The same one. We just vented it
9 -- the open-end vent valve on top of the makeup tank vented
10 to the gas header. We stood the same chance of venting it
11 that way as if we let that relief valve keep going. The
12 think about the relief valve, it took a lot of water from
13 the BWST with it doing it manually. We weren't. We were
14 venting the gas pressure off trying to get it down to where
15 we could reestablish our voluntary control system, in other
16 words.

17 We were heading also to another part, if you look at the
18 primary, we weren't getting much water out for what we were
19 putting in. And we were heading solid at the time of the
20 primary. That is another headache we didn't need.

21 MR. BELLAMY: If this a good time, I have five or
22 six questions.

23 MR. FRAMPTON: I have one more.

24 When you came on shift, Mr. Zewe, in the late evening of
25 Thursday, were you told that there were any ground rules

LDWros 1 or procedures to be followed in connection with this
2 venting?

3 That is, were you told that we are venting and we should
4 continue to vent; or before we vent we have to ask somebody;
5 or was the shift turned over to you in a way that that would
6 be your decision to make?

7 WITNESS ZEWE: We had a procedure that directed us
8 how to vent with the current plant conditions that we had.

9 MR. FRAMPTON: What was that procedure?

10 WITNESS ZEWE: Basically exactly what we said it
11 was, to go ahead and send in an auxiliary operator into the
12 auxiliary building to start the gas compressors and bring
13 down the waste gas header down as low as he could. And then
14 cycle the vent, open and shut, wait for the operator to
15 reduce the gas pressure, which normally went up to about 12
16 or 15 pounds on that burst. And then he would manually
17 operate the compressor again and bring down the pressure to
18 about two or three pounds, cycle it again. And you might
19 have to cycle it several times to reduce the pressure far
20 enough to where he could come on out and there would be
21 sometime before you would have to send him in again.

22 We were operating with that procedure.

23 MR. FRAMPTON: Let me show you something that I
24 would like to have marked as Exhibit 7.

25 (Exhibit 7 identified.)

LWros

1 MR. FRAMPTON: This is a one-page handwritten
2 procedure called venting MU tank gas space to vent header,
3 dated 3/29/79. This appears to be a procedure that someone
4 wrote out for doing what you described.

5 Do you know what that is? Do you recognize it?

6 WITNESS ZEWE: That looks like the procedure that
7 we had in effect at the time, yes.

8 MR. FRAMPTON: Do you recall whether somebody
9 handed that to you?

10 WITNESS ZEWE: We had this available to us, yes.

11 MR. FRAMPTON: That was developed by somebody
12 before you came on shift?

13 WITNESS ZEWE: Yes. We had developed this earlier
14 on the 29th, as I remember. Yes, earlier on the 29th,
15 before I left in the afternoon.

16 We changed our procedures somewhat because we had been
17 opening up the vent as necessary. But then as it became
18 apparent of the hotter release that we had, we had gone to
19 the cycling of the valve. So actually as I remember it, we
20 had had two different venting procedures up to this point.
21 One had superceded the other one.

22 MR. FRAMPTON: Do you know who wrote this out? Do
23 you recognize that handwriting?

24 WITNESS ZEWE: One of the two we had was written
25 in part at least, by another shift supervisor, Joe Chwastyk,

LPWros 1 as I remember. Only what I believe I remember, so to speak.

2 MR. FRAMPTON: Did you and Mr. Chwastyk pretty
3 much, work out these procedures yourselves?

4 WITNESS ZEWE: Every procedure that was written we
5 certainly had a definite input into it, because we had to
6 perform that. Mr. Chwastyk relieved me on the 28th when I
7 left, and then when I returned I in turn relieved him at a
8 quarter of 3:00 on the 29th. We had a great deal of
9 interface.

10 Every procedure always went through the shift foreman
11 and shift supervisor to make sure if they had comments on
12 them. That is standard procedurally. The shift supervisor
13 has final approval on all procedures.

14 MR. FRAMPTON: When the decision was made to vent
15 the tank at around 7:00 in the morning, I take it there was
16 one or more NRC people in the control room; is that right?

17 WITNESS ZEWE: Yes.

18 MR. FRAMPTON: What was their role as you
19 perceived it? Were they there simply to observe what was
20 happening and report back to their supervisors? Or did they
21 have more of an operational role?

22 WITNESS ZEWE: From my standpoint, I had very
23 little input from them in the way of recommendations. I
24 used them more as informing them, all right. How they
25 interfaced with the emergency director and the unit

LWros

1 super, I don't know, because we kept a pretty definite
2 separation between operations of the plant and the use of
3 the TMI emergency planners. So whether they had more input
4 to the unit super or the station super in relationship to
5 overall emergency plans, I don't know. But I had very
6 little input and I really can't recall any specifics of help
7 from the NRC, so to speak, on recommendations on what to
8 do.

9 I really didn't look toward them for that help on a
10 plant related nature because I know the plant and their
11 plant knowledge is somewhat limited. All right? So I
12 really couldn't ask them on general specifics, all right?
13 But just overall guidance, all right?

14 Yes. But I don't recall asking for or receiving any.

15 MR. FRAMPTON: So there were NRC people in the
16 control room at that time.

17 Now, had there been any kind of agreement or arrangement
18 that significant operations action should be told to the NRC
19 or cleared with any NRC people prior to 7:00 on Friday
20 morning that you knew about?

21 WITNESS ZENE: My understanding was to keep them
22 informed and certainly if they had any objections or any
23 comments, you know, to take them into account.

24 MR. FRAMPTON: When you say keep them informed,
25 you understood that they should -- they were there to

LDWros 1 observe, and they should be informed as to what was
2 happening so if they had any strong objections they had an
3 opportunity to interpose them; is that right?

4 WITNESS ZEWE: Certainly. For any evolution, we
5 hope that every evolution is planned and that we have a
6 method of attack and a procedure to follow and observe. All
7 right? In every case, we certainly informed them prior to
8 the event or prior to the evolution.

9 MR. FRAMPTON: Do you know when that agreement or
10 understanding was reached? Would that have been in effect
11 from the first time these fellows showed up on Wednesday?

12 WITNESS ZEWE: From the beginning. We were at the
13 point -- it's always that way, you know, that you are always
14 open for suggestions from anybody because two heads are
15 better than one, so to speak. And you certainly can never
16 afford to ignore any judgment or any comments or any
17 criticism from another source that may be valuable in
18 helping you to reach your own conclusions and assessments.
19 It's foolish not to do so.

20 I don't know if Mr. Miller, who was in charge, stopped
21 everyone and said from now on we will do this. It was more
22 of an understood thing and that is how we operated.

23 The senior management that was there were making the
24 decisions based on their inputs, just like any other
25 evolution that we had, and they were always informed

1 before hand, if we could, naturally, because they were
2 making the decisions and the NRC were there the whold time
3 and were included in Mr. Miller's team that was making
4 decisions and having the input to it.

5 MR. FRAMPTON: Would that have been the same,
6 then, on Friday morning as it was when the NRC people got
7 there to observe what was happening on Wednesday?

8 In other words, in your view the situation hadn't
9 changed any in terms of your wanting to inform the NRC
10 people of what you're doing between Wednesday and Friday.
11 Was there a different regime that had come into effect
12 between Wednesday when NRC inspectors were in the control
13 room and Friday morning?

14 WITNESS ZEWE: I am not sure of the different
15 regime, so to speak, but all the things we were doing on the
16 28th after the command team, so to speak, was established,
17 all the direction came from them and we had input back.

18 But on the 30th, where we had a problem where we didn't
19 have any clear direction, we dealt with the problem as best
20 we could. We kept them informed in that light so that that
21 mode of progress very logically to where you have an input
22 and you have a decision and everyone is informed and
23 everything, that really didn't take place on that level. It
24 moved down to my level as the shift supervisor to handle
25 immediate plant actions which Mr. Miller directed from the

LRWros

1 beginning, that any immediate actions I felt had to be taken
2 were strictly our decisions at that time.

3 But certainly try to use the command team that we had.
4 But anything that arose immediately we had to take care of
5 in the normal course of action that we felt was warranted.

6 MR. FRAMPTON: If you recall on Friday morning,
7 were there any NRC people in the control room who had enough
8 knowledge about the plant to even be helpful on something
9 like this?

10 WITNESS ZEWE: The only inspector there that I can
11 remember on Friday was James Higgins, who I dealt with
12 previously. He is an expert, so to speak, on containment
13 for leak rate testing and for pressurizing the containment
14 stems and the containment building itself. I had dealings
15 with Mr. Higgins in unit one and unit two. He was fairly
16 familiar with the containment structure as it was.

17 But by and large, the other ones that were there for the
18 most part I didn't know them, and I really had no confidence
19 level either way of how capable they were, other than they
20 were outside people and any one that was not closely
21 connected with the operations of the unit, I rather doubted
22 their limited capability because of their knowledge level of
23 the plant. Other than general type physics knowledge, or
24 general radioactivity knowledge, or something like this.
25 But not specifics.

LWros

1 MR. FRAMPTON: Was there any question in your mind
2 as to whether they had any kind of veto authority?

3 In other words, suppose one of those NRC inspectors had
4 said when you announced you were going to start venting the
5 makeup tank: "Hey, I don't want you to do that. You
6 shouldn't do that." Or, "I have a different idea. I don't
7 want you to do that until we discuss it."

8 Would that have stopped it?

9 I mean, did they have, in effect, the authority to say
10 you can't do something until I tell you it's all right? In
11 your mind?

12 WITNESS ZEWE: In my own mind, I have the license
13 and the responsibility for the unit. I take action deemed
14 according to what I feel I must do, based on my own
15 assessment.

16 I would have certainly taken into consideration anything
17 or any alternatives he had. But where I had certain
18 options, A, B, C, D, E, I would have applied the best
19 options I had and taken that course of action which I hope
20 would not have been vitally against what he had suggested.

21 But I was mainly, myself, Greg Hitz, the other
22 supervisors there, Jim Floyd and the superintendent that was
23 there, would have certainly went to them to say: "Hey," --
24 if it was a violent don't do this, "It's bad, and I forbid
25 that from the NRC-type standpoint." All right?

LWros

1 I would have certainly questioned that. Looking at the
2 alternatives that we had, depending on what input they
3 supplied. It's purely conjecture on my part. I couldn't
4 see them raising a very stern objection. If they had I
5 would have certainly considered it.

6 MR. FRAMPTON: That didn't happen, however, at any
7 time during their descent?

8 WITNESS ZEWE: I personally didn't have any
9 response negative or really positively either from the NRC
10 that was there. It was more of a question, of a problem,
11 and I had the feeling that they would certainly have helped
12 and provided input if they had one. I'm sure they would not
13 have hesitated to come forth. But I didn't receive any.

14 MR. FRAMPTON: I'm sorry we have spent so long on
15 this subject. I know Ron wants to ask some questions.

16 Let's take a break and then let Ron finish up, and we
17 will move on to something else.

18 (Recess.)

19

20

21

22

23

24

25

1 MR. FRAMPTON: Back on the record. Mr. Scheimann,
2 we were having a conversation during the break about your
3 hours on duty and I think you said that you definitely recall
4 that you came back on Thursday evening so you were Thursday
5 at 11:00 p.m. to Friday morning at 7:00 a.m. roughly.

6 WITNESS SCHEIMANN: I think it was more like unti
7 about 11:00 in the morning.

8 MR. FRAMPTON: So you were in the control room
9 during the period we have been talking about that had to do
10 with the venting of the makeup tank; is that right?

11 WITNESS SCHEIMANN: Yes.

12 MR. FRAMPTON: And Mr. Zewe, you wanted to -- counsel
13 wanted you to make clear what you recalled about the paper
14 we have marked as Exhibit 7.

15 Do you want to do that?

16 WITNESS ZEWE: Okay. The exhibit that you showed
17 me here, which references the venting of the makeup tank gas
18 waste to the vent header, it is the basic procedure, as I remem-
19 ber, that we followed, but I can't say with 100 percent
20 certainty that this is the actual one I followed that day.
21 But it is the same sequence and I have no reason to believe
22 that it isn't, but I can't say that it is. Okay?

23 MR. FRAMPTON: Fine, thank you.

24 Mr. Frederick, at around 10:00 or 11:00 o'clock on Friday
25 morning, you left the site to go into Middletown and get

1 something to eat; is that correct?

2 WITNESS FREDERICK: Yes.

3 MR. FRAMPTON: Could you tell us what happened when you
4 got to the restaurant in Middletown?

5 WITNESS FREDERICK: I noticed some proprietors of
6 local business packing their cars with their belongings and
7 leaving town. Several of the construction workers at an
8 adjacent construction site were running quickly to their
9 vehicles and driving away.

10 MR. FRAMPTON: Did you go into the restaurant to
11 find out what was happening?

12 WITNESS FREDERICK: Yes. I went in and asked them
13 where everyone was going.

14 MR. FRAMPTON: What restaurant?

15 WITNESS FREDERICK: Augie's Sub Shop in Middletown.
16 I asked them what was going on. They said they heard a
17 radio announcement which said everybody should evacuate
18 within a 20-mile radius of TMI.

19 MR. FRAMPTON: Within a 20-mile radius of the plant?
20 Had they said what radio station they heard that on?

21 WITNESS FREDERICK: It was a York AM radio station
22 I believe.

23 MR. FRAMPTON: What did you do then?

24 WITNESS FREDERICK: I tried to calm the people in the
25 restaurant. There was only three workers there. Craig Faust

1 and myself. And I asked them to make me a sandwich. Then I
2 called the plant. I tried to get a hold -- I used the outside
3 phone number which wasn't used very often and got a hold of
4 the shift supervisor.

5 MR. FRAMPTON: Mr. Hitz?

6 WITNESS FREDERICK: Yes. I told him people were evacuating
7 Middletown as a result of a radio announcement, which these
8 people said was from Civil Defense.

9 MR. FRAMPTON: These people said --

10 WITNESS FREDERICK: The people in the restaurant.

11 MR. FRAMPTON: They said Civil Defense ordered the
12 evacuation?

13 WITNESS FREDERICK: Right. I had the radio on. I
14 was trying to hear the announcement myself. They didn't
15 repeat it while I was there. I told Mr. Hitz he ought to
16 check with the Unit 1 and Unit 2 people to see if anybody
17 ordered an evacuation we didn't know about.

18 I had just left the plant ten minutes before that and I
19 knew we weren't evacuating at that time. I wanted him to
20 check to see what the source of the announcement was.

21 WITNESS FAUST: All through this we have been hearing
22 after we left the plant a lot of things that the media was
23 putting out that wasn't what was going on at the plant.

24 MR. FRAMPTON: Mr. Zewe, you were present when Mr.
25 Hitz got the phone call from Ed Frederick?

1 WITNESS ZEWE: Yes. We were still into the makeup
2 tank venting which we talked about earlier and Greg was still
3 handling some of the communications. And I was still in
4 charge of the plant at that point as I remember. As soon as
5 he received that call, I heard him say, What? You got to be
6 kidding. Then I said, What is happening? He told me.

7 So I said, We better go in and tell Gary about it.

8 MR. FRAMPTON: What did you do then?

9 WITNESS ZEWE: We went into Gary Miller's office,
10 which is the normal shift supervisor's office where he had
11 his command team set up, and they were discussing -- I am not
12 sure at this point exactly what, but they were involved in
13 discussion at this point about something, and I just broke
14 in and said that we just had a report from Ed Frederick, who
15 is in Middletown, saying they are evacuating Middletown and
16 the surrounding areas. What is wrong?

17 Gary said we didn't do anything. He turned to at least one
18 NRC guy that was there that I recognized, and spoke to him
19 directly.

20 MR. FRAMPTON: Higgens?

21 WITNESS ZEWE: Right. He said what are you people
22 doing to us? Mr. Higgens said I don't know anything about it,
23 but I will call and find out. So he made a few phone calls
24 over to the other support NRC people near the observation
25 center.

1 MR. FRAMPTON: Do you know what he found out from
2 them?

3 WITNESS ZEWE: As I remember he didn't find out
4 from them that they had issued any such statement at all.
5 They were unaware at that point of where that actual statement
6 came from. It didn't come from them. It hadn't come from us.
7 And we had then made some other phone calls to the Dauphin
8 County Civil Defense to ask if they had made anything.

9 MR. FRAMPTON: Had they? Do you know?

10 WITNESS ZEWE: As I remember, they had not made that
11 either and were unaware of it, but they had been receiving
12 reports of that but hadn't been directly involved. That is
13 really as far as I could remember of the conversation. I left
14 to go back to the control room to handle the evolution at
15 hand.

16 MR. FRAMPTON: Mr. Frederick, did you get your
17 sandwich?

18 WITNESS FREDERICK: Yes.

19 MR. FRAMPTON: Ron Bellamy, do you want to ask some
20 questions on the subject of the venting before we move on?

21 MR. BELLAMY: Yes.

22 Mr. Zewe, prior to the 28th of March of this year was there
23 a written procedure to vent the makeup tank?

24 WITNESS ZEWE: It is part of the normal makeup pro-
25 cedure that describes venting of the makeup tank for the purposes

1 of the nitrogen overpressure to establish a hydrogen over-
2 pressure. And in that regard only. Not really for the
3 situation we were in. There was no previously written
4 procedure for that as to my knowledge.

5 MR. BELLAMY: How often would you have vented this
6 tank prior to the 28th? Once a shift? It normally doesn't
7 happen during your shifts?

8 WITNESS ZEWE: Very infrequently. On the order of,
9 you know, once every couple months maybe.

10 MR. BELLAMY: Couple months.

11 WITNESS ZEWE: Yes. There is really no regularity
12 of venting the makeup tank. As long as you maintain the
13 required overpressure and if you didn't overfill the makeup
14 tank and get the pressure higher than what we would like to
15 keep it at, there was no reason to vent it.

16 MR. BELLAMY: And you previously stated that sometime
17 on the 29th, you concurred in what we have identified as
18 Exhibit 7 as being technically an accurate representation of
19 how you would continue from that time on in venting the makeup
20 tank.

21 WITNESS ZEWE: At that point of time the procedures
22 were constantly being revised as the need arose so that pro-
23 cedure was in effect, you know, for a certain period of time
24 and it was superseded by other procedures. As the conditions
25 changed or as we explored alternatives, we certainly changed

1 the procedures to reflect it.

2 MR. BELLAMY: Mr. Faust testified this morning that
3 the first time there was anything more than a cycling of MUV-13
4 to vent the makeup tank was the 7:00 or 7:10 a.m. release.

5 Was there to your knowledge any written procedure to do
6 that at the time that you did it?

7 WITNESS ZEWE: Written procedure to do what we did?

8 MR. BELLAMY: Correct. To go from the burping type
9 of release to a continuous vent.

10 WITNESS ZEWE: There was no procedure, no. It was
11 just action that was taken for the situation at hand.

12 MR. BELLAMY: You as shift supervisor would have had
13 the authority to do that?

14 WITNESS ZEWE: I certainly do, yes.

15 MR. BELLAMY: Also you as shift supervisor would have
16 had the authority to say, Mr. Faust, go open that makeup vent
17 valve MUV-13. That's within your authority?

18 WITNESS ZEWE: Yes, it is.

19 MR. BELLAMY: A couple of technical questions on the
20 recirculation of this makeup pump line back to the makeup
21 tank. When the suction is taken from the borated water storage
22 tank, is that an automatic shift from taking suction from the
23 makeup tank or is there a manual valve that needs to be opened?

24 WITNESS ZEWE: It's automatic on engineering safety
25 features actuation. It is automatic. But at this point in

1 time, it is strictly manual. This point in the sequence of
2 events that we are referring to. Because it was strictly
3 manual at this point.

4 MR. BELLAMY: The recirculation of this borated
5 water or for that matter whatever is being used as suction
6 for these makeup pumps back to the makeup tank, is that
7 automatic or does that need a manual valve to be handled?

8 WITNESS ZEWE: The recirc lines are only automatic
9 isolation. Not automatic opening up. There is two
10 automatic closure ES valves in the recirc line that automatically
11 go shut for engineering safety features so you don't divert
12 any of the water that should be going toward the reactor
13 coolant system, so you don't divert that back to the makeup
14 system.

15 Those valves are not automatic open. They are automatic
16 shut. Manually open.

17 MR. BELLAMY: Mr. Hitz is similarly titled as you are.
18 He is also a shift supervisor?

19 WITNESS ZEWE: That's correct.

20 MR. BELLAMY: He was in the control room Friday a.m.
21 to relieve you?

22 WITNESS ZEWE: Yes.

23 MR. BELLAMY: It was just because you were both there
24 at the same time that it may appear there were two shift
25 supervisors there. In effect there really should have been just

1 one, but he was there to relieve you and you were informing
2 him of what was going on and at that time --

3 WITNESS ZEWE: He relieved me before I left the
4 control room. I had left the control room for about an hour,
5 for a period of about quarter to 6:00 to about 7:00 o'clock
6 where I went for an interview with the GPU staff on the
7 accident.

8 He was there to relieve me before I left.

9 MR. BELLAMY: He was the shift supervisor on record
10 from 5:45 until --

11 WITNESS ZEWE: Until I returned.

12 MR. BELLAMY: You took your duties back as shift
13 supervisor or was it time for you to go home?

14 WITNESS ZEWE: At this point we were into the area of
15 transferring the water and then we really share the respons-
16 ibility, so to speak. Then I assumed full control again
17 once Mr. Miller came in the control room and designated me to
18 have the plant responsibility and Mr. Hitz, the communications
19 responsibility.

20 MR. BELLAMY: A little bit of a clarification on the
21 reading from the helicopter on this Friday morning vent. You
22 have indicated, Mr. Zewe, that Mr. Hitz made a telephone call
23 to the Unit 1 control room as the emergency station to request
24 the helicopter circle over the stack to determine the amount
25 of the release; is that correct?

1 WITNESS ZEWE: To the best of my memory, I remember
2 him calling them to inform them to expect a release and to
3 ensure that a helicopter was available to monitor the ensuing
4 release that we felt we would have. I am not sure if he
5 specifically directed him to fly directly over the stack or not.
6 I don't believe so.

7 It was more or less inform them to go up and track the plume.
8 They had direction from the ECS, which was in Unit 1 at that
9 point, on where the helicopter should go and what path he
10 should follow and the readings were being transmitted by radio
11 back for a plot.

12 MR. BELLAMY: Is this a request or an order -- you
13 use the term informing. Is that to imply that Mr. Hitz would
14 just call and say we are having a release. Good by? Or
15 I want the helicopter up there? Please have the helicopter
16 up there?

17 Is that the ECS decision?

18 WITNESS ZEWE: I think we are dealing in semantics
19 here now. As I recall, there was no, you know, room for
20 discussion, so to speak. He was telling them or informing
21 them we were already into this venting procedure. We would
22 have a release. And ensure we are monitoring it properly.

23 When he said have it in the air or would you ensure it is in
24 the air or -- you know. It inferred that we were going to have
25 the release and make sure we could properly monitor the

1 release we expected.

2 MR. BELLAMY: The timing of this phone call was as the
3 release was in progress?

4 WITNESS ZEWE: Yes. It wasn't before the fact but
5 during the fact.

6 MR. BELLAMY: There was piping, temperature piping in-
7 stalled from various tanks in the radwaste system back to the
8 containment vessel during the period Wednesday through Friday
9 or Saturday. What piping was installed and from what
10 components was the piping installed?

11 WITNESS ZEWE: We knew we had a serious gas problem.
12 We didn't consider the waste gas compressors to be totally
13 that reliable.

14 Also the leak somewhere from the makeup tank vent line to
15 the waste gas compressors was obvious from the releases. So
16 we installed temperature piping from a line off of the makeup
17 tank vent and also from one of the radiation monitoring
18 instruments on the waste gas tanks.

19 We vented those to a building spray penetration which led
20 right to the reactor building. So we could vent the makeup
21 tank directly to the reactor building or the waste gas tanks
22 directly to the reactor building.

23 As far as I can remember, we only vented the waste gas
24 tanks and not the makeup tank directly to containment. We were
25 just trying to use the reactor building as just a large volume

1 storage for our waste gas.

2 MR. BELLAMY: There was no line, to your knowledge,
3 installed from the reactor coolant bleed holdup tanks back to
4 containment to your knowledge?

5 WITNESS ZEWE: Not that I can remember. There could
6 be a possible tie in to the same vent line off the makeup
7 tank that could go back, being that you could get gas from
8 the bleed tanks into the vent header and then go back into
9 the lines off the waste gas tank or from the makeup tank line
10 where it tied in, but those two lines from the makeup tank
11 vent line and from the waste gas tanks are tied together and
12 joined at one place.

13 I feel certainly possibly you could position the right
14 valves to vent a bleed tank that way, too, though I am
15 not certain that a check valve might have to be removed or
16 something else, but I don't recall that we had a direct line
17 connected for the purposes of venting the RC drain tanks at that
18 time, no.

19 MR. BELLAMY: When were these lines first installed?

20 WITNESS ZEWE: I don't recall the actual time frame,
21 but it was sometime, I believe, within four or five days of
22 the accident. Like over the weekend or early part of the
23 following week. I am not certain of the time frame involved.

24 MR. BELLAMY: Do you know when they were first
25 used?

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

WITNESS ZEWE: Our records would show that in our logs and procedures for that venting, but I really lost track of exactly what occurred in that short time period because of the sequence of events. It was a very planned evolution and the route and everything was carefully constructed. I am not sure of the exact time, no.

end 5

CR6978
#6
rlp
LRW

1 MR. BELLAMY: Could you suggest somebody to
2 talk to who would be more familiar with the installation of
3 these lines?

4 WITNESS FREDERICK: Harold Denton. He is the
5 man that announced it through the media. He said the pump
6 back is working now. He was watching it.

7 WITNESS ZEWE: Are you referring to who actually
8 installed the lines of what times they were using and so forth?

9 MR. BELLAMY: I'm trying to get information on
10 when it was first considered that you needed such lines. Who
11 decided they should be installed? When were they installed?
12 When were they used? I believe the control log will show
13 the waste gas decay tanks were piped back to containment on
14 Friday afternoon.

15 WITNESS ZEWE: It was that soon? That could
16 have been.

17 MR. BELLAMY: I'm trying for verification on
18 that.

19 WITNESS ZEWE: All right, the source should be
20 the procedure that was used, which was, I think, SOP2 and 33
21 respectively, and the time should be reflected in the log, but
22 I'm not sure if anyone can say with certainty exactly, you
23 know, when the decision was made unless it would be Mr. Miller
24 or Mr. Seelinger or somebody like that. The actual installa-
25 tion was done by the I & C department so they probably can tie

Acc. General Reporters, Inc.

rlp 2
LRW

1 that to one day, too. The I & C foreman, Mr. Weaver, would
2 probably say yes, we did that Saturday because he remembers
3 that from his input, but I had so much involvement with that
4 one portion of it I really don't remember.

5 MR. BELLAMY: That is all I have.

6 MR. FRAMPTON: Ron Haynes, do you want to go into
7 the area of control room manning?

8 MR. HAYNES: Mr. Zewe, you're familiar with Table
9 6.2-1 of the technical specifications that addresses minimum
10 shift crew composition?

11 WITNESS ZEWE: I'm familiar with what is required
12 and how many are manned but not that 6.22 or something like
13 that, no.

14 MR. HAYNES: Fine. What is required during
15 normal plant power operation?

16 WITNESS ZEWE: We're required to have two control
17 room operators and a shift foreman and shift supervisors and
18 auxiliary operators.

19 MR. HAYNES: All right. Perhaps you can help me
20 with this table here. I'm looking at specification 6.2.1 titled
21 "Men and Shift Crew Composition."

22 WITNESS ZEWE: For the different modes.

23 MR. HAYNES: For modes 1 through 4, power operation
24 through hot shutdown, there's a requirement for one senior
25 operator licensed person in the control room; is that correct?

rlp 3
LRW
1 WITNESS ZEWE: Yes.

2 MR. HAYNES: At the facility, not the control
3 room. And two reactor operator licensed persons and auxiliary
4 operators.

5 WITNESS ZEWE: Right.

6 MR. HAYNES: So according to the specification,
7 the minimum shift crew composition is five persons of whom
8 three must be licensed.

9 WITNESS ZEWE: Right. We had further made a
10 commitment to always have a shift supervisor on site available.

11 MR. HAYNES: Where did you make that commitment?
12 Is that in your procedures?

13 WITNESS ZEWE: The company did that. A shift
14 supervisors is required at all times on site.

15 MR. HAYNES: Is that in the technical specs?

16 WITNESS ZEWE: It's not in there, no. That's
17 a company commitment and I'm not sure how far-reaching it is.
18 The table there for the add men under the technical specifica-
19 tions just required one senior operating license at the unit.

20 MR. HAYNES: But your company requires also a
21 licensed shift supervisor in addition to this?

22 WITNESS ZEWE: Exactly.

23 MR. HAYNES: Now, based on your experience during
24 plant operation, Mr. Zewe, is this in your view an adequate
25 number of persons for dealing with plant transients? The minimum

rlp 4
LRW
1 shift group composition?

2 WITNESS ZEWE: Dealing with transients? I feel
3 that, yes, the shift foreman who is the senior operating
4 license of the unit and both of the control room operators
5 who are the two licenses are capable of handling all transients
6 in a control room. I feel the auxiliary operator compliment
7 of two is insufficient. Here again, the company has stipulated
8 that we will not have less than four auxiliary operators,
9 which is more conservative than the technical specifications
10 themselves.

11 MR. HAYNES: I also understand from the technical
12 specifications that the requirement is that at least one
13 licensed operator shall be in the control room when fuel is
14 in the reactor. That means that you can go down to one man
15 in the control room during power operation according to the
16 technical spec; is that correct?

17 WITNESS ZEWE: Yes.

18 MR. HAYNES: Has that ever been the case at the
19 facility here where you have been in power operation with one
20 man in the control room?

21 WITNESS ZEWE: Not that I recall, no. There's
22 always two. If a control room operator leaves, we always
23 have the shift foreman or shift supervisor in the control
24 room also. There are always two. I cannot recall a single
25 instance where there was less than two operators in the control

rlp 5
LRW
1 room at any one time during power operations.

2 MR. HAYNES: Are two men capable of handling
3 transients during power operation?

4 WITNESS ZEWE: I would say for the initial
5 action that is taken, yes, but he does need further help.
6 All right? As the transient progresses or if it ensues in
7 a reactor trip or turbine trip, that two in all cases wouldn't
8 be sufficient. Another guy then would report right back to
9 the control room for any transient that was announced so he
10 is only a few minutes away. So considering in that light that
11 he is available, even though he isn't directly in the control
12 room, I think that's adequate, yes.

13 MR. HAYNES: I also see in this technical
14 specification that the shift crew composition may be less
15 than the minimum requirements for a period of time not to
16 exceed two hours. Are you familiar with that?

17 WITNESS ZEWE: Yes. We have that option.

18 MR. HAYNES: You could in fact be down to a total
19 of two licensed operators in the facility during power opera-
20 tion for a period of up to two hours and still be within
21 the technical specifications?

22 WITNESS ZEWE: Yes.

23 MR. SICILIA: That is to cover a man calling in
24 sick?

25 WITNESS ZEWE: Or somebody gets sick that's there

rlp 6
LRW

1 and we call someone in and that should give sufficient time
2 for that person to respond to the call to come in to relieve
3 the other operator. Here is a case where the shift supervisor
4 becomes very handy, so to speak. He is not counted in that
5 manning here, where if he is in Unit 1 he could come to Unit 2
6 or if he is already in Unit 2 we could use his senior operator's
7 license to either do a control operator function or SRO
8 function. Either a CRO function or SRO function. Either
9 manipulate controls or direct manipulation of the controls.

10 MR. HAYNES: This shift supervisor is a policy of
11 your company as opposed to a requirement from the technical
12 specifications, though? By that I mean according to the
13 technical specifications, you could be as low as two licensed
14 operators at the facility during power operations for periods
15 up to two hours?

16 WITNESS ZEWE: Per the tech specs, yes, we could do
17 that.

18 MR. HAYNES: And that number of people, if I under-
19 stood you correctly awhile ago, is not a sufficient number to
20 respond to a transient under certain circumstances with time?
21 That is, it would be okay for the immediate action but shortly
22 thereafter you would need additional help? They would need
23 additional help?

24 WITNESS ZEWE: That is my assessment, yes.

25 MR. HAYNES: Your assesment?

1 WITNESS ZEWE: Yes.

2 MR. HAYNES: Is that two hours too long or too
3 short or is that the type of time period you think they would
4 be needing the additional help?

5 WITNESS ZEWE: I think two hours would be too long
6 if I had to rely on that as my only source of help, to wait
7 two hours. But I'm relying on the shift supervisor and in
8 always having two control room operators and one shift foreman
9 and a shift supervisor there so if any one of those four
10 should have a problem, you still have three and then you're
11 waiting two hours for a fourth person to come in. All right?
12 But if I only had two people and I had to wait two hours for
13 a third person to help, that's much too long.

14 WITNESS SCHEIMANN: Let me bring up a point here, too.
15 At this point, most of the crew coverage had had three operat-
16 ing licensed personnel on shift such that we never really
17 came to the point where we came close to that situation.

18 MR. HAYNES: As I understand it, you also have
19 a company policy where you have in addition to this a shift
20 supervisor who is also licensed for both units 1 and 2.

21 WITNESS ZEWE: Exactly. Our shift at night was the
22 only shift, like Fred here was just saying, our shift was
23 the only shift that only had two control room operators assigned.
24 The other five shifts have three assigned.

25 MR. HAYNES: Do you know why the company has a

rlp 8
LRW

1 policy of a shift supervisor in addition to what is required
2 in the technical specification?

3 WITNESS ZEWE: I'm not aware of all the commitments
4 or all the reasons behind it, but they wanted one overall
5 person in charge so that if you had a shift foreman on one
6 unit and another shift foreman of equal authority, so to
7 speak, if you had any conflict from one unit to the other unit
8 for whatever reason that might be, auxiliary steam system or
9 what have you, that you might have some discussion evolve of
10 who has the priority, so the shift supervisor was there to
11 assert that the decisionmaking on the inner plant regulate
12 ability or priorities, also from the maintenance crews in each
13 of the plants. I was to ensure that the maintenance and
14 everything else on the shifts were conducted over the right
15 priority. Once you have conformed to the things that may be
16 we should work on this component in Unit 2 because we felt that
17 was more important than a component in Unit 1, some of the
18 interfacing between the units as opposed to an overall station
19 view was more the responsibility of the shift supervisor.
20 The unit was actually the unit of the foreman who was then
21 responsible to the shift supervisor on an overall basis.

22 MR. HAYNES: We were talking about transients.
23 Based on your experience of what occurred during the accident
24 on 3/28, how do you feel about the minimum shift crew
25 composition with respect to accident situations?

Ace-eral Reporters, Inc.

rlp 9
LRW

1 WITNESS ZEWE: I feel the manning we had that night
2 of the accident was adequate, but I could have certainly used
3 help, more thinking of the power to come up with more alterna-
4 tives. Maybe that would have taken just one more body or just
5 a different view of the accident. That's hard to say. But I
6 think for what we had, we had adequate coverage for the
7 accident.

8 MR, HAYNES: The manning you had that night,
9 Mr. Zewe, as I understand it, was about twice what the
10 technical specification requires; isn't that correct?

11 WITNESS ZEWE: In what respect are you saying twice?

12 MR. HAYNES: There were essentially two control
13 room operators. Two senior operators including yourself.
14 And you believe you had about four auxiliary operators.

15 WITNESS SCHEIMANN: Six.

16 MR HAYNES: If I look at the minimum shift crew
17 composition at least we are up to the two-hour period. I
18 could go down to two licensed operators and two non-licensed
19 operators.

20 WITNESS ZEWE: All right. That would be true that
21 we had twice what the absolute minimum would be for our
22 technical specifications, but that was our normal shift. That
23 was the normal complement we had on our shift. So I really
24 can't say that that night we had twice what we formally have.
25 We had exactly what we normally had.

Accidental Reporters, Inc.

rlp 10
LRW

1 MR. HAYNES: What I'm looking at is the adequacies
2 of the technical specification. That's what I'm probing as
3 opposed to the adequacies of your normal shift complement.
4 Your normal shift complement is about twice that of the techni-
5 cal specification.

6 WITNESS ZEWE: I would agree that that's true..
7 We're reflecting actualities versus a paper document? You're
8 always more conservative, or more manning than what you
9 absolutely need.

10 MR. HAYNES: As I understand it, you believe
11 the additional people are need.

12 WITNESS ZEWE: If you only had the very minimum
13 considering the two-hour period, I think they're adequate
14 and in considering that you only have two non-licensed auxi-
15 liary operators required, that is inadequate, yes.

16 MR. HAYNES: Now, at the time of the turbine and
17 reactor trip on 3/28, I will direct this question to
18 Mr. Scheimann. As I understand, you were were out of the
19 control room at that time working on the polishing system.

20 WITNESS SCHEIMANN: That's true.

21 MR. HAYNES: How often do you as shift foreman
22 have to leave the control room and go out into the plant?

23 WITNESS SCHEIMANN: Normally a shift foreman
24 should actually go out at least once during the course of
25 his shift for a period of about an hour to two hours, which

rlp 11
LRW

1 could be split throughout the shift, to make a tour of the
2 plant conditions. I would say normally at least once a shift
3 I should go out. Just if nothing else to observe plant
4 conditions.

5 MR. HAYNES: At times when you were out in the
6 plant, who is normally in the control room?

7 WITNESS SCHEIMANN: Under normal conditions
8 prior to that night there might just be the two control
9 room operators up there. When we were on rotation, where we
10 had one shift supervisor between the two units, the shift
11 supervisor could possibly be over in Unit 1 at the time.

12 MR. HAYNES: When you were out in the plant, with
13 a situation like this, who is in charge of the control room
14 at that time?

15 WITNESS SCHEIMANN: Just the two control room
16 operators are there, the senior guy would be in charge.

17 MR. HAYNES: Who would that be? By position or
18 duty that he is fulfilling that night or seniority or how is
19 that determined?

20 WITNESS SCHEIMANN: That would be pretty much by
21 seniority or whichever guy was on the panel. The guy on the
22 console that night is the guy that would normally call the
23 shots.

24 MR. HAYNES: So the control room operators have
25 a designated duty, as I understand, on shift; one would be a

1 console operator and the other would be switching and tagging?

2 WITNESS SCHEIMANN: Switching and tagging, logs,
3 whatever else had to be done at the time.

4 MR. HAYNES: So it's understood the man at the
5 console was the man in charge when you're out of the control
6 room?

7 WITNESS SCHEIMANN: Yes. At that time he has the
8 best idea of what the actual plant parameters are.

9 MR. HAYNES: Mr. Frederick, do you agree with
10 that?

11 WITNESS FREDERICK: Absolutely.

12 MR. HAYNES: Mr. Faust?

13 WITNESS FAUST: Yes.

14 MR. HAYNES: Since you're the operators that
15 operate the control room.

16 WITNESS SCHEIMANN: I normally make it a point
17 to address it to the person that is on the console, not
18 necessarily to the other man, that I'm leaving the control
19 room.

20 MR. HAYNES: Have there ever been occasions when
21 you had to be out of the control room for extended periods,
22 say, three to four hours as opposed to one or two?

23 WITNESS SCHEIMANN: I can't recall off the top of
24 my head. On a normal tour, I might take an hour to two hours.

25 WITNESS FREDERICKS: Mr. Scheimann has a very good

rlp 13
LRW

1 habit, if he is out of the control room for an extended
2 period of time, which he has been for three, four hours at a
3 time, he calls the control room and tells us where he is and
4 what he is doing and asks if we have problems occasionally.
5 Nothing that is required of him, but he does that.

6 WITNESS SCHEIMANN: It's very well knowledgeable
7 where I will be when I'm out.

8 MR. HAYNES: Why do you call back like that?

9 WITNESS SCHEIMANN: So I can keep up on the
10 plant status that I'm not observing up in the control room.

11 MR. HAYNES: You have a paging system in this
12 plant; is that correct?

13 WITNESS SCHEIMANN: Yes.

14 MR. HAYNES: Are there spots in the facility
15 where the paging system doesn't reach or --

16 WITNESS SCHEIMANN: There is a conceivability.
17 That's why I normally carry a radio along with me also.

18 MR. HAYNES: A beeper?

19 WITNESS SCHEIMANN: No. Direct walkie-talkie
20 type communication where I can be in contact with the control
21 room. That I would use mostly if I'm on the outside of the
22 plant, like over in the greenhouse or something like that or
23 on my way back.

24 MR. HAYNES: Is there a place in the facility
25 where neither the radio nor paging system would work?

rlp 14
LRW

1 WITNESS SCHEIMANN: I can't recall having seen
2 one as of yet. There might be somewhere, where there is a
3 lot of steel where a radio wouldn't come through. I can't
4 recall running into that problem.

5 MR. HAYNES: Mr. Zewe, do you carry a similar radio?

6 WITNESS ZEWE: Yes. I also carry the little
7 page device also, plus a radio. But I only carry the radio
8 now. The radion is ineffective if you're in the auxiliary
9 building or in the reactor and fuel handling building. You
10 have to rely on the paging there. Anywhere other than those
11 buildings or the control tower itself, the walkie-talkie is an
12 effective means of communications.

13 MR. HAYNES: Is there any place you know in the
14 facility where neither system is available?

15 WITNESS ZEWE: Well, depending on the upkeep of
16 the equipment, you may be in an area where one day the speaker
17 system is adequate and the phone is adequate. The next day
18 it could have a problem with the speaker or a problem with
19 the page phones, which occurs from time to time. At any one
20 time, considering how many stations we have with page phones
21 and speakers, there is always a certain number of those that
22 are being worked on or there is a problem with or they're abused
23 in one form or another.

24 MR. HAYNES: Have you had occasions in your
25 experience here where you have been out of contact with the

rlp 15
LRW
1 control room and they tried to get hold of you and you were
2 unaware of it?

3 WITNESS ZEWE: Yes.

4 MR. HAYNES: Very often?

5 WITNESS ZEWE: It depends on where you're at. If
6 you're in the reactor building, we have a very definite
7 communication problem with the reactor building because of
8 the nature of it. The speaker system in the reactor build-
9 ing, depending on who pages you, is very unintelligible in the
10 reactor building because of the effect of the dome and
11 everything. So loudly and slowly. It's more often than not
12 I'll say, did they call me or not? So I call back, did you
13 call me? No, it was someone else but sounded like me. So by
14 and large probably the worst communications is in the
15 reactor building. Once you're on the phone, it's fine. But
16 hearing the page and hearing the information passed is very
17 difficult.

18

19

20

21

22

23

24

25

end 6

LWRros 1

MR. HAYNES: Knowing that you are going in the reactor building and communication is difficult, what precautions do you take to make sure that people know where you are and that you can be contacted?

WITNESS ZEWE: It depends on what the mode of the plant is. If we are cold shutdown, containment is broken, all right, I'm not concerned. If I'm going into the reactor building for just a normal inspection at power, this is more concern. If I'm going inside the secondary shield to inspect for leaks or other purpose, then I have communications and I have somebody there right by the phone.

An auxiliary operator typically goes with me. If I need any communications I have him do it directly. If he hears anything on the page, he comes up and asks was that for us. Those precautions are taken.

MR. HAYNES: Mr. Sheimann, how about you?

WITNESS SHEIMANN: I would have to pretty much agree with what Mr. Zewe said there.

MR. HAYNES: Is that how you do it?

WITNESS SHEIMANN: Yes, that would be how I do it. If I know I'm going in an area where I can't hear the page I normally would have a second body with me.

WITNESS FREDERICK: Are you trying to find out whether or not the page system as it exists is adequate

LWRros 1 communications in an emergency to recall the SROs to the
2 control room?

3 MR. HAYNES: No. What I'm really probing is when
4 the senior reactor operator is out of the building, as he is
5 several times, how available is he to the control room?

6 WITNESS SHEIMANN: It might be noted the night of
7 the accident I heard the word over the page for the turbine
8 trip reactor trip and within three minutes I was up in the
9 control room.

10 MR. HAYNES: I understand. That was this time. I
11 wanted to see if there were other conditions where you may
12 be out of contact and not know.

13 WITNESS SHEIMANN: That is not usually likely.

14 WITNESS ZEWE: He was in probably the highest
15 noise level area of the entire plant, as far as being able
16 to hear the page goes, because the condensate polisher area
17 by the condensate booster pumps is without a doubt in my
18 estimate the highest noise level area in the entire plant.
19 That has general access.

20 WITNESS SHEIMANN: Of I hadn't heard the page, I
21 would have heard the pipes going and would have been darn
22 sure to check into it.

23 MR. HAYNES: Have you ever operated with one
24 licensed operator in the control room?

25 WITNESS SHEIMANN: To my knowledge I can't

LWRros 1 recall coming into a case like that. I am normally always
2 -- either the two control room operators there or myself and
3 one of the control room operators. I can't recall going
4 down to a single one.

5 MR. HAYNES: Do any of you know of any occasions
6 during power operations when there was just one licensed
7 operator in the control room? Any of you four?

8 WITNESS ZEWE: I don't know.

9 WITNESS FREDERICK: I think you will find if you
10 look through the rest of the tech specs there is a section
11 that defines the area in which the operators are allowed to
12 stand and the area in which he is allowed to go. He is not
13 allowed to go all over the control room. There is a map.

14 At any rate, when Fred or Mr. Scheimann or Mr. Zewe are
15 out of the room and Craig and I are left there, just the two
16 of us, there is an occasion where one of us may have to go
17 to one or the rear panels. In that definition of the tech
18 specs, there is only one operator at the controls.

19 MR. HAYNES: The other man is --

20 WITNESS FREDERICK: Checking a reading or an alarm
21 and comes back.

22 MR. HAYNES: He is still in the room, within
23 speaking distance?

24 WITNESS FREDERICK: Oh, yes.

25 MR. HAYNES: So to your knowledge there have

LWRros 1 always been at least two licensed operators in the control
2 room?

3 WITNESS FREDERICK: That's right.

4 MR. HAYNES: Is that correct?

5 WITNESS FAUST: Yes.

6 MR. HAYNES: On the evening, midnight and weekend
7 shifts how many station shift supervisors are on duty during
8 each shift?

9 WITNESS ZEWE: One normally. Unless there is an
10 evolution that requires more attention, where they will have
11 two.

12 MR. HAYNES: That was the case on the night of the
13 accident; is that correct?

14 WITNESS ZEWE: Yes. Unit one was in hot shutdown
15 condition, getting ready to go critical, so we needed two
16 shift supervisors that particular evening.

17 MR. HAYNES: Fine.

18 Mr. Zewe, where do you normally post yourself when you
19 are on duty? In the plant or the unit one control room or
20 unit two control room, or where?

21 WITNESS ZEWE: I typically, after I relieve the
22 shift supervisor, I go out into the control room. I Xerox
23 off my turnover notes and I go out there and turn over my
24 notes to the shift foreman and the control room operators.
25 And we discuss the plant conditions as they are, and

LWRros 1 any of the shift turn over that I got, to bring them up to
2 where I am and for them to inject any changes that they
3 see. All right? That's typically how the shift starts.

4 From there I might stay in the control room to do
5 anything from reviewing procedures to giving oral
6 walkarounds, to checking with maintainance, which I typically
7 do in the first half hour. I check with our health physics
8 department and see what they are working on. Check with
9 maintainance, all three crafts, to see what they are working
10 on -- to see what work they will be doing that shift and
11 interfece with the shift maintainance foreman. It's really
12 the whole plant, the whole island is my bound.

13 Depending on what problems we have, what work related
14 items we have, and what I feel I should be doing that shift
15 is where I am at. All over. No one place, other than I
16 typically start out my shifts all the same. I will turn
17 over to the shift foreman and the control room operator, and
18 then from there on in it's just whatever is on for that
19 night.

20 MR. HAYNES: Fine. Thank you.

21 Mr. Scheimann, when you are not in the plant, where are
22 you normally located?

23 WITNESS SHEIMANN: Normally up in the control
24 room.

25 MR. HAYNES: I didn't ask you this question

LWRros 1 before: what is your view of the minimum shift crew
2 position requirements in the technical specifications
3 wherein you could be down to as many as two licensed
4 operators for a period of two hours?

5 What is your feeling of the adequacy of that shift crew
6 with respect to transients and accidents?

7 WITNESS SHEIMANN: I definitely feel the number of
8 AOs, unlicensed personel, are too low. I have never been
9 operating with less than four.

10 MR. HAYNES: How about the number of licensed
11 personel?

12 WITNESS SHEIMANN: Number of licensed personel --
13 I would go along pretty much with what Mr. Zewe said. For a
14 time period of up to two hours. Anything beyond that we
15 would probably be pushing it.

16 MR. HAYNES: I believe Mr. Zewe felt that two
17 hours was definitely too long if you get into a transient,
18 if you have just two licensed personel in the control room;
19 is that correct?

20 WITNESS ZEWE: I believe that I said that we
21 always have three available at all times, even though the
22 third one may not be there. He should become available
23 within a few minutes into the accident.

24 If we had to rely on that two hour period to bring in the
25 third license, I feel that's too long, yes.

LWRros 1

MR. HAYNES: Do you concur?

2

WITNESS FREDERICK: What I was trying to say was for normal conditions. I wasn't referring to an accident condition. During normal conditions, two would be sufficient.

6

Again, like Mr. Zewe said, in case of an emergency like that, the two thou period would definitely be too long.

8

MR. HAYNES: Thank you.

9

I didn't have anything further.

10

MR. FRAMPTON: Let me follow up with some related questions about control room manning and what kind of assistance and expertise it would be useful to have available to a shift in the case of a severe transient or accident.

15

16

17

18

19

20

21

22

23

24

25

The reason we have been asking about this is because obviously your company has a policy that probably reflects someones view, apparently reflects your view of the number of people its wise to have there. There is a policy to have more people than the minimum required by the tech specs. It may well be that other companies go down to the minimum and your policy perhaps reflects the minimum applied across the board to other plants is inadequate. Again, in situations that might occur elsewhere.

The first three or four hours of the accident on March 29th, I think you have all testified previously that you

LWRros 1 were facing something that your really didn't totally
2 understand, that you had not really seen before in the
3 training o. on the simulator.

4 Mr. Zewe, is that a fair characterization of the
5 situation?

6 WITNESS ZEWE: Yes.

7 MR. FRAMPTON: What I would like to ask you is
8 whether it would have been useful during that period of time
9 in your view to have additional engineering or other
10 expertise available to you to try to figure out what was
11 happening and advise you as to what courses of action you
12 might try to take, either in the person of someone in the
13 control room or in the way of direct telephone lines out to
14 B&W or to NRC engineers or other industry people?

15 Would that have been something that would have been
16 useful to you at the time?

17 WITNESS ZEWE: Well, looking at it almost six
18 months later with hindsight, all I needed was one good input
19 from somebody and maybe that would have helped the situation
20 greatly. But I feel at the time that I had capable people
21 and that I had adequate help for what I had asked.

22 Within about nine minutes into the accident I had another
23 shift supervisor there that was qualified. I had two
24 nuclear engineers that were there that came over from unit
25 one.

LRWros 1

MR. FRAMPTON: Who were those two people?

2

WITNESS ZEWE: One was Kevin Harkless, and I can't remember the other guy's name right now. I had those two that came over. I had them make phone calls.

3

4

5

MR. FRAMPTON: Who was the other shift supervisor?

6

WITNESS ZEWE: Ken Bryan, over in unit one. I asked him to come over at the onset not to help that much with the accident but -- I called him as soon as it happened. You could always gain from experiences like this. At that time, the first minute or two, I thought we just had a normal trip at that point. If I hadn't called him then, I would have certainly called a few minutes later for some help and some input. Initially I did it from -- come on over, you know, to gain from it and to help out both, because he hasn't been a shift supervisor that long and particularly he first qualified on unit one and then he qualified later on unit two, so it was good experience also. Within the first hour I had the unit superintendent technical support there on site in the control room who had been the supervisor of operations in unit one.

20

21

MR. FRAMPTON: Who was that

22

23

24

25

WITNESS ZEWE: George Kunder. George was there. I consider him a very capable engineer with considerable experience in operations, even though he didn't have a license yet on unit two, the philosophies and operations

LWRros 1 were exactly like unit one as far as the primary plant goes,
2 so I considered his help very good.

3 I had at least three regular engineers. Another shift
4 supervisor. A capable shift foreman and crew. I felt where
5 we were at that point, not knowing we had a small break like
6 a -- all right?

7 I felt we certainly had enough people to do what we
8 needed to do looking at enough things at that point. But
9 certainly if I had one more person, in light of, you know,
10 to put it together and say hey, we got a small break and the
11 relief valve is stuck open, maybe that would have taken 50
12 more people, beyond that, but we certainly had enough in
13 numbers, enough in knowledge, and enough in that respect.

14 MR. FRAMPTON: Okay.

15 I understand that it's difficult to ask you to try to put
16 yourself back in the position you were in then, but that is
17 what I'm trying to ask you to do. Not in hindsight, but try
18 to think about what people were thinking during those first
19 few hours and on into the morning.

20 The reason I'm asking you to do that is to try to get
21 some sense of whether it would have been useful to have
22 telephone lines or additional people on site and to try to
23 -- for situations like this; and whether it was possible to
24 perceive at the time that that kind of input might have been
25 useful.

LWRros 1 I think that what you said is certainly during the first
2 half hour or so, the people who arrived in the control room
3 represented what appeared to be plenty of expertise to cope
4 with the situation that appeared to be developing; is that
5 right?

6 WITNESS ZEWE: We really didn't know what was
7 developing. I don't know how to describe it, but this
8 transient was like many other transients that I have been
9 involved in.

10 You have a trip, or you have something wrong that you are
11 trying to correct and to understand and take the right
12 course of action. That happens many, many times on various
13 occasions. I have had several trips, several major plant
14 problems in both units. They all start out, you know, where
15 you have all this information and you are trying to sort out
16 the information to try to make the best decision that you
17 can.

18 We just kept on going through that process, trying to
19 sort out the information for the right course of action. It
20 wasn't a situation where we lacked things to do or things to
21 look at. It was more of an interpretation type deal than
22 what you were dealing with. Every problem of any scope that
23 I ever had goes through that same process.

24 Where you have bad feedwater, for example, or end up
25 shutting down a plant or if you have a LOCA -- some are

LWRros

1 more defined and it's obvious. Like when you shut down,
2 other problems crop up.

3 It's a continuous type evaluating situation. It
4 certainly wasn't one of panic that we totally didn't know
5 where to turn.

6 MR. FRAMPTON: What I am getting at is whether
7 there was a time during the first seven or 10 hours into the
8 accident when you really perceived the need or a desire for
9 more expertise than you had available to you in the control
10 room?

11 WITNESS ZEWE: I think expertise was a phone call
12 away. If I had asked the right questions or relayed the
13 right information to the people that we had called, maybe
14 that is true. I feel the resources were there all right.
15 It's just how we used them was probably the fault.

16 I don't think that having three more guys on shift would
17 be the answer in expertise. I know now we had taken the
18 stand that we are going to have a degree engineer on shift,
19 which will start as early as next month.

20 MR. FRAMPTON: Is that a new company policy?

21 WITNESS ZEWE: Yes. The people have already been
22 selected and they will go on shift, as far as my
23 understanding goes, next week, to go on shift to help out
24 and learn, so to speak, and to help out with the shift
25 routine to provide the expertise for the core cooling

LWRros 1 situations and anything that should be needed as far as
2 protecting the plant goes.

3 WITNESS FREDERICK: Listening to your questions it
4 seems like you are looking for what was going on in our
5 heads as far as what we thought was standing in our way and
6 arriving at the right answer.

7 MR. FRAMPTON: Precisely.

8 WITNESS FREDERICK: People? Mechanics? Training?
9 What?

10 I'm volunteering an answer to that question now that I
11 formulated it.

12 In my own mind, what I was groping for was more
13 information from the instruments. It wasn't the fact that I
14 needed another brain or a book to look into or anything like
15 that. What I needed was an indication that was not subject
16 to interpretation, that would tell me exactly what was going
17 on either in the stem or in the cord itself, that was
18 causing the problem.

19 I was constantly searching the panel for an indication
20 that stood out as being so unusual that it would cause all
21 these effects. I was looking for another symptom that
22 didn't make itself obvious on the panel.

23 So my stumbling block was the information available from
24 the panel and not the number of people that were standing
25 there or the amount of knowledge that was in the room.

LWRros

1 MR. FRAMPTON: What you are saying is that what
2 you felt was needed was not more expertise or additional
3 expert people to help you evaluate or interpret what you
4 had, but rather more information which you could use to make
5 the evaluation yourself. It was inadequate information.

6 WITNESS FREDERICK: I guarantee if there was an
7 obvious indication that said the relief valve was open we
8 would have noticed the relief valve was open and we would
9 have said it shouldn't be open at this time, and let's close
10 it. That would have happened within the first few minutes
11 of the accident.

12 MR. FRAMPTON: The purpose for this series of
13 questions is to try to evaluate suggestions that have been
14 made that what we really need most to prevent this kind of
15 accident from happening is to have either a very experienced
16 engineer on shift all the time, or some kind of direct
17 tie-in between plants and some industrial locations where
18 there is a lot of engineering expertise, and you can pick up
19 the phone and get a lot of expertise very quickly if you
20 don't understand what is happening because your instruments
21 are giving you conflicting indications, or perhaps not
22 enough indications of what is really going on.

23 One of the things I wanted to ask you about is: did
24 anybody suggest, for example, calling B&W in Lynchburg?
25 They were making attempts to get into the plant, but

LWRros : weren't able to establish direct telephone contact with the
2 unit two control room until late in the afternoon.

3 What I'm trying to get at is whether that kind of thing
4 is useful? Particularly from you, whether during the course
5 of this accident there was a perceived need for that sort of
6 input, that sort of expertise from the outside? Or whether
7 that really wouldn't have helped you very much; whether you
8 felt at the time that that wasn't the problem. That wasn't
9 what you needed.

10 That is the kind of thing I'm trying to draw out.

11 WITNESS FREDERICK: The site representative from
12 B&W was present.

13 MR. FRAMPTON: Lee Rogers?

14 WITNESS FREDERICK: Yes. I would call him if I
15 wanted help from unit two. Him or Stan Mangi. I don't know
16 if Stan was there or not. There was no shortage of people
17 that you could ask questions of.

18 WITNESS ZEWE: We didn't have a communication
19 problem in trying to get ahold of someone and being unable
20 to get hold of them. We didn't experience that problem.

21 MR. FRAMPTON: You didn't at any time during
22 Wednesday feel that you needed help from somebody you
23 couldn't reach?

24 WITNESS FAUST: We couldn't reach the reactor. We
25 kept trying to ask what was going on in there.

LWRros 1

2 WITNESS ZEWE: Up until the site emergency and
3 everything else, I didn't thing of a problem reaching people
4 at all with any information I requested of them or I gave
5 them. I didn't have any problem in that respect.

6 MR. FRAMPTON: What about after the EMOV block
7 valve was closed off? Did you then realize very shortly
8 that that had been the main leak?

9 WITNESS ZEWE: Yes.

10 WITNESS SHEIMANN: Yes.

11 MR. FRAMPTON: Then you realized that in essence
12 you had a small break LOCA; right?

13 WITNESS ZEWE: True.

14 MR. FRAMPTON: Thereafter, didn't you continue to
15 face a situation in terms of the plant parameters that it
16 was very difficult to understand why the plant was behaving
17 that way?

18 WITNESS ZEWE: No. As soon as we closed the
19 electromatic valve the pressure in the reactor building
20 started to go down. The pressure in the coolant stem
21 started to come up. So we knew then that we once again had
22 a tight stem, which we didn't have before but didn't
23 preceive we didn't have a tight stem. So from then on we
24 knew that that was the leak and we were already on our
25 maximum capability of high pressure injection and just
continued on that path to pressurize up.

LWRros 1 MR. FRAMPTON: All right. You did pressurize up.

2 WITNESS ZEWE: Yes.

3 MR. FRAMPTON: But then throughout the day a
4 number of decisions were made about the strategy for trying
5 to establish forced core cooling; isn't that right?

6 WITNESS ZEWE: Right.

7 MR. FRAMPTON: Do you recall when the first
8 decision was made to try to depressurize the blowdown and
9 go on decay heat removal?

10 WITNESS ZEWE: After we tried unsuccessfully to
11 insure in our own mind the core was being cooled properly
12 with the high pressure injection flow that we had, we had
13 pressurized up and we were maintaining pressure by cycling
14 the block valve or the electromatic relief valve -- all
15 right -- cycling at a pressure around 2000 pounds.

16 MR. FRAMPTON: Both reactor coolant pumps were off
17 at the time?

18 WITNESS ZEWE: Yes. This was in the neighborhood
19 of midmorning now. We knew then that we had voids in the
20 system. We were trying to collapse the voids.

21 We were cycled for about an hour or so the block valve on
22 the electromatic to hold pressure up at about 2000 pounds,
23 plus or minus a hundred pounds, and feeding our high
24 pressure injection to increase the pressure. And we would
25 relieve the pressure by venting, and come up again; and

Cros

1 kept on cycling.

2 Well, we weren't sure in our own minds whether we were
3 adequately cooling the core, and also how long we could
4 continue to do this and cycle the block valve or the
5 electromatic relief valve.

6 We elected then through some ideas that several of the
7 operators had, including Fred Scheimann, to try to
8 depressurize the plant and dump the core flood tanks in on
9 the reactor vessel -- which we felt, at the time, would
10 assure the reactor vessel was covered with water -- and then
11 go on down and establish decay heat removal flow.

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. FRAMPTON: Let me stop you a moment and go back
2 to this time period when you were trying to keep the pressure
3 up and the high pressure injection was on at a substantial
4 rate during that period when you were trying to keep the
5 pressure up.

6 WITNESS ZEWE: As soon as we trip the last two
7 reactor coolant pumps at about 5:40 we had high pressure
8 injection flow on at that time. Once we shut the electromatic
9 relief valve isolation valve at about 6:15 or so, from that
10 point until 7:00 we had full high pressure injection on.

11 From the time of shutting the valve until about 7:00 or so,
12 we increased pressure up. Then we started to reduce the high
13 pressure injection flow because we had regained pressurizer
14 level or the pressurizer level was still high but we had some
15 indication, but now we had high level and high pressure both.

16 MR. FRAMPTON: So during the period of say approxi-
17 mately 7:00 am to around 11:00 a.m., the high pressure
18 injection continued to be throttled back pretty far as
19 necessary not to overpressurize the system, is that correct?

20 WITNESS ZEWE: Yes. I am not sure of the actual
21 flow rate but it was the neighborhood of 3- to 400 gallons
22 a minute at this time. Once we elected to depressurize and
23 try to have the core flood tanks come into the reactor vessel,
24 then we had our flow at just about 300 gallons a minute, not
25 counting the seal injection because we had to try to throttle

1 down to 100 on two pressure injection lines but that was
2 inadequate so we ended up about 130 to 150 on two legs. That
3 was about 300 gpm at that time.

4 MR. FRAMPTON: During this time period of about 7:00
5 a.m. to 11:00 a.m., did you believe that you had established
6 any natural circulation at all?

7 WITNESS ZEWE: We didn't.

8 MR. FRAMPTON: What was the method -- what was the
9 strategy for cooling the core then?

10 WITNESS ZEWE: High pressure injection.

11 MR. FRAMPTON: Feeding the high pressure injection
12 and bleeding, venting off using the EMOV black valve?

13 WITNESS ZEWE: Plus we raised the steam generator
14 levels or the A only because B had a confirmed primary and
15 secondary leak so that was isolated but we had increased the
16 water level in the A generator up to 90 percent, up 50 percent,
17 to try to enhance cooling as afforded by that generator.

18 MR. FRAMPTON: What is 90 percent of usual
19 operating level?

20 WITNESS ZEWE: Normal operating level at say 100
21 percent power or 98 percent, in our case it was about 60 percent
22 on the operating --

23 MR. FRAMPTON: How many feet is that? Do you know?

24 WITNESS ZEWE: I don't recall the exact conversion.
25 Fifty percent is 21 feet. So I would say that is about 35

jeri 3 1 feet, 37 feet.

2 MR. FRAMPTON: Does the steam generator level have
3 a dual set point? Automatic dual set point. So when the
4 reactor coolant pumps trip, the set point shoots way up?

5 WITNESS ZEWE: Yes. All right, if you lose all
6 reactor coolant pumps you initiate an emergency feed which
7 institutes an automatic set point. At 50 percent.

8 WITNESS FAUST: Depending where you are at, the
9 steam generator level actually seeks 50 percent. If we are
10 sitting before that, we would actually go down for natural
11 circulation.

12 MR. FRAMPTON: I will let Mark get into that in a
13 minute but I want to ask you a few more questions about the
14 strategy decisions during that day.

15 Basically from around 7:00 in the morning until around
16 11:00, you were trying to keep the pressure up and cool with
17 the high pressure injection and collapse the voids you know are
18 there, is that right?

19 WITNESS ZEWE: Yes.

20 MR. FRAMPTON: Around 11:00, a decision is made to
21 try to depressurize blowdown and flood the core, is that fair
22 to say?

23 WITNESS ZEWE: Right. Because we weren't certain
24 that we weren't bypassing the core somehow with our high
25 pressure injection water coming into the cold leg and going up

1 through the steam generators and then out the pressurizer and
2 short-circuiting on the -- bleeding the electromatic and not
3 really going through the core.

4 MR. FRAMPTON: How was the decision to try to
5 depressurize made late in the morning? Was that basically
6 a caucus decision?

7 WITNESS ZEWE: Yes. Based on how long that
8 isolation valve would last and based on the concerns that
9 Fred brought up and I had harbored the very same things, to
10 try to depressurize and go on decay heat. Also Mike Ross,
11 who was in charge of the control room at the time, we all
12 talked together -- Fred and Mike and myself and the other
13 operators -- about this and we went into the office where
14 Mr. Merrill was with the other members of his command team
15 there to discuss that with him, so that they discussed the
16 options of doing what we were doing andy any other inputs from
17 any other groups that were available to them.

18 We had decided to go ahead and try to depressurize and put
19 the core flood tanks on, assuring us that without a doubt that
20 we would have water in the core.

21 MR. FRAMPTON: I guess I should address the next
22 question to you, Fred. What were your main concerns about the
23 mode that you were in up until around 11:00? Was it that the
24 high pressure injection wasn't going through the core at all
25 but was going someplace else and wasn't effectively cooling

1 the core?

2 WITNESS SCHEIMANN: My main concern was I figures we
3 had to keep the core covered and cool. I figured if we could
4 get down to decay heat removal we could be pushing somewhere
5 in the neighborhood of 2500 to 3000 gallons a minute of cooling
6 water around the system, twice what we were putting in by way
7 of the high pressure injection. Maybe 300 gallons per minute
8 a leg or whatever it was at the time.

9 That was one of the main reasons I voiced my opinion on
10 coming down and going on to decay heat. We could assure we
11 had more volume of cooling water being circulated around at
12 the time.

13 MR. FRAMPTON: I think what I want to do is just go
14 through to the end of the day on the decisions that were made
15 and come back and ask one or two questions about instruments
16 and then let Mark take over on some of the details.

17 WITNESS ZEWE: I will add one more thing here. Our
18 instrumentation we had really didn't show any effective,
19 really, core sealing. Our RTD in the reactor coolant loops
20 showed high off scale. We didn't know where we were. The
21 full range recorder goes up to 800 degrees. It showed we were
22 in the neighborhood of the high 700's or 800 degrees.

23 Knowing we hadn't collapsed all the voids, these detectors
24 were seeing a steam water atmosphere and may not be totally
25 indicative of what the core was seeing.

1 Our in-cores at that time on the computer were off-scale
2 high so we couldn't use that. They did get some of those
3 readings on the in-cores of the varying temperatures from zero
4 to 200 as high as 2300 degrees all right, which I was unaware
5 of that day.

6 MR. FRAMPTON: Was any of you aware of those high
7 temperature readings on Wednesday the 26th?

8 WITNESS FAUST: Not me.

9 WITNESS ZEWE: I was really the contact for the
10 operators between the emergency control director and them. I
11 certainly didn't relate that to them because I didn't know
12 about it.

13 MR. FRAMPTON: Would that have been significant
14 information to you had you known it as to the evaluate any
15 of what was happening in the primary system?

16 WITNESS ZEWE: I am not sure because the way the
17 readings were put forth even the next day from the engineer
18 that had them taken --

19 MR. FRAMPTON: Mr. Porter?

20 WITNESS ZEWE: Right. -- saying that here they are,
21 I have really no faith in them. We just didn't perceive we
22 had that high temperature at that time, anywhere near that
23 high. We really didn't know if the thermocouples were
24 qualified to read anywhere higher than what their normal range
25 would be.

1 I really didn't have a good handle on that. So I really
2 couldn't say how I would have viewed them. I would probably
3 have said they are unreliable and we will have to use our most
4 reliable means. I am not sure it's only hindsight, if it would
5 have affected my decisions or brought up any more questions in
6 my mind other than those at that point in time.

7 That was my initial reaction when I first heard about it.
8 Shortly thereafter on the 29th, when they said there were the
9 high temperatures, the hydrogen and the high pressure spike
10 we had seen, then we said, yes, we should have believed it
11 because it was true, but not knowing of the high numbers
12 before hand, it's pure conjecture on my part.

13 MR. FRAMPTON: Let's go on through the day.

14 WITNESS FREDERICK: The important thing on those
15 readings, there is no more reason to believe the high number
16 than there was the low number. It was a 0 and 10 and 15 and
17 200 and 300 and 2000. There was no more reason to believe
18 the 2000 than the lower numbers, looking at raw data like that.

19 MR. HAYNES: Mr. Frederick, with respect to the
20 numbers of thermocouples that were read, how many were showing
21 high temperature and how many were showing --

22 WITNESS FREDERICK: I never saw them. I only heard
23 it talked about in testimony, the fact they were such variance
24 in the readings.

25 MR. HAYNES: If you would have seen that 15

1 showed temperatures above 1300 degrees F and they were in a
2 pattern and say 6 showed less than 500 degrees F, would that
3 change your view of the credibility of the high temperatures?

4 WITNESS FREDERICK: I probably would not have
5 believed the readings at any rate because they are not
6 control instruments.

7 MR. HAYNES: You would not have believe the thermo-
8 couple readings because they are not control instruments?

9 WITNESS FREDERICK: That's right. If I were to take
10 action on the readings taken on the core thermocouples and
11 ignored the console temperatures, I would be violating the
12 tech specs.

13 MR. HAYNES: The console temperatures are which?

14 MR. FREDERICK: Off-scale high. The only one we had
15 was near 700 degrees.

16 MR. HAYNES: The hot leg temperatures?

17 WITNESS FREDERICK: Yes.

18 MR. HAYNES: They were close to off-scale?

19 WITNESS FREDERICK: They were off-scale.

20 WITNESS ZEWE: They only go up to 620 degrees
21 Farenheit. We have recorders on the control room wall that go
22 from 0 to 800. These were the highest readings we had plus
23 we had connected a bridge network to the ARPS/RTD and
24 interpreted that reading to a degree Farenheit, too.

25 MR. HAYNES: I am missing something. If the in-core

1 thermocouples were reading high, a lot of them were reading
2 high, say more than -- 15 reading more than 150°, and the
3 console temperatures were reading off-scale, why does that make
4 you not believe the in-core thermocouple temperatures? I
5 didn't understand your response.

6 WITNESS FREDERICK: Well, like I said, number one,
7 the in-core thermocouples are not calibrated, displayed,
8 anywhere that one can use them for control numbers. The use
9 of the in-core thermocouple temperature is not related to a
10 technical specification or limit the precaution or any of the
11 operating procedures or any of the emergency or abnormal
12 procedures. There is no action outlined to take in the event
13 of an abnormal in-core thermocouple temperature.

14 So if I stop considering the temperatures or indications
15 or procedures we were trying to outline based on the console
16 indications and say instead of doing that we will use these
17 indications which are not confirmed but could be true, on
18 what do I base the procedure that I take after that? What do
19 I relate it to? How do I justify that any more than the fact
20 I couldn't understand what is on the panel.

21 In hindsight, if I said those 15 readings were right, I
22 should have done that, that is okay, but how can you control
23 the --

24 MR. HAYNES: You wouldn't have looked on that as
25 corroborating.

1 WITNESS FREDERICK: It was speculation as to whether
2 or not those readings were correct.

3 MR. HAYNES: The in-core.

4 WITNESS FREDERICK: Absolute pure guesswork.

5 MR. HAYNES: How about the readings on the console
6 with respect to hot leg temperature.

7 WITNESS FREDERICK: They were high.

8 MR. HAYNES: Did you believe them to be correct?

9 WITNESS FREDERICK: No, because there was not flow
10 in the system. RTD's only work if you have the representative
11 flow. It will read the temperature of the water next to the
12 RTD but that doesn't tell you what the temperature is two
13 inches away from there if there is no flow.

14 MR. HAYNES: You are saying the RTD reading is
15 dependent upon flow through the system.

16 WITNESS FREDERICK: As being a representative number
17 of what the temperature of the hot leg is, yes.

18 MR. FRAMPTON: Let's go on and cover the decisions
19 made during the day or strategies that you tried to develop
20 to deal with the situation as you saw it. When you decided
21 to try to depressurize, how long did that basic strategy get
22 implemented? Was that for the rest of the afternoon? Or did
23 you find that that didn't work and tried something different?
24 Do you recall that?

25 WITNESS ZEWE: We just tried to depressurize and we

1 got as low as about 400-some pounds after several hours. At
2 that point the decision was made by URP management off-site
3 to stop continuing trying to depressurize and to go ahead and
4 try to repressurize.

5 MR. FRAMPTON: That was 4:00 in the afternoon?

6 WITNESS ZEWE: In that neighborhood. The station
7 manager and unit officer, technical support left to go to
8 the Governor's office that day. When they returned, it wasn't
9 long afterward that there was communication between URP
10 management and Mr. Merrill and he was directed to repressurize
11 the plant and try to get the reactor coolant pump started.
12 That was about 4:30 or so that we headed in that direction.

13 MR. FRAMPTON: The basic strategy from about noon
14 to 4:00 was to try to depressurize and get the decay system
15 into operation but you were unsuccessful in getting the
16 pressure down that low, is that right?

17 WITNESS ZEWE: Exactly.

18 MR. FRAMPTON: Were any theories developed as to
19 why you couldn't depressurize the system low enough to get
20 decay heat going?

21 WITNESS SCHEIMANN: In my mind, pressure was coming
22 down fairly slow. We weren't getting pressure down to the
23 point -- if we could have held the core flood tank levels and
24 still managed to drop pressure until we got sufficiently below
25 the core flood tank set point, I was of the opinion that the

jerill

jeri 12

1 core flood tank would come down in a good surge and cool
2 everything in that immediate area of the core.

3 However, what was happening was pressure was coming down
4 very slow and as a result the core flood tank contents were
5 actually just seeping instead of a good volume. That at the
6 time appeared to be our main problem as far as depressurization.
7 We couldn't come down fast enough.

8 MR. FRAMPTON: Was there any NRC input during the
9 late morning and afternoon into this strategy? Were the
10 inspectors there urging you to go one way or another or
11 suggesting you go one way or another at any time?

12 WITNESS ZEWE: All those suggestions and interface
13 took place with Mr. Merrill. They were involved in the
14 decisionmaking process of the command team that was set up
15 in our office but I am not sure to what extent because I
16 didn't participate.

17 Whenever I did go into interface directly, I was there for
18 what I needed to do and came out again. I didn't hear all the
19 total discussions that happened.

20 MR. FRAMPTON: Okay. I know that Mark wants to go
21 into a number of specifications during the day but I want to
22 go back for a moment to talk about Mr. Frederick's comments
23 with respect to instrumentation and the reactor not telling
24 you enough. What kinds of things would you have liked to
25 have been able to see on the control panel or be able to get

1 out of the computer that would have helped you see what was
2 happening ~~here~~ that you didn't have?

3 WITNESS FREDERICK: An absolute indication of
4 valve position indication for the relief valve.

5 MR. FRAMPTON: What other kind of things during the
6 day would have helped you identify uncertainties in your own
7 mind about what was happening? I will address that first to
8 you and then to the others.

9 WITNESS FREDERICK: Well --

10 MR. FRAMPTON: Are there other specific things you
11 could think about?

12 WITNESS FREDERICK: Accurate flow indication.

13 MR. FRAMPTON: In various parts of the primary
14 system?

15 WITNESS FREDERICK: In the flow system that would
16 indicate natural circulation. We were questioned for many
17 hours as to whether or not it was taking place. The only
18 thing to base it on was Delta T. We weren't sure what that
19 looked like or how fast the temperatures would separate on
20 that circulation which depended on that flow rate.

21 MR. FRAMPTON: Delta T, you are primarily talking
22 about the Delta T between the cold and hot legs or between
23 any two points in the system?

24 WITNESS FREDERICK: Cold and hot legs. Then you
25 would want to know whether you are transferring heat to the

1 secondary side. Basic parameters like that. Core temperature;
2 reactor coolant system flow. You want some indication on your
3 coupling as a secondary sign. The same things now we have in
4 our emergency procedures that says to look for. It says
5 look for subcoolant. Your saturation mark. Whether or not
6 you are effectively transferring heat to the secondary side
7 of the plant.

8 Basic heat transfer stuff that you want to withdraw from
9 the system without interruption. Every reading that is
10 required to determine whether or not you are on that is an
11 interpretation of temperature reading. List no flow or
12 direction indication of whether or not you have natural
13 circulation taking place.

14 I don't see why you couldn't have a very low range flow
15 instrument to tell you whether or not you have movement of
16 the water. Whether or not you have water in the core. Whether
17 or not the temperatures are increasing in the core.

18 MR. FRAMPTON: Do you have anything to add to that?

19 WITNESS SCHEIMANN: Yes. We could have done without
20 a lot of the superfluous alarms on the front panel and had some
21 of the vital alarms on the back panel placed on the front
22 panel. That would have helped, along with what he said about
23 positive valve position of the electromatic relief valve.
24 I would say those would be two main points I would bring into
25 it.

1 MR. FRAMPTON: Anything to add besides those in
2 terms of things you would have liked to have known about what
3 the reactor was doing? Instruments you would have liked to
4 have had that would have given you more information?

5 WITNESS ZEWE: Some way to have assurance of a water
6 level in the reactor vessel itself. Some direct means of
7 water level to see if the core itself was actually covered.
8 A more direct information on saturation conditions in the
9 primary, other than a look-and-see type. Some alarm that says
10 you are approaching saturation conditions or something of
11 that nature would have certainly been helpful.

12 MR. FRAMPTON: Weren't you aware that you were in a
13 superheat condition during a good part of the time during the
14 day or was that not something really focused upon?

15 WITNESS ZEWE: After a period of time, yes. I am
16 talking about within the first hour of the accident.

17 MR. FRAMPTON: Mr. Faust, any other additional things
18 besides what was mentioned?

19 WITNESS FAUST: He did say core temperature. I would
20 have some of those qualifiers.

21 MR. FRAMPTON: More reliable instrumentation on core
22 temperature.

23 WITNESS FAUST: On the console. I would want even
24 one indicator right on the console so I didn't have to punch
25 it out of a computer.

1 MR. FRAMPTON: One on which you could rely.

2 WITNESS FAUST: Yes. They lit the rest of them.

3 Make them do that, fine. I got a question and it takes a lot
4 of design probably. Since one of the big hang-ups is just
5 being able to find the small leak, everybody is centralizing
6 on that electromatic relief valve. This leak could have been
7 anywhere in the pressurizer. Unisolable. What is to tell us
8 where it is coming from so we don't take hours to have somebody
9 out looking for this thing.

10 You are asking us to recognize it right away. It could be
11 slow and hidden by other parameters where we thought we had
12 a problem somewhere else which hid a lot of what we are talking
13 now about from us. Got us thinking somewhere else. You have
14 a system that you can come up with to tell me where it is
15 leaking from right away, that would be great.

16 MR. FRAMPTON: Mr. Zewe, was there any time during
17 the first day, Wednesday the 28th, when you thought that the
18 core had been uncovered for a period of time?

19 WITNESS ZEWE: No.

20 MR. FRAMPTON: Off the record.

21 (Discussion off the record.)

22 MR. FRAMPTON: Let's break.

23 (Whereupon, at 1:25 the hearing was recessed for
24 luncheon to reconvene at 2:30 p.m.)

AFTERNOON SESSION

(2:10 p.m.)

1 MR. CUNNINGHAM: On the record.

2
3
4 The first thing is to go back and claer up a couple of
5 things you talked about with George awhile ago about what you
6 were doing during the 18 hours in terms of repressurization
7 and depressurization. I think what you said was after the
8 reactor coolant pump tripped off, you turned on HPI full flow
9 and started to repressurize; is that correct?

10 WITNESS ZEWE: No.

11 MR. CUNNINGHAM: That's later in time?

12 WITNESS ZEWE: We went to HPI injection but never
13 started to repressurize. The electromatic was still open
14 and we still had a lot of voids yet we just didn't recover
15 from.

16 MR. CUNNINGHAM: So after the black valve was
17 closed --

18 WITNESS ZEWE: That's when we began to repressurize.

19 MR. CUNNINGHAM: You reached eventually about
20 2100 psi. Did you throttle back then on HPI and sat there
21 and were running and opening and closing the block valve; is
22 that correct?

23 WITNESS ZEWE: Yes.

24 MR. CUNNINGHAM: Okay. I heard, I guess it was
25 Unit 1 had a emergency procedure for high pressure decay heat

rlp 2
LRW
1 removal by running out the EMOV to the sump and recirculating
2 through the sump. Were you aware of that? Did you consider
3 it?

4 WITNESS ZEWE: I have never seen that procedure.
5 It doesn't exist as far as I know. I had heard a comment by
6 another operator that some years ago that had been discussed
7 in a training class he was in, but I never saw that as a
8 procedure.

9 MR. CUNNINGHAM Did you consider the possibility
10 of leaving the block valve open and running to the sump as
11 if it were an isolable small break under high pressure re-
12 circulation? Do you recall anything about that?

13 WITNESS ZEWE: Well, in effect, whenever we
14 were cycling the electromatic relief valve for well over an
15 hour, in effect that is what we were doing.

16 MR. CUNNINGHAM: You were back at lower flows,
17 I guess.

18 WITNESS ZEWE: We were around 300 gallons a minute
19 or so, yes.

20 MR. CUNNINGHAM: After that, you decided to
21 depressurize. Do you have any idea for how long -- there was
22 a quote made that you were floating the core fluid tanks on
23 the TCS. Do you have an idea for how long you were doing
24 that?

25 WITNESS ZEWE: The sequence of events and the

rlp 3
LRW

1 graphs show exactly how long it was. I'm not sure in time
2 frame but it was a couple hours anyway that we had seen a
3 minimal reduction in the ater level in the core fluid tanks.
4 We only had seen about 18 inches reduction the whole time.
5 We had expected to see a larger volume transfer, but that's
6 about all we had seen at that point mainly because we couldn't
7 get low enough pressure to force the water out.

8 MR. CUNNINGHAM: If we can go back now to what
9 you were doing with the secondary side of the OTSG's. You
10 were -- after the reactor coolant pumps were tripped, you
11 raised the level 70 percent. That was a manual action?

12 WITNESS ZEWE: Yes, it was.

13 MR. CUNNINGHAM: George got into briefly
14 the dual level set point system that some plants have. Do
15 you have something like that?

16 WITNESS ZEWE: Only in relationship to emergency
17 feed water. If you lose reactor coolant pumps, all reactor
18 coolant pumps you have an automatic set point of 21 feet or
19 50 percent on the operating range at which the emergency
20 feed regulation valves control that steam generator level. If
21 you have a loss of feed water, it will only control at 30
22 inches of level in the start-up range.

23 MR. CUNNINGHAM: Is this done by ICS?

24 WITNESS ZEWE: Yes.

25 WITNESS FAUST: ICS was in manual, though.

rlp 4
LRW

1 WITNESS ZEWE: He was controlling it in manual
2 at this time. That's why I responded to say he manually
3 raised the level up to 50 percent.

4 MR. CUNNINGHAM: If ICS had been in automatic when
5 the pumps were tripped, it would have automatically raised
6 it to 21 feet?

7 WITNESS ZEWE: If everything was right, yes.

8 MR. CUNNINGHAM: Is there a related system in
9 the steam generators -- in other plants it's called the SFRCS --
10 the steam and feed water rupture control system?

11 WITNESS ZEWE: We have such a system.

12 MR. CUNNINGHAM: Davis-Besse has interaction on
13 steam generator levels following an accident. Nothing like
14 that?

15 WITNESS ZEWE: Ours does not. We have two
16 different systems. One for just a low main steam pressure we
17 have isolation. Also there is one that is based on steam
18 pressure versus feed flow. If you have greater than 200
19 pounds delta p that you have, the emergency feed pumps auto-
20 matically start. But that's the only automatic signal that
21 we have for that system that looks at steams generator
22 pressure versus feed. It starts the three emergency driven
23 feed pumps. That's all it does, It does not control levels
24 or anything else.

25 MR. CUNNINGHAM: I would get into some of the small

ce-F... Reporters, Inc.

1 break procedures and some questions related to that. On the
2 28, do you recall going physically to the emergency procedures
3 and pulling out the small break procedure and working with it
4 or referring to it or anything like that?

5 WITNESS ZEWE: No. The small break procedure,
6 as it is, I didn't refer to it. I did refer to another
7 portion of the procedure that deals with high pressure in-
8 jection being initiated and I only referred to that for a
9 short period of time.

10 MR. CUNNINGHAM: This is in the overall LOCA
11 procedure, emergency procedure, is that the correct procedure?

12 WITNESS ZEWE: Yes. Loss of reactor coolant, loss
13 of pressure, right.

14 MR. CUNNINGHAM: Within the small break
15 procedures, they have all the instructions for determining
16 if you have a small break. You're losing coolant or experi-
17 encing loss of coolant. Can you briefly say what they are?
18 What the procedures say you should see in the small loss of
19 coolant?

20 WITNESS ZEWE: Well, our small break procedure
21 addresses where you recognize that you have a small LOCA
22 but it really doesn't define what is a small break and what is
23 a large break. It gets you into where you have a loss of
24 power along with a LOCA and it defines what action you have
25 to take. We as operators deal with a small break being within

rip 6
LRW
1 a capability of the system where you're still able to
2 maintain a pressurizer level and a make up tank level.

3 WITNESS FAUST: We had no problem maintaining
4 that.

5 MR. CUNNINGHAM: Yes.

6 WITNESS ZEWE: The symptoms for any break are low
7 pressure, low pressurizer level, decreasing make up tank,
8 decreasing pressure, all right? Reactor building alarms of
9 radiation. Sump level. High pressure. Depending on
10 the severity of the break. And a small break and large break
11 in terms of safety analysis is like anything that is greater
12 than .5 square feet is large. Anything smaller is small.
13 Ours is either you have the capability or you don't. Really
14 a small break to us is something that you couldn't live with
15 and you would need high pressure injection. I'm not sure I
16 fully answered your question either.

17 MR. CUNNINGHAM: I think so. I'm not sure either.
18 I guess what I was getting at is in the actual course of
19 events in the early part of the transient, did things progress
20 as a small break? You would expect a small -- back up -- as a
21 loss of coolant or break in the -- rupture of the RCS boundary.
22 Did they behave that way?

23 WITNESS ZEWE: No.

24 MR. CUNNINGHAM: So I guess you can get the
25 question then of what just were the LOCA procedures to you in

1 the early part of this accident?

2 WITNESS ZEWE: Not of much value.

3 MR. CUNNINGHAM: Was it the matter that the
4 symptoms you were seeing just didn't fit?

5 WITNESS ZEWE: Right. If you have a primary loss
6 of coolant accident, you should see more activity on your
7 building monitors and should have a low level -- not a high
8 level. There was conflicting signals we had. It really
9 didn't fit our procedure at all. We had really initiated
10 high pressure injection manually before we had to initiate
11 automatically. That was the portion of the procedure I looked
12 at briefly, was where you manually initiate the high pressure
13 injection. We normally do that anyway on a normal reactor
14 trip. Just to account for the shrink of the system caused
15 by the cool down. At that point in the procedure, it had you
16 throttle high pressure injection flows to maintain a pressurizer
17 level of 200 inches where here we were following above that and
18 we did try to throttle to accomplish that but were unsuccess-
19 ful. Right there it ended for us.

20 MR. CUNNINGHAM: Okay. I guess I have a question.
21 They have within the LOCA procedures what is defined as
22 the small break with the loss of the make up pump or loss of
23 the motor control center, I believe. They have in there --
24 could y briefly say what is contained in there? What the
25 instructions are within that part of the LOCA procedures?

rlp 8
LRW

1 WITNESS ZEWE: The instructions are to recognize
2 that you have the condition and then you have a designated
3 control room operator and a designated primary auxiliary
4 operator which will proceed to the affected side to throttle
5 the high pressure injection flows once he arrives at the
6 vales, and as the control room operator will go to the affected
7 side and establish communication with the control room
8 within a certain time period, he will throttle the valves as
9 necessary as told by the control room operator regulating the
10 flows in the control room. The auxiliary operator proceeds
11 to open up a discharge cross connect between the make up pumps
12 because you're assuming like you said that you had a LOCA and
13 for some reason you lost power or you lost the capability of
14 running a make up or supplying high pressure injection water
15 through two of the high pressure injection valves so you're
16 required to take manual action which I just described in about
17 a 10-minute period. So we practice this every month to make
18 sure we can manipulate the proper sequence of events.

19 MR. CUNNINGHAM: All of you have been through
20 a drill of trying to achieve this 10-minute --

21 WITNESS ZEWE: Several types.

22 MR. CUNNINGHAM: Do you think the criteria of
23 10 minutes or the various pieces within it are reasonable if
24 you get into a small break accident?

25 WITNESS ZEWE: I think what is written is reasonable

rlp 9
LRW

1 to accomplish what you need to accomplish in that time
2 period, but it's just that that whole section of the proce-
3 dures is all -- you have some form of loss of power or some
4 capability that dropped your normal two independent strings
5 down to one. It just addressed that aspect of it. Just for
6 a small break LOCA, that's the only thing this addressed. It
7 didn't address a, if you will, a formal small break LOCA
8 condition where you didn't lose half your capability because
9 you had a blackout or loss of a make up pump or power to
10 the valves.

11 MR. CUNNINGHAM: Within the LOCA procedures, all
12 of that which deals with the small break LOCA has the
13 presumed failures of the make up pump or the power or some-
14 thing like that tied onto it; is that correct?

15 WITNESS ZEWE: Right. The whole small break
16 LOCA part of that is just the response for those
17 conditions and these were conditions that they had just
18 analyzed for about 18 months ago, that they didn't realize
19 we weren't protected so they formed just that section of the
20 procedure to protect us against that small break with a loss
21 of power until we installed some plant modifications which
22 wouldn't require operator action.

23 MR. CUNNINGHAM: So your -- you would have been
24 modifying the plant to take away the human action, the
25 requirements for human actions and would have had systems

rlp 10
LRW
1 automatic actions that would have taken care of this?

2 WITNESS ZEWE: That is true. They're making
3 that same modification now in Unit 1.

4 MR. CUNNINGHAM: Do the rest of you believe
5 that being able to achieve these kinds of requirements
6 within 10 minutes is reasonable?

7 WITNESS SCHEIMANN: I would say so. You might
8 get down there but you might have a problem with the cross
9 connect valve. Those are notoriously pretty hefty valves
10 to try to get open.

11 MR. CUNNINGHAM: One part that concerned me was
12 the small break would be identified within two minutes. Is
13 that a problem?

14 WITNESS SCHEIMANN: That's the hardest.

15 WITNESS ZEWE: To me, as an operator, there are
16 two conditions. I can live with it and I can do a normal
17 shutdown, or I can't live with it. There is no in between.
18 So small or large, to me it's just how long you have until
19 you go on core fluid and decay heat removal pressure is how
20 big the break is.

21 MR. CUNNINGHAM: If you were to be in a
22 situation where you had a HPI actuation from an ES actuation,
23 What system parameters or changes in system parameters would
24 indicate a need to throttle back HPI? What kind of conditions
25 would you have?

rlp 11
LRW

1 WITNESS ZEWE: Greater than 550 gpm on any
2 two legs under the same side. Because our make up pump
3 capability is 550 maximum before you run out the pump, so even
4 if you do have a very bad LOCA where you know that you need
5 the high pressure injection, you should still throttle the
6 250 gallons a leg plus 25 or so but stay so that one make up
7 pump, whether A or B or C, feeding two legs does not exceed
8 550 for that particular pump. Under any condition you always
9 do that.

10 MR. CUNNINGHAM: You're trying to prevent pump
11 run out.

12 WITNESS ZEWE: Exactly. For any LOCA, you would
13 do that. If it's automatically initiated and you
14 need it -- you would still throttle under those conditions
15 in every case, and then you would throttle any other time if
16 you recovered pressure and if you were filling up the pressurizer
17 to prevent from going solid, you would throttle again.

18 MR. CUNNINGHAM: From what sources do you
19 recognize these concerns on HPI? Did you learn this in
20 the simulator or were you getting this from procedures or
21 where?

22 WITNESS FAUST: A combination of all of them.

23 MR. CUNNINGHAM: No one specific one.

24 WITNESS FAUST: Procedures, you have them there,
25 don't you? I guess you don't have them there. I thought you

rlp 12
LRW

1 had a set of procedures there. They tell you about when
2 you throttle back on high pressure injection. You look
3 at restoring normal pressurizer level. The other would be
4 stabilization mode on pressure.

5 MR. CUNNINGHAM: On the pump run out situation,
6 is this something that has been emphasized that you do not
7 want to under any circumstances have to get above 550 gpm?

8 WITNESS ZEWE: That's true.

9 WITNESS SCHEIMANN: That's covered in limits
10 and precautions.

11 WITNESS ZEWE: Procedures, too.

12 WITNESS FAUST: 500 per leg -- per loop, rather,
13 has always been the stressed value as far as that limit on
14 it.

15
16
17
18
19
20
21
22
23
24
25

nd 9

1 MR. CUNNINGHAM: Okay. In the early part of the
2 transient, you did throttle back HPI after the ES actuation.
3 Am I correct that that was because of rising pressurizer
4 level?

5 WITNESS FREDERICK: The excessive flow rates in the
6 high pressure injection legs was the initial concern in
7 throttling the high pressure injection.

8 Subsequently, we found that the pressurizer level was
9 rising rapidly and additional throttling was necessary.

10 MR. WORAM: We were originally going to funnel all
11 these questions through him, but this is getting awkward.
12 The question I had is that after reading your procedures, the
13 one criteria because the pressurizer level was going up, that
14 makes you want to throttle HPI. With the pressurizer pressure
15 going down, that would tend to make you want to be cautious
16 about this.

17 I would be interested to know what your decisionmaking
18 process was in terms of seeing both these seemingly conflicting
19 parameters going on. It is a hard question to ask.

20 You probably know what I am getting at. You have
21 probably been asked it a thousand times.

22 WITNESS FAUST: Not really.

23 MR. WORAM: The situation where if you just look at
24 pressurizer level going up it is obvious from procedure that
25 you should cut back on HPI so you don't get the plant solid.

1 If you then superimpose on that situation, the RCS pressure
2 going down it is not a simple decision anymore.

3 WITNESS FAUST: Can I answer part of that? Part was
4 I don't think -- maybe I should answer from where I was in the
5 plant.

6 I didn't perceive pressure dropping. I perceived it
7 stabilizing out. The next problem I remember hearing was that
8 level was going up.

9 WITNESS SCHEIMANN: I myself was at the pressure
10 control station. Pressurizer level was streaming up like a ban-
11 dit. I had been looking at our recorder there. It was right
12 in the vicinity of level for system pressure. At the time,
13 to me, it appeared that pressure stabilized out which that in
14 conjunction with the increased level is why I decided to go
15 ahead and start backing off.

16 To my immediate impression, there was no continued decrease
17 in pressure at that time. At which time I felt it was a
18 good idea to come back on injection.

19 WITNESS FAUST: Part of our pressure drop -- well,
20 that is getting off the subject. We thought it was -- a lot
21 of the problem was initially repressurizing feed water to
22 the generator.

23 It seemed like it held. That's all I can say now. It
24 seemed like it held. I think I was saying that then, too.

25 MR. FRAMPTON: Off the record.

1 (Discussion off the record.)

2 MR. CUNNINGHAM: Mr. Zewe, I will refer to you, but
3 if somebody else can answer it better, please do.

4 Have you been given any guidance or what kind of guidance
5 have you been given with relationship to the need for steam
6 generator levels in ruptures of the coolant boundary --
7 primary coolant boundary?

8 WITNESS ZEWE: In any rupture of the primary system,
9 you would have pressure down sufficiently low to where you
10 would trip the reactor coolant pumps.

11 You would be in a natural circulation mode anyway. Not
12 considering the high pressure injection flow as the forced
13 coolant system flow. The secondary side would automatically
14 maintain steam generator levels at 50 percent.

15 MR. CUNNINGHAM: Because of the coolant pump trip?

16 WITNESS ZEWE: Right. It would boil down to 30, but
17 as soon as you got pressure low enough to where you trip the
18 reactor coolant pumps on a large break the pressure would come
19 down rapidly. You would trip the coolant pumps and then go
20 into that mode.

21 Where your steam generators would come up 50 percent
22 regardless of a LOCA or not. It is looking at the coolant
23 pump automatic set point. Anything else would have to be
24 manually manipulated.

25 MR. CUNNINGHAM: I guess I am interested in the case

1 of a smaller break where you don't depressurize quickly and
2 the pumps can stay on for a while. The reactor coolant pumps.

3 Have vendors or anybody given you insight on what you should
4 do with steam generator levels in that instance?

5 WITNESS ZEWE: You would control at 30 inches. Just
6 enough for the decay heat. Automatically either with the
7 normal feed system or the emergency feed system. Either way.

8 MR. CUNNINGHAM: So you would want -- your background
9 would tell you you would want 30 inches in the steam
10 generators?

11 WITNESS ZEWE: Yes. Up until now, any of the new
12 changes as a result of the accident, they are a little bit
13 different now, but then it was either 30 inches or 50 percent
14 on the operating range if you lost the coolant pumps.

15 You didn't want to overfill the steam generator and didn't
16 want to boil it dry. Those were the only two control set
17 points you had. They should have occurred automatically.
18 If not, you would have to do it manually.

19 MR. CUNNINGHAM: Okay.

20 WITNESS FAUST: Can I say something? The level in
21 the upper range even change. It used to be 75 percent. It
22 changed down to 50 percent. As far as the operators went,
23 as far as I know in fact, we didn't know why it changed to that
24 level. I wasn't aware of it. I knew they dropped the level
25 for natural circulation.

1 MR. CUNNINGHAM: They?

2 WITNESS FAUST: I don't know who they was. It
3 turned up in the procedure one day. We get our information
4 by what we get out of our procedure and training department.
5 A lot of times we don't get the reason behind it.

6 MR. CUNNINGHAM: Can we turn to another subject?
7 Some of the things that were going on on the 28th in terms
8 of HPI flows. Once again, I have a feeling it has been asked
9 many times. We are trying to get some gross feelings for
10 how much flow was coming in the core and through what legs
11 and what have you.

12 We talked about it earlier, you were having problems
13 accounting for much of the water that came out of the BWST.
14 If that much water came out and the core apparently wasn't
15 cooled to a great degree, we would have to consider the
16 possibility the water went someplace else.

17 WITNESS FAUST: That is what we were getting about, we
18 had the feeling we were bypassing the core. We only had the
19 A leg on at that time, for a large part of that time.

20 We actually backed down low enough -- I was the guy, by
21 that time, I couldn't throttle the flow rate they wanted off
22 both pumps, so I tried going down to one pump to get my flow
23 rate higher and throttle at the value they wanted.

24 MR. CUNNINGHAM: You are talking about a flow path
25 that would be into the cold legs back through the pump and

1 the steam generators and out the pressurizer?

2 WITNESS FAUST: Right.

3 MR. CUNNINGHAM: You were considering that?

4 WITNESS FAUST: That is when we later on staggered --
5 we ended up with A and C. C pump -- actually staggered flow
6 across the core to be sure it was at least going through the
7 core. This was later on.

8 MR. CUNNINGHAM: I am not sure what you are talking
9 about.

10 WITNESS FAUST: We ended up putting the C pump back
11 on and staggering like a diagonal path across the core which
12 would have gotten us further away from a possible direct path
13 through the makeup pump up through the steam generator and
14 out the --

15 MR. CUNNINGHAM: Injecting into the A and B loop?

16 WITNESS FAUST: Right, trying to get the furthest
17 points from the path to the pressurizer.

18 MR. CUNNINGHAM: I see. Let me back up a bit.
19 Start kind of at the beginning and work down through the day
20 and try to figure out which valves you were using and what
21 have you.

22 For the first four hours you were running makeup pump 1A.
23 Which valves would you expect the flow from that pump would
24 be coming through?

25 WITNESS ZEWE: It could only be two valves. 16A or B

1 in the A loop.

2 MR. CUNNINGHAM: Could it have been A and B or A and
3 B?

4 WITNESS ZEWE: It varied.

5 WITNESS FAUST: The first four hours.

6 WITNESS FREDERICK: I actually don't recall what the
7 flow rates were, and -- I tried to the best of my ability to
8 recall that in one of the first interviews. I don't remember
9 what I said.

10 WITNESS FAUST: I probably picked it up somewhere
11 along the -- it had to be after the -- pinpoint where we had
12 the RC pumps off. Already fed the generators up.

13 MR. CUNNINGHAM: This would have been -- 1A was
14 running up until about 8:00 in the morning.

15 WITNESS FAUST: That is wrong. On you mean the
16 makeup pump. I am talking about the RC pumps to find out
17 when I was on the makeup system. You can't really determine
18 that right off the bat. I just know I was on the feed
19 involved with the RC pumps and feed and I ended up over on the
20 makeup pumps later on.

21 MR. CUNNINGHAM: Okay.

22 WITNESS FREDERICK: The interviews we had with Darwin
23 Hunter with the NRC I&E group that was here originally, we
24 spent many hours trying to figure out those flow rates and
25 which pumps were running.

1 If you can look that up in the testimony, you will get
2 more numbers out of that.

3 MR. CUNNINGHAM: I am not looking so much for
4 numbers as valve alignments.

5 WITNESS FREDERICK: We did that, too. Which leg we
6 were shooting through and which pump, that sort of thing.
7 Where the water was coming from.

8 WITNESS FAUST: There are pump combinations, just
9 cycling of the pumps I can only base it on relating it to
10 when we had building actuations and I don't even know -- I
11 wouldn't have gotten a 1600 pound actuation -- well, I
12 would have. I don't know for sure now. But we had several
13 actuations. That is where you get into the pump shifts. Part
14 of them.

15 One time was when I was actually shifting and I actually
16 lost the A makeup pump and went back to the B and that is when
17 you end up with the A makeup pump pull to lock.

18 MR. CUNNINGHAM: At that time, when A was pulled, B
19 was in effect replacing A?

20 WITNESS ZEWE: The same two valves.

21 MR. CUNNINGHAM: You would have been injecting through
22 16A and B?

23 WITNESS ZEWE: Right. Any time on the sequence of
24 events when C's are on, you have 16C or D as a possibility.
25 Any time A or B and A and B is running, you only have 16A and

1 B. Those are your only possible combinations that you have.
2 So if C isn't on, it is only A or B valve regardless of A or
3 B running or if A and B both are running.

4 MR. CUNNINGHAM: There is a statement later on
5 sometime that afternoon there was a quote in the I&E report
6 of flow was heavily biased through 16C. Apparently you were,
7 as I understand, attempting to regain natural circulation in
8 the A steam generator.

9 WITNESS ZEWE: Right. Toward the afternoon, we did
10 get temperature indications in the B loop, I believe, that
11 came on scale, less than 620. It got down to 560 or whatever
12 it was the way we were finally forcing some water through the
13 loop on that side. The A side.

14 So then we thought if we would bias the flow on the B
15 loop, we could force the same condition and have both loops
16 on scale again as far as the temperature goes. So we tried
17 to force more high pressure injection flow through the 16C
18 which goes into the B loop. But after a short time of trying
19 this, we ended up losing the A temperature again. It went
20 off scale high again.

21 Slowly we went back to our normal configuration and regained
22 temperature on the A side. Hours later we regained temperature
23 on the B side just before we started the coolant pump.

24 MR. CUNNINGHAM: I guess I was under the impression
25 you had done a similar thing biasing the HPSI flow through to

1 regain natural circulation on the A steam generator; is that
2 correct?

3 WITNESS ZEWE: We had the A injection flow on and it
4 may have been a few gallons a minute more on the A side than
5 it was on the B side which was through the 16C and we thought
6 that that was the difference that we recovered A first. So
7 if we thought that if we accentuated that even more, that we
8 would gain B faster but it just wasn't the case.

9 MR. CUNNINGHAM: So there was no deliberate attempt
10 to heavily bias the flow into the A steam generator?

11 WITNESS ZEWE: Not really at first. It may have been,
12 I don't know, 50 to 100 gallons more, but initially I don't
13 remember us purposely doing that. We may have.

14 MR. CUNNINGHAM: Not like you tried to on B?

15 WITNESS ZEWE: Exactly.

16 MR. CUNNINGHAM: Was there any other time during the
17 day where you attempted this kind of configuration where you
18 were running flow through one of the 16 valves only aside from
19 this one case? Any other time it would have been 16A and B
20 or 16C and D?

21 WITNESS ZEWE: For the most part the rest of the day
22 it was one injection path at least into each loop, one into A
23 loop and one into B loop.

24 MR. CUNNINGHAM: At least. Could it have been -- was
25 it typically, do you recall, two or all four legs?

1 WITNESS ZEWE: I would say two legs. A leg and C.
2 We had been given a number in the afternoon saying that we
3 needed at least 400 gallons a minute flow so that is what
4 we eventually throttled to and the capability of those two
5 paths were more than the 400 gallons we needed.

6 MR. FRAMPTON: May I break in a minute? You said you
7 were given a number at some point in the afternoon. For
8 minimum high pressure injection flow?

9 WITNESS ZEWE: Yes. We requested from B and W, and
10 they had relayed that to Lynchburg, to come up with a minimum
11 flow number for the condition that we were in. It came back
12 3,000 gallons a minute was the first number. When I -- we said
13 go back and get a different number because we don't have that
14 capability. So it was quite some time later that they came
15 back and said no, it is really 400 GPM number. We said that
16 is more believable. That is what we used.

end 10

17

18

19

20

21

22

23

24

25

jeri 1
6978
RW 11

1 MR. FRAMPTON: When did you first seek to get a
2 calculation, a number from B&W during the day? Do you remember
3 that?

4 WITNESS ZEWE: Midmorning was the earliest I
5 remember.

6 MR. FRAMPTON: Why did you want to get that
7 information from them?

8 WITNESS ZEWE: Right after, around 7:00 I guess it
9 was, the pressure was high, the level was high, we started to
10 throttle again. I had asked for a number from the group there.
11 How much high pressure injection do you want? How much can I
12 throttle? So we didn't have a good solid number other than
13 saying for all the accidents where you have redundancy, you
14 have A and B string and one pump is only capable of about 500
15 gallons so let's feed about 500 gallons and we know we are safe
16 because you have 100 percent redundancy; so we used that
17 criteria saying 4- to 500 gallons because that is within the
18 capability of one pump and for the accident you assume you
19 have an A and B string but that one is totally 100 percent
20 capacity or the other one.

21 So that is where we got the initial number there early on.
22 Then it had been requested to come up with some number. Hope-
23 fully it would be a lot lower.

24 MR. FRAMPTON: Did you specifically want --

25 WITNESS FAUST: They gave us a 300 gpm number.

1 WITNESS ZEWE: That was just an arbitrary number
2 whenever we started to depressurize trying to get down to core
3 flooding in the decay heat system.

4 MR. FRAMPTON: Go back to 7:00 in the morning on the
5 28th. When you wanted to get a number, was that a number for
6 a minimum flow? A number you wouldn't go below. Is that
7 right?

8 WITNESS ZEWE: Exactly.

9 MR. FRAMPTON: You wanted to get that number from
10 B&W specifically? Did you think they could provide that
11 number for some reason?

12 WITNESS ZEWE: I didn't ask B&W -- I asked that
13 of Gary Merrill and the team that was there.

14 MR. FRAMPTON: Of upper management.

15 WITNESS ZEWE: Among them was Lee Rogers from
16 B&W. I am not sure when he arrived. I think he was there
17 somewhere around 8:00. It's that time frame we are talking
18 about, between 7:00 and 8:00.

19 MR. FRAMPTON: Did he try to find out from Lynchburg
20 an appropriate number?

21 WITNESS ZEWE: I assume he did. The number came
22 back later in the afternoon. I am not sure exactly when they
23 relayed that or asked for it. At that time I had just asked to
24 see if anyone had a good number idea. Later on I requested
25 again we need something more.

1 MR. FRAMPTON: Did you request that of Lee Rogers
2 among other things later on? Did you say to him, do you have
3 any idea of what your people are saying for a number?

4 WITNESS ZEWE: I addressed everything through Mike
5 Ross and Gary Merrill only. He interfaced there. I directed
6 it to him.

7 MR. FRAMPTON: But you know that later in the after-
8 noon or sometime during the afternoon you got a number from
9 B&W relayed to you.

10 WITNESS ZEWE: Right. The first number was -- must
11 have been right around noon or before noon. That was that
12 3000 number we considered was ridiculous at this point.

13 MR. FRAMPTON: Why would B&W people who knew this
14 plant communicate a number like that? Was this simply a
15 miscommunication, do you think?

16 WITNESS ZEWE: I don't know at this time. I don't
17 know exactly the person that gave that number but it was given
18 to me in that light. The minimum flow you would have to have
19 now they said, and I assumed that that was B&W, and that may
20 be a wrong assumption, but that is where we would seek from
21 their analysis people on how much flow to have, was 3000.

22 We said, oh, that is ridiculous and let it drop at that time.

23 MR. FRAMPTON: Why were you looking for a minimum
24 number? Why did you need a -- why did you want to get a
25 minimum number?

1 WITNESS ZEWE: Because I have a range from zero to
2 1000 gpm and we weren't sure of our cooling status of the core
3 and we were cycling the valve and if I put in less water it
4 would require less cycling of the valve that I was concerned
5 about failing, so if I add 500 gallons a minute, the pressure
6 change in the system is a lot faster. Even though we weren't
7 solid we had voids. Pressure would change more by the more
8 volume I changed.

9 If I got adequate cooling with 200 gallons I would have to
10 cycle the valve less frequently.

11 MR. FRAMPTON: I understand that during the morning
12 period. What about after a decision was made by the group to
13 try to depressurize? Did that minimum then go by the board?
14 Wasn't high pressure injection throttled way back in the
15 process of trying to get the pressure down?

16 WITNESS ZEWE: We discussed on what flow we were
17 going to go to and we figured to try to get around 225 to 250
18 total flow.

19 MR. FRAMPTON: During the depressurization?

20 WITNESS FAUST: That is tough.

21 WITNESS ZEWE: Then we found out it was very hard
22 to throttle. We found that the best throttle point for
23 throttling and maintaining flow was about 150 gpm in two
24 legs, so we ended up at 300 gallons a minute high pressure
25 injection flow and still had about 40 gpm of seal water; so

1 at that time we had 340 gpm. That is about what we remained
2 at while in that depressurization period.

3 MR. FRAMPTON: That was until you got the feedback
4 from B&W to maintain 4- to 500 at least late in the afternoon?

5 WITNESS ZEWE: I am not sure if we didn't receive
6 that number after we began to repressurize again or not. It
7 wouldn't have been a very long time period between us receiving
8 that number and when we elected to try to repressurize up and
9 start the coolant pump. I am not sure of the time frame.

10 MR. FRAMPTON: Thank you.

11 MR. CUNNINGHAM: Late in that afternoon, the early
12 part of the evening, reactor coolant pump 1-A was restarted.
13 After it was restarted how were you using the make-up pumps?
14 Normal make-up or what valves? Do you have any idea?

15 WITNESS ZEWE: None of us were there at that time.
16 I had left. I was the last one to leave of this group. I
17 assume they just used the make-up pump in normal seal
18 injection mode and normal pressure control mode. I would
19 assume. I hadn't heard anything otherwise. Purely an
20 assumption on my part.

21 MR. CUNNINGHAM: Who would have been the person who
22 would have been doing that manipulation?

23 WITNESS ZEWE: Shift supervisor, Joe Chwastyk. The
24 supervisor of operations was Mike Ross at that time. Gary
25 Merrill was there, too. I would ask them for any details of

jери 6

1 that procedure. At that point they had pressure and they had
2 level and had a pump running so I wouldn't think they would
3 have to deviate from the norm there.

4 MR. CUNNINGHAM: You would presume they are running
5 through the 17 valve rather than the 16?

6 WITNESS ZEWE: I would assume that, yes, though I
7 don't know that to be the case.

8 MR. CUNNINGHAM: A couple of questions on the
9 pressurizer heaters. When the heaters are turned off by
10 increasing RCS pressure, do they report on the alarm printer
11 as being tripped?

12 WITNESS ZEWE: Yes.

13 MR. CUNNINGHAM: So if you were to see that on the
14 alarm printer you would assume that.

15 WITNESS ZEWE: As far as I am concerned all the
16 status of the pressurizer heaters on the computer are just
17 useless to us. It just ties up the computer for no reason.

18 MR. CUNNINGHAM: Just ties it up.

19 WITNESS ZEWE: It really don't serve any useful
20 function to us in the control room.

21 MR. WORAM: I have a question on that. It seems
22 the pressurizer heaters have electrically two things going on.
23 One is the supply breaker can be either closed or tripped.
24 The other is that the control system, you either have the
25 heaters on or off depending on RCS pressure or level or

1 whatever. When the heaters turn on and off, do you get a
2 computer alarm due to the normal cycling of the heaters or do
3 you only get that alarm when the actual supply breaker trips
4 due to, say, thermal overload or something like that.

5 WITNESS ZEWE: Normal cycling, it's on and off, too.

6 MR. WORAM: Off the record.

7 (Discussion off the record.)

8 MR. FRAMPTON: Back on the record.

9 Mark, you have to speak louder and more clearly, okay?
10 You have to talk at the reporter.

11 MR. CUNNINGHAM: Okay.

12 Like I said, we have had the problem of trying to resolve
13 the mass balances and part of this is just we have to consider
14 the possibilities of somehow bypassing the flow away from the
15 core. The one you were talking about of backing through the
16 steam generators and out the pressurizer, we have a few other
17 possibilities we would like to bounce off of you.

18 Somebody raised the possibility of a break in one of the
19 ECC injection lines. More specifically, the A line. Is there
20 any indication during the time that anything like that was
21 going on from the flow indication or anything like that?

22 WITNESS FAUST: Not that I recall. I don't remember
23 anything that would have told me I had an indication of a
24 break in one of the feed lines.

25 MR. CUNNINGHAM: Another possibility. Apparently

1 the borated water recirculation pump was on prior to the
2 transient and remained on for a while and was tripped at
3 some time. I presume that is the normal operation, just to
4 keep water in the BWST mixed. Is that correct?

5 MR. FREDERICK: Yes.

6 MR. CUNNINGHAM: Are you aware of any valve
7 manipulations or work with that system during the 28th that
8 would have affected anything?

9 WITNESS SCHEIMANN: No.

10 WITNESS FREDERICK: Are you considering that as a
11 way we might have lost water?

12 MR. CUNNINGHAM: Yes.

13 WITNESS FREDERICK: What is the pump designation
14 of the pump you are talking about?

15 MR. CUNNINGHAM: I am not sure. Borated water
16 recycling pump. I am not sure of the number.

17 WITNESS ZEWE: There are two right by the tank we
18 can recirculate the tank with. Also a spent fuel pump we can
19 put on recirc through filters with. Depending on which pump
20 you are referring to, SFP-2 or the other one is, it makes a
21 difference.

22 WITNESS FREDERICK: One is borated water tank
23 recirc pump --

24 WITNESS ZEWE: Two of them.

25 WITNESS FREDERICK: The other is the borated water

1 recirculation pump or something like that. The names are
2 almost identical. But they are completely different system.

3 WITNESS ZEWE: One is locally only.

4 WITNESS FREDERICK: One pumps from the bottom to the
5 top of the tank. The other you can pump it anywhere in the
6 world.

7 MR. CUNNINGHAM: The one I was thinking of was the
8 latter.

9 MR. FRAMPTON: Off the record.

10 (Discussion off the record.)

11 MR. CUNNINGHAM: The pump I was referring to was
12 the borated water recirculation pump that was pumping out
13 through the filters and around. Does that clarify it?

14 MR. FRAMPTON: What is the question?

15 MR. CUNNINGHAM: Were you aware of any manipulations
16 with that pump and the associated valves?

17 WITNESS ZEWE: No.

18 MR. CUNNINGHAM: Thank you.

19 WITNESS ZEWE: If there was, how could you get from
20 the high pressure injection leg back in through that pump?

21 MR. CUNNINGHAM: I am not sure what you mean.

22 WITNESS ZEWE: You are just referring that we get a
23 level reduction and can't account for it, right?

24 MR. CUNNINGHAM: Right.

25 WITNESS ZEWE: Okay.

1 MR. CUNNINGHAM: That's right. During that day,
2 were you putting water from the make-up tank out to the
3 RC bleed tanks? Were you doing any alignments between those
4 two tanks that you can remember?

5 WITNESS ZEWE: You can't do that to begin with.
6 You can redirect letdown to go to a bleed tank but you can't
7 directly go from the make-up tank to the bleed tank except
8 through that relief valve we referred to earlier.

9 MR. WORAM: I have a question on that.

10 MR. CUNNINGHAM: The more appropriate question is
11 were you taking letdown flow to the bleed tanks rather than
12 the make-up tanks?

13 WITNESS ZEWE: I believe we did at various times to
14 keep from taking the make-up tank solid.

15 WITNESS FAUST: Part of what we were doing, I
16 don't remember it all, we were actually trying, we had problems
17 with letdown even that early, where I was seeing quite
18 large surges in the letdown flow rate itself as well as DPs
19 across the letdown filters -- not filters but seal injection
20 filters, return filters, and the system was just showing us
21 that something was occurring in there, like blockage.

22 One of the things we were trying to do was improve, to see
23 where our problem was. One way we were doing it was eliminat-
24 ing part of the flow path by just going back to the RC bleed
25 tanks to see if that section of the line might have been part

1 of the problem. There wasn't too much time spent on that.

2 MR. CUNNINGHAM: On putting water to the bleed tank
3 or testing out that section?

4 WITNESS FAUST: Testing it by directing the water
5 into the bleed tank to see if there was a restriction somehow
6 downstream of that point.

7 MR. WORAM: The question I had was do you have any
8 feel for how much water you actually put into the bleed tank
9 by going through the -- or a reasonable guess, order of
10 magnitude guess as to how much water you might have put
11 through the valve in the make-up tank?

12 WITNESS FAUST: I don't think it would have been
13 anything like you are talking about. You are looking in the
14 wrong place for the loss of water there.

15 MR. CUNNINGHAM: One other possibility of losing
16 water was sometime prior, in the prior history of the TMI
17 units, there was a time where the BWST was inadvertently
18 drained to the reactor building sump through the sump
19 recirculation valves.

20 WITNESS FAUST: Unit 1, I believe.

21 MR. CUNNINGHAM: Yes. Do you think there was
22 something like that --

23 WITNESS ZEWE: I can't remember the draining of the
24 BWST to the sump but I remember draining the pressurizer
25 directly to the sump.

1 MR. CUNNINGHAM: Someplace --

2 WITNESS ZEWE: In Unit 1.

3 MR. CUNNINGHAM: Someplace that was discussed, that
4 they had drained some of the BWST water to the sump. I guess
5 the question is: do you think --

6 WITNESS FAUST: They didn't operate the DHV-6-A and
7 -B. They weren't operated that day. We didn't open them up.

8 MR. CUNNINGHAM: That is the places I am looking
9 for the water. Do you have any ideas of any places where
10 the water could have gone?

11 WITNESS FAUST: The aqua filter.

12 MR. CUNNINGHAM: How?

13 WITNESS FAUST: Through the path we are saying.
14 Put it in the system apparently and vent it off through the
15 relief.

16 MR. CUNNINGHAM: The path back thorough the steam
17 generators.

18 WITNESS FAUST: Definite decrease in the pressurizer
19 temperature. This is later on in the day. It definitely
20 seemed to be dropping.

21

22

23

24

25

978 12 01

rc LRW 1 MR. HAYNES: I am looking at P&ID drawing 2024,
2 ref 25, a flow diagram of the reactor coolant makeup
3 purification system. Do you know that if this drawing is
4 essentially correct with respect to the designation of the
5 steam generators, the A and B side, the location of the
6 pressurizer, namely, that shows that it is on the hot leg of
7 the A loop?

8 WITNESS ZEWE: That's correct.

9 MR. HAYNES: You don't know of any errors on this
10 with respect to the designation of the loop piping?

11 WITNESS ZEWE: Now that I am aware of, no.

12 MR. HAYNES: Fine. When I look at this drawing, I
13 see the makeup pump C injects on the high pressure injection
14 system through the 16 C and D valves which go into the cold
15 legs downstream of the 2-A pump and 1-A pump respectively.
16 Okay?

17 Now, I also see on this drawing that the pressurizer
18 spray line comes off of the cold leg of the loop immediately
19 downstream of the reactor coolant pump 2-A; is that your
20 recollection?

21 WITNESS ZEWE: Yes. A spray from 2-A, yes.

22 MR. HAYNES: That also heads through injection
23 valve 16-C coming into the same line. It appears on this
24 drawing -- do you know if that is a common penetration on
25 the piping?

978 12 02

rc LRW 1

WITNESS ZEWE: Common? Wait, I am not sure I understand that. You are saying 16-C comes in, if that is common to —

MR. HAYNES: To the pressurizer spray line.

WITNESS ZEWE: No, it is not. It is a separate connection to the piping system itself. It is not —

MR. HAYNES: They are both two-and-a-half-inch pipes.

WITNESS ZEWE: Right. It is not a common tap. They are separate lines.

MR. HAYNES: Are they somewhat in the same relative location?

WITNESS ZEWE: I am not sure how many feet they are apart. I don't recall how many feet. But they are not a couple of inches from each other. They are several feet from each other.

MR. HAYNES: With the C pump on injecting through the 16-C valve, if the pressurizer spray line were open at that time, then you would have a direct path into the pressuriser contract C line.

Do you know if the pressurizer spray line valves were open at any time on the day of the 28th when you were trying to inject in the loop? The high pressure injection system.

WITNESS ZEWE: I don't recall using the pressurizer spray valve at all after we shut off the reactor

978 12 03

rc LRW 1 coolant pumps other than the automatic mode. We did use the
2 pressure vent, but not the pressurizer spray.

3 Do you remember using it?

4 WITNESS SCHEIMANN: No. Pressurizer spray
5 wouldn't have done much good without the reactor
6 coolant -- it wouldn't have done any good without flow in
7 the system for ADP across the spray valve. I don't recall
8 using it, either.

9 WITNESS ZEWE: Prior to tripping the pumps, we
10 would have no need to use spray with low pressure already.
11 Only to reduce pressure further. I don't remember using the
12 spray valve at all that day.

13 MR. HAYNES: Is the position of the spray valve
14 indicated on any permanent record?

15 WITNESS ZEWE: No recorder or anything like that.

16 MR. WORAM: I believe the position of the spray
17 valve is on the reactimeter.

18 WITNESS ZEWE: Right.

19 WITNESS FAUST: Doesn't do us any good.

20 WITNESS ZEWE: I don't know, for one, all the
21 parameters we had on the reactimeter. There is no
22 permanently installed indication on that reactimeter data --
23 if it has, I didn't know it did.

24 MR. HAYNES: I finished my questions.

25 MR. CUNNINGHAM: This is just a conversation.

rc LRW 1 This confuses me a bit. We were just saying that the 16-C
2 valve goes to the A steam generator, whereas I thought
3 before, you were saying it was going to the B steam
4 generator.

5 When they were biasing flow through to the 16-C valve,
6 that was trying to establish natural circulation in B rather
7 than A.

8 WITNESS ZEWE: I believe when we talked, I had
9 reversed my -- which it was A we had on scale, B we were
10 trying to get, or if it was B, we had an A we were trying to
11 get.

12 I remember that I said it one way; you said, no, it is
13 the other. So, I changed my mind. At this time, I really
14 don't remember which leg came on scale first. All right? I
15 really didn't -- I know we had increased the flow to the leg
16 that hadn't come on scale yet and I really, if it was the A
17 side or the B side using the 16-A or C, I really don't
18 remember, but it wouldn't have made any difference.

19 We had increased the flow to the side that we had not
20 received the on-scale instrument yet.

21 MR. CUNNINGHAM: So, whichever it was, the level
22 biasing the flow was after you had -- it was a deliberate
23 act after you had established apparently some sort of
24 natural circulation in whatever the other steam generator
25 was; is that correct?

978 12 05

rc LRW 1 WITNESS ZEWE: Well, I don't believe we actually
2 thought we had positive signs of natural circulation. It
3 was just that we had filled the loops enough to flow over
4 the candy cane and past the RTD to get on-scale indication
5 of what the temperature was of the water and not the steam
6 that was in the area of the candy cane for the RTD. If you
7 can follow that.

8 MR. CUNNINGHAM: I am not sure.

9 WITNESS ZEWE: See, we perceived then that the
10 area of the RTDs a the hot legs -- that comes out of the
11 reactor, makes like a candy cane effect. After it turns an
12 comes down before the steam generator is where you have your
13 RTD.

14 The high temperatures we felt that that was just the
15 steam that was in the loops and, once later on in the day we
16 finally got some down-scale indication, we felt we were then
17 forcing water over the candy cane or over the hot leg past
18 the RTD cooling it off and showing that were once at some
19 minimal flow, if you will, or some water movement past that
20 RTD, which was more indications that we had less voids than
21 what we had before, at least in that loop.

22 So, I am not sure we said, hey, that is a sign of natural
23 circulation. That is just a sign we had some filling effect
24 in that side. We had some temperatures on scale.

25 MR. CUNNINGHAM: So, at that point, you believe

978 12 06

rc LRW 1 that was, at least in some respect, or may have been
2 attributable to the fact that the HPI flow was more biased
3 to that steam generator?

4 WITNESS ZEWE: I really didn't know, nor do I know
5 now, that we knew the ratio, that A had more than the B or B
6 had more than A or how they blew down unequally or what, but
7 it was just in the course of the conditions that we had for
8 the high pressure injection flows that we started to see the
9 temperator first in one loop and then thought, well, if we
10 increase the flow to the other loop and force more water
11 there, we will fill it up more to meet where the other one
12 was because now, to us, it seemed like we had more water in
13 one loop than the other loop because we were having some
14 flow or some indication of me water in that side.

15 MR. CUNNINGHAM: So, I think you are saying that
16 the more deliberate attempt to bias flow to one loop was as
17 a result of getting some sort of flow in the alternate
18 generator?

19 WITNESS ZEWE: Exactly.

20 MR. CUNNINGHAM: Thank you.

21 MR. HAYNES: On the three makeup pumps, we have
22 the A, B and C pumps. The A pump is normally lined up when
23 the high pressure injection mode to go through the 16-0A and
24 16-B valves; is that correct?

25 WITNESS ZEWE: That's correct.

978 12 07

rc LRW 1 MR. HAYNES: The C pump is lined up to go through
2 the 16-C and D valves.

3 WITNESS ZEWE: Correct.

4 MR. HAYNES: The B pump can go either route. The
5 same as the A or C pump, depending on how you do your
6 cross-valving.

7 WITNESS ZEWE: Exactly.

8 MR. HAYNES: The cross-valving was set up on the
9 28 such that it goes through the 16-A and B valves.

10 WITNESS ZEWE: That is correct.

11 MR. HAYNES: It was not changed during that day at
12 all?

13 WITNESS ZEWE: It was not.

14 MR. CUNNINGHAM: Try and talk about a couple of
15 other things now not related to anything else.

16 In the turbine trip procedures that you have, is there
17 any discussion or precautionary notes or anything dealing
18 with an ES actuation after a turbine trip?

19 WITNESS ZEWE: I don't recall any at all, no.

20 MR. CUNNINGHAM: So, during the beginning of the
21 transient, you had the turbine trip, reactor trip, and the
22 ES actuation. The feeling I get thirdhand from this was
23 that it was not considered to be highly significant that you
24 had the ES actuation; is that correct? Or am I missing
25 something?

978 12 08

rc LRW 1 WITNESS FAUST: That is correct.

2 MR. CUNNINGHAM: Can I ask why it wasn't
3 considered significant?

4 WITNESS FAUST: Because if you, which I think you
5 have, review our other trips we had in the past, we had ES
6 actuations on them. Turbine reactor trip where the pressure
7 goes down and picks up 1600 pounds ES and we cut back on
8 high pressure injection then.

9 MR. CUNNINGHAM: So it is not unusual to get an ES
10 actuation after a turbine trip.

11 WITNESS FAUST: No.

12 WITNESS ZEWE: You don't automatically expect it
13 to happen, but just knowing that it has happened before, it
14 is not totally surprising. But it unusual. You wouldn't
15 expect it to happen everytime you had a turbine trip that
16 you have a reactor trip.

17 MR. CUNNINGHAM: So it is not unusual but not
18 frightening. What has been the causes of the other ES
19 actuations? Is there a typical cause?

20 WITNESS FAUST: Overfeeding of the steam
21 generator.

22 MR. CUNNINGHAM: It is a matter of too much RCS
23 shrinkage?

24 WITNESS FAUST: Relief valves not seating. Not
25 the one we are talking about here. I am talking about the

rc LRW 1 main generator safety steam side.

2 WITNESS ZEWE: Normally it wa attributed to other
3 problems.

4 MR. CUNNINGHAM: I am not sure what you mean by
5 other.

6 WITNESS ZEWE: Other events that caused you to
7 cool down either more rapidly because of it. Like one case
8 where we overfed and cooled down too much so we had ES
9 actuation after turbine trip.

10 Another time the main steam valves failed to reseal which
11 further cooled us down to ES. We had a turbine trip and
12 reactor trip and, yes, we had ES, but there was something
13 else that really gave us the ES. If you just have turbine
14 trip, normally you shoulnot get it.

15 MR. CUNNINGHAM: When do you become aware of the
16 fact that the reactor coolant drain tank rupture disc had
17 broken?

18 WITNESS FAUST: I didn't even know it during that
19 day, I don't believe, myself.

20 MR. CUNNINGHAM: Anybody else? Do you recall?

21 WITNESS ZEWE: I suspected it, or at least knew
22 there was something wrong with the RC draining tank, and I
23 am not sure of the time-frame. Probably somewhere after a
24 half hour and prior to the first hour and a half, that there
25 was a definite problem with the RC drain tank, but I am not

978 12 10

rc LRW 1 sure that I knew that the rupture disc went.

2 It could have been a stuck relief valve or some other
3 breakage or problem with the RC drain tank. But it was not
4 before the first half hour.

5 MR. CUNNINGHAM: Did you attribute any
6 significance to this?

7 WITNESS ZEWE: Only that we knew that the
8 electromagnet had lifted on high pressure and it should have
9 on high pressure and the initial discharge of water into the
10 tank could have ruptured something in the tank, yes.

11 Not that it was a continuing thing, because the first
12 time I went back to look at the RC drain tank, I believe Ed
13 was with me then, and we looked at the pressure was zero and
14 the temperature was around 210 degrees and it was off-scale
15 low on the level.

16 MR. CUNNINGHAM: This would have been in this half
17 hour to 90-minute time period?

18 WITNESS ZEWE: That is as close as I can come to
19 it.

20 MR. CUNNINGHAM: Seeing the lack of level and lack
21 of pressure, is that something that is fairly typical? Is
22 that what you would expect?

23 WITNESS ZEWE: You should see level. You should
24 see a certain amount of pressure in it, too. So I thought
25 in my own mind that you did have something wrong with the

978 12 11

rc LRW 1 drain tank, but that it happened due to the reliefs opening
2 but it was not a continuing thing.

3 WITNESS FAUST: I don't know about the pressure
4 necessary because we have gone back there and not had any
5 pressure indication on the tank as far as the pressure.

6 MR. CUNNINGHAM: During normal operation?

7 WITNESS FAUST: During normal operation. We have
8 gone back there with the tank level quite low at times where
9 you didn't get down to 70, but down around I guess 80.

10 MR. CUNNINGHAM: 80 what?

11 WITNESS FAUST: 80 inches.

12 WITNESS ZEWE: But knowing that we had a relief
13 valve open on us and still now not having any pressure, we
14 should have had some pressure under these conditions still
15 in the tank from the relief because we knew it had relief,
16 but now there was no pressure in the tank, so that was an
17 issue.

18 MR. FRAMPTON: Does the reactor coolant drain tank
19 have a high temperature alarm?

20 WITNESS ZEWE: Yes.

21 MR. FRAMPTON: Where does it alarm visually, if at
22 all?

23 WITNESS ZEWE: On the computer.

24 MR. FRAMPTON: Is there a visual alarm that
25 appears anywhere on the back panel?

978 12 12

rc LRW 1 WITNESS FAUST: On the back panel itself. 8-A.

2 MR. FRAMPTON: That is a —

3 WITNESS FAUST: I am trying to remember

4 specifically. I believe an alarm —

5 MR. FRAMPTON: Is this a visual alarm?

6 WITNESS FAUST: Yes.

7 MR. FRAMPTON: High temperature alarm?

8 WITNESS FAUST: I believe so.

9 MR. FRAMPTON: That is your recollection. What

10 about a high pressure alarm? Does that in the reactor

11 coolant drain tank appear on the back panel, too?

12 WITNESS FAUST: Listed as high-low pressure.

13 MR. FRAMPTON: Would they be visual from the main

14 console?

15 WITNESS FAUST: No.

16 MR. FRAMPTON: They are facing the other

17 direction?

18 WITNESS FAUST: Yes.

19 MR. FRAMPTON: On the back of the back panel?

20 WITNESS FAUST: Right. Two panels back there.

21 MR. FRAMPTON: Do those alarms sound audibly in

22 the control room?

23 WITNESS FAUST: If it is an alarm in, you will

24 know it.

25 MR. FRAMPTON: If there are other audible alarms

978 12 13

rc LRW 1 going off, you wouldn't know either of them went off.

2 WITNESS FAUST: You wouldn't know if anything went
3 off the back panel at that time.

4 MR. FRAMPTON: What about reactor coolant and
5 drain tank rupture disc? When the disc blows out, does that
6 cause an alarm?

7 WITNESS FAUST: No, except low pressure maybe.

8 MR. FRAMPTON: Is the reactor coolant drain tank
9 disc in the bottom of the tank?

10 WITNESS FAUST: No. The top.

11 MR. FRAMPTON: It is on the top of the tank.

12 WITNESS FAUST: Yes.

13 MR. FRAMPTON: What would have caused the level
14 indication to go to zero when you went to look at it?

15 WITNESS FAUST: I am not sure. It might be a dry
16 reference.

17 WITNESS FREDERICK: The level indication doesn't
18 go to zero. The lowest level you read is 70 inches.

19 MR. FRAMPTON: That is an off-scale low, in other
20 words?

21 WITNESS FREDERICK: Yes.

22 MR. FRAMPTON: When was the first time that you,
23 either of you, Mr. Frederick or Mr. Zewe, went to find out
24 what the back panel readings were with respect to the
25 reactor coolant tank? Was that at the time you described?

rc LRW 1 Sometime about a half hour to an hour and a half into the
2 accident?

3 WITNESS FREDERICK: Yes.

- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

18

CR6978
#13
rlp
LRW

1 MR. FRAMPTON: Your discovered that the level
2 was bottom low and there was no pressure; is that right?

3 WITNESS FREDERICK: Yes.

4 MR. FRAMPTON: What would that tell you about
5 the state of the tank? What conclusion did you draw about
6 what the situation was there?

7 WITNESS FREDERICK: The only conclusion you could
8 draw directly is that the level was a little bit low. About
9 six inches low.

10 MR. FRAMPTON: Would that tell you the rupture
11 disc had probably blown?

12 WITNESS FREDERICK: No.

13 MR. FRAMPTON: It would not?

14 WITNESS FREDERICK: No.

15 MR. FRAMPTON: Then --

16 WITNESS FAUST: Uou would have to have a trend
17 or be standing there watching pressure actually go up to be
18 sure the rupture disc blew and see it decrease or else the
19 trend report printing this out so you come back and say we
20 just exceeded the capacity of the relief and picked up that of
21 a rupture of 200 pounds.

22 MR. FRAMPTON: Was the fairly high temperature
23 reading and level low indications, were they consistent with
24 the possibility that the EMOV had opened and then shut at its
25 low set point?

ce-F Reporters, Inc.

rlp 2
LRW

1 WITNESS FREDERICK: To me they were. I would have
2 expected the tank to heat up.

3 MR. FRAMPTON: Which it has.

4 WITNESS FREDERICK: Yes. I would have expected
5 the level to change one way or the other. If you had steam
6 generation and lifted the relief valve, you might have lost
7 some water level through heating up the whole tank and I
8 would have expected either a normal or higher than normal
9 pressure. When we went back, it was zero or about normal.
10 Just a bit above zero.

11 MR. FRAMPTON: What is normal pressure?

12 WITNESS FREDERICK: Zero.

13 MR. HAYNES: May I continue a moment? The
14 reactor coolant drain tank cooler intermediate cooling
15 tmeperature was alarmed at 11 and a half minutes, supposedly,
16 to some of the sequences and that alarm set point was set
17 25 degreesF. Does that strike a bell with any of you?

18 WITNESS FREDERICK: What cooling alarm temperature
19 is that?

20 MR. HAYNES: Intermediate cooling temperature
21 for the reactor building drain cooling system.

22 WITNESS FREDERICK: There is no intermediate
23 cooling closed water to the reactor coolant drain tank. The
24 system which cools that is the linkage closed cooling system
25 which is cooled by decay heat in the closed cooling water

rlp 3
LRW
1 system.

2 WITNESS FAUST: Referred to as leakage closed cool-
3 ing.

4 MR. HAYNES: You have a cooling system in the
5 reactor coolant tank; is that correct?

6 WITNESS FREDERICK: Yes.

7 MR. HAYNES: Does that have an alarm if the
8 temperature gets too high in the cooling loop?

9 WITNESS FREDERICK: Not that I'm aware of. The
10 one we have is high temperature in the tank, not in the
11 cooling water that cools the tank.

12 MR. HAYNES: Okay.

13 WITNESS FREDERICK: If there is a computer
14 alarm for the leakage in the cooling water system, that's
15 probably where you found that. Does it give the course
16 of that?

17 MR. HAYNES: Alarm printer and reactimeter. It
18 says that it's set 225 degrees F. The point I'm trying to
19 get at is if the cooling loop is 225 degrees F, then the
20 water in the tank that is trying to cool has to be at least
21 225 degrees F; is that true? Now, if the rupture disc breaks
22 under this condition, then would not the contents of the tank
23 flash into steam and empty the tank?

24 WITNESS FREDERICK: Empty the tank? Not neces-
25 sarily.

rlp 4
LRW

1 MR. HAYNES: Would it flash and tend to decrease
2 the level?

3 WITNESS FREDERICK: You would have some steam
4 generation and appropriate reduction in level. The evapora-
5 tion of the water would cause the water to cool.

6 MR. HAYNES: But there would be a decrease in
7 level?

8 WITNESS FREDERICK: Yes. It would be difficult
9 to estimate what the decrease would be unless you had a
10 continuous heat source. Then you could say it would blow
11 dry.

12 MR. HAYNES: Say the continuous heat source is
13 open relief valve from the pressurizer.

14 WITNESS FREDERICK: Certainly. I imagine it would
15 blow dry, yes.

16 MR. HAYNES: If I may pursue on this panel 8A,
17 at the time when the transient started, several alarms came
18 in the control room, as I understand it; is that right?

19 WITNESS ZEWE: Yes.

20 MR. HAYNES: When was the alarms -- enunciator
21 alarm system acknowledged first to your recollection?

22 WITNESS ZEWE: Several minutes after the start
23 of the event.

24 MR. HAYNES: More than 15 and less than 30?

25 WITNESS ZEWE: Less than 15.

1 MR. HAYNES: Was it subsequently acknowledged
2 again?

3 WITNESS ZEWE: Several times after that, yes.

4 MR. HAYNES: If I understand the panel 8A enunciator
5 system correctly, if you acknowledge out on the front board
6 that the horn will not go off, the audible alarm will not
7 go off if there is also an alarm on the back panel; is that
8 correct?

9 WITNESS FREDERICK: That depends on which alarm is
10 in on the back panel.

11 MR. HAYNES: Say the alarm is the high tempera-
12 ture in the reactor coolant drain tank, for example, or low
13 level in the reactor coolant tank.

14 WITNESS FREDERICK: The alams on panel 8A are
15 silenced in the control area.

16 MR. HAYNES: They're silenced there?

17 WITNESS FREDERICK: Yes. They would go out.
18 If that was the one causing the horn, it would stop. The
19 alarms that are not acknowledged from the front are ventila-
20 tion alarms on panel 25A.

21 MR. HAYNES: So what you're saying is that you
22 could have alarms on panel 8A that came on, acknowledged on
23 the front, which would acknowledge them on the back panel 8A
24 and they woul go, if they're still in an alarm state, on under
25 the light on status and you really would not know that those

rlp 6
LRW

1 alarms came in until you got up and walked around to take a
2 look at panel 8A; is that correct?

3 WITNESS FREDERICK: That's correct.

4 MR. HAYNES: Do you recollect, when you first
5 set the alarms and the horn cleared, did any of you go and
6 take a look at the --

7 WITNESS FAUST: It didn't clear very long. Push
8 the button and it went back on.

9 MR. HAYNES: Was there ever a period when the
10 alarm was cleared for a few minutes? The horns cleared for
11 a few minutes?

12 WITNESS ZEWE: I'm sure there was, but it didn't
13 seem to like it.

14 WITNESS FAUST: It seemed like it was going all
15 the time.

16 MR. HAYNES: I believe you went back and checked
17 the back panel sometime after 15 minutes or so; is that
18 correct, the panel 8A?

19 WITNESS ZEWE: Half hour or so.

20 MR. HAYNES: Did you notice any alarms on
21 panel 8A at that time?

22 WITNESS ZEWE: I really didn't concentrate on
23 the alarms that I had. I was concentrating on the panel
24 indications that I had.

25 MR. HAYNES: What were the panel indications that

rlp 7
LRW
1 you saw?

2 WITNESS ZEWE: Zero pressure off scale low level
3 and elevated temperatures. Those are the only parameters we
4 have there for the RC drain tank itself.

5 MR. HAYNES: And I believe you said that your
6 evaluation of that at that time was that possibly the rupture
7 disc failed or a relief valve was opened; is that correct?

8 WITNESS ZEWE: Something was wrong with the tank
9 because of the relief valve but I didn't perceive it was
10 still continuing. That's all.

11 WITNESS FAUST: At the time I think one of the
12 things we came up with later, one of the things we were
13 thinking about at the time was we might have lifted the code
14 relief valves. It was just a consideration.

15 MR. FRAMPTON: Let's take a short break.

16 MR. CUNNINGHAM: Can I ask one more question and
17 I'll be done?

18 MR. FRAMPTON: All right.

19 MR. CUNNINGHAM: This is a general question. I
20 guess for all of you. In a general sense, how do you rate
21 the B & W design of a reactor, of an NSSS and the power plant
22 in ease or difficulty of operability and operation?

23 WITNESS FREDERICK: I'm not sure the construction
24 of the NSSS is directly relatable to the layout of the control
25 room.

rlp 8
LRW

1 MR. CUNNINGHAM: I wasn't talking in terms of
2 control room layout. I was talking in terms of as you're
3 trying to produce kilowatts from a plant. Is it a plant
4 that you have to constantly fiddle with and make small adjust-
5 ments to it or is it a plant you can sit back and it will
6 purr along by itself?

7 WITNESS FREDERICK: I thought it was rather a
8 smooth running plant myself.

9 WITNESS ZEWE: I can just interject an experience
10 I had on Unit 1 in the last five years in operation. My
11 evaluation, it's a very good plant to control, but then you
12 must recognize this is all we have. We have nothing to compare
13 it to. I compare Unit 1 with Unit 2, but that's as far as I
14 can go. From operating Unit 1 for the last five years, it
15 was a very stable plant that you haven't had to adjust except
16 periodically and we went through a whole fuel sequel without
17 an unplanned reactor trip for a whole year. That in itself
18 proves it's a pretty reliable system and a pretty controllable
19 system. But it did take sometime in start up phase and then
20 some work time to work out some of the little design bugs,
21 if you will, that you will have to work out. But I don't
22 think it's hard to control. I think it's a good system.

23 WITNESS FAUST: Essentially, I was thinking along
24 the lines Ed Fredericks just said. I wouldn't mind having
25 a little more indication here and there.

Ace-...al Reporters, Inc.

rlp 9
LRW

1 MR. FRAMPTON: Let me ask a follow-up question.
2 I will start with you, Mr. Faust. Did Unit 2 have any kind
3 of reputation relative to Unit 1 of being troublesome or a
4 difficult plant during the start up preoperational testing?

5 WITNESS FAUST: I was getting the impression
6 we were having -- being harassed, being off more that we were,
7 but that was still early in operation.

8 MR. FRAMPTON: Do you mean the machine was giving
9 you a lot of trouble or somebody else was giving you a lot
10 of trouble?

11 WITNESS FAUST: I guess you would call it, when
12 you pick up the phone and talk to Unit 1, why: "Oh, are you
13 on line yet?" We experienced -- everybody is aware of quite
14 a few difficult shutdowns on Unit 2. I don't know if I
15 could point a finger at it and say we were worse than any-
16 body else.

17 MR. FRAMPTON: Do you think their attitude came
18 from the period of down time, the specific trips and problems
19 that we are aware about in the history of the plant or was
20 it a lot of other little things, too?

21 WITNESS FAUST: Just more competitive between
22 the units, I guess. Who is up more than the other one. You
23 had more operating time than we did. I don't think there
24 was anything really meant by it.

25 MR. FRAMPTON: Does anybody else have any thoughts

rlp 10
LRW
1 about that?

2 WITNESS ZEWE: I think that practically everyone
3 you talk to would prefer Unit 1 to Unit 2.

4 MR. FRAMPTON: Why?

5 WITNESS ZEWE: A number of reasons. One, they're
6 more familiar with Unit 1. The people you may talk to,
7 they first trained in Unit 1. We all first trained in Unit 1.
8 The plant has a fine record. Very, very few problems in
9 relationship to Unit 2. Different types of problems but not
10 as many. We're futher along in Unit 1. I think at that time
11 design aspect of a plant, I like Unit 1's secondary side and
12 control room layout much better to Unit 2. I think just a
13 general feeling of attitude was, you wanted to know for these
14 various reasons, was it a preferable unit to the operator.

15 WITNESS FAUST: I want to comment on what he said
16 in the sense that depending on which unit was up or down at
17 the time, whether they preferred one or the other. I heard
18 other guys state that boy, it's nice to be over at an operating
19 unit. That Unit 1 is a pain in the ass when it's down.

20 WITNESS ZEWE: If the operator was hired into
21 Unit 2 and he had very little to do with Unit 1, you would
22 find a reverse effect. Something they were familiar with
23 first, that's all you know. so you say this is better than
24 over there. Those that worked both units, like myself, for
25 a number of years, I don't believe that I know any of the

rlp 11
LRW

1 shift supervisors that worked both units that wouldn't prefer
2 Unit 1 over Unit 2. But personally, you work more with one
3 unit and it just, you know, it's preferred from that stand-
4 point.

5 MR. FRAMPTON: Can you put your finger on what
6 was preferable about the secondary side in Unit 1? Was
7 it for reliability? Was it simpler?

8 WITNESS ZEWE: From my own standpoint, I think
9 that the secondary side was better designed, laid out better,
10 more accessible, had a lot of better reliable features than
11 Unit 2 secondary side.

12 MR. FRAMPTON: Can you expand on what reliable
13 features means?

14 WITNESS ZEWE: I believe that the hot well level
15 control system was inadequate for the system. We could
16 never quality control out hot well level. We had repeated
17 problems with the condensate booster pump recirc lines
18 which have high vibration and high noise levels. We cannot
19 have any bypass valves for either the condensate polishers
20 or on high D p, and the valve we have is not open with an
21 excessive amount of D p on the system. You have to get down
22 and manually open it up locally. The design of where the
23 vacuum pumps suck out of the main condensor lead to problems
24 with feeding the main vacuum pumps. The turbine bypass valves
25 going into the condensor has led to an awful lot of problems

ace-Press Reporters, Inc.

1 with the hot well level. We don't have particularly bypass
2 valves or warm-up lines around the major valves of the plant.
3 We don't have position indication of the major valves in the
4 plant, manual valve locally. We don't have
5 bypasses around the condensate pumps or the main feed water
6 pumps so if we want to clean up feed water and run the
7 condensate pump, you have to windmill the booster pumps and
8 feed pumps. All these things in Unit 1, they do have an auto-
9 matic byoass around the polishers that opens on high D p.
10 There is no problem with recircs for the booster pumps or
11 condensate pumps. They have bypasses running to the booster
12 and feed pumos. All these things Unit 1 has. I can only
13 compare that plant with this plant. The good features. Plus
14 I consider that the condensate polishing system as a whole
15 still had lot of problems. We spent many, many years, I
16 would think, in time spent on the polishers and it was still
17 an inadequate system. We were always running near the total
18 design capacity of the system. We had problems with trans-
19 ferring resin and whatnot. Unit 1 had a resin type coating
20 bed. It was much easier to use. Maybe it couldn't handle
21 a large capacity feed water problem or a leak in the condensor,
22 but I considered that system a lot more reliable in that
23 facet. I think that just the design of the feed water pump
24 turbines, if you walk to a 281 elevation of the tubine
25 building, good luck. It's really bad now because of the

rlp 13
LRW

1 accident because we added a . w more things. But even before
2 then, if you look at the Unit 1 main feed pumps and the Unit
3 2, they're exactly the same pumps. Different turbines. And
4 the turbine designs are good. It's just crammed into too
5 small a space. Hard to work on. Very hard.

6 WITNESS FAUST: Crazy.

7 WITNESS ZEWE: Unit 2 like Unit 1 had a lot of
8 problems with heater drain pumps, but Unit 2 had more problems
9 with them. The design philosophy changed quite a bit. All
10 of those sort of things, plus the water make up system, we
11 have not been able to use it yet effectively where all the
12 de-mineralized water used for the island comes from Unit 1.
13 The Los Angeles water treatment in Unit 2 has never been used
14 effectively. Either the pretreatment system or the de-mineral-
15 izer system. We have not been able to make it work. Here
16 again, many man-hours were spent, months and years. We have
17 not been able to make that system work.

18 MR. FRAMPTON: Would it be fair to say that the
19 vast majority of the significant events, trips, and problems
20 that occurred in Unit 2 during the preoperational testing,
21 the start up year and the period of '79 up to the accident
22 originated in one way or another on the secondary side rather
23 than the reactor primary system itself?

24 WITNESS ZEWE: I would say so, yes. Typically,
25 you always have more problems on the secondary side. That's

rlp 14
LRW

1 where you devote most of your attention to, the primary
2 side or -- the secondary side problems. Primary side is a
3 lot more controllable from my aspect.

4 MR. FRAMPTON: You say from your aspect. What
5 do you mean by that? From the point of view of the operators
6 in the control room running the plant?

7 WITNESS ZEWE: Exactly. The primary side is
8 very controllable from the control room. The secondary side
9 is not necessarily as controllable from the control room as
10 what the primary is for the control room.

11 MR. FRAMPTON: So you have to have people out
12 there physically spinning the valve wheels and whatnot,
13 monitoring conditions; is that what you're saying?

14 WITNESS ZEWE: Yes.

15 MR. FRAMPTON: Is the primary side the NSSS, is
16 that relatively more reliable as well? More reliable than
17 the secondary side?

18 WITNESS ZEWE: Yes.

19 MR. FRAMPTON: And much more problem-free?

20 WITNESS ZEWE: It's much simpler. You have two
21 pieces of pipe with a pot in the middle and four pumps. From
22 the time you begin the start up until the time you're 100
23 percent power, there is not much change in the system except
24 for the rod portion or the boron in the water. In the
25 secondary side you're changing the speed of the pumps, flow

ace-P...al Reporters, Inc.

rlp 15
LRW

1 rate through the systems, temperature of all components. You
2 have many, many more variables in the secondary side whereas
3 the primary side the temperature is constant, flow is constant,
4 pressure is constant. What is going to go wrong? As soon
5 as you're producing a little bit of power, you're hardly
6 going to change anything in the primary system all the way up
7 to full power.

8 MR. FRAMPTON: Yet isn't it the case for you in
9 the control room, anything that happens in the secondary side
10 can have a very subtle and immediate impact on the primary
11 side in many cases, causing a trip or a run back or some
12 other potential problem? Would you say that is a fair
13 statement?

14 WITNESS ZEWE: Yes. For, the whole reason for
15 the primary system is the secondary side, which is to make --
16 to turn the water into steam and spin the turbine. We
17 wouldn't need the primary side if we didn't have to have
18 the secondary side.

19 MR. FRAMPTON: Thank you. Let's take our break
20 now.

F13

21 (Recess.)
22
23
24

dwLRW 1 MR. FRAMPTON: Back on the record. Mark this 8,
2 please.

3 (Exhibit 8 identified.)

4 MR. FRAMPTON: Mr. Frederick, I would like to ask
5 you a couple of questions about what we have marked as
6 Exhibit 8, a handwritten note from you to "Jim," dated May
7 3, 1978, which I believe is a memorandum you sent to
8 Mr. Seelinger making some comments on his report on the
9 April 23, 1978 transient; is that right?

10 WITNESS FREDERICK: Yes.

11 MR. FRAMPTON: You have been questioned about that
12 memorandum rather extensively in a previous deposition, and
13 I won't go through it completely, but there are one or two
14 questions I want to ask you about it.

15 Did you ever receive any feedback from Mr. Seelinger on
16 your suggestions made in this memorandum?

17 WITNESS FREDERICK: Yes. The deposition that is
18 an exhibit in the Presidential thing, the other half of the
19 letter is attached to it.

20 MR. FRAMPTON: He returned a two-page handwritten
21 memo to you commenting on your suggestions?

22 WITNESS FREDERICK: Right.

23 MR. FRAMPTON: After that, do you recall whether
24 there was any feedback to you as to whether any of
25 Mr. Seelinger's superiors acted on any of these suggestions?

DwLRW

1 WITNESS FREDERICK: I can't remember any specific
2 feedback from Mr. Seelinger, but I saw some modifications in
3 the plan.

4 MR. FRAMPTON: Made as a result of your
5 suggestions?

6 WITNESS FREDERICK: Probably not made as a result
7 of my suggestions, no, but they were similar concerns that
8 other people shared, I suppose. In other words, I never
9 received a memorandum that said, "In reply to your
10 suggestion 3 of such and such, there is a new light on the
11 control panel."

12 MR. FRAMPTON: Okay. Paragraph 3 in your memo
13 noted the alarm system was poorly designed and contributes
14 little in the analysis of a casualty.

15 Prior to this time, had you and other operators
16 suggested that the number of alarms that indicated in the
17 control room be reduced?

18 WITNESS FREDERICK: Had we requested it of
19 Mr. Seelinger?

20 MR. FRAMPTON: Of anyone.

21 WITNESS FREDERICK: Yes.

22 MR. FRAMPTON: Was there any program in effect to
23 try to look at the alarms and see whether some of them
24 weren't necessary?

25 WITNESS FREDERICK: At what time?

978 14 03

bwLRW 1 MR. FRAMPTON: At the time of the April 23
2 transient.

3 WITNESS FREDERICK: I don't recall. I know there
4 was one ir. progress earlier this year before the accident.

5 MR. FRAMPTON: There was?

6 WITNESS FREDERICK: Yes.

7 MR. FRAMPTON: Can you describe what that was?

8 WITNESS FREDERICK: Met Ed had two full-time
9 engineers analyzing each alarm and its applicability to
10 normal and emergency operations, and they were deciding one
11 by one which alarms would be retained and which would be
12 eliminated or modified.

13 MR. FRAMPTON: Was their program in response to a
14 perception that the number of alarms in the control room was
15 just overwhelming?

16 WITNESS FREDERICK: Yes.

17 MR. FRAMPTON: Do you know whether such progress
18 was actually made in reducing the number of alarms before
19 the accident on March 28, 1979?

20 WITNESS FREDERICK: As far as I know, it was still
21 in the stage where they had identified which alarms they
22 wanted to change. They may have changed a few, but they had
23 not really gotten into the hardware changes full tilt.

24 MR. FRAMPTON: Mr. Zewe, do you happen to know
25 whether a large number of alarms had been identified to be

bwLRW 1 eliminated, if possible?

2 WITNESS ZEWE: We really had two different facets
3 of the alarm, rectifying the alarm problem. We had reduced
4 the number of alarms from over 100 down to about 50 that
5 were in when you would normally operate, and these ones that
6 were in when you were normally operating were the ones that
7 they were trying to evaluate to see if we shouldn't change
8 the condition of the alarm to reflect an abnormal condition,
9 rather than a normal condition, but we did have considerable
10 work from the maintenance force in fixing alarms or reasons
11 why alarms within that were valid.

12 There was just something wrong with the alarm circuit
13 itself, but it measured the right parameter, but there was
14 some problem with it. An awful lot of these were fixed. We
15 used to identify the existing alarms and reasons for them on
16 the surveillance which was done every Wednesday morning.

17 We would tabulate all the alarms we had. This would go
18 to maintenance. They would try to work on all these alarm
19 problems and try to rectify them. This engineering twosome
20 that Ed talked about was working on the same things, but on
21 rectifying existing problems with the alarm as it existed,
22 not fixing any discrepancies that the alarms had at that
23 time.

24 I thought we had made considerable progress with the
25 number of alarms we had that were valid or they were

978 14 05

bwLRW 1 nuisance alarms or they were alarms that were broken, so to
2 speak.

3 MR. FRAMPTON: Would you say that the number —
4 the gross number of alarms that are displayed in the control
5 room, that factor in itself contributed adversely to your
6 handling of the accident in this case?

7 WITNESS ZEWE: I think it had an effect, yes,
8 because the number of alarms is somewhat overwhelming on
9 trying to go through and methodically account for each of
10 the alarms and what to do about the individual alarms. The
11 volume was just too great.

12 MR. FRAMPTON: What you are saying is the number
13 of alarms made it difficult to prioritize, pay attention to
14 the more important ones and leave the least important ones
15 for later?

16 WITNESS ZEWE: Exactly, yes.

17 MR. FRAMPTON: What about the noises? The fact
18 that there was constant or recurring horns? Was that a
19 factor? Would that make it somewhat difficult to respond in
20 a measured way to what was going on? Was it annoying?

21 WITNESS ZEWE: Annoying, yes.

22 MR. FRAMPTON: Do you have any suggestions about
23 anything that could be done to rectify that, to have some
24 kind of a system that brings the alarm to your attention
25 during an accident situation but doesn't overwhelm you with

dwLRW 1 a constant buzzing?

2 WITNESS FAUST: You could use a silencer for one
3 thing. When you are clearing it, you are acknowledging the
4 alarm. Okay, acknowledge it and have that alarm locked in
5 until you then can get a chance to clear that individual
6 alarm to look at it. Not to where you push a button and
7 that one goes off and another comes in. Or the same one
8 comes in and out again and again.

9 MR. FRAMPTON: What you are saying is there should
10 be an acknowledgement system which permits you to turn off
11 the noise but freeze the alarm until you actually go to a
12 second action of clearing it?

13 WITNESS FAUST: If we had a system that froze the
14 alarms that came in and kept them in, it would get to a
15 point where the alarm would no longer -- you freeze enough
16 alarms you have a lot of alarms in. We freeze them in
17 state. They would be in. We knew we had to look at them.
18 We would then individually eliminate an alarm, if we had the
19 time to go up and look at it to get rid of it. But to have
20 it coming in and out, and you don't know which state you are
21 catching it in necessarily, that is when it gets annoying
22 and gets useless when you are trying -- you don't have the
23 time to look at that one, and you have several other ones you
24 are trying to work on at the same time coming on.

25 What is the sense in having it that way? You might as

978 14 07

bwLRW 1 well have it come in, freeze, and when you have the time, of
2 it takes 14 hours to get to that alarm, at least it's still
3 in, not continually alarming in our area.

4 WITNESS FREDERICK: The comment I made in that
5 memo was partially in request to have the alarm system
6 worked on that had problems with that system, but also the
7 system as a whole, to have it considered as far as how
8 effective it was in performing its function. The overhead
9 enunciator blinking-light type alarm I think is kind of
10 an ancient idea by now, in that the type of information the
11 operator needs to respond to could better be displayed in a
12 different way. Probably a more expensive way but certainly
13 a more — in a manner that gives the operator more
14 information than simply, for instance, a level alarm that
15 says level high or low. Then it just leaves you with a
16 limited amount of information.

17 You know of the problem but have no idea what is causing
18 it.

19 MR. FRAMPION: The view you expressed was the
20 system as it existed at the time was not very effective in
21 giving you the most important information you need under
22 abnormal circumstances; is that correct?

23 WITNESS FREDERICK: Yes.

24 MR. FRAMPION: Had you and other operators been
25 making such inputs since the beginning of the installation

bwLRW 1 control room in Unit 2? Is this something you observed
2 prior to this time?

3 WITNESS FREDERICK: Comment that the number of
4 alarms was excessive and the enunciator acknowledgement was
5 undesirable, that comment was made prior to the time the
6 panels were energized, while they were still installing the
7 panels. While the room still has no electricity in it.

8 We were touring the plant looking it over casually. We
9 could see there was one enunciator acknowledgement button
10 in the center console in the middle of all of these,
11 whatever, 13 panels. There is only one button to
12 acknowledge 1200 alarms.

13 MR. FRAMPTON: That was changed, was it not?

14 WITNESS FAUST: Got more buttons.

15 MR. FRAMPTON: But didn't change the fundamental
16 system of single state acknowledgement of enunciators.

17 WITNESS FREDERICK: Right. Just gave you more
18 buttons that perform the same function.

19 MR. FRAMPTON: How realistic do you think it was
20 to suggest that the whole system be reconsidered after it
21 was designed and in the process of being installed?

22 WITNESS FREDERICK: The statement I made was
23 probably unrealistic in that I asked them to change the
24 system, but at least they could have installed the same
25 acknowledgement system Unit 1 had. A three-button

978 14 09

bwLRW

1 acknowledgement system. Where you can test, acknowledge and
2 clear alarms all from the same station. With several on the
3 panel.

4 MR. FRAMPTON: Do you think there were other
5 aspects of the control room design or display system that
6 made it difficult to respond effectively to this accident or
7 might well make it difficult to respond effectively to other
8 accidents?

9 WITNESS FREDERICK: The location of the
10 instrumentation on the panels, we have discussed many times.
11 Most of the operators that I have talked with agree that the
12 parameters are not displayed in the area in which you
13 institute the controlling function. In other words, you are
14 manipulating the feedwater station, it will have a definite
15 effect on reactor coolant system pressure. The two are not
16 anywhere near each other on the panel. They are probably 12
17 feet apart. Going into ES actuation you would expect the
18 operator to throttle high pressure injection or control high
19 pressure injection flow.

20 The control valves are on the forward desk section and
21 the flow indicators on the rear upper-right panels. They
22 are another 10 feet apart. They are standard 6-inch gauges
23 or 8-inch gauges. So that the indicators for the parameters
24 which you are controlling should be located near the control
25 station, so you can see what you are doing. In many cases

978 14 10

bwLRW 1 for critical operations your controlling station and
2 parameter are quite a distance apart. That makes it very
3 difficult to operate.

4 MR. FRAMPTON: I believe someone told me that an
5 operator, perhaps it was you, installed a mirror at one
6 point to be able to see the necessary instruments. Do you
7 know about that?

8 WITNESS FREDERICK: That was after the accident.
9 We had made the suggestion repeatedly that a separate alarm
10 system or some type of viewing system be established that we
11 could see the alarms on the rear panels, so we could read
12 them from the operating station, to separate them from the
13 rest of the alarm system completely. We suggested putting
14 up a long mirror so we could look up and see where there was
15 a light flashing back there or up in front. That was never
16 done. But after the accident, we came across a small
17 mirror, and I hung it up there. It didn't work very well,
18 but it was better than nothing.

19 MR. FRAMPTON: Are there other things about the
20 control room design itself that made it difficult to respond
21 to this accident?

22 WITNESS FAUST: You have here the one about the
23 console being too long without any access to the back
24 panel. Talking about the control room console itself.
25 without going around the end of the panel — it end up the

bwLRW 1 whole length and you have to jump over the panel, so it ends
2 up in a nice little walk around the corner of the panel and
3 back around to where you are at.

4 WITNESS FREDERICK: You might be able to see in
5 this diagram. There is only one split panel for access to
6 the upright panels between 2 and 3. It would have been
7 advantageous to have one on the other side of the room
8 between 5 and 6 or 4 and 5, so one could reach the rear
9 upright panels without having to exit the control area and
10 come all the way around the side of the panels.

11 WITNESS FAUST: Just the way out of controls alone
12 on the panel, as far as what is pertinent to the operation,
13 switches you rarely use or in an emergency situation you
14 don't need to use, being up on the front panel compared to
15 what is on the back.

16 MR. FRAMPTON: Mr. Zewe, do you happen to know
17 whether there was any system for operators, foremen and
18 shift supervisors to have an input into what the TMI 2
19 control room would look like at the time it was being
20 designed? Was there any way the company came to people who
21 would have to run this thing and said, "Looking at the Unit
22 1 control room, what changes, additions, improvements can we
23 make?" Do you happen to know whether there was any
24 systemized way of doing that?

25 WITNESS ZEWE: The design was pretty well set when

978 14 12

DwLRW

1 I was first a shift foreman at Unit 2 in 1973, the design
2 was pretty well set even though none of the panels were in
3 place. I can only recall one instance where I had inquired
4 about a separation in the panels also, and they said it had
5 already been considered, but that the engineering was too
6 far along for it to be changed, and we really couldn't prove
7 in their minds, being upper management, that we really
8 needed it. I think we took more the stand we would learn to
9 operate what we had, more so than to try to change it,
10 because it was very difficult from our standpoint to
11 institute changes without really operating it and really
12 knowing if it was difficult, unless it's totally obvious
13 from the beginning. Then it was hard to support, well it's
14 more of a convenience item, more so than a real hindrance
15 that could lead to safety aspects.

16 But we did have the mechanism available through problem
17 reports that we could bring it up to upper-level management,
18 so they could make the final determination whether it was
19 valid or warranted a change or not.

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. FRAMPTON: What are the major improvements that you think are necessary or major directions you would like to see control room design move in to handle the kind of thing you had to go through on the 28th? What are the big things that are important that this control room perhaps didn't do well?

WITNESS ZEWE: Better all around indication. More reliable indication from a recording standpoint. I think a lot more things that are just displayed should be recorded in a more effective manner by way of a brush recorder rather than a slow pen and ink type recorder that we have. It is a very slow speed, very inaccurate, hard to trend because it is low speed. Most of the recorders that we have external to the main console that are on the upright panels by and large are pretty well useless to us.

The multipoint recorder aspect, I think we are way past that stage to where we need to rely on a multipoint recorder for any important parameter at all.

MR. FRAMPTON: Can you really read those things in the middle of a fast moving event?

WITNESS ZEWE: No. That is what I am getting at. You have to have something you can relate to in a timely fashion at a sufficient speed so that you could see trends and see the parameters as they are happening.

Of course, a higher speed, more capacity computer would be a lot better, too. So they could have the information

1 readily available if and when we asked for it.

2 MR. FRAMPTON: Would it be important that the
3 computer call up if it were on a console be able to show you
4 a trend rather than a number and give you a display that would
5 give the last five minutes or hour of five hours?

6 WITNESS ZEWE: I think the CRT display aspects of a
7 computerized input for primary and secondary system parameters
8 is very useful.

9 WITNESS SCHEIMANN: I go along with what Bill said.
10 I would try and get some of those possibilities and information we
11 got in the back out towards the front more. Some of the more
12 critical information. RPS cabinets, I am not too pleased with
13 where they are sitting. They are back behind the main console
14 section where you have to go all the way around to get to them.

15 If you have a trip or something, you have to check and
16 reset papers, you have to actually go out behind the control
17 area itself in order to get to them. I would move them in.
18 Pressurizer heater controls, I would move them.

19 The motor control center and the breakers for them. It is
20 in an area where in the past we normally had steam problems
21 in there. You mess up your heater controls. Things along
22 that nature would be what I would change as well as some of
23 the others.

24 WITNESS FAUST: Just having -- this goes along with
25 what we are talking about on panel location of meters. What I

1 have in mind is just more of the principal data, pressures,
2 primary temperature and pressures related not only in one
3 corner, but in other areas of the plant, the console -- in
4 other words, operators usually take up station during a
5 transient. It helps more if he is looking at it when he is
6 trying to concentrate on something, if he is looking at it in
7 front of him than hearing somebody else talk in the back-
8 ground what he is watching and what you are trying to watch
9 and relay it between you that way.

10 WITNESS FREDERICK: Last week the Essex Corporation
11 interviews, I suggested they consider having a central
12 location in a prominent place along the central console, a
13 display of reactor coolant system temperature, pressure, steam
14 pressure, feed water flow, pressurizer level, all where you can
15 see them in a group so that as one changes, you can see the
16 effect on the others, instead of having to walk through all
17 different panels to gather all the information.

18 MR. FRAMPTON: Put the major, most important
19 parameters from different systems in one central location where
20 you can look at the way they are reacted?

21 WITNESS FAUST: Multiply it once or twice. In other
22 words, I can look at it here while Ed looks at it in his corner
23 and saying what are you doing that is causing that? If he knows
24 he is not doing something, I might be creating the problem
25 over at the station where I am at.

1 MR. FRAMPTON: I want to turn to a slightly different
2 topic that also arises out of your memo, Exhibit 8. In
3 paragraphs 7 and 9 of that memo, you noted that the April 23
4 transient was something that presented you with a situation
5 that you really weren't trained for. And where you have
6 multiple failures in a situation that you are not really
7 trained or prepared for, it is very difficult to be effective.

8 Is that a fair characterization of what you felt about
9 that particular transient?

10 WITNESS FREDERICK: I think that is fair, yes.

11 MR. FRAMPTON: One of the things that you said in
12 your memo was: "You might do well to remember that this is
13 only the tip of the iceberg. Incidents like this are easy
14 to get into."

15 Could you explain what you meant by that?

16 WITNESS FREDERICK: I believe I was trying to illustrate
17 that the incident which we had survived without suffering any
18 core damage or any significant equipment damage other than the
19 fact we may have to replace the main steam relief valve, which
20 we eventually did do, I said that incidents like this, meaning
21 incidents which involve multiple casualties or multiple fail-
22 ures of equipment, seem to me to be easily postulated.

23 The failure of any two components simultaneously or as a
24 result of the other seem to me to be fairly simple.

25 MR. FRAMPTON: But you hadn't been trained for such

1 an event?

2 WITNESS FREDERICK: Yes.

3 MR. FRAMPTON: The same is true of the accident on
4 March 28, '79, right?

5 That was something that you hadn't seen before and you
6 hadn't been trained to see or respond to; is that right?

7 WITNESS FREDERICK: Yes.

8 MR. FRAMPTON: I guess what I am getting at is this:
9 I think it was Mr. Zewe who said before that on a number of
10 occasions when there were trips or transients, the operators
11 were seeing something in the sequence of events that was not
12 anticipated. It wasn't a by-the-book element of that particular
13 trip or transient. Let me ask you, Mr. Frederick, to start
14 with, events that you have had familiarity with where you
15 have been in the control room, is it true with respect to TMI 2 that
16 almost every trip or transient had some element that is
17 unexpected in it?

18 Have most of the trips and transients that you experienced
19 have gone the way they were supposed to go according to your
20 training or simulator sessions?

21 WITNESS FREDERICK: Most of the transients we went
22 through did have some conflicting factor in it that was not
23 accounted for in a single emergency procedure, yes.

24 MR. FRAMPTON: Can you respond to that?

25 WITNESS SCHEIMANN: I would go along with what he

1 said on that, too. Almost any time you get in a situation
2 with a trip there will be something that just ain't covered
3 by that procedure. You can never get a procedure that will
4 cover every possible conception of what can happen.

5 MR. FRAMPTON: Would it be fair to say in many or
6 most of the trips or transients you have had experience with
7 you get something that is not only not covered by a procedure
8 but which is really not covered by your training or
9 simulator training?

10 WITNESS SCHEIMANN: I would say it is conceivable.

11 MR. FRAMPTON: What has your experience with that
12 been?

13 WITNESS SCHEIMANN: A lot of times they don't go
14 in in simulator training or other types of training into a
15 lot of different things that could happen on the secondary
16 side in the course of a trip. Like you might have a heater
17 drain pump that trips on you when you need it or a feed pump
18 go out in conjunction with the trip.

19 There are so many different things that can happen and there
20 are different ways of seeing trips. There are some things
21 that are not covered on the procedure. They couldn't very well
22 all be.

23 MR. FRAMPTON: Mr. Faust? What has your experience
24 been with that? Do most trips, scrams, transients, more or
25 less go by the book or usually have some factor that you really

1 haven't been trained to expect?

2 WITNESS FAUST: I think they go by the book for the
3 most part myself. I think our training has been -- it has
4 proven itself, I think, just from the fact that the idea of
5 our training is to prevent core damage by recognizing symptoms
6 and going by that procedure for it. That sort of got us into
7 somewhat of a problem because we ended up not being able to
8 cipher out all the symptoms we suddenly ended up with and apply
9 them to a specific procedure. That is a little short fall
10 in the training area if you want to look at it that way.

11 We were looking awful hard to get a procedure to fit.
12 There wasn't one that fit, that actually came out and said
13 we had this, this, this, and that and now this is the one you
14 use.

15 MR. FRAMPTON: Mr. Zewe, do you have any thoughts
16 about that?

17 WITNESS ZEWE: As far as the trip experience goes,
18 you mean? I think that each transient that I have has had
19 some uniqueness to it. It had some related problems or some
20 unrelated problems from one another that made it unique so
21 that they weren't mere images.

22 MR. FRAMPTON: Does the training that you have gotten
23 really prepare you to handle abnormal situations or most
24 abnormal situations, had an element that just wasn't covered
25 by the training?

1 WITNESS ZEWE: Training is a very broad scope. It
2 encompasses all of the postulated possibilities that could arise
3 and tries to put it forth in a cookbook fashion. A, B, C, D.
4 This is what you will see and that is what will happen.

5 I think we are all trained that you really won't see the
6 eight out of eight symptoms or maybe only see three out of
7 eight and you can't follow it A, B, C, D, as far as the
8 procedure goes. Use it as a very good guideline because you
9 always have some varying circumstances that makes that par-
10 ticular transient unique.

11 I think at least I have felt that is how the procedure
12 should be used. You always can't cover it in every case. I
13 think the training we have received on the simulator always
14 dealt with single case failures.

15 The current training trend is multiple system failures.
16 At the last simulator class I was at, that I have been at
17 about ten of them so far, but this last one was far above
18 the other ones in that there was multiple casualties. You
19 look more toward an overall objective more so than getting
20 bogged down in specifics and doing this, this, this, and that.
21 Looking at what you are trying to accomplish and then working
22 toward that end.

23 MR. FRAMPTON: Was this most recent session also a
24 session that involved team response?

25 WITNESS ZEWE: Yes.

jc 9

1 MR. FRAMPTON: And also played out the casualty over a
2 longer period of time?

3 WITNESS ZEWE: Yes. That was a very large portion
4 of it. They would give you a casualty and then just perpetuate
5 it longer periods of time until you reached a stable condition.
6 It had other failures along the way.

7 MR. FRAMPTON: Let me ask you a specific question
8 about the training with respect to going solid. I think I
9 have been told or read in prior testimony that in the
10 simulator training given at B&W, there has previously been
11 no simulation of what happens after you go solid. The
12 simulation ends when you go solid. Is that correct?

13 WITNESS ZEWE: Yes. Prior to the Unit 2 accident,
14 the B&W simulator was not programmed to go beyond a solid
15 plant.

16 MR. FRAMPTON: What were the things in your training
17 and simulation that made you want to avoid or be wary of
18 going solid, running solid?

19 WITNESS ZEWE: It is inherently unstable. A solid
20 system changing with large flow rates is inherently a
21 very large pressure transient, either up or down.

22 If you are putting in a lot of water or removing a lot.
23 It is inherently very difficult to control. From my previous
24 experience in the Navy also, we used to take the primary
25 plant solid every year to do instrument calibrations and

1 pressure was very hard to control.

2 MR. FRAMPTON: When you say pressure is hard to
3 control, is that because small changes in liquid inventory
4 result in large changes of pressure?

5 WITNESS ZEWE: Yes.

6 MR. FRAMPTON: That is dangerous to the system for
7 stress reasons among others?

8 WITNESS ZEWE: The controllability aspect which
9 relates to -- from going solid, you are worried about over-
10 pressurizing.

11 MR. FRAMPTON: What was your experience in the Navy
12 with these tests of going solid? Can you describe a little
13 more about that?

14 WITNESS ZEWE: Well, we used to go solid just to
15 calibrate the primary instrumentation, but while we were
16 solid, we took every precaution that we could to avert any
17 pressure change because of charging in water or adding heat
18 to the system or draining any water or removing any heat from
19 the system, so that you didn't have this pressure excursion
20 because of the change in inventory system affecting the
21 pressure.

22 WITNESS FREDERICK: Are you done with that, about
23 going solid?

24 MR. FRAMPTON: I was going to go on to another
25 subject. Would you like to respond to that?

1 WITNESS FREDERICK: Can I go back to the one you
2 asked about --

3 MR. FRAMPTON: Absolutely.

4 WITNESS FREDERICK: Somehow we got from looking at
5 reactions to reactor trips or other casualties, talking about
6 how sometimes the EP may not apply or more than one emergency
7 procedure may apply and whether or not the training was
8 deficient. Whether or not the operators felt confident
9 they could handle some kind of hot reaction in the plant on
10 any given transient.

11 I think the training is based on staying away from the
12 emergency procedures as being the bible and what you have to
13 do during a transient. There is much more emphasis on an
14 in-depth knowledge of the characteristics of each of the
15 independent systems than there is on the rote response to
16 emergency.

17 The backup that you have to some abnormality during emer-
18 gency is the fact that you understand the systems intimately.
19 That some slight perturbation during an emergency, you would be
20 able to figure out what caused it because you understand the
21 system as a whole.

22 That backup is what allows the operator to have some
23 confidence that something going wrong during an emergency
24 isn't going to panic because they can probably figure out what
25 caused it. It is when you get more than one emergency

jc 12

1 procedure going at the same time and several unexplained
2 recurrences, and then you don't have time to figure out
3 each one, that the training somehow got us steered in the
4 wrong direction during this accident. We kept looking for
5 more and more symptoms, more indications of what was causing
6 the problem instead of zeroing in on the safety aspects of
7 losing control of the plant.

end 15

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

078 16 01

sbnLRW

1 MR. FRAMPTON: Had you ever had a training
2 exercise or simulation where you were given conflicting
3 systems and then required to find more and more symptoms to
4 determine which of the conflicting symptoms was the correct
5 indication of what was happening?

6 Do you remember any training that tested you along that
7 line or challenged you along those lines?

8 WITNESS FREDERICK: Not specifically. I don't
9 think that is a valid method of training either. If the
10 idea is to go on the fault tree type method of analyzing the
11 problem and if the fault tree fails you in analyzing the
12 problem, then you should revert back to your basic safety
13 concepts. Do we have heat removal? Is there flow? And
14 what is the temperature in the core as best we know it?

15 WITNESS FAUST: Given those indications at hand.

16 WITNESS FREDERICK: Given the fact that is
17 available in the control room. Once you lose track of the
18 emergency procedure, once it no longer applies, you should
19 revert back to, since we don't really know what will happen
20 next, are we protected at this moment? Are we moving in a
21 safe direction? Should we change what we are doing? Once
22 we had throttle back high pressure injection and it didn't
23 give us the indication we wanted, decrease in pressurizer
24 level, and the pressure, ACS pressure didn't increase when
25 we wanted it to, there should have been those three criteria

978 16 02

sbnLRW 1 in our mind that says do you have subcoolant? We would look
2 for our saturation module. Have you been stable on high
3 pressure injection and low pressure injection for twenty
4 minutes?

5 Do you have the secondary loop coupling? If we had those
6 three criteria at that time, we would have started high
7 pressure injection and would have been able to survive the
8 casualty. Those generic concepts were not in the training
9 program. I don't believe they were --

10 MR. FRAMPTON: They are now?

11 WITNESS FREDERICK: They are now.

12 MR. FRAMPTON: Are those concepts that have been
13 part of the remedial training coming out of this?

14 WITNESS FREDERICK: That is the big difference
15 Bill is talking about in that the casualty is more complex
16 and carried out to a much more restrictive and positive
17 end. You have to get each casualty to a normal cool-down
18 situation before you can terminate, which was unheard of
19 before, spending two to three hours on a single casualty.
20 That change comes from this concept.

21 MR. FRAMPTON: The concept is when you have a very
22 complex situation or situation which is conflicting or where
23 more than one procedure applies or no procedure applies that
24 you try to fall back to certain fundamental principles or
25 fundamental precepts and apply your overall knowledge of

sdnLRW 1 how the systems work and interact to those principles. In
2 effect, make up from first principles what you think is the
3 best emergency procedure to deal with this unforeseen
4 situation; is that right?

5 WITNESS FREDERICK: Not exactly. What it is is
6 unless you have a prescribed set of circumstances, that is
7 positively represented on the panel, you are not allowed to
8 take any manual actions. You must fall back on the
9 automatic protection steps and assure that they are
10 functional. You must have high pressure injection in the
11 automatic mode and low pressure injection and isolation.
12 Everything must be left automatic unless you prove you have
13 those three criteria outlined before.

14 When you do, you can begin to take manual action to
15 restore the normal cooldown. If you can never achieve those
16 basic criteria then stay in basically pressure injection
17 until something happens where you can gain control. That is
18 what saves you.

19 MR. FRAMPTON: If you had to abandon the control
20 room at 6 o'clock on account of high radiation levels, what
21 state would the high pressure injection and other systems be
22 left in when you all left there? Would that have been the
23 basic position that things would have been left in? All
24 the safety systems actuated and on automatic and you just
25 walk out? Is there a procedure for that?

978 16 04

sbnLRW 1

WITNESS ZEWE: Not under these conditions, no.

2 First, I can't conceive of any reason that I would have to
3 totally evacuate the control room for any period of time.
4 If the radiation level got such that I would limit the stay
5 time, that would be a different story. I could still occupy
6 the control room and take control. But I can't conceive
7 myself of any case where I would have to totally evacuate
8 the control room for a long period of time.

9 If I would have to evacuate for certain periods of time
10 for one reason or another, I would certainly have to
11 institute the engineering safety feature system.

12 MR. FRAMPTON: Are there any provisions whatsoever
13 in your emergency procedures for having to abandon the
14 control room for an indefinite period of time?

15 WITNESS FR. DERICK: Yes.

16 WITNESS ZEWE: The only thing is we do have a
17 procedure for cooling down the plant outside the control
18 room which only deals with some problem in the control room
19 like a fire that limits the -- which causes the operator to
20 leave the control room to where you can control a plant in a
21 remote cooldown station, but in this case if you are dealing
22 with high radiation the plant that -- the portion of the
23 plant that we would go to would have the exact same effects
24 as the control room because it is directly below the control
25 room and some of the local control stations which we would

978 16 05

sonLRW 1 have the auxiliary operating to would be inaccessible
2 because of further high radiation.

3 The control room is designed for a certain postulated
4 accident with enough shielding to allow you to occupy the
5 control room. So that would be the one place which should
6 be the last place where we should have to abandon.

7 Just to reemphasize the training now, is that we have one
8 objective, to protect the core and the devil with everything
9 else. Before we used to worry about the coolant pump. You
10 have a three or four million dollar pump here. You have a
11 turbine. And then in real world you are dealing with
12 dollars and dollars is how the whole world survives, I
13 guess. And you are worried about that. But somehow you can
14 lose sight of the overall objective of the core which has to
15 supercede everything.

16 So the training objectives Ed was talking about, if you
17 don't meet the basics to protect the core, you don't go any
18 further. You have to have that before you can go any
19 further to protect anything else.

20 MR. FRAMPTON: You think that's really different
21 than the emphasis in the training you received before the
22 accident?

23 WITNESS ZEME: Yes, because we were dealing with
24 specific procedures for specific symptoms which -- reactor
25 coolant pump procedure, you are worried about the reactor

978 16 06

sbnLRW 1 coolant pump there. The turbine trip; you are worried about
2 that the turbine is isolated and the valves shut and you got
3 oil pumps on and zero speed, you put it on the jack and all
4 those sorts of things.

5 Now casualty training is really a lot easier. Now you
6 know exactly what your objectives are for any category. You
7 go to the main thing. Is the core cool? Subcooled? Could
8 you have control? Then you can branch out knowing that the
9 most important thing is all right and you just keep
10 rechecking that every 15 or 20 minutes to make sure that
11 whatever you do in between your initial conditions, that you
12 go back to check to make sure you still meet that core
13 cooling criteria. It is really easy from a large accident
14 type status because you throw everything else out the window
15 and it is all secondary.

16 You always protect that so you are always safe, even
17 though you may ruin everything else in the plant, you do
18 protect that.

19 That is the philosophy we needed that day. It is rather
20 easy now because you know exactly anything that happens, all
21 right, it is multiple plant. You focus that one thing and
22 make sure of that. It makes the rest if it easy to do.

23 MR. FRAMPTON: Let me move on to another subject.

24 MR. WORAM: Before you do, may I ask a question?

25 It may be appropriate here.

978 16 07

sonLRW

1 I am interested to know what your opinion is on the
2 licensing examination process. Does it address what is
3 really important for an operator to really know? Are the
4 decisions made for the right or the wrong reasons?

5 WITNESS FREDERICK: The NRC examination technique,
6 is that what you are asking about?

7 MR. WORAM: Yes. The technique and general format
8 of the exam. I am sure the technique varies from examiner
9 to examiner, of course.

10 WITNESS FREDERICK: There is a written and oral
11 exam. The oral examination format has been usually
12 acceptable to me. It gives under stress conditions to the
13 operator to think quickly and remember important facts. I
14 think that is a good fundamental way of testing a person for
15 this type of job.

16 The written examination, on the other hand, leaves a
17 great deal to be desired. The emphasis historically made in
18 each section of the examination. Emergency procedures are
19 memorization quizzes. How well can you memorize this sheet
20 of paper? Not how well do you understand the objectives of
21 this procedure and the results of not performing these
22 steps. Or what can go wrong in this procedure that is not
23 outlined? In-depth questions about casualties that never
24 come up on examinations and never have.

25 MR. FRAMPTON: Do they come up on oral

sbpLR# 1 examinations?

2 WITNESS FREDERICK: I couldn't specifically
3 outline any questions that have been asked to everyone but I
4 have never been faced with multiple casualty type questions
5 on an oral examination. Still the emphasis is on how well
6 do you remember this emergency procedure but then on an oral
7 examination you always have the option to say I will follow
8 the procedure now and remember what I forget or look up what
9 I forget.

10 That is acceptable to the examiner in most cases. The
11 written exam has a section on reactor theory. A section on
12 operational characteristics. And several other sections.
13 But the questions are nearly predictable in each section.
14 So that a review session before the examination could get
15 you ready for an examination if you already had the basics
16 and had been studying for several months. I think most
17 operators will agree the exams are in most parts
18 predictable.

19 I don't think that is bad as far as an operator goes. As
20 far as the range of questions, the topic matter, things that
21 will be covered, the depth of the questions hardly ever
22 changes as far as if you look at a brand new operator who
23 was an operator for a year and an operator who has been
24 there for eight years, they will be tested on the same
25 level. They are not expected to have learned any more or

978 16 09

sbnLRW 1 forgotten any less.

2 And I don't believe that is the way it should be. There
3 should be an initial operator exam that says, okay, now you
4 know the basics. Now progress and learn more and go into
5 more depth and become a better operator. The exam does not
6 require that. It requires you to stay at the same level of
7 knowledge with the same amount of expertise. It is like
8 learning algebra over and over every year and memorizing the
9 same axioms and same laws over and over again.

10 You don't learn any more about algebra, but you are ready
11 for the exam each year.

12 MR. WORAM: I gather you are getting into both the
13 initial exam and requal program.

14 WITNESS FREDERICK: They are identical.

15 MR. WORAM: That was going to be my follow-up
16 question. What do you think of the requal program? I think
17 you have answered that.

18 WITNESS FREDEPICK: Okay.

19 MR. WORAM: Anybody else have any comments you
20 would like to make?

21 WITNESS FAUST: Sounds like an exam where you are
22 going to get tough.

23 MR. FRAMPTON: Are you cross-licensed, Mr. Zewe?

24 WITNESS ZEWE: Yes.

25 MR. FRAMPTON: You were licensed first on Unit 1?

978 16 10

sonLRW 1 WITNESS ZEWE: Yes.

2 MR. FRAMPTON: When you got your cross-license for
3 Unit 2 did you have to take that second oral examination?

4 WITNESS ZEWE: Written test administered by the
5 company.

6 MR. FRAMPTON: That only.

7 WITNESS ZEWE: Yes.

8 MR. FRAMPTON: Do you think the cross-licensing
9 process absolutely required you to become as familiar with
10 the Unit 2 as you had been when you got your original
11 license on Unit 1, to be familiar with Unit 1?

12 Do you think someone could gain a cross-license without
13 really becoming familiar with the second unit?

14 WITNESS ZEWE: I think that somebody could gain a
15 license of any type and really not be that proficient. I
16 don't think an NRC examination would necessarily make you a
17 better operator. I just feel that now can you have an
18 organization come in and examine you specifically on your
19 unit if they don't know the unit themselves?

20 They can certainly examine you on how safe you would
21 react to key questions and overall operation from a basic
22 standpoint to tell when they feel that you will operate in a
23 safe manner, when you can manipulate the controls, you know,
24 but not specifically. They really can examine you.

25 Like if I gave an oral examination to a control room

978 16 11

sonLRW 1 operator, if I felt he was really acceptable, or if an NRC
2 guy went out and examined him not knowing the plant, I think
3 that an exam by a person who knows the facility is a lot
4 more worthwhile than the NRC exam because of the outside
5 not knowing the plant.

6 He knows theory and the basics. You have to know that
7 too, but I don't think that you could only examine on
8 generalities and not deal with very specific terms which I
9 don't believe the examiners are really that qualified to
10 do. I don't think there is any examiner at NRC that knows
11 more about that plant than I do.

12 I better know more than he does if he is here for a week
13 or three weeks every year.

14 MR. FRAMPTON: Do you think a person can pass an
15 NRC license exam for a particular plant and still not be
16 competent to operate that plant safely?

17 WITNESS ZEWE: I think how well -- not to evade
18 your question with a vague answer, but I think it depends
19 more on the training program afforded the operator from the
20 company more so than the exam of the NRC.

21 If you have a guy that is a very good talker, so to
22 speak, and really has a way with words, I think it's
23 possible, yes. I think that the examiners I have dealt with
24 can look past this to a certain degree. I think they do
25 just examine you on generalities and pull out a procedure

978 16 12

sdnLRW 1 and see if you could follow it and find all the components.
2 That is something, too, which needs to be done. I just
3 think the exams should be by more qualified people on the
4 particular plant and I am not sure what the best method of
5 that would be.

6 MR. FRAMPTON: So you think the main weakness, if
7 there is one, in NRC licensing exams, is the fact that the
8 examinations are done by people who don't have sufficient
9 knowledge of the particular plant.

10 WITNESS ZEWE: I think so because I think our
11 record shows that the operators were qualified more than
12 sufficiently to pass the NRC exams. Not meaning that the
13 NRC if they were to qualify on the plant could shoot them
14 down either.

15 If they are qualified, they are qualified. It is just a
16 view that I have, having somebody come in for a few hours to
17 tell you when you can operate or not when you know the plant
18 and they don't. That has always been a negative aspect from
19 my aspect and it has always been, now you got your license,
20 now you can learn the plant by operating. And that is
21 true.

22 MR. FRAMPTON: From your personal training
23 experience, was there any evidence that the NRC was really
24 monitoring the substance of the training you were getting?
25 Did you see any evidence of that yourself while you were
being trained?

sonLRM

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

WITNESS ZEWE: They were here for periodic review of the training records and the documentation that we do for our initial training and for the subsequent training and even for the initial license.

We mark down what training the person has gone through and how many weeks of this and at this simulator and how many hours of formal training and so forth.

I know these have all been reviewed to see if there was sufficient training done for the knowledge level the man should have and then they come in to examine you to make sure you are where they consider you should be.

9-16

978 17 01

1tLRW

1 MR. FRAMPTON: Do you think from that kind of
2 review by NRC inspectors. they can really form a conclusion
3 as to whether the training program that a given utility has
4 in place is a real crackerjack program or below-average
5 program?

6 WITNESS ZEWE: I think the final analysis is in
7 talking to the people themselves to form their own opinion
8 rather than solely on paper.

9 MR. FRAMPTON: Mr. Scheimann, do you have any
10 thoughts about that from your own training experience? Did
11 you have a sense that the NRC was really monitoring the
12 substance of the training you were getting?

13 WITNESS SCHEIMANN: I would say substance, no. I
14 would say the requirements or the amount of material that
15 was covered, yes.

16 By means of their periodic inspections. However, I have
17 yet to see one that came and sat down in the damn class to
18 see what material was being presented.

19 MR. FRAMPTON: Mr. Faust, any thoughts about that?

20 WITNESS FAUST: You covered everything.

21 MR. FRAMPTON: Mr. Frederick?

22 WITNESS FREDERICK: You missed my speech. The NRC
23 as I see it, even now they don't examine the content of the
24 lessons or the lectures that are given down there.

25 There is a huge retraining program going on now for Unit

978 17 02

1tLRW 1 1 and they don't -- they review the written material
2 produced for electric plants and for tests and things like
3 that.

4 MR. FRAMPTON: Outlines and study guides?

5 WITNESS FREDERICK: Yes, and study guides that are
6 used. As Fred said, I never saw one in the classroom
7 evaluating teaching techniques or asking operators what they
8 think of the training program.

9 MR. FRAMPTON: Do you think NRC inspectors ought
10 to do that?

11 WITNESS FREDERICK: It would give them a better
12 idea what they should have on their exam. The training
13 department reacts to previous exams as to what they should
14 teach, the way it is now.

15 The NRC is reacting to the exams that they give as to
16 what they should emphasize. It's kind of a closed cycle.

17 There is no new input into the system. The
18 training department will teach what they have to to get
19 operators to pass the exam or be ready for an oral exam and
20 the NRC, in turn, examines people on what the format exam is
21 already based on.

22 You never really expand beyond the boundaries of what has
23 been taught for the last many years. The new lessons and
24 things learned from accidents are included in training
25 programs and occasionally show up in a question on an exam

978 17 03

1tLRW 1 but it's never really expounded upon as far as increasing
2 the operator's study of a particular area.

3 You study reactor theory in general and cover the basic
4 questions but you never dig down and go beyond what you need
5 to pass the exam.

6 WITNESS FAUST: Something I seemed to know when he
7 was talking about material coming up tht you are examined
8 on, on recall exam or something like that, it seems like the
9 NRC picked up on something, it was a casualty or some sort
10 that happened.

11 You might end up getting questions along those lines.
12 Something had to occur before you got questioned on it.

13 It just seems like a wait until it happens and then we
14 will talk to you attitude.

15 MR. CUNNINGHAM: Could I ask a question? We have
16 pretty much concluded here, I guess, that you people know
17 these plants better than anybody coming in from NRC. The
18 question comes to mind: What do you think -- where do you
19 thin. the vulnerabilities of these plants are? To what type
20 of accident is a plant like this going to succumb in your
21 mind?

22 Will it be a large break? A transient-induced accident?
23 Whatever? As an operator. And is that being covered at all
24 by what NRC put forward in training requirements?

25 WITNESS FAUST: We are not covered for the

978 17 04

ltLRW 1 long-term accident, or hadn't been anyway.

2 I wouldn't say that now. I haven't had the training down
3 at Lynchburg that Ed and Bill have seen, but it sounds
4 pretty good.

5 WITNESS ZEWE: I think the vulnerability lies on
6 what we haven't call it major accident that nuclear power
7 will have, no matter whether it is or if it ever happens, it
8 ain't going to be the same.

9 All right, I don't think we will ever have another
10 stuck-open relief valve that will end up like this one did.

11 That's not saying we won't have some other problem that
12 won't lead to a more serus problem or not so serious when
13 it's something there that you are unprepared for, either
14 trainingwise or whatever it might be. I think that is where
15 the problem lies.

16 It's just a continual thing that you never know at all
17 and it's always the unexpected that gets you. The things
18 you aren't prepared for. I am not sure I know what that
19 is. Some of the things now that have been identified 15
20 years ago that we thought were incredible could be very
21 credible.

22 Like this one. It was brought up and for some reason put
23 on the rear inner or rear shelf, well, saying it isn't too
24 credible so we won't explore it further and it will crop up
25

978 17 04
ltLRW

1 because it's a growing industry yet and there is a lot of
2 other problems out there that we don't see.

3 WITNESS FREDERICK: One thing, my experience with
4 the two units, one thing Bill pointed out, he may have
5 forgotten, is that the industry doesn't seem to learn from
6 itself during construction.

7 Unit 1 turned out to be a fairly good plant. Unit 2 had
8 a lot more problems as far as I can see. And Unit 2 was
9 built after Unit 1. There was no attempt made to change
10 Unit 2 to conform with all the good things they learned
11 about Unit 1.

12 I am not sure how other multiple units or even how the
13 units of the same manufacturer feed each other to improve
14 each model.

15 I don't see it happening. If you don't learn from your
16 mistakes, you will make them over and over again.

17 MR. FRAMPTON: Do any of you disagree with that
18 assessment?

19 WITNESS FAUST: Me? I was just talking. I know
20 another man in another plant, Millstone, that I was talking
21 to recently and he was pointing out some of the
22 instrumentation of what they have and how they handle their
23 training as far as who gets it.

24 They have three units up there. He is talking about
25 separation between units and different things we haven't

978 17 06

1 done here. I was saying it sounds like their operators
2 designed their remaining two control room units, the panels.

3 They had a lot of input into the panels. We just --

4 MR. FRAMPTON: Didn't.

5 WITNESS FAUST: Didn't. Somebody is learning in
6 the industry, I am saying. It sounds to me like there is
7 information out there that isn't getting spread around.

8 That is what it's amounting to. We haven't been talking
9 nationwide as well as -- as much as it sounds like they have
10 been talking between companies, their own companies
11 possibly?

12 WITNESS ZEWE: Also, to point out one example, I
13 had gone to the B&W similarity for a couple of years before
14 we had a similarity primary- to secondary-tube leak. They
15 had an actual one at the Oconee plant for Duke Power.

16 They had a procedure for preliminary-to-secondary leak
17 and we didn't even have one. We went to the similarity. I
18 am not sure if it was 1975

19 They gave us a preliminary-to-secondary leak. We pretty
20 much handled it fairly well, but we didn't have a procedure
21 for it. There was no formal procedure for it. Yet, Duke
22 Power Oconee had one, an approved procedure, and there
23 are two B&W plants, like sister-type plants, yet they had
24 procedures we didn't have. Generic-type procedures. That

25

978 17 08

1 is true for natural circulation. Like we didn't have a
2 natural circulation procedure prior to their accident as
3 such were Toledo Edison had one.

4 I am not sure how long they had it prior to the accident
5 but they had one and we didn't.

6 Maybe it would have helped. It certainly wouldn't have
7 hindered. I think one manufacturer that only has seven or
8 eight units like B&W does, they have B&W user meetings where
9 the superintendents and so forth from the various companies
10 get together.

11 I am not sure that they trade all the information that
12 they necessarily should. At least they should all have the
13 same generic procedures.

14 MR. FRAMPTON: In a similar vein, am I correct in
15 understanding that you had never had knowledge of the
16 transient at the Davis-Besse plant that occurred in
17 September of 1977 which involved stuck-open EMOV prior to
18 the TMI accident, is that correct?

19 WITNESS ZEWE: That is true. I heard about it for
20 the first time two days after the accident.

21 MR. FRAMPTON: Is that true for the other three of
22 you gentlemen?

23 WITNESS FAUST: Yes.

24 MR. FRAMPTON: All of you are nodding your assent.

25 WITNESS ZEWE: Normally, the shift trains

1tLRW 1 together.

2 In training, we get all the information we get, we get --
3 either I get it or Fred gets it and I get it both or
4 everyone gets it.

5 If I get it, I always pass it on. If it isn't covered in
6 the training week, we don't have the information.

7 MR. FRAMPTON: You had never seen in training or
8 simulation a failed open EMOV on the pressurizer, I take it.

9 WITNESS ZEWE: I have had transients at the
10 similarity where we have had the valve fail to recede. I
11 have had that. But it was just level and pressure went down
12 and plus you had the indication of it.

13 MR. FRAMPTON: Did the similarity have a position
14 indication showing that the valve was open when the
15 simulation was supposed to have failed to recede?

16 WITNESS ZEWE: I don't recall exactly how they
17 simulated it. There was no question in your mind the PORV
18 was the culprit, so to speak, for the accident.

19 MR. FRAMPTON: Were you supposed to figure that
20 out or told in advance that that is what you were going to
21 be seeing?

22 WITNESS ZEWE: You had to figure it out.

23 MR. FRAMPTON: But it was either shown on the
24 similarity console or it was easy to figure out? One or the
25 other?

1tLRW

1 WITNESS ZEWE: It was easier to figure out. We
2 had the quench alarm right overhead on the trip. You had
3 the pressurizer also never increased in the level.

4 You always had a loss of coolant which resulted in a
5 low-pressurizer level. They could only simulate at that
6 time a loss of coolant of a certain magnitude and they can
7 vary that magnitude but it would be from the system and not
8 from a certain portion of the system. Not from the
9 pressurizer or not from the hotleg or -- just a leak from
10 the coolant system which would result in reduced pressurizer
11 level even though it was from the electromatic valve so you
12 knew you were still losing water and then you put the
13 quench tank -- you looked and I can't remember if they had
14 the red indication on it or not for that simulation, but you
15 isolate it and terminate the transient.

16 MR. WORAM: May I ask a question here? You
17 indicated that -- particularly Mr. Frederick -- that
18 training is improving in terms of getting back to basic
19 things that you have to protect against.

20 Do you feel that's true across the board for all
21 categories of responses or is it just being dwelled upon in
22 this specific small break analysis and everything else is
23 the same?

24 WITNESS FREDERICK: No, I don't consider it
25 getting back to basics. I consider it an advanced form of

978 17 10

ltLRW 1 training in that you progress beyond memorization of basic
2 emergencies. You progress on to multiple casualties and how
3 you -- they are very complex casualties. That is not
4 restricted to LOCAs.

5 They do it for loss of feedwater and steam generator leak
6 and loss of within-reactor coolant pump and a failed
7 pressurizer level instrument.

8 They will do two or three things at the same time. It's
9 seem to me like a random selection of failures. They say
10 this, this, and this fails. What do you do?

11 It gets very complicated.

12 MR. WORAM: If I understand it, you said this is
13 really reflecting a general change of philosophy rather than
14 a small response to a specific problem.

15 WITNESS FREDERICK: Right. Every casualty we
16 attack now in the similarity takes in this basic
17 concept-type approach, whereas if the symptoms are simply
18 and cleanly represented as there is a reactor trip caused by
19 one thing, then you follow the procedure.

20 You follow right into that and keep in mind there is
21 basic generic constants at the same time. But if something
22 happens that doesn't exactly fit an emergency procedure,
23 then you still have this new concept with which you can work
24 and still protect the core.

25 It makes the operator feel much more comfortable and less

978 17 1

1tLRW 1 emphasis on transient behavior of the plant.

2 Now, they eliminated that with changing of the EMOV set
3 point. Every transient results in a trip just about.

4 Before there were several minutes or a long time for the
5 transient to progress before the trip just because of the
6 capacity of the system to absorb pressure changes, which it
7 no longer has, so the casualties are, in one respect, more
8 complicated but in the operator's eyes, it becomes more of a
9 controlled situation.

10 MR. FRAMPTON: Let's take about a two- or
11 three-minute break.

12 (Recess.)

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. FRAMPTON: On the record. I have already asked
2 about the role of NRC inspectors in the control room on the
3 first couple of days after the accident began. Did the nature
4 of the NRC presence or the amount of responsibility that the
5 NRC people on-site had for operations change after the first
6 several days? Was there any different arrangement between
7 the people in the control room and the NRC people on-site on
8 Saturday or Sunday or Monday?

9 WITNESS ZEWE: I am not sure of the time frame there
10 from what day their role changed but it definitely did change.
11 They were more involved and wanted to see more and wanted to
12 be explained more. It was a tremendous influx of various
13 inspectors where you dealt with X number of inspectors for a
14 one- or two-week period and then you would have five or six
15 new ones come in and start all over again.

16 Bring them up to speed, so to speak, on the problems we
17 were having.

18 MR. FRAMPTON: On Friday afternoon, the 30th, Harold
19 Denton and a large group of people from Washington arrived
20 with communications gear and so forth. Was there any change
21 then or within a day or two after the arrival of all those NRC
22 people in terms of when NRC would be informed more of what was
23 going on or have more veto power over plant operations?

24 WITNESS ZEWE: Not that I was aware of. The only time
25 I ever seen Mr. Denton was on TV. That is the only interface

1 I ever had with him other than he was walking around with the
2 President on Sunday in the control room. That is the only time
3 I had any interface at all, which wasn't any personal thing
4 at all. Just that I seen him.

5 MR. FRAMPTON: From your point of view there wasn't
6 any increased NRC involvement in or veto power over operations
7 come Saturday or Sunday directly in the control room.

8 WITNESS ZEWE: No. As far as I knew, all the
9 decisions and all the responsibility was entirely the utility's.

10 WITNESS FAUST: We felt the pressure of the NRC
11 presence, if you want.

12 MR. FRAMPTON: What kind of pressure was that?

13 WITNESS FAUST: IT seemed like we didn't do something
14 unless we were forced to do it. Every step of the way just
15 about, if you look at it. When we went to another mode or
16 something, we were forced into it. In other words, if we
17 wanted to do something, we didn't do it until it came about
18 that something forced us to the next step, so to speak.

19 MR. FRAMPTON: Talking about beginning Saturday and
20 Sunday after the accident?

21 WITNESS FAUST: Even Saturday and Sunday -- even on
22 the vent, we were forced into that. I consider that forced.

23 MR. FRAMPTON: You are talking about Friday morning.
24 How did that relate to NRC presence or non-presence?

25 WITNESS FAUST: I am saying, and this is on my level

1 of it, from what I know. What I don't know is tremendous.
2 But it just seems that we were told to minimize releases, which
3 is understandable, when plant conditions started warranting we
4 should maybe release a little more to get into a better
5 situation, it took a relief valve lifting to get moving where
6 we were actually able to do something by trying to bottle it
7 up and not getting rid of it sooner -- I am just talking,
8 it seemed like generally I don't know if it was stated or
9 what, it seemed like it was keep that in there. Don't leave
10 it out no matter what.

11 MR. FRAMPTON: Did you want to comment?

12 WITNESS FREDERICK: In the beginning, when the NRC
13 first arrived, they wanted to observe everything. As far as
14 I could see they didn't take much part in the analysis or the
15 directing. They just wanted to watch. In the days after the
16 arrival of Mr. Denton they became more active in watching.
17 They required that we give them hourly readings in writing.

18 MR. FRAMPTON: Of major plant parameters?

19 WITNESS FREDERICK: Of many plant parameters.
20 Hundreds of plant parameters. And the readings became very
21 cumbersome. Almost impossible to deal with in the fact that
22 several NRC organizations all wanted copies and they wanted
23 them over the observation center and in the supervisor's
24 office and here and there. Every hour.

25 They shifted from watching what was going on to taking

1 an active role in confusing things by making it mandatory that
2 we produce readings that they could look at.

3 MR. FRAMPTON: When did this begin? Saturday? Sunday?
4 After that? Before?

5 WITNESS FREDERICK: It began to mount Saturday and
6 Sunday as far as what parameters were supposed to be
7 monitored. In the weeks following, the readings they were
8 taking continued to grow.

9 MR. FRAMPTON: Would you say as early as Saturday
10 and Sunday the NRC demands for information and the fact that it
11 had to go to more than one NRC source was detrimental to the
12 efficient operation of the plant?

13 WITNESS FREDERICK: I can't blame it all on NRC.
14 There were other organizations that began to see that as a
15 nice way to go. They all wanted readings. B&W wanted
16 readings. GPU wanted readings. Everybody wanted their own
17 set of readings so they could monitor this. But there was
18 never any feedback from this, at least on the operator level.
19 Okay, we have been analyzing all this. This is what you
20 should do now.

21 Still it was left with the shift supervisors and Met Ed
22 people to decide what to do next. They would decide and tell
23 NRC about it and it would be held up until somebody decided
24 either you can do that or just wait until something changes.
25 Normally the answer is don't change anything. Wait.

jeri 5 1 Which frustrated a lot of us in the fact we wanted to move on
2 to natural circulation or something that was more permanent.
3 And the pump back operation was delayed I feel by the NRC
4 until they were absolutely sure of what would happen.

5 Getting the waste gas decay tanks -- it was hooked up
6 within a few days after the accident but not used for many
7 days. That may be just the way I remember it. You can look
8 it up I guess. Primarily my interface with the NRC was giving
9 them readings which took up a great deal of the operator's
10 time.

11 As a matter of fact, there were three operators working on
12 it almost full-time during the first few weeks. Three
13 licensed operators.

14 MR. FRAMPTON: Did you feel the burden of these
15 requests for information, Mr. Zewe, or was this something a
16 matter of being laid on the operators' shoulders?

17 WITNESS ZEWE: Well, it became troublesome in the
18 control room in that it tied up the operators and caused an
19 awful lot of people to be transient through the control room
20 looking at parameters, looking over your shoulder, trying to
21 get data. I personally felt it more in the ensuing period
22 in trying to write special procedures for the evolutions we
23 wanted to conduct to go through the review chain.

24 It took days and days for NRR and NRC to review the changes
25 and bring back their comments and do this. It seemed like by

1 and large an awful lot of it really wasn't tremendously
2 constructive. It seemed like we couldn't do anything from
3 that point on. All procedures we had were void and anything
4 you wanted to do you had to rewrite a new procedure for.

5 We ended up writing all these procedures and recovery and
6 special procedures, some of which we really didn't need, nor
7 did we ever use.

8 It seemed like for a large part we did operate from one
9 crisis to another where we ran something as long as we could
10 and we had some alternatives but no initiative was taken
11 until a pump quit or something else happened where we were
12 forced into another area.

13 It seemed like we just fell from one pit into the next one
14 and not a great deal of forethought and planning. The answers
15 were there but it took so long to make sure that everybody
16 approved of it and to get that approval. But the burden was
17 clearly on the utility, on us, meaning Met Ed and GPU to come
18 up with the answers and come up with the procedures and they
19 were there by and large to audit, to make sure we followed
20 what we said and somewhere down the line they had more and
21 more and better input as they got more and more familiar with
22 the steps.

23 Their details and things they asked, there were a lot of
24 good inputs then. But I think that developed over some period
25 of time.

1 MR. FRAMPTON: I would like to move to another subject.
2 I would like to ask you a couple of questions about the
3 emergency feedwater block valves. The twelve valves. Had
4 these valves been found closed on previous occasions during
5 normal operation when they were supposed to be opened, to your
6 knowledge?

7 WITNESS ZEWE: No.

8 MR. FRAMPTON: Do you know of any indication they
9 were previously closed when they were not supposed to be,
10 Mr. Faust? That you can recall.

11 WITNESS FAUST: I feel like they have been. Not both
12 of them. But I don't even know if it was those valves in
13 particular as to just the emergency feed system having
14 something out of alignment in it. I can't place it now.
15 It was just like we would be starting out with maybe a start-up
16 procedure, since we didn't always start from zero and go up to
17 where the plant stopped at, it might have been overlooked that
18 way.

19 That is my problem with trying to remember. Yes, I think
20 I came across them like that. It was just noted.

21 MR. FRAMPTON: Would that have been noted in a log?

22 WITNESS FAUST: I don't know. I think it would have
23 been just informing the foreman at that time.

24 MR. FRAMPTON: Mr. Scheimann, do you recall any
25 occasions on which the valves had been closed or found closed?

jeri 7

6:p.m

6:p.m.

1 WITNESS SCHEIMANN: I physically haven't seen them
2 closed when they weren't supposed to be. As far as knowing
3 about it, if there had been, I can't recall any incident.

4 MR. FRAMPTON: You don't have a present recollection
5 as you sit here now of any occasion on which those valves
6 were closed or found closed when they were not supposed to
7 be?

8 WITNESS SCHEIMANN: Not to my recollection at the
9 moment.

10 MR. FRAMPTON: Mr. Frederick?

11 WITNESS FREDERICK: I don't recall a time when the
12 valves were shut when they weren't supposed to be.

13 MR. FRAMPTON: Could those valves have been used --
14 I guess I should ask Mr. Scheimann -- could those valves
15 have been used to delay emergency feed in a turbine trip
16 reactor trip?

17 WITNESS SCHEIMANN: In what way? Intentionally?
18 Somebody saying, hey, I will sabotage you by doing this?

19 MR. FRAMPTON: Not sabotage but for the purpose of
20 trying to prevent the primary system shrinkage and ES
21 actuation?

22 WITNESS SCHEIMANN: To that I would have to say no.
23 The valve line up for the system calls for those valves to
24 be open. I don't recall any place in our procedures that
25 tells you that you are permitted to close those valves for

jери 9

1 that reason.

2 MR. FRAMPTON: Do you know of any occasion on which
3 that had been done prior to the accident?

4 WITNESS SCHEIMANN: No.

5 MR. FRAMPTON: Mr. Frederick, do you?

6 WITNESS FREDERICK: No.

7 WITNESS FAUST: I don't either.

8 MR. FRAMPTON: Mr. Zewe, do you have any knowledge
9 of how those valves got closed or came to be closed in the
10 case of this accident?

11 WITNESS ZEWE: I have no idea at this point, no.
12 From hearing previous testimony, I don't have any idea.

13 MR. FRAMPTON: Mr. Scheimann?

14 WITNESS SCHEIMANN: Likewise no.

15 WITNESS FREDERICK: No, sir, I don't know how they
16 were shut.

17 WITNESS FAUST: No.

18 MR. FRAMPTON: I know you have been asked these
19 questions before but we are on the record and you are under
20 oath and I thought it's important to ask them again.

21 Ron Haynes, I think you have two topics that you want
22 to take up. Why don't you go ahead.

23 MR. HAYNES: Mr. Zewe, I would like to talk a bit
24 about the discontinued use of the atmospheric relief valves
25 on the afternoon of March 28. I believe the previous testimony

jeri 10
1 has shown that these valves were closed about 1:15 in the
2 afternoon. Why were the valves closed at that time?

3 WITNESS ZEWE: I was instructed by senior management
4 to shut the valve. I didn't agree with it but I shut the valve.

5 MR. HAYNES: Who was that who instructed you?

6 WITNESS ZEWE: Gary Merrill did. He was instructed
7 by his upper managment to shut it.

8 MR. HAYNES: Who would that be?

9 WITNESS ZEWE: Jack Herbein is as far as I can go,
10 the vice president, instructed Mr. Merrill, who instructed me
11 to shut it.

12 MR. HAYNES: Do you know where Mr. Herbein was at
13 that time?

14 WITNESS ZEWE: At that particular time I believe he
15 was at the observation center.

16 MR. HAYNES: Did you receive directions from
17 Mr. Herbein or other personnel at the observation center to
18 perform particular operations at the facility other than this
19 one event?

20 WITNESS ZEWE: That day all the direction came from
21 Mr. Merrill or through Mr. Ross to me or from Mr. Merrill to
22 me directly. I received no direct communications from off-
23 site. Other days, I had. The ensuing several weeks, I had
24 taken direct communications and orders directly from the
25 observation center. Mainly Mr. Herbein.

1 MR. HAYNES: In these ensuing days, was this the
2 Thursday, Friday or Saturday immediately after the accident
3 or when? When was it?

4 WITNESS ZEWE: More like the following Monday,
5 Tuesday, Wednesday, sort of deal.

6 MR. HAYNES: What kind of instructions were they
7 Mr. Herbein gave you?

8 WITNESS ZEWE: It depended on the situation. He
9 would call in by radio or by phone and give some direction
10 that he had for that particular situation that we were in
11 at that time. Whether it was part of the natural circulation
12 or what have you, venting off the hydrogen bubble or what have
13 you. It varied as time went on.

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. HAYNES: I believe you stated earlier that there
2 was a command organization in place during the days immediately
3 after the accident that included, I believe, Mr. Miller
4 and Seelinger trading off, 12 on 12 off, this type of thing
5 and Mr. Floyd and Mr. Ross; is that right?

6 Was that the sort of chain of command?

7 WITNESS ZEWE: Yes.

8 MR. HAYNES: Were these orders from the observation
9 center coming directly to you going around those people?

10 WITNESS ZEWE: Directly to them at that time.

11 MR. HAYNES: And what did they do? They passed it on
12 down to you?

13 WITNESS ZEWE: Yes.

14 MR. HAYNES: So Mr. Harbin was not directing you
15 specifically? It was through the chain of command?

16 WITNESS ZEWE: There were days after the accident
17 where he addressed me personally with a direction. I don't
18 believe that he bypassed the other group. In some cases Mr.
19 Miller handed me the phone to talk to directly to Jack. He
20 had already related to Gary that he wanted Mr. Harbin to relate
21 it to me directly. Just to save representing it back.

22 MR. HAYNES: Has that been a normal practice during
23 plant operation, for you to receive directions directly from
24 the vice president of generation?

25 WITNESS ZEWE: I have on many occasions, yes.

1 MR. HAYNES: Is that one method of the way Mr.
2 Harbin operates?

3 WITNESS ZEWE: Well, Mr. Harbin was assistant
4 superintendent and superintendent and station manager and
5 operations nuclear and he is very familiar with us and very
6 familiar with the plant. And we have often taken directions
7 directly from him at his varying capacities.

8 MR. HAYNES: All right. Back to the atmospheric
9 relief valves. When they were closed at that time, I
10 understand that was your heat sink; is that correct?

11 WITNESS ZEWE: That was our only heat sink. The B
12 steam generator was completely bottled up, isolated both steam
13 and feed. We were steaming the A generator out to the atmos-
14 pheric dumps because we didn't have vacuum in the main
15 condenser.

16 MR. HAYNES: How long before you reestablished vacuum
17 in the main condenser?

18 WITNESS ZEWE: I am not sure, but it was 3:00 or
19 4:00 in the afternoon I believe.

20 MR. HAYNES: You were without a heat sink for up to
21 three hours, something like that?

22 WITNESS ZEWE: I would say so. I really don't
23 remember the exact time, but I am certain it was a couple
24 hours.

25 MR. HAYNES: What were your instructions, if any, for

1 reestablishing flow through the atmospheric relief valves
2 in the event you needed it? Say that suddenly you got
3 natural circulation reestablished in the A loop. But the
4 condenser vacuum wasn't available.

5 WITNESS ZEWE: My instructions were not to use it
6 at all, with no other leeway at that point. It was my
7 interpretation from asking Mr. Miller that the state government
8 had instructed us to shut the valve. It was really their
9 decision in ordering us to have it shut. We were merely
10 complying with them. Not that it was in our best interest
11 to do that.

12 I mean from a plant standpoint. I felt it was totally
13 acceptable to do that.

14 MR. HAYNES: Why do you feel it was totally acceptable
15 to use atmospheric relief valves?

16 WITNESS ZEWE: The State was worried about any
17 release of radioactivity in the steam that would be released
18 to the atmosphere. We had no reason to believe we were
19 releasing anything and we had also had an operator at the
20 valve itself where it was discharging dew into the atmosphere
21 with a hand-held instrument checking for any sign of
22 radiation.

23 We had none on our installed instruments for that
24 generator. We didn't have any at the final discharging point
25 of the operator on the roof holding it right by the steam

1 being passed to the atmosphere. We had no indications at all
2 that that steam in any way was contaminated.

3 MR. HAYNES: Did you do any chemistry tests on the
4 water in the steam generator?

5 WITNESS ZEWE: We sampled on water in the A and B
6 steam generator and the generator A didn't show signs of
7 contamination. B did. The first samples that we had all
8 showed the A was contaminated and B was not.

9 We found there was an error. They confused the samples.
10 We subsequently rectified that and drew another sample and
11 confirmed there was no activity there. We had the sample of
12 the water.

13 The other monitors showed that initially we only had a
14 primary-secondary leak in one generator and we were monitor-
15 ing the steam locally at the final exit point. That proved
16 to me without a doubt we didn't have a problem.

17 MR. HAYNES: At this time you still had high
18 pressure injection going into the reactor coolant system.
19 I believe the data shows you possibly got a bubble shift out
20 of the A loop somewhere during this time. There was some
21 heat transfer to the A steam generator.

22 Do you recall that?

23 WITNESS ZEWE: In vague terms, yes. I don't recall
24 if that coincided when I shut the atmospheric relief valves
25 or not.

1 MR. HAYNES: Subsequent to that?

2 WITNESS ZEWE: I didn't correlate that with that
3 indication. I didn't have the time frame there to correlate
4 it. It very well may be.

5 MR. HAYNES: I am not saying it was related to shutting
6 the atmospheric dump valve.

7 I am saying it occurred about two hours after the
8 atmospheric dump valves were closed, but about an hour before
9 the condenser vacuum was reestablished, which would give
10 you the --

11 WITNESS ZEWE: Okay, well that is a fact from the
12 time frame and that is how it was, I guess.

13 MR. HAYNES: Let's say that the natural circulation
14 through the A loop would have stayed or would have taken,
15 would have kept the natural circulation, that would start
16 transferring heat from the core to the water and steam
17 generator which in turn would heat up and be able to remove
18 heat from the core; is that correct?

19 WITNESS ZEWE: It should have, yes.

20 MR. HAYNES: What would you have done if that would
21 have occurred and you needed to get the heat -- get a heat
22 sink reestablished?

23 WITNESS ZEWE: I would have shut the valve like I
24 was directed to do, but I would have certainly, if it had
25 changed the parameters any, gotten right back through Mr.

1 Miller and back to Mr. Harbin. It would have been imperative
2 we would have reestablishing steaming on that generator and
3 it would have been his decision at that point.

4 I got the impression at that point, because I did try
5 to argue with Mr. Miller on a -- not really arguing but
6 discuss my concerns that it is ridiculous to do that and we
7 were advised to shut it in no uncertain terms.

8 MR. HAYNES: During this time Mr. Harbin and Mr.
9 Miller were in transit and also at the governor's office or
10 lieutenant governor's office; is that correct? To your
11 recollection?

12 WITNESS ZEWE: I was instructed to shut the valve
13 before Mr. Miller left.

14 MR. HAYNES: But then he left to go to the state
15 house; is that correct?

16 WITNESS ZEWE: He did leave, yes.

17 MR. HAYNES: Did you have a way to contact him?

18 WITNESS ZEWE: They took a beeper with them and
19 also a walkie-talkie, but as soon as they arrived in Harrisburg,
20 they established phone communications from the lieutenant
21 governor's office to the control room.

22 MR. HAYNES: So in fact the natural circulation had
23 taken in the A loop, you had to wait to notify Mr. Miller and
24 Mr. Harbin of that to get the decision changed to get the
25 atmospheric relief valves back in operation if you needed them;

jc 7

1 is that correct?

2 WITNESS ZEWE: I could have, yes.

3 MR. HAYNES: That is speculation, of course. It
4 didn't happen. I wanted to see what the decision would have
5 been or what your approach would have been to that problem.

6 WITNESS ZEWE: I would have certainly related to
7 them, but it would have still been their final decision
8 because I was still taking their directions.

9 MR. HAYNES: What do you feel about that type of
10 direction since you have the license and you were the one
11 that had the license for the safe operation of the facility?

12 WITNESS ZEWE: If I felt it would really do a
13 tremendous amount of harm, I would not hesitate to go
14 against any other direction, whether it be from NRC or my
15 own corporate management.

16 I felt that closing it would not affect it a great deal.
17 I didn't think it was necessary, nor would I have chosen
18 to do it if I had my own decisions. Whether the governor wanted
19 it or not or whoever it was that ultimately told us to shut
20 it. But if it would have placed the plant in real danger,
21 I would have certainly gone against it if I felt in my own
22 estimation that that was the best thing to do. I wouldn't
23 have hesitated in that.

24 MR. HAYNES: Now let's flip over to a new subject.

25 This has to do with the diesel generator automatic start system

jc 8

1 and the core flood tanks during the course of the accident.

2 You had a chance to -- I believe you testified earlier
3 to the I&E investigation report. In that report it states
4 that early in the event that the automatic start system on
5 the diesel generator was placed out of service and also
6 that the core flood tank valves were isolated early in the
7 course of the accident. Are you aware?

8 WITNESS ZEWE: I read that, yes.

9 MR. HAYNES: Do you agree with that? With the
10 systems placed out of service on your shift?

11 WITNESS ZEWE: The diesel generators, as far as I
12 can remember, ran for at least 30 minutes just sitting there
13 running unloaded before we had an auxiliary operator go
14 down to shut them down locally. At that point I assumed
15 they were in auto-standby. Only from interviews that I
16 had later on with the operators involved, did I know that they
17 weren't available.

18 MR. HAYNES: So your intent was not to place the
19 auto-start feature of the diesel generator out of service;
20 is that correct?

21 WITNESS ZEWE: My intent was not to do that
22 specifically, no. My intent was to shut down the diesels to
23 save them from just sitting there at 900 RPM unloaded, but I
24 really didn't concern myself with the diesels after that
25 because I didn't need them. But I felt they were available

jc 9

1 for use if I didn't need them.

2 MR. HAYNES: And that they would have automatically
3 started and loaded on the bus if needed?

4 WITNESS ZEWE: I made that assumption, yes.

5 MR. HAYNES: You say later you found out that the
6 automatic start feature was placed out of service in your
7 interview with the operator; is that right?

8 WITNESS ZEWE: This was on the order of two months
9 later or so when I was approached repeatedly by two of the
10 I&E inspectors saying that did you know the diesels were
11 inoperable? I said no, they were operable. They said they
12 had testimony from the sequence of the events from the
13 computer and so forth dealing with the air compressors, if
14 the diesel had started, the air compressors should have come
15 on to restore the pressures and so forth. And then they had
16 an interview of one of the auxiliary operators that went
17 down there to secure the diesels and from that interview and
18 from my interviews with a few of the operators, which is months
19 later, that they very well could have been disabled from the
20 automatic start feature.

21 MR. HAYNES: Did you ever get a chance to talk to
22 the operator yourself?

23 WITNESS ZEWE: I did ask who the operator was that
24 did it and his mind was somewhat vague on who he talked to
25 and why he placed the diesels in a certain condition. But

1 one thing that I have tried to do is I have not really tried
2 to talk to a lot of people in their involvement. I have
3 tried to keep my own mind as clear and uncluttered as I
4 can for the whole evolution. I let the investigative part
5 up to other people.

6 MR. HAYNES: Mr. Zewe, I understand that the
7 automatic start feature was placed back in service a little
8 bit later on on the 28th. I believe that morning or so.
9 Is that your understanding?

10 WITNESS ZEWE: From what I recall, it was placed back
11 on automatic somewhere mid-morning, yes.

12 MR. HAYNES: You didn't know at that time that it
13 had been placed back in service?

14 WITNESS ZEWE: I didn't know that.

15 MR. HAYNES: Were you aware of this evolution?

16 WITNESS SCHEIMANN: No, I wasn't.

17 MR. HAYNES: Mr. Faust?

18 WITNESS FAUST: I am aware vaguely that morning we had
19 the diesel coming on. Vaguely. I will tell you what I
20 remember is that the diesel did come on initially and ran.
21 We sent an operator down to shut it down. We had another ES
22 actuation where the diesel came back up on line again. It
23 was going to be a problem with the diesel coming on every
24 time we had an ES actuation and I don't know who said it, but
25 somebody said put that thing so it won't come back on right now.

jc 11

1 If we need it we will turn it on. That is not the
2 exact words. I am just saying it was along that line. It
3 was becoming an annoyance or something else we had to take
4 care of on top of what we were doing.

5 It was along those lines that it was probably taken and
6 put out so it wouldn't automatically respond to an ES
7 actuation. I don't know who directed the operator to do that
8 or who did it.

9 WITNESS FREDERICK: May I ask by what method the
10 diesel was rendered inoperable?

11 MR. HAYNES: My reading of the report -- you have
12 not had a chance to read the report?

13 WITNESS FREDERICK: No.

14 MR. HAYNES: My understanding of the report is the
15 fuel rack was blocked out.

16 WITNESS FAUST: Not reset.

17 MR. HAYNES: Therefore, it 'couldn't rack in for a
18 fast start. Is that your understanding of it?

19 WITNESS FAUST: No. I thought it was from the
20 control room that somebody went through the exercise position
21 and switch. All the operator would have to do to put it back
22 in ES position or start it manually himself.

23 MR. HAYNES: That is -- that is your understanding?

24 WITNESS FREDERICK: That is my understanding.

25 MR. HAYNES: Okay.

1 WITNESS FREDERICK: That the diesel was lined up for
2 ES actuation but placed in maintenance exercise so it would
3 not start unless you put the switch on ES which is a control
4 room function.

5 MR. HAYNES: That is your recollection or what you
6 heard?

7 WITNESS FREDERICK: What I heard, yes. I was not
8 aware of the status during the day, but that was related to
9 me by the operators.

10 WITNESS FAUST: Part of what I am saying is probably
11 pieced in but I remember the diesel giving us a problem.
12 Something was set to keep it from coming on automatically.
13 So I guess partially I might have assumed it was done from
14 within the control room.

end19

15

16

17

18

19

20

21

22

23

24

25

1 MR. HAYNES: It is my understanding, and it is in the
2 report, that it was later in the morning that the fuel rack
3 was put back in position and the switch was placed in the
4 exercise position in the control room so in the event there was
5 a loss of off-site power the operator could take action in the
6 control room and get the unit back on line. That was a second
7 step.

8 MR. FRAMPTON: Let me ask one or two questions about
9 that.

10 When the diesel is running, do you have to send an auxiliary
11 operator down to turn it off?

12 WITNESS FAUST: Yes. In ES. If it starts on ES
13 single we have to go locally to shut it off. The problem with
14 it running like that for no reason unloaded is it does carbon
15 up. We don't know at what point we might end up with a fire
16 in the stack on that because of the carbon buildup in it.

17 It is stupid to let it run. It is there for your function.
18 It is foolish to let it run. Put it that way.

19 MR. FRAMPTON: When the auxiliary operator goes to
20 turn it off at the site of the diesel, does he have to do
21 something additional affirmative to disable it from being
22 reactivated by another ES actuation?

23 WITNESS ZEWE: In order for him to stop the diesel
24 after this, he has to trip the fuel rack. Then he must set
25 the fuel racks after that to put it back.

1 MR. FRAMPTON: If he does nothing more than trip
2 the fuel racks, then the diesel is in a condition that it will
3 not automatically restart on another ES actuation; is that
4 right?

5 WITNESS ZEWE: It won't start anyway. Not manually
6 or from the control room.

7 MR. FRAMPTON: In order to reset it he has to not
8 only turn it off but reset the fuel rack into it; is that
9 correct?

10 WITNESS ZEWE: Right.

11 MR. FRAMPTON: So if you wanted to, from the control
12 room, to set it up so that it was ready, available for
13 another ES actuation down in the plant but it would not
14 actually respond, you would have to instruct the operator to
15 completely reset it and then in the control room you would have
16 to put the switch on to test, on to exercise; is that right?

17 WITNESS ZEWE: Yes.

18 WITNESS FREDERICK: That is not a common practice,
19 but it was through the in-depth knowledge the operators had
20 they could reason that out and say they could prevent unneeded
21 wear on the machine by using that position of the switch.
22 It was not the intent of the switch.

23 MR. FRAMPTON: Do you know when the diesel came on
24 the second time and it appeared it would keep coming on that
25 instructions were affirmatively given to an auxiliary operator

1 to reset it in the plant or whether that operator was told to
2 turn it off so it wouldn't come on, Mr. Faust?

3 WITNESS FAUST: That I can't answer.

4 MR. FRAMPTON: Do you know who gave that instruction?

5 WITNESS FAUST: I am saying that was one over
6 those just hearing -- I was over near that side during that
7 period and I remember hearing that.

8 MR. FRAMPTON: Mr. Frederick, do you know who passed
9 that on down the line?

10 WITNESS FREDERICK: No, sir.

11 MR. HAYNES: Mr. Scheimann, do you?

12 WITNESS SCHEIMANN: No.

13 MR. CUNNINGHAM: One more related question. If the
14 diesels had been racked, and the fuel racks had been tripped
15 electrically, and you found that you had a need for the
16 diesels to start, how long would you estimate it would take to
17 send somebody to the diesels and reset it and start it?

18 WITNESS ZEWE: Five minutes.

19 MR. HAYNES: I assume if that occurred, the whole
20 building would have been dark; is that correct? Or would
21 there have been lighted passageways from DC lighting system to
22 show the way to the diesel generator?

23 WITNESS FAUST: There was a flashlight. The operator
24 carries a flashlight with him anyway. But there is a certain
25 amount of lighting, I believe.

jon4

1 WITNESS ZEWE: Diesel generators are approached from
2 outside anyway. From outside into the diesel generator
3 building themselves.

4 MR. HAYNES: With respect to the core flood tanks,
5 the statement is made the core flood tanks were isolated early
6 on in the course of the accident. Do you have any recollection
7 of that, Mr. Zewe?

8 WITNESS ZEWE: I don't. It is only in talking again
9 with another person who was there that night a couple of months
10 afterwards that I learned that that may have happened, but I
11 was totally unaware of it at the time.

12 MR. HAYNES: Do you believe that these valves were
13 closed at a time that I guess they were supposed to be open
14 according to the tech specs?

15 WITNESS ZEWE: I can't think of any reason why we
16 would shut them or attempt to shut them at this point in time,
17 but I believe if the man says he deliberately went and shut
18 them, that he shut them.

19 MR. HAYNES: These tanks were later floated on to the
20 system early or in the middle of the afternoon on the 28th.
21 If that is the case, if those valves had been blocked out,
22 wouldn't someone have to go down to the breakers and
23 reestablish the power to them?

24 WITNESS ZEWE: Yes. Plus someone would have to go
25 and reopen the valves from the control room too, using the

1 Operators.

2 I have not yet heard testimony or otherwise that anyone
3 ever did that.

4 MR. HAYNES: How many people were operating controls
5 in the control room on the 28th?

6 WITNESS ZEWE: The only ones that I know of that
7 should have or could have operated anything were the four
8 of us or Ken Bryan. The other shift supervisor.

9 WITNESS FREDERICK: During the entire day?

10 WITNESS ZEWE: That's early on.

11 MR. HAYNES: I am talking about the time the core
12 flood tanks were floated on to the system which I recall was
13 about mid-afternoon.

14 WITNESS ZEWE: Then there were several other people
15 that would operate it. There was at least two full crews that
16 were there or more people available who could have been
17 directed to operate the valves.

18 MR. HAYNES: Who was in charge of the control room
19 at that time when the decision was made to depressurize and
20 float the core flood tanks?

21 WITNESS ZEWE: Mike Ross was there.

22 MR. HAYNES: Was he issuing orders directly to
23 operators?

24 WITNESS ZEWE: The chain of command that day was
25 Mr. Miller to Mr. Ross to me to the operators.

jon6

1 MR. HAYNES: Do you recollect telling any operator to
2 open up the valves on the core flood decks?

3 WITNESS ZEWE: I don't. The valves were open, as I
4 recall. We didn't have to reopen the valves. We had
5 discussed closing the valves during that same period because
6 I had suggested, which Mr. Scheimann had said before, that I
7 thought it might be better to try to depressurize below 600
8 pounds and keep the core flood valves shut and let a PD
9 develop between core flood and reactor coolant system and
10 surge the core flood tanks.

11 That is when I had the first idea of closing the breaker,
12 is we could operate from the control room. The only time that
13 day I addressed that, other than actually not doing that, just
14 letting them come in gradually as we tried to reduce pressure.

15 MR. HAYNES: These core flood tank valves may be
16 closed to isolate these tanks according to a certain pressure
17 on the reactor; is that correct?

18 WITNESS ZEWE: That is true. At approximately 700
19 pounds you would isolate it on a normal plant. Cool down
20 pressure reduction so you didn't empty the contents into the
21 reactor coolant system.

22 MR. HAYNES: You were in the control room that day
23 on the 28th, Mr. Scheimann. Do you recall the valves being
24 closed or having to be reopened to float the --

25 WITNESS SCHEIMANN: No, I don't. To my knowledge,

1 those valves were open during the whole course of the time. The
2 only thing I knew of concerning those valves was at the time
3 Mr. Zewe was walking about, we did have the breakers closed.

4 The normal condition of the breakers was to be open. In
5 that case the valves themselves would be open, but the
6 breakers closed. There would be no way of closing the valves.
7 However, in anticipation of coming down and attempting to
8 close the valves just prior to a sudden surge into the vessel,
9 I had had the breakers closed.

10 But to my knowledge, the valves were never closed.

11 MR. HAYNES: So the breakers were closed in
12 preparation of closing the valves from the control room switch
13 if you wanted to?

14 WITNESS SCHEIMANN: Yes. As to valves, to my
15 knowledge, they were never closed.

16 MR. HAYNES: The fact that the breakers were closed
17 in preparation for closing the valves, did you view that as a
18 problem, Mr. Scheimann?

19 WITNESS SCHEIMANN: No.

20 WITNESS ZEWE: No. The first time that I had heard
21 the core flood valves were shut and reopened and so forth, I
22 thought that there was confusion relating to the time that that
23 occurred.

24 I am referring here to when we made the depressurization
25 attempt, which was early afternoon. But the time the I&E

1 inspector rela' d to me was when the core flood valves were
2 shut early into the accident, before 7:00 o'clock, somewhere
3 between 5:00 and 6:00 o'clock is when he said he had found
4 out that they had been shut.

5 For that time period there I said no, it should not have
6 happened at all. It was later on in the day. But I have
7 talked with the operator who posed the valves the first time
8 and he went to the valves for the control center to close the
9 power supplies and he was not wearing a respirator. He was
10 not in special clothing, meaning it was done before the site
11 emergency was declared. It had to be done before 7:00
12 o'clock.

13 MR. HAYNES: At that time breakers were closed or
14 what?

15 WITNESS ZEWE: That the breakers were closed by the
16 auxiliary operator to provide power to it. He was not the
17 one that said the valves were closed from the control room.

18 WITNESS FAUST: That is where I am saying I
19 remember something, once again, and it was in anticipation --
20 it was early into the accident when we were actually
21 anticipating future event of cooling down. This was before
22 we started getting longer.

23 I think that is when they said why not close the breakers
24 now just so we close the valves as we need to as we cool them
25 later on.

1 MR. HAYNES: The normal shutdown procedure, if you are
2 planning on going down to the delay heat removal system, would
3 be to close the breakers first. As reactor pressures comes
4 below 700 psi, close out the tank valves; is that correct?

5 WITNESS ZEWE: That's right. But the fact is that
6 just closing the power supply to the breaker wouldn't have
7 altered anything but it is physically closing the valves is
8 the real question.

9 MR. HAYNES: Are you satisfied in your mind that
10 the valves were closed that morning or not from what you have
11 learned since?

12 WITNESS ZEWE: Talking to the man who says he
13 thinks he closed them, and he is pretty sure he closed them
14 in those words, I think I did. I am pretty sure I did. But I
15 couldn't say positively. But I would have to say he did.

16 MR. HAYNES: Who is the man?

17 WITNESS ZEWE: Ken Bryan.

18 MR. HAYNES: Okay.

19 WITNESS ZEWE: This was also a conversation that I
20 had that was at least 60 days after the accident. Once I
21 learned from the INC guy that that happened, he said that he
22 had testimony to support that, but he wouldn't tell me who, so
23 I went asking around to try to find out who it was.

24 MR. HAYNES: When you heard this from the I&E man,
25 inspection and enforcement inspector, this was about two

1 months after the accident he learned about it?

2 WITNESS ZEWE: I would say the time frame of month
3 and a half to two months that he related it to me that I can
4 remember as far as a time period goes, yes.

5 It wasn't, you know, hours or even days or just one or two
6 weeks later. It was in the order of a month and a half to two
7 months that he first related it to me.

8 The first time he questioned me, I believe he questioned me
9 and Fred together in the control room. I said, you know,
10 something is just screwed up. There is no way I did that. I
11 don't know where you are getting your information from. I
12 never did that. There is no reason for me to do that. So
13 he said, well, he would check further and then he brought it
14 up two or three other times and I said well, where did you get
15 that information. He wouldn't say that other than that he had
16 verbal testimony to that effect.

17 MR. HAYNES: So you issued no order to close the
18 valves early in the accident.

19 WITNESS ZEWE: No, I didn't.

20 MR. HAYNES: You issued no such order.

21 WITNESS SCHEIMANN: No. I had directed somebody to
22 close the breakers, but being unaware that -- quotes unquote --
23 they were supposedly shut already.

24 MR. HAYNES: All right.

25 MR. FRAMPTON: One more question that I omitted to

1 ask you. Mr. Zewe, were you aware on March 28 of the pressure
2 spike in the containment building?

3 WITNESS ZEWE: Yes.

4 MR. FRAMPTON: What did you learn or what were you
5 told about the magnitude of it?

6 WITNESS ZEWE: Waht I was told about the magnitude
7 of it? I seen the magnitude of it. I probably seen it first
8 because I was directly in front of the RB pressure indicator and
9 I was directing the evolution we were doing for depressurizing
10 and Mr. Scheimann was operating the electromagnetic lock
11 valve, opening it up to reduce pressure, and I was trying to
12 have him open it up at a point where we would not have another
13 four point engineering safety feature actuation, so I was
14 picking the point where the RB pressure was rather low so he
15 could vent and we wouldn't have another actuation on four pound
16 pressure.

17 As soon as I said all right, open it, Fred and I was right
18 in front of the recorder. As soon as he hit it, I was
19 watching it the whole time. Up and down. I stepped back.
20 Everybody there did because it was -- you know, I said did you
21 see that. Yes. Wonder what that was.

22 We looked at Lynn Wright, one of the control room operators
23 said the building spray pumps were on which were about six feet
24 to my left. So we -- and then we waited a few minutes and then
25 we looked at everything and everything looked normal.

1 The pressure returned immediately to zero as fast as it
2 appeared. And we secured the building spray pumps since the
3 pressure was down and they were no longer needed. We didn't
4 see any other effect of it. We didn't know what it was. We
5 had a limited discussion on what sort of electrical transient
6 or instrument malfunction could give us that pressure spike.
7 No one had any really good ideas or answers. And we went on
8 with the evolution at hand at that point.

9 MR. FRAMPTON: When you say "we" discussed this, how
10 many people were in the control room at that time in total?

11 WITNESS ZEWE: I don't know, but I would think in
12 the neighborhood of 25 people. There were three shift
13 supervisors there. Myself, Joe Chwastyk and Bryan were there.
14 There were operators there. Two different sets of operators.
15 NRC inspectors there. Mr. Miller and Mr. Ross were there.

16 MR. FRAMPTON: Was there -- this was after
17 Mr. Miller came back from the Lt. Governor's office?

18 WITNESS ZEWE: Prior to him leaving.

19 MR. FRAMPTON: Before he left?

20 WITNESS ZEWE: Yes.

21 MR. FRAMPTON: Do you recall discussing the spike
22 with Mr. Miller specifically?

23 WITNESS ZEWE: I don't. I heard his comments later
24 saying he heard a thud. He hadn't witnessed the spike, but
25 heard the thud and had reported that to Mr. Ross, and he had

1 attributed that to maybe a ventilation change in the control
2 tower.

3 MR. FRAMPTON: Do you recall discussing the pressure
4 spike with Mr. Ross?

5 WITNESS ZEWE: Yes.

6 MR. FRAMPTON: How about Mr. Kunder? Was he there?

7 WITNESS ZEWE: I didn't discuss it with Mr. Kunder
8 directly. The discussions mainly were between myself and
9 Mr. Chwastyk and Mr. Ross. What was it sort of thing. We
10 sort of concluded it was some sort of electrical transient.
11 It was just unexplainable to us.

12 MR. FRAMPTON: You reached a tentative conclusion,
13 if any conclusion, that it was an instrument malfunction in
14 effect?

15 WITNESS ZEWE: Or some electrical spike that caused
16 a malfunction. Not really --

17 MR. FRAMPTON: Not a true indication of increased
18 pressure, in other words?

19 WITNESS ZEWE: Yes. We hadn't perceived we had
20 hydrogen at all in the building. We didn't perceive we had
21 temperatures to create any hydrogen. All our training as far
22 as hydrogen in the reactor building goes is that sometime
23 after the event, in the order of days and weeks, you build up
24 hydrogen in the reactor building from the reaction with the
25 aluminum in the building. It is a long-term type effect, not

1 an immediate type.

2 MR. FRAMPTON: Do you recall whether Mr. Ross said
3 anything about whether he was going to relate this to Mr. Miller
4 or anyone else in the chain of command?

5 WITNESS ZEWE: I would not see why not, but he
6 didn't relate to me I am going to go and call Mr. Herbein
7 about this right away or something of that nature.

8 I don't see how anyone in the control room at that time
9 would be aware of it. I find that very hard to believe. I
10 remember just backing up right after it happened and literally
11 stepping on two or three other people's shoes because I was in
12 a hurry to back up to look at it. Actually stepped on one of
13 the NRR guy's shoes, as I remember, too.

14 MR. FRAMPTON: Do you recall whether any NRC people
15 were in on any discussions about what it was?

16 WITNESS ZEWE: I don't, no. They were there
17 observing the same sort of thing that I observed that was
18 available. I didn't specifically sit down and talk to them
19 about it. Like I stated before, my interface with them there
20 was very limited. I didn't ask anything of them and they
21 certainly didn't come forth with anything.

22 I just went on with what I had to do and what I was directed
23 to do and the observations were there to be observed.

24

25
Ace-Reporter, Inc.

CR6978
#21
rl
LRW

1 MR. FRAMPTON: Was there any discussion of whether
2 the fact that there was a thud in the building was inconsistent
3 with the possibility this was just a stray electrical pulse
4 of some kind?

5 WITNESS ZEWE: I had personally not heard any
6 this nor did Mr. Miller relate to me or anyone else he had
7 heard anything. I learned this from testimony at the Udall
8 Commission in Washington for the first time that he heard
9 anything and had questioned that he heard something. I
10 hadn't heard it before.

11 MR. FRAMPTON: Your jumping back was not from
12 anything other than seeing the spinning on the instrument?

13 WITNESS ZEWE: Yes. I was probably 10 inches
14 from the record looking at it very closely. This spiked up,
15 I stepped back, a natural reaction. Nor from any noise or
16 anything else. I found it so hard to believe that anyone
17 who was in the control room observing anything would have
18 missed that or turning off the pumps or any of the
19 discussions at all.

20 MR. FRAMPTON: When you say missed it, you mean
21 missed the discussion that ensued.

22 WITNESS ZEWE: Or missed what was -- that the
23 spike had happened or that we secured two building spray
24 pumps because of it. We actually had ES actuation because
25 of that, too. On high pressure you had isolation again so the

rlp 2
LRW
1 spray pumps were on and everything else went to ES position.

2 MR. FRAMPTON: When you say missed that, you mean
3 missed the flurry of activity caused by that?

4 WITNESS ZEWE: Yes. I'm observing something.
5 Even if I didn't see the spike, I see a flurry of activity
6 and say what was that? I don't see that --

7 MR. HAYNES: On the pressure spike, I believe
8 4 psi you get containment isolation?

9 WITNESS ZEWE: That's correct.

10 MR. HAYNES: 28 psi is the trip point for the
11 building spray system?

12 WITNESS ZEWE: 30 or less is the set point.

13 MR. HAYNES: I believe the pressure peak was
14 28 psi as indicated on the chart and the building spray
15 system came on?

16 WITNESS ZEWE: True.

17 MR. HAYNES: Are you aware in the control room
18 logs, I believe you have the chief foreman's log and also
19 the operator's log, the pressure peak is not recorded in those
20 logs?

21 WITNESS SCHEIMANN: May I comment as far as that
22 is concerned? You have four people in that control room.
23 You have a piece of mess going on in front of you. There is
24 no way in hell you got time to take and worry about inking
25 an entry in your log.

rlp 3
LRW

1 WITNESS ZEWE: We had log takers at that point.
2 Like you mentioned before, Mr. Berry was taking logs, so
3 to speak, on timed events and writing down the sequence of
4 events. We relied on him and the other people that were
5 taking time sequence type data. It wouldn't surprise me at
6 all we didn't write it down in the book.

7 MR. HAYNES: That's correct about Mr. Berry's
8 notes showing that he was taking data in the afternoon of
9 the 28th and that also he made the late entry in the control
10 room perator's log, I believe it is. You have a foreman's
11 log and you also have an operator's log. And there is a
12 late entry in that where he notes the four psi and then the
13 securing of the spray system. So I would say from that,
14 what would you deduce from that? That Mr. Berry was not
15 aware of the spike also?

16 WITNESS ZEWE: Either that or like the rest of us,
17 he failed to grasp the significance of it. Greater than
18 four pounds was greater than four pounds. I don't know if
19 he was -- since it was there and gone, not thinking that it
20 was significant, maybe it didn't make any difference. Maybe
21 the most important thing to him was we had an actuation of an
22 ES system. Mr. Berry has a very long experience in the nuclear
23 power field and I think that he, too, also just thought the
24 ES at that time was the most important thing and the spike
25 was inconsequential to the event, so he elected not to write

Ace-Federal Reporters, Inc.

rlp 4
LRW

1 about it. I guess. I can only surmise. He was behind the
2 panel looking at all the operations and everything that was
3 done and said and watching the clock. I'm sure he was aware of
4 it.

5 MR. HAYNES: The control room operator's log
6 entry for that day is four to four and a half psi spike.
7 The shift foreman's entry for that afternoon also said there
8 is about four and a half to five psi pressure in the contain-
9 ment. Do you know why the two apparently independent logs
10 would have the same value recorded and ignore the 28 psi
11 spike? You're shaking your head, Mr. Frederick. Do you
12 know why?

13 WITNESS FREDERICK: First it's two questions.
14 The narrow range instrument showed a spike as well as
15 the wide range instrument.

16 MR. HAYNES: I understand it did. It goes up
17 to 10 psi. I understand that was at full scale?

18 WITNESS FREDERICK: Why did they write down four
19 instead of 10?

20 MR. HAYNES: Four instead of 28.

21 WITNESS FREDERICK: Just the same logic as
22 the thermocouple readings. If you have 150 readings that
23 say four pounds and one that says 29, which do you consider
24 is correct?

25 MR. HAYNES: I understand one reading was on a

rlp 5
LRW
1 10 psi scale that went full scale. Another went up to 26.

2 That's not inconsistent, is it?

3 WITNESS FREDERICK: It seemed to everybody in
4 the control room, whether they were NRC or GPU or B & W, they
5 call came to the same conclusion, that there wasn't anything
6 aprticularly significant about that spike.

7 MR. HAYNES: That it was not due to a pressure
8 spike. It was due to electronic signal or transient. Electri-
9 cal transient.

10 WITNESS ZEWE: Some sort of transient that we would
11 investigate through the electrical department to see what
12 sort of interaction would case that.

13 MR. HAYNES: That was your evaluation?

14 WITNESS ZEWE: Sure.

15 WITNESS FREDERICK: What type of transient can
16 cause a 2 million cubic foot building to pressurize and
17 depressurize that quickly?

18 MR. HAYNES: I thought we were talking about
19 the instrument.

20 WITNESS FREDERICK: That's why none of us
21 considered it plausible. It's impossible to do that.

22 MR. HAYNES: I wouldn't say it was impossible.
23 I thought it actually occurred.

24 WITNESS FREDERICK: Based on our training, it
25 was impossible. It was completely foreign. If you look back

rlp 6
LRW

1 through everybody's training and the FSAR and safety
2 analysis and the building construction, you will not see
3 a paragraph that projects that type of transient. Nor
4 will you see it in anybody's training as far as -- that is so
5 particularly foreign and unbelievable that it has absolutely
6 no significance. That's why nobody did anything about it
7 for two days.

8 MR. FRAMPTON: Would you say the same about the
9 in-core thermocouple readings?

10 WITNESS FREDERICK: Yes. Looking back on
11 them, they're very logical but at the time they were read
12 they make no sense.

13 MR. FRAMPTON: Would it be fair to say that at
14 the time these readings came off the wires that they were
15 so incredible that they weren't believed?

16 WITNESS FREDERICK: The engineer that took them
17 said they're garbage. They don't mean anything. Wait until
18 I tune these instruments and we will take some readings.

19 MR. HAYNES: Do you agree with that?

20 WITNESS ZEWE: Which part of the statement?

21 MR. HAYNES: That the fact that you had some
22 thermocouple temperatures there in the core that were high
23 and that you hadn't been trained for it, that therefore they
24 were unbelievable, the readings?

25 WITNESS ZEWE: Not totally, no. If the indications

rlp 7
LRW

1 off scale are high enough, I would hope in retrospect it
2 would have meant something more to me then. But I couldn't
3 say that it would have.

4 MR. HAYNES: I guess my question is, is the fact
5 it's not discussed in the FSAR or covered in the training,
6 does that make such indications on the instrumentation
7 unbelievable. therefore you would not consider them in
8 evaluation of an event?

9 WITNESS ZEWE: No, that isn't true.

10 WITNESS SCHEIMANN: I would have to say that
11 isn't necessarily true also.

12 WITNESS FREDERICK: I believe I said indecipherable
13 or meaningless, not meaning that they would be -- that they
14 should be purposely ignored just because you have never seen
15 it before. If you don't understand it, there is not much you
16 can do about it.

17 WITNESS FAUST: I don't know that it would have
18 changed what we did.

19 MR. HAYNES: I'm not saying it would. I'm
20 trying to understand why something that is not covered in
21 the training or in the FSAR, your perception of why it would
22 be meaningless to you.

23 WITNESS FAUST: I wasn't aware of the thermocouples,
24 for one thing. I'm not so sure even if I was aware of them
25 and -- hey, that's not right. If anybody would have

rlp 8
LRW
1 considered my saying it that significant.

2 WITNESS FREDERICK: Again, none of us were
3 presented with that thermocouple information. We were
4 presented with this information and obviously made no con-
5 clusion from it. I'm saying the reason I made no conclusion
6 from it, I was the one he stepped on by the way, that it
7 was absolutely meaningless because it tells you nothing. If
8 someone said to me that an explosion will cause an instantan-
9 eous spike like that, I would tend to disagree with that
10 anyway. I would expect to see the pressurizer dive slowly.

11 MR. HAYNES: I believe this pressure peak was
12 something like a 6-second duration from the time it started
13 until the time it came back down to pressure. Just a few
14 second.

15 WITNESS FREDERICK: If someone deciphered that from
16 that strip chart -- excellent work. Commendable.

17 (Laughter.)

18 WITNESS SCHEIMAN:: Especially since the darn
19 chart is only in 15-minute increments.

20 MR. HAYNES: Is this the only place pressure for
21 the containment is reported?

22 WITNESS FAUST: All we saw.

23 WITNESS SCHEIMANN: As far as I was concerned
24 was like this, that quick. Boom, it was there. Boom, it was
25 gone. It wasn't: "Hey, this is increasing," that type of

ace-ral Reporters, Inc.

rlp 9
LRW
1 thing.

2 MR. HAYNES: So your recollection is the spike
3 was much faster than a few seconds; is that correct?

4 WITNESS ZEWE: Yes. I'm convinced even that day,
5 I was convinced that it didn't go completely off scale high
6 and that it only recorded up to 28 pounds. I don't know
7 how high it got.

8 MR. FRAMPTON: What would off scale be in that
9 case?

10 WITNESS ZEWE: 60 pounds.

11 MR. FRAMPTON: Gentlemen, this has been a long
12 day. Thank you very much for your help and your cooperation.

13 As I said at the beginning, we had a chance to review
14 and we have available to us all of the transcripts of your
15 former interviews with I & E and your depositions taken by
16 the President's Commission. I would like to give each of you
17 a chance before we finish to bring up anything in addition
18 to the subjects that have been covered in those interviews
19 and in our questioning today. That is, are there subject
20 matters or areas that haven't really been gone into at all
21 in your previous interviews with I & E or the President's
22 Commission or today that you think are important to the
23 accident or important to the ramifications of the accident
24 or the lessons we ought to be learning from the accident
25 that really haven't been covered before that we ought to be

rlp 10
LRW

1 looking for? Are there any areas or subject matters that
2 haven't been touched that you think are pretty important?

3 I would start with Mr. Frederick.

4 WITNESS FREDERICK: Having been given the
5 opportunity to voice such comments before other committees, I
6 feel I have been properly verbose on that subject.

7 MR. FRAMPTON: Mr. Scheiamnn?

8 WITNESS SCHEIMANN: I kind of go along with
9 what he says.

10 MR. FRAMPTON: Mr. Zewe?

11 MR. ZEWE: I think the reason we are where we
12 are at now, and I'm looking at it more personally as the
13 company Met Ed goes, is that I think the undue press coverage
14 and media coverage has contributed to our situation right
15 now, which has certainly hurt the industry and hurt us and
16 hurt the people and certainly contributed to the effects of
17 the whole industry in general. I don't think enough has been
18 said and I don't know if enough could be said about the
19 media coverage and the very poor response that they have
20 shown and the disillusionment they have over the accident,
21 over covering the accident, the effects and the real detri-
22 mental effect that they had on the nation as a whole. I
23 think we could have gotten through this accident and
24 corrected it to sufficient magnitude so that it would not
25 endanger the public again, and we could go on from there, but

ce-...al Reporters, Inc.

rlp 11
LRW

1 I'm not sure if we can ever go on from here with the way the
2 media and press has really made a circus out of it. That
3 includes their tremendous influence and pressure certainly
4 influenced and pressured all the commissions we talked to at
5 every level, particularly when -- a fine example of that was
6 related to me very strongly by the subcommittee -- the Udall
7 Commission. This was related to me from Mr. Miller because
8 I was not involved in the public hearings with them. They
9 were very nice to us. We went there as a group. As soon as
10 they got the camera people there, they were totally different.
11 Totally vindictive was the word, and pointed. No longer
12 dealing with human beings. It was on another latitude.

13 I think I could see that same thing with the President's
14 Commission. I could see that same thing with members of the
15 NRC when they were trying to have the right light in
16 respect to the press coverage to show that they were good and
17 we were bad. I could not, being a member of Met Ed now, go
18 out to the public and say anything that they wouldn't totally
19 disbelieve and that wasn't because we didn't tell the truth.
20 I totally believe that.

21 I believe during the whole thing, and I was immediately
22 involved with an awful lot of the decisionmaking and some of
23 the related words that were put out by the company, and
24 totally tried to be honest. They got slaughtered for it.
25 When a Congressman tells a vice-president of the company who

Ace-Federal Reporters, Inc.

rlp 12
LRW

1 I felt acted very, very well that maybe everybody's too
2 defensive and that's why they took him apart, but to call
3 him a liar, that he lied, wilfully lied, is totally disrespect
4 for a human being. We can't say to a Congressman that you're
5 a liar, but they can certainly have any freedom of speech
6 they choose for whatever reason they want. It's a lot of
7 political soapboxing. I think we all realize that.

8 I don't know if we can overcome that, but it certainly
9 hurt everybody involved and certainly hasn't helped anything.
10 And that is only my subjective views. Some of it is very
11 objective, though, because it's cases that actually happened.
12 That's why I totally refuse to talk with any member of the
13 press. I have been contacted quite a bit. I make no
14 comments. Not that I didn't have comments or not that
15 I didn't think they could be constructive, but I would be
16 misquoted. I have relatives in the area here that have told
17 me that the reporter has gone down the street and asked five
18 or six different people things and passed six by until he
19 came to the seventh one with something derogatory to say or
20 something really enlightening and then the camera lights
21 were on and they had a story.

22 We didn't educate the people about nuclear power for
23 the last 25 years. It's a black box and they're using
24 that tactic to sell newspapers and the right stories. I
25 just wish something could be done to put the responsibility

1 on the press. I think they do have tremendous responsibility
2 and certainly are not living up to it. Even though I was
3 involved very heavily in the accident and some of the
4 decisions I made contributed to the accident, I feel I acted
5 more responsibly than they did.

6 MR. FRAMPTON: We appreciate your candor and
7 your comments. Mr. Faust?

8 WITNESS FAUST: I couldn't relate to that any
9 better.

10 MR. FRAMPTON: Gentlemen, thank you very much.
11 (Whereupon, at 7:02 p.m., the interview was adjourned.)

E 21
12

13

14

15

16

17

18

19

20

21

22

23

24

25